

AD718060


TECHNICAL REPORT NO.

10774

Army Vehicle Power System
and Load Study



Final Report
December 1970



by J. G. Nell

TACOM

Westinghouse Electric Corporation
Aerospace Electrical Division
Lima, Ohio


DAAE07-67-C-1563 Amendment II

VEHICULAR COMPONENTS & MATERIALS LABORATORY

U.S. ARMY TANK AUTOMOTIVE COMMAND Warren, Michigan

Distribution of this report is unlimited.

Reproduced by
NATIONAL TECHNICAL
INFORMATION SERVICE
Springfield, Va. 22151



BEST AVAILABLE COPY

54

Technical Report No. 10774

Army Vehicle Power System
and Load Study

Final Report

by

J. G. Nell

December 1970

Contract No. DAAE07-67-C-1563 Amendment II

Westinghouse Electric Corporation
Aerospace Electrical Division
Lima, Ohio

BEST AVAILABLE COPY

REPRODUCTION QUALITY NOTICE

This document is the best quality available. The copy furnished to DTIC contained pages that may have the following quality problems:

- **Pages smaller or larger than normal.**
- **Pages with background color or light colored printing.**
- **Pages with small type or poor printing; and or**
- **Pages with continuous tone material or color photographs.**

Due to various output media available these conditions may or may not cause poor legibility in the microfiche or hardcopy output you receive.

☐ **If this block is checked, the copy furnished to DTIC contained pages with color printing, that when reproduced in Black and White, may change detail of the original copy.**

SUMMARY

The study summarized in this report has compiled a band of power system data so that, given an electric power profile for an army vehicle, an optimum power system approach can be selected. The basis for the selection are four parameters; weight, volume, efficiency, and life cycle cost.

The major power system components included in the study were a gas turbine, fuel for a 24 hour and a 48 hour mission, a generator, a voltage regulator, system controls, and protection.

Three types of electric power were investigated; 28 volts d-c, 56 volts d-c and 115/200 volts, 3 phase, 400 Hz a-c.

The study indicates that the type of electric power selected should be a function of what is best for the loads since fuel weight is quite large compared with the other components. Also, a method of determining life cycle cost for a vehicle electric power system is described.

TABLE OF CONTENTS AND ILLUSTRATIONS

		PAGE
I	Contract Objectives and Guidelines	1
II	Load Analysis	2
	Figure 1 - Power Profile - Standby Mode	
	Figure 2 - Power Profile - Battlefield Day	
	Figure 3 - Power Profile - Normal Mode	
III	Power System Analysis	7
	Figure 4 - Total System Weight; 24 and 48 hour	
	Figure 5 - Total System Volume; 24 and 48 hour	
	Table 1 - Total Power System Weight and Volume Data	
	Figure 6 - Effect of Efficiency on Total Power System Weight	
	Table 2 - Total Power System Efficiency Data	
IV	Life Cycle Cost	8
	Figure 7 - Life Cycle Cost v.s. Power Output	
	Table 3 - Life Cycle Cost Analysis	
	Table 3A - Development of Unscheduled Maintenance Cost for Table 3	
V	Power System Components	14
	<u>Turbine Prime Movers</u>	14
	Figure 8 - Turbine and Fuel Weight; 24 hr., -65°F	
	Figure 9 - Turbine and Fuel Weight; 24 hr., +130°F	
	Figure 10 - Turbine and Fuel Weight; 48 hr., -65°F	
	Figure 11 - Turbine and Fuel Weight; 48 hr., +130°F	
	Figure 12 - Turbine and Fuel Volume; 24 hr., -65°F	
	Figure 13 - Turbine and Fuel Volume; 24 hr., +130°F	
	Figure 14 - Turbine and Fuel Volume; 48 hr., -65°F	
	Figure 15 - Turbine and Fuel Volume; 48 hr., +130°F	
	Table 4 - Turbine Weight and Volume Data	

PAGE

Generators

16

- Table 5 - Generator Requirements and Characteristics
- Table 6 - Rectifier Capability
- Table 7 - Output Rectifier Description
- Table 8 - Calculated Generator Data

Generator Control Unit

23

- Figure 14 - Logic Diagram; 28 volt GCU
- Figure 15 - Logic Diagram; 56 volt GCU
- Figure 16 - Logic Diagram; AC GCU

I. Contract Objectives and Guidelines

The purpose of the APU study program defined on Amendment II of Contract DA AE07-67C 1563 was to establish a method of systematic study for applying electric power to army vehicles.

The study indicated that power system application should be approached from two standpoints. First, the loads of the vehicle should be analyzed, grouped by usage with respect to operating mode, and arranged into power profiles for each operating mode. Second, different types of auxiliary power supplies should be investigated to determine characteristic data over a wide band of possible operating conditions and power output levels. The requirements defined by the power profiles determine the level of power and the type of power required. When the power level is established the following information can be derived from data generated by the power system analysis: weight, volume, efficiency, and life cycle cost.

As an example of the type of analysis required for application of power systems to army vehicles, the loads of the M60A1E2 were plotted in power profiles for each vehicle operating mode.

Also, power supply data was generated such that effects of power system weight volume, efficiency, and life-cycle cost could be evaluated for different mission times and different output power levels.

The prime mover for all the systems was a gas turbine engine. Types of electrical power considered were 28 volt dc, 56 volt dc, and 115/200 volt 3 phase, 400 Hz ac.

II Load Analysis

Information about M60A1E2 tank loads was obtained from Chrysler Corporation, Defense Engineering, drawings and from discussions with vehicle users at the Armor Agency, Combat Development Command (CDC), Fort Knox, Kentucky. The major loads on the M60A1E2 are listed on Chrysler drawing 11591511. This drawing, a schematic of the turret and cupola, identifies each load by a designator. The designators can be associated with part numbers on the interconnecting wiring diagram 11607959. Knowledge of the part numbers gives access to the product specifications for each part number.

Only a few of these product specifications were made available for this study; however, enough were available to establish the general guidelines for the loads.

Load data was not available in sufficient detail to engage a comprehensive load analysis. Power profiles for the M60A1E2 were formulated from the data obtained on the product specifications and from CDC. Profiles have been drawn for the normal, standby, and battlefield day operating modes.

ATAC defined the operating modes for the M60A1E2 as:

Normal	Gun tied down, driving vehicle
Standby	Ready for action but not in action. Alert condition.
Battlefield Day	Silent watch included; vehicle in action. For the M60A1E2, the battlefield day can be broken down as follows:

24 Hour Stated

40% Idling
40% Cross-Country from 2-1/2 to
10 MPH
20% Secondary Roads at 15-20 MPH

24 Hour Interpretation

(Equivalent 18-25 miles wear)
(Approximately 37.5 odometer
Miles)
(Approximately 37.5 odometer miles)

Comparatively, the 24 hour version can be expressed as the equivalent of approximately 93-100 miles of wear on the vehicle or 75 odometer miles.

48 Hour Stated

48 Hour Interpretation

32 hours intensified

40% Idling

(Equivalent 25-35 miles engine wear)

40% Cross-Country 2-1/2 to
maximum safe

(Approximately 50 odometer miles)

20% Secondary Roads at 15
to maximum safe

(Approximately 50 odometer miles)

16 Hours Minimized

At least 12 hours light time
operation of components
to maintain operational
readiness.

(Equivalent to 10-15 miles of
engine wear)

Comparatively, the 48 hour version can be expressed as the equivalent of approximately 150 miles of wear on the vehicle or 100 odometer miles.

The loads are listed and identified on the following pages. The power profiles for the three operating modes follow the list of loads (figures 1, 2, and 3). These profiles indicate that a 28 volt dc system (battery-generator) rated at 300 amperes with a three per-unit short-time overload rating will be adequate for the present M60 vehicle. Selection of this rating was based on the most severe profile, the battle field day. Continuous loads were between 300 and 325 amperes with pulsed loads adding 25 amperes to the continuous loads. The hydraulic pump operation is the most severe of any load; adding 600 amperes for 5 to 10 seconds. This would be serviced by the generator overload capacity and the battery.


Battery charging was not added into the power profiles because of the irregularity of the amount of amperes required for battery charging. With a normally charged battery short periods of high current will be experienced immediately after start-up, especially after resumption of engine operation after a silent watch period or a long idle period; and after any operation of the hydraulic pump. The battery should be used, as a voltage source, in these high current instances, to assist the system voltage regulator. Current limiting the generator output may be required to limit peak load and battery charging currents to a level safe for the rectifier.

Xenon Searchlight	-	Consumes 2.2 kw continuously and operates in two modes:
White Light	-	observation while driving in standby, normal, or battlefield-day modes.
Infrared	-	observation during silent watch.
Grenade Launcher	-	Launch igniter; consists of a small solenoid pulse of about 12 amperes. Used in battlefield-day mode.
Breech Motor	-	Used in large gun/missile launcher to open and close breech - battlefield day.
Scavenging System	-	A compressor which provides a blast of air to clear the breech of unconsumed cartridge material. Used after firing during battlefield-day.
Master Relay	-	Continuous operation during vehicle operation. All modes.
Radio-Receive and Transmit	-	Used during all modes.
Batteries	-	Used for startup and during silent watch. Could possibly reduce number of batteries if silent APU is applied.
Dome Lamp	-	Used full time.
Blasting Machine	-	Manual backup for electric igniter. No requirement electric power.
Transmitter Door	-	Used during day or night firing.
Grenade Launcher Power Supply	-	D-C to D-C Converter

Firing Probe	-	Consumes no electric power
Cupola	-	Used during all modes
Passive Night Vision	-	D-C to D-C converter consumes 96 watts during all three modes at night.
Turret	-	Used when firing, during search, and for target acquisition. Necessary for standby, normal and battlefield-day operation.
Blower Assembly	-	Heater-blower used when environment dictates.
Amplifier	-	Both turret and cupola. Search, target acquisition, and firing aid; used for stabilization during battlefield day, standby, and normal modes.
CBR (Chemical, Biological, Radiation)	-	These are continuous loads. The air from these may be heated by operating the blower assembly when environmental condition dictates.
Gyro	-	Search, target acquisition and firing aid used for stabilization during battlefield-day, standby and normal modes.
Rate Sensor	-	Same as Gyro and amplifier above.
Laser Range Finder	-	Consumes 500 watts average during battlefield-day, standby and normal modes.
Optical Tracker	-	Used for following missile after firing - battlefield-day.
Infrared Transmitter	-	Used in conjunction with tracker to communicate with missile. Two operating modes - standby and battlefield-day.
Modulator and Signal Data Converter	-	Operational link between optical tracker and transmitter. Battlefield-day and standby.

- Intercom Set - Consumes 2 amperes when in use. Unit on standby (no current drain) whenever vehicle in operation.
- Frequency Control - Consumes no appreciable electric power.
- Antenna Matching Unit - Stepping relay used when changing frequency. Used any time during all modes.
- Receiver/Transmitter - Receiver consumes 80 watts. Receiver and transmitter combination consumes 300 watts. Used any time during all modes except minimum transmit during silent watch.

WESTINGHOUSE ELECTRIC CORPORATION





III Power System Analysis

The systems considered in this study are to be applied as self-powered units for mounting outside the vehicle. The systems include the gas turbine, the generator, the voltage regulator, controls, and protection. Fuel weight is also considered for the different system concepts; however, the tankage, since its characteristics are so dependent on individual vehicle constraints, is not included.

Power systems have been investigated at four ratings which will give a band of data that would hopefully encompass both present and future vehicle needs. The ratings are 10 kw, 25 kw, 40 kw, and 60 kw. Three types of systems have been considered, the standard 28 volt brushless d-c system, a three-wire 56 volt d-c system and a 400 Hz, 3 phase 120/208 volt a-c system.

The desirability of the different power systems are compared over the load range with respect to weight, volume, efficiency, and life-cycle cost. More detailed discussions of the equipment studied follows under the appropriate subheadings later in the report. Please note, however, that data presented was not intended to be firm for quotation purposes but was derived more to show relative differences in power system characteristics.

Power system weight and volume data are plotted on Figures 4 and 5, respectively. Supporting data are shown on Table 1 which follows the curves. The turbine and fuel weight analysis, and the electrical component weights are given in Section V. The lightest turbine-fuel combination was used as turbine data on the power system curves. This way the lightest and smallest system over the load range is shown on the system weight curves.

The data is plotted over a temperature range of -65°F to $+130^{\circ}\text{F}$; a 24 hour mission and a 48 hour mission; and a power output range of 10 kw to 60 kw. Although calculations were made for a-c and d-c systems the differences in weight and volume of these two systems were overwhelmed by the fuel weight making the decision of what type of power is best, a decision of what is best for the loads inside the vehicle.

The effects of system efficiency versus power output and type of system is shown on Figure 6 and Table 2. Whereas the total system weights and volumes are plotted at a constant electrical system efficiency of 75%, efficiency curves utilized the generator efficiency predictions on Table 8 in the generator data section of this report. The curves show the a-c system to provide a small weight advantage mostly due to the improved fuel consumption rate made possible by the lower power demand of the more efficient systems.

IV Life Cycle Cost

The cost and reliability evaluation will be combined into a cost effectiveness concept defined as availability. This section explains the derivation of the life cycle cost used in this study.

The life cycle cost of a component of a larger system equals the total dollar value of procuring, maintaining, operating, and replacing that component. The object is to develop a dollar cost per hour for each component. This cost would include labor, material, training, spares administration, technical data, tools, test equipment, and original procurement.

Costs occurring during the life cycle of system components can be divided into four groups:


1. Scheduled Maintenance Costs

Includes parts, materials, and labor costs. Scheduled maintenance costs are a function of the mean-time-between-maintenance and the degree of difficulty of the scheduled maintenance; or, the mean scheduled maintenance down time.

2. Failure or Unscheduled Maintenance Cost

Parts, materials, and labor costs. Failure maintenance cost is a function of mean-time-between-failure and the mean failure maintenance down time.

TOTAL POWER SYSTEM (APU) WEIGHT VS ELECTRICAL POWER OUTPUT



24 HOUR MISSION ○

48 HOUR MISSION □


SIGNATURE

DATE

FIGURE NO

FIGURE 4

TERMINAL POWER SYSTEM (APU) VOLUME VS ELECTRICAL POWER OUTPUT



24 HOUR MISSION ○

48 HOUR MISSION □

SIGNATURE

DATE


FIGURE 5

TABLE 1

TOTAL POWER SYSTEM WEIGHT AND VOLUME DATA

KW Power Output	Lightest Turbine & Fuel	Mission Time Temp.	Weight Turbine & Fuel	Weight Elect. ac/28v/56v dc dc	Total Weight (Pounds) ac/28v/56v dc dc	Volume Turbine & Fuel	Volume Elect. ac/28v/56v dc dc	(Cubic Feet) Total Volume ac/28v/56v dc dc
10	T1	24 - 65	1409	39/ 40/ 43	1448/1449/1452	30.4	.26/.41/.41	30.7/30.8/30.8
	T1	48 - 65	2729	39/ 40/ 43	2768/2769/2772	58.0	↓	58.3/58.4/58.4
	T2	24 +130	1237	↓	1276/1277/1280	27.5	↓	27.8/27.9/27.9
	T2	48 +130	2389	↓	2428/2429/2432	51.7	↓	52 /52.1/52.1
25	T1	24 - 65	1865	49/ 56/ 57	1914/1921/1922	39.9	.30/.44/.44	40.2/40.3/40.3
	T1	48 - 65	3641	↓	3690/3697/3698	72.2	↓	72.5/72.6/72.6
	T2	24 +130	1669	↓	1718/1725/1726	36.6	↓	36.9/37 /37
	T2	48 +130	3253	↓	3202/3309/3310	69.8	↓	70.1/70.2/70.2
40	T2	24 - 65	2317	58/ 66/ 67	2375/2383/2384	50.3	.32/.48/.48	50.6/50.8/50.8
	T2	48 - 65	4549	↓	4607/4615/4616	96.7	↓	97 /97.2/97.2
	T2	24 +130	2197	↓	2255/2263/2264	47.4	↓	47.7/47.9/47.9
	T2	48 +130	4309	↓	4367/4375/4376	91.7	↓	92 /92.2/92.2
60	T3	24 - 65	3048	69/ 85/ 86	3117/3133/3134	64.3	.34/.73/.73	64.6/65 /65
	T3	48 - 65	5952	↓	6021/6037/6038	125.3	↓	125.6/126 /126
	T3	24 +130	2796	↓	2865/2881/2882	62.8	↓	63.1/63.5/63.5
	T3	48 +130	5808	↓	5877/5893/5894	122.3	↓	122.6/123 /123

SYSTEM WEIGHT
VS
POWER OUTPUT LEVEL
CONSIDERING
THE EFFECT OF GENERATOR
EFFICIENCY.



UPPER CURVE OF EACH GROUP - DC SYSTEMS 28V & 56V.

LOWER CURVE - AC SYSTEM - 115/200, 400 HZ.

--- 24 HOUR MISSION

○ 48 HOUR MISSION

SIGNATURE

DATE

FIGURE 6

TABLE 2

SYSTEM EFFICIENCY DATA

KW	Turbine	Mission Time	Elect. System	-65°F HP	Fuel Weight	Fixed Weight Elect. & Turb. Total Tu. El.	Total System Wt.
10	T4	24	ac	19 Regd	2260	134	2394
		24	dc	22	2300	127	2427
		48	ac	19	4520	134	4654
		48	dc	22	4600	127	4727
10	T2	24	ac	19	1390	124	1514
		24	dc	22	1440	127	1567
		48	ac	19	2780	124	2904
		48	dc	22	2880	127	3007
10	T1	24	ac	19	1320	128	1448
		24	dc	22	1370	131	1501
		48	ac	19	2640	128	2768
		48	dc	22	2740	131	2871
10	T3	24	ac	19	1680	183	1763
		24	dc	22	1730	186	1916
		48	ac	19	3360	183	3543
		48	dc	22	3460	186	3646
25	T1	24	ac	40	1620	138	1758
		24	dc	43	1660	146	1806
		48	ac	40	3240	138	3378
		48	dc	43	3320	146	3466
25	T2	24	ac	40	1630	134	1764
		24	dc	43	1680	142	1822
		48	ac	40	3200	134	3394
		48	dc	43	3360	142	3502

TABLE 2

SYSTEM EFFICIENCY DATA

kW	Turbine	Mission Time	Elect. System	-65°F #/Hr.		Fuel Weight	Fixed Weight Elect. & Turb.		Total System Wt.
				Reqd HP			Total	Tu. El.	
25	T3	24	ac	40	79	1900	193	144	2093
		24	dc	43	81	1940	201	↓	2141
		48	ac	40	79	3800	193	49	3993
		48	dc	43	81	3880	201	57	4081
40	T2	24	ac	65	84	2020	143	85	2163
		24	dc	70	86	2060	152	↓	2212
		48	ac	65	84	4040	143	58	4183
		48	dc	70	86	4120	152	67	4272
40	T3	24	ac	65	91	2180	202	144	2382
		24	dc	70	95	2280	211	↓	2491
		48	ac	65	91	4360	202	58	4562
		48	dc	70	95	4560	211	67	4771
60	T3	24	ac	94	107	2570	213	144	2783
		24	dc	100	110	2640	230	↓	2870
		48	ac	94	107	5140	213	69	5353
		48	dc	100	110	5280	230	86	5510

3. Procurement Costs

The dollar cost of equipment procurement.

4. Operating Costs

Cost to operate equipment i.e. fuel costs: For this evaluation operating costs are neglected. The components in question do not use fuel directly and the relative power consumption should be studied as part of a total vehicle weight-efficiency-mission time optimization. The life cycle cost will be defined as:

$$\begin{aligned}\text{Life Cycle Cost} &= \text{Scheduled Maintenance Cost} \\ &+ \text{Unscheduled Maintenance Cost} \\ &+ \text{Procurement Cost}\end{aligned}$$

Determination of Maintenance Costs - Maintainability & Availability

To state maintenance costs accurately, there must be a value assigned to the maintenance actions which permits a prediction of the frequency of maintenance required and the duration of a maintenance action. The concepts of maintainability and availability provide techniques to do this.

Academically, maintainability is the probability that a device will be restored to operational effectiveness within a given period of time when the maintenance action is performed in accordance with prescribed procedures. Mathematically, maintainability, M, may be expressed in terms of the mean-time-to-repair, MTTR, and the allowable maintenance time constraint, t:

$$M = 1 - e^{-\left(\frac{t}{MTTR}\right)}$$

This equation shows that the longer the time constraint or the shorter the mean-time-to-repair, the greater the maintainability will be.

Equipment availability is the probability that a stated percent of equipment or missions will provide adequate performance during a mission with no down-time interval exceeding the maintenance time constraint, t. Good availability can be achieved in two ways: (1) Increase reliability and reduce the probability of failure; and/or (2) Design equipment for rapid maintenance. Thus,

$$\text{Availability} = \text{Probability of survival} + \text{maintainability}.$$

This concept of availability is basically a reliability concept in that it is tied to a mission time constraint. That is, it is a probability of survival through a mission time with no failure requiring more time than t hours to repair.

There is another measure of availability which is commonly applied to continuously operable maintained systems. This is called the up-time ratio or time availability. The up-time ratio consists of a steady state component and a transient component. The steady state is merely the ratio of the up, or operable, time to the sum of the up and down time. If the mean-time-between-failure is the up time and mean-time-to-repair the down time, the steady state equation for the up-time ratio is:

$$\text{UTR} = \frac{\text{MTBF}}{\text{MTBF} + \text{MTTR}} = 1 - \text{down time ratio} = 1 - \text{DTR}$$

$$\text{DTR} = \frac{\text{MTTR}}{\text{MTTR} + \text{MTBF}}$$

At the beginning of a mission it is obvious that the probability of an equipment operating at the end of the mission is higher at the beginning of an equipment's life than at the end. It can be shown that the complete expression for the UTR is*:

$$\text{UTR} = \frac{u}{\lambda + u} + \frac{\lambda}{T(\lambda + u)^2} - \frac{\lambda}{T(\lambda + u)^2} \exp \left[-(\lambda + u)T \right]$$

where

T = mission time

$\lambda = \frac{1}{\text{MTBF}}$ = failure rate (failure/hour)

$u = \frac{1}{\text{MTTR}}$ = maintenance action rate (action/hour)

*R. E. Barlow, L. C. Hunter; Mathematical Models For Systems Reliability; The Sylvania Technologist; Vol. 13, January 1960.

As T approaches infinity the transient state disappears and the equation reduces to the steady-state component.

For this analysis the mission time, T, will be assumed to be the time until scheduled maintenance. Since the time until scheduled maintenance is almost as long as the total vehicle life, the transient portion of the UTR equation will be neglected.* For this study then, the availability, hence the unscheduled maintenance cost of equipment will be defined by $1 - \text{UTR}$ or:

$$\text{DTR} = \frac{\text{MTTR}}{\text{MTTR} + \text{MTBF}}$$

The percentage of the mission time which the equipment is estimated to be down will be multiplied by the maintenance hourly costs to find the unscheduled maintenance cost portion of life cycle cost. Figure 7 and Tables 3 and 3A on the following pages present the life cycle cost data for this study.

*With a T of 3000 hours, an MTBF of 300 hours and an MTTR of 50 hours the steady state component calculates to be .87 and the transient component calculates to .002.

Table 3 and 3A depict the development of the cost numbers plotted on Figure 7. Explanation of the life cycle cost calculation process used will be by defining the make-up of each column.

System - Three systems were considered at each power level; an a-c system, a 56 volt d-c system, and a 28 volt d-c system.

Original Cost - The estimated procurement costs for each system component are listed to get comparative system costs. These costs were not intended to be firm selling prices but relative comparisons between systems. Quantities greater than 1000 units were assumed.

Scheduled Maintenance Cost - Essentially these are based on overhaul costs. Vehicle usage was based on the assumption that tank life is approximately 6 years and it is utilized at the rate of 2000 miles/year or 200 hours per year. Although system mean-time-between-overhauls are 3000 hours, it was assumed that the tank would be completely overhauled at the end of the third year.

Compounded Scheduled Maintenance - The cost of overhaul was compounded at the rate of 3-1/2%/year to conservatively account for inflation. In making the future expenditure calculations it was further assumed that there will be no cost of capital or alternative uses for funds considered. Thus the value of a dollar today equals the value of a dollar next year plus an inflation rate of 3-1/2%.

Maintenance Rate per Hour - This was assumed to be \$10 per hour.


Unscheduled Maintenance Cost - These are derived on Table 3A explained below.

LIFE CYCLE COST

V8

POWER OUTPUT

(BASED ON USE OF LIGHTEST & SMALLEST TURBINE + FUEL COMBINATION AT RESPECTIVE POWER LEVEL)



LOWER CURVE GROUP - ORIGINAL COST (PRESENT)

UPPER CURVE GROUP - ORIG. COST + MAINT. COST COMPOUNDED AT 3.5%/YR

TABLE 3

LIFE CYCLE COST ANALYSIS (USEFUL LIFE 6 YEARS)

System	Orig. Cost	Sch. Maint. Cost	Compounded Scheduled Maint.	Maint. Rate/Hr.	Unsched Maint. Cost 1 Yr.	Total Unsched Maint. 6 Yr.	Compounded Total Maint.	Total Cost
10 KW								
Generator, 28 vdc	\$1,550	\$ 500						
GCU	503	-						
Turbine	6,000	1,600	\$ 2,411	\$ 10	\$ 290.78	\$2,261	\$ 4,672	\$12,725
	<u>\$8,053</u>	<u>\$ 2,100</u>						
Generator, 56 vdc	\$1,580	\$ 500						
GCU	606	-						
Turbine	6,000	1,600	\$ 2,411	\$ 10	\$ 289.24	\$2,250	\$ 4,661	\$12,847
	<u>\$8,186</u>	<u>\$ 2,100</u>						
Generator, ac	\$1,200	\$ 500						
GCU	742	-						
Turbine	6,000	1,600	\$ 2,411	\$ 10	\$ 290.68	\$2,260	\$ 4,671	\$12,613
	<u>\$7,942</u>	<u>\$ 2,100</u>						
25 KW								
Generator, 28 vdc	\$1,930	\$ 500						
GCU	503	-						
Turbine	6,000	1,600	\$ 2,411	\$ 10	\$ 290.86	\$2,263	\$ 4,674	\$13,107
	<u>\$8,433</u>	<u>\$ 2,100</u>						
Generator, 56 vdc	\$1,970	\$ 500						
GCU	606	-						
Turbine	6,000	1,600	\$ 2,411	\$ 10	\$ 290.94	\$2,263	\$ 4,674	\$13,250
	<u>\$8,576</u>	<u>\$ 2,100</u>						
Generator, ac	\$1,220	\$ 500						
GCU	742	-						
Turbine	6,000	1,600	\$ 2,411	\$ 10	\$ 290.68	\$2,260	\$ 4,671	\$12,633
	<u>\$7,962</u>	<u>\$ 2,100</u>						

TABLE 3

LIFE CYCLE COST ANALYSIS (USEFUL LIFE 6 YEARS)

System	Orig. Cost	Sch. Maint. Cost	Compounded Scheduled Maint.	Maint. Rate/Hr.	Unsched. Maint. Cost	Total Unsched. Maint.	Compounded Total Maint.	Total Cost
40 KW Generator, 28 vdc GCU Turbine	\$2,320 503 6,000 <u>\$8,823</u>	\$ 500 - 1,600 <u>\$2,100</u>	\$ 2,411	\$ 10	\$ 290.82	\$2,262	\$ 4,673	\$13,496
Generator, 56 vdc GCU Turbine	\$2,370 606 6,000 <u>\$8,976</u>	\$ 500 - 1,600 <u>\$2,100</u>	\$ 2,411	\$ 10	\$290.90	\$2,263	\$ 4,674	\$13,650
Generator, ac GCU Turbine	\$1,240 742 6,000 <u>\$7,982</u>	\$ 500 - 1,600 <u>\$2,100</u>	\$ 2,411	\$ 10	\$ 290.68	\$2,260	\$ 4,671	\$12,653
60 KW Generator, 28 vdc GCU Turbine	\$2,720 503 12,000 <u>\$15,223</u>	\$ 500 - 11,600 <u>\$2,100</u>	\$ 2,411	\$ 10	\$ 290.90	\$2,263	\$ 4,674	\$19,897
Generator, 56 vdc GCU Turbine	\$2,780 606 12,000 <u>\$15,386</u>	\$ 500 - 1,600 <u>\$2,100</u>	\$ 2,411	\$ 10	\$ 290.98	\$2,264	\$ 4,675	\$20,061
Generator, ac GCU Turbine	\$ 1,270 742 12,000 <u>\$14,012</u>	\$ 500 - 1,600 <u>\$2,100</u>	\$ 2,411	\$ 10	\$ 290.68	\$2,260	\$ 4,671	\$18,683

TABLE 3A

DEVELOPMENT OF UNSCHEDULED MAINTENANCE COST FOR TABLE 3

MTBF	MTTR	MTBF & MTTR	UTR	DTR	Yearly Hrs. Maint. x \$10/Hr.
11,520 31,400 300	10 4 51	11,530 31,404 351	.99913 .99987 .85547 <u>.85461</u>	.14539	\$290.78
11,200 23,300 300	10 4 51	11,210 23,304 351	.99911 .99983 .85547 <u>.85538</u>	.14462	\$289.24
12,240 18,700 300	9 4 51	12,249 18,704 351	.99926 .99979 .85547 <u>.85466</u>	.14534	\$290.68
10,880 31,400 300	10 4 51	10,890 31,404 351	.99908 .99987 .85547 <u>.85457</u>	.14543	\$290.86
10,800 23,300 300	10 4 51	10,810 23,304 351	.99907 .99983 .85547 <u>.85453</u>	.14547	\$290.94
12,240 18,700 300	9 4 51	12,249 18,704 351	.99926 .99979 .85547 <u>.85466</u>	.14534	\$290.6

TABLE 3A.

DEVELOPMENT OF UNSCHEDULED MAINTENANCE COST FOR TABLE 3

MTBF	MTTR	MTBF & MTTR	UTR	DTR	Yearly Hrs. Maint. x \$10/Hr.
11,040	10	11,050	.99910		
31,400	4	31,404	.99987		
300	51	351	.85547	.14541	\$290.82
			<u>.85459</u>		
11,040	10	11,050	.99910		
23,300	4	23,304	.99983		
300	51	351	.85547	.14545	\$290.90
			<u>.85455</u>		
12,240	9	12,249	.99926		
18,700	4	18,704	.99979		
300	51	351	.85547	.14534	\$290.66
			<u>.85466</u>		
10,560	10	10,570	.99905		
31,400	4	31,404	.99987		
300	51	351	.85547	.14545	\$290.90
			<u>.85455</u>		
10,560	10	10,570	.99905		
23,300	4	23,304	.99983		
300	51	351	.85547	.14549	\$290.98
			<u>.85451</u>		
12,240	9	12,249	.99926		
18,700	4	18,704	.99979		
300	51	351	.85547	.14534	\$290.68
			<u>.85466</u>		

Total Unscheduled Maintenance Expense - These are based on a useful life of 6 years for the M60A1E2. Unscheduled maintenance is compounded at 3-1/2% per year for 6 years. Essentially this is the present cost of unscheduled maintenance.

Compounded Total Maintenance - This is the sum of compounded scheduled maintenance and compounded unscheduled maintenance. This is the present value of maintenance.

Total Cost - The sum of original cost plus present value of maintenance expense. Total cost is plotted as an ordinate of Figure 7.

Table 3A on which the annual costs of unscheduled maintenance are determined, is described below:

The up-time rates for each component is determined so that system availability can be calculated.

$$A = (\text{UTR Gen}) (\text{UTR GCU}) (\text{UTR Turbine})$$

$$1-A = \text{DTR System}$$

MTBF - The MTBF for each system component is listed. The turbine MTBF includes all other auxiliary components and controls except the generator and the generator control unit. These are predicted achieved MTBF's.

MTTR - Based on field experience.

UTR - Product of three component UTR's.

DTR - 1 - System UTR.

Yearly Hours of Maintenance - 200 hours usage per year times the DTR times \$10.00/hr maintenance labor cost.

V Power System Components

Information for the following presentations are based on data from the component manufacturers. The turbine data were calculated from information supplied by the AiResearch Manufacturing Company, Phoenix, Arizona; and Solar, San Diego, California. Electric component data were generated by Westinghouse at the Aerospace Electrical Division, in Lima, Ohio.

Turbine Prime Mover

Westinghouse has assembled information on engine-fuel systems which will be applicable to any vehicle presently or within 2 years. Conditions which were established for operating the turbine are:

- Duty Cycle: Continuous, 3-4 starts per day.
- General Environmental Rest Requirements - Climatic conditions per MIL-STD-210A and MIL-STD-810A.
- Output Pad - One pad for spline-driven generator.
- Power Profile - 1.0 per unit continuous load with 1.5 per unit load occurring for 5 minutes once every hour. (This is a simplification of the power profiles and turbine load is shared with the battery load.)

Two gas turbine manufacturers were especially helpful by supplying necessary parametric data and supporting information. The engines appearing most suited for this type of application are:

	20 HP	50 HP	80 HP	120 HP
Rating	10 KW	25 KW	40 KW	60 KW

Manufacturers:

AiResearch	GTP30-67	GTCP30-92	GTP30-106	GTP36-60
Solar	T-62T-33	T-62T-33	T-62T-32	T-62T-32

Since the comparison of different manufacturers' turbines is not an objective of this contract, Westinghouse will define a standard-composite turbine for each rating studied. Turbine information is based on equipment that is fully developed and in production. These turbines will be directly applicable as prime movers for vehicle ground power in the 10 kw to 60 kw range.

The turbine output speed will be a function of the turbine gearbox. Since output speeds up to direct drive can be easily accommodated, and since the generator operates best at 12, 000 RPM, a 12,000 RPM gearbox is assumed.

All of the engines are simple-cycle, single-shaft gas turbines.

By-products are available from these turbines. Briefly these are: clean compressed air, auxiliary shaft power, and hot gases.

Typically, small gas turbine engines do not require any maintenance for operational periods of up to 250-300 hours. At this time it is normal to replace filters, check the ignition system, oil level, etc. Depending on the application, lube oil may be replaced at the 300 hour point or at about 1000 hours. Except for these maintenance items, turbine engines are generally operated on an "on-condition" basis.

Gas Turbine Application Data

Figures are plots of turbine and fuel, weights and volumes over the load range and temperature range anticipated. The data is plotted for two profiles, one for 24 hours and the other for 48 hours.

The curves show plots of various available turbine ratings identified only by T1, T2, T3, and T4. The dry weight of individual turbines was combined with the fuel consumption at -65°F or $+130^{\circ}\text{F}$ and for the 24 or 48 hour profile. A generator efficiency of 75% was used for all calculations.

The fuel volume was calculated by determining the average of the specific gravities of gasoline and kerosene. This figure was 6.4 pounds per cubic foot. The turbine volumes were estimated from envelope drawings supplied by the turbine manufacturers.

Generators

Generators for the following three types of systems were investigated:

1. 120/208 volt, 400 Hz, 3 phase, 4 wire system
2. 28 volt d-c, 2 wire system
3. 56 volt d-c, 3 wire system


For each type of system, data on 10 kw, 25 kw, 40 kw, and 60 kw rated generators was calculated. The generator requirements and characteristics which form the basis upon which this study was conducted are shown in Table 3.

The electrical portion of all the generators in this study consists of a main machine from which the output power is obtained, an exciter which supplies power to the rotor of the main machine, a rotating rectifier assembly which converts the exciter output to d-c, and a permanent magnet generator for supplying control and excitation power. In the case of the d-c machines, a three-phase, full-wave stationary rectifier assembly is included to rectify the output of the main machine to d-c. The main machine is of the salient-pole, synchronous design.


The output diode rating for the d-c machines was established on the basis that the rectifier assembly must be capable of carrying 3.0 per unit short circuit current while operating at a diode case temperature of 160°C (30°C over the maximum oil inlet temperature of 130°C). Available diode ratings considered and their current carrying capability at 160°C are shown in Table 4. The number of diodes and diode rating required for each d-c machine in this study are presented in Table 5 along with other data pertinent to rectifier selection.

The electrical components are housed in an aluminum casting. The rotor is supported at each end by oil lubricated bearings.

Generator weight and size reductions were accomplished through the use of spray oil cooling. Spray oil cooling, a relatively new concept in cooling generators, is more effective at removing heat from the generator windings than other methods such as air cooling or oil cooling through conduction. Spray cooling permits higher current densities, reduced diameters, and, therefore, weight and size reductions. In a spray oil cooled generator, oil is sprayed directly on the generator windings through nozzles that are specially designed so that proper atomization of the oil can be obtained to



VARIOUS TURBINE + FUEL WEIGHTS VS POWER OUTPUT



24 HR
 1130 HP


SIGNATURE-

DATE

SHEET NO

FIGURE 9

VARIOUS TURBINE + FUEL WEIGHTS VS POWER OUTPUT



ABNR
- 6574

SIGNATURE

DATE

FIGURE 10

VARIOUS TURBINE + FUEL WEIGHTS VS POWER OUTPUT






FIGURE 11



SIGNATURE

DATE


GRAPH NO. **FIGURE 12**



SIGNATURE

FIGURE 13

VARIOUS TURBINE FUEL VOLUMES
VS
POWER OUTPUT



SIGNATURE

DATE

FIGURE 14

VARIOUS TURBINE + FUEL VOLUMES VS POWER OUTPUT




TABLE 4

TURBINE WEIGHT & VOLUME DATA

HP	Turbine	Mission Time	Temp. °F.	#/Hr.	Fuel Weight	Total Weight	Tot. Vol. Ft. 3	Fuel Vol. Ft. 3	Tot. Vol. Ft. 3
20	T4 85 Pounds	24	- 65	95	2280	2365	2.8	47.9	50.7
		48	- 65	95	4560	4645	2.8	95.8	98.6
		24	+130	72	1728	1813	2.8	36.3	39.1
		48	+130	72	3456	3541	2.8	72.6	75.4
20	T2 85 Pounds	24	- 65	57	1368	1453	3.3	28.7	32.0
		48	- 65	57	2736	2821	3.3	57.5	60.8
		24	+130	48	1152	1237	3.3	24.2	27.5
		48	+130	48	2304	2389	3.3	48.4	51.7
20	T1 89 Pounds	24	- 65	55	1320	1409	2.6	27.8	30.4
		48	- 65	55	2640	2729	2.6	55.4	58.0
		24	+130	50	1200	1289	2.6	25.2	27.8
		48	+130	50	2400	2489	2.6	50.4	53.0
20	T3 144 Pounds	24	- 65	70	1680	1824	3.3	35.3	38.6
		48	- 65	70	3360	3504	3.3	70.6	73.9
		24	+130	58	1392	1536	3.3	29.2	32.5
		48	+130	58	2784	2928	3.3	58.5	61.8
50	T1 89 Pounds	24	- 65	74	1776	1865	2.6	37.3	39.9
		48	- 65	74	3552	3641	2.6	74.6	77.2
		24	+130	78	1872	1961	2.6	39.3	41.9
		48	+130	78	3744	3833	2.6	78.6	81.2
50	T2 85 Pounds	24	- 65	75	1800	1885	3.3	37.8	41.1
		48	- 65	75	3600	3685	3.3	75.6	78.9
		24	+130	66	1584	1669	3.3	33.3	36.6
		48	+130	66	3168	3253	3.3	66.5	69.8

TABLE 4

TURBINE WEIGHT & VOLUME DATA

HP	Turbine	Mission Time	Temp. °F	#/Hr.	Fuel Weight	Total Weight	Tot. Vol. Ft. 3	Fuel Vol. Ft. 3	Tot. Vol. Ft. 3
50	T3 144 Pounds	24	- 65	84	2016	2160	3.3	42.3	45.6
		48	- 65	84	4032	4176	3.3	84.7	88.0
		24	+130	74	1776	1920	3.3	37.3	40.6
		48	+130	74	3552	3696	3.3	74.6	77.9
80	T2 85 Pounds	24	- 65	93	2232	2317	3.0	47.3	50.3
		48	- 65	93	4464	4549	3.0	93.7	96.7
		24	+130	88	2112	2197	3.0	44.4	47.4
		48	+130	88	4224	4309	3.0	88.7	91.7
80	T3 144 Pounds	24	- 65	99	2376	2520	3.3	49.9	53.2
		48	- 65	99	4752	4896	3.3	99.8	103.1
		24	+130	92	2208	2352	3.3	46.4	49.7
		48	+130	92	4416	4560	3.3	92.8	96.1
120	T3 144 Pounds	24	- 65	121	2904	3048	3.3	61	64.3
		48	- 65	121	5808	5952	3.3	122	125.3
		24	+130	118	2832	2976	3.3	59.5	62.8
		48	+130	118	5664	5808	3.3	119	122.3

prevent winding insulation erosion and to obtain the proper oil velocity over the coils. The surface temperature of the windings is held to below 200°C to prevent oil coking on the windings. A sump pump must be provided to remove the spray oil and oil leakage. For the d-c machines in this study, a combination of spray and conduction cooling is used in the area of the output rectifier assembly to insure adequate cooling of the diodes under all operating conditions.

The calculated data on the various generators is shown in Table 6. A brief discussion of the parameters tabulated in Table 6 is presented below:

1. Weight

The weight shown in the total weight of the generator, including the output rectifier assembly in the case of the d-c machines. In arriving at the weights shown, the weight of the electrical components (main a-c portion, exciter, permanent magnet generator, and output diodes for d-c machines) was calculated. The remaining mechanical weight was estimated based on that of similar generators.

2. Approximate Outline Dimensions

These figures are approximate since no layouts of the machines were made. The diameters shown are the basic machine diameters and do not take into account localized projections such as terminals, oil tubes, etc., which have some flexibility as to location and can usually be positioned to avoid interferences with other vehicle components. For the d-c generators with more than twelve output diodes, the diameter of the portion of the generator containing the diodes is increased to 12" to permit the nesting of the exciter and permanent magnet generator under the output rectifier assembly, thereby reducing the overall machine length and weight.

3. Efficiency

The efficiency was calculated based on the following operating conditions: 100% rated load, minimum rated speed

(11400 RPM), and maximum oil inlet temperature (130°C). In addition, for the a-c machines minimum rated power factor (0.8 lagging) was assumed. For the d-c generators, the losses associated with the output rectifier assembly were included in the efficiency calculation, the result being lower efficiencies for these machines.

4. Life

The life of the generators is based on the life of the polyimide insulation system used.

5. MTBF

The mean-time-between-failure was calculated from failure rates based on field data on in-service aircraft generators and MIL-HDBK-217A where possible. The MTBF values are predicted achieved MTBF which is 80% of the calculated inherent values.

6. Costs

The costs shown are Engineering estimates based on the assumptions that approximately 50 units per month are being produced and adequate production tooling is available.

As can be seen, costs for the d-c machines are higher, reflecting the cost of the output rectifier assembly. The cost of the output rectifier assembly is directly affected by the severity of the overload requirement on the generator. For example, if the maximum overload required of the 60 kw, 28 volt d-c machine was 1.5 per unit instead of 3.0 per unit short circuit, the total cost of the generator would be reduced by approximately 25%.

TABLE 5

GENERATOR REQUIREMENTS AND CHARACTERISTICS

	120/208 Volt 400 Hz	28 Volt DC	56 Volt DC
Speed (rpm)	12000 $\pm$ 5%	12000 $\pm$ 5%	12000 $\pm$ 5%
Power Factor (min.)	0.8 lagging	-	-
Cooling			
1. Medium	130°C Oil	130°C Oil	130°C Oil
2. Method	Spray	Spray plus Conduction	Spray plus Conduction
Overloads			
1. 1.5 per unit	2 minutes	2 minutes	2 minutes
2. 2.0 per unit	5 seconds	5 seconds	5 seconds
3. 3.0 per unit short circuit	5 seconds	5 seconds	5 seconds
Excitation (max.)			
1. Continuous	2 amps	2 amps	2 amps
2. Overload	4 amps	4 amps	4 amps
Output Rectifier Assembly	None Req'd	Integral part of machine	Integral part of machine

Other Requirements and Characteristics (applicable to generators for all three types of systems):

1. Brushless design to be used.
2. Two bearing design to be used.
3. Single-phase permanent magnet generator to be included for control and excitation power.
4. Conventional silicon steel (AISI M-15) to be used.

TABLE 6

RECTIFIER CAPABILITY

<u>Diode Rating</u>	<u>Forward Current Capacity @ 160°C Case Temperature</u>
160 a.	115 a.
240 a.	170 a.
400 a.	260 a.
650 a.	430 a.

TABLE 7 - OUTPUT RECTIFIER DESCRIPTION (DC MACHINES ONLY)

Generator Rating	Max. D-C Current @ 3.0 P.U. S.C.	Parallel Paths in Main Stator	Matched Diodes per Rect. Leg	Current per Diode	Diode Rating Required *	Total No. of Diodes
A. 28 Volt d-c, 2-wire Designs						
1. 10 KW	1070 a.	1	1	357 a.	650 a.	6
2. 25 KW	2680 a.	4	1	224 a.	400 a.	24
3. 40 KW	4286 a.	4	1	357 a.	650 a.	24
4. 60 KW	6440 a.	4	2	268 a.	650 a.	48
B. 56 Volt d-c, 3-wire Designs (2 series connected bridges req'd)						
1. 10 KW	535 a.	1	1	179 a.	400 a.	12
2. 25 KW	1339 a.	2	1	224 a.	400 a.	24
3. 40 KW	2145 a.	2	1	357 a.	650 a.	24
4. 60 KW	3220 a.	4	1	268 a.	650 a.	48

* Selected from Table 4

TABLE 8 - CALCULATED GENERATOR DATA

<u>RATING</u>	<u>WTGHT</u>	<u>APPROX. OUTLINE</u> (Length x dia.)	<u>EFF.</u>	<u>LIFE</u>	<u>MTEF</u> (Predicted Achieved)	<u>COST</u>
A. 120/200 Volt, 400 Hz Designs						
1. 12.5 KVA, 0.8 p.f.	36 lbs	9.0" x 7.0"	78.1%	20,000 hrs.	12240 hrs.	\$1200
2. 31.3 KVA, 0.8 p.f.	46 lbs	10.7" x 7.0"	83.4%	"	"	\$1220
3. 50 KVA, 0.8 p.f.	55 lbs	11.6" x 7.0"	86.6%	"	"	\$1240
4. 75 KVA, 0.8 p.f.	66 lbs	13.1" x 7.0"	87.6%	"	"	\$1270
B. 28 Volt d-c Designs						
1. 10 KW	36 lbs	11.2" x 8.0"	69.2%	20,000 hrs.	11520 hrs.	\$1550
2. 25 KW	52 lbs	12.1" x 8.0"/12.0"*	78.6%	"	10880 hrs.	\$1930
3. 40 KW	62 lbs	13.2" x 8.5"/12.0"*	80.7%	"	11040 hrs.	\$2320
4. 60 KW	81 lbs	20.9" x 9.25"/12.0"*	80.8%	"	10560 hrs.	\$2720
C. 56 Volt d-c Designs						
1. 10 KW	39 lbs	14.2" x 8.0"	69.2%	20,000 hrs.	11200 hrs.	\$1580
2. 25 KW	53 lbs	12.1" x 8.0"/12.0"*	78.6%	"	10880 hrs.	\$1970
3. 40 KW	63 lbs	13.2" x 8.5"/12.0"*	80.7%	"	11040 hrs.	\$2370
4. 60 KW	80 lbs	20.9" x 9.25"/12.0"*	80.8%	"	10560 hrs.	\$2780

* 12" diameter applies to portion of machine containing output rectifiers

Dual 28 VDC GCU (Reference: EDSK-349668)

The dual voltage GCU is operationally identical to the single voltage GCU. The only differences are in the voltage regulator, Current Limit, OV Trip, and UV Warning Circuits.

For the dual voltage system it is necessary for the voltage regulator to sense line-to-line voltage instead of line-to-neutral. This is accomplished by means of a converter which changes the line-to-line voltage to an equivalent line-to-neutral voltage for the regulator.

The Current Limit must limit both positive and negative generator output currents so two current transformers are required instead of one.

The OV Trip and UV Warning Circuits monitor each battery individually to ensure that both voltages are within normal limits.

115 VAC GCU (Reference: EDSK-349669)

The 115 V GCU has five indicated functions - GCR Open, Abnormal Frequency (AF) Trip, Overcurrent (OC) Trip, OV Trip, and UV Trip. All four trip signals will cause the GCR to open unless the Commit Switch is closed. The appropriate trip indicator will light as a warning even if the GCR does not open.

The AF circuit senses whether the frequency of the generator output is within normal limits. This is important because magnetic components, such as motors and transformers, can be damaged by improper frequency.

The OC circuit senses generator output current by means of three current transformers in the three A-C lines. The circuit produces an output signal if any one of the three lines is carrying excessive current.


The OV and UV circuits produce output signals if any one of the three phase voltages is above or below normal limits.

Summary

The following table summarizes the estimated size, weight, cost, and reliability for the three GCU's.

	<u>Size*</u> <u>HXWXL</u> <u>(in.)</u>	<u>Wt* (lb)</u>	<u>Cost (\$)</u>	<u>MTBF</u> <u>Inherent</u> <u>(hr.)</u>	<u>MTBF</u> <u>Predicted</u> <u>Achieved</u>
28V	3 x 5 x 7	2.9	703	39,200	31,400
Dual	3 x 6 x 8	3.7	606	29,100	23,300
115V	3 x 6 x 8	3.9	742	23,400	18,700

*Figures based on a bolt-down, fabricated aluminum, rectangular package.



GCR GENERATOR CONTROL RELAY
 POR POINT OF REGULATION
 PMG PERMANENT MAGNET GENERATOR
 OV OVERVOLTAGE
 UV UNDERVOLTAGE
 P.S. POWER SUPPLY
 LO LOCKOUT

QTY	SYM	DESCRIPTION	PART NO	SPECIFICATION	CODE	INFORMATION	ITEM NO
LIST OF MATERIAL OR PARTS LIST							
1	RELAY	GENERATOR CONTROL RELAY	349668				1
1	CONTACTOR	GENERATOR CONTACTOR	349669				2
1	RELAY	28VDC RELAY	349670				3
1	RELAY	120VDC RELAY	349671				4
1	RELAY	28VDC RELAY	349672				5
1	RELAY	120VDC RELAY	349673				6
1	RELAY	28VDC RELAY	349674				7
1	RELAY	120VDC RELAY	349675				8
1	RELAY	28VDC RELAY	349676				9
1	RELAY	120VDC RELAY	349677				10
1	RELAY	28VDC RELAY	349678				11
1	RELAY	120VDC RELAY	349679				12
1	RELAY	28VDC RELAY	349680				13
1	RELAY	120VDC RELAY	349681				14
1	RELAY	28VDC RELAY	349682				15
1	RELAY	120VDC RELAY	349683				16
1	RELAY	28VDC RELAY	349684				17
1	RELAY	120VDC RELAY	349685				18
1	RELAY	28VDC RELAY	349686				19
1	RELAY	120VDC RELAY	349687				20
1	RELAY	28VDC RELAY	349688				21
1	RELAY	120VDC RELAY	349689				22
1	RELAY	28VDC RELAY	349690				23
1	RELAY	120VDC RELAY	349691				24
1	RELAY	28VDC RELAY	349692				25
1	RELAY	120VDC RELAY	349693				26
1	RELAY	28VDC RELAY	349694				27
1	RELAY	120VDC RELAY	349695				28
1	RELAY	28VDC RELAY	349696				29
1	RELAY	120VDC RELAY	349697				30
1	RELAY	28VDC RELAY	349698				31
1	RELAY	120VDC RELAY	349699				32
1	RELAY	28VDC RELAY	349700				33
1	RELAY	120VDC RELAY	349701				34
1	RELAY	28VDC RELAY	349702				35
1	RELAY	120VDC RELAY	349703				36
1	RELAY	28VDC RELAY	349704				37
1	RELAY	120VDC RELAY	349705				38
1	RELAY	28VDC RELAY	349706				39
1	RELAY	120VDC RELAY	349707				40
1	RELAY	28VDC RELAY	349708				41
1	RELAY	120VDC RELAY	349709				42
1	RELAY	28VDC RELAY	349710				43
1	RELAY	120VDC RELAY	349711				44
1	RELAY	28VDC RELAY	349712				45
1	RELAY	120VDC RELAY	349713				46
1	RELAY	28VDC RELAY	349714				47
1	RELAY	120VDC RELAY	349715				48
1	RELAY	28VDC RELAY	349716				49
1	RELAY	120VDC RELAY	349717				50
1	RELAY	28VDC RELAY	349718				51
1	RELAY	120VDC RELAY	349719				52
1	RELAY	28VDC RELAY	349720				53
1	RELAY	120VDC RELAY	349721				54
1	RELAY	28VDC RELAY	349722				55
1	RELAY	120VDC RELAY	349723				56
1	RELAY	28VDC RELAY	349724				57
1	RELAY	120VDC RELAY	349725				58
1	RELAY	28VDC RELAY	349726				59
1	RELAY	120VDC RELAY	349727				60
1	RELAY	28VDC RELAY	349728				61
1	RELAY	120VDC RELAY	349729				62
1	RELAY	28VDC RELAY	349730				63
1	RELAY	120VDC RELAY	349731				64
1	RELAY	28VDC RELAY	349732				65
1	RELAY	120VDC RELAY	349733				66
1	RELAY	28VDC RELAY	349734				67
1	RELAY	120VDC RELAY	349735				68
1	RELAY	28VDC RELAY	349736				69
1	RELAY	120VDC RELAY	349737				70
1	RELAY	28VDC RELAY	349738				71
1	RELAY	120VDC RELAY	349739				72
1	RELAY	28VDC RELAY	349740				73
1	RELAY	120VDC RELAY	349741				74
1	RELAY	28VDC RELAY	349742				75
1	RELAY	120VDC RELAY	349743				76
1	RELAY	28VDC RELAY	349744				77
1	RELAY	120VDC RELAY	349745				78
1	RELAY	28VDC RELAY	349746				79
1	RELAY	120VDC RELAY	349747				80
1	RELAY	28VDC RELAY	349748				81
1	RELAY	120VDC RELAY	349749				82
1	RELAY	28VDC RELAY	349750				83
1	RELAY	120VDC RELAY	349751				84
1	RELAY	28VDC RELAY	349752				85
1	RELAY	120VDC RELAY	349753				86
1	RELAY	28VDC RELAY	349754				87
1	RELAY	120VDC RELAY	349755				88
1	RELAY	28VDC RELAY	349756				89
1	RELAY	120VDC RELAY	349757				90
1	RELAY	28VDC RELAY	349758				91
1	RELAY	120VDC RELAY	349759				92
1	RELAY	28VDC RELAY	349760				93
1	RELAY	120VDC RELAY	349761				94
1	RELAY	28VDC RELAY	349762				95
1	RELAY	120VDC RELAY	349763				96
1	RELAY	28VDC RELAY	349764				97
1	RELAY	120VDC RELAY	349765				98
1	RELAY	28VDC RELAY	349766				99
1	RELAY	120VDC RELAY	349767				100

LOGIC DIAGRAM
 ±28VDC GCU

C 83843 EDSK 349668

FIGURE 15


[illegible]

FIGURE 16

Unclassified

Security Classification

DOCUMENT CONTROL DATA - R & D

(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)

1. ORIGINATING ACTIVITY (Corporate author) Westinghouse Electric Corporation Aerospace Electrical Division, Lima, Ohio		2a. REPORT SECURITY CLASSIFICATION Unclassified	
		2b. GROUP	
3. REPORT TITLE ARMY VEHICLE POWER SYSTEM AND LOAD STUDY			
4. DESCRIPTIVE NOTES (Type of report and inclusive dates) Technical Report, Final December 1970			
5. AUTHOR(S) (First name, middle initial, last name) J. G. Nell			
6. REPORT DATE December 1970		7a. TOTAL NO. OF PAGES 56	7b. NO. OF REFS 0
8a. CONTRACT OR GRANT NO. DAAE07-67-C-1563 Amendment II		8b. ORIGINATOR'S REPORT NUMBER(S) XXXXXXXXXX	
b. PROJECT NO		8c. OTHER REPORT NO(S) (Any other numbers that may be assigned this report) TACOM Technical Report No. 10774	
c.			
d.			
10. DISTRIBUTION STATEMENT Distribution of this Report is Unlimited.			
11. SUPPLEMENTARY NOTES		12. SPONSORING MILITARY ACTIVITY U.S. Army Tank Automotive Command Vehicular Components and Materials Lab, Warren, Mich. 48090	
13. ABSTRACT This study has compiled a band of power system data so that, given an electric power profile for an army vehicle, an optimum power system approach can be selected. The basis for the selection are four parameters; weight, volume, efficiency, and life cycle cost. The major power system components included in the study were a gas turbine, fuel for a 24 hour and a 48 hour mission, a generator, a voltage regulator, system controls, and protection. Three types of electric power were investigated; 28 volts d-c, 56 volts d-c and 115/200 volts, 3 phase, 400 Hz a-c. The study indicates that the type of electric power selected should be a function of what is best for the loads since fuel weight is quite large compared with the other components. Also, a method of determining life cycle cost for a vehicle electric power system is described.			

DD FORM 1473
1 NOV 66

REPLACES DD FORM 1473, 1 JAN 66, WHICH IS
OBSOLETE FOR ARMY USE.

Unclassified
Security Classification

BEST AVAILABLE COPY

