

HEAT-TRANSFER CHARACTERISTICS
OF 98% H₂O₂ AT
HIGH PRESSURE AND HIGH VELOCITY

804006

D. C. Rousar and N. E. Van Huff
Aerojet-General Corporation

TECHNICAL REPORT AFRPL-TR-66-263
August 1966

Air Force Rocket Propulsion Laboratory
Air Force Systems Command
Research and Technology Division
United States Air Force
Edwards Air Force Base, California

AGC Report I0785-SR-1

4

AFRPL-TR-66-263

August 1966

HEAT-TRANSFER CHARACTERISTICS
OF 98% H₂O₂ AT
HIGH PRESSURE AND HIGH VELOCITY

D. C. Rousar and N.E. Van Huff

Aerojet-General Report 10785-SR-1

35251

FOREWORD

This special report presents the results of an investigation, conducted under Contract AF 04(611)-10785, to determine the heat-transfer characteristics of 98% H₂O₂ at high pressure and high velocity. Portions of this study have been presented in various progress reports and have been compiled herein to assist the reader in application of the technology discussed.

The investigation was part of the Advanced-Propellant Staged-Combustion Feasibility Program conducted by the Advanced Storable Engine Division of Liquid Rocket Operations, Aerojet-General Corporation, Sacramento, California.

Technical managerial control is provided by Mr. R. J. Kuntz, PE, Project Engineer. Mr. R. Beichel is Program Manager.

Contributors to this report, in addition to those noted on the title page, included the following Aerojet-General personnel:

R. F. Bechtold
A. Fink

This technical report has been reviewed and is approved.

Richard Weiss
Air Force Program Manager

ABSTRACT

High-pressure heat-transfer experiments have been conducted with both 90 and 98% H_2O_2 . Electrically heated 3/16- and 1/4-in.-dia Inconel 718 and 3/16-in.-dia stainless-steel test sections were used, at pressures of 850 to 4700 psi and at coolant velocities of 25 to 198 ft/sec. Titration of the peroxide after short-duration testing indicated that little or no H_2O_2 decomposition had occurred in the test section. The short-duration burnout tests have shown that the maximum burnout heat flux is directly proportional to coolant velocity and is insensitive to coolant pressure. The Dittus-Boelter equation was found to yield a conservative estimate of heat-transfer coefficients for 98% H_2O_2 and is recommended for design purposes. Long-duration tests conducted at velocities of 50 to 150 ft/sec with Inconel 718 tubing indicated that the long-duration burnout heat flux is degenerated to about 65% of that demonstrated in short-duration tests. Titration of the peroxide after these tests indicated that minor H_2O_2 decomposition had occurred.

It can be concluded that 98% H_2O_2 would be an excellent regenerative coolant in rocket engine systems. The long-duration burnout phenomenon at high pressure can be avoided by limiting the design burnout heat flux to about 65% of the short-duration burnout point.

BLANK PAGE

TABLE OF CONTENTS

	<u>Page</u>
I. Introduction and Summary	1
II. Technical Discussion	3
A. Experimental Apparatus	3
B. Testing	5
C. Test Procedures	6
D. Data Reduction	7
E. Discussion of Results	11
III. Conclusions and Recommendations	22

References

APPENDIXES

<u>Appendix</u>		<u>Page</u>
A	Test-Section Metallographic Examinations	76
B	Tabulated Heat-Transfer Data	85

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
I	Test-Section Dimensions	25
II	98% H ₂ O ₂ Burnout Test Results	26
III	Extended-Duration Test Results	27
IV	H ₂ O ₂ Concentration Data	28
V	Isothermal Pressure-Drop Data for 98% H ₂ O ₂	29
VI	Pressure-Drop Data for 98% H ₂ O ₂ Heated	30
VII	Burnout Test Results for 90% H ₂ O ₂ and Deionized Water	31

LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1	Schematic of High-Pressure Heat-Transfer Loop	32
2	10,000-psig Pressurization System	33
3	High-Pressure Heat-Transfer Loop	34
4	Preheater--Test-Section Assembly	35
5	Test-Section Schematic	36
6	Mounted Test Section	37
7	Thermal Conductivity and Electrical Sensitivity of Inconel-718 and 347 Stainless Steel	38
8	Complete Severance Burnout with Tube Split	39
9	Complete Severance Burnout without Tube Split	40
10	Burnout with Complete Severance at Two Locations	41
11	Tube-Split Burnout	42
12	98% H ₂ O ₂ Burnout Test Results	43
13	Subcritical 98% H ₂ O ₂ Burnout Test Results	44
14	Subcritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 134	45
15	Subcritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 139	46
16	Subcritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 109	47
17	Subcritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 110	48
18	Deionized Water Heat Flux-Wall Temperature Data, Test 106	49
19	Supercritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 113	50

LIST OF FIGURES (cont.)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
20	Supercritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 124	51
21	Supercritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 112	52
22	Supercritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 116	53
23	Supercritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 114	54
24	Supercritical 98% H ₂ O ₂ Heat Flux-Wall Temperature Data, Test 115	55
25	Extended-Duration Test Results	56
26	Burnout Test-Energy Balances	57
27	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 130	58
28	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 135	59
29	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 136	60
30	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 137	61
31	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 138	62
32	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 142	63
33	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 132	64
34	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 133	65
35	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 143	66
36	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 140	67
37	98% H ₂ O ₂ Extended-Duration Test Parameters, Test 141	68
38	Water Extended-Duration Test Parameters, Test 144	69
39	98% H ₂ O ₂ Forced-Convection Data Correlation Based on Bulk-Temperature Properties	70

LIST OF FIGURES (cont.)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
40	98% H_2O_2 Forced-Convection Data Correlation Based on Film-Temperature Properties	71
41	98% H_2O_2 Isothermal Friction Factors	72
42	Heated 98% H_2O_2 Pressure-Drop Data	73
43	Comparison of 90% H_2O_2 and 98% H_2O_2 Burnout Test Results	74
44	Water Burnout Heat-Flux Data	75

Report AFRL-DR-66-263

I.

INTRODUCTION AND SUMMARY

I.

INTRODUCTION AND SUMMARY

Advanced concepts for storable propellant liquid rocket engines have been under extensive investigation for the past few years. These studies have shown that the performance of existing N_2O_4 /AeroZINE 50 systems can be increased significantly by using high chamber pressures, a staged-combustion engine cycle, and fuels that are gelled mixtures of hydrazine and metals or metal hydrides. The system under investigation in the Advanced Propellant Staged Combustion Feasibility Program, Contract AF 04(611)-10785, employs 98% H_2O_2 /Alumizine-43 propellants at a chamber pressure of 3000 psia. It has been established that a regenerative coolant for this system must be capable of accepting high heat fluxes.

Because of the low burnout-heat-flux limits and because of the uncertain heat-transfer characteristics of Alumizine (1), 98% H_2O_2 was chosen as the more suitable regenerative coolant for 98% H_2O_2 /Alumizine-43 systems. The feasibility of using H_2O_2 as a regenerative coolant has previously been demonstrated in experimental investigations with 98% H_2O_2 (2) and 90% H_2O_2 (2, 3, 4). These previous results were obtained at relatively low pressures (300 to 1100 psia) and low velocities (14 to 67 ft/sec). Data on the heat-transfer characteristics of 98% H_2O_2 at pressures up to 5000 psia and velocities up to 200 ft/sec are needed for evaluating regenerative cooling designs for high-pressure, high-heat-flux systems.

In the present investigation, 24 heat-transfer tests were conducted with 98% H_2O_2 in electrically heated round tubes with uniform heat-flux distribution. The ranges of conditions encountered in these tests were:

Pressure, psia	830 to 4700
Velocity, ft/sec	25 to 200
Bulk Temperature, °F	40 to 215
Heat Flux, Btu/in. ² sec	Up to 48

Thirteen of these tests were burnout tests, in which the burnout or ultimate heat flux was evaluated in electrically heated round tubes by increasing the heat flux in increments, at a fixed flow rate and at fixed pressure conditions, until failure of the tube occurred. Data on the forced-convection heat-transfer characteristics were also obtained at each heat-flux level below the burnout point.

The remaining 11 of the 98% H_2O_2 tests were extended-duration tests in which a constant heat-flux level was maintained for durations up to ten minutes. This extensive investigation of duration effects was initiated when it was found that burnouts occurred during extended operation at significantly lower heat fluxes than during the shorter-duration burnout tests.

I, Introduction and Summary (cont.)

Seven tests to determine the pressure-drop characteristics of 98% H_2O_2 at isothermal and heated conditions were also conducted.

Heat-transfer tests with 90% H_2O_2 and deionized water were conducted in addition to the 98% H_2O_2 testing. The burnout heat flux of 90% H_2O_2 was evaluated in four tests at a nominal pressure of 4000 psia, with velocities from 45 to 135 ft/sec, bulk temperatures from 140 to 205°F, and at heat fluxes up to 36 Btu/in.² sec.

Testing with deionized water consisted of two burnout tests and of one extended-duration test. The water burnout tests served as loop-checkout tests, and the extended-duration test with water provided a comparison to the results of the 98% H_2O_2 extended-duration tests. Water testing was done at velocities from 38 to 150² ft/sec, pressures from 1000 to 3000 psia, and bulk temperatures from 120 to 285°F with heat fluxes up to 28 Btu/in.² sec. Sections of the burned-out tubes were subjected to metallographic analysis to determine the surface changes that occurred (Appendix A).

All testing was done on Aerojet-General's high-pressure, storable-propellant heat-transfer loop. This "blowdown" type loop is pressurized with a nitrogen system capable of operating at 10,000 psia. The liquid run tank can operate at pressures up to 5500 psia. Electrical power for preheating the 98% H_2O_2 and for applying a heat flux to the test section is provided by a 200-kw-rated dc power source.

ii.

TECHNICAL DISCUSSION

II.

TECHNICAL DISCUSSION

This section contains descriptions of the experimental apparatus, of the types of tests conducted, of the test procedures used, and of the method of data analysis. A discussion of the results obtained is also included.

A. EXPERIMENTAL APPARATUS

1. High-Pressure Heat-Transfer Loop

All tests were conducted on Aerojet-General's high-pressure "blowdown" heat-transfer loop shown schematically in Figure 1. The main components of the loop are the pressurization system, the run-tank assembly, the preheater-test section assembly, the heat exchanger, the flow-control valve, and the dump-tank assembly. Electrical power for the preheater-test section assembly is provided by four 15-v power supplies rated at 50 kw dc each.

The pressurization system, shown in Figure 2, consists of an 18-ft³ 10,000-psig-rated nitrogen storage vessel, of a high-pressure booster pump, and of associated piping and valve components. The run-tank assembly consists of a 115-gal 5500-psig-rated 321 stainless-steel spherical vessel, of piping and valve components, and of a control system which allows remote operation. Three interconnected 42-gal 2000-psig-rated spherical stainless-steel vessels make up the dump-tank system. The electrically operated flow-control valve is located upstream of the dump tanks. The run tank and the dump-tank assemblies are shown in Figure 3.

The preheater-test section assembly consists of a 150-kw-rated preheater coil constructed from 1/2-in.-OD by 0.058-in.-thick stainless-steel tubing, of a test-section mounting stand with attached copper bus-bar clamps for holding the test section in place; of inlet and outlet fluid-mixing sections; and of a stand for mounting pressure transducers and the thermocouple ice bath. A water-cooled, multi-pass, shell and tube-type heat exchanger is located downstream of the test section. The preheater-test section assembly and the heat exchanger can be seen in Figures 3 and 4.

2. Test Sections

Test sections were constructed from 1/4- and 3/16-in.-OD tubing with wall thicknesses from 0.015 to 0.016 in. The tube material was Inconel 718 for the majority of the tests, but some testing was done with 347 stainless-steel tubing. The basic configuration of a test section is shown in Figure 5. Dimensions of the test sections used in each test are given in Table I.

The heated lengths of the test sections were formed by silver-brazing two predrilled copper cylinders onto the tubing. These copper cylinders

II, A, Experimental Apparatus (cont.)

fit the copper bus-bar clamps. Fittings for connecting the test section to the mixing sections and to the transducer lines were then installed, together with the wall-temperature and voltage tap instrumentation. An unheated entrance length of 5 in. (yielding length-to-diameter, L/D, ratios of 23 and 31 for the 1/4- and 3/16-in.-OD tubing, respectively) was maintained on all test sections. Figure 6 shows a completed test section installed on the mounting stand.

3. Passivation Procedure

Prior to testing with 98% H_2O_2 , the heat-transfer loop was thoroughly passivated. Passivation was accomplished in the following sequence: (1) the system was cleaned with solvents and flushed with deionized water; (2) 70% nitric acid was flushed through the system and left in the tanks and lines for 24 hr; (3) the system was flushed with deionized water; (4) the entire system was filled with 35% H_2O_2 , was left full for about 60 hr, and was then drained; (5) the run tank was filled with 98% H_2O_2 .

Test sections were also passivated prior to installation by filling the sections with 70% nitric acid and allowing the acid to remain in the tubes for four hours. The tubes were then flushed with deionized water and purged with nitrogen.

4. Instrumentation

The following measurements were made in each test:

- a. Test-section outer wall temperature (at two or three axial positions),
- b. Test-section inlet and outlet bulk temperature,
- c. Flow rate,
- d. Test-section inlet and outlet pressure,
- e. Test-section current,
- f. Overall test-section voltage drop, and
- g. Voltage levels at incremental distances along the test section.

In addition, test-section pressure drop was measured in seven pressure-drop tests. The accuracy of the data was enhanced by taking redundant measurements whenever possible. Average readings of these measurements were used in evaluating the data.

II, A, Experimental Apparatus (cont.)

Test-section outer wall temperatures were measured with 40-gage chromel-alumel thermocouples installed upon a 0.0005-in.-thick layer of mica. They were held in place by an overwrap of glass roving. The accuracy of these measurements was evaluated by comparing the readings from two thermocouples placed opposite each other at each axial position where a wall-temperature measurement was desired. The data indicated agreement within 20 to 100°F at wall temperatures from 500 to 1500°F.

Both the inlet and the outlet bulk temperatures were measured with three copper-constantan immersion-type thermocouples installed downstream of the mixing baffles in the fluid-mixing sections. Agreement between the readings of the three thermocouples was generally within 2°F.

Flow-rate measurements were obtained from two turbine-type flow meters connected in series upstream of the preheater. Agreement between these two meters was consistently within 1.5%.

Test-section inlet and outlet pressures were measured with transducers connected to pressure-tap fittings upstream and downstream of the test-section electrical connections. Readings from these two transducers consistently agreed within 2% at the no-flow data point recorded in each test after system pressurization had been achieved. Test-section pressure-drop measurements were obtained using 0-to-100-psi and 0-to-500-psi pressure-drop transducers.

Overall test-section voltage drop was measured between the test-section electrodes. Incremental voltage levels along the test-section tube were also measured with voltage taps, which consisted of 0.005-in.-dia wire that was spot-welded to the tube. Agreement between these voltage measurements was good, and a linear voltage relationship was found to exist along the test section.

Test-section current was measured with a 50-mv shunt. The accuracy of this measurement was good, as indicated by the overall energy balances calculated for each test, which generally compared within 10% for short-duration variable-heat-flux tests and within 4% for long-duration constant-heat-flux tests.

B. TESTING

Three types of tests were conducted: (1) burnout tests, (2) extended-duration tests, and (3) pressure-drop tests. These tests are discussed separately in the following paragraphs.

II, B, Testing (cont.)

1. Burnout Tests

The objective of the burnout tests was to determine the burnout heat flux and the forced-convection characteristics of 98% H_2O_2 at given pressures, velocities, and bulk temperatures. In these tests, the heat flux was increased stepwise until the test section burned out. Forced-convection data were obtained at each heat-flux level up to the point of burnout. The duration of these tests was typically from three to four minutes. During this time, heat fluxes ranging from zero to the burnout value were applied to the test section.

Thirteen burnout tests were conducted with 98% H_2O_2 , four with 90% H_2O_2 , and two with deionized water (loop-checkout tests).

2. Extended-Duration Tests

Tests with extended durations at a constant heat flux were also conducted. The objective of these tests was to determine whether the burnout heat-flux limits established for 98% H_2O_2 in the burnout tests of relatively short duration were applicable for operation at longer durations. In these extended-duration tests, a predetermined heat flux was applied to the test section after the desired flow conditions had been established, and the system was then allowed to operate at steady-state conditions until the desired duration (ranging from 5 to 10 min) had been achieved or until burnout of the test section occurred.

Twelve extended-duration tests were conducted: eleven with 98% H_2O_2 and one with water.

3. Pressure-Drop Tests

Testing with 98% H_2O_2 included tests to evaluate pressure-drop characteristics at isothermal and heated conditions. Seven of these tests were conducted.

C. TEST PROCEDURES

Prior to testing, the high-pressure GH_2 receiver was pressurized to 10,000 psi by utilizing a boost-pump system. Next, the dump tanks were vented, the drain lines were closed, water flow in the heat exchanger was initiated, and the system was pressurized to a predetermined level.

The desired flow rate and outlet pressure for the test section was then initiated and controlled by slowly opening the electrically operated

II, C, Test Procedures (cont.)

flow-control valve. When the desired flow conditions had been achieved, power was applied to the preheater and the test-section inlet temperature was adjusted to the desired value. Test-section power was then raised to a predetermined level, and the wall temperature of the section was monitored on a visual gage to determine when steady-state conditions were obtained (the time required to achieve steady state was generally about 10 sec). All pertinent data were then recorded automatically on magnetic tape and oscillograph paper.

In the burnout tests, test-section power was slowly increased to a higher level and, as soon as steady-state had been achieved, the data-taking process was repeated. This step-wise increase in heat flux was repeated until burnout of the test section occurred.

The heat flux initially applied to the test section was not changed during the long-duration tests, and the system was maintained at steady state for a specified time or until the test section burned out. The high-pressure tests (outlet pressure > 2000 psia) with durations exceeding five minutes were conducted in two blowdowns of the loop.

The pressure-drop tests were conducted in essentially the same manner as the burnout and long-duration tests except that during the start sequence the system was pressurized more slowly and with the flow-control valve slightly open to avoid an excessive pressure difference across the pressure-drop transducers.

D. DATA REDUCTION

The data obtained during these tests were reduced using Aerojet-General's data-reduction computer program, Program 22105 (5). The outputs from this program for the 98% H₂O₂ and 90% H₂O₂ tests are given in Appendix B.

Local values of heat-transfer coefficient were calculated from the relationship:

$$h = \frac{\phi}{T_1 - T_B}$$

where:

h = heat-transfer coefficient, Btu/in.²sec °F

ϕ = local heat flux, Btu/in.²sec

T_1 = inside tube wall temperature, °F

T_B = local bulk temperature, °F

II, D, Data Reduction (cont.)

Values of heat flux were calculated from electrical power measurements and from the tube geometry:

$$\phi = \frac{CAEI}{\pi(ID)(\Delta L)}$$

where:

E = voltage drop

I = current, amp

ID = inside tube diameter, in.

ΔL = length between voltage taps, in.

$$C = 0.000948 \frac{\text{Btu/sec}}{\text{watt}}$$

Inner-wall temperatures were evaluated assuming radial conduction and no heat transfer at the outer tube wall. The thermal conductivity and the electrical resistivity of the tube wall were considered as functions of temperature. The differential equation (6) for this condition is:

$$\frac{d^2T}{dr^2} + \frac{1}{r} \frac{dT}{dr} + \frac{1}{k} \frac{dT}{dr} \frac{dk}{dr} = \frac{-CAE^2}{\rho_e k \Delta L^2}$$

where:

T = temperature, °F

r = radius, in.

k = tube-wall thermal conductivity, Btu/sec in.°F

ρ_e = tube-wall electrical resistivity, ohm-in.

Substitution of the expressions:

$$\frac{dT}{dr} = \frac{T_{n-1} - T_n}{\Delta r}$$

$$\frac{dk}{dr} = \frac{k_{n-1} - k_n}{\Delta r}$$

II, D, Data Reduction (cont.)

and

$$\frac{d^2 T}{dr^2} = \frac{T_{n+1} - 2T_n + T_{n-1}}{(\Delta r^2)}$$

into the differential equation yields the finite-difference equation from which the inside tube-wall temperature was calculated:

$$T_{n+1} = T_n - (T_{n-1} - T_n) \left[\frac{\Delta r}{r_n} + \frac{k_{n-1} - k_n}{k_n} + 1 \right]$$

$$\Delta = \frac{CAE^2 \Delta r^2}{k_n \rho_n \Delta L^2}$$

where:

$n+1$, n , $n-1$ refer to adjacent radial increments of thickness Δr . The values of k and ρ used for Inconel 718 and 347 stainless steel are shown in Figure 7 and were taken from References 7, 8, and 9. Local bulk temperature was calculated assuming uniform power input along the length of the test section, i.e.,

$$T_B = T_{Bin} + (T_{Bout} - T_{Bin}) \frac{(L-X)}{L}$$

where:

T_{Bin} = inlet bulk temperature, °F

T_{Bout} = outlet bulk temperature, °F

L = heated length of test section, in.

X = distance from downstream end of heated length, in.

The local pressure was calculated from a similar expression:

$$P = P_{in} - (P_{in} - P_{out}) \frac{(L-X)}{L}$$

where:

P_{in} = inlet pressure, psia

P_{out} = outlet pressure, psia

II, D, Data Reduction (cont.)

The dimensionless forced-convection correlating parameters listed below were evaluated at the local bulk temperature and at the average film temperature:

$$Nu = \text{Nusselt Number} = \frac{h d_e}{k}$$

$$Re = \text{Reynolds Number} = \frac{V d_e \rho}{12 \mu}$$

$$Pr = \text{Prandtl Number} = \frac{w C_p}{12 k}$$

where:

V = velocity, ft/sec

d_e = equivalent diameter, in.

ρ = density, lbm/ft³

μ = viscosity, lbm/ft-sec

C_p = specific heat, Btu/lbm°F

The overall reliability of the data was evaluated by performing an energy balance for the test section:

$$\text{Energy Balance} = \frac{Q_{in} - Q_{out}}{Q_{in}}$$

where:

Q_{in} = electrical energy input to the fluid, Btu/sec

Q_{out} = sensible energy transferred to the fluid, Btu/sec

The input energy was calculated from

$$Q_{in} = 0.000948 E_T I$$

where:

E_T = total test-section voltage drop,

I = test-section current, amp

II, D, Data Reduction (cont.)

and output energy was calculated from:

$$Q_{out} = \dot{W} \left[\bar{C}_p (T_{out} - T_{in}) + \frac{(v_{out})^2 - (v_{in})^2}{2 g J} - \Delta T_o \right]$$

where:

- \dot{W} = flow rate, lbm/sec
- \bar{C}_p = average specific heat, Btu/lbm^oF
- g = 32.174 lbm ft/lbf sec²
- J = 778 ft lbf/Btu

The term ΔT_o is the bulk-temperature rise observed before application of test-section power. This temperature rise is caused by frictional heating and was observed to increase with velocity. Incorporation of this term into the energy balance also provides a zero correction for the inlet and outlet bulk-temperature thermocouples. Values of ΔT_o ranging from 0.2 to 5.0^oF were observed at velocities from 25 to 200 ft/sec.

E. DISCUSSION OF RESULTS

1. 98% H₂O₂

a. Burnout Heat Flux

(1) Burnout Test Results

Thirteen burnout tests were conducted with 98% H₂O₂ in which burnout heat fluxes from 8.1 to 48.2 Btu/in.²sec were encountered. Eight of these tests were conducted at pressures above the critical pressure of 3220 psia. In these tests, test-section outlet pressures ranged from 3500 to 4700 psi, velocities from 25 to 200 ft/sec, and bulk temperatures from 140 to 235^oF. The remaining five burnout tests were conducted at subcritical pressure levels of 3000 and 850 psia, velocities from 50 to 170 ft/sec, and bulk temperatures from 150 to 190^oF. The results of the 98% H₂O₂ burnout tests are summarized in Table II.

The burnouts observed in these tests occurred within about one inch of the downstream end of the test section. This location of the burnout point is typical and has been observed with many fluids. Two types of burnout were observed, the most common being a complete severance burnout in which failure of the tube wall occurred in a fairly even plane roughly perpendicular to the axis of the test section. In addition, splitting of the

II, E, Discussion of Results (cont.)

tube in the longitudinal direction downstream of the severance point usually occurred. Local melting on the outside of the tube at the point of severance was observed on all complete severance burnouts. Heat marks (purple-hued discolorations) were consistently observed on the inside of the tube along the edges where tube failure occurred. Typical complete severance burnouts with and without tube spitting are shown in Figures 8 and 9. The most explosive burnout occurred during Test HT-4-109 where complete severance occurred in two locations, as shown in Figure 10.

In two of the burnout tests, a tube-split failure occurred, as shown in Figure 11. These failures were accompanied by bulging of the test section in the region of the split and by heat marks on the inside of the tube. No melting of the tube wall was observed.

It is apparent that burnout resulted from a sudden excursion in tube-wall temperature since outer tube-wall temperatures ranging from 850 to 1700°F were observed just prior to burnout.

A satisfactory correlation of the burnout test results is obtained by plotting burnout heat flux as a function of velocity. The data reported in Reference 2 for pressures from 300 to 1000 psia and bulk temperatures from 213 to 298°F also correlate well. As shown in Figure 12, the variation is essentially linear, and a good representation of the data is obtained with:

$$\phi_{BC} = 0.24 V \quad (\text{Eq 1})$$

No significant effect of pressure or bulk temperature is evident. All but one of the data points are within 2 Btu/in.² sec and at velocities greater than 40 ft/sec are within 10% of the values predicted by Equation 1. All the data correlate within 25% for the general range of conditions:

$$P = 300 \text{ to } 4700 \text{ psia}$$

$$V = 14 \text{ to } 198 \text{ ft/sec}$$

$$T_b = 137 \text{ to } 298^\circ\text{F}$$

The burnout obtained in Test HT-4-139 appears low in comparison to the rest of the data and lies about 25% below the line given by Equation 1. This suggests an effect of material since Test 139 was the only test conducted with a 347 stainless-steel test section instead of an Inconel 718 test section. However, the agreement of the data given in Reference 2 for 316 stainless-steel test sections with the data points for Inconel 718 tubing tends to negate this effect.

II, E, Discussion of Results (cont.)

The data obtained at subcritical pressures also correlate with the product of velocity and subcooling (ΔT_{sub}), as shown in Figure 13, from which the following equation is derived:

$$\phi_{\text{BO}} = 2.5 + 0.00034(V\Delta T_{\text{sub}}) \quad (\text{Eq 2})$$

where:

$$\Delta T_{\text{sub}} = T_{\text{sat}} - T_{\text{B}}, \text{ } ^\circ\text{F}$$

$$T_{\text{sat}} = \text{saturation temperature, } ^\circ\text{F (boiling point at operating pressure)}$$

This type of correlation has been found to be applicable to a wide variety of subcritical fluids at high velocity and high subcooling (ΔT_{sub}) conditions (discussed in References 10, 11, and 12). Equation 2 does not yield a more precise prediction of the subcritical pressure data because deviations of up to 30% are present.

However, the applicability of Equation 2 to the 98% H_2O_2 data is questionable because this type of correlation was established for burnout caused by the transition from nucleate to film boiling. Nucleate boiling apparently did not occur in the 98% H_2O_2 subcritical-pressure tests, as evidenced by the relationship between heat flux and wall temperature shown in Figures 14 through 17. The slope in heat flux is not steep, as in nucleate boiling, and this indicates that a convective heat-transfer mechanism was present up to the point of burnout. Furthermore, these data indicate that burnout occurred at wall temperatures below the saturation temperature (boiling point). Calculated wall temperatures at burnout ranged from 350 to 400°F at 850 psia ($T_{\text{sat}} = 655^\circ\text{F}$) and from 500 to 600°F at 3000 psia ($T_{\text{sat}} = 850^\circ\text{F}$).

The lack of a boiling phenomenon was also noted in the data reported in Reference 2; however, these data indicated that wall temperatures at burnout exceeded the saturation temperature by as much as 300°F. The discrepancy between the two sets of data has not been explained. Comparison of inner-wall temperatures calculated from water checkout test data with the temperatures given by the superheat correlations developed for water by Bernath (13) and by Jens and Lottes (14) indicate that the inner-wall temperatures obtained in this investigation are low by about 100 to 150°F, as shown in Figure 18. This error is not sufficiently large to explain the difference between the wall temperatures obtained for 98% H_2O_2 in this investigation and those reported in Reference 2.

The tests at supercritical pressure yielded the same relationship between heat flux and wall temperature as the tests at subcritical pressure. A normal, convective heat-transfer mechanism is

II, E, Discussion of Results (cont.)

evidenced up to the point of burnout, as shown in Figures 19 through 24. This type of relationship has also been observed for AeroZINE 50 at supercritical pressures.

(2) Extended-Duration Test Results

Twelve extended-duration tests were conducted: eleven with 98% H_2O_2 and one with deionized water. These tests were conducted at velocities of 50, 100, and 150 ft/sec at pressures from 830 to 3700 psia, and at bulk temperatures ranging from 115 to 155°F. Inconel 718 test sections were employed in the high-pressure tests (2800 to 3700 psia), whereas a 347 stainless-steel test section was used for low-pressure testing. The results of these tests are summarized in Table III and Figure 25.

Six of the 98% H_2O_2 extended-duration tests terminated in test-section burnout at heat fluxes that were 20 to 35% lower than the burnout values given by the velocity correlation (Equation 1) established from the results of burnout tests at relatively short duration. Burnouts were observed at 50, 100, and 150 ft/sec, as shown in Figure 25. The time interval from start of steady state to burnout ranged from 50 sec to 8.3 min.

Testing with 98% H_2O_2 in Inconel 718 test sections (eight tests, five burnouts) at pressures of 2800 to 3700 psia resulted in burnout whenever the heat flux exceeded 65% of the burnout heat flux given by Equation 1. At heat fluxes below this critical level, durations of up to ten minutes were achieved without burnout.

Somewhat different extended-duration burnout characteristics were observed with a stainless-steel test section at lower pressure ($P = 850$ psia). Tests HT-4-140, -141, and -142 were conducted with a stainless-steel test section at the same flow conditions as the stainless-steel burnout test (Test 139) discussed earlier. During extended duration testing, burnout did not occur until the maximum heat flux observed in the burnout test (Test 139) was attained. This corresponds to about 75% of the value given by Equation 1. These maximum heat flux results obtained with stainless-steel tubes are what is normally expected because burnout-heat-flux limits are not usually related to duration. A general agreement between burnout-heat-flux limits of 98% H_2O_2 in short-duration and in extended-duration tests has also been noted in Reference 2 for 316 stainless-steel test sections, at a velocity of 15 ft/sec and at a pressure of 300 psia. However, Reference 4 reports anomalous behavior (e.g., transient and recurrent wall-temperature peaks) in some extended-duration tests with stainless-steel test sections.

II, E, Discussion of Results (cont.)

Again, indications are that the material may affect the burnout heat flux of 98% H_2O_2 . However, tests with Inconel 718 at low pressures and with stainless steel at high pressure are needed to evaluate the effect of pressure on the maximum heat flux for extended duration.

The fact that extended-duration burnouts are a unique characteristic of 98% H_2O_2 was demonstrated by conducting a test with deionized water and an Inconel 718 test section (Test 144A, B) at the velocity, pressure, and heat-flux conditions of extended-duration tests with 98% H_2O_2 that resulted in two burnouts. This test had a duration of 11 min, and no burnout occurred.

An extended-duration test was also conducted with an Inconel 718 test section that was cleaned but not passivated (Test HT-4-143A, B). This test had a duration of 6.5 min at a heat flux about 60% of that given by Equation 1; no burnout occurred.

All the extended-duration burnouts occurred at heat fluxes equal to or greater than 65% of the Equation 1 value. Thus:

$$\phi_{BO} = 0.16 V \quad (\text{Eq 3})$$

appears to represent a good upper limit for safe extended-duration operation with 98% H_2O_2 and is recommended for design purposes.

(3) Burnout Mechanism

Burnouts with fluids at subcritical pressures are normally related to the transition from nucleate to film boiling, whereas most burnouts with fluids at supercritical pressure appear to result from a degradation of the heat-transfer coefficients when the properties of the fluid near the wall begin to change rapidly. These two mechanisms are entirely different, and the burnout data at these two pressure levels cannot be expected to correlate. The fact that the burnout data for 98% H_2O_2 correlate over such a wide range of pressures (300 to 4700 psia--roughly 10 to 150% of the critical pressure) suggests that H_2O_2 burnout is governed by a mechanism other than film-boiling or variations in fluid properties.

The burnouts obtained with 98% H_2O_2 appear to be the result of a sudden deterioration of the normal forced-convective heat-transfer mechanism caused by exothermic decomposition:



$$\Delta H = 23.4 \text{ Kcal/mole}$$

II, E, Discussion of Results (cont.)

A relationship between the burnouts and decomposition is indicated by the energy-balance calculations performed for the burnout and extended-duration tests. In the burnout tests, the energy balances tended to become increasingly negative as burnout was approached. By definition, a negative energy balance indicates an excess of sensible energy (Q_{out}) over the input electrical energy (Q_{in}). Such an excess in sensible energy was indicated at the burnout point in each of the burnout tests. As shown in Table II, the amount of excess energy ranged from 1.5 to 23%. Typical examples of the manner in which the apparent energy excess increased as burnout was approached are shown in Figure 26.

The energy balances for the extended-duration tests in which burnout occurred also indicate an increasing excess of sensible energy as burnout is approached. The magnitude of excess energy is somewhat less than observed in the burnout tests, ranging from 1.5 to 6%. As shown in Figures 27 through 32, a slowly increasing excess in sensible energy is indicated for each extended-duration test that terminated in burnout. Significantly, the energy balances for the extended duration tests where no burnout occurred do not show such a perceptible trend towards excess sensible energy. This is demonstrated in Figures 33 through 38.

The amounts of excess energy indicated at burnout are small and generally within the $\pm 10\%$ energy balance tolerance normally considered sufficient to ensure reliable heat-transfer data. However, the fact that this small excess was consistently observed prior to burnout is strong evidence that burnout is caused by exothermic decomposition of the 98% H_2O_2 .

Comparison of the heat of reaction (Equation 4) to the energy balances at burnout indicates that only 0.1 to 0.6% of the 98% H_2O_2 need decompose to yield the indicated excess energy. This is consistent with the fact that no large-scale H_2O_2 decomposition was observed throughout the course of testing. The lowest concentration measured was 96.3%, as shown in Table IV.

The onset of the decomposition which causes burnout is apparently quite sudden. In most of the tests, no degradation of the heat-transfer coefficient was observed prior to burnout. Only a slight degradation was indicated for some of the burnout tests and in four of the extended-duration tests which terminated in burnout. This degradation is evidenced by an increasing inner-wall temperature at relatively constant heat flux and velocity conditions, as shown in Figure 17 for Test HT-4-110 (burnout test) and in Figure 27 for Test HT-4-130 (extended-duration test).

II, E, Discussion of Results (cont.)

A plausible qualitative explanation of the 98% H_2O_2 burnout mechanism is obtained by considering a discrete packet of fluid which comes into contact with the heated wall for a certain period of time, δ , and is heated from its initial temperature, T_B (the bulk temperature of the main stream), to a new temperature T_B' .

$$T_B' = T_B + \frac{\phi \delta A_c}{C} \quad (\text{Eq 5})$$

where:

ϕ = heat flux, Btu/in.²sec

δ = contact time, sec

A_c = effective contact area, in.²

C = thermal capacity of fluid packet, Btu/°F

The packet then joins the main fluid stream and contributes to an increase in bulk temperature.

It is conceivable that a chemical decomposition begins when the temperature of the fluid packet reaches a certain value. If sufficient mixing occurs as a result of turbulence, a small amount of this decomposition can be quenched in the mainstream. Previous analyses (15) have shown that up to 0.5% of the decomposition products of 98% H_2O_2 can be dissolved in the mainstream at high pressures. This would account for the excess sensible energies observed prior to burnout. Eventually, as the heat flux is increased, the exothermic decomposition overcomes the turbulent quenching process, and high-temperature decomposition products suddenly cover the tube wall locally. Burnout is the result because of the drastic reduction in the liquid-side heat-transfer coefficient.

Equation 5 indicates that the temperature rise of a given fluid packet depends on the heat flux, ϕ , and on the contact time, δ . The contact time can be expected to decrease with an increased intensity of turbulence. Therefore, it is logical that the contact time would decrease with increased velocity. Consequently, at higher velocities, higher heat fluxes are required to raise the temperature of the packet to the point where excessive decomposition begins. This is consistent with the observed correlation between burnout heat flux and velocity; i.e., the heat flux at which burnout occurred was found to increase with velocity.

II, E, Discussion of Results (cont.)

It is not known why burnout in the extended-duration tests occurred at lower heat fluxes than expected; possibly, it may have been caused by microscopic changes in the surface of the tube walls which catalytically promoted the exothermic decomposition of H_2O_2 . However, examination of burned-out test sections revealed no obvious changes of the surfaces. (See Appendix A for further discussion.)

If the extended-duration burnouts are caused by microscopic changes in the exposed surface of the tubes, the tube material, the surface finish, and the passivation technique may be important factors affecting the burnout heat flux. The tests conducted during this investigation appear to confirm that a material effect exists, as shown by the different results obtained with Inconel 718 and stainless-steel tubing. However, a pressure effect may also exist and additional tests with Inconel 718 at low pressures and with stainless steel at high pressures are needed to clarify the influence of material and pressure on 98% H_2O_2 burnout heat flux. Testing with an unpassivated (but thoroughly cleaned) Inconel 718 test section (Test 143) indicated that nitric-acid passivation does not yield significantly different extended-duration burnout limits with this material. Alternative passivation techniques should be investigated for future testing.

b. Forced Convection

Local values of heat flux, inner-wall temperature, and heat-transfer coefficient calculated at each test-section thermocouple station and for each power level of the 98% burnout tests are given in Appendix B.

The data are correlated in terms of the Nusselt, Reynolds, and Prandtl numbers in Figures 39 and 40. Data points having energy balances greater than $\pm 10\%$ are not shown.

As shown in Figure 39, the two most commonly used bulk-temperature property equations do not correlate the test data very well. The most generally accepted correlation for high-velocity heat transfer is that developed by Hines (16):

$$Nu_b = 0.005 Re^{0.95} Pr^{0.4} \quad (\text{Eq 6})$$

A plot of this correlation passes through the center of the data, but deviations up to 80% are present. Part of this deviation is caused by L/D effects. The data for $L/D > 20$ correlate within $\pm 40\%$.

The Dittus-Boelter correlation (17):

$$Nu_b = 0.023 Re_b^{0.8} Pr_b^{0.4}$$

II, E, Discussion of Results (cont.)

yields conservative values for heat-transfer coefficients that will be sufficient for most design applications.

Use of average film-temperature properties does not improve the correlation, as shown in Figure 40. A Dittus-Boelter type equation evaluated with average film properties passes through the center of the data; however, deviations of +70% and -40% exist.

The correlation presented in Reference 18:

$$Nu = (Nu') \left(\frac{\mu_b}{\mu_w} \right)^{0.11} \left(\frac{k_b}{k_w} \right)^{-0.33} \left(\frac{\bar{c}_p}{c_{pb}} \right)^{0.35} \quad (\text{Eq 8})$$

where:

$$Nu' = \frac{(r/8) Re_b Pr_b}{12.7 \sqrt{r/8} (Pr_b^{2/3} - 1) + 1.07}$$

$$r = [1.82 \log_{10} Re_b - 1.64]^{-2}$$

$$\bar{c}_p = \frac{\int_{T_b}^{T_w} c_p dT}{T_w - T_b}$$

is compared to the observed heat flux-inner wall temperature data in Figures 19, 20, 22, and 24. This correlation predicts the general trend of the data although in some cases significant deviations are present. A modified version of this equation may yield a more precise correlation, and it is recommended that efforts be expended to obtain such a correlation. To this end, the actual data have been included in this report as Appendix B.

c. Pressure Drop

The results of the 98% H₂O₂ pressure-drop tests are shown in Tables V and VI. In two of these tests the pressure drop was evaluated during isothermal flow with bulk temperatures of 70 and 200°F. In five tests, the pressure drop with 70°F inlet temperature was evaluated at heat fluxes ranging from zero to 75% of the burnout heat flux observed in the burnout tests. These tests were conducted at pressures ranging from 3800 to 4600 psia and velocities from 50 to 200 ft/sec. Inconel 718 test sections were used in all the pressure-drop tests.

A. E. Discussion of Results (cont.)

Isothermal friction factors calculated from the data are shown in Figure 41 as a function of Reynolds number. These data generally agree with the standard charts for friction factor (19), but the dependency of experimental friction factor on Reynolds number is less than would be anticipated. The maximum deviation from the published curve for drawn tubing is about 18%. This discrepancy may have been caused by the fitting used to attach the pressure-transducer line to the test section (the fitting is shown in Figure 10). The fitting was observed to contract the diameter of the tube slightly in the region where it was fastened, producing a slight contraction and expansion at each end of the test section. This could conceivably yield pressure-drop characteristics different from those of a constant-diameter tube.

The ratio of pressure drop with and without heat transfer is shown in Figure 42 for velocities ranging from 55 to 188 ft/sec. Data were obtained at heat fluxes of 25, 50, and (except for Test 123) 75% of the burnout heat flux. In general, these curves are similar to those obtained for hydrazine in the nonboiling region reported in Reference 20. A certain amount of error exists in these calculated ratios because the pressure-drop measurements were obtained across heated and unheated sections of approximately equal length. The unusual behavior indicated at 98 ft/sec velocity and 4400 psia pressure (Test 122) is probably a result of this error. However, the data are considered valid, and they demonstrate that heated 98% H_2O_2 does not exhibit any unusual pressure-drop characteristics.

d. Testing Difficulties

Most of the 98% H_2O_2 tests were conducted without difficulty; however, certain problems attributable to equipment failure were encountered, and these are stated in the following paragraphs as a matter of record. No explosions or detonations ever occurred simply as a result of test-section burnout.

In Test HT-4-131, an inadvertent electrical connection of the power supplies allowed current to leak through an adjacent test system and back into normally unheated portions of the high-pressure heat-transfer loop. This resulted in heating of relatively stagnant 98% H_2O_2 , and ultimately caused detonations in a short length of tubing (connecting the main propellant valve to a drain valve) and in the drain lines. The test section was destroyed, apparently as a result of the pressure spikes produced by the detonations.

Test HT-4-132 was scheduled for a ten-minute duration, but was terminated after two minutes of steady power when the electrical insulator in the outlet pressure-transducer line failed and caused the 98%

II. E. Discussion of Results (cont.)

H₂O₂ in this line to heat-up and to detonate. This detonation collapsed the test-section tube at the point where the transducer line is attached, stopped the flow of 98% H₂O₂, and caused the test section to burn out.

2. 90% H₂O₂

Four burnout tests were conducted with 90% H₂O₂ at a nominal pressure of 4000 psia, at velocities of 45 to 155 ft/sec and bulk temperatures of 140 to 205°F. The 90% H₂O₂ was obtained by diluting the 98% H₂O₂ with deionized water after completion of the 98% H₂O₂ heat-transfer tests.

The results of these tests are listed in Table VII and compared to the 98% H₂O₂ data in Figure 43 together with the low-pressure 90% H₂O₂ data presented in References 2 and 4. Figure 43 shows that the burnout heat flux of 90% H₂O₂ is essentially the same as that of 98% H₂O₂ and correlates equally well with velocity. The 90% H₂O₂ forced-convection data also agree with the 98% H₂O₂ data. No extended-duration tests were conducted with 90% H₂O₂; however, it is recommended that behavior similar to that observed with 98% H₂O₂ be assumed for design purposes.

3. Water

Two burnout heat-flux tests were conducted with deionized water to checkout the loop prior to 98% H₂O₂ testing. In these water tests, pressures of 1000 and 2000 psia, velocities of 38 and 48 ft/sec, and bulk temperatures of 165 and 280°F were encountered.

The results obtained in the water tests are listed in Table VII. These results are compared in Figure 44 to the high-velocity, high-subcooling burnout data obtained for distilled and deionized water in a previous investigation (Ref 21). Good agreement with the previous data is apparent, and the expression:

$$\dot{q}_{BO} = 5.1 + 0.000860 (VAT_{sub})$$

yields predictions of the burnout heat flux within $\pm 20\%$.

III.

CONCLUSIONS AND RECOMMENDATIONS

III.

CONCLUSIONS AND RECOMMENDATIONS

A. The burnout heat flux of 98% H_2O_2 at pressures from 300 to 4700 psia, bulk temperatures from 130 to 298°F, and velocities from 14 to 198 ft/sec correlates with velocity. The burnout heat fluxes observed in burnout tests of relatively short duration are predicted within about 25% by the expression:

$$\dot{q}_{Bo} = 0.24 V$$

The burnout heat fluxes observed in the extended-duration tests were significantly lower than the burnout test values. The equation recommended for design:

$$\dot{q}_{Bo} = 0.16 V$$

yields a value which lies below all the observed burnout points.

B. The burnouts observed with 98% H_2O_2 appear to be caused by the sudden onset of exothermic decomposition in the boundary layer. Boiling or boiling-like phenomena were not observed at subcritical or supercritical pressures.

C. The long-duration burnout heat flux of 98% H_2O_2 is possibly dependent on tube material, surface conditions, and pressure. Further investigation of these effects is recommended.

D. No chemical attack of the Inconel 718 test sections by the 98% H_2O_2 was observed.

E. The Dittus-Boelter equation:

$$Nu_b = 0.023 Re_b^{0.8} Pr_b^{0.4}$$

yields a conservative estimate of heat-transfer coefficients for 98% H_2O_2 and is recommended for design purposes. Precise correlation of the forced-convection data was not obtained, but the general trend of these data is predicted by an equation which includes bulk-to-wall-temperature fluid property ratios.

F. Ninety-eight percent hydrogen peroxide does not exhibit any unusual pressure-drop characteristics at isothermal or heated conditions.

G. Ninety-eight percent H_2O_2 can be used as a regenerative coolant.

H. Test results clearly indicate that 98% H_2O_2 will not detonate at burnout.

REFERENCES

1. R. L. Ipsen, R. C. Keith, and B. W. Cathroe, Heat Transfer Characteristics of Alumazine 33Q50, Confidential, Aerojet-General Internal Report 034, 12 March 1963; Contract AF 04(647)-652 SA 4.
2. T. J. Devine, et al., Heat Transfer Characteristics of 98% Hydrogen Peroxide, Pratt and Whitney Aircraft, East Hartford, Conn., May 1961.
3. C. E. Sanborn, et al., "Convective Heat Transfer to Liquid 90% Hydrogen Peroxide at High Heat Flux," AIChE Preprint No. 21, Presented at the Sixth National Heat Transfer Conference, Boston, Massachusetts, August 1963.
4. N. J. Socolowski and R. H. Tromans, The Effect of Spiral Insert Flow Agitators on the Heat Transfer Properties of Hydrogen Peroxide, Reaction Motors Division of Thiokol Chemical Corp., Report RMD 103-F, Vol. I, for the Period June 1958 to December 1958.
5. H. Morinaka, "Liquid Side Heat Transfer Analysis with Several Fluids, Program 22105," Computing Sciences Division, Aerojet-General Corp., February 1966.
6. J. O. Sane, "Two-Dimensional Conduction in a Heat Generating Solid," Advanced Research Division Technical Memorandum, TM 183-62-35, Aerojet-General Corp., October 1962.
7. A. C. Kobayashi, "Specific Heat and Thermal Conductivities of Materials Commonly Used in Heat Transfer Calculations," Aerojet-General Internal Memorandum 9648:0406, December 1964.
8. W. R. Thompson, E. L. Geery, and J. F. Harkee, An Experimental Study of the Heat Transfer Characteristics of Nitrogen Tetroxide at Supercritical Pressure, Aerojet-General VKC Report TM 183-64-39, 12 June 1964, or Volume IV of Final Report on Improved Titan, Contract AF 04(694)-212.
9. W. R. Thompson and E. L. Geery, An Experimental Investigation of Heat Transfer to AeroZINE 50 at Supercritical Pressures, Aerojet-General Special Report 2654 (VKC), Contract AF 04(611)-8017, August 1963.
10. Heat Transfer Study of Prepackaged Propellants, Volume I: Technical, Aerojet-General Corporation Proposal LR 661032, January 1966.
11. Heat Transfer Study of Compound-A, Volume I: Technical, Aerojet-General Corporation, Proposal LR 661077, June 1966.

REFERENCES (cont.)

12. D. C. Rousar, "Correlation of Burnout Heat Flux for Fluids at High Velocity and High Subcooling Conditions," M.S. Thesis, University of California, Davis, June 1966.
13. Louis Bernath, "A Theory of Local-Boiling Burnout and its Application to Existing Data," Chemical Engineering Progress Symposium Series, No. 30, Volume 56, 1960.
14. W. H. Jens and P. H. Lottes, Analysis of Heat Transfer, Burnout, Pressure Drop, and Density Data for High-Pressure Water, Argonne National Laboratory Report ANL 4627, 1951.
15. N. H. Globus, et al., Informal Monthly Progress Report for September 1965, Advanced Propellant Staged Combustion Feasibility Program, Aerojet-General Corp., Report 10785-M-4, October 1965.
16. W. S. Hines, Turbulent Forced Convection Heat Transfer to Liquids at Very High Heat Fluxes and Flow Rates, Rocketdyne Research Report 61-14, November 1961.
17. W. H. McAdams, Heat Transmission, First Edition, McGraw Hill Book Company, New York, N.Y., p. 219.
18. B. S. Petukhov, E. A. Krasnoschekov, V. S. Protopopov, "An Investigation of Heat Transfer to Fluids Flowing in Pipes under Supercritical Conditions," Intl. Devel. in Heat Transfer, Part III, 1961, Intl. Heat Transfer Conference, Boulder, Colorado.
19. Victor L. Streeter, Fluid Mechanics, Second Edition, McGraw Hill Book Company, New York, N.Y., p. 183.
20. M. B. Noel, Experimental Investigation of Heat Transfer Characteristics of Hydrazine and a Mixture of 90% Hydrazine and 10% Ethylenediamine, Jet Propulsion Laboratory, Pasadena, California, Technical Report 32-109, June 1961.
21. W. R. Thompson and J. F. Harkes, Burnout Heat Fluxes with Distilled Water at High Velocities and High Degrees of Subcooling, Aerojet-General VKC Report 183-64-38, 20 May 1964, or Volume IV, Final Report on Improved Titan, Contract AF 04(694)-212.

TABLES

TABLES

TABLE I
TEST-SECTION DIMENSIONS

<u>Test</u>	<u>Material</u>	<u>OD, in.</u>		<u>Heated Length, in.</u>	<u>Measured ID, in.</u>	<u>Nominal Wall Thickness, in.</u>
		<u>Nom.</u>	<u>Meas.</u>			
HT-4-105	Inc. 718	1/4	--	5.0	--	0.015
-106	347 SS	1/4	--	4.0	--	0.016
HT-4-108	Inc. 718	1/4	--	5.0	--	0.015
-109	Inc. 718	3/16	--	4.0	--	0.015
-110	Inc. 718	3/16	--	3.5	--	0.015
-111	Inc. 718	3/16	--	4.0	--	0.015
-112	Inc. 718	1/4	--	4.5	--	0.015
-113	Inc. 718	1/4	--	5.0	--	0.015
-114	Inc. 718	3/16	--	4.5	--	0.015
-115	Inc. 718	3/16	--	5.0	--	0.015
-116	Inc. 718	3/16	--	3.5	--	0.015
-117	Inc. 718	3/16	--	4.0	--	0.015
-118,-119	Inc. 718	1/4	--	5.0	--	0.015
-120 to -123,						
& -125	Inc. 718	3/16	--	5.0	--	0.015
-124	Inc. 718	1/4	--	4.0	--	0.015
HT-4-126	Inc. 718	3/16	--	5.0	--	0.015
-127	Inc. 718	3/16	--	6.0	--	0.015
-128	Inc. 718	1/4	--	5.0	--	0.015
-129	Inc. 718	1/4	--	4.0	--	0.015
HT-4-130	Inc. 718	3/16	0.1895	4.0	0.160	0.015
-132	Inc. 718	3/16	0.1895	5.0	0.160	0.015
-133A,B	Inc. 718	3/16	0.1895	4.0	0.159	0.015
-134	Inc. 718	3/16	--	4.5	--	0.015
-135	Inc. 718	3/16	0.1895	4.0	0.159	0.015
-136A,B	Inc. 718	3/16	0.1895	4.0	0.159	0.015
-137A,B	Inc. 718	1/4	0.2540	5.0	0.224	0.015
-138	Inc. 718	3/16	--	5.0	--	0.015
-139	347 SS	3/16	0.1865	4.5	0.154	0.016
-140,-141,-142	347 SS	3/16	0.1855	4.5	0.154	0.016
-143A,B	Inc. 718	3/16	0.1895	4.0	0.159	0.015
-144A,B	Inc. 718	3/16	0.1895	4.0	0.159	0.015

TABLE II

98% H₂O₂ BURNOUT TEST RESULTS

Test	P, psia	V, ft/sec	T _B , °F	q _{Bo} , Btu/in. ² sec	X, in.	Energy** Balance, %	Type of Failure
HT-4-134	840	101.5	156	22.0	0.1	- 5.5	Complete severance
-139	860	106.0	147	18.6	0.1	- 1.5	Complete severance
HT-4-108	3020	49.4	190	12.2	0.1	- 8.0	Complete severance
-109	3020	91.0	176	19.6	1.1	-13.7	Severance in two places
-110***	2910	169.0	154	41.5	0.6	- 7.1	Severance and split tube
-113	4020	25.3	137	8.1	0.65	-16.9	Split tube
-124	4150	44.6	235	9.4	0.3	- 7.6	Severance and split tube
-112	3950	47.9	170	12.0	0.45	-24.0	Severance and split tube
-116	3930	91.5	156	20.7	0.65	-11.5	Severance and split tube
-111***	3860	96.5	130	24.8	0.65	- 8.0	Split tube
-114	3750	161.5	144	39.6	0.1	- 5.3	Complete severance
-117	3530	198.0	143	48.2	0.1	- 5.5	Complete severance
-115	4700	95.5	153	23.0	0.5	-10.8	Severance and split tube

*X = Distance from burnout point to downstream end of heated section, in.

**Energy balance = $\frac{Q_{in} - Q_{out}}{Q_{in}} \times 100\%$

***Heat Flux based on tube resistance

TABLE III
 EXTENDED-DURATION TEST RESULTS

Test Number	90% H ₂ O TESTS	Max. Vel., ft/sec	Outlet Pressure, psia	Outlet Temp., °F	Heat Flux, Btu/in. ² /sec	Inner Wall Temp., °F	Test-Section Material	Energy Balance, %	Remarks
130	150	3300	135	28.0	80	380 to 460	Inc 718	+ 2.0 to - 7.0	Burnout after 3 min
131	150	3300	130	28.0	78	300 to 330	Inc 718	- 2.0 to - 4.0	Burnout after 50 sec
132	150	2800	115	23.0	61	360 to 400	Inc 718	0.0 to - 2.0	No burnout, 5 min steady state
133	150	2800	130	24.5	67	420 to 470	Inc 718	- 1.0 to - 4.0	Burnout after 1 min
134	150	3500 to 3400	130	20.0	56	370 to 430	Inc 718	+ 2.0 to + 0.8	No burnout, 2 min steady state
135	150	3500 to 3400	120	20.0	56	300 to 340	Inc 718	+ 0.4 to + 0.2	No burnout, 4 min steady state
136	150	3500 to 2800	120	20.0	56	360 to 470	Inc 718 (3)	+ 1.5 to + 0.8	No burnout, 6 min steady state
137	150	3200 to 2800	120	22.5	61	360 to 360	Inc 718 (2)	+ 1.0 to + 0.5	No burnout, 2 min steady state
138	150	3200	120	22.5	61	360 to 390	Inc 718 (2)	+ 4.0 to + 3.0	No burnout, 4.5 min steady state
139	100	3500	155	16.0	67	480 to 330	Inc 718	+ 0.5 to - 5.0	Burnout after 1.7 min
140	100	850	130	13.5	53	340 to 360	347 8.8.	- 0.5 to - 1.0	No burnout, 9.5 min steady state
141	100	830	140	17.0	68	400 to 430	347 8.8.	+ 1.0 to - 0.5	No burnout, 9 min steady state
142	100	840	148	19.0	75	430 to 460	347 8.8.	- 0.2 to - 1.5	Burnout after 2 min
137A	50	3700	135	7.8	68	330 to 460	Inc 718	- 2.0 to - 4.0	No burnout, 5 min steady state
137B	50	3700	140	7.9	68	320 to 400	Inc 718	- 2.0 to - 6.0	Burnout after 3.3 min
144	150	3000	120	28.0	N/A	280 to 320	Inc 718	+ 2.0 to + 0.5	No burnout, 6 min steady state
145	150	3000	135	28.0	N/A	280 to 330	Inc 718	+ 3.0 to + 1.0	No burnout, 5 min steady state

WATER TESTS

(1) Indicates same test section as previous test.
 (2) Percentage of burnout heat flux indicated by Phase-I short-duration burnout data.
 (3) Test section unpassivated
 (4) $\frac{Q_{1s} - Q_{out}}{Q_{in}} \times 100\%$

TABLE IV

H₂O₂ CONCENTRATION DATA

Test	Wt % H ₂ O ₂ *		Date	Remarks
	Before Test	After Test		
HT-4-108	98.00	--	10/1/65	
-109	98.09	--	10/4	
-110	96.69	--	10/13	
-112	96.35	--	10/14	
-113	96.63	96.29	10/15	Refilled unit after Test 113.
-114	98.01	97.12	10/21	
-115	97.52	97.52	10/21	
-116	96.69	96.33	10/22	
-117	96.71	96.68	10/25	
-118	96.66	--	10/29	
-119	96.66	--	10/29	
-120	96.66	--	11/1	
-121	96.65	--	11/2	
-122	96.67	--	11/2	Fresh 98% H ₂ O ₂ added after Test 122.
-123	96.6	--	11/3	
-124	96.85	96.67	11/4	
-125	96.68	--	11/5	Diluted for 90% H ₂ O ₂ tests after Test 125.
-126	91.05	90.72	11/10	
-127	91.04	--	11/11	
-128	90.84	--	11/12	
-129	90.03	--	11/15	
-130	98.6**	98.6**	12/17	Refilled unit prior to Test 130.
-133B	--	97.54	1/11	
-135	--	96.5	1/19	
-139	96.45	96.64	2/2	
-140	96.25	96.45	2/3	
-141	96.5	96.2	2/3	
-143B	96.45	96.35	2/7	

*Determined by titration except Test 130

**Hydrometer data

TABLE V
98% H₂O ISOTHERMAL PRESSURE-DROP DATA

Test	P _{out} , psia	T _B , °F	Ẇ, lb/sec	ΔP	ID, in.	Total Length, in.	Re _b x 10 ⁻⁵	f
HT-4-118	4200	68.6	1.277	23.2	0.220	9.5	1.05	0.0191
V _{nom} = 50 ft/sec	--	205.1	1.197	21.3	--	--	2.50	0.0188
	--	205.0	1.197	21.3	--	--	2.50	0.0188
	--	70.0	1.276	23.0	--	--	1.07	0.0189
HT-4-119	4100	71.1	1.286	23.1	0.220	9.5	1.08	0.0187
V _{nom} = 54 ft/sec	--	71.4	1.276	22.7	--	--	1.07	0.0186
HT-4-120	4030	64.0	1.247	108.3	0.159	9.0	1.36	0.0193
V _{nom} = 100 ft/sec	3907	203.7	1.175	103.2	--	--	3.37	0.0195
	3848	66.6	1.224	104.1	--	--	1.37	0.0193
HT-4-121	4000	60.7	1.198	98.1	0.159	9.0	1.26	0.0190
V _{nom} = 100 ft/sec	--	61.3	1.172	93.8	--	--	1.24	0.0189
HT-4-122	4613	63.7	1.181	94.9	0.159	9.0	1.25	0.0189
V _{nom} = 100 ft/sec	4289	64.3	1.182	95.0	--	--	1.28	0.0189
HT-4-123	3060	63.4	2.230	329.5	0.159	9.0	2.41	0.0180
V _{nom} = 180 ft/sec	2670	63.1	2.192	318.4	--	--	2.36	0.0180
HT-4-125	3965	65.2	2.412	377.8	0.159	9.0	2.66	0.0180
V _{nom} = 200 ft/sec	3470	65.7	2.253	328.6	--	--	2.48	0.0180

TABLE VI
90% H₂O HEATED PRESSURE-DROP DATA

Test	P _{out} , psia	T _B in., °F	T _B out., °F	W, lb/sec	Btu / in. ² sec	Heated Length, in.	Unheated Length, in.	ID, in.	Total AP, psi	(ΔP) h ₂ O (ΔP) h ₂ O
HT-4-119	4128	70.6	87.2	1.280	3.07	5.0	4.5	0.22	20.7	0.832
	4122		99.8	1.277	6.08				19.7	0.756
	4116		113.6	1.273	9.09				19.5	0.740
HT-4-121	3975	59.8	77.2	1.190	4.41	5.0	4.0	0.159	89.0	0.834
	3956	60.1	95.8	1.190	9.66				87.1	0.800
	3899	59.9	112.4	1.190	14.47				85.8	0.784
HT-4-122	4539	63.2	81.4	1.180	4.49	5.0	4.0	0.159	83.7	0.787
	4447	63.4	99.0	1.180	9.57				85.2	0.815
	4354	63.5	115.9	1.190	14.60				86.5	0.840
HT-4-123	2819	60.5	85.6	2.260	10.89	5.0	4.0	0.159	324.3	0.940
	2733		102.1	2.240	20.33				315.6	0.920
HT-4-125	3792	63.5	84.5	2.360	10.49	5.0	4.0	0.159	347.9	0.925
	3687		100.6	2.325	19.97				337.4	0.920
	3548		118.2	2.280	29.90				324.7	0.915

*Calculated for the heated portion of the test section

TABLE VII
 BURNOUT TEST RESULTS FOR 90% H₂O₂ AND DEIONIZED WATER

<u>Test</u>	<u>Fluid</u>	<u>P, psia</u>	<u>V, ft/sec</u>	<u>T_B, °F</u>	<u>q_{Bo}, Btu/in.² sec</u>	<u>X, in.**</u>	<u>Energy Balance, %**</u>	<u>Type of Failure</u>
HT-4-105	Water	2000	48.1	165***	21.5	0.1	(3)	Severance
-106	Water	1020	38.0	282	14.6	0.1	+4.7	Severance
-129	90% H ₂ O ₂	3970	44.6	205	10.7	0.5	-4.3	Split tube
-128	90% H ₂ O ₂	4130	52.0	169	11.8	0.4	-4.6	Split tube
-127	90% H ₂ O ₂	3980	105.0	155	23.4	0.15	-1.5	Severance
-126	90% H ₂ O ₂	4060	155.0	141	36.1	0.1	-3.0	Severance

* X = distance from burnout point to downstream end of heated section

** Energy balance = $\frac{Q_{in} - Q_{out}}{Q_{in}} \times 100\%$

*** Bulk temperature calculated from power measurements because an inadvertent sudden increase in power produced burnout before the outlet bulk-temperature thermocouples achieved steady state.

Report A/RPL-TR-66-263

FIGURES



Figure 2. 10,000-psig Pressurization System




Figure 3. High-Pressure Heat-Transfer Loop




Figure 4. Preheater--Test-Section Assembly




Figure 5. Test-Section Schematic




Figure 6. Mounted Test Section.




Figure 7. Thermal Conductivity and Electrical Resistivity of Inconel-718 and 347 Stainless Steel




Figure 8. Complete Severance Burnout with Tube Split



Figure 9. Complete Severance Burnout without Tube Split




Figure 10. Buried with Complete Severance at Two Locations




Figure 11. Tube-Split Burnout




Figure 12. 98% H₂O₂ Burnout Test Results





Figure 13. Subcritical 98% H₂O₂ Burnout Test Results



HT-4-134

CONDITIONS AT BURNOUT POINT:


$P = 840 \text{ PSIA}$

$V = 101.5 \text{ FT/SEC}$

$T_b = 156^\circ\text{F}$

$\dot{q}_{Bo} = 22.0 \text{ BTU/IN.}^2 \text{ SEC}$

Figure 14. Subcritical 98% H_2O_2 Heat Flux-Wall Temperature Data, Test 134



HT-4-139

CONDITIONS AT BURNOUT POINT:


P = 860 PSIA

V = 106.0 FT/SEC

T_b = 147°F

q_{Bo} = 18.6 BTU/IN.² SEC


Figure 15. Subcritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 139



CONDITIONS AT BURNOUT POINT:

$P = 3020$ PSIA
 $V = 91$ FT/SEC
 $T_b = 176^\circ\text{F}$
 $q_{Bo} = 19.6$ BTU/IN.² SEC


Figure 16. Subcritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 109



HT-4-110
 CONDITIONS AT BURNOUT POINT:

$P = 2910$ PSIA
 $V = 169$ FT/SEC
 $T_b = 154^\circ\text{F}$
 $\dot{q}_{Bo} = 41.5$ BTU/IN.² SEC


Figure 17. Subcritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 110



CONDITIONS AT BURNOUT POINT

- P = 1020 PSIA
- V = 38.0 FT/SEC
- T_b = 282°F
- q_{w,c} = 14.6 BTU/IN.² SEC
- Δ - L/D = 16 (STA 1)
- - L/D = 10 (STA 2)

Figure 18. Deionized Water Heat Flux-Wall Temperature Data, Test 106




- △ STA 1 - L/D = 13.0
- STA 2 - L/D = 17.0
- STA 3 - L/D = 22.0
- ▲ INDICATES BURNOUT

HT-4-113

CONDITIONS AT BURNOUT POINT:

P = 4020 PSIA
 V = 25.3 FT/SEC
 T_b = 137°F
 q_{B_o} = 8.1 BTU/IN.² SEC

Figure 19. Supercritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 113




- △ STA 1 - L/D = 13.0
- STA 2 - L/D = 17.0
- ▲ INDICATES BURNOUT


HT-4-124

CONDITIONS AT BURNOUT POINT:

P = 4150 PSIA
 V = 44.6
 $T_b = 235^\circ\text{F}$
 $\dot{q}_{Bo} = 9.4 \text{ BTU/IN.}^2 \text{ SEC}$

Figure 20. Supercritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 124





HT-4-116

CONDITIONS AT BURNOUT POINT:


$P = 3930 \text{ PSIA}$

$V = 91.5 \text{ FT/SEC}$

$T_b = 156^\circ\text{F}$

$\dot{q}_{Bo} = 20.7 \text{ BTU/IN.}^2 \text{ SEC}$

Figure 22. Supercritical 98% H_2O_2 Heat Flux-Wall Temperature Data, Test 116



- STA 2 - L/D = 21.0
- STA 3 - L/D = 27.0
- INDICATES BURNOUT

HT-4-114

CONDITIONS AT BURNOUT POINT:


$P = 3750 \text{ PSIA}$

$V = 161.5 \text{ FT/SEC}$

$T_b = 144^\circ\text{F}$

$q_{Bo} = 39.6 \text{ BTU/IN.}^2 \text{ SEC}$

Figure 23. Supercritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 114



- Δ STA 1 - L/D = 17.0
- STA 2 - L/D = 24.0
- STA 3 - L/D = 30.0
- ▲ INDICATES BURNOUT

HT-4-115

CONDITIONS AT BURNOUT POINT:

P = 4700 PSIA
 V = 95.5 FT/SEC
 $T_b = 153^\circ\text{F}$
 $\phi_{Bo} = 23.0 \text{ BTU/IN.}^2 \text{ SEC}$

Figure 24. Supercritical 98% H₂O₂ Heat Flux-Wall Temperature Data, Test 115




Figure 25. Extended-Duration Test Results




Figure 26. Burnout Test-Energy Balances




Figure 27. 98% H₂O₂ Extended-Duration Test Parameters, Test 130




Figure 28. 98% H₂O₂ Extended-Duration Test Parameters, Test 135




Figure 29. 98% H₂O₂ Extended-Duration Test Parameters, Test 136

INCONEL 718
TEST SECTION
 $P_{OUT} = 3500 \text{ PSIA}$
 $T_{B \text{ OUT}} = 155^\circ\text{F}$




Figure 31. 98% H₂O₂ Extended-Duration Test Parameters, Test 138

347 STAINLESS STEEL
TEST SECTION

$P_{OUT} = 840$ PSIA

$T_{B OUT} = 148^{\circ}F$




Figure 32. 98% H₂O₂ Extended-Duration Test Parameters, Test 142

INCOHEL 718
TEST SECTION

$P_{OUT} = 3500 - 3400$ PSIA

$T_B OUT = 130^{\circ}F$




Figure 33. 98% H₂O₂ Extended-Duration Test Parameters, Test 132




Figure 34. 98% H₂O₂ Extended-Duration Test Parameters, Test 133




Figure 35. 98% H₂O₂ Extended-Duration Test Parameters, Test 143




Figure 36. 98% H₂O₂ Extended-Duration Test Parameters, Test 140




Figure 37. 98% H₂O₂ Extended-Duration Test Parameters, Test 141




Figure 38. Water Extended-Duration Test Parameters, Test 144




Figure 39. 98% H₂O₂ Forced-Convection Data Correlation Based on Bulk-Temperature Properties




Figure 40. 98% H₂O₂ Forced-Convection Data Correlation Based on Film-Temperature Properties

LEGEND

- Δ - ID = 0.220 IN.
- - ID = 0.159 IN.
- DRAWN TUBING: $\epsilon = 0.000005$ FT.
- SHADED: $T_b = 200^\circ\text{F}$
- UNSHADED: $T_b = 70^\circ\text{F}$
- ϵ/D = RELATIVE ROUGHNESS
- CURVES FROM REFERENCE 19




Figure 41. 98% H_2O_2 Isothermal Friction Factors




Figure 42. Pressure-Drop Data for Heated 98% H₂O₂




Figure 43. Comparison of 90% H₂O₂ and 98% H₂O₂ Burnout Test Results




Figure 44. Water Burnout Heat-Flux Data

Report AFAPL-TR-66-263

APPENDIX A

TEST-SECTION METALLOGRAPHIC EXAMINATIONS

APPENDIX A

TEST-SECTION METALLOGRAPHIC EXAMINATION

Two of the Inconel 718 test sections in which burnout occurred with 98% H_2O_2 were sectioned and examined for evidence of chemical attack. These test sections had been used in Tests HT-4-110 and HT-4-130.

Test 110 was a burnout test in which tube failure occurred at the following local conditions: heat flux, 41.5 Btu/in.² sec; velocity, 169 ft/sec; bulk temperature, 154°; pressure, 2910 psia.

Test 130 was an extended-duration test which terminated in burnout three minutes after steady state had been achieved at a heat flux of 28 Btu/in.² sec. The test-section outlet conditions for this test were velocity, 150 ft/sec; outlet pressure, 3300 psia; and outlet bulk temperature, 135°F.

The investigations and their results are discussed in the following two Materials R&D reports.

I.

MATERIALS R&D REPORT LRD 65-344

PURPOSE. To determine the material condition of an Inconel 718 heat-transfer test specimen (tubing) after exposure to hot, flowing hydrogen peroxide.

CONCLUSION. The Inconel 718 tubing material was not attacked by the hot, flowing hydrogen peroxide.

INVESTIGATION AND RESULTS. A section of annealed Inconel 718 tubing was submitted for observation after it was utilized in a heat-transfer test, in which 98% H₂O₂ was flowed through the tubing (heated electrically) until a burnout occurred. The tubing was cross-sectioned in the center (midway between the two electrical connections) and close to the point of burnout. These two sections were compared to a control specimen (i.e., a section of tubing that had not been exposed to H₂O₂) to determine the effect of H₂O₂ on the tube material (Figure 1). The total duration of testing was 3 min (from start to burnout). Power was increased gradually during this time until the burnout occurred. The average inner wall temperature at the end of the test was calculated to be 600°F.

Examination of the inner wall of the tubing showed that the hot H₂O₂ had very little, if any, effect on the Inconel 718 material. At a magnification of 500X the tube wall still appears to be relatively smooth, and no signs of intergranular attack are present (Figure 1).

DISCUSSION. The tubing utilized in heat-transfer testing is in the annealed condition. For heat-transfer test purposes, annealed Inconel 718 will give the same results as solution-annealed and aged material. However, for compatibility studies, the material should be tested in the condition in which it will be utilized in the finished hardware. If the Inconel 718 tubing will be solution-annealed and aged when put into service, it should be compatibility-tested in the same condition. The aging treatment of this material causes precipitation of a constituent by which the material is strengthened. Precipitation of a constituent sometimes changes the corrosion-resisting properties of a material, especially at the grain boundaries. In a previous compatibility study, tests indicated that hot N₂O₄ attacked solution-annealed and aged Inconel 718 at the grain boundaries.* Hydrogen peroxide may have the same effect on the material. Further, the test duration should be increased to equal the proposed life of the chamber tubes.

RECOMMENDATIONS. Solution-annealed and aged Inconel 718 tubing should be utilized in compatibility testing with the hot, flowing hydrogen peroxide.

Compatibility testing duration should be equivalent to the planned service life of the chamber tubes.

*Bechtold, R. F., Materials Development Report DVR 64-365, Aerojet-General Corporation, Liquid Rocket Components Department 4630, 15 July 1964.

II.

MATERIALS R&D REPORT FSC 66-135

PURPOSE. To determine if premature "burnthrough" of an Inconel 718 heat-transfer test specimen (tubing) was caused by corrosion attack.

CONCLUSIONS. The Inconel 718 tube material was not attacked (corroded) by the tube coolant (hydrogen peroxide).

Overheating of the tube at the test conditions of pressure and flow rate caused the tube to rupture.


HISTORY. Heat-transfer Test Specimen HT-4-130 (annealed 3/16-in.-dia Inconel 718 tubing) had been undergoing testing at a heat flux of 28 Btu/in.² sec (electrical resistance heating) for about 3 min when a rupture occurred 1 in. from the downstream electrode (Figures 2 and 3). Hydrogen peroxide with a concentration of 98% was flowing at a pressure of about 3000 psi through the tube at a rate of 150 ft/sec at the time of failure. Calculations indicate that the outer and inner wall temperatures were 1200 to 1300°F and 400 to 500°F, respectively, shortly before failure.

VISUAL OBSERVATIONS. Three cross-sections of the tube were mounted and polished for examination. Two cross-sections of the tube were taken in the immediate rupture area (Figures 4 and 5), and the third was taken about 1/4 in. away (Figure 6). Figure 5 shows that the tube melted completely through. No evidence of corrosion attack on the inner wall is present, and the inner surface of the tube appears to be relatively smooth even at a magnification of 500X (Figure 6). The tube wall thickness (0.015 in.) was unchanged by testing except in the immediate rupture area where it thinned to 0.014 in.

DISCUSSION. The tube specimen sustained a heat flux of 28 Btu/in.² sec for 3 min before rupture occurred. Heat-transfer data indicated that the tube should have been able to withstand the applied heat flux, fluid pressure (about 3000 psi), and coolant (hydrogen peroxide) flow rate without failure. However, the appearance of the failure indicates that overheating and melting initiated tube rupture. No evidence of corrosive attack was found, and the tube wall thickness was unchanged (except in the immediate rupture area where the reduction-in-area effect due to yielding thinned the tube).

Although short-duration heat-transfer data indicate that the tube material should withstand the conditions applied to the failed tube, several other heat-transfer test sections have failed during extended-duration operation at similar test conditions. Apparently, an unknown factor (possibly a catalytic reaction between the surface layer of the tube material and the hydrogen peroxide) remains to be determined. Further testing is necessary to determine the combination of maximum heat flux, pressure, and flow rate the Inconel 718 tube material will withstand.

RECOMMENDATIONS. Investigate and test for a catalytic reaction between Inconel 718 and hydrogen peroxide utilizing various temperatures and pressures.







Top: Inside surface of a tube that was not exposed to hot H_2O_2
(control specimen)

Center: Inside surface of a tube section cut from the approximate midpoint of the heat-transfer test specimen.

Bottom: ID area of a tube section cut approximately 3/16 in. from the burnout area (high temperature area).

The relatively smooth inside surface of the heat transfer test tubing indicates that no corrosion occurred during testing. No intergranular attack is evidenced. (Black spots in the material were caused by the etchant)


Figure 1. Photomicrographs Showing the Inside Surface (Tube ID) of the Inconel 718 Tubing Material (Magnification 500 X; Etchant-- HNO_3 , HCl , HF and H_2O)



Top: outer surface
Bottom: inner surface

Mag: 4X

Figure 2. Photographs of the Rupture Edges of the Tube (Right Side on Both Tubes). Arrows point to the area which appears to be the initial rupture area (see Figure 3).



Mag: 13X

Figure 3. Probable Area of Rupture Initiation (Areas of melted metal and several cracks appear. The microstructure of this area appears in Figure 4).



Etchant -- HNO_3 , HCl , HF & H_2O

Mag: 150X


Figure 4. Microstructure of the Tube in the Initial Failure Area. The OD of the tube is at the top of the photograph. Melted tube metal (darkened metal) appears in the center of the thinned area. Incipient melting at the grain boundaries probably initiated intergranular cracking (indicated by arrows).



Etchant -- HNO_3 , HCl , HF & H_2O

Mag: 100X

Figure 5. Failure Area of Smaller Tube Section Shown in Figure 2. Darkened metal shows that melting proceeded entirely through the tube. The ID of the tube appears to be unaffected by the hot hydrogen peroxide (no corrosion occurred).



Etchant: HNO_3 , HCl , HF & H_2O

Mag: 500X

Figure 6. Inside Surface of the Tube Approximately $1/4$ in. from Rupture Area. Staining, caused by the etchant, has darkened the edge, but no indications of corrosion attack are present.

BLANK PAGE

APPENDIX B

TABULATED HEAT-TRANSFER DATA

The outputs from the data-reduction computer program for the 98% H₂O₂ burnout tests, the extended-duration and heated pressure-drop tests, and the 90% H₂O₂ burnout tests are given on the following pages. The data are listed in numerical order, by test number. The equations for the data-reduction computer program are given in Section II,D of the main body of this report.

The output for each test consists of three sections: overall test parameters, local test parameters, and dimensionless parameters. The nomenclature for each section is described below.

Overall Test Parameters

AF	=	Test section flow area, ft ²
D	=	Test section inside diameter, ft
L	=	Heated length, in.
DELTA TO	=	Bulk temperature rise observed prior to application of test section power, °F
POINT, DATA POINT	=	Refers to a heat-flux level in the burnout tests and a certain time in the extended-duration tests
PB-IN	=	Inlet pressure, psia
PB-OUT	=	Outlet pressure, psia
TB-IN	=	Inlet bulk temperature, °F
TB-OUT	=	Outlet bulk temperature, °F
W	=	Flow rate, lb/sec
E2	=	Overall test-section voltage drop
I2	=	Test-section current, amp
QP	=	Electrical power, Btu/sec
HT BAL	=	Heat balance, %
G	=	Mass velocity, lb/sec ft

Report AFKPL-TR-66-263, Appendix B

Local Test Parameters

- STA = Refers to axial position where wall temperature was measured.
- PB = Local pressure, psia
- TB = Local bulk temperature, °F
- TV = Measured outside wall temperature, °F
- TI = Calculated inside wall temperature, °F
- Q/A = Heat flux calculated from wall temperature gradient, Btu/in.² sec
- Q/AP = Heat flux calculated from voltage and current measurements, Btu/in.² sec
- h = Heat-transfer coefficient based on Q/AP, Btu/in.² sec °F
- DEL TF = TI - TB
- VB = Local coolant velocity, ft/sec
- L/D = Length-to-diameter ratio based on length between data station and upstream end of heated length
- DELTA E = Voltage drop
- LE = Length over which ΔE was measured, in.

Dimensionless Parameters

- NU = Nusselt number based on bulk-temperature properties
- PR = Prandtl number based on bulk-temperature properties
- RE = Reynolds number based on bulk-temperature properties
- TI/TB = Ratio of inside wall temperature to bulk temperature, °R/°R
- NU/PR(0.4) = Nusselt No. / (Prandtl No.)^{0.4}
- RHO RATIO = Ratio of bulk-temperature density to wall-temperature density

Report AFRPL-TR-66-263, Appendix B

Dimensionless Parameters (cont.)

- K RATIO = Ratio of bulk-temperature thermal conductivity to wall-temperature thermal conductivity
- NU RATIO = Ratio of bulk-temperature viscosity to wall-temperature viscosity
- CP RATIO = Ratio of average specific heat to bulk-temperature specific heat, where:

$$\text{average specific heat} = \bar{C}_P = \frac{\int_{T_b}^{T_w} C_P dT}{T_w - T_b}$$

- NU(F) = Nusselt number based on average film-temperature properties
- PR(F) = Prandtl number based on average film-temperature properties
- RE(F) = Reynolds number based on average film-temperature properties
- TI/TF = Ratio of inside wall temperature to average film temperature, °R/°R
- TF = 1/2 (TB + TI)

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST HT-4-109 DATA POINT 7 IS BURNTOUT

AF = 0.138E-03 D = 0.132E-01 L = 0.400E 01 DELTA TO = 0.200E 01

DATA POINTS

POINT	P6-IN	P6-OUT	TB-IN	TB-OUT	W	E2	I2	OP	MT-RM	S
1	2.828E 03	2.845E 03	1.275E 04	1.418E 02	1.090E 00	1.499E 01	6.020E 02	9.554E 00	-6.679E-01	7.904E 03
2	3.070E 03	2.588E 03	1.295E 02	1.493E 02	1.110E 00	2.000E 01	7.943E 02	1.506E 01	-3.259E 00	6.049E 03
3	3.070E 03	2.588E 03	1.256E 02	1.591E 02	1.097E 00	2.415E 01	9.521E 02	2.180E 01	-1.971E 00	7.908E 03
4	3.070E 03	2.988E 03	1.257E 02	1.714E 02	1.090E 00	2.816E 01	1.100E 03	2.939E 01	-4.504E 00	7.904E 03
5	3.070E 03	2.988E 03	1.257E 02	1.787E 02	1.083E 00	3.037E 01	1.182E 03	3.404E 01	-4.558E 00	7.904E 03
6	3.074E 03	2.990E 03	1.260E 02	1.892E 02	1.075E 00	3.230E 01	1.259E 03	3.885E 01	-1.407E 01	7.904E 03
7	3.000E 03	3.000E 03	1.265E 02	1.941E 02	1.053E 00	3.264E 01	1.265E 03	3.914E 01	-1.370E 01	7.904E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST HT-4-109 DATA POINT 7 IS BURNTOUT

DATA POINT 1

DATA POINT	P6	TB	T*	TI	Q/A	Q/AP	H	DEL TF	VS
1	3.070E 03	1.330E 02	4.340E 02	2.539E 02	4.340E 00	4.420E 00	3.680E-02	1.201E 02	9.069E 01
2	3.070E 03	1.373E 02	3.370E 02	2.190E 02	4.365E 00	4.329E 00	5.259E-02	8.231E 01	9.032E 01
3	3.000E 03	1.469E 02	4.040E 02	2.305E 02	4.289E 00	4.292E 00	4.774E-02	8.969E 01	9.096E 01

DATA POINT	DELTA E	LE
1	3.835E 00	1.000E 00
2	3.700E 00	1.000E 00
3	2.743E 00	7.500E-01

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST FT-4-10, DATA POINT 7 IS BURNOUT

STA	PE	TC	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	1.000E-01	1.000E-00	0.170E 02	3.230E 02	7.974E 00	7.771E 00	4.140E-02	1.077E 02	9.243E 01
2	1.014E-02	1.014E-00	0.440E 02	2.515E 02	7.742E 00	7.642E 00	7.003E-02	1.091E 02	9.266E 01
3	1.000E-03	1.000E-00	0.000E 02	2.745E 02	7.370E 00	7.560E 00	5.947E-02	1.271E 02	9.290E 01
STA	L/O	DELTA T	LE						
1	1.010E-01	0.111E 00	1.000E 00						
2	1.000E-01	0.000E 00	1.000E 00						
3	1.000E-01	0.000E 00	7.500E-01						

LOCAL TEST PARAMETERS

TEST FT-4-10, DATA POINT 7 IS BURNOUT

STA	PE	TC	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	1.000E-01	1.000E-00	7.500E 02	3.932E 02	1.197E 01	1.128E 01	4.460E-02	2.529E 02	9.151E 01
2	1.014E-02	1.014E-00	7.000E 02	3.000E 02	1.121E 01	1.108E 01	7.317E-02	1.514E 02	9.184E 01
3	1.000E-03	1.000E-00	7.210E 02	3.323E 02	1.387E 01	1.091E 01	6.217E-02	1.735E 02	9.217E 01
STA	L/O	DELTA T	LE						
1	1.010E-01	0.100E 00	1.000E 00						
2	1.000E-01	0.000E 00	1.000E 00						
3	1.000E-01	0.000E 00	7.500E-01						

LOCAL TEST PARAMETERS

TEST FT-4-10, DATA POINT 7 IS BURNOUT

STA	PE	TC	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	1.000E-01	1.000E-00	0.710E 02	4.601E 02	1.574E 01	1.526E 01	4.854E-02	3.144E 02	9.114E 01
2	1.014E-02	1.014E-00	0.330E 02	4.347E 02	1.504E 01	1.490E 01	5.367E-02	2.776E 02	9.159E 01
3	1.000E-03	1.000E-00	0.000E 02	4.420E 02	1.457E 01	1.467E 01	5.363E-02	2.735E 02	9.204E 01
STA	L/O	DELTA T	LE						
1	1.010E-01	0.000E 00	1.000E 00						
2	1.000E-01	0.000E 00	1.000E 00						
3	1.000E-01	0.000E 00	7.500E-01						

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST HT-4-100 DATA POINT 7 IS BURNOUT

STA	P5	Td	Ta	Ti	Q/A	G/AP	M	DEL TF	VS
1	3.000E 03	1.800E 02	1.270E 03	4.937E 02	1.414E 01	1.766E 01	5.110E-02	3.450E 02	9.068E 01
2	3.015E 03	1.621E 02	9.801E 02	4.000E 02	1.754E 01	1.733E 01	7.234E-02	2.378E 02	9.119E 01
3	2.992E 03	1.754E 02	9.910E 02	4.330E 02	1.688E 01	1.700E 01	6.449E-02	2.636E 02	9.172E 01

STA	L/D	DELTA E	LE
1	1.101E 01	7.901E 00	1.000E 00
2	1.721E 01	7.855E 00	1.000E 00
3	2.300E 01	5.639E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST HT-4-100 DATA POINT 7 IS BURNOUT

STA	P5	Td	Ta	Ti	Q/A	G/AP	M	DEL TF	VS
1	3.007E 03	1.850E 02	1.132E 03	5.527E 02	2.053E 01	2.005E 01	5.023E-02	3.991E 02	9.019E 01
2	3.016E 03	1.659E 02	1.136E 03	5.255E 02	1.962E 01	1.958E 01	5.500E-02	3.560E 02	9.061E 01
3	2.995E 03	1.802E 02	1.118E 03	5.242E 02	1.901E 01	1.927E 01	5.684E-02	3.390E 02	9.143E 01

STA	L/D	DELTA E	LE
1	1.101E 01	8.217E 00	1.000E 00
2	1.721E 01	8.124E 00	1.000E 00
3	2.300E 01	5.955E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST HT-4-100 DATA POINT 7 IS BURNOUT

STA	P5	Td	Ta	Ti	Q/A	G/AP	M	DEL TF	VS
1	3.000E 03	1.500E 02	1.230E 03	6.054E 02	2.082E 01	2.011E 01	4.477E-02	4.493E 02	8.843E 01
2	3.020E 03	1.724E 02	1.180E 03	5.744E 02	1.984E 01	1.963E 01	4.894E-02	4.011E 02	8.919E 01
3	3.005E 03	1.508E 02	1.150E 03	5.351E 02	1.986E 01	1.963E 01	5.700E-02	3.443E 02	8.979E 01

STA	L/D	DELTA E	LE
1	1.101E 01	6.380E 00	1.000E 00
2	1.721E 01	1.431E 01	1.750E 00
3	2.300E 01	1.431E 01	1.750E 00

DIMENSIONLESS PARAMETERS

TEST FT-4-100, DATA POINT 7 IS CURNOUT

DATA POINT	STA	AU	PH	RE	TI/TB	MU/PH(0.4)
1	1	2.404E 02	3.137E 00	2.030E 05	1.202E 00	4.315E 02
1	2	9.657E 02	3.665E 00	2.124E 05	1.157E 00	6.199E 02
1	3	3.758E 02	2.965E 00	2.107E 05	1.149E 00	5.654E 02
2	1	7.049E 02	3.691E 00	2.140E 05	1.315E 00	4.870E 02
2	2	1.263E 03	4.937E 00	2.219E 05	1.181E 00	8.303E 02
2	3	1.000E 03	2.852E 00	2.292E 05	1.209E 00	7.105E 02
2	4	3.167E 02	4.999E 00	2.173E 05	1.421E 00	5.277E 02
2	5	1.248E 03	2.537E 00	2.275E 05	1.248E 00	6.750E 02
3	1	1.113E 03	4.885E 00	2.380E 05	1.244E 00	7.515E 02
3	2	6.385E 02	4.892E 00	2.235E 05	1.519E 00	5.783E 02
4	1	5.631E 02	2.683E 00	2.367E 05	1.449E 00	6.489E 02
4	2	4.486E 02	2.488E 00	2.524E 05	1.435E 00	6.591E 02
4	3	2.201E 02	2.532E 00	2.242E 05	1.566E 00	6.122E 02
5	1	1.355E 03	4.595E 00	2.419E 05	1.382E 00	8.871E 02
5	2	1.131E 03	4.758E 00	2.606E 05	1.414E 00	8.005E 02
6	1	5.851E 02	2.745E 00	2.290E 05	1.650E 00	6.045E 02
6	2	9.718E 02	2.470E 00	2.501E 05	1.565E 00	5.768E 02
6	3	6.660E 02	4.232E 00	2.728E 05	1.525E 00	7.155E 02
7	1	6.981E 02	4.704E 00	2.272E 05	1.729E 00	5.405E 02
7	2	4.665E 02	4.407E 00	2.506E 05	1.633E 00	6.057E 02
7	3	5.339E 02	4.163E 00	2.747E 05	1.529E 00	7.230E 02

DATA POINT	STA	K RATIO	MU RATIO	CP RATIO
1	1	6.529E-01	1.800E 00	9.9507E-01
1	2	5.144E-01	1.531E 00	9.9555E-01
1	3	5.126E-01	1.575E 00	9.9434E-01
2	1	4.758E-01	2.327E 00	9.9526E-01
2	2	5.049E-01	1.697E 00	9.9267E-01
2	3	5.036E-01	1.801E 00	9.9247E-01
2	4	6.045E-01	2.848E 00	1.0029E 00
2	5	6.702E-01	1.934E 00	9.9292E-01
3	1	4.035E-01	2.147E 00	9.9487E-01
3	2	5.035E-01	3.427E 00	1.0186E 00
3	3	5.312E-01	3.014E 00	1.0130E 00
3	4	4.282E-01	2.845E 00	1.0145E 00
3	5	5.282E-01	3.669E 00	1.0263E 00
4	1	5.124E-01	2.752E 00	1.0131E 00
4	2	5.631E-01	4.116E 00	1.0415E 00
4	3	4.899E-01	3.540E 00	1.0338E 00
4	4	5.829E-01	3.239E 00	1.0334E 00
4	5	1.014E 00	4.541E 00	1.0581E 00
7	1	1.005E 00	3.660E 00	1.0478E 00
7	2	5.743E-01	3.225E 00	1.0354E 00

DIMENSIONLESS PARAMETERS

TEST HT-9-109 DATA POINT 7 IS BURDOUT

DATA POINT	STA	NU(F)	PR(F)	RE(F)	TL/TP	NUMERICAL
1	1	6.3334E 02	2.1216E 00	2.8177E 05	1.0919E 00	4.6879E 02
1	2	9.1955E 02	2.3285E 00	2.6222E 05	1.0643E 00	6.5376E 02
1	3	6.2819E 02	2.2236E 00	2.7234E 05	1.0490E 00	6.0100E 02
2	1	6.9357E 02	1.7696E 00	3.3160E 05	1.1261E 00	6.0091E 02
2	2	1.2026E 03	2.0916E 00	2.9115E 05	1.0831E 00	6.0000E 02
2	3	1.0087E 03	1.9334E 00	3.1060E 05	1.0947E 00	7.7406E 02
3	1	7.3475E 02	1.5109E 00	3.7398E 05	1.1740E 00	6.2261E 02
3	2	1.2292E 03	1.6186E 00	3.2296E 05	1.1106E 00	6.6205E 02
3	3	1.0332E 03	1.6539E 00	3.4948E 05	1.1308E 00	6.4400E 02
4	1	7.9083E 02	1.3071E 00	4.2164E 05	1.2040E 00	7.1040E 02
4	2	8.7598E 02	1.3636E 00	4.1373E 05	1.1826E 00	7.7034E 02
4	3	8.7327E 02	1.2926E 00	4.3002E 05	1.1787E 00	7.8807E 02
5	1	8.3099E 02	1.2145E 00	4.4700E 05	1.2206E 00	7.4434E 02
5	2	1.1940E 03	1.4259E 00	3.9142E 05	1.1605E 00	1.0310E 01
5	3	1.0497E 03	1.2028E 00	4.3143E 05	1.1710E 00	9.8030E 02
6	1	8.1383E 02	1.0816E 00	4.9122E 05	1.2404E 00	7.0000E 02
6	2	8.9117E 02	1.1018E 00	4.8727E 05	1.2200E 00	8.5707E 02
6	3	9.2093E 02	1.0734E 00	5.0220E 05	1.2080E 00	8.9520E 02
7	1	7.2642E 02	9.9146E-01	5.2272E 05	1.2672E 00	7.2822E 02
7	2	7.9355E 02	1.0102E 00	5.1732E 05	1.2403E 00	7.9034E 02
7	3	9.2366E 02	1.0446E 00	5.0526E 05	1.2092E 00	9.0700E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 110 CURRENT CALC CURRENT AFTER DATA POINT 8

AF = 0.118E-03 D = 0.132E-01 L = 0.350E 01 DELTA TO = 0.430E 01

DATA POINTS

POINT	Pd-IN	Wd-GUT	Td-IN	Td-OUT	W	E2	I2	SP	ME BAL	S
1	2.214E 04	2.014E 03	1.004E 02	1.078E 02	2.030E 00	9.950E 00	4.520E 02	4.264E 00	5.593E 00	1.472E 04
2	2.200E 03	2.005E 03	1.000E 02	1.140E 02	2.020E 00	2.020E 01	9.000E 02	1.728E 01	-2.413E 00	1.448E 04
3	2.137E 03	2.531E 03	9.990E 01	1.334E 02	2.020E 00	2.997E 01	1.300E 03	3.620E 01	-2.292E 00	1.448E 04
4	2.150E 03	2.965E 03	9.930E 01	1.460E 02	1.960E 00	3.610E 01	1.590E 03	8.399E 01	-4.560E-01	1.421E 04
5	2.125E 02	2.930E 03	1.000E 02	1.511E 02	2.000E 00	3.745E 01	1.610E 03	8.777E 01	-2.530E 00	1.420E 04
6	2.105E 03	2.920E 03	1.000E 02	1.539E 02	1.985E 00	3.675E 01	1.647E 03	8.880E 01	-4.420E 00	1.438E 04
7	2.005E 03	2.900E 03	1.000E 02	1.560E 02	1.990E 00	3.980E 01	1.647E 03	8.214E 01	-7.500E 00	1.443E 04
8	2.075E 03	2.885E 03	1.000E 02	1.600E 02	1.965E 00	4.055E 01	1.725E 03	6.631E 01	-7.060E 00	1.439E 04

Report AFRPL-TR-66-263, Appendix B

TEST SECTION

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC BURNOUT AFTER DATA POINT 5

STA	L/U	PB	TL	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS
1	1.114E 03	1.041E 02	2.550E 02	2.550E 02	2.520E 00	2.520E 00	2.430E 00	2.430E 00	5.095E-02	4.136E 01	1.660E 02
2	3.070E 03	1.050E 02	2.570E 02	2.570E 02	2.520E 00	2.520E 00	2.430E 00	2.430E 00	5.951E-02	4.097E 01	1.657E 02
3	3.020E 03	1.073E 02	2.590E 02	2.590E 02	2.520E 00	2.520E 00	2.430E 00	2.430E 00	5.880E-02	4.144E 01	1.670E 02
STA	L/U	DELTA E	LE								
1	1.101E 01	5.550E 00	3.500E 00								
2	1.541E 01	5.550E 00	3.500E 00								
J	2.044E 01	5.550E 00	3.500E 00								

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC BURNOUT AFTER DATA POINT 2

STA	L/U	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS
1	3.162E 03	1.055E 02	6.310E 02	6.310E 02	2.481E 02	1.021E 01	9.885E 00	7.108E-02	1.391E 02	1.663E 02
2	3.041E 03	1.129E 02	6.290E 02	6.290E 02	2.455E 02	1.021E 01	9.885E 00	7.452E-02	1.326E 02	1.666E 02
3	3.017E 03	1.167E 02	6.430E 02	6.430E 02	2.595E 02	1.020E 01	9.885E 00	6.921E-02	1.420E 02	1.640E 02
STA	L/U	DELTA E	LE							
1	1.101E 01	2.026E 01	3.500E 00							
2	1.574E 01	2.016E 01	3.500E 00							
3	2.044E 01	2.026E 01	3.500E 00							

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC BURNOUT AFTER DATA POINT 6

STA	L/U	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS
1	3.067E 03	1.106E 02	1.065E 03	1.065E 03	3.465E 02	2.180E 01	2.112E 01	9.190E-02	2.290E 02	1.660E 02
2	3.047E 03	1.258E 02	1.062E 03	1.062E 03	3.425E 02	2.180E 01	2.112E 01	9.673E-02	2.184E 02	1.673E 02
3	3.005E 03	1.310E 02	1.072E 03	1.072E 03	3.565E 02	2.179E 01	2.112E 01	9.367E-02	2.255E 02	1.679E 02
STA	L/U	DELTA E	LE							
1	1.101E 01	2.557E 01	3.500E 00							
2	1.572E 01	2.557E 01	3.500E 00							
J	2.044E 01	2.557E 01	3.500E 00							

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC CURRENT AFTER DATA POINT 0

DATA POINT 4

STA	PL	TI	TM	U/A	U/AP	M	DEL TF	VS
1	0.072E 03	1.029E 02	1.397E 03	3.012E 01	3.033E 01	9.067E-02	3.346E 02	1.623E 02
2	2.015E 03	1.527E 02	1.395E 03	3.130E 01	3.033E 01	1.047E-01	2.704E 02	1.630E 02
3	2.972E 03	1.427E 02	1.376E 03	3.130E 01	3.033E 01	1.072E-01	2.831E 02	1.637E 02

STA	L/D	DELTA C	LE
1	1.111E 01	3.010E 01	3.500E 00
2	1.572E 01	3.010E 01	3.500E 00
3	2.044E 01	3.010E 01	3.500E 00

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC CURRENT AFTER DATA POINT 5

DATA POINT 5

STA	PL	TI	TM	U/A	U/AP	M	DEL TF	VS
1	0.072E 03	1.029E 02	1.470E 03	3.032E 01	3.304E 01	9.056E-02	3.352E 02	1.650E 02
2	2.015E 03	1.527E 02	1.455E 03	3.032E 01	3.304E 01	1.131E-01	2.921E 02	1.666E 02
3	2.972E 03	1.427E 02	1.470E 03	3.032E 01	3.304E 01	1.086E-01	3.042E 02	1.674E 02

STA	L/D	DELTA C	LE
1	1.101E 01	3.075E 01	3.500E 00
2	1.572E 01	3.075E 01	3.500E 00
3	2.044E 01	3.075E 01	3.500E 00

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC CURRENT AFTER DATA POINT 6

DATA POINT 6

STA	PL	TI	TM	U/A	U/AP	M	DEL TF	VS
1	0.072E 03	1.029E 02	1.523E 03	3.594E 01	3.460E 01	1.005E-01	3.443E 02	1.687E 02
2	2.015E 03	1.527E 02	1.503E 03	3.594E 01	3.460E 01	1.134E-01	3.050E 02	1.658E 02
3	2.972E 03	1.427E 02	1.491E 03	3.594E 01	3.460E 01	1.273E-01	2.717E 02	1.663E 02

STA	L/D	DELTA C	LE
1	1.101E 01	3.675E 01	3.500E 00
2	1.572E 01	3.675E 01	3.500E 00
3	2.044E 01	3.675E 01	3.500E 00

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC BURNOUT AFTER DATA POINT 8

STA	FB	TB	TW	TI	O/A	G/AP	M	DEL TP	VS
1	2.93E 03	1.243E 02	1.025E 03	5.542E 02	3.700E 01	3.554E 01	0.343E-02	4.259E 02	1.652E 02
2	2.93E 03	1.404E 02	1.560E 03	4.675E 02	3.788E 01	3.554E 01	1.007E-01	3.271E 02	1.681E 02
3	2.913E 03	1.526E 02	1.560E 03	4.551E 02	3.787E 01	3.884E 01	1.178E-01	2.668E 02	1.662E 02
STA	L/D	DELTA E	LE						
1	1.101E 01	3.580E 01	3.500E 00						
2	1.572E 01	3.560E 01	3.500E 00						
3	2.044E 01	3.580E 01	3.500E 00						

LOCAL TEST PARAMETERS

TEST 110 CURRENT CALC BURNOUT AFTER DATA POINT 8

STA	FB	TB	TW	TI	O/A	G/AP	M	DEL TP	VS
1	2.980E 03	1.300E 02	1.710E 03	6.303E 02	3.942E 01	3.792E 01	7.579E-02	5.603E 02	1.649E 02
2	2.939E 03	1.429E 02	1.630E 03	5.103E 02	3.930E 01	3.792E 01	1.032E-01	3.674E 02	1.650E 02
3	2.899E 03	1.557E 02	1.615E 03	4.872E 02	3.930E 01	3.792E 01	1.104E-01	3.315E 02	1.687E 02
STA	L/D	DELTA E	LE						
1	1.101E 01	4.055E 01	3.500E 00						
2	1.572E 01	4.055E 01	3.500E 00						
3	2.044E 01	4.055E 01	3.500E 00						

DIMENSIONLESS PARAMETERS

TEST 110 CURRENT CALC BURNDUT AFTER DATA POINT 8

DATA POINT	STA	MU	PR	RE	TL/TB	MU/PR(1.4)
1	1	1.1432E 03	3.9635E 00	3.1775E 05	1.0733E 00	6.5770E 02
1	2	1.1515E 03	3.9347E 00	3.2106E 05	1.0729E 00	6.5574E 02
1	3	1.1349E 03	3.8802E 00	3.2464E 05	1.0731E 00	6.5970E 02
2	1	1.3682E 03	3.8286E 00	3.2710E 05	1.2444E 00	7.9990E 03
2	2	1.4261E 03	3.7072E 00	3.3061E 05	1.2318E 00	8.4430E 03
2	3	1.5167E 03	3.5919E 00	3.4482E 05	1.2377E 00	7.8050E 02
3	1	1.7466E 03	3.5938E 00	3.4467E 05	1.3966E 00	1.0482E 03
3	2	1.6208E 03	3.3657E 00	3.5242E 05	1.3740E 00	1.1179E 03
3	3	1.7445E 03	3.2029E 00	3.7957E 05	1.3818E 00	1.6951E 03
4	1	1.7096E 03	3.4183E 00	3.4884E 05	1.5743E 00	1.8004E 03
4	2	2.0390E 03	3.1644E 00	3.7200E 05	1.4664E 00	1.2848E 03
4	3	1.9627E 03	2.9515E 00	3.9388E 05	1.4697E 00	1.2730E 03
5	1	1.3564E 03	3.3395E 00	3.6299E 05	1.5724E 00	1.1424E 03
5	2	2.0654E 03	3.0787E 00	3.6827E 05	1.4697E 00	1.1325E 03
5	3	1.9761E 03	2.8595E 00	4.1246E 05	1.5007E 00	1.8900E 03
6	1	1.2829E 03	3.3031E 00	3.6358E 05	1.5665E 00	1.1679E 03
6	2	2.0596E 03	3.0362E 00	3.8976E 05	1.5997E 00	1.3401E 03
6	3	2.3081E 03	2.8111E 00	4.1514E 05	1.4454E 00	1.5265E 03
7	1	1.5609E 03	3.2669E 00	3.6766E 05	1.7240E 00	9.7134E 02
7	2	1.9542E 03	2.9964E 00	3.9500E 05	1.5447E 00	1.2820E 03
7	3	2.1225E 03	2.7654E 00	4.2184E 05	1.4930E 00	1.4120E 03
8	1	1.4136E 03	3.2271E 00	3.7064E 05	1.8480E 00	8.8474E 02
8	2	1.8846E 03	2.9478E 00	3.9932E 05	1.8095E 00	1.2243E 03
8	3	2.0584E 03	2.7085E 00	4.2807E 05	1.5383E 00	1.3817E 03

DATA POINT	STA	MU RATIO	K RATIO	MU RATIO	CP RATIO
1	1	1.0177E 00	9.4074E-01	1.3035E 00	9.9757E-01
1	2	1.0175E 00	9.4143E-01	1.2977E 00	9.9806E-01
1	3	1.0177E 00	9.4102E-01	1.2976E 00	1.0005E 00
2	1	1.0628E 00	8.6274E-01	2.0689E 00	9.9359E-01
2	2	1.0598E 00	8.6885E-01	1.9970E 00	9.9542E-01
2	3	1.0647E 00	8.6857E-01	2.0569E 00	9.9798E-01
3	1	1.1023E 00	8.5226E-01	2.3569E 00	9.9596E-01
3	2	1.1010E 00	8.6162E-01	2.6844E 00	9.9751E-01
3	3	1.1070E 00	8.7064E-01	2.7044E 00	1.0006E 00
4	1	1.1497E 00	8.7590E-01	3.9013E 00	1.0190E 00
4	2	1.1559E 00	8.7743E-01	3.1962E 00	1.0095E 00
4	3	1.1607E 00	8.9342E-01	3.1824E 00	1.0137E 00
5	1	1.1762E 00	8.3004E-01	3.8859E 00	1.0215E 00
5	2	1.1812E 00	8.6612E-01	3.3212E 00	1.0151E 00
5	3	1.1839E 00	8.6603E-01	3.3323E 00	1.0190E 00
6	1	1.1764E 00	8.6633E-01	3.4351E 00	1.0247E 00
6	2	1.1838E 00	8.9234E-01	3.4735E 00	1.0182E 00
6	3	1.1847E 00	8.9104E-01	3.0231E 00	1.0118E 00
7	1	1.2620E 00	8.5128E-01	4.7667E 00	1.0459E 00
7	2	1.1674E 00	8.9024E-01	3.6029E 00	1.0233E 00
7	3	1.1544E 00	8.9449E-01	3.2740E 00	1.0192E 00
8	1	1.2594E 00	1.0019E 00	5.5193E 00	1.0726E 00
8	2	1.1678E 00	9.2470E-01	3.9580E 00	1.0330E 00
8	3	1.1713E 00	9.4988E-01	3.4641E 00	1.0263E 00

Report AFRPL-TR-66-263, Appendix B

DIMENSIONLESS PARAMETERS

TEST 110 CURRENT CALC CURRENT AFTER DATA POINT 8

DATA POINT	STA	MU(F)	PR(F)	RE(F)	TL/TP	WAVELENGTH
1	1	1.1081E 03	3.3600E 00	3.6336E 05	1.6384E 00	6.6230E 02
1	2	1.1165E 03	3.3260E 00	3.6649E 05	1.6398E 00	6.5937E 02
1	3	1.1000E 03	3.2762E 00	3.7106E 05	1.6382E 00	6.6039E 02
2	1	1.2437E 03	2.3267E 00	4.8045E 05	1.1009E 00	8.8091E 02
2	2	1.3030E 03	2.3190E 00	4.8282E 05	1.1036E 00	8.7978E 02
2	3	1.1987E 03	2.1943E 00	5.0515E 05	1.1102E 00	8.7540E 02
3	1	1.5493E 03	1.7566E 00	6.8260E 05	1.1662E 00	1.2287E 03
3	2	1.6188E 03	1.7435E 00	6.8007E 05	1.1578E 00	1.2316E 03
3	3	1.5587E 03	1.6619E 00	6.3448E 05	1.1602E 00	1.2723E 03
4	1	1.4832E 03	1.3788E 00	7.1734E 05	1.2318E 00	1.3044E 03
4	2	1.3055E 03	1.4852E 00	6.7628E 05	1.1891E 00	1.2616E 03
4	3	1.7560E 03	1.4071E 00	7.1119E 05	1.1902E 00	1.3317E 03
5	1	1.6109E 03	1.3594E 00	7.4201E 05	1.2235E 00	1.4267E 03
5	2	1.6539E 03	1.4165E 00	7.1968E 05	1.1907E 00	1.6129E 03
5	3	1.7724E 03	1.3217E 00	7.6763E 05	1.2002E 00	1.8088E 03
6	1	1.6401E 03	1.3264E 00	7.5281E 05	1.2268E 00	1.4649E 03
6	2	1.8549E 03	1.3690E 00	7.3616E 05	1.2031E 00	1.6398E 03
6	3	2.0851E 03	1.3961E 00	7.2749E 05	1.1822E 00	1.8246E 03
7	1	1.3532E 03	1.1253E 00	8.7084E 05	1.2658E 00	1.2988E 03
7	2	1.7711E 03	1.2982E 00	7.7347E 05	1.2141E 00	1.5958E 03
7	3	1.3150E 03	1.2979E 00	7.7773E 05	1.1906E 00	1.7233E 03
8	1	1.2306E 03	9.8883E-01	9.7791E 05	1.2978E 00	1.2361E 03
8	2	1.6756E 03	1.1866E 00	8.3482E 05	1.2336E 00	1.5888E 03
8	3	1.5589E 03	1.2091E 00	8.2599E 05	1.2121E 00	1.7230E 03

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 112 BURNOUT AT DATA POINT 7

AF = 0.264E-03 D = 0.103E-01 L = 0.450E 01 DELTA TD = 0.900E 00

POINT	Pa-IN	PB-OUT	TB-IN	TB-OUT	W	E2	I2	QP	MT BAL	G
1	3.956E 03	3.943E 03	1.089E 02	1.181E 02	1.100E 00	9.010E 00	4.638E 02	3.962E 00	-4.742E 01	4.167E 03
2	3.950E 03	3.935E 03	1.092E 02	1.311E 02	1.095E 00	1.522E 01	7.730E 02	1.115E 01	-3.204E 01	4.140E 03
3	3.950E 03	3.973E 03	1.095E 02	1.437E 02	1.097E 00	2.036E 01	1.020E 03	1.969E 01	-2.254E 01	4.155E 03
4	3.973E 03	3.956E 03	1.085E 02	1.571E 02	1.110E 00	2.436E 01	1.209E 03	2.792E 01	-2.174E 01	4.205E 03
5	3.970E 03	3.955E 03	1.065E 02	1.649E 02	1.090E 00	2.630E 01	1.302E 03	3.246E 01	-1.972E 01	4.129E 03
6	3.959E 02	3.950E 03	1.099E 02	1.762E 02	1.085E 00	2.808E 01	1.385E 03	3.687E 01	-2.548E 01	4.110E 03
7	3.945E 03	3.940E 03	1.090E 02	1.757E 02	1.082E 00	2.825E 01	1.400E 03	3.749E 01	-2.399E 01	4.098E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 112 BURNOUT AT DATA POINT 7

STA	L/D	DELTA E	LE	DATA POINT	I	J/AP	H	DEL TF	VS
1	1.024E 01	4.00E 00	2.000E 00	1.741E 02	1.209E 00	1.297E 00	2.009E-02	5.457E 01	4.739E 01
2	1.073E 01	4.00E 00	2.000E 00	1.572E 02	1.271E 00	1.247E 00	3.111E-02	4.161E 01	4.743E 01
3	1.044E 01	1.070E 02	7.000E-01	2.110E 02	5.982E-01	8.904E-01	9.639E-03	3.238E 01	4.748E 01

LUCAL TEST PARAMETERS

TEST 112 BURROUT AT DATA POINT 7

STA	PG	FB	TL	TB	TI	Q/A	Q/AP	M	DEL TF	VS
1	2.992E-03	1.221E-02	4.190E-02	2.759E-02	3.558E-00	3.641E-00	2.338E-02	1.597E-02	4.731E-01	
2	2.939E-03	1.250E-02	3.970E-02	2.520E-02	3.563E-00	3.641E-00	2.854E-02	1.276E-02	4.741E-01	
3	2.852E-03	1.259E-02	4.950E-02	3.730E-02	3.533E-00	3.533E-00	1.453E-02	2.631E-02	4.751E-01	
STA	L/D	DELTA C	LE							
1	1.024E-01	6.670E-00	2.000E-00							
2	1.477E-01	6.270E-00	2.000E-00							
3	1.433E-01	2.500E-00	7.500E-01							

LUCAL TEST PARAMETERS

TEST 112 BURROUT AT DATA POINT 7

STA	PG	FB	TL	TB	TI	Q/A	Q/AP	M	DEL TF	VS
1	2.501E-03	1.215E-02	6.050E-02	3.745E-02	6.280E-00	6.420E-00	2.584E-02	2.434E-02	4.733E-01	
2	2.770E-03	1.255E-02	5.850E-02	3.515E-02	6.288E-00	6.420E-00	2.951E-02	2.175E-02	4.767E-01	
3	2.974E-03	1.417E-02	5.330E-02	4.465E-02	5.966E-00	6.266E-00	2.058E-02	3.045E-02	4.783E-01	
STA	L/D	DELTA C	LE							
1	1.022E-01	5.100E-00	2.000E-00							
2	1.472E-01	5.150E-00	2.000E-00							
3	1.520E-01	3.300E-00	7.500E-01							

LUCAL TEST PARAMETERS

TEST 112 BURROUT AT DATA POINT 7

STA	PG	FB	TL	TB	TI	Q/A	Q/AP	M	DEL TF	VS
1	3.225E-03	1.220E-02	7.440E-02	4.336E-02	8.899E-00	9.094E-00	3.024E-02	2.000E-02	4.822E-01	
2	3.502E-03	1.256E-02	7.300E-02	4.109E-02	8.500E-00	9.094E-00	3.327E-02	2.733E-02	4.824E-01	
3	3.859E-03	1.244E-02	5.130E-02	3.304E-02	8.423E-00	8.864E-00	2.358E-02	3.760E-02	4.866E-01	
STA	L/D	DELTA C	LE							
1	1.023E-01	1.097E-01	2.000E-00							
2	1.472E-01	1.097E-01	2.000E-00							
3	1.550E-01	4.010E-00	7.500E-01							

LOCAL TEST PARAMETERS

TEST 112 BURNOUT AT DATA POINT 7

STA	PE	TH	TW	TI	U/A	U/AP	M	DEL TF	VS
1	3.963E 03	1.367E 02	6.030E 02	4.461E 02	2.040E 01	1.061E 01	3.428E-02	3.094E 02	4.743E 01
2	3.955E 03	1.492E 02	7.840E 02	4.231E 02	1.041E 01	1.061E 01	3.473E-02	2.738E 02	4.768E 01
3	3.950E 03	1.619E 02	8.780E 02	5.508E 02	9.652E 00	1.024E 01	2.565E-02	3.991E 02	4.794E 01
STA	L/D	DELTA E	LE						
1	1.022E 01	1.188E 01	2.000E 00						
2	1.478E 01	1.188E 01	2.000E 00						
3	1.533E 01	4.300E 00	7.500E-01						

LOCAL TEST PARAMETERS

TEST 112 BURNOUT AT DATA POINT 7

STA	PE	TB	TW	TI	J/A	U/AP	M	DEL TF	VS
1	3.958E 03	1.425E 02	7.900E 02	4.990E 02	1.174E 01	1.201E 01	3.362E-02	3.573E 02	4.723E 01
2	3.955E 03	1.575E 02	8.700E 02	4.840E 02	1.175E 01	1.201E 01	3.693E-02	3.253E 02	4.763E 01
3	3.951E 03	1.725E 02	9.800E 02	6.400E 02	1.114E 01	1.173E 01	2.580E-02	4.544E 02	4.794E 01
STA	L/D	DELTA E	LE						
1	1.022E 01	1.265E 01	2.000E 00						
2	1.478E 01	1.265E 01	2.000E 00						
3	1.533E 01	4.630E 00	7.500E-01						

LOCAL TEST PARAMETERS

TEST 112 BURNOUT AT DATA POINT 7

STA	PE	TB	TW	TI	U/A	U/AP	M	DEL TF	VS
1	1.972E 03	1.420E 02	9.000E 02	5.071E 02	1.113E 01	1.021E 01	1.751E-02	1.644E 02	4.720E 01
2	2.949E 03	1.579E 02	8.820E 02	4.800E 02	1.113E 01	1.021E 01	3.729E-02	1.278E 02	4.750E 01
3	3.726E 03	1.729E 02	9.650E 02	6.011E 02	1.109E 01	1.021E 01	2.384E-02	4.402E 02	4.781E 01
STA	L/D	DELTA E	LE						
1	1.022E 01	1.272E 01	2.000E 00						
2	1.478E 01	1.272E 01	2.000E 00						
3	1.533E 01	4.700E 00	7.500E-01						

DIMENSIONLESS PARAMETERS

TEST 112 BURNDOUT AT DATA POINT 7

DATA POINT	STA	NU(F)	PR(F)	RE(F)	T/TF	MU/PR(01)
1	1	5.0660E 02	2.8886E 00	1.6031E 05	1.0533E 00	3.3143E 02
1	2	7.9673E 02	3.0804E 00	1.5282E 05	1.0349E 00	5.0180E 02
1	3	2.3730E 02	2.5672E 00	1.7568E 05	1.0740E 00	1.6274E 02
2	1	5.5465E 02	2.1020E 00	2.0429E 05	1.1183E 00	4.1207E 02
2	2	6.8205E 02	2.2081E 00	1.9705E 05	1.0943E 00	4.9756E 02
2	3	3.3320E 02	1.6396E 00	2.5014E 05	1.1709E 00	2.7341E 02
3	1	5.9274E 02	1.6437E 00	2.4901E 05	1.1749E 00	4.8529E 02
3	2	6.7937E 02	1.7035E 00	2.4323E 05	1.1548E 00	5.4900E 02
3	3	4.6492E 02	1.3806E 00	2.9128E 05	1.2019E 00	4.0865E 02
4	1	6.8522E 02	1.4415E 00	2.8292E 05	1.2023E 00	5.9190E 02
4	2	7.5458E 02	1.4582E 00	2.8143E 05	1.1846E 00	6.4882E 02
4	3	5.2867E 02	1.1491E 00	3.4715E 05	1.2343E 00	5.0007E 02
5	1	7.7513E 02	1.3951E 00	2.8622E 05	1.2059E 00	6.7647E 02
5	2	8.7655E 02	1.4244E 00	2.8264E 05	1.1835E 00	7.6123E 02
5	3	5.7516E 02	1.0792E 00	3.6154E 05	1.2429E 00	5.5790E 02
6	1	7.5543E 02	1.2408E 00	3.1600E 05	1.2287E 00	6.9297E 02
6	2	8.2983E 02	1.2456E 00	3.1896E 05	1.2085E 00	7.6804E 02
6	3	5.8066E 02	9.6429E-01	4.0341E 05	1.2643E 00	5.8917E 02
7	1	7.5249E 02	1.1894E 00	3.2813E 05	1.2321E 00	7.0206E 02
7	2	8.3781E 02	1.2070E 00	3.2600E 05	1.2094E 00	7.7747E 02
7	3	6.0364E 02	9.7152E-01	3.9914E 05	1.2615E 00	6.1086E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNDOUT

AF = 0.254E-03 D = 0.183E-01 L = 0.500E 01 DELTA TO = 0.200E-00

DATA POINTS

POINT	PB-IN	PB-OUT	TB-IN	TB-OUT	W	Q/AP	H	DEL TF	VS	MT BAL	S
1	3.948E 03	3.975E 03	6.170E 01	7.410E 01	5.790E-01	1.023E 01	4.716E 02	4.574E 00	2.054E 00	2.054E 00	2.192E 03
2	3.900E 03	3.975E 03	6.175E 01	7.990E 01	5.790E-01	1.234E 01	5.662E 02	6.624E 00	4.395E-01	4.395E-01	2.192E 03
3	4.008E 03	4.001E 03	2.190E 01	6.640E 01	5.840E-01	1.433E 01	6.548E 02	6.895E 00	-1.298E 00	-1.298E 00	2.212E 03
4	4.002E 03	3.948E 03	6.200E 01	5.340E 01	5.830E-01	1.620E 01	7.383E 02	1.130E 01	-1.844E 00	-1.844E 00	2.200E 03
5	4.039E 03	4.035E 03	6.200E 01	9.710E 01	5.810E-01	1.721E 01	7.795E 02	1.272E 01	-2.630E 00	-2.630E 00	2.210E 03
6	4.037E 03	4.028E 03	6.215E 01	1.020E 02	5.850E-01	1.833E 01	6.293E 02	1.441E 01	-2.240E 00	-2.240E 00	2.210E 03
7	4.030E 03	4.026E 03	6.220E 01	1.074E 02	5.850E-01	1.950E 01	6.801E 02	1.627E 01	-2.938E 00	-2.938E 00	2.210E 03
8	4.029E 03	4.024E 03	6.220E 01	1.123E 02	5.850E-01	2.049E 01	9.234E 02	1.794E 01	-3.566E 00	-3.566E 00	2.210E 03
9	4.028E 03	4.024E 03	6.220E 01	1.171E 02	5.850E-01	2.136E 01	9.625E 02	1.949E 01	-4.540E 00	-4.540E 00	2.210E 03
10	4.028E 03	4.022E 03	6.230E 01	1.243E 02	5.860E-01	2.263E 01	1.015E 03	2.178E 01	-5.976E 00	-5.976E 00	2.220E 03
11	4.027E 03	4.022E 03	6.230E 01	1.300E 02	5.850E-01	2.340E 01	1.053E 03	2.344E 01	-7.400E 00	-7.400E 00	2.210E 03
12	4.027E 03	4.022E 03	6.240E 01	1.400E 02	5.810E-01	2.463E 01	1.101E 03	2.571E 01	-1.163E 01	-1.163E 01	2.201E 03
13	4.030E 03	4.022E 03	6.230E 01	1.483E 02	5.790E-01	2.533E 01	1.130E 03	2.713E 01	-1.652E 01	-1.652E 01	2.193E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 1.3 DATA POINT 13 IS BURNDOUT

DATA POINT 1

STA	PB	TB	TB	W/A	Q/AP	H	DEL TF	VS
1	3.948E 03	6.852E 01	2.280E 02	1.301E 00	1.335E 00	1.311E-02	1.019E 02	2.448E 01
2	3.900E 03	7.100E 01	2.280E 02	1.301E 00	1.335E 00	1.344E-02	9.939E 01	2.451E 01
3	3.979E 03	7.348E 01	2.480E 02	1.352E 00	1.362E 00	1.180E-02	1.155E 02	2.453E 01

STA	L/D	DELTA E	LE
1	1.251E 01	4.130E 00	2.000E 00
2	1.706E 01	4.130E 00	2.000E 00
3	2.161E 01	1.580E 00	7.500E-01

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNGUT

STA	DATA POINT 2									
	Pb	Td	Tb	Ti	Q/A	Q/AP	M	DEL TF	VS	
1	3.977E 03	7.173L 01	2.590E 02	2.191E 02	1.883E 03	1.93E 00	1.312E-02	1.474E 02	2.451E 01	
2	2.976E 03	7.530E 01	2.990E 02	2.191E 02	1.883E 03	1.93E 00	1.345E-02	1.438E 02	2.455E 01	
3	3.975E 03	7.859L 01	3.260E 02	2.441E 02	1.967E 03	1.977E 00	1.198E-02	1.651E 02	2.459E 01	
STA	L/D	DELTA C	LE							
1	1.251E 01	4.580E 00	2.000E 00							
2	1.766E 01	4.580E 00	2.000E 00							
3	2.161E 01	1.910E 00	7.500E-01							

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNGUT

STA	DATA POINT 3									
	Pb	Td	Tb	Ti	Q/A	Q/AP	M	DEL TF	VS	
1	4.004E 03	7.537E 01	3.800E 02	2.700E 02	2.524E 03	2.595E 00	1.281E-02	2.026E 02	2.476E 01	
2	4.003E 03	8.027E 01	3.790E 02	2.709E 02	2.525E 03	2.595E 00	1.320E-02	1.966E 02	2.481E 01	
3	4.001E 03	8.517E 01	4.080E 02	3.039E 02	2.594E 03	2.659E 00	1.220E-02	2.179E 02	2.486E 01	
STA	L/D	DELTA C	LE							
1	1.251E 01	5.780E 00	2.000E 00							
2	1.766E 01	5.780E 00	2.000E 00							
3	2.161E 01	2.220E 00	7.500E-01							

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNGUT

STA	DATA POINT 4									
	Pb	Td	Tb	Ti	Q/A	Q/AP	M	DEL TF	VS	
1	4.000E 03	7.927E 01	4.490E 02	3.229E 02	3.034E 03	3.021E 00	1.363E-02	2.436E 02	2.476E 01	
2	4.000E 03	8.559E 01	4.490E 02	3.189E 02	3.039E 03	3.021E 00	1.425E-02	2.339E 02	2.482E 01	
3	4.000E 03	9.103E 01	4.490E 02	3.589E 02	3.384E 03	3.002E 00	1.274E-02	2.671E 02	2.489E 01	
STA	L/D	DELTA C	LE							
1	1.251E 01	9.560E 00	2.000E 00							
2	1.766E 01	9.560E 00	2.000E 00							
3	2.161E 01	2.520E 00	7.500E-01							

Report AIRPL-TR-66-263, Appendix B

LUCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNTOUT

STA	PH	TL	TB	TI	U/A	J/AP	M	DEL TF	VS
1	4.07E 03	8.130E 01	4.840E 02	3.504E 02	3.005E 03	3.704E 00	1.376E-02	2.691E 02	2.447E 01
2	4.03E 03	8.032E 01	4.800E 02	3.410E 02	3.606E 03	3.704E 00	1.462E-02	2.533E 02	2.494E 01
3	4.035E 03	8.534E 01	5.250E 02	3.850E 02	3.790E 03	3.805E 00	1.323E-02	2.876E 02	2.501E 01

STA	L/D	DELTA F	LE
1	1.661E 01	6.930E 00	2.000E 00
2	1.706E 01	6.930E 00	2.000E 00
3	2.161E 01	2.670E 00	7.500E-01

LUCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNTOUT

STA	PH	TL	TB	TI	U/A	J/AP	M	DEL TF	VS
1	4.030E 03	6.407E 01	5.200E 02	3.600E 02	4.091E 00	4.202E 00	1.491E-02	2.419E 02	2.444E 01
2	4.024E 03	6.204E 01	5.150E 02	3.615E 02	4.092E 00	4.202E 00	1.559E-02	2.695E 02	2.498E 01
3	4.220E 03	1.600E 02	5.600E 02	4.066E 02	4.245E 00	4.306E 00	1.395E-02	3.086E 02	2.506E 01

STA	L/D	DELTA F	LE
1	1.251E 01	7.350E 00	2.000E 00
2	1.706E 01	7.350E 00	2.000E 00
3	2.161E 01	2.640E 00	7.500E-01

LUCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNTOUT

STA	PH	TL	TB	TI	U/A	J/AP	M	DEL TF	VS
1	4.023E 03	4.700E 01	5.850E 02	3.900E 02	4.603E 00	4.737E 00	1.521E-02	3.115E 02	2.493E 01
2	4.027E 03	4.810E 01	5.850E 02	3.750E 02	4.604E 00	4.737E 00	1.711E-02	2.769E 02	2.502E 01
3	4.025E 03	1.851E 02	6.240E 02	4.502E 02	4.651E 00	4.876E 00	1.413E-02	3.450E 02	2.512E 01

STA	L/D	DELTA F	LE
1	1.251E 01	7.850E 00	2.000E 00
2	1.706E 01	7.850E 00	2.000E 00
3	2.161E 01	2.630E 00	7.500E-01

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNT

STA	PL	TL	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	4.720E-03	5.970E-01	5.970E-02	4.043E-02	5.076E-00	5.223E-00	1.660E-02	3.147E-02	2.495E-01
2	4.720E-03	5.970E-01	5.970E-02	3.810E-02	5.083E-00	5.223E-00	1.858E-02	2.812E-02	2.506E-01
3	4.720E-03	1.553E-01	1.550E-02	4.000E-02	5.446E-00	5.369E-00	1.530E-02	3.508E-02	2.517E-01
STA	L/D	DELTA L	LE						
1	1.251E-01	8.250E-00	2.000E-00						
2	1.726E-01	8.250E-00	2.000E-00						
3	2.101E-01	8.160E-00	7.500E-01						

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNT

STA	PL	TL	TW	TI	W/A	Q/AP	M	DEL TF	VS
1	4.720E-03	5.230E-01	5.210E-02	4.224E-02	5.508E-00	5.676E-00	1.720E-02	3.300E-02	2.498E-01
2	4.720E-03	1.934E-01	5.95E-02	3.976E-02	5.515E-00	5.676E-00	1.929E-02	2.943E-02	2.510E-01
3	4.720E-03	1.849E-01	5.120E-02	4.797E-02	5.781E-00	5.825E-00	1.594E-02	3.654E-02	2.521E-01
STA	L/D	DELTA L	LE						
1	1.251E-01	8.000E-00	2.000E-00						
2	1.700E-01	8.000E-00	2.000E-00						
3	2.111E-01	8.310E-00	7.500E-01						

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS BURNT

STA	PL	TL	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	4.720E-03	9.640E-01	6.520E-02	4.314E-02	6.183E-00	6.347E-00	1.895E-02	3.350E-02	2.507E-01
2	4.720E-03	1.583E-01	6.310E-02	4.075E-02	6.191E-00	6.347E-00	2.125E-02	2.987E-02	2.538E-01
3	4.720E-03	1.812E-01	7.233E-02	5.007E-02	6.448E-00	6.496E-00	1.712E-02	3.795E-02	2.533E-01
STA	L/D	DELTA L	LE						
1	1.251E-01	9.120E-00	2.000E-00						
2	1.700E-01	9.120E-00	2.000E-00						
3	2.111E-01	8.500E-00	7.500E-01						

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 11 IS SKIPPED

STA	PB	L/D	TJ	TI	O/A	U/AP	M	DEL TF	VS
1	4.074E 03	9.923E 01	0.720E 02	4.204E 02	0.143E 00	0.630E 00	2.028E-02	3.260E 02	2.504E 01
2	4.022E 03	1.131E 04	4.520E 02	4.189E 02	0.052E 00	0.430E 00	2.204E-02	3.030E 02	2.520E 01
3	4.022E 03	1.066E 04	7.550E 02	5.188E 02	0.102E 00	7.008E 00	1.787E-02	3.922E 02	2.534E 01

STA	L/D	DELTA E	LE
1	1.075E 01	9.400E 01	2.000E 00
2	1.706E 01	9.400E 00	2.000E 00
3	2.161E 01	3.040E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 12 IS SKIPPED

STA	PB	L/D	TU	TI	O/A	U/AP	M	DEL TF	VS
1	4.022E 03	1.051E 02	7.190E 02	4.624E 02	7.287E 00	7.489E 00	2.079E-02	3.603E 02	2.494E 01
2	4.022E 03	1.206E 02	6.990E 02	4.244E 02	7.293E 00	7.489E 00	2.327E-02	3.218E 02	2.511E 01
3	4.022E 03	1.361E 02	4.120E 02	5.556E 02	7.084E 00	7.710E 00	1.030E-02	4.179E 02	2.527E 01

STA	L/D	DELTA E	LE
1	1.251E 01	9.920E 00	2.000E 00
2	1.706E 01	9.920E 00	2.000E 00
3	2.161E 01	3.040E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 113 DATA POINT 13 IS SKIPPED

STA	PB	L/D	TU	TI	O/A	U/AP	M	DEL TF	VS
1	4.022E 03	1.056E 02	7.590E 02	4.959E 02	7.686E 00	7.903E 00	2.046E-02	3.863E 02	2.490E 01
2	4.022E 03	1.249E 02	7.490E 02	4.844E 02	7.691E 00	7.903E 00	2.210E-02	3.576E 02	2.509E 01
3	4.022E 03	1.440E 02	8.560E 02	5.936E 02	8.070E 00	8.120E 00	1.806E-02	4.496E 02	2.527E 01

STA	L/D	DELTA E	LE
1	1.251E 01	1.020E 01	2.000E 00
2	1.706E 01	1.020E 01	2.000E 00
3	2.161E 01	3.930E 00	7.500E-01

Report AFRPL-TR-66-263, Appendix B

DIMENSIONLESS PARAMETERS

TEST 11, DATA POINT 13 IS OMINOUT

DATA POINT	STA	KU	PH	RE	Y1/T8	MU/PRI(0)
1	1	3.7244E 02	3.7672E 00	4.7587E 04	1.1927E 00	1.8481E 02
1	2	3.6012E 02	3.5547E 00	4.9346E 04	1.1872E 00	1.9087E 02
1	3	3.5238E 02	3.4526E 00	5.0120E 04	1.2164E 00	1.6888E 02
2	1	3.7090E 02	3.5473E 00	4.9222E 04	1.2772E 00	1.8675E 02
2	2	3.7759E 02	3.6312E 00	5.1110E 04	1.2685E 00	1.9359E 02
2	3	3.8421E 02	3.6924E 00	5.3033E 04	1.3063E 00	1.7423E 02
3	1	3.9381E 02	3.8121E 00	5.4551E 04	1.3784E 00	1.8439E 02
3	2	3.9747E 02	3.9177E 00	5.6183E 04	1.3639E 00	1.9278E 02
3	3	3.9696E 02	4.0537E 00	5.6793E 04	1.3996E 00	1.8062E 02
4	1	4.017E 02	4.0760E 00	5.7349E 04	1.4518E 00	1.9851E 02
4	2	3.9343E 02	4.7344E 00	5.6881E 04	1.4270E 00	2.1123E 02
4	3	3.8759E 02	4.4442E 00	6.0034E 04	1.4041E 00	2.1916E 02
5	1	3.8259E 02	4.5903E 00	5.4331E 04	1.4971E 00	2.0164E 02
5	2	4.0178E 02	4.6003E 00	5.8506E 04	1.4820E 00	2.1820E 02
5	3	3.9554E 02	4.2598E 00	6.1992E 04	1.5179E 00	2.0062E 02
6	1	4.1245E 02	4.6104E 00	5.6302E 04	1.5181E 00	2.2004E 02
6	2	4.2539E 02	4.4354E 00	6.0374E 04	1.4882E 00	2.3471E 02
6	3	3.7640E 02	4.1242E 00	5.4213E 04	1.5311E 00	2.1359E 02
7	1	3.8728E 02	4.4007E 00	5.7855E 04	1.5094E 00	2.2623E 02
7	2	4.0432E 02	4.2702E 00	6.2357E 04	1.4980E 00	2.5980E 02
7	3	3.7537E 02	3.9491E 00	6.6517E 04	1.6105E 00	2.1839E 02
8	1	4.0453E 02	4.5354E 00	5.9231E 04	1.5725E 00	2.4851E 02
8	2	3.9138E 02	4.1331E 00	6.4106E 04	1.5024E 00	2.8420E 02
8	3	4.0632E 02	4.3100E 00	6.3747E 04	1.5157E 00	2.3848E 02
9	1	4.6543E 02	4.4202E 00	6.0550E 04	1.5975E 00	2.5909E 02
9	2	3.1771E 02	3.9073E 00	6.5793E 04	1.5223E 00	2.9711E 02
9	3	3.9062E 02	3.8060E 00	7.0460E 04	1.6362E 00	2.5039E 02
10	1	3.1405E 02	4.2554E 00	6.2633E 04	1.6020E 00	2.8795E 02
10	2	3.0571E 02	3.8313E 00	6.3633E 04	1.5251E 00	3.3053E 02
10	3	3.4717E 02	3.4524E 00	7.4504E 04	1.6530E 00	2.7219E 02
11	1	3.4756E 02	4.1417E 00	6.3595E 04	1.6020E 00	3.1011E 02
11	2	3.0457E 02	3.7006E 00	7.0342E 04	1.5302E 00	3.5230E 02
11	3	4.1504E 02	3.3114E 00	7.7227E 04	1.6662E 00	2.6686E 02
12	1	3.0051E 02	3.9511E 00	6.6134E 04	1.6376E 00	3.2121E 02
12	2	3.4477E 02	3.4775E 00	7.3019E 04	1.5542E 00	3.6972E 02
12	3	4.1570E 02	3.0052E 00	8.1327E 04	1.7037E 00	2.9935E 02
13	1	3.4401E 02	3.4604E 00	6.7541E 04	1.6791E 00	3.1870E 02
13	2	3.7243E 02	3.3604E 00	7.0326E 04	1.6044E 00	3.5492E 02
13	3	4.3051E 02	2.9224E 00	8.4722E 04	1.7443E 00	2.9726E 02

Report AFRPL-TR-66-263, Appendix B

DATA POINT	TA	KPL RATIO	K RATIO	VU RATIO	CP RATIO
1	1	1.0440E 00	8.8592E-01	2.2527E 00	9.9255E-01
1	2	1.0427E 00	8.8527E-01	1.9975E 00	9.9161E-01
1	3	1.0502E 00	8.8592E-01	2.1304E 00	9.9593E-01
1	4	1.0752E 00	8.8618E-01	2.4439E 00	9.8717E-01
2	1	1.0368E 00	8.8515E-01	2.3914E 00	9.8593E-01
2	2	1.0741E 00	8.8244E-01	2.2532E 00	9.8251E-01
2	3	1.0426E 00	8.8064E-01	3.0235E 00	9.8240E-01
2	4	1.0558E 00	8.8154E-01	2.8853E 00	9.8088E-01
3	1	1.0509E 00	8.8162E-01	3.6297E 00	9.7997E-01
3	2	1.1134E 00	8.8558E-01	3.4572E 00	9.8194E-01
3	3	1.1087E 00	8.8427E-01	3.2024E 00	9.8013E-01
3	4	1.1263E 00	8.8205E-01	3.4987E 00	9.7983E-01
4	1	1.1272E 00	8.8057E-01	3.7552E 00	9.8290E-01
4	2	1.1194E 00	8.8163E-01	3.2561E 00	9.8067E-01
4	3	1.1790E 00	8.8265E-01	3.0954E 00	9.8294E-01
4	4	1.1345E 00	8.8185E-01	3.0543E 00	9.8316E-01
5	1	1.1261E 00	8.8202E-01	3.5231E 00	9.8073E-01
5	2	1.1511E 00	8.8353E-01	3.0001E 00	9.8795E-01
5	3	1.1513E 00	8.8171E-01	4.1617E 00	9.8796E-01
5	4	1.1224E 00	8.8205E-01	3.2544E 00	9.8099E-01
6	1	1.1751E 00	8.8592E-01	4.2722E 00	1.0000E 00
6	2	1.1536E 00	8.8215E-01	4.1467E 00	9.8668E-01
6	3	1.1251E 00	8.8518E-01	1.5402E 00	9.8133E-01
6	4	1.1727E 00	8.8601E-01	4.2694E 00	1.0027E 00
7	1	1.1639E 00	8.8479E-01	4.3072E 00	9.9345E-01
7	2	1.1429E 00	8.8561E-01	3.6643E 00	9.8415E-01
7	3	1.1503E 00	8.8729E-01	4.3771E 00	1.0046E 00
7	4	1.1672E 00	8.8497E-01	4.2944E 00	9.9539E-01
8	1	1.1468E 00	8.8642E-01	4.6275E 00	9.8590E-01
8	2	1.2098E 00	8.8912E-01	4.4275E 00	1.0147E 00
8	3	1.1896E 00	8.8601E-01	4.2610E 00	9.9639E-01
8	4	1.1499E 00	8.8553E-01	3.6612E 00	9.8787E-01
9	1	1.1101E 00	8.8794E-01	4.4734E 00	1.0206E 00
9	2	1.1856E 00	8.8559E-01	4.4729E 00	1.0350E 00
9	3	1.1624E 00	8.8667E-01	3.7463E 00	9.9502E-01
9	4	1.2331E 00	8.8440E-01	4.5966E 00	1.0300E 00
10	1	1.2036E 00	8.8735E-01	4.7533E 00	1.0145E 00
10	2	1.1872E 00	8.8713E-01	4.3707E 00	1.0087E 00
10	3	1.2539E 00	8.8762E-01	4.7499E 00	1.0386E 00

Report AFRPL-TR-66-263, Appendix B

DIMENSIONLESS PARAMETERS

LIST THE DATA POINT IS L. COLUMN

DATA POINT	STA	NO(F)	PR(F)	KE(F)	TI/TF	NO/PR(1.0)
1	1	2.9243E 02	2.9243E 00	7.1232E 04	1.0079E 00	2.9762E 02
1	2	3.0139E 02	3.0139E 00	7.1931E 04	1.0054E 00	2.1350E 02
1	3	3.0573E 02	3.0573E 00	7.2512E 04	1.0077E 00	1.9981E 02
2	1	3.0954E 02	2.0954E 00	8.2771E 04	1.1217E 00	2.1627E 02
2	2	3.1240E 02	2.0810E 00	8.4646E 04	1.1184E 00	2.2224E 02
2	3	3.1572E 02	2.0652E 00	8.9531E 04	1.1328E 00	2.0162E 02
3	1	3.1653E 02	2.0493E 00	9.7888E 04	1.1591E 00	2.1992E 02
3	2	3.1530E 02	2.0420E 00	9.8519E 04	1.1539E 00	2.2715E 02
3	3	3.1490E 02	2.0390E 00	1.0554E 05	1.1605E 00	2.1399E 02
4	1	3.2254E 02	2.0719E 00	1.0804E 05	1.1643E 00	2.4161E 02
4	2	3.2700E 02	2.0616E 00	1.0673E 05	1.1700E 00	2.3231E 02
4	3	3.3002E 02	1.0491E 00	1.1722E 05	1.1949E 00	2.3184E 02
5	1	3.2148E 02	1.0261E 00	1.1422E 05	1.1991E 00	2.4762E 02
5	2	3.4425E 02	1.0361E 00	1.1676E 05	1.1876E 00	2.6277E 02
5	3	3.0512E 02	1.0222E 00	1.2539E 05	1.2057E 00	2.4493E 02
6	1	3.4657E 02	1.0063E 00	1.1349E 05	1.2058E 00	2.7110E 02
6	2	3.5210E 02	1.0222E 00	1.2017E 05	1.1962E 00	2.6927E 02
6	3	3.1547E 02	1.0222E 00	1.3377E 05	1.2160E 00	2.6324E 02
7	1	3.5006E 02	1.0044E 00	1.2707E 05	1.2216E 00	2.8282E 02
7	2	3.5249E 02	1.0766E 00	1.2332E 05	1.1993E 00	3.1490E 02
7	3	3.2079E 02	1.0745E 00	1.4454E 05	1.2339E 00	2.7464E 02
8	1	3.4122E 02	1.0729E 00	1.2919E 05	1.2225E 00	3.1031E 02
8	2	3.4210E 02	1.0722E 00	1.2667E 05	1.2004E 00	3.4441E 02
8	3	3.4163E 02	1.0405E 00	1.4462E 05	1.2354E 00	3.0037E 02
9	1	3.5224E 02	1.0016E 00	1.3403E 05	1.2306E 00	3.2572E 02
9	2	3.4244E 02	1.0426E 00	1.3150E 05	1.2071E 00	3.6214E 02
9	3	3.5594E 02	1.0441E 00	1.5514E 05	1.2413E 00	3.1768E 02
10	1	3.5214E 02	1.0599E 00	1.3757E 05	1.2316E 00	3.0164E 02
10	2	3.5577E 02	1.0586E 00	1.3552E 05	1.2080E 00	4.0284E 02
10	3	3.5516E 02	1.0296E 00	1.6353E 05	1.2461E 00	3.4780E 02
11	1	3.6132E 02	1.0333E 00	1.3943E 05	1.2314E 00	3.8922E 02
11	2	3.6123E 02	1.0221E 00	1.4099E 05	1.2095E 00	4.2300E 02
11	3	3.6114E 02	1.0233E 00	1.7006E 05	1.2506E 00	3.6990E 02
12	1	3.7077E 02	1.0304E 00	1.4732E 05	1.2417E 00	4.0797E 02
12	2	3.6270E 02	1.0323E 00	1.4600E 05	1.2170E 00	4.5497E 02
12	3	3.6159E 02	1.1397E 00	1.6223E 05	1.2603E 00	3.9164E 02
13	1	3.6124E 02	1.0333E 00	1.5631E 05	1.2532E 00	4.1110E 02
13	2	3.6790E 02	1.0312E 00	1.5901E 05	1.2335E 00	4.4382E 02
13	3	3.6311E 02	1.0542E 00	1.9474E 05	1.2712E 00	3.9664E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 114 3/16X4.5 TUBE WALL TEMP AGREEMENT=100% BURNDOUT AT DATA POINT 6

AF = 0.138E-03 D = 0.132E-01 L = 0.455E 01 DELTA TO = 0.280E 01

DATA POINTS

POINT	PB-IN	PJ-OUT	TB-IN	TB-OUT	W	E2	I2	OP	MT-RAN	S
1	3.913E 03	3.705E 03	6.730E 01	6.890E 01	1.920E 00	2.603E 01	9.083E 02	2.241E 01	-1.852E 00	1.392E 04
2	3.976E 03	3.730E 03	6.680E 01	1.003E 02	1.915E 00	3.394E 01	1.149E 03	3.642E 01	-2.728E 00	1.309E 04
3	3.970E 03	3.724E 03	6.680E 01	1.129E 02	1.910E 00	4.006E 01	1.362E 03	5.172E 01	-1.945E 00	1.385E 04
4	3.896E 03	3.720E 03	6.680E 01	1.258E 02	1.902E 00	4.566E 01	1.550E 03	6.709E 01	-1.643E 00	1.379E 04
5	3.840E 03	3.710E 03	6.660E 01	1.353E 02	1.902E 00	4.910E 01	1.670E 03	7.773E 01	-2.652E 00	1.379E 04
6	3.830E 03	3.705E 03	6.680E 01	1.455E 02	1.900E 00	5.200E 01	1.775E 03	8.750E 01	-5.381E 00	1.379E 04

TEST SECTION

LOCAL TEST PARAMETERS

TEST 114 3/10/66 5 TURE BALL TEMP AGREEMENT=100F BURNT AT DATA POINT 6

STA	L/O	DATA POINT 1									
		TI	Tb	TA	Q/A	Q/AP	M	DEL TP	VS		
1	50700-03	7.300E 01	5.100E 02	9.134E 01	1.040E 01	1.000E 01	7.440E-01	1.330E 01	1.540E 02		
2	50700-03	6.200E 01	4.800E 02	8.000E 01	1.010E 01	9.675E 00	-9.442E-01	-2.220E 01	1.560E 02		
3	50717-03	5.700E 01	5.750E 02	1.620E 02	1.052E 01	1.011E 01	1.342E-01	7.530E 01	1.560E 02		
STA	L/O	LE									
1	1.410E 01	5.000E 00	1.000E 00								
2	5.000E 01	5.700E 00	1.000E 00								
3	5.000E 01	5.000E 00	7.500E-01								

LOCAL TEST PARAMETERS

TEST 115 3/10/66 5 TURE BALL TEMP AGREEMENT=100F BURNT AT DATA POINT 6

STA	L/O	DATA POINT 2									
		TI	Tb	TA	Q/A	Q/AP	M	DEL TP	VS		
1	50710-03	5.350E 01	7.400E 02	9.800E 01	1.000E 01	1.030E 01	1.060E 00	1.540E 01	1.560E 02		
2	50720-03	7.000E 01	7.700E 02	1.700E 02	1.040E 01	1.000E 01	2.010E-01	7.970E 01	1.560E 02		
3	50740-03	5.000E 01	1.200E 02	2.000E 02	1.000E 01	1.630E 01	1.250E-01	1.300E 02	1.570E 02		
STA	L/O	LE									
1	1.000E 01	7.400E 00	1.000E 00								
2	5.000E 01	7.000E 00	1.000E 00								
3	5.000E 01	5.000E 00	7.500E-01								

LOCAL TEST PARAMETERS

TEST 116 3/10/66 5 TURE BALL TEMP AGREEMENT=100F BURNT AT DATA POINT 6

STA	L/O	DATA POINT 3									
		TI	Tb	TA	Q/A	Q/AP	M	DEL TP	VS		
1	50700-03	5.500E 01	5.900E 02	1.400E 02	2.000E 01	2.310E 01	1.970E-01	5.820E 01	1.560E 02		
2	50720-03	1.000E 01	1.000E 03	2.300E 02	2.330E 01	2.290E 01	1.750E-01	1.300E 02	1.560E 02		
3	50710-03	1.000E 01	1.100E 03	3.100E 02	2.000E 01	2.310E 01	1.130E-01	2.000E 02	1.570E 02		
STA	L/O	LE									
1	1.000E 01	5.900E 00	1.000E 00								
2	5.000E 01	5.000E 00	1.000E 00								
3	5.000E 01	5.000E 00	7.500E-01								

LOCAL TEST PARAMETERS

TEST 114 3/16X4.5 TUBE WALL TEMP AGREEMENT=100F BURDOUT AT DATA POINT 4

DATA POINT 4												
STA	PB	TS	TU	TI	Q/A	Q/AP	M	DEL TP	VS			
1	3-808E 03	9-630E 01	1-208E 03	1-600E 02	3-000E 01	3-018E 01	4-200E-01	7-100E 01	1-207E 02			
2	3-769E 03	1-574E 02	1-238E 03	2-821E 01	3-028E 01	3-078E 01	1-828E-01	1-828E 02	1-828E 02			
3	3-730E 03	1-225E 02	1-300E 03	3-328E 02	3-067E 01	3-000E 01	1-429E-01	2-102E 02	1-579E 02			
DELTA E												
1	1-416E 01	1-025E 01	1-000E 00									
2	2-006E 01	1-010E 01	1-000E 00									
3	2-675E 01	7-660E 00	7-888E-01									

LOCAL TEST PARAMETERS

TEST 114 3/16X4.5 TUBE WALL TEMP AGREEMENT=100F BURDOUT AT DATA POINT 5

DATA POINT 5												
STA	PB	TS	TU	TI	Q/A	Q/AP	M	DEL TP	VS			
1	3-800C 03	1-010E 02	1-354E 03	2-164E 02	3-538E 01	3-486E 01	3-028E-01	1-183E 02	1-008E 02			
2	3-760E 03	1-163E 02	1-390E 03	3-171E 02	3-440E 01	3-430E 01	1-712E-01	2-000E 02	1-071E 02			
DELTA E												
1	1-416E 01	1-100E 01	1-000E 00									
2	2-046E 01	1-065E 01	1-000E 00									

LOCAL TEST PARAMETERS

TEST 114 3/16X4.5 TUBE WALL TEMP AGREEMENT=100F BURDOUT AT DATA POINT 6

DATA POINT 6												
STA	PB	TS	TU	TI	Q/A	Q/AP	M	DEL TP	VS			
1	3-792E 03	1-061E 02	1-475E 03	2-346E 02	3-965E 01	3-939E 01	3-059E-01	1-205E 02	1-542E 02			
2	3-754E 03	1-236E 02	1-522E 03	3-589E 02	3-868E 01	3-877E 01	1-648E-01	2-353E 02	1-571E 02			
DELTA E												
1	1-416E 01	1-167E 01	1-000E 00									
2	2-046E 01	1-151E 01	1-000E 00									

DIMENSIONLESS PARAMETERS

TEST 114 3/16X4.5 TUBE WALL TEMP AGREEMENT RIGOR BURNDOUT AT DATA POINT 6

DATA POINT	STA	MU	PR	RE	TL/TB	ML/PR(0.9)
1	1	1.5126E 00	5.1482E 00	2.4101E 05	1.0209E 00	7.8536E 03
1	2	-8.9013E 03	4.8759E 00	2.5206E 05	9.5905E-01	-3.17231E 03
1	3	2.6682E 03	4.6346E 00	2.6400E 05	1.1376E 00	1.9940E 03
2	1	2.1209E 04	4.8378E 00	2.5375E 05	1.0203E 00	1.1209E 04
2	2	3.9893E 03	4.4663E 00	2.7100E 05	1.1447E 00	2.1870E 03
3	1	7.8785E 03	4.1817E 00	2.8749E 05	1.2339E 00	1.3817E 03
3	2	3.4147E 03	4.5310E 00	2.6778E 05	1.1066E 00	4.3044E 03
3	3	2.1801E 03	4.1216E 00	2.9020E 05	1.2334E 00	1.2373E 03
4	1	8.2463E 03	3.7840E 00	3.1189E 05	1.3500E 00	1.2803E 03
4	2	3.7390E 03	4.2625E 00	2.8094E 05	1.1809E 00	4.6174E 03
4	3	2.0925E 03	3.8128E 00	3.0862E 05	1.2802E 00	2.1870E 03
5	1	5.1844E 03	3.4219E 00	3.3797E 05	1.3409E 00	1.4461E 03
5	2	2.2568E 03	4.0878E 00	2.9108E 05	1.2055E 00	3.3504E 03
5	3	5.9091E 03	3.6050E 00	3.2344E 05	1.3405E 00	1.9540E 03
6	1	3.6597E 03	3.9162E 00	3.0146E 05	1.2270E 00	3.4220E 03
6	2	1.1110E 00	3.3906E 00	3.4021E 05	1.4431E 00	1.9220E 03

DATA POINT	STA	MU RATIO	K RATIO	MU RATIO	CP RATIO
1	1	1.0050E 00	4.7431E-01	1.1319E 00	1.0007E 00
1	2	4.7092E-01	1.0395E 00	7.9384E-01	1.0049E 00
1	3	1.0224E 00	6.9566E-01	1.6317E 00	9.8450E-01
2	1	1.0064E 00	4.7505E-01	1.1374E 00	9.9647E-01
2	2	1.0244E 00	6.9217E-01	1.6544E 00	9.8434E-01
2	3	1.0250E 00	6.5753E-01	2.0387E 00	9.7747E-01
3	1	1.0583E 00	9.1882E-01	1.4763E 00	9.8693E-01
3	2	1.0551E 00	8.5881E-01	2.0267E 00	9.7657E-01
3	3	1.0309E 00	8.4477E-01	2.8107E 00	9.7163E-01
4	1	1.0693E 00	9.0261E-01	1.5612E 00	9.8275E-01
4	2	1.0693E 00	8.5814E-01	2.1479E 00	9.7133E-01
4	3	1.0549E 00	8.6047E-01	2.5642E 00	9.6903E-01
5	1	1.0510E 00	8.6607E-01	1.5943E 00	9.7764E-01
5	2	1.0537E 00	8.5405E-01	2.5307E 00	9.7011E-01
6	1	1.0274E 00	8.6406E-01	1.9710E 00	9.7439E-01
6	2	1.1110E 00	8.0124E-01	2.7844E 00	9.7002E-01

DIMENSIONLESS PARAMETERS

TABLE 11a 2/10/66: FULL BALL TEMP AGREEMENT=100% SUMMARY AT DATA POINT 6

DATA POINT	STA	AU(F)	PR(F)	RE(F)	VI/TF	MA/PR(0)
1	1	1.0453E 04	4.7754E 00	2.5656E 05	1.0123E 00	6.0036E 03
1	2	-5.3703E 03	5.5489E 00	2.2643E 05	9.7910E-01	-4.5789E 03
1	3	2.5188E 03	3.3466E 00	3.4211E 05	1.0644E 00	1.5636E 03
2	1	2.5546E 04	4.4698E 00	2.7080E 05	1.0140E 00	1.1509E 04
2	2	3.7522E 03	3.2055E 00	3.5334E 05	1.0475E 00	2.3506E 03
2	3	4.2292E 03	2.5671E 00	4.1974E 05	1.1047E 00	1.5209E 03
2	4	7.3285E 03	3.5244E 00	3.2702E 05	1.0503E 00	4.5522E 03
2	5	3.1099E 03	2.5337E 00	4.2259E 05	1.1045E 00	2.1423E 03
3	1	1.0249E 03	1.9470E 00	5.2174E 05	1.1518E 00	1.4745E 03
4	1	7.6127E 03	3.1754E 00	3.5429E 05	1.0605E 00	4.9213E 03
4	2	3.3747E 03	4.2410E 00	4.4635E 05	1.1102E 00	2.3430E 03
4	3	2.3304E 03	1.9113E 00	5.5330E 05	1.1529E 00	1.9897E 03
5	1	4.4124E 03	2.0054E 00	4.0674E 05	1.0932E 00	3.0428E 03
5	2	4.6927E 03	1.9085E 00	5.2914E 05	1.1484E 00	2.2337E 03
6	1	5.3987E 03	2.4597E 00	4.3189E 05	1.1819E 00	3.7465E 03
6	2	2.7430E 03	1.7061E 00	5.0004E 05	1.1670E 00	2.2132E 03

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 116 DATA POINT 7 IS BURNDOUT

AF = 0.130E-03 D = 0.132E-01 L = 0.500E 01 DELTA TO = 0.220E 01

DATA POINTS

POINT	PS-IN	PS-OUT	TB-IN	TB-OUT	W	L 2	S 2	OP	NT BAL	G
1	4.601E 03	4.730E 03	6.740E 01	4.500E 01	1.141E 00	1.950E 01	6.200E 02	1.150E 01	-2.334E 00	8-274E 03
2	4.790E 03	4.715E 03	6.750E 01	9.810E 01	1.131E 00	2.590E 01	6.177E 02	2.015E 01	-1.012E 00	8-202E 03
3	4.780E 03	4.710E 03	6.760E 01	1.123E 02	1.130E 00	3.400E 01	9.930E 02	3.012E 01	-1.545E 00	8-194E 03
4	4.775E 03	4.705E 03	6.760E 01	1.259E 02	1.124E 00	3.692E 01	1.132E 03	3.902E 01	-1.500E 00	8-151E 03
5	4.770E 03	4.700E 03	6.760E 01	1.355E 02	1.130E 00	3.977E 01	1.215E 03	4.581E 01	-3.958E 00	8-194E 03
6	4.770E 03	4.695E 03	6.760E 01	1.400E 02	1.122E 00	4.283E 01	1.307E 03	5.307E 01	-5.000E 00	8-134E 03
7	4.772E 03	4.690E 03	6.760E 01	1.631E 02	1.112E 00	4.553E 01	1.300E 03	5.991E 01	-1.003E 01	8-084E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 7 IS BURNDOUT

DATA POINT 1

STA	PS	TS	TH	TB	TI	Q/A	S/WAP	M	DEL TF	VS
1	4.72L 03	7.752F 01	3.000E 02	1.034E 02	4.953E 00	4.756L 00	4.052E-02	4.052E-02	1.061E 02	9.270F 01
2	4.740L 03	8.129E 01	3.910E 02	1.925E 02	4.329E 00	4.694E 00	4.217E-02	4.217E-02	1.113E 02	9.204E 01
3	4.730E 03	6.080E 01	4.000E 02	2.300E 02	4.341E 00	4.453E 00	3.051E-02	1.450E 02	1.450E 02	9.209E 01

STA	L/D	DELTA E	LE
1	1.731L 01	4.000E 00	1.000E 00
2	2.300L 01	3.550E 00	1.900E 00
3	4.990L 01	2.810E 00	7.500L-01

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 7 IS BURNDOUT

STA	PE	TH	TI	Q/A	Q/AP	M	DEL TF	VS
1	4.751E 03	9.433E 01	3.560E 02	6.710E 00	3.359E 00	4.560E-02	1.937E 02	9.215E 01
2	4.727E 03	9.045E 01	5.980E 02	4.780E 02	3.255E 00	4.392E-02	1.882E 02	9.239E 01
3	4.723E 03	9.657E 01	6.210E 02	3.453E 02	7.755E 00	3.129E-02	2.480E 02	9.262E 01

STA	L/D	DELTA E	LE
1	1.721E 01	5.240E 00	1.000E 00
2	2.500E 01	5.260E 00	1.000E 00
3	2.950E 01	3.730E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 7 IS BURNDOUT

STA	PE	TH	TI	Q/A	Q/AP	M	DEL TF	VS
1	4.741E 03	9.210E 01	7.950E 02	1.311E 01	1.253E 01	5.163E-02	2.426E 02	9.237E 01
2	4.727E 03	1.011E 02	7.960E 02	3.519E 02	1.234E 01	4.921E-02	2.507E 02	9.272E 01
3	4.713E 03	1.101E 02	6.210E 02	4.476E 02	1.135E 01	3.454E-02	3.375E 02	9.307E 01

STA	L/D	DELTA E	LE
1	1.721E 01	6.590E 00	1.000E 00
2	2.360E 01	6.490E 00	1.000E 00
3	2.950E 01	4.000E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 7 IS BURNDOUT

STA	PE	TH	TI	Q/A	Q/AP	M	DEL TF	VS
1	4.736E 03	9.566E 01	9.650E 02	1.728E 01	1.647E 01	5.205E-02	3.164E 02	9.217E 01
2	4.722E 03	1.113E 02	9.830E 02	4.254E 02	1.632E 01	5.195E-02	3.141E 02	9.263E 01
3	4.738E 03	1.220E 02	1.022E 03	5.532E 02	1.526E 01	3.546E-02	4.302E 02	9.309E 01

STA	L/D	DELTA E	LE
1	1.731E 01	7.600E 00	1.000E 00
2	2.360E 01	7.830E 00	1.000E 00
3	2.950E 01	5.260E 00	7.500E-01

LOCAL TEST PARAMETERS

*** 11A 3/16/65 TUGS BALL TEMP AGREEMENT=100F BURNDUT AT DATA POINT 6

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 5 IS BURNDUT

STA	Pb	Tb	Tl	Q/A	Q/AP	M	DEL TF	VS
1	4.789E 03	1.649E 02	4.541E 02	1.993E 01	1.993E 01	5.440E-02	3.492E 02	9.287E 01
2	4.795E 03	1.125E 02	4.730E 02	1.980E 01	1.877E 01	5.283E-02	3.553E 02	9.350E 01
3	4.701E 03	1.321E 02	5.994E 02	1.732E 01	1.774E 01	3.796E-02	4.673E 02	9.394E 01

STA	L/D	DELTA E	L
1	1.731E 01	6.100E 00	1.000E 00
2	2.360E 01	8.070E 00	1.000E 00
3	2.990E 01	5.720E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 7 IS BURNDUT

STA	Pb	Tb	Tl	Q/A	Q/AP	M	DEL TF	VS
1	4.766E 03	1.110E 02	4.854E 02	2.291E 01	2.192E 01	5.886E-02	3.734E 02	9.246E 01
2	4.701E 03	1.279E 02	5.854E 02	2.270E 01	2.189E 01	5.886E-02	3.775E 02	9.381E 01
3	4.856E 03	1.440E 02	8.694E 02	1.986E 01	2.036E 01	3.679E-02	5.254E 02	9.375E 01

STA	L/D	DELTA E	L
1	1.731E 01	8.790E 00	1.000E 00
2	2.360E 01	8.750E 00	1.000E 00
3	2.990E 01	6.110E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 115 DATA POINT 7 IS BURNDUT

STA	PE	To	Tl	W/A	Q/AP	M	DEL TF	VS
1	4.727E 03	1.201E 02	6.104E 02	2.556E 01	2.471E 01	5.886E-02	4.903E 02	9.190E 01
2	4.711E 03	1.352E 02	5.557E 02	2.582E 01	2.434E 01	5.984E-02	4.154E 02	9.272E 01
3	4.854E 03	1.583E 02	7.794E 02	2.286E 01	2.296E 01	3.725E-02	6.163E 02	9.390E 01

STA	L/D	DELTA E	L
1	1.731E 01	9.300E 00	1.000E 00
2	2.360E 01	9.350E 00	1.000E 00
3	2.990E 01	6.480E 00	7.500E-01

DIMENSIONLESS PARAMETERS

TEST 115 DATA POINT 7 IS SHOWN

DATA POINT	STA	MO	PR	RE	TL/VD	END/PRI-01
1	1	9.0610E 02	9.1801E 00	1.4244E 05	1.1973E 00	4.0000E 02
1	2	9.0721E 02	8.9652E 00	1.0781E 05	1.2037E 00	4.0000E 02
1	3	9.0923E 02	8.7608E 00	1.5300E 05	1.2078E 00	3.2610E 02
2	1	9.0940E 02	8.7960E 00	1.3997E 05	1.3078E 00	4.0000E 02
2	2	9.0920E 02	8.5002E 00	1.5937E 05	1.3419E 00	4.0000E 02
2	3	9.1342E 02	8.2521E 00	1.0740E 05	1.4470E 00	3.4300E 02
3	1	9.1010E 03	8.4298E 00	1.6154E 05	1.4394E 00	5.0100E 02
3	2	9.5792E 02	8.0852E 00	1.7303E 05	1.4088E 00	5.4550E 02
3	3	9.6331E 02	3.7925E 00	1.0410E 05	1.5910E 00	3.0910E 02
4	1	1.0154E 03	8.1370E 00	1.7020E 05	1.5604E 00	3.7530E 02
4	2	9.5540E 02	3.7530E 00	1.0470E 05	1.5490E 00	5.0000E 02
4	3	9.6777E 02	3.4080E 00	2.0037E 05	1.7300E 00	5.0000E 02
5	1	1.0542E 03	3.9552E 00	1.7779E 05	1.6101E 00	6.0030E 02
5	2	1.0104E 03	3.5333E 00	1.9521E 05	1.6101E 00	6.0030E 02
5	3	7.0529E 02	3.1750E 00	2.1374E 05	1.7092E 00	4.0030E 02
6	1	1.1273E 03	3.7307E 00	1.0507E 05	1.5530E 00	6.0521E 02
6	2	1.0643E 03	3.2770E 00	2.0660E 05	1.6421E 00	6.7530E 02
7	1	7.0662E 02	2.9200E 00	2.2730E 05	1.0451E 00	5.7812E 02
7	2	9.5323E 02	3.4900E 00	1.9424E 05	1.0451E 00	5.7812E 02
7	3	1.0571E 03	3.0170E 00	2.1930E 05	1.6900E 00	7.0530E 02
7	5	6.6737E 02	2.0605E 00	2.4324E 05	1.9067E 00	9.5121E 02

DATA POINT	STA	GMU RATIO	K RATIO	RU RATIO	CP RATIO
1	1	1.0401E 00	6.0310E-01	1.9701E 00	1.0079E 00
1	2	1.0405E 00	1.5773E-01	1.9803E 00	1.0082E 00
1	3	1.0650E 00	6.3043E-01	2.2452E 00	1.0100E 00
2	1	1.0230E 00	8.2345E-01	2.6330E 00	1.0157E 00
2	2	1.0861E 00	8.2869E-01	2.6063E 00	1.0100E 00
2	3	1.1174E 00	5.2065E-01	3.2034E 00	1.0200E 00
3	1	1.1140E 00	8.2140E-01	3.1970E 00	1.0210E 00
3	2	1.1100E 00	9.3233E-01	3.1034E 00	1.0205E 00
3	3	1.1721E 00	8.5600E-01	4.0000E 00	1.0400E 00
4	1	1.1561E 00	6.3613E-01	3.9530E 00	1.0349E 00
4	2	1.1650E 00	8.5298E-01	3.7543E 00	1.0340E 00
4	3	1.2200E 00	7.2570E-01	4.9426E 00	1.0600E 00
5	1	1.1791E 00	8.5182E-01	4.2751E 00	1.0423E 00
5	2	1.1854E 00	6.7620E-01	4.1135E 00	1.0466E 00
5	3	1.2455E 00	5.7070E-01	5.0632E 00	1.0771E 00
6	1	1.1904E 00	8.7193E-01	4.8352E 00	1.0505E 00
6	2	1.2001E 00	9.0252E-01	4.2135E 00	1.0548E 00
6	3	1.2506E 00	1.0712E 00	5.3140E 00	1.0877E 00
7	1	1.2547E 00	9.0963E-01	5.5925E 00	1.0813E 00
7	2	1.2210E 00	7.4995E-01	4.9303E 00	1.0604E 00
7	3	1.3175E 00	1.2352E 00	5.0153E 00	1.1507E 00

Report AFRL-TR-66-263, Appendix B

DIMENSIONLESS PARAMETERS

TABLE 11E DATA POINT 7 IS DUMMY

DATA POINT	STA	ML(F)	PR(F)	KE(F)	TL/TF	MU/PR(=4)
1	1	4.3448E 02	4.2121E 00	2.6704E 05	1.0890E 00	5.2330E 02
1	2	7.7710E 02	3.0073E 00	2.1051E 05	1.0933E 00	4.9697E 02
1	3	3.4693E 02	2.6686E 00	2.4139E 05	1.1181E 00	3.6934E 02
2	1	7.0760E 02	4.3898E 00	2.6105E 05	1.1444E 00	5.6291E 02
2	2	7.6256E 02	2.2857E 00	2.6957E 05	1.1460E 00	5.4815E 02
2	3	3.6729E 02	1.4135E 00	3.0040E 05	1.1627E 00	4.0607E 02
3	1	3.7426E 02	1.9032E 00	3.0042E 05	1.1901E 00	6.6481E 02
3	2	5.2511E 02	1.8050E 00	3.1613E 05	1.1626E 00	6.4382E 02
3	3	3.6648E 02	1.4749E 00	3.9507E 05	1.2284E 00	4.8440E 02
4	1	7.2552E 02	1.6148E 00	3.5361E 05	1.2204E 00	7.0927E 02
4	2	3.5400E 02	1.5463E 00	3.6944E 05	1.2354E 00	7.1800E 02
4	3	3.7477E 02	1.1734E 00	4.7207E 05	1.2635E 00	5.3908E 02
5	1	3.9330E 02	1.4744E 00	3.0989E 05	1.2401E 00	7.6485E 02
5	2	6.6214E 02	1.4755E 00	4.1207E 05	1.2449E 00	7.5488E 02
5	3	5.1521E 02	1.0734E 00	5.1035E 05	1.2830E 00	5.9803E 02
6	1	5.5556E 02	1.3618E 00	4.1161E 05	1.2402E 00	9.4944E 02
6	2	4.4235E 02	1.2040E 00	4.3102E 05	1.2430E 00	8.5696E 02
6	3	3.3164E 02	5.5072E-01	5.7756E 05	1.3031E 00	6.4054E 02
7	1	3.1682E 02	1.0750E 00	5.0473E 05	1.2978E 00	7.9336E 02
7	2	3.6659E 02	1.1377E 00	4.8052E 05	1.2579E 00	9.1799E 02
7	3	6.1689E 02	3.1492E-01	6.0613E 05	1.3326E 00	6.8924E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 116 BURNOUT AT DATA POINT 7

AF * 0.138E-03 O = 0.132E-01 L = 0.350E 01 DELTA T0 = 0.140E 01

DATA POINTS

POINT	PJ-IN	PJ-OUT	TB-IN	TB-OUT	M	E2	I2	GP	MT BAL	C
1	3.904E 03	3.854E 03	1.222E 02	1.206E 02	1.087E 00	9.930E 00	4.522E 02	4.257E 00	1.567E 01	7.883E 03
2	3.903E 03	3.854E 03	1.224E 02	1.304E 02	1.080E 00	1.521E 01	6.840E 02	9.863E 00	-1.204E 00	7.832E 03
3	3.956E 03	3.948E 03	1.218E 02	1.490E 02	1.088E 00	2.052E 01	9.109E 02	1.776E 01	2.093E 00	7.890E 03
4	3.965E 03	3.917E 03	1.218E 02	1.565E 02	1.080E 00	2.337E 01	1.028E 03	2.278E 01	-2.118E 00	7.832E 03
5	3.959E 03	3.911E 03	1.218E 02	1.660E 02	1.075E 00	2.629E 01	1.148E 03	2.861E 01	-3.466E 00	7.794E 03
6	3.956E 03	3.907E 03	1.218E 02	1.747E 02	1.072E 00	2.849E 01	1.230E 03	3.330E 01	-6.508E 00	7.774E 03
7	3.956E 03	3.906E 03	1.218E 02	1.813E 02	1.069E 00	2.950E 01	1.284E 03	3.591E 01	-1.145E 01	7.752E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 116 BURNOUT AT DATA POINT 7

DATA POINT 1

SYA	PU	TB	TW	TI	Q/A	U/AP	N	DEL TF	VS
1	3.860E 03	1.246E 02	2.880E 02	1.807E 02	2.507E 00	2.456E 00	4.376E-02	5.613E 01	9.008E 01
2	3.872E 03	1.205E 02	2.770E 02	1.688E 02	2.509E 00	2.456E 00	5.807E-02	4.239E 01	9.015E 01
3	3.858E 03	1.283E 02	2.870E 02	1.796E 02	2.507E 00	2.456E 00	4.788E-02	5.130E 01	9.022E 01

STA	L/D	DELTA E	LE
1	7.666E 00	9.930E 00	3.500E 00
2	1.416E 01	9.530E 00	3.500E 00
3	2.046E 01	5.930E 00	3.500E 00

LOCAL TEST PARAMETERS

TEST 116 BURNDOUT AT DATA POINT 2

STA	PB	TB	TW	TI	W/A	Q/AP	M	DEL TF	VS
1	3-679E 03	1-262E 02	4-860E 02	2-596E 02	5-811E 00	5-690E 00	4-333E-02	1-313E 02	8-964E 01
2	3-671E 03	1-229E 02	4-670E 02	2-373E 02	5-818E 00	5-690E 00	5-443E-02	1-045E 02	8-901E 01
3	3-657E 03	1-373E 02	4-790E 02	2-514E 02	5-813E 00	5-690E 00	4-987E-02	1-141E 02	8-998E 01
STA	L/D	DELTA E	LE						
1	7-668E 00	1-521E 01	3-500E 00						
2	1-416E 01	1-521E 01	3-500E 00						
3	2-046E 01	1-521E 01	3-500E 00						

LOCAL TEST PARAMETERS

TEST 116 BURNDOUT AT DATA POINT 3

STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	3-579E 03	1-312E 02	7-040E 02	3-341E 02	1-043E 01	1-021E 01	5-032E-02	2-029E 02	9-041E 01
2	3-958E 03	1-366E 02	6-040E 02	2-814E 02	1-046E 01	1-021E 01	7-157E-02	1-427E 02	9-070E 01
3	3-951E 03	1-461E 02	6-760E 02	2-946E 02	1-045E 01	1-021E 01	6-998E-02	1-079E 02	9-099E 01
STA	L/D	DELTA E	LE						
1	7-668E 00	2-052E 01	3-500E 00						
2	1-416E 01	2-052E 01	3-500E 00						
3	2-046E 01	2-052E 01	3-500E 00						

LOCAL TEST PARAMETERS

TEST 116 BURNDOUT AT DATA POINT 4

STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	3-940E 03	1-341E 02	8-500E 02	3-917E 02	1-343E 01	1-314E 01	5-106E-02	2-877E 02	8-988E 01
2	3-934E 03	1-440E 02	7-990E 02	3-260E 02	1-346E 01	1-314E 01	7-221E-02	1-820E 02	9-020E 01
3	3-920E 03	1-540E 02	8-180E 02	3-507E 02	1-386E 01	1-314E 01	6-802E-02	1-987E 02	9-082E 01
STA	L/D	DELTA E	LE						
1	7-668E 00	2-337E 01	3-500E 00						
2	1-416E 01	2-337E 01	3-500E 00						
3	2-046E 01	2-337E 01	3-500E 00						

LOCAL TEST PARAMETERS

TEST 116 RUNOUT AT DATA POINT 7

STA	Pb	Tu	Tb	Tl	U/A	Q/AP	M	DEL TF	VS
1	3.592E 03	1.376E 02	9.980E 02	4.803E 02	1.687E 01	1.651E 01	5.313E-02	3.107E 02	8.964E 01
2	3.529E 03	1.502E 02	9.280E 02	3.503E 02	1.671E 01	1.651E 01	6.049E-02	2.081E 02	9.006E 01
3	3.514E 03	1.645E 02	9.700E 02	4.114E 02	1.690E 01	1.651E 01	6.640E-02	2.486E 02	9.956E 01
STA	L/D	DELTA E		LE					
1	7.610E 00	2.623E 01	3.500E 00						
2	1.416E 01	2.623E 01	3.500E 00						
3	2.040E 01	2.627E 01	3.500E 00						

LOCAL TEST PARAMETERS

TEST 116 RUNOUT AT DATA POINT 7

STA	Pb	Tu	Tb	Tl	U/A	Q/AP	M	DEL TF	VS
1	3.592E 03	1.407E 02	1.100E 03	4.775E 02	1.566E 01	1.926E 01	5.721E-02	3.364E 02	8.944E 01
2	3.529E 03	1.508E 02	1.045E 03	4.028E 02	1.470E 01	1.926E 01	7.796E-02	2.470E 02	9.002E 01
3	3.514E 03	1.709E 02	1.059E 03	4.626E 02	1.960E 01	1.926E 01	6.603E-02	2.916E 02	9.061E 01
STA	L/D	DELTA E		LE					
1	7.610E 00	2.623E 01	3.500E 00						
2	1.416E 01	2.623E 01	3.500E 00						
3	2.040E 01	2.640E 01	3.500E 00						

LOCAL TEST PARAMETERS

TEST 116 RUNOUT AT DATA POINT 7

STA	Pb	Tu	Tb	Tl	U/A	Q/AP	M	DEL TF	VS
1	3.592E 03	1.430E 02	1.104E 03	5.030E 02	2.110E 01	2.072E 01	5.662E-02	3.107E 02	8.928E 01
2	3.529E 03	1.600E 02	1.140E 03	4.705E 02	2.111E 01	2.072E 01	6.547E-02	3.165E 02	8.993E 01
3	3.514E 03	1.779E 02	1.130E 03	4.829E 02	2.112E 01	2.072E 01	7.240E-02	2.850E 02	9.060E 01
STA	L/D	DELTA E		LE					
1	7.610E 00	2.623E 01	3.500E 00						
2	1.416E 01	2.623E 01	3.500E 00						
3	2.040E 01	2.650E 01	3.500E 00						

DIMENSIONLESS PARAMETERS

TEST 116 BURNDOUT AT DATA POINT 7

DATA POINT	STA	MU	PR	RE	TI/TB	MU/PR(1.0)
1	1	3.2206E 02	3.3649E 30	1.4583E 05	1.0960E 00	5.0596E 02
1	2	1.0880E 03	3.3154E 30	1.9833E 05	1.0721E 00	6.7361E 02
1	3	8.9480E 02	3.2676E 00	2.0075E 05	1.0872E 00	5.5704E 02
2	1	8.0970E 02	3.2690E 00	1.9934E 05	1.2232E 00	5.0410E 02
2	2	1.0104E 03	3.1611E 00	2.0501E 05	1.1764E 00	6.3762E 02
2	3	9.1966E 02	3.0607E 00	2.1054E 05	1.1910E 00	5.8790E 02
3	1	9.3630E 02	3.1989E 00	2.0453E 05	1.3433E 00	5.4909E 02
3	2	1.3172E 03	3.0313E 00	2.1379E 05	1.2304E 00	8.4538E 02
3	3	1.2578E 03	2.8821E 00	2.2281E 05	1.2440E 00	8.2344E 02
4	1	9.4485E 02	3.1311E 00	2.0663E 05	1.4337E 00	5.9053E 02
4	2	1.3109E 03	2.9224E 00	2.1867E 05	1.3813E 00	8.5482E 02
4	3	1.2039E 03	2.7379E 00	2.3071E 05	1.3203E 00	6.0473E 02
5	1	9.7930E 02	3.0537E 00	2.0995E 05	1.5199E 00	6.2659E 02
5	2	1.4577E 03	2.4060E 00	2.2504E 05	1.3361E 00	8.6478E 02
5	3	1.1828E 03	2.5829E 00	2.4103E 05	1.3991E 00	8.0923E 02
6	1	1.0498E 03	2.9990E 00	2.1308E 05	1.5604E 00	6.7749E 02
6	2	1.4013E 03	2.7059E 00	2.3124E 05	1.4011E 00	9.4111E 02
6	3	1.1646E 03	2.4527E 00	2.1523E 05	1.4622E 00	8.1345E 02
7	1	1.0388E 03	2.9417E 00	2.1523E 05	1.6060E 00	6.7259E 02
7	2	1.1703E 03	2.6030E 00	2.3601E 05	1.5104E 00	7.9400E 02
7	3	1.2693E 03	2.3622E 00	2.5835E 05	1.4487E 00	9.8891E 02

DATA POINT	STA	K RATIO	MU RATIO	CP RATIO
1	1	9.2842E-01	1.3663E 00	9.7316E-01
1	2	9.4390E-01	1.4003E 00	9.7347E-01
1	3	9.3469E-01	1.3263E 00	9.7224E-01
2	1	8.8365E-01	1.0861E 00	9.5662E-01
2	2	8.9876E-01	1.0623E 00	9.6697E-01
2	3	8.9809E-01	1.7122E 00	9.6461E-01
3	1	8.7194E-01	2.4342E 00	9.6986E-01
3	2	8.9034E-01	1.9052E 00	9.6473E-01
3	3	8.9055E-01	1.9205E 00	9.6336E-01
4	1	8.7685E-01	2.9075E 00	9.7500E-01
4	2	8.5837E-01	2.1953E 00	9.6522E-01
4	3	8.4919E-01	2.2693E 00	9.6416E-01
5	1	8.9257E-01	3.4257E 00	9.8292E-01
5	2	8.9402E-01	2.3527E 00	9.6544E-01
5	3	9.1467E-01	2.6522E 00	9.7600E-01
6	1	1.1753E 00	3.6653E 00	1.0028E 00
6	2	1.1208E 00	2.6760E 00	9.7425E-01
6	3	1.1505E 00	2.9828E 00	9.9423E-01
7	1	1.1556E 00	3.5589E 00	1.0135E 00
7	2	1.1651E 00	3.2950E 00	1.0006E 00
7	3	1.1477E 00	2.1327E 00	9.4347E-01

DIMENSIONLESS PARAMETERS

TEST 116 BURNOUT AT DATA POINT 7

DATA POINT	STA	NU(F)	PR(F)	RE(F)	YL/TR	MINIMUM -A)
1	1	7.8986E 02	2.7616E 00	2.2779E 05	1.0460E 00	5.2610E 02
1	2	1.9956E 03	2.8549E 04	2.2236E 03	1.0200E 00	5.9381E 02
1	3	8.6271E 02	2.7381E 00	2.2944E 05	1.0441E 00	5.7048E 02
2	1	7.4578E 02	2.1458E 00	2.7535E 06	1.1004E 00	5.4961E 02
2	2	9.4509E 02	2.2834E 00	2.6863E 05	1.0810E 00	5.8880E 02
2	3	6.5793E 02	2.1399E 00	2.7703E 05	1.0878E 00	6.3204E 02
3	1	8.4172E 02	1.7811E 00	3.2153E 05	1.1469E 00	6.4010E 02
3	2	1.2151E 03	1.9883E 00	2.9650E 03	1.1062E 00	9.2451E 02
3	3	1.1642E 03	1.8861E 00	3.0913E 05	1.1007E 00	9.0303E 02
4	1	8.4997E 02	1.5638E 00	3.8564E 05	1.1782E 00	7.0384E 02
4	2	1.2861E 03	1.7683E 00	3.2403E 05	1.1382E 00	8.6182E 02
4	3	1.1066E 03	1.6329E 00	3.4603E 05	1.1380E 00	9.09947E 02
5	1	8.6772E 02	1.3842E 00	3.9284E 05	1.2063E 00	7.6146E 02
5	2	1.3328E 03	1.6303E 00	3.4433E 05	1.1838E 00	1.0284E 03
5	3	1.0863E 03	1.4183E 00	3.8930E 05	1.1664E 00	9.4463E 02
6	1	9.3074E 02	1.3882E 00	4.1463E 05	1.2109E 00	8.3790E 02
6	2	1.2783E 03	1.6633E 00	3.7892E 05	1.1671E 00	1.08177E 03
6	3	1.0729E 03	1.2817E 00	4.3102E 05	1.1877E 00	9.7784E 02
7	1	9.1873E 02	1.2184E 00	4.3752E 05	1.2328E 00	8.4888E 02
7	2	1.0634E 03	1.2544E 00	4.2995E 05	1.2833E 00	9.7123E 02
7	3	1.1770E 03	1.2443E 00	4.3551E 05	1.1832E 00	1.0778E 03

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 117 3/16 X 4 TUBE FIRST DATA POINT ONLY

AF = 0.136E-C3 D = 0.132E-01 L = 0.400E 01 DELTA TD = 0.520E 01

DATA POINTS

POINT	PR-IN	PR-OUT	TR-IN	TR-OUT	W	E2	I2	OP	MT BAL	C
1	3.744E C3	3.562E 03	7.180E 01	1.046E 02	2.350E 00	3.306E 01	1.316E 03	0.224E 01	-0.964E 00	1.794E 04

TEST SECTION

LOCAL TEST PARAMETERS

TEST 117 3/16 X 4 TUBE FIRST DATA POINT ONLY

STA	PU	TU	Tn	TI	O/A	Q/MP	N	DEL TP	VR
1	2-622E 03	0-742E 01	1-110E 03	4-140E 02	2-180E 01	2-101E 01	5-300E-02	3-270E 02	1-917E 02
2	2-572E 03	5-572E 01	1-132E 03	4-677E 02	2-100E 01	2-120E 01	5-700E-02	3-720E 02	1-960E 02
3	3-517E 03	1-000E 02	1-137E 03	4-745E 02	2-100E 01	2-120E 01	5-720E-02	3-701E 02	1-920E 02

STA	L/D	DELTA L	LE
1	1-101E 01	0-880E 00	1-000E 00
2	1-731E 01	1-473E 01	1-750E 00
3	2-360E 01	1-473E 01	1-750E 00

CIPLEASIONLESS PARAMETERS

TEST 117 3/16 X 4 TUBE FIRST DATA POINT ONLY

DATA POINT	STA	MU	PP	RE	VI/TP	MU/PP(1-0)
1	1	1-122E 03	4-620E 00	3-210E 05	1-590E 00	7-000E 02
1	2	1-118E 03	4-780E 00	3-457E 05	1-660E 00	6-231E 02
1	3	1-105E 03	3-572E 00	3-600E 05	1-665E 00	6-300E 02

DATA POINT	STA	MMD RATIO	K RATIO	MU RATIO	CP RATIO
1	1	1-101E 00	4-190E-01	4-340E 00	9-000E-01
1	2	1-107E 00	4-421E-01	4-810E 00	1-000E 00
1	3	1-100E 00	4-570E-01	4-601E 00	1-000E 00

TEST 117 3/16 X 4 TUBE FIRST DATA POINT ONLY

DATA POINT	STA	MU(F)	PP(F)	RE(F)	VI/TP	MU/PP(1-0)
1	1	1-0520E 03	1-030E 00	7-3210E 05	1-230E 00	8-9700E 02
1	2	4-320E 02	1-4430E 00	3-1521E 05	1-250E 00	8-0630E 02
1	3	5-3665E 02	1-390E 00	4-0030E 05	1-240E 00	8-187E 02

TEST SECTION

LOCAL TEST PARAMETERS

TEST 119 NO BURNDOUT HEATED DELTA P TEST

STA	PO	TI	TU	TV	W/A	W/MP	M	DEL TV	VS
1	0.124E 03	0.308E 01	3.920E 02	2.750E 02	2.903E 00	3.100E 00	1.030E-02	1.900E 02	5.000E 01
2	0.129E 03	0.337E 01	3.900E 02	2.500E 02	3.020E 00	3.310E 00	2.130E-02	1.800E 02	5.000E 01
STA	L/D	DELTA E	LE						
1	1.700E 01	2.100E 00	1.000E 00						
2	2.101E 01	2.000E 00	7.000E-01						

LOCAL TEST PARAMETERS

TEST 119 NO BURNDOUT HEATED DELTA P TEST

STA	PO	TI	TU	TV	W/A	W/MP	M	DEL TV	VS
1	0.124E 03	0.280E 01	0.102E 02	0.140E 02	5.300E 00	5.017E 00	1.000E-02	3.220E 02	5.051E 01
2	0.123E 03	0.034E 01	0.200E 02	3.792E 02	0.590E 00	0.400E 00	2.200E-02	2.800E 02	5.007E 01
STA	L/D	DELTA E	LE						
1	1.700E 01	0.200E 00	1.000E 00						
2	2.101E 01	3.000E 00	7.000E-01						

LOCAL TEST PARAMETERS

TEST 119 NO BURNDOUT HEATED DELTA P TEST

STA	PO	TI	TU	TV	W/A	W/MP	M	DEL TV	VS
1	0.122E 03	1.050E 02	0.000E 02	5.300E 02	0.002E 00	0.710E 00	2.010E-02	0.330E 02	5.000E 01
2	0.117E 03	1.115E 02	0.210E 02	0.000E 02	0.017E 00	0.000E 00	2.500E-02	3.770E 02	5.000E 01
STA	L/D	DELTA E	LE						
1	1.700E 01	5.000E 00	1.000E 00						
2	2.101E 01	0.300E 00	7.000E-01						

DIMENSIONLESS PARAMETERS

TEST 114 NU EMBLUT HEATED DELTA P TEST

DATA POINT	STA	NU	PK	RE	TL/TO	NUMPR(,4)
1	1	0.0011E 02	0.0040E 00	1.2201E 05	1.3534E 00	2.4111E 02
1	2	0.0054E 02	0.0092E 00	1.2502E 05	1.2011E 00	3.1733E 02
2	1	0.0240E 02	0.0157E 00	1.3289E 05	1.5030E 00	2.7100E 02
2	2	0.2100E 02	0.1050E 00	1.2000E 05	1.5030E 00	3.0992E 02
3	1	0.0587E 02	0.0240E 00	1.0217E 05	1.7705E 00	3.0931E 02
3	2	0.0745E 02	0.0374E 00	1.0139E 05	1.0000E 00	3.0750E 02

DATA POINT	STA	GMJ RATIO	K RATIO	NU RATIO	CP RATIO
1	1	1.0070E 00	0.1975E-01	2.7081E 00	9.0310E-01
1	2	1.0741E 00	0.0109E-01	2.0375E 00	9.0250E-01
2	1	1.0127E 00	0.2071E-01	0.1999E 00	9.9001E-01
2	2	1.0120E 00	0.2005E-01	0.0037E-01	9.0037E-01
3	1	1.2257E 00	0.2027E-01	0.5032E 00	1.0307E 00
3	2	1.0101E 00	0.2703E-01	0.5001E 00	1.0101E 00

DIMENSIONLESS PARAMETERS

TEST 119 NU EMBLUT HEATED DELTA P TEST

DATA POINT	STA	NU(1)	PR(1)	RE(1)	TL/TF	NUMPR(,4)
1	1	0.0017E 02	0.0091E 00	2.1037E 05	1.1502E 01	2.0001E 02
1	2	0.0220E 02	0.0100E 00	2.0000E 05	1.1309E 00	3.0030E 02
2	1	0.0121E 02	0.0299E 00	2.0000E 05	1.2250E 00	3.3900E 02
2	2	0.0290E 02	0.0300E 00	2.7010E 05	1.2000E 00	0.2000E 02
3	1	0.0510E 02	0.0200E 00	3.0077E 05	1.2701E 00	0.1300E 02
3	2	0.0700E 02	0.0375E 00	3.0077E 05	1.2003E 00	0.0933E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

GENERAL TEST PARAMETERS

TEST 121 NU CURRANT HEATED DELTA P TEST

AF = 0.132E-03 U = 0.132E-01 L = 0.500E 01 DELTA TD = 0.230E 01

DATA POINTS

PCINAT	PG-IN	PG-OUT	TE-IN	TE-OUT	V	F2	F2	CP	WT OIL	C
1	4.007E 03	3.575E 03	5.520E 03	7.720E 01	1.010E 00	1.951E 01	6.000E 02	1.103E 01	-3.327E 00	0.230E 01
2	4.200E 03	3.550E 03	6.010E 01	9.500E 01	1.010E 00	2.052E 01	0.900E 02	2.417E 01	-0.200E 00	0.140E 03
3	2.980E 03	2.070E 03	5.550E 01	1.120E 02	1.010E 00	3.515E 01	1.000E 03	3.010E 01	-1.010E 00	0.257E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 121 NO BURST HEATED DELTA P TEST

STA	PU	TC	TD	TI	O/A	Q/MP	N	DEL TF	VS
1	2455E 01	7482E 01	4.040E 02	2.332E 02	4.231E 00	4.279E 00	2.440E-02	1.000E 02	9.050E 01
2	3490E 01	7482E 01	4.000E 02	2.140E 02	4.710E 00	4.514E 00	3.200E-02	1.300E 02	9.640E 01

DELTA E

STA	L/D	DELTA E	LE
1	4250E 01	2470E 00	1.000E 00
2	4550E 01	2420E 00	7.500E-01

LOCAL TEST PARAMETERS

TEST 121 NO BURST HEATED DELTA P TEST

STA	PU	TC	TD	TI	O/A	Q/MP	N	DEL TF	VS
1	3479E 01	6487E 01	7482E 02	3.790E 02	9.279E 00	9.301E 00	3.200E-02	2.920E 02	9.700E 01
2	3456E 01	9481E 01	7482E 02	3.490E 02	1.011E 01	9.703E 00	3.835E-02	2.553E 02	9.730E 01

DELTA E

STA	L/D	DELTA E	LE
1	4250E 01	2470E 00	1.000E 00
2	4490E 01	4330E 00	7450E-01

LOCAL TEST PARAMETERS

TEST 121 NO BURST HEATED DELTA P TEST

STA	PU	TC	TD	TI	O/A	Q/MP	N	DEL TF	VS
1	2482E 01	9487E 01	5.020E 02	4.740E 02	1.015E 01	1.410E 01	3.730E-02	3.790E 02	9.070E 01
2	2490E 01	1.050E 02	5.390E 02	4.440E 02	1.480E 01	1.451E 01	4.279E-02	3.391E 02	9.710E 01

DELTA E

STA	L/D	DELTA E	LE
1	4250E 01	2470E 00	1.000E 00
2	24550E 01	54200E 00	74500E-01

DIMENSIONLESS PARAMETERS

TEST 121 NO BURNDOUT HEATED DELTA P TEST

DATA POINT	STA	MU	PR	ME	VI/TO	MU/PR(1.0)
1	1	5.4319E 02	5.4730E 00	1.4161E 05	1.3610E 00	2.7810E 02
1	2	6.6148E 02	5.2527E 00	1.4679E 05	1.2570E 00	3.4094E 02
2	1	6.3781E 02	4.6694E 00	1.6257E 05	1.5333E 00	3.4433E 02
2	2	7.5479E 02	4.3531E 00	1.7846E 05	1.4609E 00	4.1902E 02
3	1	7.2805E 02	4.1511E 00	1.7835E 05	1.6787E 00	4.1290E 02
3	2	8.2195E 02	3.8015E 00	1.9194E 05	1.5931E 00	4.8100E 02

DATA POINT	STA	MHO RATIO	K RATIO	MU RATIO	CP RATIO
1	1	1.0715E 00	8.2849E-01	2.6014E 00	9.8572E-01
1	2	1.0610E 00	8.3833E-01	2.3230E 00	9.8695E-01
2	1	1.1405E 00	8.1803E-01	3.9110E 00	9.8303E-01
2	2	1.1207E 00	8.2306E-01	3.3266E 00	9.7791E-01
3	1	1.1571E 00	8.5285E-01	4.0491E 00	1.0089E 00
3	2	1.1719E 00	8.5657E-01	4.1193E 00	9.9627E-01

DIMENSIONLESS PARAMETERS

TEST 121 NO BURNDOUT HEATED DELTA P TEST

DATA POINT	STA	MU(F)	PR(F)	RE(F)	VI/TF	MU/PR(1.0)
1	1	4.6050E 02	2.7544E 00	2.4452E 05	1.1308E 00	3.2066E 02
1	2	5.9228E 02	2.8949E 00	2.3585E 05	1.1142E 00	3.6911E 02
2	1	5.3576E 02	1.7761E 00	3.4595E 05	1.2111E 00	4.2578E 02
2	2	6.4581E 02	1.6722E 00	3.3266E 05	1.1873E 00	5.0254E 02
3	1	6.0581E 02	1.4977E 00	4.1874E 05	1.2534E 00	5.3185E 02
3	2	7.0155E 02	1.4631E 00	4.0694E 05	1.2293E 00	6.0249E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 122 NU BURNUST HEATED DELTA P TEST

AF = 0.138E-03 D = 0.132E-01 L = 0.500E 01 DELTA TD = 0.100E 01

DATA POINTS

PCINT	PS-IN	PS-OUT	TS-IN	TS-OUT	W	E2	I2	OP	MT BAL	C
1	4.627E 03	4.539E 03	6.320E 01	8.140E 01	1.180E 00	1.938E 01	6.110E 02	1.123E 01	-1.878E 01	3.557E 03
2	4.536E 03	4.447E 03	6.340E 01	9.900E 01	1.182E 00	2.848E 01	4.870E 02	2.395E 01	-6.532E 00	8.557E 03
3	4.445E 03	4.356E 03	6.350E 01	1.159E 02	1.190E 00	3.534E 01	1.790E 03	3.652E 01	-5.438E 00	8.639E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 122 NO BURNOUT HEATED DELTA P TEST

STA	FB	TB	TI	TA	Q/MP	M	DEL TP	VS
1	4.501E 03	7.088E 01	2.352E 02	4.553E 00	4.052E 00	2.811E-02	1.504E 02	9.534E 01
2	4.543E 03	6.049E 01	2.279E 02	4.776E 00	4.500E 00	3.094E-02	1.470E 02	9.590E 01
STA	L/D	DELTA E	LE					
1	2.360E 01	3.840E 00	1.000E 00					
2	2.590E 01	2.580E 00	7.800E-01					

LOCAL TEST PARAMETERS

TEST 122 NO BURNOUT HEATED DELTA P TEST

STA	FB	TB	TI	TA	Q/MP	M	DEL TP	VS
1	4.489E 03	9.010E 01	3.712E 02	9.647E 00	9.400E 00	3.377E-02	2.811E 02	9.637E 01
2	4.451E 03	9.722E 01	3.610E 02	9.900E 00	9.649E 00	3.650E-02	2.630E 02	9.646E 01
STA	L/D	DELTA E	LE					
1	2.360E 01	5.640E 00	1.000E 00					
2	2.590E 01	4.300E 00	7.500E-01					

LOCAL TEST PARAMETERS

TEST 122 NO BURNOUT HEATED DELTA P TEST

STA	FB	TB	TI	TA	Q/MP	M	DEL TP	VS
1	4.377E 03	1.020E 02	4.663E 02	1.972E 01	1.450E 01	3.909E-02	3.630E 02	9.771E 01
2	4.355E 03	1.133E 02	4.600E 02	1.996E 01	1.462E 01	4.210E-02	3.407E 02	9.819E 01
STA	L/D	DELTA E	LE					
1	2.360E 01	7.810E 00	1.000E 00					
2	2.990E 01	5.300E 00	7.500E-01					

DIMENSIONLESS PARAMETERS

TEST 122 NU SURFNUIT HEATED DELTA P TEST

DATA POINT	STA	NU	PH	RE	TI/TO	NU/PR(.4)
1	1	5.6554E 02	5.2204E 00	1.4633E 05	1.2950E 00	2.9374E 02
1	2	6.2227E 02	5.0053E 00	1.5180E 05	1.2727E 00	3.2674E 02
2	1	6.6276E 02	4.5194E 00	1.6579E 05	1.5109E 00	3.4870E 02
2	2	7.1634E 02	4.2273E 00	1.7553E 05	1.6774E 00	4.0243E 02
3	1	7.7448E 02	4.0273E 00	1.8452E 05	1.8452E 00	4.4361E 02
3	2	8.0357E 02	3.6945E 00	1.9225E 05	1.6044E 00	4.7742E 02

DATA POINT	STA	NU RATIO	K RATIO	NU RATIO	CP RATIO
1	1	1.077E 00	6.2524E-01	2.4844E 00	1.0026E 00
1	2	1.0650E 00	6.3304E-01	2.3241E 00	1.0003E 00
2	1	1.1542E 00	6.1871E-01	3.6904E 00	1.0034E 00
2	2	1.1459E 00	6.2740E-01	3.3702E 00	9.5939E-01
3	1	1.1677E 00	6.5289E-01	4.5437E 00	1.0204E 00
3	2	1.1782E 00	6.6459E-01	4.1512E 00	1.0165E 00

DIMENSIONLESS PARAMETERS

TEST 122 NU SURFNUIT HEATED DELTA P TEST

DATA POINT	STA	NU(IF)	PR(IF)	RE(IF)	TI/TF	NU/PR(.4)
1	1	5.9514E 02	2.7004E 00	2.4457E 05	1.1285E 00	3.3963E 02
1	2	5.5727E 02	2.7327E 00	2.4473E 05	1.1200E 00	3.7274E 02
2	1	5.6553E 02	1.8170E 00	3.3641E 05	1.2030E 00	4.4859E 02
2	2	6.1212E 02	1.4590E 00	3.3644E 05	1.1914E 00	4.0149E 02
3	1	6.5303E 02	1.4302E 00	4.1403E 05	1.2041E 00	5.4069E 02
3	2	6.9573E 02	1.4282E 00	4.1004E 05	1.2323E 00	5.9042E 02

LIGUID SIDE HEAT TRANSFER TEST DATA

LIVEMALL TEST PARAMETERS

TEST 123 NU BLANKOUT HEATED DELTA P TEST

AF = 0.132E-03 D = 0.132E-01 L = 0.500E 01 DELTA T0 = 0.500E 01

FLIAT	PH-IN	PH-OUT	T0-IN	T0-OUT	N	E2	I2	CP	MT BAL	G
1	2.140E 03	2.619E 03	0.050E 01	0.500E 01	2.230E 00	3.033E 01	9.470E 02	2.723E 01	-2.823E 00	1.617E 04
2	2.046E 03	2.733E 03	0.050E 01	1.021E 02	2.260E 00	4.175E 01	1.280E 03	5.000E 01	-2.372E 00	1.639E 04

DATA POINTS

TEST SECTION

LOCAL TEST PARAMETERS

TEST 123 NU BLANKOUT HEATED DELTA P TEST

STA	PE	T0	TI	Q/A	Q/AD	N	DEL TF	VS
1	2.899E 03	0.790E 02	2.512E 02	1.156E 01	1.109E 01	6.451E-02	1.719E 02	1.013E 02
2	2.825E 03	0.780E 02	2.542E 02	1.050E 01	1.057E 01	5.034E-02	2.099E 02	1.817E 02

STA	L/D	DELTA E	LE
1	2.360E 01	0.170E 00	1.000E 00
2	2.550E 01	0.410E 00	7.560E-01

LOCAL TEST PARAMETERS

TEST 123 NU BLANKOUT HEATED DELTA P TEST

STA	PH	T0	TI	Q/A	Q/AD	N	DEL TF	VS
1	2.611E 03	1.030E 03	3.346E 02	2.115E 01	2.055E 01	8.461E-02	2.429E 02	1.047E 02
2	2.749E 03	1.000E 02	3.952E 02	1.978E 01	1.986E 01	6.730E-02	2.951E 02	1.054E 02

STA	L/D	DELTA E	LE
1	4.240E 01	0.430E 00	1.000E 00
2	2.550E 01	0.110E 00	7.560E-01

DIMENSIONLESS PARAMETERS

TEST 123 NO BURNOUT HEATED DELTA P TEST

CATA POINT	STA	NU	PR	RE	TI/TO	WATER(-4)
1	1	1.3001E 03	5.0720E 00	2.0300E 05	1.3107E 00	6.7900E 02
1	2	1.0042E 03	4.7901E 00	2.9770E 05	1.3004E 00	6.3743E 02
2	1	1.6712E 03	4.4400E 00	3.2100E 05	1.4400E 00	6.1500E 02
2	2	1.3122E 03	4.1243E 00	3.4300E 05	1.5270E 00	7.0000E 02

CATA POINT	STA	COND RATIO	K RATIO	NU RATIO	CP RATIO
1	1	1.0774E 00	0.2215E-01	2.6701E 00	1.0000E 00
1	2	1.0500E 00	0.1600E-01	3.0171E 00	1.0007E 00
2	1	1.1101E 00	0.2000E-01	3.3103E 00	1.0000E 00
2	2	1.1031E 00	0.3300E-01	3.6400E 00	1.0120E 00

DIMENSIONLESS PARAMETERS

TEST 123 NO BURNOUT HEATED DELTA P TEST

CATA POINT	STA	NU(F)	PR(F)	RE(F)	TI/TF	WATER(-4)
1	1	1.1064E 03	2.5390E 00	4.6004E 05	1.1370E 00	7.0900E 02
1	2	8.7026E 02	2.1774E 00	5.5302E 05	1.1610E 00	6.3743E 02
2	1	1.0332E 03	1.9130E 00	6.2800E 05	1.1000E 00	1.1000E 03
2	2	1.1170E 03	1.6297E 00	7.1103E 05	1.2004E 00	9.1077E 02

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 126 CONTINUED AT DATA POINT 5

AF = 0.2204E-03 U = 0.103E-01 L = 0.400E 01 DELTA TU = 0.600E 00

POINT	DATA POINTS									
	PL-IN	PL-OUT	TS-IN	TS-OUT	B	C2	I2	CP	MT BAL	S
1	4.175E 03	4.155E 03	1.722E 02	1.935E 02	5.900E-01	6.520E 00	3.400E 02	2.307E 00	1.054E 02	3.750E 03
2	4.175E 03	4.151E 03	1.734E 02	2.060E 02	5.900E-01	1.371E 01	5.230E 02	6.600E 00	-1.343E 01	3.750E 03
3	4.175E 03	4.142E 02	1.703E 02	2.170E 02	5.900E-01	1.960E 01	1.011E 03	1.731E 01	1.100E 01	3.750E 03
4	4.175E 03	4.144E 03	1.736E 02	2.204E 02	5.900E-01	2.022E 01	1.127E 03	2.160E 01	4.519E 00	3.750E 03
5	4.175E 03	4.141E 03	1.707E 02	4.385E 02	5.900E-01	2.222E 01	1.230E 03	2.591E 01	-7.500E 00	3.750E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 124 SUMMARY AT DATA POINT 1

STA	PU	TB	TS	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	4.14E 03	1.935E 02	2.74E 02	2.34E 02	0.30E-01	0.65E-01	1.93E-02	1.93E-02	0.40E 01	4.41E 01
2	4.15E 03	1.93E 02	2.90E 02	2.40E 02	0.10E-01	2.55E-01	1.65E-02	1.65E-02	5.10E 01	4.81E 01

DELTA E

STA	L/U	DELTA E	LE
1	1.251E 01	1.40E 00	1.00E 00
2	1.73E 01	1.25E 00	7.50E-01

LOCAL TEST PARAMETERS

TEST 124 SUMMARY AT DATA POINT 2

STA	PU	TB	TS	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	4.16E 03	2.02E 02	5.10E 02	3.77E 02	3.52E 00	2.44E 00	1.40E-02	1.40E-02	1.75E 02	4.43E 01
2	4.15E 03	2.05E 02	5.25E 02	3.90E 02	3.49E 00	2.48E 00	1.28E-02	1.28E-02	1.07E 02	4.43E 01

DELTA E

STA	L/U	DELTA E	LE
1	1.251E 01	2.43E 00	1.00E 00
2	1.70E 01	2.30E 00	7.50E-01

LOCAL TEST PARAMETERS

TEST 124 SUMMARY AT DATA POINT 3

STA	PU	TB	TS	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	4.15E 03	2.10E 02	7.02E 02	4.91E 02	0.05E 00	5.20E 00	2.22E-02	2.22E-02	2.81E 02	4.40E 01
2	4.15E 03	2.10E 02	7.20E 02	5.21E 02	0.01E 00	8.20E 00	2.00E-02	2.00E-02	3.00E 02	4.40E 01

DELTA E

STA	L/U	DELTA E	LE
1	1.251E 01	4.92E 00	1.00E 00
2	1.70E 01	3.30E 00	7.50E-01

LOCAL TEST PARAMETERS

TEST 124 SUMMARY AT DATA POINT 4

STA	PU	TB	TS	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	4.15E 03	2.10E 02	7.00E 02	5.42E 02	7.30E 00	7.00E 00	2.47E-02	2.47E-02	3.15E 02	4.40E 01
2	4.16E 03	2.20E 02	8.15E 02	5.07E 02	7.40E 00	7.70E 00	2.20E-02	2.20E-02	3.43E 02	4.47E 01

DELTA E

STA	L/U	DELTA E	LE
1	1.251E 01	5.07E 00	1.00E 00
2	1.70E 01	3.77E 00	7.50E-01

LUCAL TEST PARAMETERS

TEST 124 SUMMARY AT DATA POINT 5

STA	CB	TH	TH	TI	Q/A	Q/MP	M	REL TP	V3
1	4.152L 03	2.240E 02	6.92E 02	9.06E 02	9.361E 00	9.361E 00	2.507E-02	3.730E 02	0.076E 01
2	4.144E 03	2.352E 02	9.12E 02	6.201E 02	9.065E 00	9.370E 00	2.000E-02	3.000E 02	0.000E 01
STA	L/U	DELTA E	LE						
1	1.201E 01	9.550E 00	1.000E 00						
2	1.706E 01	4.170E 00	7.500E-01						

DIMENSIONLESS PARAMETERS

TEST 124 SUMMARY AT DATA POINT 5

DATA POINT	STA	MU	PR	ME	V1/T0	RELTPR(0)
1	1	4.596E 02	2.161E 00	1.063E 05	1.0667E 00	3.3772E 02
1	2	3.9340E 02	2.160E 00	1.0642E 05	1.0793E 00	2.9709E 02
2	1	3.3240E 02	2.088E 00	1.9352E 05	1.2640E 00	2.0660E 02
2	2	3.0405E 02	2.0361E 00	1.9620E 05	1.2851E 00	2.2930E 02
3	1	5.2270E 02	1.987E 00	2.0035E 05	1.0202E 00	3.9710E 02
3	2	4.7770E 02	1.929E 00	2.0509E 05	1.0522E 00	3.0734E 02
4	1	5.7970E 02	1.930E 00	2.0563E 05	1.0674E 00	4.0570E 02
4	2	5.2640E 02	1.850E 00	2.1241E 05	1.3013E 00	4.1110E 02
5	1	5.8205E 02	1.853E 00	2.1310E 05	1.5054E 00	4.5530E 02
5	2	5.6374E 02	1.7627E 00	2.2307E 05	1.5524E 00	4.0930E 02

DATA POINT	STA	MU RATIO	K RATIO	MU RATIO	CP RATIO
1	1	1.0203E 00	9.6842E-01	1.2092E 00	9.5917E-01
1	2	1.0235E 00	9.6509E-01	1.2030E 00	9.5840E-01
2	1	1.0844E 00	9.427E-01	1.9665E 00	9.6854E-01
2	2	1.0924E 00	9.5365E-01	2.0013E 00	9.7303E-01
3	1	1.1506E 00	9.8649E-01	2.7129E 00	1.0125E 00
3	2	1.1655E 00	1.0043E 00	2.9809E 00	1.0235E 00
4	1	1.1735E 00	1.0310E 00	2.9499E 00	1.0270E 00
4	2	1.1526E 00	1.0422E 00	3.0042E 00	1.0376E 00
5	1	1.2097E 00	1.0747E 00	3.2567E 00	1.0446E 00
5	2	1.2099E 00	1.1117E 00	3.2053E 00	1.0473E 00

DIMENSIONLESS PARAMETERS

TABLE 12. DIMENSIONLESS PARAMETERS AT DATA POINT 5

DATA POINT	STA	NU(1)	PRO(1)	RE(1)	TL/TP	IND(1)
1	1	0.5134E 02	1.9233E 00	2.0325E 05	1.0230E 00	3.0072E 02
1	2	3.0520E 02	1.9002E 00	2.0507E 05	1.0201E 00	2.0004E 02
2	1	3.1011E 02	1.0495E 00	2.0530E 05	1.1100E 00	2.7780E 02
2	2	2.9103E 02	1.0404E 00	2.7578E 05	1.1200E 00	2.0070E 02
3	1	4.7090E 02	1.1100E 00	3.2307E 05	1.1700E 00	4.7720E 02
3	2	4.5020E 02	1.0533E 00	3.0019E 05	1.1000E 00	0.0003E 02
4	1	3.5020E 02	1.0237E 00	3.0010E 05	1.1000E 00	0.0010E 02
4	2	3.0920E 02	0.7299E-01	3.7272E 05	1.2000E 00	3.1500E 02
5	1	3.0530E 02	0.3000E-01	3.0999E 05	1.2100E 00	3.0000E 02
5	2	3.0320E 02	0.0000E-01	4.0072E 05	1.2100E 00	3.7030E 02

LIGUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 125 NO BURNOUT HEATED DELTA P TEST

A = 0.120E-03 D = 0.122E-01 L = 0.000E 01 DELTA TD = 0.370E 01

DATA POINTS

POINT	PO-IN	PO-OUT	TA-IN	TA-OUT	W	E1	E2	IS	MP	HT DEL	Q
1	0.129E 03	2.752E 03	0.330E 01	0.400E 01	2.200E 00	2.970E 01	2.970E 01	9.210E 02	2.020E 01	1.700E 00	1.710E 02
2	0.029E 03	3.007E 03	0.220E 01	1.000E 02	2.200E 00	4.120E 01	4.120E 01	1.270E 02	0.900E 01	1.000E 00	1.000E 02
3	2.071E 03	2.500E 03	0.330E 01	1.100E 02	2.200E 00	5.000E 01	5.000E 01	1.200E 02	0.000E 01	-1.130E 01	1.000E 02

TEST SECTION

LOCAL TEST PARAMETERS

TEST 125 NU BURMAUT HEATED DELTA P TEST

STA	PU	TD	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	3.077E CJ	7.527E 01	6.330E C2	2.331E 02	1.076E 01	1.030E 01	6.029E-02	1.530E 02	1.079E 02
2	2.009E CJ	6.308E 01	6.340E 02	2.309E 02	1.061E 01	1.032E 01	7.102E-02	1.079E 02	1.020E 02

STA	L/D	DELTA E	LE
1	2.060E C1	2.527E 01	4.232E 00
2	2.950E C1	4.470E 00	7.599E-01

LOCAL TEST PARAMETERS

TEST 125 NU BURMAUT HEATED DELTA F TEST

STA	PU	TD	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	2.771E CJ	9.122E 01	1.000E 03	3.159E 02	2.041E 01	2.000E 01	8.752E-02	2.200E 02	1.900E 02
2	2.709E CJ	9.279E 01	1.007E 03	2.257E 02	2.031E 01	1.990E 01	8.792E-02	2.200E 02	1.900E 02

STA	L/D	DELTA E	LE
1	2.420E 01	3.517E 01	4.250E 00
2	2.950E C1	6.150E C3	7.500E-01

LOCAL TEST PARAMETERS

TEST 125 NU BURMAUT HEATED DELTA P TEST

STA	PU	TD	TD	TI	Q/A	Q/AP	M	DEL TP	VS
1	2.620E CJ	1.005E 02	1.205E 03	4.033E 02	3.020E 01	2.000E 01	7.037E-02	3.700E 02	1.073E 02
2	2.009E CJ	1.155E 02	1.241E 03	4.190E 02	3.102E 01	2.720E 01	8.002E-02	3.000E 02	1.000E 02

STA	L/D	DELTA L	LE
1	2.060E 01	4.031E 01	4.250E 00
2	2.950E C1	7.700E 00	7.500E-01

TEST 125 NO BURNOUT HEATED DELTA P TEST

DATA POINT	STA	NU	PR	RE	TI/TO	NU/PR(.4)
1	1	1.376E 03	5.0787E 00	2.9903E 05	1.2052E 00	7.1877E 02
1	2	1.4295E 03	4.8425E 00	3.1244E 05	1.2713E 00	7.6067E 02
2	1	1.7297E 03	4.4899E 00	3.3003E 05	1.4142E 00	7.8663E 02
2	2	1.7176E 03	4.1702E 00	3.4964E 05	1.4061E 00	9.7012E 02
3	1	1.3427E 03	3.9494E 00	3.8266E 05	1.6711E 00	7.8663E 02
3	2	1.7069E 03	3.6291E 00	3.8897E 05	1.5284E 00	1.0193E 03

DATA POINT	STA	RND RATIO	K RATIO	NU RATIO	CP RATIO
1	1	1.0486E 00	6.2962E-01	2.4405E 00	9.8264E-01
1	2	1.0667E 00	6.3447E-01	2.3284E 00	9.8144E-01
2	1	1.1067E 00	6.2170E-01	3.0632E 00	9.7644E-01
2	2	1.1062E 00	6.3062E-01	2.9527E 00	9.7487E-01
3	1	1.1571E 00	6.6146E-01	4.7220E 00	1.0074E 00
3	2	1.1502E 00	5.5710E-01	3.6131E 00	9.8707E-01

DIMENSIONLESS PARAMETERS

TEST 125 NO BURNOUT HEATED DELTA P TEST

DATA POINT	STA	NU(F)	PR(F)	RE(F)	TI/TF	NU/PR(.4)
1	1	1.2270E 03	2.9991E 00	4.9376E 05	1.1248E 00	8.2483E 02
1	2	1.2615E 03	2.6817E 00	4.9706E 05	1.1194E 00	8.6368E 02
2	1	1.4511E 03	2.0155E 00	6.1311E 05	1.1717E 00	1.1264E 03
2	2	1.4902E 03	1.9478E 00	6.3194E 05	1.1688E 00	1.1414E 03
3	1	1.1490E 03	1.3774E 00	8.2647E 05	1.2512E 00	1.0193E 03
3	2	1.4753E 03	1.5258E 00	7.6120E 05	1.2090E 00	1.2459E 03

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

901 M202 TEST 126 BURNOUT AT DATA POINT 8

AF = 0.138E-03 D = 0.132E-01 L = 0.500E 01 DELTA TO = 0.160E 01

DATA POINTS

POINT	PS-IN	PS-OUT	TB-IN	TB-OUT	M	E2	I2	CP	WT BAL	C
1	4.209E 03	3.969E 03	6.210E 01	6.090E 01	1.828E 00	3.037E 01	9.843E 02	2.748E 01	-5.531E 00	1.327E 04
2	4.203E 03	3.966E 03	6.220E 01	6.037E 02	1.822E 00	4.031E 01	1.849E 03	4.773E 01	-0.918E 00	1.322E 04
3	4.270E 03	4.034E 03	6.240E 01	1.127E 02	1.827E 00	4.470E 01	1.379E 03	5.034E 01	-1.302E 00	1.326E 04
4	4.248E 03	4.014E 03	6.240E 01	1.203E 02	1.814E 00	4.790E 01	1.448E 03	6.079E 01	-1.645E 00	1.316E 04
5	4.243E 03	4.008E 03	6.250E 01	1.250E 02	1.807E 00	4.973E 01	1.810E 03	7.136E 01	-2.263E 00	1.311E 04
6	4.239E 03	4.005E 03	6.250E 01	1.311E 02	1.806E 00	5.213E 01	1.891E 03	7.883E 01	-2.403E 00	1.311E 04
7	4.235E 03	4.004E 03	6.250E 01	1.341E 02	1.797E 00	5.377E 01	1.838E 03	8.380E 01	-3.161E 00	1.304E 04
8	4.235E 03	4.003E 03	6.250E 01	1.419E 02	1.798E 00	5.577E 01	1.704E 03	9.609E 01	-2.963E 00	1.299E 04

TEST SECTION

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURNOUT AT DATA POINT 8

		DATA POINT 1									
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS		
1	4.029E 03	8.042E 01	6.920E 02	2.659E 02	1.140E 01	1.180E 01	5.996E-02	1.863E 02	1.538E 02		
2	3.981E 03	8.556E 01	6.970E 02	2.733E 02	1.140E 01	1.180E 01	5.857E-02	1.879E 02	1.523E 02		
STA	L/D	DELTA E	LE								
1	2.350E 01	3.837E 01	5.000E 00								
2	2.987E 01	3.037E 01	5.000E 00								

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURNOUT AT DATA POINT 8

		DATA POINT 2									
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS		
1	4.025E 03	9.332E 01	1.016E 03	3.489E 02	1.972E 01	1.911E 01	7.470E-02	2.890E 02	1.579E 02		
2	3.978E 03	1.016E 02	1.019E 03	3.531E 02	1.972E 01	1.911E 01	7.890E-02	2.519E 02	1.541E 02		
STA	L/D	DELTA E	LE								
1	2.350E 01	4.031E 01	5.000E 00								
2	2.987E 01	4.031E 01	5.000E 00								

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURNOUT AT DATA POINT 8

		DATA POINT 3									
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS		
1	4.023E 03	1.001E 02	1.063E 03	2.564E 02	2.019E 01	2.334E 01	1.494E-01	1.563E 02	1.508E 02		
2	4.046E 03	1.102E 02	1.081E 03	2.533E 02	2.020E 01	2.334E 01	1.631E-01	1.432E 02	1.553E 02		
STA	L/D	DELTA E	LE								
1	2.350E 01	4.476E 01	5.000E 00								
2	2.987E 01	4.476E 01	5.000E 00								

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURNOUT AT DATA POINT 8

		DATA POINT 4									
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TP	VS		
1	4.072E 03	1.050E 02	1.324E 03	4.799E 02	2.766E 01	2.673E 01	7.323E-02	3.651E 02	1.908E 02		
2	4.026E 03	1.174E 02	1.312E 03	4.535E 02	2.766E 01	2.673E 01	7.956E-02	3.360E 02	1.901E 02		
STA	L/U	DELTA E	LE								
1	2.350E 01	4.759E 01	5.000E 00								
2	2.987E 01	4.799E 01	5.000E 00								

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURMOUT AT DATA POINT 5

STA	P/B	T/B	TU	TI	O/A	G/AP	M	DEL TP	VS
1	4.067E 03	1.094E 02	1.406E 03	5.169E 02	2.964E 01	2.065E 01	7.029E-02	4.070E 02	1.537E 02
2	4.020E 03	1.219E 02	1.391E 03	4.922E 02	2.964E 01	2.065E 01	7.730E-02	3.704E 02	1.545E 02

STA	L/O	DELTA E	LE
1	2.360E 01	4.573E 01	5.000E 00
2	2.987E 01	4.973E 01	5.000E 00

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURMOUT AT DATA POINT 6

STA	P/B	T/B	TU	TI	O/A	G/AP	M	DEL TP	VS
1	4.043E 03	1.130E 02	1.641E 03	6.037E 02	3.255E 01	3.147E 01	6.427E-02	4.097E 02	1.540E 02
2	4.017E 03	1.277E 02	1.513E 03	5.633E 02	3.255E 01	3.147E 01	7.285E-02	4.367E 02	1.550E 02

STA	L/O	DELTA E	LE
1	2.350E 01	5.213E 01	5.000E 00
2	2.987E 01	5.213E 01	5.000E 00

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURMOUT AT DATA POINT 7

STA	P/B	T/B	TU	TI	O/A	G/AP	M	DEL TP	VS
1	4.062E 03	1.177E 02	1.630E 03	6.591E 02	3.461E 01	3.342E 01	6.173E-02	5.410E 02	1.534E 02
2	4.015E 03	1.324E 02	1.623E 03	6.550E 02	3.461E 01	3.342E 01	6.433E-02	5.194E 02	1.543E 02

STA	L/O	DELTA E	LE
1	2.360E 01	5.377E 01	5.000E 00
2	2.987E 01	5.377E 01	5.000E 00

LOCAL TEST PARAMETERS

901 M202 TEST 126 BURMOUT AT DATA POINT 8

STA	P/B	T/B	TU	TI	O/A	G/AP	M	DEL TP	VS
1	4.061E 03	1.230E 02	1.706E 03	7.630E 02	3.727E 01	3.606E 01	5.686E-02	6.410E 02	1.530E 02
2	4.018E 03	1.379E 02	1.623E 03	6.466E 02	3.727E 01	3.606E 01	5.009E-02	7.007E 02	1.541E 02

STA	L/O	DELTA E	LE
1	2.360E 01	5.577E 01	5.000E 00
2	2.987E 01	5.577E 01	5.000E 00

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

901 H2O2 TEST 127 SHUNOUT AT DATA POINT 8

AF = 6.130E-03 D = 0.132E-01 L = 0.600E 01 DELTA T0 = 0.170E 01

DATA POINTS

PCINT	PG-IN	PG-OUT	TR-IN	TR-OUT	N	E2	12	GP	WT BAL	6
1	4.117E 03	3.580E 03	6.150E 01	5.240E 01	1.190E 00	2.997E 01	7.870E 02	1.234E 01	-3.607E 00	8.894E 03
2	4.111E 03	3.975E 03	6.160E 01	1.057E 02	1.190E 00	3.634E 01	9.040E 02	3.239E 01	-3.102E 00	8.791E 03
3	4.104E 03	3.570E 03	6.160E 01	1.211E 02	1.197E 00	4.285E 01	1.099E 03	4.464E 01	-2.574E 00	8.687E 03
4	4.097E 03	3.563E 03	6.160E 01	1.313E 02	1.194E 00	4.650E 01	1.100E 03	5.224E 01	-3.500E 00	8.670E 03
5	4.095E 03	3.500E 03	6.160E 01	1.404E 02	1.195E 00	4.907E 01	1.257E 03	8.099E 01	-3.922E 00	8.670E 03
6	4.090E 03	3.558E 03	6.160E 01	1.473E 02	1.196E 00	5.104E 01	1.307E 03	6.374E 01	-4.843E 00	8.670E 03
7	4.090E 03	2.554E 03	6.160E 01	1.547E 02	1.195E 00	5.343E 01	1.366E 03	6.064E 01	-5.940E 00	8.670E 03
8	4.090E 02	3.983E 03	6.160E 01	1.568E 02	1.193E 00	5.410E 01	1.370E 03	7.024E 01	-5.750E 00	8.687E 03

LOCAL TEST PARAMETERS

901 M202 TEST 127 BURNDUT AT DATA POINT 6

STA	PG	TB	TU	TI	O/A	O/MP	M	DEL TP	VS
1	3-900E 03	1-240E 02	1-134E 03	4-790E 02	2-050E 01	1-907E 01	5-530E-02	3-000E 02	1-000E 02
2	3-900E 03	1-371E 02	1-104E 03	5-403E 02	2-000E 01	1-907E 01	4-000E-02	4-000E 02	1-000E 02
STA	L/D	DELTA E	LE						
1	2-907E 01	4-907E 01	6-000E 00						
2	3-610E 01	4-907E 01	6-000E 00						

LOCAL TEST PARAMETERS

901 M202 TEST 127 BURNDUT AT DATA POINT 6

STA	PG	TB	TU	TI	O/A	O/MP	M	DEL TP	VS
1	3-902E 03	1-294E 02	1-222E 03	5-330E 02	2-210E 01	2-127E 01	5-260E-02	4-000E 02	1-007E 02
2	3-901E 03	1-437E 02	1-344E 03	6-954E 02	2-210E 01	2-127E 01	3-000E-02	5-517E 02	1-031E 02
STA	L/D	DELTA E	LE						
1	2-907E 01	5-140E 01	6-000E 00						
2	3-610E 01	5-140E 01	6-000E 00						

LOCAL TEST PARAMETERS

901 M202 TEST 127 BURNDUT AT DATA POINT 6

STA	PG	TB	TU	TI	O/A	O/MP	M	DEL TP	VS
1	3-902E 03	1-283E 02	1-329E 03	6-161E 02	2-300E 01	2-290E 01	4-764E-02	4-000E 02	1-007E 02
2	3-902E 03	1-500E 02	1-548E 03	9-010E 02	2-301E 01	2-290E 01	3-000E-02	7-000E 02	1-000E 02
STA	L/D	DELTA E	LE						
1	2-907E 01	5-340E 01	6-000E 00						
2	3-610E 01	5-340E 01	6-000E 00						

LOCAL TEST PARAMETERS

901 M202 TEST 127 BURNDUT AT DATA POINT 6

STA	PG	TB	TU	TI	O/A	O/MP	M	DEL TP	VS
1	3-902E 03	1-370E 02	1-333E 03	6-011E 02	2-440E 01	2-344E 01	5-050E-02	4-041E 02	1-000E 02
2	3-909E 03	1-520E 02	1-590E 03	9-230E 02	2-439E 01	2-344E 01	3-041E-02	7-707E 02	1-031E 02
STA	L/D	DELTA E	LE						
1	2-907E 01	5-410E 01	6-000E 00						
2	3-610E 01	5-410E 01	6-000E 00						

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

901 H202 TEST 120 BURNOUT AT DATA POINT 7

AF = C.273E-03 D = 0.212E-01 L = 0.500E 01 DELTA TO = 0.900E 00

DATA POINTS

PCINT	PG-IN	PG-OUT	TO-IN	TO-OUT	W	E2	J2	CP	HT DEL.	G
1	4.156E 03	4.145E 03	1.194E 02	1.210E 02	1.144E 00	9.570E 00	4.400E 02	3.992E 00	-5.200E 00	4.103E 03
2	4.153E 03	4.130E 03	1.195E 02	1.400E 02	1.144E 00	2.620E 01	9.140E 02	1.757E 01	-7.000E 00	4.103E 03
3	4.150E 03	4.133E 03	1.193E 02	1.499E 02	1.144E 00	2.427E 01	1.000E 03	2.496E 01	-6.370E 00	4.173E 03
4	4.147E 03	4.120E 03	1.190E 02	1.610E 02	1.143E 00	2.624E 01	1.250E 03	3.352E 01	-7.100E 00	4.174E 03
5	4.145E 03	4.126E 03	1.190E 02	1.691E 02	1.141E 00	3.029E 01	1.137E 03	3.039E 01	-7.970E 00	4.172E 03
6	4.142E 03	4.125E 03	1.190E 02	1.733E 02	1.140E 00	3.120E 01	1.301E 03	4.100E 01	-8.617E 00	4.160E 03
7	4.142E 03	4.125E 03	1.190E 02	1.740E 02	1.138E 00	3.150E 01	1.300E 03	4.130E 01	-9.000E 00	4.101E 03

TEST ACTIVITY

LOCAL TEST PARAMETERS

900 M2C2 TEST 126 WURNALUT AT DATA POINT 7

STA	PB	Ta	Tb	Tc	Td	Q/A	Q/AP	M	DEL TP	VS
1	4-181E C3	1-194E 02	2-040E 02	2-109E 01	1-111E 00	1-134E 00	1-134E 00	1-240E-02	4-108E 01	1-903E 01
2	4-185E C3	1-207E 02	2-070E 02	1-640E 02	1-115E 00	1-134E 00	1-134E 00	1-059E-02	7-779E 01	1-903E 01
STA	L/O	DELTA E	LB							
1	1-076E C1	9-070E 00	5-000E 00							
2	1-070E C1	9-070E 00	5-000E 00							

LOCAL TEST PARAMETERS

901 M2C2 TEST 126 WURNALUT AT DATA POINT 7

STA	PB	Ta	Tb	Tc	Td	Q/A	Q/AP	M	DEL TP	VS
1	4-140E C3	1-126E 02	6-160E 02	4-021E 02	4-090E 00	4-993E 00	4-993E 00	1-520E-02	1-209E 01	4-978E 01
2	4-137E C3	1-207E 02	6-100E 02	4-309E 02	4-097E 00	4-993E 00	4-993E 00	1-063E-02	3-000E 01	4-978E 01
STA	L/O	DELTA E	LB							
1	1-076E C1	2-020E 01	5-000E 00							
2	1-070E C1	2-020E 01	5-000E 00							

LOCAL TEST PARAMETERS

902 M2C2 TEST 126 WURNALUT AT DATA POINT 7

STA	PB	Ta	Tb	Tc	Td	Q/A	Q/AP	M	DEL TP	VS
1	4-137E C3	1-010E 02	4-090E 02	5-733E 02	6-035E 00	7-093E 00	7-093E 00	1-021E-02	4-375E 02	1-978E 01
2	4-134E C3	1-021E 02	7-920E 02	5-095E 02	6-041E 00	7-093E 00	7-093E 00	1-724E-02	4-110E 02	1-978E 01
STA	L/O	DELTA E	LB							
1	1-076E C1	4-027E 01	5-000E 00							
2	1-070E C1	2-027E 01	5-000E 00							

LOCAL TEST PARAMETERS

903 M202 TEST 126 WURNALUT AT DATA POINT 7

STA	PB	Ta	Tb	Tc	Td	Q/A	Q/AP	M	DEL TP	VS
1	4-124E C3	1-050E 02	5-040E 02	6-030E 02	9-031E 00	9-524E 00	9-524E 00	1-754E-02	5-031E 02	1-903E 01
2	4-131E C3	1-054E 02	4-030E 02	6-090E 02	9-320E 00	9-524E 00	9-524E 00	1-069E-02	5-090E 02	5-007E 01
STA	L/O	DELTA E	LB							
1	1-076E C1	2-024E 01	5-000E 00							
2	1-070E C1	2-024E 01	5-000E 00							

LOCAL TEST PARAMETERS

901 M2C2 TEST 145 DUMMOUT AT DATA POINT 7

		DATA POINT 5							
STA	PB	TH	TO	TI	O/A	Q/MP	M	DEL TP	VS
1	4.122E C3	1.553E 02	1.081E 03	7.586E 02	1.007E 01	1.091E 01	1.509E-02	0.031E 02	1.997E 01
2	4.129E C3	1.663E 02	1.029E 03	7.319E 02	1.068E 01	1.091E 01	1.927E-02	3.655E 02	5.013E 01
STA		L/D	DELTA E	LE					
1	1.076E C1	3.029E 01	5.000E 00						
2	1.070E C1	3.029E 01	5.000E 00						

LOCAL TEST PARAMETERS

901 P202 TEST 140 DUMMOUT AT DATA POINT 7

		DATA POINT 6							
STA	PB	TH	TO	TI	O/A	Q/MP	M	DEL TP	VS
1	4.120E C3	1.565E 02	1.129E 03	7.876E 02	1.102E 01	1.107E 01	1.852E-02	0.291E 02	1.971E 01
2	4.127E C3	1.763E 02	1.113E 03	7.762E 02	1.100E 01	1.107E 01	1.946E-02	3.999E 02	5.017E 01
STA		L/D	DELTA L	LE					
1	1.076E C1	3.128E 01	5.000E 00						
2	1.070E C1	3.128E 01	5.000E 00						

LOCAL TEST PARAMETERS

561 M2C2 TEST 126 DUMMOUT AT DATA POINT 7

		DATA POINT 7							
STA	PB	TH	TO	TI	O/A	Q/MP	M	DEL TP	VS
1	4.124E C3	1.890E 02	1.148E 03	7.529E 02	1.151E 01	1.179E 01	1.094E-02	0.339E 02	1.961E 01
2	4.126E C3	1.710E 02	1.125E 03	7.013E 02	1.122E 01	1.175E 01	1.920E-02	0.103E 02	5.000E 01
STA		L/D	DELTA L	LE					
1	1.076E C1	3.150E 01	5.000E 00						
2	1.070E C1	3.150E 01	5.000E 00						

Report AFRPL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

901 M202 TEST 129 SHUTDOWN AT DATA POINT 8

AF = 9.273E-03 Q = 0.212E-01 L = 0.160E 01 DELTA TO = 0.000E-00

POINT	DATA POINTS									
	PS-IN	PS-OUT	TS-IN	TS-OUT	U	E2	I2	MP	HT SALL	U
1	4.012E 03	3.997E 03	1.937E 02	1.994E 02	9.091E-01	0.760E 00	3.740E 02	2.000E 00	6.511E 01	3.042E 03
2	4.009E 03	3.994E 03	1.936E 02	2.071E 02	9.701E-01	1.417E 01	7.530E 02	1.012E 01	1.365E 01	3.047E 03
3	4.007E 03	3.992E 03	1.934E 02	2.172E 02	9.702E-01	1.612E 01	9.500E 02	1.000E 01	5.800E 00	3.047E 03
4	4.008E 03	3.993E 03	1.931E 02	2.232E 02	9.097E-01	2.012E 01	1.000E 03	2.007E 01	2.311E 00	3.040E 03
5	3.996E 03	3.968E 03	1.942E 02	1.924E 02	9.724E-01	2.220E 01	1.190E 03	2.040E 01	-1.060E 00	3.040E 03
6	3.978E 03	3.963E 03	1.941E 02	1.971E 02	9.722E-01	2.339E 01	1.210E 03	2.004E 01	-3.617E 00	3.040E 03
7	3.992E 03	3.977E 03	1.942E 02	2.022E 02	9.049E-01	2.430E 01	1.262E 03	2.010E 01	-7.092E 00	3.038E 03
8	3.979E 03	3.964E 03	1.944E 02	2.080E 02	9.044E-01	2.477E 01	1.260E 03	3.000E 01	-8.715E 00	3.036E 03

TEST SECTION

LOCAL TEST PARAMETERS

901 M802 TEST 129 BURNDOUT AT DATA POINT 0

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	TEST	STA	TEST	STA	TEST	STA	TEST
1	1.002E 01	1	1.002E 01	1	1.002E 01	1	1.002E 01
2	1.070E 01	2	1.070E 01	2	1.070E 01	2	1.070E 01
DELTA E		DELTA E		DELTA E		DELTA E	
1	0.000E 00	1	0.000E 00	1	0.000E 00	1	0.000E 00
2	0.000E 00	2	0.000E 00	2	0.000E 00	2	0.000E 00
L/D		L/D		L/D		L/D	
1	0.000E 00	1	0.000E 00	1	0.000E 00	1	0.000E 00
2	0.000E 00	2	0.000E 00	2	0.000E 00	2	0.000E 00
T/B		T/B		T/B		T/B	
1	1.900E 02	1	1.900E 02	1	1.900E 02	1	1.900E 02
2	1.900E 02	2	1.900E 02	2	1.900E 02	2	1.900E 02
T/U		T/U		T/U		T/U	
1	2.770E 02	1	2.770E 02	1	2.770E 02	1	2.770E 02
2	2.810E 02	2	2.810E 02	2	2.810E 02	2	2.810E 02
O/A		O/A		O/A		O/A	
1	9.292E-01	1	9.292E-01	1	9.292E-01	1	9.292E-01
2	9.210E-01	2	9.210E-01	2	9.210E-01	2	9.210E-01
O/AP		O/AP		O/AP		O/AP	
1	8.700E-01	1	8.700E-01	1	8.700E-01	1	8.700E-01
2	8.700E-01	2	8.700E-01	2	8.700E-01	2	8.700E-01
M		M		M		M	
1	2.030E-02	1	2.030E-02	1	2.030E-02	1	2.030E-02
2	2.200E-02	2	2.200E-02	2	2.200E-02	2	2.200E-02
DEL TP		DEL TP		DEL TP		DEL TP	
1	4.300E 01	1	4.300E 01	1	4.300E 01	1	4.300E 01
2	2.012E 01	2	2.012E 01	2	2.012E 01	2	2.012E 01
VS		VS		VS		VS	
1	4.311E 01	1	4.311E 01	1	4.311E 01	1	4.311E 01
2	4.312E 01	2	4.312E 01	2	4.312E 01	2	4.312E 01

LOCAL TEST PARAMETERS

901 M802 TEST 129 BURNDOUT AT DATA POINT 0

DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	TEST	STA	TEST	STA	TEST
1	2.000E 03	1	2.000E 03	1	2.000E 03
2	2.000E 03	2	2.000E 03	2	2.000E 03
DELTA E		DELTA E		DELTA E	
1	1.000E 01	1	1.000E 01	1	1.000E 01
2	1.070E 01	2	1.070E 01	2	1.070E 01
L/D		L/D		L/D	
1	0.000E 00	1	0.000E 00	1	0.000E 00
2	0.000E 00	2	0.000E 00	2	0.000E 00
T/B		T/B		T/B	
1	2.000E 02	1	2.000E 02	1	2.000E 02
2	2.000E 02	2	2.000E 02	2	2.000E 02
T/U		T/U		T/U	
1	2.700E 02	1	2.700E 02	1	2.700E 02
2	2.700E 02	2	2.700E 02	2	2.700E 02
O/A		O/A		O/A	
1	2.700E 00	1	2.700E 00	1	2.700E 00
2	2.700E 00	2	2.700E 00	2	2.700E 00
O/AP		O/AP		O/AP	
1	2.000E 00	1	2.000E 00	1	2.000E 00
2	2.000E 00	2	2.000E 00	2	2.000E 00
M		M		M	
1	2.000E-02	1	2.000E-02	1	2.000E-02
2	2.000E-02	2	2.000E-02	2	2.000E-02
DEL TP		DEL TP		DEL TP	
1	1.077E 02	1	1.077E 02	1	1.077E 02
2	1.200E 02	2	1.200E 02	2	1.200E 02
VS		VS		VS	
1	4.310E 01	1	4.310E 01	1	4.310E 01
2	4.310E 01	2	4.310E 01	2	4.310E 01

LOCAL TEST PARAMETERS

901 M802 TEST 129 BURNDOUT AT DATA POINT 0

DATA POINT 3		DATA POINT 4	
STA	TEST	STA	TEST
1	2.000E 03	1	2.000E 03
2	2.000E 03	2	2.000E 03
DELTA E		DELTA E	
1	1.000E 01	1	1.000E 01
2	1.070E 01	2	1.070E 01
L/D		L/D	
1	0.000E 00	1	0.000E 00
2	0.000E 00	2	0.000E 00
T/B		T/B	
1	2.000E 02	1	2.000E 02
2	2.000E 02	2	2.000E 02
T/U		T/U	
1	2.700E 02	1	2.700E 02
2	2.700E 02	2	2.700E 02
O/A		O/A	
1	2.700E 00	1	2.700E 00
2	2.700E 00	2	2.700E 00
O/AP		O/AP	
1	2.000E 00	1	2.000E 00
2	2.000E 00	2	2.000E 00
M		M	
1	2.000E-02	1	2.000E-02
2	2.000E-02	2	2.000E-02
DEL TP		DEL TP	
1	2.320E 02	1	2.320E 02
2	1.900E 02	2	1.900E 02
VS		VS	
1	4.310E 01	1	4.310E 01
2	4.310E 01	2	4.310E 01

LOCAL TEST PARAMETERS

901 M802 TEST 129 BURNDOUT AT DATA POINT 0

DATA POINT 4	
STA	TEST
1	2.000E 03
2	2.000E 03
DELTA E	
1	1.000E 01
2	1.070E 01
L/D	
1	0.000E 00
2	0.000E 00
T/B	
1	2.000E 02
2	2.000E 02
T/U	
1	2.700E 02
2	2.700E 02
O/A	
1	2.700E 00
2	2.700E 00
O/AP	
1	2.000E 00
2	2.000E 00
M	
1	2.000E-02
2	2.000E-02
DEL TP	
1	2.000E 02
2	2.000E 02
VS	
1	4.310E 01
2	4.310E 01

LOCAL TEST PARAMETERS

901 M202 TEST 129 BURNDUT AT DATA POINT 5

STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	2.970E 03	1.605E 02	7.960E 02	4.553E 02	9.124E 00	8.687E 00	2.850E-02	3.048E 02	4.290E 01
2	3.966E 03	1.900E 02	7.730E 02	4.582E 02	9.135E 00	8.687E 00	3.239E-02	2.492E 02	4.317E 01
STA	L/D	DELTA E	LE						
1	1.083E 01	2.226E 01	4.000E 00						
2	1.476E 01	2.226E 01	4.000E 00						

LOCAL TEST PARAMETERS

901 M202 TEST 129 BURNDUT AT DATA POINT 6

STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	3.966E 03	1.637E 02	8.425E 02	5.054E 02	1.005E 01	9.569E 00	2.974E-02	3.217E 02	4.303E 01
2	3.966E 03	1.749E 02	8.230E 02	4.703E 02	1.004E 01	9.569E 00	3.448E-02	2.789E 02	4.303E 01
STA	L/D	DELTA E	LE						
1	1.083E 01	2.339E 01	4.000E 00						
2	1.476E 01	2.339E 01	4.000E 00						

LOCAL TEST PARAMETERS

901 M202 TEST 129 BURNDUT AT DATA POINT 7

STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	3.982E 03	1.276E 02	8.930E 02	5.347E 02	1.087E 01	1.035E 01	2.982E-02	3.471E 02	4.280E 01
2	3.978E 03	1.998E 02	8.692E 02	5.066E 02	1.088E 01	1.035E 01	3.373E-02	3.069E 02	4.311E 01
STA	L/D	DELTA E	LE						
1	1.083E 01	2.436E 01	4.000E 00						
2	1.476E 01	2.436E 01	4.000E 00						

LOCAL TEST PARAMETERS

901 M202 TEST 129 BURNDUT AT DATA POINT 8

STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	3.966E 03	1.892E 02	9.115E 02	5.436E 02	1.123E 01	1.058E 01	3.912E-02	3.544E 02	4.280E 01
2	3.965E 03	2.018E 02	9.000E 02	5.298E 02	1.124E 01	1.058E 01	3.255E-02	3.280E 02	4.303E 01
STA	L/D	DELTA E	LE						
1	1.083E 01	2.477E 01	4.000E 00						
2	1.476E 01	2.477E 01	4.000E 00						

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS . . .

AP = 0.138E-03 C = 0.132E-01 L = 0.400E 01 DELTA T0 = 0.230E 01

DATA POINTS

FCIAT	PH-IN	PE-CLT	TL-IN	TB-OUT	W	E2	I2	OP	MT GAL	G
1	3.515E 03	3.285E 03	8.100E 01	1.298E 02	1.785E 00	3.832E 01	1.497E 03	5.438E 01	2.466E 00	1.295E 04
2	3.675E 03	3.440E 03	6.082E 01	1.304E 02	1.823E 00	3.893E 01	1.516E 03	5.595E 01	1.507E 00	1.323E 04
3	3.835E 03	3.595E 03	6.040E 01	1.313E 02	1.833E 00	3.901E 01	1.519E 03	5.617E 01	-1.351E 00	1.339E 04
4	3.995E 03	3.750E 03	6.050E 01	1.315E 02	1.817E 00	3.910E 01	1.514E 03	5.612E 01	-7.746E-01	1.319E 04
5	4.155E 03	3.905E 03	6.090E 01	1.308E 02	1.820E 00	3.968E 01	1.495E 03	5.482E 01	-9.972E-01	1.321E 04
6	4.315E 03	4.060E 03	6.040E 01	1.310E 02	1.827E 00	3.969E 01	1.497E 03	5.491E 01	-2.710E 00	1.326E 04
7	4.475E 03	4.215E 03	6.060E 01	1.322E 02	1.805E 00	3.872E 01	1.497E 03	5.495E 01	-3.504E 00	1.310E 04
8	4.635E 03	4.370E 03	6.070E 01	1.341E 02	1.805E 00	3.901E 01	1.506E 03	5.569E 01	-5.871E 00	1.310E 04
9	4.795E 03	4.525E 03	6.060E 01	1.351E 02	1.782E 00	3.890E 01	1.504E 03	5.546E 01	-7.224E 00	1.293E 04
10	4.950E 03	4.680E 03	6.130E 01	1.365E 02	1.756E 00	3.888E 01	1.503E 03	5.540E 01	-7.222E 00	1.276E 04

TEST SECTION

LOCAL TEST PARAMETERS

TEST 130. DURATION TEST. DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 80

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4		DATA POINT 5	
STA	PU	TB	TI	TW	Q/A	Q/AP	M	DEL TF	VS
1	3.357E C3	1.149F C4	4.530E 02	1.285E 03	2.709E 01	2.721E 01	9.040E-02	3.300E 02	1.470E 02
2	3.457E C3	1.207L C2	3.812E 02	1.236E 03	2.709E 01	2.721E 01	1.063E-01	2.845E 02	1.400E 02
STA	L/D	DELTA E	LE						
1	1.730E C1	3.022E C1	4.000E 00						
2	2.358E C1	3.032E C1	4.000E 00						

LOCAL TEST PARAMETERS

TEST 130. DURATION TEST. DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 80

DATA POINT 2		DATA POINT 3		DATA POINT 4		DATA POINT 5	
STA	PU	TB	TI	TW	Q/A	Q/AP	M
1	3.513E C3	1.149L C2	4.545E 02	1.336E 03	2.793E 01	2.800E 01	7.376E-02
2	3.955E C3	1.273L C2	3.832E 02	1.260E 03	2.707E 01	2.800E 01	1.094E-01
STA	L/D	DELTA E	LE				
1	1.730E C1	3.032E C1	4.000E 00				
2	2.358E C1	3.032E C1	4.000E 00				

LOCAL TEST PARAMETERS

TEST 129. DURATION TEST. DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 80

DATA POINT 3		DATA POINT 4		DATA POINT 5					
STA	PU	TB	TI	TW	Q/A	Q/AP	M	DEL TF	VS
1	3.525E C3	1.154L C2	4.555E 02	1.312E 03	2.835E 01	2.811E 01	9.264E-02	3.401E 02	1.514E 02
2	3.465E C3	1.261L C2	4.011E 02	1.275E 03	2.807E 01	2.811E 01	1.030E-01	2.730E 02	1.522E 02
STA	L/D	DELTA E	LE						
1	1.730E C1	3.031E C1	4.000E 00						
2	2.358E C1	3.031E C1	4.000E 00						

LOCAL TEST PARAMETERS

TEST 130. DURATION TEST. DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 80

DATA POINT 4		DATA POINT 5							
STA	PU	TB	TI	TW	Q/A	Q/AP	M	DEL TF	VS
1	3.472E C3	1.156E C2	4.519E 02	1.366E 03	2.818E 01	2.808E 01	9.604E-02	3.264E 02	1.501E 02
2	3.418L C3	1.282E C2	4.006E 02	1.278E 03	2.820E 01	2.808E 01	1.031E-01	2.723E 02	1.509E 02
STA	L/D	DELTA E	LE						
1	1.730E C1	3.030E C1	4.000E 00						
2	2.358E C1	3.030E C1	4.000E 00						

LCCAL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 00

		DATA POINT 5									
STA	PU	TJ	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.407E 03	1.152L 02	1.34CE 03	5.131E 02	2.757E 01	2.743E 01	6.694E-02	3.979E 02	1.503E 02		
2	3.407E 03	1.277E 02	1.259E 03	3.756E 02	2.761E 01	2.743E 01	1.024E-01	2.679E 02	1.511E 02		
STA	L/O	DELTA E	LF								
1	1.730E 01	3.661E 01	4.000E 00								
2	2.358E 01	3.661E 01	4.000E 00								

LCCAL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 00

		DATA POINT 6									
STA	PU	TJ	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.403E 03	1.152L 02	1.320E 03	5.689E 02	2.757E 01	2.747E 01	6.055E-02	4.530E 02	1.509E 02		
2	3.445E 03	1.276E 02	1.255E 03	3.891E 02	2.761E 01	2.747E 01	1.052E-01	2.613E 02	1.517E 02		
STA	L/O	DELTA E	LF								
1	1.730E 01	3.665E 01	4.000E 00								
2	2.358E 01	3.665E 01	4.000E 00								

LCCAL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 00

		DATA POINT 7									
STA	PU	TJ	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.483E 03	1.161E 02	1.412E 03	6.111E 02	2.764E 01	2.750E 01	5.546E-02	4.937E 02	1.492E 02		
2	3.425E 03	1.290E 02	1.278E 03	4.214E 02	2.766E 01	2.750E 01	9.401E-02	2.925E 02	1.500E 02		
STA	L/O	DELTA E	LF								
1	1.730E 01	3.672E 01	4.000E 00								
2	2.358E 01	3.672E 01	4.000E 00								

LCCAL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DPI-145SEC. DPI0 IS 00

		DATA POINT 8									
STA	PU	TJ	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.477E 03	1.174E 02	1.452E 03	6.527E 02	2.803E 01	2.787E 01	5.207E-02	5.352E 02	1.492E 02		
2	3.415L 03	1.308E 02	1.286E 03	4.174E 02	2.807E 01	2.787E 01	9.722E-02	2.867E 02	1.501E 02		
STA	L/O	DELTA E	LF								
1	1.730E 01	3.901E 01	4.000E 00								
2	2.358E 01	3.901E 01	4.000E 00								

LOCAL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DP1-108SEC. DP10 IS 80

DATA POINT 9

STA	PB	TO	TU	VI	Q/A	Q/MP	M	DEL TV	VS
1	3.413E 03	1.181E 02	1.456E 03	6.634E 02	2.787E 01	2.775E 01	5.009E-02	5.454E 02	1.079E 02
2	3.355E 03	1.317E 02	1.290E 03	4.293E 02	2.791E 01	2.775E 01	9.325E-02	2.976E 02	1.488E 02

STA	L/O	DELTA E	LE
1	1.730E 01	3.890E 01	4.000E 00
2	2.358E 01	3.890E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 130. DURATION TEST DATA POINTS AT 20 SEC INT. DP1-108SEC. DP10 IS 80

DATA POINT 10

STA	PB	TO	TU	VI	Q/A	Q/MP	M	DEL TV	VS
1	3.345E 03	1.192E 02	1.402E 03	6.726E 02	2.784E 01	2.772E 01	5.016E-02	5.533E 02	1.463E 02
2	3.289E 03	1.330E 02	1.310E 03	4.596E 02	2.787E 01	2.772E 01	8.409E-02	3.268E 02	1.461E 02

STA	L/O	DELTA E	LE
1	1.730E 01	3.890E 01	4.000E 00
2	2.358E 01	3.890E 01	4.000E 00

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 138-7 MIN STEADY POWER-001-146 SEC.20 SEC INTERVAL.%.PIN ESTIMATED

AF = 0.140E-03 D = 0.132E-01 L = 0.550E 01 DELTA T0 = 0.300E 01

POINT	DATA POINTS									
	PB-IN	PB-OUT	TO-IN	TO-OUT	S	E2	I2	MP	MT DAL	S
1	3.640E 03	3.489E 03	8.250E 01	1.291E 02	1.010E 00	4.154E 01	1.270E 03	5.114E 01	1.200E 00	1.277E 04
2	3.630E 03	3.478E 03	8.270E 01	1.290E 02	1.000E 00	4.142E 01	1.290E 03	5.121E 01	1.000E 00	1.270E 04
3	3.625E 03	3.470E 03	8.270E 01	1.290E 02	1.810E 00	4.160E 01	1.291E 03	5.079E 01	1.300E 00	1.277E 04
4	3.640E 03	3.360E 03	8.260E 01	1.291E 02	1.780E 00	4.121E 01	1.290E 03	5.016E 01	1.072E 00	1.277E 04
5	3.385E 03	3.230E 03	8.240E 01	1.282E 02	1.815E 00	4.110E 01	1.270E 03	4.991E 01	5.310E-01	1.300E 04
6	3.250E 03	3.100E 03	8.375E 01	1.294E 02	1.810E 00	4.110E 01	1.270E 03	4.900E 01	5.051E-01	1.300E 04
7	3.160E 03	3.005E 03	8.200E 01	1.270E 02	1.000E 00	4.121E 01	1.270E 03	4.993E 01	5.091E-01	1.270E 04

Report AFRPL-TR-66-263, Appendix B

TEST SECTION

LOCAL TEST PARAMETERS

TEST 132.2 MIN STEADY POWER-DPI-146 SEC.20 SEC INTERVALS.PIN ESTIMATED

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PC	TI	TI	TI	TI	TI	TI
1	3-542E 03	1-174E 02	9-940E 02	3-240E 02	2-033E 01	2-034E 01	9-000E-02
2	3-494E 03	1-260E 02	1-042E 03	4-199E 02	2-020E 01	2-034E 01	6-940E-02
STA	L/D	DELTA E	LE				
1	2-344E 01	4-184E 01	5-000E 00				
2	2-909E 01	4-190E 01	7-000E 00				

LOCAL TEST PARAMETERS

TEST 132.2 MIN STEADY POWER-DPI-146 SEC.20 SEC INTERVALS.PIN ESTIMATED

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PC	TI	TI	TI	TI	TI	TI
1	3-832E 03	1-179E 02	9-940E 02	2-041E 02	2-031E 01	2-037E 01	1-393E-01
2	3-486E 03	1-272E 02	1-072E 03	4-300E 02	2-020E 01	2-037E 01	6-789E-02
STA	L/D	DELTA E	LE				
1	2-344E 01	4-182E 01	5-000E 00				
2	2-909E 01	4-162E 01	5-000E 00				

LOCAL TEST PARAMETERS

TEST 132.2 MIN STEADY POWER-DPI-146 SEC.20 SEC INTERVALS.PIN ESTIMATED

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PC	TI	TI	TI	TI	TI	TI
1	3-520E 03	1-174E 02	5-080E 02	2-560E 02	2-021E 01	2-020E 01	1-400E-01
2	3-481E 03	1-267E 02	1-040E 03	3-980E 02	2-010E 01	2-020E 01	7-025E-02
STA	L/D	DELTA E	LE				
1	2-344E 01	4-180E 01	5-000E 00				
2	2-909E 01	4-180E 01	5-000E 00				

LOCAL TEST PARAMETERS

TEST 132.2 MIN STEADY POWER-DPI-146 SEC.20 SEC INTERVALS.PIN ESTIMATED

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PC	TI	TI	TI	TI	TI	TI
1	3-442E 03	1-179E 02	9-360E 02	2-540E 02	1-993E 01	1-990E 01	1-487E-01
2	3-396E 03	1-260E 02	1-030E 03	3-874E 02	1-987E 01	1-990E 01	7-000E-02
STA	L/D	DELTA E	LE				
1	2-344E 01	4-181E 01	5-000E 00				
2	2-909E 01	4-181E 01	5-000E 00				

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS
TEST 132.2 MIN STEADY POWER-DPI-146 SEC-20 SEC INTERVALS.PIN ESTIMATED

		DATA POINT 5									
STA	PB	TB	TU	TI	G/A	G/MP	M	DEL TP	VS		
1	3.287E 03	1.167E 02	9.310E 02	2.492E 02	1.999E 01	1.999E 01	1.499E-01	1.334E 02	1.401E 02		
2	3.201E 03	1.299E 02	1.019E 03	3.791E 02	1.993E 01	1.999E 01	7.999E-02	2.402E 02	1.407E 02		

		DELTA E		LE	
1	2.244E 01	4.116E 01	5.000E 00		
2	2.969E 01	4.116E 01	5.000E 00		

LOCAL TEST PARAMETERS
TEST 132.2 MIN STEADY POWER-DPI-146 SEC-20 SEC INTERVALS.PIN ESTIMATED

		DATA POINT 6									
STA	PB	TB	TU	TI	G/A	G/MP	M	DEL TP	VS		
1	3.157E 03	1.180E 02	9.270E 02	2.442E 02	1.987E 01	1.994E 01	1.873E-01	1.263E 02	1.400E 02		
2	3.111E 03	1.271E 02	1.019E 03	3.739E 02	1.991E 01	1.994E 01	8.999E-02	2.404E 02	1.407E 02		

		DELTA E		LE	
1	2.344E 01	4.114E 01	5.000E 00		
2	2.969E 01	4.114E 01	5.000E 00		

LOCAL TEST PARAMETERS
TEST 132.2 MIN STEADY POWER-DPI-146 SEC-20 SEC INTERVALS.PIN ESTIMATED

		DATA POINT 7									
STA	PB	TB	TU	TI	G/A	G/MP	M	DEL TP	VS		
1	3.062E 03	1.263E 02	9.300E 02	2.957E 02	1.994E 01	1.994E 01	1.644E-01	1.194E 02	1.400E 02		
2	3.016E 03	1.356E 02	1.024E 03	3.792E 02	1.987E 01	1.994E 01	8.181E-02	2.437E 02	1.400E 02		

		DELTA E		LE	
1	2.244E 01	4.121E 01	5.000E 00		
2	2.969E 01	4.121E 01	5.000E 00		

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER DP1 AT 102 SEC OTHER DP AT 40 SEC INTERVALS

AF = 0.130E-03 D = 0.132E-01 L = 0.403E 01 DELTA TO = 0.300E 01

DATA POINTS

POINT	PO-IN	PO-OUT	TE-IN	TE-OUT	U	Z	IZ	OP	WT BAL	Q
1	3.623E 03	3.440E 03	0.210E 01	1.201E 02	1.012E 00	3.314E 01	1.250E 03	0.000E 01	0.030E-01	1.210E 04
2	3.612E 03	3.437E 03	0.190E 01	1.190E 02	1.010E 00	3.310E 01	1.250E 03	0.077E 01	0.000E-02	1.210E 04
3	3.600E 03	3.430E 03	0.180E 01	1.201E 02	1.027E 00	3.210E 01	1.250E 03	0.072E 01	0.071E-01	1.210E 04
4	3.600E 03	3.430E 03	0.180E 01	1.190E 02	1.000E 00	3.220E 01	1.201E 03	0.077E 01	0.000E-01	1.210E 04
5	3.610E 03	3.440E 03	0.090E 01	1.190E 02	1.010E 00	3.302E 01	1.250E 03	0.071E 01	0.030E-01	1.210E 04
6	3.400E 03	3.330E 03	0.090E 01	1.193E 02	1.000E 00	3.200E 01	1.200E 03	0.070E 01	-1.000E 00	1.210E 04
7	3.340E 03	3.100E 03	0.040E 01	1.100E 02	1.000E 00	3.204E 01	1.251E 03	0.040E 01	-1.797E-01	1.210E 04

TEST SECTION

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER DPI AT 192 SEC OTHER DP AT 40 SEC INTERVALS

DATA POINT 1

STA	PO	TS	TU	TI	O/A	O/AP	N	DEL TP	VS
1	3-514E 03	1-083E 02	1-030E 03	3-264E 02	2-090E 01	2-021E 01	0-009E-02	2-201E 02	1-000E 02
2	3-476E 03	1-177E 02	1-030E 03	3-264E 02	2-090E 01	2-021E 01	9-201E-02	2-187E 02	1-000E 02
STA	L/D	DELTA E	LE						
1	1-740E 01	2-314E 01	4-030E 00						
2	2-377E 01	3-314E 01	4-030E 00						

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER DPI AT 192 SEC OTHER DP AT 40 SEC INTERVALS

DATA POINT 2

STA	PO	TS	TU	TI	O/A	O/AP	N	DEL TP	VS
1	3-500E 03	1-079E 02	1-027E 03	3-291E 02	2-090E 01	2-022E 01	9-112E-02	2-222E 02	1-001E 02
2	3-467E 03	1-174E 02	1-017E 03	3-190E 02	2-090E 01	2-022E 01	1-021E-01	1-903E 02	1-000E 02
STA	L/D	DELTA E	LE						
1	1-740E 01	2-310E 01	4-030E 00						
2	2-377E 01	3-310E 01	4-030E 00						

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER DPI AT 192 SEC OTHER DP AT 40 SEC INTERVALS

DATA POINT 3

STA	PO	TS	TU	TI	O/A	O/AP	N	DEL TP	VS
1	3-490E 03	1-061E 02	1-020E 03	3-259E 02	2-090E 01	2-022E 01	0-009E-02	2-202E 02	1-000E 02
2	3-460E 03	1-177E 02	1-010E 03	3-087E 02	2-090E 01	2-022E 01	1-070E-01	1-000E 02	1-000E 02
STA	L/D	DELTA E	LE						
1	1-740E 01	2-310E 01	4-030E 00						
2	2-377E 01	3-310E 01	4-030E 00						

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER DPI AT 192 SEC OTHER DP AT 40 SEC INTERVALS

DATA POINT 4

STA	PO	TS	TU	TI	O/A	O/AP	N	DEL TP	VS
1	3-490E 03	1-079E 02	1-030E 03	3-290E 02	2-090E 01	2-022E 01	9-100E-02	2-210E 02	1-000E 02
2	3-460E 03	1-179E 02	1-030E 03	3-190E 02	2-091E 01	2-022E 01	1-010E-01	2-002E 02	1-000E 02
STA	L/D	DELTA E	LE						
1	1-740E 01	2-320E 01	4-030E 00						
2	2-377E 01	3-320E 01	4-030E 00						

Report AFRL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER CP1 AT 192 SEC OTHER DP AT 40 SEC INTERVALS

		DATA POINT 5									
STA	PO	TS	TU	TI	C/A	C/AP	M	DEL TP	VS		
1	3-900E 03	1-070E 02	1-030E 03	3-300E 02	2-000E 01	2-000E 01	0-700E-02	2-230E 02	1-000E 02		
2	3-070E 03	1-170E 02	1-030E 03	2-200E 02	2-000E 01	2-000E 01	0-700E-02	2-230E 02	1-000E 02		
STA	L/D	DELTA E		L E							
1	1-740E 01	3-220E 01	4-000E 00								
2	2-377E 01	2-320E 01	4-020E 00								

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER CP1 AT 192 SEC OTHER DP AT 40 SEC INTERVALS

		DATA POINT 6									
STA	PO	TS	TU	TI	C/A	C/AP	M	DEL TP	VS		
1	3-370E 03	1-070E 02	1-030E 03	3-500E 02	2-000E 01	2-000E 01	0-230E-04	2-420E 02	1-007E 02		
2	3-340E 03	3-100E 02	1-040E 03	3-000E 02	2-000E 01	2-000E 01	0-000E-02	2-200E 02	1-000E 02		
STA	L/D	DELTA E		L E							
1	1-740E 01	3-300E 01	4-020E 00								
2	2-377E 01	3-300E 01	4-020E 00								

LOCAL TEST PARAMETERS

TEST 133A 4 MIN STEADY POWER CP1 AT 192 SEC OTHER DP AT 40 SEC INTERVALS

		DATA POINT 7									
STA	PO	TS	TU	TI	C/A	C/AP	M	DEL TP	VS		
1	3-230E 03	1-007E 02	1-030E 03	3-400E 02	2-000E 01	2-000E 01	0-000E-02	2-230E 02	1-000E 02		
2	3-100E 03	1-101E 02	1-030E 03	3-270E 02	2-000E 01	2-000E 01	0-510E-02	2-110E 02	1-000E 02		
STA	L/D	DELTA E		L E							
1	1-740E 01	3-300E 01	4-020E 00								
2	2-377E 01	3-300E 01	4-020E 00								

Report AFRPL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 1200 6 MIN STEADY POWER CPl AT 120 SEC OTHER DATA 80 SEC INTERVALS

AP = 0.1200-03 D = 0.1225-01 L = 0.4020 01 DELTA TO = 0.2000 01

DATA POINTS

POINT	PG-IN	PG-OUT	TD-IN	TD-OUT	V	IS	CP	MS BAL	g
1	3.7020 03	3.5320 03	0.5100 01	1.2370 02	1.7770 00	3.2040 03	4.0340 01	1.0000 00	1.2040 04
2	3.6070 03	3.4370 03	0.6000 01	1.2400 02	1.7900 00	3.2000 03	4.0320 01	1.1220 00	1.2020 04
3	3.6710 03	3.5010 03	0.6000 01	1.2250 02	1.7970 00	3.2020 03	4.0340 01	7.3000-01	1.2040 04
4	3.6000 03	3.4300 03	0.6000 01	1.2200 02	1.7900 00	3.2040 03	4.0340 01	4.0000-01	1.2020 04
5	3.6140 03	3.4400 03	0.6000 01	1.2200 02	1.7700 00	3.2020 03	4.0300 01	0.9700-01	1.2020 04
6	3.6000 03	3.4300 03	0.6000 01	1.2120 02	1.8000 00	3.2000 03	4.0370 01	9.2700-01	1.2000 04
7	3.2020 03	3.1020 03	0.6000 01	1.2120 02	1.7900 00	3.2720 03	3.0000 01	1.0000 00	1.2000 04
8	3.1630 03	3.0120 03	0.3000 01	1.2100 02	1.7920 00	3.2700 03	3.0020 01	1.1700 00	1.2010 04
9	3.0200 03	2.8000 03	0.3000 01	1.2070 02	1.8000 00	3.2740 03	2.0040 01	0.0000-01	1.2100 04
10	2.9000 03	2.6000 03	0.3000 01	1.2000 02	1.8100 00	3.2740 03	2.0040 01	7.0100-01	1.2010 04

TEST SECTION

LOCAL TEST PARAMETERS

TEST 1338 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

		DATA POINT 1									
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	3.5992 03	1.110E 02	1.040E 03	3.556E 01	2.037E 01	2.004E 01	0.193E-02	2.448E 02	1.408E 02		
2	3.561E 03	1.204E 02	1.050E 03	3.697E 02	2.037E 01	2.004E 01	0.037E-02	2.002E 02	1.408E 02		
STA	L/D	DELTA E	LE								
1	1.748E 01	3.304E 01	4.030E 00								
2	2.377E 01	3.304E 01	4.030E 00								

LOCAL TEST PARAMETERS

TEST 1339 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 27 SEC INTERVALS

		DATA POINT 2									
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	3.564E 03	1.111E 02	1.044E 03	3.632E 02	2.032E 01	2.002E 01	7.944E-02	2.511E 02	1.401E 02		
2	3.546E 03	1.208E 02	1.070E 03	3.992E 02	2.032E 01	2.002E 01	7.170E-02	2.790E 02	1.407E 02		
STA	L/D	DELTA E	LE								
1	1.748E 01	3.300E 01	4.030E 00								
2	2.377E 01	3.300E 01	4.030E 00								

LOCAL TEST PARAMETERS

TEST 1338 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

		DATA POINT 3									
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	3.568E 03	1.111E 02	1.050E 03	3.702E 02	2.035E 01	2.005E 01	7.740E-02	2.590E 02	1.408E 02		
2	3.530E 03	1.205E 02	1.095E 03	4.328E 02	2.034E 01	2.005E 01	6.425E-02	3.120E 02	1.408E 02		
STA	L/D	DELTA E	LE								
1	1.748E 01	3.303E 01	4.030E 00								
2	2.377E 01	3.303E 01	4.030E 00								

LOCAL TEST PARAMETERS

TEST 1338 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

		DATA POINT 4									
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	3.585E 03	1.108E 02	1.052E 03	3.725E 02	2.036E 01	2.004E 01	7.687E-02	2.617E 02	1.401E 02		
2	3.547E 03	1.202E 02	1.105E 03	4.458E 02	2.035E 01	2.004E 01	6.185E-02	3.258E 02	1.407E 02		
STA	L/D	DELTA E	LE								
1	1.748E 01	3.304E 01	4.030E 00								
2	2.377E 01	3.304E 01	4.030E 00								

TEST 1330 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

LOCAL TEST PARAMETERS

		DATA POINT 5									
STA	PS	TS	TU	TI	O/A	O/AP	H	DEL TF	VS		
1	3.511E 03	1.108E 02	1.053E 03	3.792E 02	2.023E 01	1.989E 01	7.411E-02	2.684E 02	1.464E 02		
2	3.473E 03	1.202E 02	1.104E 03	4.495E 02	2.021E 01	1.989E 01	6.941E-02	3.293E 02	1.470E 02		
STA	L/D	DELTA E		LE							
1	1.740E 01	3.293E 01	4.030E 00								
2	2.377E 01	3.293E 01	4.030E 00								

TEST 1330 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

LOCAL TEST PARAMETERS

		DATA POINT 6									
STA	PS	TS	TU	TI	O/A	O/AP	H	DEL TF	VS		
1	3.347E 03	1.007E 02	1.046E 03	3.760E 02	2.000E 01	1.979E 01	7.425E-02	2.660E 02	1.403E 02		
2	3.309E 03	1.190E 02	1.110E 03	4.748E 02	2.005E 01	1.979E 01	5.886E-02	3.855E 02	1.409E 02		
STA	L/D	DELTA E		LE							
1	1.740E 01	3.280E 01	4.030E 00								
2	2.377E 01	3.280E 01	4.030E 00								

TEST 1330 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

LOCAL TEST PARAMETERS

		DATA POINT 7									
STA	PS	TS	TU	TI	O/A	O/AP	H	DEL TF	VS		
1	3.200E 03	1.007E 02	1.077E 03	4.820E 02	1.990E 01	1.902E 01	6.300E-02	3.122E 02	1.475E 02		
2	3.162E 03	1.190E 02	1.097E 03	4.492E 02	1.990E 01	1.902E 01	5.903E-02	3.363E 02	1.481E 02		
STA	L/D	DELTA E		LE							
1	1.700E 01	3.273E 01	4.030E 00								
2	2.377E 01	3.273E 01	4.030E 00								

TEST 1330 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

LOCAL TEST PARAMETERS

		DATA POINT 8									
STA	PS	TS	TU	TI	O/A	O/AP	H	DEL TF	VS		
1	3.000E 03	1.000E 02	1.072E 03	4.101E 02	2.000E 01	1.900E 01	6.400E-02	3.090E 02	1.477E 02		
2	3.022E 03	1.187E 02	1.112E 03	4.000E 02	2.000E 01	1.900E 01	6.231E-02	3.499E 02	1.483E 02		
STA	L/D	DELTA E		LE							
1	1.740E 01	3.276E 01	4.030E 00								
2	2.377E 01	3.276E 01	4.030E 00								

LOCAL TEST PARAMETERS
 TEST 1330 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

		DATA POINT 9									
STA	PM	TU	TU	TI	G/A	G/AP	N	DEL TP	VS		
1	2-933E 03	1-092E 02	1-092E 03	4-102E 02	2-001E 01	1-904E 01	0-817E-02	3-012E 02	1-407E 02		
2	2-092E 03	1-182E 02	1-091E 03	4-008E 02	1-999E 01	1-904E 01	0-894E-02	3-222E 02	1-402E 02		
STA	L/D	DELTA E	LE								
1	1-746E 01	3-274E 01	4-030E 00								
2	2-377E 01	3-274E 01	4-030E 00								

LOCAL TEST PARAMETERS
 TEST 1330 6 MIN STEADY POWER DPI AT 130 SEC OTHER DATA 20 SEC INTERVALS

		DATA POINT 10									
STA	PM	TU	TU	TI	G/A	G/AP	N	DEL TP	VS		
1	2-062E 03	1-090E 02	1-090E 03	3-932E 02	2-001E 01	1-904E 01	0-800E-02	2-042E 02	1-091E 02		
2	2-914E 03	1-182E 02	1-100E 03	4-222E 02	1-999E 01	1-904E 01	0-840E-02	3-307E 02	1-097E 02		
STA	L/D	DELTA E	LE								
1	1-746E 01	3-274E 01	4-030E 00								
2	2-377E 01	3-274E 01	4-030E 00								

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

X TEST 134 BURNOUT AFTER DATA POINT 6

AF = 0.130E-03 D = 0.132E-01 L = 0.450E 01 DELTA TO " 0.190E 01

POINT	DATA POINTS									
	PG-IN	PG-OUT	TP-IN	TP-OUT	U	E2	I2	CP	HT RAL	C
1	9.150E 02	9.550E 02	9.490E 01	1.030E 02	1.160E 00	1.169E 01	4.110E 02	4.077E 00	2.021E 00	9.563E 03
2	9.150E 02	9.500E 02	9.490E 01	1.030E 02	1.170E 00	1.512E 01	5.350E 02	7.683E 00	1.150E 00	9.549E 03
3	9.100E 02	9.500E 02	9.420E 01	1.230E 02	1.177E 00	2.093E 01	6.670E 02	2.007E 01	-2.000E-01	9.541E 03
4	9.050E 02	9.450E 02	9.390E 01	1.377E 02	1.177E 00	3.197E 01	1.000E 03	3.319E 01	1.000E-01	9.541E 03
5	9.040E 02	9.420E 02	9.350E 01	1.474E 02	1.174E 00	3.470E 01	1.102E 03	3.002E 01	-0.683E-01	9.520E 03
6	9.000E 02	9.430E 02	9.300E 01	1.540E 02	1.164E 00	3.667E 01	1.240E 03	4.330E 01	-2.413E 00	9.447E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 134 BURNOUT AFTER DATA POINT 6

STA	DATA POINT 1									
	P/B	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS	
1	0.650E 02	9.065E 01	2.260E 02	1.393E 02	2.037E 00	1.991E 00	5.430E-02	2.640E 01	9.079E 01	
2	0.717E 02	1.003E 02	2.250E 02	1.343E 02	2.037E 00	1.991E 00	5.407E-02	3.394E 01	9.000E 01	
3	0.503E 02	1.020E 02	2.320E 02	1.010E 02	2.030E 00	1.991E 00	5.003E-02	3.900E 01	9.000E 01	
STA	L/D	DELTA E	LE							
1	1.415E 01	1.149E 01	4.500E 00							
2	2.044E 01	1.140E 01	4.500E 00							
3	2.673E 01	1.149E 01	4.500E 00							

LOCAL TEST PARAMETERS

TEST 134 BURNOUT AFTER DATA POINT 6

STA	DATA POINT 2									
	P/B	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS	
1	0.825E 02	1.600E 02	3.180E 02	1.600E 02	3.507E 00	3.417E 00	5.023E-02	6.000E 01	9.071E 01	
2	0.681E 02	1.035E 02	3.190E 02	1.700E 02	3.507E 00	3.417E 00	5.139E-02	6.040E 01	9.000E 01	
3	0.530E 02	1.001E 02	3.300E 02	1.023E 02	3.505E 00	3.417E 00	4.487E-02	7.010E 01	9.000E 01	
STA	L/D	DELTA E	LE							
1	1.415E 01	1.012E 01	4.500E 00							
2	2.044E 01	1.012E 01	4.500E 00							
3	2.673E 01	1.012E 01	4.500E 00							

LOCAL TEST PARAMETERS

TEST 134 BURNOUT AFTER DATA POINT 6

STA	DATA POINT 3									
	P/B	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS	
1	0.800E 02	1.000E 02	6.100E 02	2.670E 02	9.300E 00	9.114E 00	5.735E-02	1.990E 02	9.000E 01	
2	0.667E 02	1.153E 02	6.100E 02	2.570E 02	9.303E 00	9.114E 00	6.394E-02	1.425E 02	9.723E 01	
3	0.533E 02	1.218E 02	6.300E 02	2.903E 02	9.349E 00	9.114E 00	5.410E-02	1.000E 02	9.749E 01	
STA	L/D	DELTA E	LE							
1	1.415E 01	2.493E 01	4.500E 00							
2	2.044E 01	2.493E 01	4.500E 00							
3	2.673E 01	2.493E 01	4.500E 00							

LOCAL TEST PARAMETERS

TEST 134 BURROUT AFTER DATA POINT 6

		DATA POINT 4									
STA		PB	VB	TV	TI	Q/A	Q/MP	M	DEL TP	VS	
1	0.750E 02	1.167E 02	0.530E 02	3.201E 02	1.510E 01	1.470E 01	7.001E-02	2.094E 02	9.729E 01		
2	0.617E 02	1.260E 02	0.400E 02	3.007E 02	1.510E 01	1.470E 01	0.122E-02	1.017E 02	5.771E 01		
3	0.403E 02	1.371E 02	0.730E 02	3.027E 02	1.510E 01	1.470E 01	0.000E-02	2.150E 02	9.013E 01		
STA	L/D	DELTA E		LE							
1	1.015E 01	3.107E 01	4.500E 00								
2	2.044E 01	3.157E 01	4.500E 00								
3	2.073E 01	3.107E 01	4.500E 00								

LOCAL TEST PARAMETERS

TEST 134 BURROUT AFTER DATA POINT 6

		DATA POINT 5									
STA		PB	VB	TV	TI	Q/A	Q/MP	M	DEL TP	VS	
1	0.745E 02	1.204E 02	0.430E 02	3.303E 02	1.703E 01	1.731E 01	7.940E-02	2.170E 02	9.719E 01		
2	0.605E 02	1.324E 02	0.260E 02	3.140E 02	1.704E 01	1.731E 01	0.000E-02	1.024E 02	9.760E 01		
3	0.405E 02	1.444E 02	0.670E 02	3.711E 02	1.701E 01	1.731E 01	7.639E-02	2.007E 02	9.010E 01		
STA	L/D	DELTA E		LE							
1	1.015E 01	3.074E 01	4.500E 00								
2	2.044E 01	3.074E 01	4.500E 00								
3	2.073E 01	3.074E 01	4.500E 00								

LOCAL TEST PARAMETERS

TEST 134 BURROUT AFTER DATA POINT 6

		DATA POINT 6									
STA		PB	VB	TV	TI	Q/A	Q/MP	M	DEL TP	VS	
1	0.750E 02	1.241E 02	1.014E 03	3.559E 02	1.900E 01	1.920E 01	0.302E-02	2.310E 02	9.051E 01		
2	0.611E 02	1.370E 02	0.350E 02	3.292E 02	1.901E 01	1.920E 01	1.000E-01	1.910E 02	9.707E 01		
3	0.406E 02	1.514E 02	1.040E 03	3.920E 02	1.973E 01	1.920E 01	0.001E-02	2.000E 02	9.764E 01		
STA	L/D	DELTA E		LE							
1	1.015E 01	3.667E 01	4.500E 00								
2	2.044E 01	3.667E 01	4.500E 00								
3	2.073E 01	3.667E 01	4.500E 00								

DIMENSIONLESS PARAMETERS

TEST 134 BURDOUT A*Y B DATA POINT 6

DATA PCINT	STA	MU	PR	RE	VI/TS	MM/PR(-4)
1	1	1.0614E 03	4.1740E 00	1.7749E 05	1.0667E 00	5.0034E 02
1	2	1.1443E 03	4.1177E 00	1.7909E 05	1.0660E 00	5.0090E 02
1	3	9.7370E 02	4.0933E 00	1.8200E 05	1.0700E 00	5.0090E 02
2	1	9.7830E 02	4.0966E 00	1.8022E 05	1.1213E 00	5.0600E 02
2	2	9.5706E 02	4.0642E 00	1.8370E 05	1.1100E 00	5.0707E 02
2	3	6.6744E 02	3.9167E 00	1.8716E 05	1.1349E 00	5.0844E 02
3	1	1.1030E 03	3.8318E 00	1.9047E 05	1.2769E 00	6.0400E 02
3	2	1.2154E 03	3.6243E 00	1.9910E 05	1.2477E 00	7.0700E 02
3	3	1.0214E 03	3.6430E 00	2.0037E 05	1.2894E 00	8.0200E 02
4	1	1.3413E 03	3.5999E 00	2.0111E 05	1.3630E 00	9.0430E 02
4	2	1.5210E 03	3.3032E 00	2.1573E 05	1.3994E 00	9.0430E 02
4	3	1.2642E 03	3.0682E 00	2.2040E 05	1.3600E 00	8.0767E 02
5	1	1.5936E 03	3.4014E 00	2.6500E 05	1.3783E 00	9.0790E 02
5	2	1.7645E 03	3.1700E 00	2.2266E 05	1.3978E 00	1.1123E 03
5	3	1.3954E 03	2.9181E 00	2.3630E 05	1.3750E 00	9.0933E 02
6	1	1.5625E 03	3.3776E 00	2.8944E 05	1.3960E 00	9.0030E 02
6	2	1.8541E 03	3.0820E 00	2.2774E 05	1.3203E 00	1.1066E 03
6	3	1.4477E 03	2.7871E 00	2.4533E 05	1.3939E 00	9.0679E 02

DATA PCINT	STA	RMO RATIO	R RATIO	MU RATIO	CP RATIO
1	1	1.0156E 00	9.4646E-01	1.2813E 00	1.0034E 00
1	2	1.0148E 00	9.5034E-01	1.2576E 00	1.0031E 00
1	3	1.0170E 00	9.4254E-01	1.2960E 00	1.0020E 00
2	1	1.0253E 00	9.0792E-01	1.5200E 00	1.0030E 00
2	2	1.0287E 00	9.1036E-01	1.5900E 00	1.0029E 00
2	3	1.0330E 00	9.0137E-01	1.5704E 00	1.0020E 00
3	1	1.0723E 00	8.5553E-01	2.2515E 00	1.0000E 00
3	2	1.0645E 00	8.6732E-01	2.0727E 00	9.9871E-01
3	3	1.0776E 00	8.6636E-01	2.2428E 00	9.9831E-01
4	1	1.0981E 00	8.5366E-01	2.6730E 00	1.0016E 00
4	2	1.0946E 00	8.6913E-01	2.3300E 00	9.9875E-01
4	3	1.1022E 00	8.7041E-01	2.5823E 00	9.9985E-01
5	1	1.1025E 00	8.5745E-01	2.7255E 00	1.0016E 00
5	2	1.0851E 00	8.7516E-01	2.3071E 00	9.9815E-01
5	3	1.1085E 00	8.8033E-01	2.6456E 00	1.0009E 00
6	1	1.1100E 00	8.6105E-01	2.8306E 00	1.0024E 00
6	2	1.0899E 00	8.8022E-01	2.3627E 00	9.9802E-01
6	3	1.1117E 00	8.9248E-01	2.7390E 00	1.0039E 00

DIMENSIONLESS PARAMETERS

TEST 134 BURNOUT AFTER DATA POINT 6

DATA POINT	STA	NU(F)	PR(F)	RE(F)	TI/TF	NU/PR(0.0)
1	1	1.0323E 03	3.5837E 00	2.0041E 05	1.0318E 00	6.1953E 02
1	2	1.1152E 03	3.5750E 00	2.0094E 05	1.0294E 00	6.6995E 02
1	3	9.4435E 02	3.4399E 00	2.0731E 05	1.0302E 00	5.7612E 02
2	1	9.3021E 02	3.1159E 00	2.2337E 05	1.0572E 00	5.9041E 02
2	2	9.4920E 02	3.0744E 00	2.2590E 05	1.0557E 00	6.0568E 02
2	3	8.2000E 02	2.9219E 00	2.3504E 05	1.0430E 00	5.3401E 02
3	1	9.9259E 02	2.1851E 00	2.9473E 05	1.1226E 00	7.2667E 02
3	2	1.1057E 03	2.2090E 00	2.9300E 05	1.1102E 00	8.0018E 02
3	3	9.2159E 02	1.9781E 00	3.2066E 05	1.1265E 00	7.0188E 02
4	1	1.1803E 03	1.8307E 00	3.4034E 05	1.1536E 00	9.3303E 02
4	2	1.3723E 03	1.6632E 00	3.3704E 05	1.1341E 00	1.0499E 03
4	3	1.1350E 03	1.6451E 00	3.7428E 05	1.1529E 00	9.3330E 02
5	1	1.3330E 03	1.7632E 00	3.5041E 05	1.1500E 00	1.0424E 03
5	2	1.5679E 03	1.6114E 00	3.4461E 05	1.1334E 00	1.2399E 03
5	3	1.2632E 03	1.5991E 00	3.9143E 05	1.1579E 00	1.0576E 03
6	1	1.3844E 03	1.6803E 00	3.6181E 05	1.1654E 00	1.1250E 03
6	2	1.6820E 03	1.7301E 00	3.5539E 05	1.1300E 00	1.3500E 03
6	3	1.3161E 03	1.4741E 00	4.0797E 05	1.1644E 00	1.1269E 03

Report AFRPL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 135.00 AT DP6.DP1-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

AF = 0.138E-03 C = 0.132E-01 L = 0.400E 01 DELTA TO = 0.160E 01

CATA POINTS

PCINT	PB-IA	PB-CLY	TB-IN	TE-OUT	W	E2	I2	OP'	MT BAL	C
1	3.337E 03	3.210E 03	7.970E 01	1.293E 02	1.844E 00	3.866E 01	1.519E 03	5.503E 01	-2.126E 00	1.342E 04
2	3.336E 03	3.209E 03	7.970E 01	1.304E 02	1.852E 00	3.890E 01	1.532E 03	5.545E 01	-2.574E 00	1.342E 04
3	3.330E 03	3.203E 03	7.965E 01	1.307E 02	1.849E 00	3.909E 01	1.534E 03	5.605E 01	-2.990E 00	1.342E 04
4	3.327E 03	3.202E 03	7.970E 01	1.311E 02	1.850E 00	3.911E 01	1.536E 03	5.645E 01	-3.831E 00	1.342E 04
5	3.325E 03	3.200E 03	7.960E 01	1.314E 02	1.851E 00	3.914E 01	1.532E 03	5.684E 01	-4.664E 00	1.342E 04
6	3.321E 03	3.197E 03	7.945E 01	1.314E 02	1.840E 00	3.916E 01	1.534E 03	5.695E 01	-3.962E 00	1.335E 04

TEST SECTION

LOCAL TEST PARAMETERS

TEST 135.00 AT DP6.DP1-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

DATA POINT 1

STA	PB	TB	TB	TI	O/A	Q/AP	M	DEL TF	VS
1	3.218E 03	1.262E 02	1.221E 03	3.071E 02	2.790E 01	2.779E 01	1.536E-01	1.809E 02	1.534E 02
STA	L/O	DELTA E	LE						
1	2.356E 01	3.656E 01	4.000E 00						

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 135.80 AT DP6.DPI-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

DATA POINT 2

STA	PB	TB	TU	TI	C/A	G/AP	H	DEL TF	VS
1	3.217E 03	1.272E 02	1.245E 03	3.191E 02	2.846E 01	2.835E 01	1.477E-01	1.919E 02	1.535E 02

STA	L/D	DELTA E	LE
1	2.358E 01	3.858E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 135.80 AT DP6.DPI-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

DATA POINT 3

STA	PB	TB	TU	TI	C/A	G/AP	H	DEL TF	VS
1	3.211E 03	1.275E 02	1.251E 03	3.210E 02	2.864E 01	2.844E 01	1.464E-01	1.943E 02	1.535E 02

STA	L/D	DELTA E	LE
1	2.358E 01	3.969E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 135.80 AT DP6.DPI-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

DATA POINT 4

STA	PB	TB	TU	TI	C/A	G/AP	H	DEL TF	VS
1	3.210E 03	1.279E 02	1.254E 03	3.253E 02	2.867E 01	2.866E 01	1.444E-01	1.974E 02	1.543E 02

STA	L/D	DELTA E	LE
1	2.358E 01	3.911E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 135.80 AT DP6.DPI-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

DATA POINT 5

STA	PB	TB	TU	TI	C/A	G/AP	H	DEL TF	VS
1	3.208E 03	1.282E 02	1.258E 03	3.297E 02	2.871E 01	2.844E 01	1.411E-01	2.014E 02	1.537E 02

STA	L/D	DELTA E	LE
1	2.358E 01	3.914E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 135.80 AT DP6.DPI-100 SEC.DP6-146 SEC.OTHER DATA AT 10 SEC INTERVAL

DATA POINT 6

STA	PB	TB	TU	TI	C/A	G/AP	H	DEL TF	VS
1	3.205E 03	1.282E 02	1.243E 03	3.061E 02	3.874E 01	2.858E 01	1.611E-01	1.764E 02	1.528E 02

STA	L/D	DELTA E	LE
1	2.358E 01	3.916E 01	4.000E 00

Report AFRL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 133A.5 MIN STEADY PC6E4UPI-9C SCL-GUTMER DATA AT 20 SEC INTERVALS

AF = 0.138E-01 U = 0.132E-01 L = 0.00E 01 DELTA TU = 0.200E 01

DATA POINTS

POINT	PA-IN	PA-OUT	TA-IN	TA-OUT	W	E2	I2	JP	HT BAL	G
1	2.670E 03	2.720E 03	7.620E 01	1.167E 02	1.800E 00	3.521E 01	1.372E 03	4.580E 01	2.110E-01	1.364E 04
2	2.670E 03	2.720E 03	7.650E 01	1.167E 02	1.800E 00	3.522E 01	1.370E 03	4.574E 01	-2.750E-01	1.364E 04
3	2.670E 03	2.720E 03	7.550E 01	1.165E 02	1.807E 00	3.520E 01	1.372E 03	4.578E 01	0.004E-02	1.364E 04
4	2.670E 03	2.720E 03	7.550E 01	1.165E 02	1.807E 00	3.525E 01	1.371E 03	4.581E 01	1.810E-02	1.364E 04
5	2.670E 03	2.720E 03	7.550E 01	1.158E 02	1.804E 00	3.521E 01	1.367E 03	4.583E 01	-8.839E-02	1.374E 04
6	2.670E 03	2.720E 03	7.550E 01	1.158E 02	1.804E 00	3.504E 01	1.362E 03	4.531E 01	-8.66E-01	1.379E 04
7	2.670E 03	2.720E 03	7.550E 01	1.158E 02	1.804E 00	3.512E 01	1.362E 03	4.535E 01	-3.602E-01	1.372E 04
8	2.670E 03	2.720E 03	7.550E 01	1.153E 02	1.804E 00	3.509E 01	1.361E 03	4.519E 01	-9.201E-01	1.374E 04
9	2.670E 03	2.720E 03	7.620E 01	1.153E 02	1.804E 00	3.509E 01	1.361E 03	4.527E 01	-7.259E-01	1.371E 04
10	2.670E 03	2.720E 03	7.670E 01	1.152E 02	1.804E 00	3.507E 01	1.362E 03	4.528E 01	-8.439E-01	1.371E 04
11	2.670E 03	2.720E 03	7.650E 01	1.152E 02	1.804E 00	3.504E 01	1.354E 03	4.514E 01	-1.142E 00	1.364E 04
12	2.670E 03	2.720E 03	7.650E 01	1.153E 02	1.804E 00	3.511E 01	1.363E 03	4.537E 01	-1.454E 00	1.374E 04
13	2.670E 03	2.720E 03	7.550E 01	1.153E 02	1.804E 00	3.509E 01	1.354E 03	4.511E 01	-4.352E-01	1.374E 04
14	2.670E 03	2.720E 03	7.650E 01	1.154E 02	1.804E 00	3.516E 01	1.361E 03	4.546E 01	-1.457E 00	1.371E 04
15	2.670E 03	2.720E 03	7.650E 01	1.153E 02	1.807E 00	3.514E 01	1.359E 03	4.523E 01	-1.659E 00	1.369E 04
16	2.670E 03	2.720E 03	7.640E 01	1.153E 02	1.807E 00	3.517E 01	1.359E 03	4.531E 01	-1.001E 00	1.362E 04

Report AFRL-TR-66-263, Appendix B

TEST SECTION - LOCAL TEST PARAMETERS
 TEST 136A.5 MIN STEADY POWER/DPI-90 SEC/OTHER DATA AT 20 SEC INTERVALS

DATA POINT 1											
STA	PH	TS	TI	TA	W/A	C/AP	M	DEL TF	VS		
1	2.772E 03	1.002E 02	3.074E 02	2.336E 01	2.202E 01	0.050E-02	0.050E-02	2.033E 02	1.546E 02		
DATA POINT 2											
STA	PH	TS	TI	TA	W/A	C/AP	M	DEL TF	VS		
1	2.754E 03	1.040E 02	3.096E 02	2.339E 01	2.204E 01	0.051E-02	0.051E-02	2.050E 02	1.551E 02		
DATA POINT 3											
STA	PH	TS	TI	TA	W/A	C/AP	M	DEL TF	VS		
1	2.810E 03	1.038E 02	3.770E 02	2.332E 01	2.291E 01	0.035E-02	0.035E-02	2.741E 02	1.751E 02		
DATA POINT 4											
STA	PH	TS	TI	TA	W/A	C/AP	M	DEL TF	VS		
1	2.805E 03	1.033E 02	3.790E 02	2.342E 01	2.292E 01	0.031E-02	0.031E-02	2.790E 02	1.551E 02		
DATA POINT 5											
STA	PH	TS	TI	TA	W/A	C/AP	M	DEL TF	VS		
1	2.834E 03	1.032E 02	3.817E 02	2.337E 01	2.283E 01	0.019E-02	0.019E-02	2.760E 02	1.507E 02		
DATA POINT 6											
STA	PH	TS	TI	TA	W/A	C/AP	M	DEL TF	VS		
1	2.825E 03	1.024E 02	3.842E 02	2.322E 01	2.207E 01	0.051E-02	0.051E-02	2.803E 02	1.561E 02		

TEST SECTION - LOCAL TEST PARAMETERS
 TEST 1300+5 MIN STEADY PUMP, DPI-90 SEC. OUTLINE DATA AT 20 SEC INTERVALS

		DATA POINT 7									
STA	PB	TU	TI	TW	Q/A	Q/AP	M	DEL TF	VS		
1	2.824E 03	1.027E 02	3.662E 02	1.131E 03	2.326E 01	2.269E 01	8.614E-02	2.634E 02	1.553E 02		
	L/D	DELTA L	LE								
1	1.730E 01	3.512E 01	4.000E 00								
		DATA POINT 6									
STA	PB	TU	TI	TW	Q/A	Q/AP	M	DEL TF	VS		
1	2.815E 03	1.027E 02	3.657E 02	1.142E 03	2.317E 01	2.261E 01	7.989E-02	2.830E 02	1.556E 02		
	L/D	DELTA L	LE								
1	1.730E 01	3.505E 01	4.000E 00								
		DATA POINT 9									
STA	PB	TU	TI	TW	Q/A	Q/AP	M	DEL TF	VS		
1	2.824E 03	1.027E 02	3.764E 02	1.137E 03	2.322E 01	2.265E 01	8.274E-02	2.738E 02	1.552E 02		
	L/D	DELTA L	LE								
1	1.730E 01	3.505E 01	4.000E 00								
		DATA POINT 10									
STA	PB	TU	TI	TW	Q/A	Q/AP	M	DEL TF	VS		
1	2.819E 03	1.025E 02	3.947E 02	1.149E 03	2.321E 01	2.266E 01	7.755E-02	2.922E 02	1.552E 02		
	L/D	DELTA L	LE								
1	1.730E 01	3.507E 01	4.000E 00								
		DATA POINT 11									
STA	PB	TU	TI	TW	Q/A	Q/AP	M	DEL TF	VS		
1	2.814E 03	1.025E 02	3.681E 02	1.144E 03	2.319E 01	2.259E 01	7.909E-02	2.855E 02	1.550E 02		
	L/D	DELTA L	LE								
1	1.730E 01	3.506E 01	4.000E 00								
		DATA POINT 12									
STA	PB	TU	TI	TW	Q/A	Q/AP	M	DEL TF	VS		
1	2.810E 03	1.025E 02	3.655E 02	1.144E 03	2.325E 01	2.270E 01	8.024E-02	2.629E 02	1.556E 02		
	L/D	DELTA L	LE								
1	1.730E 01	3.511E 01	4.000E 00								

TEST SECTION - LOCAL TEST PARAMETERS
 TEST 136A15 MIN STEADY POWER/OPI-90 SECTION DATA AT 20 SEC INTERVALS

		DATA POINT 13									
STA	PB	TB	T _B	TI	Q/A	Q/AP	H	DEL TF	VS		
1	2.810E 03	1.028E 02	1.154E 03	4.006E 02	2.324E 01	2.257E 01	7.573E-02	2.981E 02	1.556E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.509E 01	4.000E 00								
		DATA POINT 14									
STA	PB	TB	T _B	TI	Q/A	Q/AP	H	DEL TF	VS		
1	2.810E 03	1.026E 02	1.154E 03	3.972E 02	2.333E 01	2.270E 01	7.706E-02	2.946E 02	1.552E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.516E 01	4.000E 00								
		DATA POINT 15									
STA	PB	TB	T _B	TI	Q/A	Q/AP	H	DEL TF	VS		
1	2.805E 03	1.025E 02	1.160E 03	4.073E 02	2.329E 01	2.263E 01	7.425E-02	3.046E 02	1.550E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.513E 01	4.000E 00								
		DATA POINT 16									
STA	PB	TU	T _B	TI	Q/A	Q/AP	H	DEL TF	VS		
1	2.800E 03	1.025E 02	1.160E 03	4.053E 02	2.334E 01	2.267E 01	7.449E-02	3.027E 02	1.542E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.517E 01	4.000E 00								

DIMENSIONLESS PARAMETERS

TEST 130A.5 MIN STEADY PUMED-DPI-90 SEC. OTHER DATA AT 20 SEC INTERVALS

DATA POINT	STA	NU	PR	RE	TI/TB	NU/PRI(0.4)
1	1	1.5600E 03	3.9600E 00	2.9465E 05	1.5021E 00	9.6266E 02
2	1	1.6719E 03	3.9675E 00	2.9533E 05	1.4710E 00	9.6117E 02
3	1	1.6210E 03	3.9931E 00	2.9496E 05	1.4801E 00	9.3202E 02
4	1	1.6127E 03	3.9937E 00	2.9495E 05	1.4692E 00	9.2666E 02
5	1	1.5420E 03	4.0146E 00	2.9475E 05	1.4945E 00	9.1302E 02
6	1	1.6536E 03	4.0237E 00	2.9511E 05	1.4731E 00	9.4761E 02
7	1	1.6738E 03	4.0277E 00	2.9532E 05	1.4680E 00	9.5669E 02
8	1	1.5523E 03	4.0311E 00	2.9373E 05	1.5030E 00	8.8895E 02
9	1	1.6081E 03	4.0321E 00	2.9289E 05	1.4800E 00	9.2066E 02
10	1	1.5074E 03	4.0361E 00	2.9265E 05	1.5194E 00	8.6267E 02
11	1	1.5375E 03	4.0360E 00	2.9215E 05	1.5076E 00	8.7983E 02
12	1	1.5597E 03	4.0348E 00	2.9350E 05	1.5029E 00	8.9272E 02
13	1	1.4715E 03	4.0404E 00	2.9390E 05	1.5298E 00	8.8275E 02
14	1	1.4577E 03	4.0324E 00	2.9287E 05	1.5435E 00	8.5744E 02
15	1	1.4433E 03	4.0359E 00	2.9235E 05	1.5418E 00	8.2601E 02
16	1	1.4558E 03	4.0364E 00	2.9077E 05	1.5362E 00	8.3311E 02

DIMENSIONLESS PARAMETERS

TEST 130A.5 MIN STEADY PUMED-DPI-90 SEC. OTHER DATA AT 20 SEC INTERVALS

DATA POINT	STA	NU(F)	PK(F)	ME(F)	TI/TF	NU/PRI(0.4)
1	1	1.3444E 03	1.6826E 00	5.9003E 05	1.2007E 00	1.1027E 03
2	1	1.4391E 03	1.7394E 00	5.7303E 05	1.1900E 00	1.1613E 03
3	1	1.3929E 03	1.6794E 00	5.8149E 05	1.1955E 00	1.1321E 03
4	1	1.3847E 03	1.6731E 00	5.8325E 05	1.1955E 00	1.1270E 03
5	1	1.3650E 03	1.6680E 00	5.8670E 05	1.1938E 00	1.1124E 03
6	1	1.4222E 03	1.7157E 00	5.7507E 05	1.1913E 00	1.1459E 03
7	1	1.4404E 03	1.7281E 00	5.6872E 05	1.1896E 00	1.1573E 03
8	1	1.3291E 03	1.6547E 00	5.9044E 05	1.2013E 00	1.0666E 03
9	1	1.3798E 03	1.6892E 00	5.7902E 05	1.1937E 00	1.1188E 03
10	1	1.2674E 03	1.6234E 00	5.9618E 05	1.2024E 00	1.0606E 03
11	1	1.3151E 03	1.6469E 00	5.9022E 05	1.2024E 00	1.0772E 03
12	1	1.3351E 03	1.6500E 00	5.9005E 05	1.2009E 00	1.0912E 03
13	1	1.2554E 03	1.6015E 00	6.0660E 05	1.2094E 00	1.0398E 03
14	1	1.2766E 03	1.6144E 00	6.0100E 05	1.2073E 00	1.0557E 03
15	1	1.2293E 03	1.5804E 00	6.1100E 05	1.2131E 00	1.0236E 03
16	1	1.2464E 03	1.5872E 00	6.0500E 05	1.2120E 00	1.0311E 03

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 1368 DU AT CW 7.0PI-125 SEC.0P7-1875 SEC.0UTHER DATA AT 10 SEC INTERVAL

AF = 0.130E-01 D = 0.132E-01 L = 0.400E 01 DELTA TU = 0.260E 01

POINT	DATA POINTS							C		
	PB-IN	PB-OUT	TB-IN	TB-OUT	N	C2	I2		QP	MT GAL
1	2.895E 03	2.725E 03	8.400E 01	1.266E 02	1.850E 00	3.653E 01	1.414E 03	4.097E 01	-1.422E 00	1.343E 04
2	2.915E 03	2.725E 03	8.400E 01	1.285E 02	1.857E 00	3.653E 01	1.414E 03	4.905E 01	-1.396E 00	1.348E 04
3	2.905E 03	2.780E 03	8.400E 01	1.289E 02	1.861E 00	3.655E 01	1.415E 03	4.903E 01	-2.628E 00	1.351E 04
4	2.915E 03	2.790E 03	8.400E 01	1.289E 02	1.861E 00	3.657E 01	1.414E 03	4.902E 01	-2.645E 00	1.351E 04
5	2.920E 03	2.750E 03	8.400E 01	1.291E 02	1.857E 00	3.654E 01	1.414E 03	4.890E 01	-2.994E 00	1.340E 04
6	2.915E 03	2.766E 03	8.400E 01	1.292E 02	1.863E 00	3.655E 01	1.411E 03	4.889E 01	-3.764E 00	1.353E 04
7	2.915E 03	2.788E 03	8.400E 01	1.295E 02	1.861E 00	3.663E 01	1.414E 03	4.910E 01	-3.936E 00	1.351E 04

TEST SECTION - LOCAL TEST PARAMETERS

TEST 1-66-60 AT DP 7.0F1-125 SEC, WP7-187 SEC, UTMEN DATA AT 10 DEL INTERVA

DATA POINT 1											
STA	PU	TU	Tb	Ti	C/A	Q/AP	M	DEL TF	VS		
1	2.860E 03	1.187E 02	1.222E 03	4.231E 02	2.512E 01	2.450E 01	7.944E-02	3.004E 02	1.520E 02		
STA	L/C	DELTA L	LE								
1	1.730E 01	3.053E 01	4.000E 00								
DATA POINT 2											
STA	PU	TU	Tb	Ti	C/A	Q/AP	M	DEL TF	VS		
1	2.826E 03	1.180E 02	1.220E 03	4.200E 02	2.529E 01	2.454E 01	7.917E-02	3.140E 02	1.534E 02		
STA	L/C	DELTA L	LE								
1	1.730E 01	3.053E 01	4.000E 00								
DATA POINT 3											
STA	PU	TU	Tb	Ti	C/A	Q/AP	M	DEL TF	VS		
1	2.813E 03	1.184E 02	1.234E 03	4.405E 02	2.518E 01	2.453E 01	7.399E-02	3.316E 02	1.537E 02		
STA	L/C	DELTA L	LE								
1	1.730E 01	3.053E 01	4.000E 00								
DATA POINT 4											
STA	PU	TU	Tb	Ti	C/A	Q/AP	M	DEL TF	VS		
1	2.824E 03	1.184E 02	1.240E 03	4.400E 02	2.510E 01	2.453E 01	7.384E-02	3.320E 02	1.537E 02		
STA	L/C	DELTA L	LE								
1	1.730E 01	3.053E 01	4.000E 00								
DATA POINT 5											
STA	PU	TU	Tb	Ti	C/A	Q/AP	M	DEL TF	VS		
1	2.831E 03	1.150E 02	1.247E 03	4.504E 02	2.512E 01	2.451E 01	7.138E-02	3.434E 02	1.534E 02		
STA	L/C	DELTA L	LE								
1	1.730E 01	3.053E 01	4.000E 00								
DATA POINT 6											
STA	PU	TU	Tb	Ti	C/A	Q/AP	M	DEL TF	VS		
1	2.828E 03	1.151E 02	1.245E 03	4.550E 02	2.513E 01	2.448E 01	7.190E-02	3.394E 02	1.539E 02		
STA	L/C	DELTA L	LE								
1	1.730E 01	3.053E 01	4.000E 00								

Report AFRPL-TR-66-263, Appendix B

TEST SECTION - LOCAL TEST PARAMETERS

TEST 1300.00 AT CP 7.0PI-125 SLC.0P7-1875CL.OTHER DATA AT 10 SEC INTERVAL

STA	PH	TU	TU	TI	Q/A	Q/AP	M	DEL TF	VS
1	2.020E 03	1.152E 02	1.257E 03	4.074E 02	2.523E 01	2.457E 01	6.907E-02	3.527E 02	1.537E 02
STA	L/D	DELTA L	LE						
1	1.730E 01	3.663L 01	4.000E 00						

DATA POINT 7

DIMENSIONS UNLESS PARAMETERS

TEST 1200.00 AT CP 7.0PI-125 SLC.0P7-1875CL.OTHER DATA AT 10 SEC INTERVAL

DATA POINT	STA	NU	PH	RE	TI/TO	NU/PR(1.4)
1	1	1.5101E 03	3.0530E 00	3.1159E 05	1.2307E 00	9.0294E 02
2	1	1.4515E 03	3.0531E 00	3.1263E 05	1.2500E 00	8.0037E 02
3	1	1.4115E 03	3.0400E 00	3.1309E 05	1.2700E 00	8.4125E 02
4	1	1.4057E 03	3.0400E 00	3.1309E 05	1.2775E 00	8.4014E 02
5	1	1.3614E 03	3.0427E 00	3.1351E 05	1.2972E 00	8.1173E 02
6	1	1.3725E 03	3.0407E 00	3.1467E 05	1.2911E 00	8.1854E 02
7	1	1.3283E 03	3.0452E 00	3.1476E 05	1.3130E 00	7.9270E 02

DATA POINT	STA	NU(F)	PR(F)	RE(F)	TI/TF	NU/PR(1.4)
1	1	1.3081E 03	1.4922E 00	6.3175E 05	1.2116E 00	1.1140E 03
2	1	1.2400E 03	1.4760E 00	6.3905E 05	1.2140E 00	1.1004E 03
3	1	1.2130E 03	1.4230E 00	6.6159E 05	1.2230E 00	1.0530E 03
4	1	1.2110E 03	1.4220E 00	6.6194E 05	1.2240E 00	1.0520E 03
5	1	1.1600E 03	1.3890E 00	6.7396E 05	1.2294E 00	1.0240E 03
6	1	1.1790E 03	1.3980E 00	6.7234E 05	1.2201E 00	1.0300E 03
7	1	1.1351E 03	1.3021E 00	6.6710E 05	1.2300E 00	1.0067E 03

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.OPI-140 SEC.OTHER DATA AT 20 SEC INTERVALS

AF = 0.273E-03 C = 0.212E-01 L = 0.500E 01 DELTA TO = 0.700E 00

DATA POINTS

POINT	PG-1A	PG-OUT	TO-IN	TO-OUT	B	E2	I2	OP	MT GAL	C
1	3.752E 03	3.750E 03	5.900E 01	1.377E 02	1.143E 00	2.609E 01	1.100E 03	2.733E 01	-1.704E 00	4.174E 03
2	3.747E 03	2.745E 03	5.800E 01	1.366E 02	1.141E 00	2.629E 01	1.119E 03	2.779E 01	-2.790E 00	4.172E 03
3	3.744E 03	3.742E 03	5.850E 01	1.379E 02	1.141E 00	2.610E 01	1.104E 03	2.700E 01	-2.990E 00	4.172E 03
4	3.738E 03	2.736E 03	5.840E 01	1.360E 02	1.144E 00	2.624E 01	1.108E 03	2.750E 01	-3.370E 00	4.163E 03
5	3.735E 03	2.733E 03	5.810E 01	1.372E 02	1.139E 00	2.613E 01	1.104E 03	2.740E 01	-3.533E 00	4.162E 03
6	3.731E 03	3.729E 03	5.810E 01	1.379E 02	1.138E 00	2.610E 01	1.104E 03	2.702E 01	-3.777E 00	4.161E 03
7	3.727E 03	3.725E 03	5.800E 01	1.379E 02	1.141E 00	2.610E 01	1.104E 03	2.742E 01	-4.310E 00	4.172E 03
8	3.724E 03	3.722E 03	5.780E 01	1.376E 02	1.134E 00	2.610E 01	1.102E 03	2.742E 01	-3.500E 00	4.140E 03
9	3.721E 03	3.719E 03	5.760E 01	1.377E 02	1.139E 00	2.610E 01	1.106E 03	2.742E 01	-4.650E 00	4.165E 03
10	3.716E 03	2.714E 03	5.750E 01	1.375E 02	1.130E 00	2.611E 01	1.104E 03	2.733E 01	-4.830E 00	4.132E 03
11	3.712E 03	3.710E 03	5.740E 01	1.375E 02	1.131E 00	2.614E 01	1.104E 03	2.736E 01	-4.267E 00	4.135E 03
12	3.710E 03	3.708E 03	5.730E 01	1.374E 02	1.130E 00	2.609E 01	1.108E 03	2.740E 01	-3.995E 00	4.132E 03
13	3.702E 03	3.700E 03	5.630E 01	1.350E 02	1.149E 00	2.604E 01	1.104E 03	2.730E 01	-4.497E 00	4.201E 03
14	3.697E 03	3.695E 03	5.620E 01	1.357E 02	1.156E 00	2.607E 01	1.104E 03	2.720E 01	-5.201E 00	4.227E 03
15	3.692E 03	3.690E 03	5.600E 01	1.354E 02	1.149E 00	2.607E 01	1.104E 03	2.733E 01	-4.641E 00	4.201E 03
16	3.690E 03	3.687E 03	5.590E 01	1.356E 02	1.145E 00	2.610E 01	1.100E 03	2.742E 01	-4.830E 00	4.180E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.OPI-140 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 1

STA	PG	TR	TW	TI	Q/A	Q/AP	M	DEL TF	VS
1	3.751E 03	1.222E 02	6.290E 02	3.259E 02	8.095E 00	7.766E 00	3.765E-02	2.946E 02	4.767E 01
2	3.750E 03	1.280E 02	6.500E 02	3.550E 02	8.005E 00	7.766E 00	3.421E-02	2.270E 02	4.783E 01
3	3.750E 03	1.250E 02	6.590E 02	4.130E 02	8.066E 00	7.766E 00	2.001E-02	2.772E 02	4.799E 01

STA	L/D	DELTA E	LE
1	1.084E 01	2.609E 01	5.000E 00
2	1.476E 01	2.609E 01	5.000E 00
3	1.476E 01	2.609E 01	5.000E 00

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER-DPI-140 SEC. OTHER DATA AT 20 SEC INTERVALS

DATA POINT 2											
STA	PG	TR	TR	TI	C/A	G/AP	N	DEL TP	VS		
1	3.746E 03	1.207E 02	6.520E 02	3.527E 02	0.209E 00	7.094E 00	3.407E-02	2.310E 02	4.764E 01		
2	3.745E 03	1.205E 02	6.700E 02	3.739E 02	0.200E 00	7.094E 00	3.219E-02	2.453E 02	4.770E 01		
3	3.745E 02	1.306E 02	7.100E 02	4.212E 02	0.104E 00	7.094E 00	2.775E-02	2.045E 02	4.790E 01		
STA	L/D	DELTA E	LE								
1	1.003E 01	2.629E 01	5.000E 00								
2	1.076E 01	2.629E 01	5.000E 00								
3	1.070E 01	2.629E 01	5.000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER-DPI-140 SEC. OTHER DATA AT 20 SEC INTERVALS

DATA POINT 3											
STA	PG	TR	TR	TI	C/A	G/AP	N	DEL TP	VS		
1	3.743E 03	1.202E 02	6.400E 02	3.400E 02	0.143E 00	7.000E 00	3.423E-02	2.279E 02	4.750E 01		
2	3.743E 03	1.200E 02	6.620E 02	3.671E 02	0.134E 00	7.000E 00	3.262E-02	2.301E 02	4.774E 01		
3	3.742E 02	1.259E 02	7.030E 02	4.155E 02	0.120E 00	7.000E 00	2.709E-02	2.794E 02	4.740E 01		
STA	L/D	DELTA E	LE								
1	1.003E 01	2.610E 01	5.000E 00								
2	1.076E 01	2.610E 01	5.000E 00								
3	1.070E 01	2.610E 01	5.000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER-DPI-140 SEC. OTHER DATA AT 20 SEC INTERVALS

DATA POINT 4											
STA	PG	TR	TR	TI	C/A	G/AP	N	DEL TP	VS		
1	3.737E 03	1.202E 02	6.390E 02	3.202E 02	0.104E 00	7.030E 00	3.093E-02	2.100E 02	4.770E 01		
2	3.734E 03	1.201E 02	6.610E 02	3.644E 02	0.173E 00	7.030E 00	3.314E-02	2.303E 02	4.707E 01		
3	3.736E 02	1.300E 02	7.000E 02	4.200E 02	0.155E 00	7.030E 00	2.750E-02	2.040E 02	4.803E 01		
STA	L/D	DELTA E	LE								
1	1.003E 01	2.624E 01	5.000E 00								
2	1.076E 01	2.624E 01	5.000E 00								
3	1.070E 01	2.624E 01	5.000E 00								

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER-DPI-140 SEC-OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 5									
STA	P/B	TE	TU	Tl	C/A	G/AP	M	DEL TP	VS		
1	3-720E 03	1-199E 02	6-450E 02	3-401E 02	0-113E 00	7-700E 00	3-411E-02	2-203E 02	0-750E 01		
2	3-720E 03	1-279E 02	6-530E 02	3-576E 02	0-100E 00	7-700E 00	3-307E-02	2-270E 02	0-700E 01		
3	2-733E 03	1-357E 02	7-000E 02	4-202E 02	0-007E 00	7-700E 00	2-730E-02	2-000E 02	0-700E 01		
STA	L/D	DELTA E	L								
1	1-003E 01	2-012E 01	5-000E 00								
2	1-076E 01	2-012E 01	5-000E 00								
3	1-070E 01	2-013E 01	5-000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER-DPI-140 SEC-OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 6									
STA	P/B	TE	TU	Tl	C/A	G/AP	M	DEL TP	VS		
1	3-730E 03	1-200E 02	6-430E 02	3-440E 02	0-102E 00	7-000E 00	3-475E-02	2-203E 02	0-700E 01		
2	3-720E 03	1-350E 02	6-510E 02	3-500E 02	0-101E 00	7-000E 00	3-576E-02	2-101E 02	0-770E 01		
3	2-720E 03	1-279E 02	7-000E 02	4-220E 02	0-117E 00	7-000E 00	2-607E-02	2-900E 02	0-700E 01		
STA	L/D	DELTA E	L								
1	1-003E 01	2-010E 01	5-000E 00								
2	1-070E 01	2-010E 01	5-000E 00								
3	1-070E 01	2-010E 01	5-000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER-DPI-140 SEC-OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 7									
STA	P/B	TE	TU	Tl	C/A	G/AP	M	DEL TP	VS		
1	3-720E 03	1-199E 02	6-450E 02	3-440E 02	0-104E 00	7-000E 00	3-437E-02	2-203E 02	0-750E 01		
2	3-725E 03	1-279E 02	6-510E 02	3-059E 02	0-130E 00	7-000E 00	3-277E-02	2-300E 02	0-770E 01		
3	2-725E 03	1-359E 02	7-120E 02	4-261E 02	0-115E 00	7-000E 00	2-000E-02	2-900E 02	0-700E 01		
STA	L/D	DELTA E	L								
1	1-003E 01	2-010E 01	5-000E 00								
2	1-070E 01	2-010E 01	5-000E 00								
3	1-070E 01	2-010E 01	5-000E 00								

LOCAL TEST PARAMETERS
TEST 137A.5 MIN STEADY FCNDR.DPI-140 SEC. OTHER DATA AT 20 SEC INTERVALS

STA	PB	TI	TM	TU	TV	W/A	W/AP	M	DEL TP	VS
1	2.723E 03	1.157E 02	6.440E 02	3.456E 02	0.144E 00	7.793E 00	7.793E 00	3.449E-02	2.260E 02	4.720E 01
2	3.722E 03	1.276E 02	6.630E 02	3.603E 02	0.135E 00	7.793E 00	7.793E 00	3.230E-02	2.487E 02	4.744E 01
2	2.722E 03	1.255E 02	7.110E 02	4.249E 02	0.116E 00	7.793E 00	7.793E 00	2.693E-02	2.693E 02	4.740E 01
STA	L/D	DELTA E	L							
1	1.003E 01	2.610E 01	5.000E 00							
2	1.475E 01	2.615E 01	5.000E 00							
3	1.670E 01	2.610E 01	5.000E 00							

LOCAL TEST PARAMETERS
TEST 137A.5 MIN STEADY FCNDR.DPI-140 SEC. OTHER DATA AT 20 SEC INTERVALS

STA	PB	TI	TM	TU	TV	W/A	W/AP	M	DEL TP	VS
1	2.720E 03	1.157E 02	6.420E 02	3.433E 02	0.145E 00	7.800E 00	7.800E 00	3.400E-02	2.230E 02	4.740E 01
2	3.720E 03	1.277E 02	6.580E 02	3.624E 02	0.137E 00	7.800E 00	7.800E 00	3.325E-02	2.347E 02	4.765E 01
2	3.719E 03	1.257E 02	7.160E 02	4.300E 02	0.113E 00	7.800E 00	7.800E 00	2.693E-02	2.951E 02	4.782E 01
STA	L/D	DELTA E	L							
1	1.003E 01	2.610E 01	5.000E 00							
2	1.476E 01	2.610E 01	5.000E 00							
3	1.670E 01	2.610E 01	5.000E 00							

LOCAL TEST PARAMETERS
TEST 137A.5 MIN STEADY FCNDR.DPI-140 SEC. OTHER DATA AT 20 SEC INTERVALS

STA	PB	TI	TM	TU	TV	W/A	W/AP	M	DEL TP	VS
1	3.715E 03	1.155E 02	6.410E 02	3.430E 02	0.102E 00	7.765E 00	7.765E 00	3.462E-02	2.243E 02	4.711E 01
2	3.715E 03	1.275E 02	6.580E 02	3.631E 02	0.094E 00	7.765E 00	7.765E 00	3.282E-02	2.300E 02	4.727E 01
2	2.714E 03	1.255E 02	7.170E 02	4.335E 02	0.075E 00	7.765E 00	7.765E 00	2.605E-02	2.981E 02	4.703E 01
STA	L/D	DELTA E	L							
1	1.003E 01	2.610E 01	5.000E 00							
2	1.475E 01	2.611E 01	5.000E 00							
3	1.670E 01	2.611E 01	5.000E 00							

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.DPI-140 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 11		DATA POINT 11		DATA POINT 11		DATA POINT 11		DATA POINT 11		DATA POINT 11	
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TF	VS	DEL TF	VS
1	3.711E 03	1.198E 02	6.408E 02	3.419E 02	8.121E 00	7.774E 00	3.495E-02	2.224E 02	4.715E 01	2.224E 02	4.715E 01
2	3.711E 03	1.278E 02	6.270E 02	3.622E 02	8.113E 00	7.774E 00	3.312E-02	2.347E 02	4.731E 01	2.347E 02	4.731E 01
3	3.710E 03	1.355E 02	7.180E 02	4.341E 02	8.088E 00	7.774E 00	2.604E-02	2.986E 02	4.748E 01	2.986E 02	4.748E 01
STA	L/D	DELTA E	L								
1	1.083E 01	2.614E 01	5.000E 00								
2	1.476E 01	2.614E 01	5.000E 00								
3	1.870E 01	2.614E 01	5.000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.DPI-140 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 12		DATA POINT 12		DATA POINT 12		DATA POINT 12		DATA POINT 12		DATA POINT 12	
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TF	VS	DEL TF	VS
1	3.708E 03	1.104E 02	6.380E 02	3.407E 02	8.091E 00	7.787E 00	3.510E-02	2.213E 02	4.711E 01	2.213E 02	4.711E 01
2	3.708E 03	1.274E 02	6.560E 02	3.622E 02	8.083E 00	7.787E 00	3.316E-02	2.348E 02	4.727E 01	2.348E 02	4.727E 01
3	3.708E 03	1.354E 02	7.230E 02	4.411E 02	8.055E 00	7.787E 00	2.548E-02	3.057E 02	4.743E 01	3.057E 02	4.743E 01
STA	L/D	DELTA E	L								
1	1.083E 01	2.609E 01	5.000E 00								
2	1.476E 01	2.609E 01	5.000E 00								
3	1.870E 01	2.609E 01	5.000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.DPI-140 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 13		DATA POINT 13		DATA POINT 13		DATA POINT 13		DATA POINT 13		DATA POINT 13	
STA	PB	TB	TU	TI	Q/A	Q/AP	M	DEL TF	VS	DEL TF	VS
1	3.701E 03	1.180E 02	6.410E 02	3.455E 02	8.059E 00	7.758E 00	3.410E-02	2.275E 02	4.788E 01	2.275E 02	4.788E 01
2	3.701E 03	1.259E 02	6.570E 02	3.646E 02	8.051E 00	7.758E 00	3.250E-02	2.367E 02	4.804E 01	2.367E 02	4.804E 01
3	3.700E 03	1.338E 02	7.440E 02	4.666E 02	8.014E 00	7.758E 00	2.331E-02	3.328E 02	4.820E 01	3.328E 02	4.820E 01
STA	L/D	DELTA E	L								
1	1.083E 01	2.604E 01	5.000E 00								
2	1.476E 01	2.604E 01	5.000E 00								
3	1.870E 01	2.604E 01	5.000E 00								

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.DPI-100 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 14												
STA	PO	TR	TU	TV	YI	YU	YV	Q/A	Q/AP	M	DEL TP	VS
1	3.690E 03	1.170E 02	6.300E 02	3.412E 02	0.070E 00	7.753E 00	7.753E 00	3.072E-02	2.233E 02	4.017E 01		
2	3.690E 03	1.200E 02	6.810E 02	3.867E 02	0.072E 00	7.753E 00	7.753E 00	3.307E-02	2.302E 02	4.032E 01		
3	3.690E 03	1.317E 02	6.980E 02	4.123E 02	0.054E 00	7.753E 00	7.753E 00	2.783E-02	2.170E 02	4.049E 01		
STA	L/D	DELTA E										
1	1.000E 01	2.667E 01	5.000E 00									
2	1.476E 01	2.567E 01	5.000E 00									
3	1.070E 01	2.667E 01	5.000E 00									

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.DPI-100 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 15												
STA	PO	TR	TU	TV	YI	YU	YV	Q/A	Q/AP	M	DEL T	VS
1	3.690E 03	1.170E 02	6.410E 02	3.440E 02	0.077E 00	7.767E 00	7.767E 00	3.421E-02	2.272E 02	4.707E 01		
2	3.690E 03	1.207E 02	6.810E 02	3.866E 02	0.040E 00	7.767E 00	7.767E 00	3.197E-02	2.452E 02	4.702E 01		
3	3.690E 03	1.336E 02	7.020E 02	4.170E 02	0.052E 00	7.767E 00	7.767E 00	2.741E-02	2.034E 02	4.019E 01		
STA	L/D	DELTA E										
1	1.000E 01	2.667E 01	5.000E 00									
2	1.476E 01	2.667E 01	5.000E 00									
3	1.070E 01	2.667E 01	5.000E 00									

LOCAL TEST PARAMETERS

TEST 137A.5 MIN STEADY POWER.DPI-100 SEC.OTHER DATA AT 20 SEC INTERVALS

DATA POINT 16												
STA	PO	TR	TU	TV	YI	YU	YV	Q/A	Q/AP	M	DEL TP	VS
1	3.690E 03	1.177E 02	6.300E 02	3.309E 02	0.101E 00	7.790E 00	7.790E 00	3.650E-02	2.131E 02	4.770E 01		
2	3.690E 03	1.207E 02	6.800E 02	3.843E 02	0.060E 00	7.790E 00	7.790E 00	3.284E-02	2.207E 02	4.700E 01		
3	3.690E 03	1.336E 02	7.000E 02	4.130E 02	0.071E 00	7.790E 00	7.790E 00	2.779E-02	2.003E 02	4.003E 01		
STA	L/D	DELTA E										
1	1.000E 01	2.610E 01	5.000E 00									
2	1.476E 01	2.610E 01	5.000E 00									
3	1.070E 01	2.610E 01	5.000E 00									

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 1378.80 AT DF 11.DP1-120 SEC.DP11-318 SEC.CYMER DATA 20 SEC INTERVAL

AF = 0.273E-C3 O = 0.212E-01 L = 0.500E 01 DELTA TO = 0.700E 00

DATA POINTS

POINT	PB-IN	PB-OUT	TB-IN	TB-OUT	W	E2	I2	OP	MT BAL	C
1	3.709E 03	3.707E 03	1.011E 02	1.409E 02	1.135E 00	2.628E 01	1.116E 03	2.777E 01	-2.360E 00	4.150E 03
2	3.703E 03	3.701E 03	1.009E 02	1.413E 02	1.139E 00	2.628E 01	1.118E 03	2.783E 01	-4.073E 00	4.165E 03
3	3.697E 03	3.695E 03	1.009E 02	1.412E 02	1.139E 00	2.621E 01	1.114E 03	2.768E 01	-4.381E 00	4.165E 03
4	3.689E 03	3.687E 03	1.004E 02	1.406E 02	1.144E 00	2.619E 01	1.116E 03	2.771E 01	-4.454E 00	4.183E 03
5	3.685E 03	3.683E 03	1.002E 02	1.404E 02	1.144E 00	2.622E 01	1.112E 03	2.764E 01	-4.708E 00	4.183E 03
6	3.678E 03	3.676E 03	1.001E 02	1.407E 02	1.144E 00	2.627E 01	1.117E 03	2.782E 01	-5.090E 00	4.183E 03
7	3.675E 03	3.673E 03	1.002E 02	1.410E 02	1.143E 00	2.631E 01	1.116E 03	2.784E 01	-5.469E 00	4.179E 03
8	3.618E 03	3.716E 03	9.978E 01	1.403E 02	1.148E 00	2.630E 01	1.115E 03	2.780E 01	-5.525E 00	4.197E 03
9	3.696E 03	3.694E 03	5.946E 01	1.404E 02	1.146E 00	2.622E 01	1.112E 03	2.764E 01	-6.478E 00	4.196E 03
10	3.692E 03	3.690E 03	9.990E 01	1.411E 02	1.141E 00	2.628E 01	1.115E 03	2.778E 01	-6.549E 00	4.172E 03
11	3.712E 03	3.710E 03	5.880E 01	1.393E 02	1.141E 00	2.654E 01	1.125E 03	2.871E 01	-2.732E 00	4.172E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 1378.80 AT DP 11.0P1-120 SEC.DP11-318 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4		DATA POINT 5	
STA	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A
1	3.708E 03	1.230E 02	6.250E 02	3.210E 02	0.197E 00	7.091E 00	3.904E-02	1.900E 02	4.739E 01
2	3.708E 03	1.309E 02	6.420E 02	3.412E 02	0.180E 00	7.091E 00	3.708E-02	2.100E 02	4.758E 01
3	3.707E 03	1.309E 02	6.830E 02	3.903E 02	0.180E 00	7.091E 00	3.139E-02	2.510E 02	4.771E 01
STA	L/D	DELTA E	LE						
1	1.003E 01	2.628E 01	5.000E 00						
2	1.076E 01	2.628E 01	5.000E 00						
3	1.070E 01	2.628E 01	5.000E 00						

LOCAL TEST PARAMETERS

TEST 1378.80 AT DP 11.0P1-120 SEC.DP11-318 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 2		DATA POINT 3		DATA POINT 4		DATA POINT 5		DATA POINT 6	
STA	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A
1	3.702E 03	1.221E 02	6.300E 02	3.340E 02	0.197E 00	7.090E 00	3.707E-02	2.133E 02	4.756E 01
2	3.701E 03	1.312E 02	6.560E 02	3.900E 02	0.180E 00	7.090E 00	3.407E-02	2.260E 02	4.772E 01
3	3.701E 03	1.393E 02	6.890E 02	3.940E 02	0.174E 00	7.090E 00	3.081E-02	2.567E 02	4.780E 01
STA	L/D	DELTA E	LE						
1	1.003E 01	2.620E 01	5.000E 00						
2	1.076E 01	2.620E 01	5.000E 00						
3	1.070E 01	2.620E 01	5.000E 00						

LOCAL TEST PARAMETERS

TEST 1378.80 AT DP 11.0P1-120 SEC.DP11-318 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 3		DATA POINT 4		DATA POINT 5		DATA POINT 6		DATA POINT 7	
STA	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A	Q/A
1	3.696E 03	1.231E 02	6.340E 02	3.320E 02	0.160E 00	7.090E 00	3.708E-02	2.090E 02	4.756E 01
2	3.696E 03	1.311E 02	6.230E 02	3.657E 02	0.159E 00	7.090E 00	3.503E-02	2.243E 02	4.772E 01
3	3.695E 03	1.392E 02	6.870E 02	3.960E 02	0.144E 00	7.090E 00	3.043E-02	2.560E 02	4.780E 01
STA	L/D	DELTA E	LE						
1	1.003E 01	2.621E 01	5.000E 00						
2	1.076E 01	2.621E 01	5.000E 00						
3	1.070E 01	2.621E 01	5.000E 00						

LOCAL TEST PARAMETERS

TEST 1370.00 AT DP 11.0P1-120 SEC.DP11-310 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 4	
STA	1 3.600E 03
	2 3.607E 03
	3 3.607E 03
STA	L/D DELTA E
	1 1.003E 01
	2 1.070E 01
	3 1.070E 01
	TS
	1 1.220E 02
	2 1.300E 02
	3 1.300E 02
	TU
	1 6.300E 02
	2 6.370E 02
	3 6.090E 02
	TI
	1 3.773E 02
	2 3.709E 02
	3 3.900E 02
	G/A
	1 0.132E 00
	2 0.144E 00
	3 0.132E 00
	Q/AP
	1 7.073E 00
	2 7.073E 00
	3 7.073E 00
	M
	1 2.924E-02
	2 3.410E-02
	3 3.023E-02
	DEL TP
	1 2.693E 02
	2 2.300E 02
	3 2.603E 02
	VS
	1 4.770E 01
	2 4.700E 01
	3 4.800E 01

LOCAL TEST PARAMETERS

TEST 1370.00 AT DP 11.0P1-120 SEC.DP11-310 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 5	
STA	1 3.604E 03
	2 3.603E 03
	3 3.603E 03
STA	L/D DELTA E
	1 1.003E 01
	2 1.070E 01
	3 1.070E 01
	TU
	1 6.370E 02
	2 6.000E 02
	3 6.000E 02
	TI
	1 3.343E 02
	2 3.630E 02
	3 3.930E 02
	G/A
	1 0.172E 00
	2 0.101E 00
	3 0.150E 00
	Q/AP
	1 7.064E 00
	2 7.064E 00
	3 7.064E 00
	M
	1 3.671E-02
	2 3.305E-02
	3 3.810E-02
	DEL TP
	1 2.130E 02
	2 2.334E 02
	3 2.600E 02
	VS
	1 4.770E 01
	2 4.792E 01
	3 4.800E 01

LOCAL TEST PARAMETERS

TEST 1370.00 AT DP 11.0P1-120 SEC.DP11-310 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 6	
STA	1 3.677E 03
	2 3.676E 03
	3 3.676E 03
STA	L/D DELTA E
	1 1.003E 01
	2 1.070E 01
	3 1.070E 01
	TU
	1 6.400E 02
	2 6.030E 02
	3 6.000E 02
	TI
	1 3.304E 02
	2 3.601E 02
	3 3.901E 02
	G/A
	1 0.202E 00
	2 0.191E 00
	3 0.181E 00
	Q/AP
	1 7.904E 00
	2 7.904E 00
	3 7.904E 00
	M
	1 3.657E-02
	2 3.354E-02
	3 3.007E-02
	DEL TP
	1 2.162E 02
	2 2.356E 02
	3 2.594E 02
	VS
	1 4.770E 01
	2 4.792E 01
	3 4.800E 01

LOCAL TEST PARAMETERS

TEST 1370.00 AT DP 11.0P1-120 SEC.DP11-310 SEC.OTHER DATA 20 SEC INTERVAL

DATA POINT 7	
STA	1 3.674E 03
	2 3.674E 03
	3 3.673E 03
STA	L/D DELTA E
	1 1.003E 01
	2 1.070E 01
	3 1.070E 01
	TU
	1 6.410E 02
	2 6.050E 02
	3 6.030E 02
	TI
	1 3.300E 02
	2 3.675E 02
	3 4.007E 02
	G/A
	1 0.227E 00
	2 0.215E 00
	3 0.205E 00
	Q/AP
	1 7.900E 00
	2 7.900E 00
	3 7.900E 00
	M
	1 3.659E-02
	2 3.391E-02
	3 3.022E-02
	DEL TP
	1 2.162E 02
	2 2.367E 02
	3 2.617E 02
	VS
	1 4.770E 01
	2 4.780E 01
	3 4.805E 01

LOCAL TEST PARAMETERS
 TEST 1378.80 AT DP 11.0P1-120 SEC.OTHER DATA 20 SEC INTERVAL

LOCAL TEST PARAMETERS		DATA POINT 8									
STA	PB	TB	TH	TI	C/A	Q/AP	M	DEL TP	VS		
1	3.672E 03	1.220E 02	6.500E 02	3.490E 02	8.210E 00	7.890E 00	3.400E-02	2.270E 02	4.760E 01		
2	3.692E 03	1.301E 02	6.640E 02	3.660E 02	8.200E 00	7.890E 00	3.301E-02	2.364E 02	4.800E 01		
3	3.711E 03	1.383E 02	6.890E 02	3.962E 02	8.190E 00	7.890E 00	3.003E-02	2.579E 02	4.820E 01		
STA	L/D	DELTA E	LE								
1	1.083E 01	2.630E 01	5.800E 00								
2	1.476E 01	2.620E 01	5.000E 00								
3	1.870E 01	2.620E 01	5.000E 00								

LOCAL TEST PARAMETERS
 TEST 1378.80 AT DP 11.0P1-120 SEC.OTHER DATA 20 SEC INTERVAL

LOCAL TEST PARAMETERS		DATA POINT 9									
STA	PB	TB	TH	TI	C/A	Q/AP	M	DEL TP	VS		
1	3.692E 03	1.250E 02	6.400E 02	3.494E 02	8.167E 00	7.894E 00	3.454E-02	2.270E 02	4.700E 01		
2	3.694E 03	1.302E 02	6.640E 02	3.600E 02	8.150E 00	7.894E 00	3.290E-02	2.303E 02	4.800E 01		
3	3.694E 03	1.384E 02	6.890E 02	3.993E 02	8.150E 00	7.894E 00	3.010E-02	2.600E 02	4.810E 01		
STA	L/D	DELTA E	LE								
1	1.083E 01	2.622E 01	5.000E 00								
2	1.476E 01	2.622E 01	5.000E 00								
3	1.870E 01	2.622E 01	5.000E 00								

LOCAL TEST PARAMETERS
 TEST 1378.80 AT DP 11.0P1-120 SEC.OTHER DATA 20 SEC INTERVAL

LOCAL TEST PARAMETERS		DATA POINT 10									
STA	PB	TB	TH	TI	C/A	Q/AP	M	DEL TP	VS		
1	3.691E 03	1.220E 02	6.500E 02	3.503E 02	8.204E 00	7.893E 00	3.400E-02	2.270E 02	4.760E 01		
2	3.690E 03	1.300E 02	6.600E 02	3.719E 02	8.190E 00	7.893E 00	3.270E-02	2.310E 02	4.700E 01		
3	3.690E 02	1.390E 02	6.920E 02	4.002E 02	8.187E 00	7.893E 00	3.022E-02	2.612E 02	4.797E 01		
STA	L/D	DELTA E	LE								
1	1.083E 01	2.620E 01	5.000E 00								
2	1.476E 01	2.620E 01	5.000E 00								
3	1.870E 01	2.620E 01	5.000E 00								

LOCAL TEST PARAMETERS
 TEST 1378.80 AT DP 11.0P1-120 SEC.OTHER DATA 20 SEC INTERVAL

LOCAL TEST PARAMETERS		DATA POINT 11									
STA	PB	TB	TH	TI	C/A	Q/AP	M	DEL TP	VS		
1	3.711E 03	1.211E 02	6.400E 02	3.414E 02	8.367E 00	8.043E 00	3.680E-02	2.290E 02	4.700E 01		
2	3.711E 03	1.290E 02	6.600E 02	3.684E 02	8.350E 00	8.043E 00	3.400E-02	2.303E 02	4.777E 01		
3	3.710E 03	1.372E 02	6.940E 02	3.963E 02	8.347E 00	8.043E 00	3.100E-02	2.590E 02	4.700E 01		
STA	L/D	DELTA E	LE								
1	1.083E 01	2.624E 01	5.000E 00								
2	1.476E 01	2.624E 01	5.000E 00								
3	1.870E 01	2.624E 01	5.000E 00								

LIGUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 136.00 AT 0P9(295 SEC) DPI-136 SEC. OTHER DATA AT 20 SEC INTERVALS

AF = C.130E-03 D = 0.132E-01 L = 0.500E 01 DELTA TO = 0.100E 01

DATA POINTS

POINT	PG-IN	PG-OUT	TB-IN	TB-OUT	W	G2	I2	OP	WT GMA.	C
1	3.644E 03	3.557E 03	5.910E 01	1.532E 02	1.174E 00	3.715E 01	1.137E 03	4.004E 01	5.347E-01	0.530E 03
2	3.639E 03	3.549E 03	9.070E 01	1.525E 02	1.182E 00	3.693E 01	1.129E 03	3.942E 01	-0.023E-01	0.570E 03
3	3.636E 03	3.546E 03	5.064E 01	1.527E 02	1.178E 00	3.679E 01	1.132E 03	3.900E 01	-1.702E-01	0.540E 03
4	3.634E 03	3.542E 03	9.069E 01	1.531E 02	1.182E 00	3.696E 01	1.130E 03	3.900E 01	-0.290E-01	0.570E 03
5	3.624E 03	3.534E 03	5.020E 01	1.527E 02	1.164E 00	3.697E 01	1.131E 03	3.900E 01	-1.402E 00	0.567E 03
6	3.623E 03	3.533E 03	9.790E 01	1.529E 02	1.193E 00	3.704E 01	1.130E 03	3.972E 01	-2.100E 00	0.607E 03
7	3.624E 03	3.532E 03	5.790E 01	1.531E 02	1.182E 00	3.709E 01	1.132E 03	3.972E 01	-3.072E 00	0.630E 03
8	3.623E 03	3.531E 03	9.790E 01	1.540E 02	1.192E 00	3.706E 01	1.132E 03	3.972E 01	-4.040E 00	0.570E 03
9	3.622E 03	3.527E 03	5.770E 01	1.544E 02	1.180E 00	3.709E 01	1.132E 03	3.900E 01	-5.300E 00	0.590E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST 136.00 AT 0P9(295 SEC) DPI-136 SEC. OTHER DATA AT 20 SEC INTERVALS

DATA POINT 1

STA	PB	TB	TW	G/A	G/AP	H	DEL TP	VS
1	2.579E 03	1.359E 02	5.740E 02	1.601E 01	1.603E 01	5.553E-02	2.693E 02	9.799E 01
2	3.561E 03	1.500E 02	5.510E 02	1.600E 01	1.603E 01	8.707E-02	2.809E 02	9.800E 01

STA	L/D	DELTA E	LE
1	2.350E 01	3.715E 01	5.000E 00
2	2.587E 01	3.715E 01	5.000E 00

TEST 138.00 AT DP9(295 SEC), DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

LOCAL TEST PARAMETERS

DATA POINT 2									
STA	PB	TE	TW	TI	Q/A	Q/AP	H	DEL TF	VS
1	3-572E 03	1-390E 02	5-600E 02	4-090E 02	1-653E 01	1-570E 01	5-829E-02	2-707E 02	9-863E 01
2	3-553E 03	1-490E 02	9-820E 02	4-309E 02	1-652E 01	1-570E 01	5-515E-02	2-810E 02	9-900E 01
STA	L/D	DELTA E	LE						
1	2-350E 01	3-623E 01	5-000E 00						
2	2-507E 01	3-683E 01	5-000E 00						

TEST 138.00 AT DP9(295 SEC), DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

LOCAL TEST PARAMETERS

DATA POINT 3									
STA	PB	TE	TW	TI	Q/A	Q/AP	H	DEL TF	VS
1	3-560E 03	1-392E 02	5-600E 02	4-079E 02	1-665E 01	1-500E 01	5-909E-02	2-687E 02	9-830E 01
2	3-551E 02	1-500E 02	9-860E 02	4-316E 02	1-663E 01	1-500E 01	5-637E-02	2-817E 02	9-875E 01
STA	L/D	DELTA E	LE						
1	2-350E 01	3-650E 01	5-000E 00						
2	2-507E 01	3-650E 01	5-000E 00						

TEST 138.00 AT DP9(295 SEC), DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

LOCAL TEST PARAMETERS

DATA POINT 4									
STA	PB	TE	TW	TI	Q/A	Q/AP	H	DEL TF	VS
1	3-565E 03	1-395E 02	5-710E 02	4-110E 02	1-665E 01	1-593E 01	5-850E-02	2-724E 02	9-804E 01
2	3-547E 03	1-500E 02	9-870E 02	4-330E 02	1-663E 01	1-593E 01	5-630E-02	2-800E 02	9-910E 01
STA	L/D	DELTA E	LE						
1	2-350E 01	3-650E 01	5-000E 00						
2	2-907E 01	3-694E 01	5-000E 00						

TEST 138.00 AT DP9(295 SEC), DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

LOCAL TEST PARAMETERS

DATA POINT 5									
STA	PB	TE	TW	TI	Q/A	Q/AP	H	DEL TF	VS
1	3-807E 03	1-391E 02	9-720E 02	4-120E 02	1-660E 01	1-507E 01	5-797E-02	2-737E 02	9-890E 01
2	3-830E 03	1-500E 02	9-910E 02	4-370E 02	1-660E 01	1-507E 01	5-811E-02	2-870E 02	9-900E 01
STA	L/D	DELTA E	LE						
1	2-350E 01	3-650E 01	5-000E 00						
2	2-907E 01	3-694E 01	5-000E 00						

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 130.00 AT OPS(295 SEC).DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 5									
STA	PS	TS	TU	TV	Q/A	Q/AP	M	DEL TP	VS		
1	3-554E 03	1-390E 02	9-000E 02	9-210E 02	1-671E 01	1-990E 01	9-000E-02	2-300E 02	9-000E 01		
2	3-537E 03	1-490E 02	9-000E 02	3-133E 02	1-670E 01	1-990E 01	9-730E-02	1-630E 02	10-000E 01		
L/D		DELTA E									
1	2-390E 01	3-700E 01	5-000E 00								
2	2-907E 01	3-700E 01	5-000E 00								

LOCAL TEST PARAMETERS

TEST 130.00 AT OPS(295 SEC).DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 7									
STA	PS	TS	TU	TV	Q/A	Q/AP	M	DEL TP	VS		
1	3-554E 03	1-390E 02	9-530E 02	9-370E 02	1-671E 01	1-990E 01	9-237E-02	2-900E 02	9-000E 01		
2	3-537E 03	1-500E 02	9-570E 02	3-900E 02	1-670E 01	1-990E 01	6-000E-02	2-390E 02	9-000E 01		
L/D		DELTA E									
1	2-390E 01	3-700E 01	5-000E 00								
2	2-907E 01	3-700E 01	5-000E 00								

LOCAL TEST PARAMETERS

TEST 130.00 AT OPS(295 SEC).DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 8									
STA	PS	TS	TU	TV	Q/A	Q/AP	M	DEL TP	VS		
1	3-554E 03	1-400E 02	9-030E 02	9-370E 02	1-670E 01	1-990E 01	5-360E-02	2-570E 02	9-000E 01		
2	3-536E 03	1-510E 02	9-400E 02	3-750E 02	1-670E 01	1-990E 01	7-110E-02	2-230E 02	9-010E 01		
L/D		DELTA E									
1	2-390E 01	3-700E 01	5-000E 00								
2	2-907E 01	3-700E 01	5-000E 00								

LOCAL TEST PARAMETERS

TEST 130.00 AT OPS(295 SEC).DPI-135 SEC. OTHER DATA AT 20 SEC INTERVALS

		DATA POINT 9									
STA	PS	TS	TU	TV	Q/A	Q/AP	M	DEL TP	VS		
1	3-551E 03	1-400E 02	1-000E 03	9-500E 02	1-670E 01	1-990E 01	5-130E-02	3-100E 02	9-000E 01		
2	3-532E 03	1-510E 02	9-070E 02	9-020E 02	1-670E 01	1-990E 01	6-300E-02	2-500E 02	9-030E 01		
L/D		DELTA E									
1	2-390E 01	3-700E 01	5-000E 00								
2	2-907E 01	3-700E 01	5-000E 00								

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 139 STAINLESS STEEL BURNDOUT DATA POINT 3 IS BURNDOUT

AF # 0.129E-03 D = 0.128E-01 L = 0.450E 01 DELTA TO = 0.110E 01

DATA POINTS

POINT	PB-IN	PB-OUT	TB-IN	TB-OUT	M	E2	I2	OP	MT BAL	S
1	9.120E 02	8.690E 02	9.410E 01	9.900E 01	1.100E 00	7.680E 00	4.693E 02	3.417E 00	-1.331E 00	9.120E 03
2	9.950E 02	8.500E 02	9.335E 01	1.342E 02	1.184E 00	2.520E 01	1.240E 03	2.901E 01	-1.179E 00	9.172E 03
3	9.000E 02	8.600E 02	9.270E 01	1.479E 02	1.184E 00	3.014E 00	1.415E 03	4.043E 01	-1.495E 00	9.157E 03

TEST SECTION - LOCAL TEST PARAMETERS

TEST 139 STAINLESS STEEL BURNDOUT DATA POINT 3 IS BURNDOUT

DATA POINT 1

STA	PB	TB	TI	Q/A	M	DEL TF	VS
1	8.600E 02	9.822E 01	1.240E 02	1.650E 00	1.569E 00	2.640E 01	1.031E 02
2	8.714E 02	9.940E 01	1.228E 02	1.650E 00	1.569E 00	2.320E 01	1.032E 02

STA L/D DELTA E LE

1	2.111E 01	7.680E 00	4.500E 00
2	2.760E 01	7.680E 00	4.500E 00

DATA POINT 2

STA	PB	TB	TI	Q/A	M	DEL TF	VS
1	8.653E 02	1.229E 02	3.360E 02	1.421E 01	1.369E 01	2.151E 02	1.047E 02
2	8.531E 02	1.219E 02	3.352E 02	1.422E 01	1.369E 01	2.033E 02	1.051E 02

STA L/D DELTA E LE

1	2.111E 01	2.520E 01	4.500E 00
2	2.760E 01	2.520E 01	4.500E 00

DATA POINT 3

STA	PB	TB	TI	Q/A	M	DEL TF	VS
1	8.711E 02	1.326E 02	3.075E 02	1.919E 01	1.057E 01	2.550E 02	1.050E 02
2	8.622E 02	1.440E 02	3.061E 02	1.919E 01	1.057E 01	2.412E 02	1.055E 02

STA L/D DELTA E LE

1	2.111E 01	3.014E 01	4.500E 00
2	2.760E 01	3.014E 01	4.500E 00

Report AFRPL-TR-66-263, Appendix B

DIMENSIONLESS PARAMETERS

TEST 139 STAINLESS STEEL BURNDOUT DATA POINT 3 IS BURNDOUT

DATA POINT	STA	NU	PR	RE	T1/TB	NU/PR(.4)
1	1	1.1181E 03	9.1902E 00	1.8277E 05	1.0078E 00	6.2812E 02
1	2	1.2744E 03	4.1434E 00	1.0051E 05	1.0010E 00	7.2167E 02
2	1	1.1619E 03	3.6127E 00	2.1829E 05	1.3491E 00	7.1000E 02
2	2	1.2128E 03	3.1611E 00	2.3142E 05	1.3434E 00	7.6340E 02
3	1	1.3148E 03	3.1648E 00	2.3192E 05	1.0303E 00	8.2510E 02
3	2	1.2807E 03	2.4099E 00	2.4050E 05	1.3798E 00	8.8761E 02

DATA POINT	STA	NUO RATIO	K RATIO	NU RATIO	CP RATIO
1	1	1.0111E 00	9.6042E-01	1.2048E 00	1.0035E 00
1	2	1.0099E 00	9.6335E-01	1.1764E 00	1.0032E 00
2	1	1.1013E 00	8.0054E-01	2.6773E 00	1.0012E 00
2	2	1.0950E 00	8.7235E-01	2.4090E 00	9.9941E-01
3	1	1.1231E 00	8.7446E-01	2.9949E 00	1.0057E 00
3	2	1.1165E 00	8.8977E-01	2.7800E 00	1.0036E 00

DATA POINT	STA	NUM(F)	PR(F)	RE(F)	T1/TF	NU/PR(.4)
1	1	1.0917E 03	3.7446E 00	1.9967E 05	1.0233E 00	6.4366E 02
1	2	1.2520E 03	3.7599E 00	1.9922E 05	1.0204E 00	7.3711E 02
2	1	1.0327E 03	1.7846E 00	3.6712E 05	1.1558E 00	8.2673E 02
2	2	1.0910E 03	1.7295E 00	3.7205E 05	1.1466E 00	8.7620E 02
3	1	1.1649E 03	1.5446E 00	4.0854E 05	1.1771E 00	9.7898E 02
3	2	1.2286E 03	1.5112E 00	4.1021E 05	1.1663E 00	1.0010E 03

Report AFRPL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST: 140.9.5MIN STEADY POWER: PPI-1.03SEC: OP11-712SEC: 1 MIN DATA INTERVAL

MP = 0.189E-03 D = 0.125E-01 L = 0.400E 01 DELTA TD = 0.190E 01

DATA POINTS

POINT	PG-IN	PG-OUT	TD-IN	TD-OUT	V	EZ	I2	CP	WT BAL	S
1	9.290E 02	0.400E 02	0.900E 01	1.200E 02	1.020E 00	2.507E 01	1.200E 03	2.901E 01	-4.091E-01	9.280E 03
2	9.250E 02	0.390E 02	0.900E 01	1.200E 02	1.190E 00	2.500E 01	1.200E 03	2.900E 01	-7.079E-01	9.280E 03
3	9.230E 02	0.390E 02	0.910E 01	1.200E 02	1.197E 00	2.500E 01	1.201E 03	2.901E 01	-9.570E-01	9.230E 03
4	9.170E 02	0.310E 02	0.800E 01	1.270E 02	1.194E 00	2.500E 01	1.201E 03	2.901E 01	-1.000E 00	9.230E 03
5	9.120E 02	0.400E 02	0.800E 01	1.270E 02	1.192E 00	2.500E 01	1.201E 03	2.901E 01	-1.300E 00	9.227E 03
6	9.230E 02	0.400E 02	0.770E 01	1.200E 02	1.197E 00	2.501E 01	1.202E 03	2.902E 01	-1.300E 00	9.230E 03
7	9.100E 02	0.300E 02	0.700E 01	1.200E 02	1.190E 00	2.500E 01	1.202E 03	2.902E 01	-1.300E 00	9.230E 03
8	9.100E 02	0.400E 02	0.600E 01	1.270E 02	1.192E 00	2.500E 01	1.202E 03	2.902E 01	-1.500E 00	9.227E 03
9	9.100E 02	0.400E 02	0.670E 01	1.270E 02	1.180E 00	2.490E 01	1.202E 03	2.902E 01	-1.303E 00	9.180E 03
10	9.000E 02	0.390E 02	0.610E 01	1.270E 02	1.187E 00	2.501E 01	1.201E 03	2.902E 01	-1.307E 00	9.180E 03
11	9.000E 02	0.300E 02	0.600E 01	1.200E 02	1.180E 00	2.503E 01	1.202E 03	2.903E 01	-3.000E-01	9.157E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST140.9.5MIN STEADY POWER.DP1-143SEC.DP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4			
STA	PG	TB	TU	TI	Q/A	Q/AP	H	DEL TP	VS
1	0.792E 02	1.192E 02	7.880E 02	3.400E 02	1.399E 01	1.360E 01	6.138E-02	2.217E 02	1.069E 02
2	0.630E 02	1.282E 02	7.960E 02	3.861E 02	1.392E 01	1.360E 01	5.969E-02	2.278E 02	1.063E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.507E 01	4.500E 00						
2	2.760E 01	2.507E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST140.9.5MIN STEADY POWER.DP1-143SEC.DP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 2		DATA POINT 3		DATA POINT 4					
STA	PG	TB	TU	TI	Q/A	Q/AP	H	DEL TP	VS
1	0.773E 02	1.193E 02	7.880E 02	3.371E 02	1.399E 01	1.360E 01	6.238E-02	2.170E 02	1.054E 02
2	0.627E 02	1.283E 02	7.900E 02	3.082E 02	1.394E 01	1.360E 01	6.178E-02	2.199E 02	1.060E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.506E 01	4.500E 00						
2	2.760E 01	2.506E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST140.9.5MIN STEADY POWER.DP1-143SEC.DP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 3		DATA POINT 4							
STA	PG	TB	TU	TI	Q/A	Q/AP	H	DEL TP	VS
1	0.739E 02	1.185E 02	7.880E 02	3.328E 02	1.392E 01	1.351E 01	6.111E-02	2.210E 02	1.059E 02
2	0.580E 02	1.275E 02	7.940E 02	3.541E 02	1.386E 01	1.351E 01	5.910E-02	2.292E 02	1.059E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.500E 01	4.500E 00						
2	2.760E 01	2.500E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST140.9.5MIN STEADY POWER.DP1-143SEC.DP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 4		DATA POINT 5							
STA	PG	TB	TU	TI	Q/A	Q/AP	H	DEL TP	VS
1	0.693E 02	1.182E 02	7.940E 02	3.423E 02	1.391E 01	1.351E 01	6.024E-02	2.241E 02	1.062E 02
2	0.547E 02	1.272E 02	7.980E 02	3.574E 02	1.384E 01	1.351E 01	5.857E-02	2.302E 02	1.056E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.500E 01	4.500E 00						
2	2.760E 01	2.500E 01	4.500E 00						

LOCAL TEST PARAMETERS
 TEST140.9.5MIN STEADY POWER-OP1-143SEC-OP11-713SEC.1 MIN DATA INTERVAL

STA	PG	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS
1	0.650E 02	1.179E 02	7.880E 02	3.437E 02	1.390E 01	1.381E 01	5.903E-02	2.257E 02	1.051E 02
2	0.516E 02	1.270E 02	7.960E 02	3.500E 02	1.304E 01	1.361E 01	5.837E-02	2.310E 02	1.050E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.500E 01	4.500E 00						
2	2.760E 01	2.500E 01	4.500E 00						

LOCAL TEST PARAMETERS
 TEST140.9.5MIN STEADY POWER-OP1-143SEC-OP11-713SEC.1 MIN DATA INTERVAL

STA	PG	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS
1	0.743E 02	1.172E 02	7.840E 02	3.419E 02	1.392E 01	1.352E 01	6.020E-02	2.204E 02	1.050E 02
2	0.597E 02	1.263E 02	7.900E 02	3.571E 02	1.308E 01	1.382E 01	5.801E-02	2.307E 02	1.059E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.501E 01	4.500E 00						
2	2.760E 01	2.501E 01	4.500E 00						

LOCAL TEST PARAMETERS
 TEST140.9.5MIN STEADY POWER-OP1-143SEC-OP11-713SEC.1 MIN DATA INTERVAL

STA	PG	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS
1	0.690E 02	1.171E 02	7.880E 02	3.450E 02	1.394E 01	1.307E 01	5.931E-02	2.257E 02	1.050E 02
2	0.584E 02	1.262E 02	7.980E 02	3.590E 02	1.306E 01	1.387E 01	5.812E-02	2.304E 02	1.050E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.502E 01	4.500E 00						
2	2.760E 01	2.502E 01	4.500E 00						

LOCAL TEST PARAMETERS
 TEST140.9.5MIN STEADY POWER-OP1-143SEC-OP11-713SEC.1 MIN DATA INTERVAL

STA	PG	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS
1	0.671E 02	1.160E 02	7.800E 02	3.450E 02	1.390E 01	1.300E 01	5.900E-02	2.200E 02	1.050E 02
2	0.536E 02	1.250E 02	7.900E 02	3.500E 02	1.304E 01	1.300E 01	5.787E-02	2.300E 02	1.050E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.500E 01	4.500E 00						
2	2.760E 01	2.500E 01	4.500E 00						

LOCAL TEST PARAMETERS
 TEST140.9.8MIN STEADY POWER.OP1-143SEC.OP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 9

STA	PS	TB	TU	TI	G/A	G/AP	H	DEL TP	VS
1	8.621E 02	1.164E 02	7.896E 02	3.446E 02	1.300E 01	1.347E 01	5.900E-02	2.204E 02	1.044E 02
2	8.404E 02	1.256E 02	7.966E 02	3.596E 02	1.301E 01	1.347E 01	5.778E-02	2.341E 02	1.044E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.506E 01	4.506E 00						
2	2.760E 01	2.498E 01	4.506E 00						

LOCAL TEST PARAMETERS
 TEST140.9.8MIN STEADY POWER.OP1-143SEC.OP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 10

STA	PS	TB	TU	TI	G/A	G/AP	H	DEL TP	VS
1	8.576E 02	1.179E 02	7.896E 02	3.474E 02	1.300E 01	1.301E 01	5.900E-02	2.250E 02	1.044E 02
2	8.427E 02	1.276E 02	7.996E 02	3.628E 02	1.303E 01	1.301E 01	5.737E-02	2.300E 02	1.044E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.501E 01	4.506E 00						
2	2.760E 01	2.501E 01	4.506E 00						

LOCAL TEST PARAMETERS
 TEST140.9.8MIN STEADY POWER.OP1-143SEC.OP11-713SEC.1 MIN DATA INTERVAL

DATA POINT 11

STA	PS	TB	TU	TI	G/A	G/AP	H	DEL TP	VS
1	8.574E 02	1.186E 02	7.896E 02	3.466E 02	1.291E 01	1.304E 01	5.900E-02	2.250E 02	1.044E 02
2	8.419E 02	1.277E 02	7.996E 02	3.604E 02	1.306E 01	1.304E 01	5.821E-02	2.327E 02	1.044E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.503E 01	4.506E 00						
2	2.760E 01	2.503E 01	4.506E 00						

LIGUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST141.9MIN STEADY POWER.DPJ-2-08SEC.DP9-10-75SEC.OTHER INTERVALS 1 MIN

AF = 0.129E-03 D = 0.129E-01 L = 0.450E 01 DELTA TO = 0.220E 01

DATA POINTS

POINT	PB-IN	PB-OUT	TR-IN	TR-OUT	M	EZ	I2	OP	MT BAL	G
1	9.100E 02	0.460E 02	9.390E 01	1.439E 02	1.187E 00	2.050E 01	1.364E 03	3.687E 01	1.394E 00	9.180E 03
2	9.090E 02	0.440E 02	9.490E 01	1.447E 02	1.189E 00	2.050E 01	1.340E 03	3.680E 01	-1.539E-01	9.194E 03
3	9.050E 02	0.400E 02	9.400E 01	1.450E 02	1.186E 00	2.060E 01	1.166E 03	3.704E 01	-9.701E-02	9.172E 03
4	9.110E 02	0.810E 02	9.340E 01	1.440E 02	1.192E 00	2.060E 01	1.364E 03	3.680E 01	-2.610E-01	9.219E 03
5	9.070E 02	0.470E 02	9.300E 01	1.432E 02	1.192E 00	2.040E 01	1.343E 03	3.670E 01	-0.802E-01	9.219E 03
6	9.030E 02	0.430E 02	9.260E 01	1.432E 02	1.188E 00	2.040E 01	1.367E 03	3.667E 01	-0.003E-01	9.180E 03
7	9.000E 02	0.400E 02	9.220E 01	1.428E 02	1.184E 00	2.040E 01	1.360E 03	3.662E 01	-3.791E-01	9.172E 03
8	8.960E 02	0.360E 02	9.180E 01	1.428E 02	1.184E 00	2.050E 01	1.363E 03	3.663E 01	-0.500E-01	9.137E 03
9	8.930E 02	0.330E 02	9.160E 01	1.428E 02	1.181E 00	2.050E 01	1.361E 03	3.677E 01	-7.599E-01	9.139E 03
10	8.950E 02	0.300E 02	9.170E 01	1.427E 02	1.184E 00	2.040E 01	1.361E 03	3.671E 01	-0.390E-01	9.126E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST1101.9MIN STEADY POWER.DPI-2-45SEC.DPD-10-75SEC.OTHER INTERVALS 1 MIN

DATA POINT 1

STA	PS	TB	TU	TI	Q/A	Q/MP	M	DEL TP	VS
1	0.630E 02	1.300E 02	9.300E 02	4.030E 02	1.720E 01	1.070E 01	0.103E-02	2.737E 02	1.000E 02
2	0.490E 02	1.411E 02	9.450E 02	4.251E 02	1.719E 01	1.072E 01	5.900E-02	2.640E 02	1.000E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.850E 01	4.500E 00						
2	2.760E 01	2.850E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST1101.9MIN STEADY POWER.DPI-2-45SEC.DPD-10-75SEC.OTHER INTERVALS 1 MIN

DATA POINT 2

STA	PS	TB	TU	TI	Q/A	Q/MP	M	DEL TP	VS
1	0.621E 02	1.360E 02	9.330E 02	4.080E 02	1.727E 01	1.070E 01	0.103E-02	2.774E 02	1.000E 02
2	0.476E 02	1.419E 02	9.460E 02	4.260E 02	1.710E 01	1.074E 01	5.900E-02	2.640E 02	1.000E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.850E 01	4.500E 00						
2	2.760E 01	2.850E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST1101.9MIN STEADY POWER.DPI-2-45SEC.DPD-10-75SEC.OTHER INTERVALS 1 MIN

DATA POINT 3

STA	PS	TB	TU	TI	Q/A	Q/MP	M	DEL TP	VS
1	0.591E 02	1.360E 02	9.370E 02	4.090E 02	1.737E 01	1.070E 01	0.103E-02	2.707E 02	1.000E 02
2	0.436E 02	1.422E 02	9.500E 02	4.280E 02	1.729E 01	1.070E 01	5.900E-02	2.600E 02	1.000E 02
STA	L/D	DELTA E	LE						
1	2.111E 01	2.860E 01	4.500E 00						
2	2.760E 01	2.860E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST1101.9MIN STEADY POWER.DPI-2-45SEC.DPD-10-75SEC.OTHER INTERVALS 1 MIN

DATA POINT 4

STA	PS	TB	TU	TI	Q/A	Q/MP	M	DEL TP	VS
1	0.677E 02	1.290E 02	9.340E 02	4.090E 02	1.720E 01	1.070E 01	0.098E-02	2.790E 02	1.000E 02
2	0.543E 02	1.412E 02	9.470E 02	4.270E 02	1.710E 01	1.070E 01	5.900E-02	2.607E 02	1.000E 02
STA	L/D	DELTA E	L						
1	2.111E 01	2.850E 01	4.500E 00						
2	2.760E 01	2.850E 01	4.500E 00						

LOCAL TEST PARAMETERS

TEST141.9MIN STEADY POWER.DP1-2-4SSEC.DP9-10-7SSEC.OTHER INTERVALS 1 MIN

		DATA POINT 5										
STA		PB	L/D	TB	DELTA E	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1		0.537E 02		1.295E 02		9.310E 02	4.090E 02	1.710E 01	1.600E 01	6.022E-02	2.790E 02	1.050E 02
2		0.503E 02		1.400E 02		9.440E 02	4.270E 02	1.707E 01	1.600E 01	5.071E-02	2.370E 02	1.051E 02
STA		L/D		DELTA E		LE						
1		2.111E 01		2.040E 01		4.500E 00						
2		2.700E 01		2.040E 01		4.500E 00						

LOCAL TEST PARAMETERS

TEST141.9MIN STEADY POWER.DP1-2-4SSEC.DP9-10-7SSEC.OTHER INTERVALS 1 MIN

		DATA POINT 6										
STA		PB	L/D	TB	DELTA E	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1		0.597E 02		1.291E 02		9.270E 02	4.037E 02	1.710E 01	1.600E 01	6.133E-02	2.740E 02	1.052E 02
2		0.403E 02		1.404E 02		9.400E 02	4.222E 02	1.710E 01	1.600E 01	5.970E-02	2.810E 02	1.057E 02
STA		L/D		DELTA E		LE						
1		2.111E 01		2.040E 01		4.500E 00						
2		2.700E 01		2.040E 01		4.500E 00						

LOCAL TEST PARAMETERS

TEST141.9MIN STEADY POWER.DP1-2-4SSEC.DP9-10-7SSEC.OTHER INTERVALS 1 MIN

		DATA POINT 7										
STA		PB	L/D	TB	DELTA E	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1		0.547E 02		1.287E 02		9.300E 02	4.030E 02	1.710E 01	1.600E 01	6.022E-02	2.792E 02	1.050E 02
2		0.433E 02		1.400E 02		9.430E 02	4.264E 02	1.700E 01	1.600E 01	5.071E-02	2.804E 02	1.050E 02
STA		L/D		DELTA E		LE						
1		2.111E 01		2.040E 01		4.500E 00						
2		2.700E 01		2.040E 01		4.500E 00						

LOCAL TEST PARAMETERS

TEST141.9MIN STEADY POWER.DP1-2-4SSEC.DP9-10-7SSEC.OTHER INTERVALS 1 MIN

		DATA POINT 8										
STA		PB	L/D	TB	DELTA E	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1		0.527E 02		1.280E 02		9.260E 02	3.980E 02	1.732E 01	1.600E 01	6.277E-02	2.694E 02	1.040E 02
2		0.303E 02		1.400E 02		9.420E 02	4.200E 02	1.721E 01	1.600E 01	6.021E-02	2.600E 02	1.032E 02
STA		L/D		DELTA E		LE						
1		2.111E 01		2.050E 01		4.500E 00						
2		2.700E 01		2.050E 01		4.500E 00						

LOCAL TEST PARAMETERS

TEST141.0MIN STEADY POWER.BPI-2-0000C.BPP-10-7500C.OTHER INTERVALS 1 MIN

STA	FB	TS	TU	VI	Q/A	Q/MP	M	DEL TP	VS
1	0.407E 02	1.200E 02	0.200E 02	0.02E 02	1.730E 01	1.000E 01	0.100E-02	2.730E 02	1.000E 02
2	0.303E 02	1.400E 02	0.300E 02	0.100E 02	1.730E 01	1.000E 01	0.130E-02	2.730E 02	1.000E 02
STA	L/D	DELTA E	LE						
1	2.110E 01	2.000E 01	0.000E 00						
2	2.700E 01	2.000E 01	0.000E 00						

LOCAL TEST PARAMETERS

TEST141.0MIN STEADY POWER.BPI-2-0000C.BPP-10-7500C.OTHER INTERVALS 1 MIN

STA	FB	TS	TU	VI	Q/A	Q/MP	M	DEL TP	VS
1	0.401E 02	1.200E 02	0.200E 02	3.000E 02	1.731E 01	1.000E 01	0.230E-02	2.700E 02	1.000E 02
2	0.330E 02	1.300E 02	0.300E 02	0.000E 02	1.730E 01	1.000E 01	0.200E-02	2.000E 02	1.000E 02
STA	L/D	DELTA E	LE						
1	2.110E 01	2.000E 01	0.000E 00						
2	2.700E 01	2.000E 01	0.000E 00						

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 142.00 AT 207 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS. PIN EST

POINT	PG-IN	PG-OUT	TD-IN	TD-OUT	N	EZ	I2	CP	WT BAL	G
1	9.110E 02	8.940E 02	9.100E 01	1.477E 02	1.109E 00	3.057E 01	1.437E 03	4.104E 01	-2.140E-01	9.190E 03
2	9.120E 02	8.970E 02	9.110E 01	1.477E 02	1.104E 00	3.048E 01	1.437E 03	4.152E 01	-7.460E-02	9.172E 03
3	9.120E 02	8.970E 02	9.100E 01	1.477E 02	1.101E 00	3.047E 01	1.430E 03	4.142E 01	-9.232E-01	9.212E 03
4	9.110E 02	8.960E 02	9.100E 01	1.470E 02	1.102E 00	3.050E 01	1.430E 03	4.104E 01	-2.463E-01	9.142E 03
5	9.090E 02	8.940E 02	9.090E 01	1.470E 02	1.100E 00	3.050E 01	1.430E 03	4.104E 01	-1.109E 00	9.140E 03
6	9.090E 02	8.960E 02	9.090E 01	1.477E 02	1.109E 00	3.051E 01	1.437E 03	4.142E 01	-1.141E 00	9.190E 03
7	9.070E 02	8.920E 02	9.050E 01	1.477E 02	1.102E 00	3.048E 01	1.429E 03	4.122E 01	-1.290E 00	9.142E 03

TEST SECTION

LOCAL TEST PARAMETERS

TEST142.80 AT 077 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

DATA POINT 1											
STA	PO	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	0.641E 02	1.319E 02	1.019E 03	4.372E 02	1.043E 01	1.912E 01	6.282E-02	3.000E 02	1.000E 02		
2	0.506E 02	1.446E 02	1.022E 03	4.074E 02	1.072E 01	1.912E 01	6.310E-02	3.000E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.007E 01	4.500E 00								
2	2.760E 01	3.007E 01	4.500E 00								

LOCAL TEST PARAMETERS

TEST142.80 AT 077 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

DATA POINT 2											
STA	PO	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	0.651E 02	1.320E 02	1.019E 03	4.400E 02	1.000E 01	1.907E 01	6.024E-02	3.100E 02	1.000E 02		
2	0.506E 02	1.446E 02	1.022E 03	4.090E 02	1.022E 01	1.907E 01	6.007E-02	3.100E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.000E 01	4.500E 00								
2	2.760E 01	3.000E 01	4.500E 00								

LOCAL TEST PARAMETERS

TEST142.80 AT 077 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

DATA POINT 3											
STA	PO	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	0.651E 02	1.319E 02	1.017E 03	4.440E 02	1.020E 01	1.902E 01	6.007E-02	3.120E 02	1.000E 02		
2	0.506E 02	1.446E 02	1.027E 03	4.500E 02	1.021E 01	1.902E 01	6.051E-02	3.100E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.007E 01	4.500E 00								
2	2.760E 01	3.007E 01	4.500E 00								

LOCAL TEST PARAMETERS

TEST142.80 AT 077 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

DATA POINT 4											
STA	PO	TB	TU	TI	Q/A	Q/AP	M	DEL TP	VS		
1	0.641E 02	1.320E 02	1.019E 03	4.400E 02	1.024E 01	1.900E 01	6.177E-02	3.000E 02	1.000E 02		
2	0.506E 02	1.446E 02	1.027E 03	4.074E 02	1.025E 01	1.900E 01	6.000E-02	3.100E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.000E 01	4.500E 00								
2	2.760E 01	3.000E 01	4.500E 00								

LOCAL TEST PARAMETERS

TEST142.00 AT 8P7 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

		DATA POINT 5									
STA	PG	TU	TV	TI	O/A	O/MP	M	REL TV	VS		
1	0.021E 02	1.320E 02	1.012E 03	4.402E 02	1.934E 01	1.901E 01	6.100E-02	3.000E 02	1.000E 02		
2	0.070E 02	1.047E 02	1.000E 03	4.857E 02	1.927E 01	1.921E 01	6.130E-02	3.100E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.000E 01	4.000E 00								
2	2.700E 01	3.000E 01	4.000E 00								

LOCAL TEST PARAMETERS

TEST142.00 AT 8P7 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

		DATA POINT 6									
STA	PG	TU	TV	TI	O/A	O/MP	M	REL TV	VS		
1	0.001E 02	1.310E 02	1.012E 03	4.370E 02	1.930E 01	1.900E 01	6.107E-02	3.000E 02	1.000E 02		
2	0.010E 02	1.040E 02	1.000E 03	4.800E 02	1.930E 01	1.900E 01	6.270E-02	3.000E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.000E 01	4.000E 00								
2	2.700E 01	3.000E 01	4.000E 00								

LOCAL TEST PARAMETERS

TEST142.00 AT 8P7 AFTER 2MIN STEADY POWER. 30 SEC DATA INTERVALS.PIN EST

		DATA POINT 7									
STA	PG	TU	TV	TI	O/A	O/MP	M	REL TV	VS		
1	0.001E 02	1.310E 02	1.012E 03	4.360E 02	1.930E 01	1.900E 01	6.210E-02	3.000E 02	1.000E 02		
2	0.000E 02	1.040E 02	1.000E 03	4.501E 02	1.930E 01	1.900E 01	6.130E-02	3.000E 02	1.000E 02		
STA	L/D	DELTA E		LE							
1	2.111E 01	3.000E 01	4.000E 00								
2	2.700E 01	3.000E 01	4.000E 00								

Report AFRL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 1034.2MIN STEADY POWER.0PI-100 SEC.20 SEC DATA INTERVALS

AF = 0.130E-03 D = 0.132E-01 L = 0.400E 01 DELTA T0 = 0.300E 01

POINT	DATA POINTS									
	PG-IN	PG-OUT	TO-IN	TO-OUT	V	E2	E2	SP	HT ENL	G
1	3.397E 03	3.211E 03	8.000E 01	1.204E 02	1.000E 00	3.490E 01	3.490E 01	4.400E 01	1.123E 00	1.303E 04
2	3.324E 03	3.142E 03	7.990E 01	1.203E 02	1.000E 00	3.491E 01	3.491E 01	4.400E 01	9.000E-01	1.303E 04
3	3.250E 03	3.060E 03	7.980E 01	1.201E 02	1.000E 00	3.490E 01	3.490E 01	4.400E 01	1.000E 00	1.303E 04
4	3.180E 03	2.990E 03	7.940E 01	1.190E 02	1.000E 00	3.497E 01	3.497E 01	4.400E 01	1.000E 00	1.303E 04
5	3.097E 03	2.900E 03	7.900E 01	1.191E 02	1.000E 00	3.490E 01	3.490E 01	4.400E 01	3.201E-01	1.303E 04
6	3.031E 03	2.840E 03	7.880E 01	1.190E 02	1.000E 00	3.490E 01	3.490E 01	4.400E 01	7.300E-02	1.303E 04
7	2.962E 03	2.770E 03	7.860E 01	1.180E 02	1.000E 00	3.490E 01	3.490E 01	4.400E 01	5.930E-01	1.303E 04

Report AFRPL-TR-66-263, Appendix B

TEST SECTION

LOCAL TEST PARAMETERS

TEST 143A.2MIN STEADY POWER-OPI-180 SEC.20 SEC DATA INTERVALS

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PB	TI	TW	TI	TW	TI	TW
1	3-269E 03	1-120E 02	1-120E 03	3-307E 02	1-120E 03	3-307E 02	1-120E 03
2	3-223E 03	1-177E 02	1-130E 03	3-732E 02	1-130E 03	3-732E 02	1-130E 03
STA	L/D	DELTA E	LE	DELTA E	LE	DELTA E	LE
1	1-730E 01	3-496E 01	4-6C0E 00	3-496E 01	4-6C0E 00	3-496E 01	4-6C0E 00
2	2-358E 01	3-496E 01	4-6C0E 00	3-496E 01	4-6C0E 00	3-496E 01	4-6C0E 00

LOCAL TEST PARAMETERS

TEST 143A.2MIN STEADY POWER-OPI-180 SEC.20 SEC DATA INTERVALS

DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PB	TI	TW	TI	TW
1	3-199E 03	1-677E 02	1-120E 03	3-729E 02	1-120E 03
2	3-153E 03	1-176E 02	1-131E 03	3-772E 02	1-131E 03
STA	L/D	DELTA E	LE	DELTA E	LE
1	1-730E 01	3-491E 01	4-6C0E 00	3-491E 01	4-6C0E 00
2	2-358E 01	3-491E 01	4-6C0E 00	3-491E 01	4-6C0E 00

LOCAL TEST PARAMETERS

TEST 143A.2MIN STEADY POWER-OPI-180 SEC.20 SEC DATA INTERVALS

DATA POINT 3		DATA POINT 4			
STA	PB	TI	TW	TI	TW
1	3-123E 03	1-675E 02	1-133E 03	3-796E 02	1-133E 03
2	3-077E 03	1-176E 02	1-134E 03	3-810E 02	1-134E 03
STA	L/D	DELTA E	LE	DELTA E	LE
1	1-730E 01	3-492E 01	4-6C0E 00	3-492E 01	4-6C0E 00
2	2-358E 01	3-492E 01	4-6C0E 00	3-492E 01	4-6C0E 00

LOCAL TEST PARAMETERS

TEST 143A.2MIN STEADY POWER-OPI-180 SEC.20 SEC DATA INTERVALS

DATA POINT 4		DATA POINT 5			
STA	PB	TI	TW	TI	TW
1	3-083E 03	1-678E 02	1-135E 03	3-796E 02	1-135E 03
2	3-007E 03	1-173E 02	1-137E 03	3-827E 02	1-137E 03
STA	L/D	DELTA E	LE	DELTA E	LE
1	1-730E 01	3-457E 01	4-6C0E 00	3-457E 01	4-6C0E 00
2	2-358E 01	3-457E 01	4-6C0E 00	3-457E 01	4-6C0E 00

LOCAL TEST PARAMETERS
TEST 143A.2MIN STEADY POWER.DPI-180 SEC.20 SEC DATA INTERVALS

		DATA POINT 5									
STA	PB	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS		
1	2.967E 03	1.060E 02	1.135E 03	3.793E 02	2.308E 01	2.238E 01	0.194E-02	2.728E 02	1.847E 02		
2	2.920E 03	1.166E 02	1.136E 03	3.806E 02	2.308E 01	2.238E 01	0.461E-02	2.642E 02	1.854E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.498E 01	4.000E 00								
2	2.358E 01	3.458E 01	4.000E 00								

LOCAL TEST PARAMETERS
TEST 143A.2MIN STEADY POWER.DPI-180 SEC.20 SEC DATA INTERVALS

		DATA POINT 6									
STA	PB	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS		
1	2.904E 03	1.064E 02	1.134E 03	3.792E 02	2.312E 01	2.238E 01	0.198E-02	2.728E 02	1.847E 02		
2	2.898E 03	1.168E 02	1.137E 03	3.806E 02	2.312E 01	2.238E 01	0.463E-02	2.642E 02	1.854E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.501E 01	4.000E 00								
2	2.358E 01	3.501E 01	4.000E 00								

LOCAL TEST PARAMETERS
TEST 143A.2MIN STEADY POWER.DPI-180 SEC.20 SEC DATA INTERVALS

		DATA POINT 7									
STA	PB	TB	TV	TI	Q/A	Q/AP	M	DEL TP	VS		
1	2.836E 03	1.061E 02	1.135E 03	3.809E 02	2.304E 01	2.238E 01	0.132E-02	2.748E 02	1.847E 02		
2	2.789E 03	1.161E 02	1.136E 03	3.823E 02	2.304E 01	2.238E 01	0.394E-02	2.642E 02	1.854E 02		
STA	L/D	DELTA E	LE								
1	1.730E 01	3.458E 01	4.000E 00								
2	2.358E 01	3.495E 01	4.000E 00								

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 1438.5 MIN STEADY POWER, DP11-12=37SEC. OTHER INTERVALS 20SEC

AF = 0.138E-03 D = 0.132E-01 L = 0.400E 01 DELTA TO = 0.300E 01

POINT	DATA POINTS											
	PB-IN	PB-OUT	TB-IN	TB-OUT	W	E2	I2	CP	MT SAL	G		
1	3.422E 03	3.226E 03	8.250E 01	1.219E 02	1.830E 00	3.505E 01	1.348E 03	4.479E 01	4.601E 00	1.334E 04	1.334E 04	
2	3.415E 03	3.229E 03	8.231E 01	1.219E 02	1.830E 00	3.504E 01	1.344E 03	4.464E 01	3.766E 00	1.334E 04	1.334E 04	
3	3.412E 03	3.225E 03	8.230E 01	1.220E 02	1.830E 00	3.502E 01	1.346E 03	4.469E 01	3.590E 00	1.334E 04	1.334E 04	
4	3.404E 03	3.218E 03	8.200E 01	1.216E 02	1.830E 00	3.504E 01	1.345E 03	4.468E 01	2.843E 00	1.334E 04	1.334E 04	
5	3.395E 03	3.211E 03	8.210E 01	1.219E 02	1.833E 00	3.503E 01	1.346E 03	4.470E 01	3.095E 00	1.337E 04	1.337E 04	
6	3.394E 03	3.208E 03	8.210E 01	1.219E 02	1.830E 00	3.507E 01	1.347E 03	4.479E 01	3.540E 00	1.334E 04	1.334E 04	
7	3.387E 03	3.199E 03	8.190E 01	1.217E 02	1.835E 00	3.499E 01	1.344E 03	4.458E 01	3.266E 00	1.332E 04	1.332E 04	
8	3.389E 03	3.201E 03	8.190E 01	1.216E 02	1.829E 00	3.496E 01	1.341E 03	4.444E 01	3.547E 00	1.327E 04	1.327E 04	
9	3.379E 03	3.194E 03	8.190E 01	1.217E 02	1.834E 00	3.501E 01	1.346E 03	4.467E 01	3.517E 00	1.331E 04	1.331E 04	
10	3.375E 03	3.190E 03	8.180E 01	1.216E 02	1.834E 00	3.501E 01	1.344E 03	4.461E 01	3.375E 00	1.331E 04	1.331E 04	
11	3.376E 03	3.192E 03	8.170E 01	1.215E 02	1.824E 00	3.499E 01	1.345E 03	4.461E 01	3.921E 00	1.324E 04	1.324E 04	
12	3.363E 03	3.177E 03	8.170E 01	1.216E 02	1.829E 00	3.498E 01	1.339E 03	4.440E 01	2.934E 00	1.327E 04	1.327E 04	

TEST SECTION

LOCAL TEST PARAMETERS

TEST 1438.5 MIN STEADY POWER,UP11-12=37SEC,OTHER INTERVALS 20SEC

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4		
STA	P/B	YB	YI	O/A	O/AP	M	DEL TF	VS
1	3.287E 03	1.096E 02	1.131E 03	3.699E 02	2.317E 01	2.261E 01	2.663E 02	1.515E 02
2	3.236E 03	1.194E 02	1.174E 03	3.771E 02	2.317E 01	2.261E 01	2.677E 02	1.521E 02
L/D		DELTA E		LE				
1	1.730E 01	3.505E 01	4.000E 00					
2	2.356E 01	3.505E 01	4.000E 00					

LOCAL TEST PARAMETERS

TEST 1438.5 MIN STEADY POWER,UP11-12=37SEC,OTHER INTERVALS 20SEC

DATA POINT 2		DATA POINT 3		DATA POINT 4		DATA POINT 5		
STA	P/B	TB	TI	O/A	O/AP	M	DEL TF	VS
1	2.267E 03	1.095E 02	1.135E 03	3.762E 02	2.316E 01	2.236E 01	2.667E 02	1.515E 02
2	3.241E 03	1.194E 02	1.139E 03	3.820E 02	7.315E 01	2.236E 01	2.025E 02	1.521E 02
L/D		DELTA E		LE				
1	1.730E 01	3.504E 01	4.000E 00					
2	2.356E 01	3.504E 01	4.000E 00					

LOCAL TEST PARAMETERS

TEST 1438.5 MIN STEADY POWER,UP11-12=37SEC,OTHER INTERVALS 20SEC

DATA POINT 3		DATA POINT 4		DATA POINT 5		DATA POINT 6		
STA	P/B	TB	TI	O/A	O/AP	M	DEL TF	VS
1	2.263E 03	1.096E 02	1.136E 03	3.787E 02	2.313E 01	2.236E 01	2.691E 02	1.515E 02
2	3.237E 03	1.195E 02	1.140E 03	3.844E 02	2.313E 01	2.236E 01	2.649E 02	1.521E 02
L/D		DELTA E		LE				
1	1.730E 01	3.502E 01	4.000E 00					
2	2.356E 01	3.502E 01	4.000E 00					

LOCAL TEST PARAMETERS

TEST 1438.5 MIN STEADY POWER,UP11-12=37SEC,OTHER INTERVALS 20SEC

DATA POINT 4		DATA POINT 5		DATA POINT 6		DATA POINT 7		
STA	P/B	TB	TI	O/A	O/AP	M	DEL TF	VS
1	3.274E 03	1.092E 02	1.136E 03	3.776E 02	2.316E 01	2.236E 01	2.694E 02	1.514E 02
2	3.227E 03	1.191E 02	1.139E 03	3.820E 02	2.315E 01	2.236E 01	2.638E 02	1.521E 02
L/D		DELTA E		LE				
1	1.730E 01	3.504E 01	4.000E 00					
2	2.356E 01	3.504E 01	4.000E 00					

LOCAL TEST PARAMETERS
 TEST 1430.5 MIN STEADY POWER, DP11-12-3755C, OTHER INTERVALS 2000C

		DATA POINT 5							
STA	PB	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-260E 03	1-095E 02	1-137E 03	3-794E 02	2-314E 01	2-237E 01	0-200E-02	2-761E 02	1-519E 02
2	3-222E 03	1-194E 02	1-140E 03	3-839E 02	2-314E 01	2-237E 01	0-667E-02	2-648E 02	1-535E 02
STA		L/D		DELTA E		LE			
1	1-730E 01	3-563E 01	4-000E 00						
2	2-358E 01	3-503E 01	4-000E 00						

LOCAL TEST PARAMETERS
 TEST 1430.5 MIN STEADY POWER, DP11-12-3755C, OTHER INTERVALS 2000C

		DATA POINT 6							
STA	PB	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-267E 03	1-095E 02	1-139E 03	3-799E 02	2-316E 01	2-241E 01	0-394E-02	2-692E 02	1-518E 02
2	3-220E 03	1-194E 02	1-140E 03	3-810E 02	2-316E 01	2-241E 01	0-839E-02	2-634E 02	1-521E 02
STA		L/D		DELTA E		LE			
1	1-730E 01	3-567E 01	4-000E 00						
2	2-358E 01	3-507E 01	4-000E 00						

LOCAL TEST PARAMETERS
 TEST 1430.5 MIN STEADY POWER, DP11-12-3755C, OTHER INTERVALS 2000C

		DATA POINT 7							
STA	PB	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-258E 03	1-093E 02	1-132E 03	3-790E 02	2-309E 01	2-231E 01	0-366E-02	2-667E 02	1-512E 02
2	3-211E 03	1-192E 02	1-137E 03	3-817E 02	2-309E 01	2-231E 01	0-699E-02	2-622E 02	1-518E 02
STA		L/D		DELTA E		LE			
1	1-730E 01	3-490E 01	4-000E 00						
2	2-358E 01	3-499E 01	4-000E 00						

LOCAL TEST PARAMETERS
 TEST 1430.5 MIN STEADY POWER, DP11-12-3755C, OTHER INTERVALS 2000C

		DATA POINT 8							
STA	PB	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-260E 03	1-092E 02	1-138E 03	3-804E 02	2-308E 01	2-234E 01	0-201E-02	2-712E 02	1-507E 02
2	3-213E 03	1-191E 02	1-137E 03	3-832E 02	2-308E 01	2-234E 01	0-626E-02	2-641E 02	1-522E 02
STA		L/D		DELTA E		LE			
1	1-730E 01	3-494E 01	4-000E 00						
2	2-358E 01	3-494E 01	4-000E 00						

LOCAL TEST PARAMETERS

TEST 1430.5 MIN STEADY POWER, OP11-12-37SEC. OTHER INTERVALS 20SEC

DATA POINT 9

STA	PG	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-204E 03	1-092E 02	1-134E 03	3-770E 02	2-312E 01	2-232E 01	0-208E-02	2-608E 02	1-511E 02
2	3-204E 03	1-191E 02	1-137E 03	3-664E 02	2-312E 01	2-232E 01	0-000E-02	2-014E 02	1-517E 02

STA	L/D	DELTA E	LE
1	1-730E 01	3-501E 01	4-000E 00
2	2-358E 01	3-501E 01	4-000E 00

LOCAL TEST PARAMETERS

TEST 1430.5 MIN STEADY POWER, OP11-12-37SEC. OTHER INTERVALS 20SEC

DATA POINT 10

STA	PG	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-204E 03	1-092E 02	1-134E 03	3-770E 02	2-312E 01	2-232E 01	0-208E-02	2-700E 02	1-511E 02
2	3-204E 03	1-191E 02	1-137E 03	3-664E 02	2-312E 01	2-232E 01	0-002E-02	2-604E 02	1-517E 02

STA	L/D	DELTA E	LE
1	1-730E 01	3-501E 01	4-000E 00
2	2-358E 01	3-501E 01	4-000E 00

LOCAL TEST PARAMETERS

TEST 1430.5 MIN STEADY POWER, OP11-12-37SEC. OTHER INTERVALS 20SEC

DATA POINT 11

STA	PG	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-250E 03	1-091E 02	1-134E 03	3-802E 02	2-309E 01	2-232E 01	0-232E-02	2-712E 02	1-502E 02
2	3-204E 03	1-190E 02	1-137E 03	3-817E 02	2-309E 01	2-232E 01	0-005E-02	2-637E 02	1-509E 02

STA	L/D	DELTA E	LE
1	1-730E 01	3-490E 01	4-000E 00
2	2-358E 01	3-490E 01	4-000E 00

LOCAL TEST PARAMETERS

TEST 1430.5 MIN STEADY POWER, OP11-12-37SEC. OTHER INTERVALS 20SEC

DATA POINT 12

STA	PG	TB	TU	TI	G/A	G/AP	M	DEL TP	VS
1	3-238E 03	1-091E 02	1-137E 03	3-822E 02	2-300E 01	2-222E 01	0-137E-02	2-730E 02	1-507E 02
2	3-180E 03	1-191E 02	1-137E 03	3-822E 02	2-300E 01	2-222E 01	0-005E-02	2-630E 02	1-513E 02

STA	L/D	DELTA E	LE
1	1-730E 01	3-490E 01	4-000E 00
2	2-358E 01	3-490E 01	4-000E 00

Report AFRPL-TR-66-263, Appendix B

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 144A-WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.DPI-111 SEC

AF = 0.138E-03 D = 0.132E-01 L = 0.400E 01 DELTA TO = 0.260E 01

POINT	DATA POINTS									
	PB-IN	PB-OUT	TD-IN	TD-OUT	W	F2	I2	OP	HT PAL	C
1	3.082E 03	2.967E 03	7.556E 01	1.201E 02	1.320E 00	3.898E 01	1.520F 03	5.617E 01	2.427E 00	9.370E 01
2	3.094E 03	2.971E 03	7.580E 01	1.197E 02	1.332E 00	3.906F 01	1.515F 03	5.610F 01	1.383E 00	9.444E 01
3	3.078E 03	2.962E 03	7.450E 01	1.188E 02	1.341E 00	3.897F 01	1.504E 03	5.564E 01	8.008E-01	9.731F 01
4	3.090E 03	2.971E 03	7.430E 01	1.188E 02	1.346E 00	3.899E 01	1.502E 03	5.552E 01	4.948E-01	9.764E 01
5	3.116E 03	2.967E 03	7.486E 01	1.188E 02	1.357E 00	3.905E 01	1.502E 03	5.540F 01	3.148E-01	9.944E 01
6	3.118E 03	2.992E 03	7.340E 01	1.177E 02	1.358E 00	3.903E 01	1.503E 03	5.561F 01	1.003E 00	9.797E 01
7	3.101E 03	2.988E 03	7.366E 01	1.174E 02	1.353E 00	3.898E 01	1.497E 03	5.532E 01	5.777E-01	9.819E 01

TEST SECTION

LOCAL TEST PARAMETERS

TEST 140A-WATER TEST.6MIN STEADY POWER.1MIN TA INTERVALS.DPI-111 SEC

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PO	TI	TU	TI	TU	TI	TU
1	3.003E 03	1.042E 02	1.172E 03	2.022E 01	1.172E 03	2.022E 01	1.172E 03
2	2.974E 03	1.172E 02	1.221E 03	2.015E 02	1.221E 03	2.015E 01	1.221E 03
L/D		DELTA E		O/A		O/AP	
1	1.730E 01	3.000E 01	4.000E 00	2.850E 01	4.000E 00	2.811E 01	4.000E 00
2	2.350E 01	3.000E 01	4.000E 00	2.800E 01	4.000E 00	2.811E 01	4.000E 00
M		DELTA E		O/A		O/AP	
1	1.730E 01	3.000E 01	4.000E 00	2.850E 01	4.000E 00	2.811E 01	4.000E 00
2	2.350E 01	3.000E 01	4.000E 00	2.800E 01	4.000E 00	2.811E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 140A-WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.DPI-111 SEC

DATA POINT 2		DATA POINT 3		DATA POINT 4	
STA	PO	TI	TU	TI	TU
1	3.000E 03	1.057E 02	1.222E 03	2.781E 02	1.222E 03
2	2.979E 03	1.109E 02	1.240E 03	3.100E 02	1.240E 03
L/D		DELTA E		O/A	
1	1.730E 01	3.966E 01	4.000E 00	2.807E 01	4.000E 00
2	2.350E 01	3.966E 01	4.000E 00	2.807E 01	4.000E 00
M		DELTA E		O/A	
1	1.730E 01	3.966E 01	4.000E 00	2.807E 01	4.000E 00
2	2.350E 01	3.966E 01	4.000E 00	2.807E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 140A-WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.DPI-111 SEC

DATA POINT 3		DATA POINT 4	
STA	PO	TI	TU
1	2.990E 03	1.060E 02	1.222E 03
2	2.960E 03	1.100E 02	1.242E 03
L/D		DELTA E	
1	1.730E 01	3.007E 01	4.000E 00
2	2.350E 01	3.007E 01	4.000E 00
M		DELTA E	
1	1.730E 01	3.007E 01	4.000E 00
2	2.350E 01	3.007E 01	4.000E 00

LOCAL TEST PARAMETERS

TEST 140A-WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.DPI-111 SEC

DATA POINT 4		DATA POINT 5	
STA	PO	TI	TU
1	3.000E 03	1.067E 02	1.224E 03
2	2.970E 03	1.157E 02	1.246E 03
L/D		DELTA E	
1	1.730E 01	3.000E 01	4.000E 00
2	2.350E 01	3.000E 01	4.000E 00
M		DELTA E	
1	1.730E 01	3.000E 01	4.000E 00
2	2.350E 01	3.000E 01	4.000E 00

Report AFRPL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS
TEST 144A.WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.D01-111 SEC

DATA POINT 5											
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.034E 03	1.042E 02	1.225E 03	2.835E 02	2.859E 01	2.782F 01	1.552E-01	1.702F 02	1.576F 02		
2	3.004E 03	1.152E 02	1.245E 03	3.149E 02	2.858E 01	2.782E 01	1.390E-01	1.990F 02	1.580F 02		
DELTA E											
1	1.730E 01	3.988E 01	4.000E 00								
2	2.358E 01	3.905E 01	4.000E 00								

LOCAL TEST PARAMETERS
TEST 144A.WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.D01-111 SEC

DATA POINT 6											
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.029E 03	1.040E 02	1.222E 03	2.800E 02	2.856E 01	2.783E 01	1.581E-01	1.768E 02	1.568E 02		
2	2.999E 03	1.150E 02	1.245E 03	3.181E 02	2.855E 01	2.783F 01	1.383F-01	2.018E 02	1.571F 02		
DELTA E											
1	1.730E 01	3.983E 01	4.000E 00								
2	2.358E 01	3.983E 01	4.000E 00								

LOCAL TEST PARAMETERS
TEST 144A.WATER TEST.6MIN STEADY POWER.1MIN DATA INTERVALS.D01-111 SEC

DATA POINT 7											
STA	PB	TB	TW	TI	Q/A	Q/AP	M	DEL TF	VS		
1	3.021E 03	1.037E 02	1.224E 03	2.862E 02	2.849E 01	2.749E 01	1.517E-01	1.825E 02	1.571E 02		
2	2.992E 03	1.147E 02	1.245E 03	3.191E 02	2.848E 01	2.749E 01	1.356F-01	2.045E 02	1.575E 02		
DELTA E											
1	1.720E 01	3.898E 01	4.000E 00								
2	2.358E 01	3.898E 01	4.000E 00								

LIQUID SIDE HEAT TRANSFER TEST DATA

OVERALL TEST PARAMETERS

TEST 1448-WATER TEST-5 MIN STEADY POWER-1 MIN DATA INTERVALS-0.01-12300C

AF = 0.138E-03 D = 0.132E-01 L = 0.400E 01 DELTA TB = 0.200E 01

DATA POINTS

POINT	PO-IN	PO-OUT	TO-IN	TO-OUT	W	E2	E2	I2	CP	HT SML	C
1	3.101E 03	2.988E 03	9.180E 01	1.368E 02	1.296E 00	3.897E 01	3.897E 01	1.422E 03	5.810E 01	2.010E 13	9.47E 03
2	3.099E 03	2.987E 03	9.178E 01	1.368E 02	1.310E 00	3.900E 01	3.900E 01	1.407E 03	5.805E 01	2.009E 00	9.47E 03
3	3.114E 03	3.002E 03	9.190E 01	1.368E 02	1.322E 00	3.900E 01	3.900E 01	1.400E 03	5.832E 01	1.002E 00	9.500E 03
4	3.105E 03	2.992E 03	9.210E 01	1.368E 02	1.318E 00	3.900E 01	3.900E 01	1.409E 03	5.840E 01	1.004E 00	9.500E 03
5	3.094E 03	2.984E 03	9.220E 01	1.368E 02	1.315E 00	3.898E 01	3.898E 01	1.407E 03	5.832E 01	1.004E 00	9.572E 03
6	3.106E 03	2.986E 03	9.200E 01	1.368E 02	1.333E 00	3.898E 01	3.898E 01	1.401E 03	5.831E 01	1.002E 00	9.672E 03

Report AFRPL-TR-66-263, Appendix B

TEST SECTION

LOCAL TEST PARAMETERS

TEST 1448.WATER TEST.5 MIA STEADY POWER.1 MIN DATA INTERVALS.DP1-123SEC

DATA POINT 1		DATA POINT 2		DATA POINT 3		DATA POINT 4			
STA	PB	TB	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1	3.023E 03	1.218E 02	1.224E 03	2.888E 02	2.847E 01	2.768E 01	1.672E-01	1.668E 02	1.811E 02
2	2.995E 03	1.330E 02	1.250E 03	3.275E 02	2.847E 01	2.768E 01	1.419E-01	1.908E 02	1.818E 02
STA	L/D	DELTA E	LE						
1	1.730E 01	3.857E 01	4.000E 00						
2	2.358E 01	3.897E 01	4.000E 00						

LOCAL TEST PARAMETERS

TEST 1448.WATER TEST.5 MIA STEADY POWER.1 MIN DATA INTERVALS.DP1-123SEC

DATA POINT 2		DATA POINT 3		DATA POINT 4					
STA	PB	TB	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1	3.022E 03	1.227E 02	1.239E 03	3.031E 02	2.864E 01	2.783E 01	1.543E-01	1.804E 02	1.827E 02
2	2.994E 03	1.340E 02	1.258E 03	3.233E 02	2.864E 01	2.783E 01	1.409E-01	1.883E 02	1.838E 02
STA	L/D	DELTA E	LE						
1	1.730E 01	3.905E 01	4.000E 00						
2	2.358E 01	3.909E 01	4.000E 00						

LOCAL TEST PARAMETERS

TEST 1448.WATER TEST.5 MIA STEADY POWER.1 MIN DATA INTERVALS.DP1-123SEC

DATA POINT 3		DATA POINT 4							
STA	PB	TB	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1	3.037E 03	1.228E 02	1.237E 03	3.036E 02	2.866E 01	2.768E 01	1.839E-01	1.808E 02	1.804E 02
2	3.009E 03	1.340E 02	1.257E 03	3.347E 02	2.855E 01	2.768E 01	1.379E-01	2.007E 02	1.846E 02
STA	L/D	DELTA E	LE						
1	1.730E 01	3.903E 01	4.000E 00						
2	2.358E 01	3.903E 01	4.000E 00						

LOCAL TEST PARAMETERS

TEST 1448.WATER TEST.5 MIA STEADY POWER.1 MIN DATA INTERVALS.DP1-123SEC

DATA POINT 4									
STA	PB	TB	TV	TI	Q/A	Q/MP	M	DEL TP	VS
1	3.028E 03	1.229E 02	1.235E 03	3.023E 02	2.881E 01	2.773E 01	1.846E-01	1.794E 02	1.838E 02
2	3.000E 03	1.341E 02	1.249E 03	3.241E 02	2.851E 01	2.773E 01	1.409E-01	1.908E 02	1.838E 02
STA	L/D	DELTA E	LE						
1	1.730E 01	3.900E 01	4.000E 00						
2	2.358E 01	3.900E 01	4.000E 00						

Report AFRL-TR-66-263, Appendix B

LOCAL TEST PARAMETERS

TEST 1448-WATER TEST-5 MIN STEADY POWER-1 MIN DATA INTERVALS-0P1-1230EC

		DATA POINT 5									
STA	PG	TB	TU	TI	Q/A	Q/MP	M	DEL TP	VS		
1	3-018E 03	1-229E 02	1-236E 03	3-095E 02	2-800E 01	2-760E 01	1-520E-01	1-822E 02	1-532E 02		
2	2-991E 03	1-361E 02	1-240E 03	3-253E 02	2-848E 01	2-748E 01	1-447E-01	1-912E 02	1-842E 02		
STA	L/D	DELTA E	LE								
1	1-730E 01	3-890E 01	4-000E 00								
2	2-350E 01	3-890E 01	4-000E 00								

LOCAL TEST PARAMETERS

TEST 1448-WATER TEST-5 MIN STEADY POWER-1 MIN DATA INTERVALS-0P1-1230EC

		DATA POINT 6									
STA	PG	TB	TU	TI	Q/A	Q/MP	M	DEL TP	VS		
1	3-022E 03	1-225E 02	1-236E 03	3-045E 02	2-800E 01	2-730E 01	1-516E-01	1-830E 02	1-804E 02		
2	2-992E 03	1-336E 02	1-228E 03	3-340E 02	2-840E 01	2-790E 01	1-376E-01	2-000E 02	1-800E 02		
STA	L/D	DELTA E	LE								
1	1-730E 01	3-890E 01	4-000E 00								
2	2-350E 01	3-890E 01	4-000E 00								

Report AFRPL-TR-66-263

Unclassified
Security Classification

DOCUMENT CONTROL DATA - R&D		
<small>(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)</small>		
1 ORIGINATING ACTIVITY (Corporate author) Aerojet-General Corporation Liquid Rocket Operations Sacramento, California 95809		2a REPORT SECURITY CLASSIFICATION Unclassified 2b GROUP
3 REPORT TITLE Heat-Transfer Characteristics of 98% H₂O₂ at High pressure and High Velocity		
4 DESCRIPTIVE NOTES (Type of report and inclusive dates)		
5 AUTHOR(S) (Last name, first name, initial) Rousar, D. C. Van Huff, N. E.		
6 REPORT DATE August 1966	7a TOTAL NO OF PAGES 225	7b NO OF REFS 21
8a CONTRACT OR GRANT NO. AF 04(611)-10785	8b ORIGINATOR'S REPORT NUMBER(S) Aerojet-General Report 10785-77-1	
8c PROJECT NO.	8d OTHER REPORT NO(S) (Any other numbers that may be assigned to this report) AFRPL TR-66-263	
10 AVAILABILITY/LIMITATION NOTICES		
11 SUPPLEMENTARY NOTES		12 SPONSORING MILITARY ACTIVITY Air Force Rocket Propulsion Lab. Edwards Air Force Base, California
13 ABSTRACT High-pressure heat-transfer experiments have been conducted with both 90 and 98% H ₂ O ₂ . Electrically heated 3/16- and 1/4-in.-dia Inconel 718 and 3/16-in.-dia stainless-steel test sections were used at pressures of 850 and 4700 psi and at coolant velocities of 25 to 198 ft/sec. Titration of the peroxide after short-duration testing indicated that little or no H ₂ O ₂ decomposition had occurred in the test section. The short-duration burnout tests have shown that the maximum burnout heat flux is directly proportional to coolant velocity and is insensitive to coolant pressure. The Dittus-Boelter equation was found to yield a conservative estimate of heat-transfer coefficients for 98% H ₂ O ₂ and is recommended for design purposes. Long-duration tests conducted at velocities of 50 to 150 ft/sec with Inconel 718 tubing indicated that the long-duration burnout heat flux is degenerated to about 65% of that demonstrated in short-duration tests. Titration of the peroxide after these tests indicated that minor H ₂ O ₂ decomposition had occurred. It can be concluded that 98% H ₂ O ₂ would be an excellent regenerative coolant in rocket engine systems. The long-duration burnout phenomenon at high pressure can be avoided by limiting the design burnout heat flux to about 65% of the short-duration burnout point.		

DD FORM 1473
1 JAN 64

Unclassified
Security Classification

Unclassified
Security Classification

14. KEY WORDS	LINK A		LINK B		LINK C	
	ROLE	WT	ROLE	WT	ROLE	WT
Hydrogen Peroxide (90 and 98% H ₂ O ₂) High-Pressure Testing Staged-Combustion Engines Regenerative Cooling High-Heat-Flux Systems Heat-Transfer Testing Forced-Convection Heat-Transfer Characteristics Pressure-Drop Characteristics of 98% H ₂ O ₂						

INSTRUCTIONS

1. **ORIGINATING ACTIVITY:** Enter the name and address of the contractor, subcontractor, grantee, Department of Defense activity or other organization (corporate author) issuing the report.
- 2a. **REPORT SECURITY CLASSIFICATION:** Enter the overall security classification of the report. Indicate whether "Restricted Data" is included. Marking is to be in accordance with appropriate security regulations.
- 2b. **GROUP:** Automatic downgrading is specified in DoD Directive 5200.10 and Armed Forces Industrial Manual. Enter the group number. Also, when applicable, show that optional markings have been used for Group 3 and Group 4 as authorized.
3. **REPORT TITLE:** Enter the complete report title in all capital letters. Titles in all cases should be unclassified. If a meaningful title cannot be selected without classification, show title classification in all capitals in parentheses immediately following the title.
4. **DESCRIPTIVE NOTES:** If appropriate, enter the type of report, e.g., interim, progress, summary, annual, or final. Give the inclusive dates when a specific reporting period is covered.
5. **AUTHOR(S):** Enter the name(s) of author(s) as shown on or in the report. Enter last name, first name, middle initial. If military, show rank and branch of service. The name of the principal author is an absolute minimum requirement.
6. **REPORT DATE:** Enter the date of the report as day, month, year, or month, year. If more than one date appears on the report, use date of publication.
- 7a. **TOTAL NUMBER OF PAGES:** The total page count should follow normal pagination procedures, i.e., enter the number of pages containing information.
- 7b. **NUMBER OF REFERENCES:** Enter the total number of references cited in the report.
- 8a. **CONTRACT OR GRANT NUMBER:** If appropriate, enter the applicable number of the contract or grant under which the report was written.
- 8b, 8c, & 8d. **PROJECT NUMBER:** Enter the appropriate military department identification, such as project number, subproject number, system numbers, task number, etc.
- 9a. **ORIGINATOR'S REPORT NUMBER(S):** Enter the official report number by which the document will be identified and controlled by the originating activity. This number must be unique to this report.
- 9b. **OTHER REPORT NUMBER(S):** If the report has been assigned any other report numbers (either by the originator or by the sponsor), also enter this number(s).
10. **AVAILABILITY/LIMITATION NOTICES:** Enter any limitations on further dissemination of the report, other than those

imposed by security classification, using standard statements such as:

- (1) "Qualified requesters may obtain copies of this report from DDC."
- (2) "Foreign announcement and dissemination of this report by DDC is not authorized."
- (3) "U. S. Government agencies may obtain copies of this report directly from DDC. Other qualified DDC users shall request through _____."
- (4) "U. S. military agencies may obtain copies of this report directly from DDC. Other qualified users shall request through _____."
- (5) "All distribution of this report is controlled. Qualified DDC users shall request through _____."

If the report has been furnished to the Office of Technical Services, Department of Commerce, for sale to the public, indicate this fact and enter the price, if known.

11. **SUPPLEMENTARY NOTES:** Use for additional explanatory notes.
12. **SPONSORING MILITARY ACTIVITY:** Enter the name of the departmental project office or laboratory sponsoring (paying for) the research and development. Include address.
13. **ABSTRACT:** Enter an abstract giving a brief and factual summary of the document indicative of the report, even though it may also appear elsewhere in the body of the technical report. If additional space is required, a continuation sheet shall be attached.

It is highly desirable that the abstract of classified reports be unclassified. Each paragraph of the abstract shall end with an indication of the military security classification of the information in the paragraph, represented as (TS), (S), (C), or (U).

There is no limitation on the length of the abstract. However, the suggested length is from 150 to 225 words.

14. **KEY WORDS:** Key words are technically meaningful terms or short phrases that characterize a report and may be used as index entries for cataloging the report. Key words must be selected so that no security classification is required. Identifiers, such as equipment model designation, trade name, military project code name, geographic location, may be used as key words but will be followed by an indication of technical context. The assignment of links, rules, and weights is optional.

Unclassified
Security Classification

SUPPLEMENTARY

INFORMATION



AEROJET-GENERAL CORPORATION

SACRAMENTO

CALIFORNIA

SACRAMENTO PLANT

9300:0537:JRC:pe

24 January 1967


Subject: Contract AF 04(611)-10785, Report AFRPL-TR-66-263

To: All Recipients of Report AFRPL-TR-66-263

1. In accordance with a directive received from Air Force Rocket Propulsion Laboratory, please add the following statement to the cover and title pages of your copy of the subject report.

"This document is subject to special export controls and each transmittal to foreign governments or foreign nationals may be made only with prior approval of AFRPL (RPRR/STINFO), Edwards, California 93523."

AEROJET-GENERAL CORPORATION


J. A. Cannon, Contract Manager
Advanced Storable Engine Program
Liquid Rocket Operations

AD-804006