

324

AD A 048324

FESA-RT-2034

BUILDING HEATING ENERGY CONSUMPTION AT FIXE

Mounir M. Botros

20 June 1977

Final Report

APPROVED FOR PUBLIC RELEASE, DISTRIBUTION

Prepared by

AD No. _____
DDC FILE COPY
USA Facilities Engineering Support Agency
Research and Technology Division
Fort Belvoir, VA 22060

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER FESA-RT-2034 ✓	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) 6 Building Heating Energy Consumption at Fixed Facilities,		7. TYPE OF REPORT & PERIOD COVERED 9 Final report-Apr-Jun 77,
	14 USA	6. PERFORMING ORG. REPORT NUMBER FESA-RT-2034
7. AUTHOR(s) 10 Mounir M. Botros		8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS US Army Facilities Engineering Support Agency Research and Technology Division Fort Belvoir, VA 22060	16 4A	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 762731AT41 Task 06, Work Unit 010, Energy Control Sys.
11. CONTROLLING OFFICE NAME AND ADDRESS	11	12. REPORT DATE 20 June 77
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		13. NUMBER OF PAGES 12 127p.
		15. SECURITY CLASS. (of this report) UNCLASSIFIED
16. DISTRIBUTION STATEMENT (of this Report) APPROVED FOR PUBLIC RELEASE, DISTRIBUTION UNLIMITED.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) The high, the low, and the average heating consumption The total average of heating consumption (the average line) The baseline of heating consumption		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) Oil delivery data were collected for twenty-four building types at three Army installations in the Washington, DC area. These data, collected for FY 75 and FY 76, were analyzed to determine the heating energy consumed by the different building types. The average heating energy consumption as well as the high and low samples were calculated and plotted for each building type. The report provides a basis for determining where the application of energy conservation techniques and the use of energy control systems is most cost effective.		

17 06

DD FORM 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE.

UNCLASSIFIED
SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

409266

[Handwritten signature]

PREFACE

This report was prepared under RDT&E program 6.27.31A, project 4A762731AT41, task 06, wrk unit 010, Energy Control Systems.

COL James R. C. Miller is Commander and Director of FESA, and Mr. Homer D. Müsselman is Chief/Research and Technology Division. Mr. James Walton (DAEN-FEU-A) and Mr. Harrison Maschke (DAEN-MCE-U) are the technical monitors for the project.

ACCESSION for		
NTIS	White Section	<input checked="" type="checkbox"/>
DGC	Buff Section	<input type="checkbox"/>
UNANNOUNCED		<input type="checkbox"/>
JUSTIFICATION		
BY		
DISTRIBUTION/AVAILABILITY CODES		
Dist.	AvAIL. and/or	SPECIAL
A		

Summary

Oil delivery data were collected for twenty-four building types at three Army installations in the Washington, DC area. These data, collected for F&75 and FY76, were analyzed to determine the heating energy consumed by the different building types. The average heating energy consumption as well as the high and low samples were calculated and plotted for each building type. The report provides a data base for determining where the application of energy conservation techniques is feasible and cost effective and where the use of energy control systems is not cost effective.



TABLE OF CONTENTS

<u>Section</u>	<u>Page No.</u>
Preface	i
Summary	ii
1.0 Introduction	1
2.0 Data Collection and Preparation	1
2.1 Calculation of the High, Low and Average Heating Consumption	2
2.2 Calculation of the Combined Installation Data	2
3.0 Assumptions	3
4.0 Results	4
5.0 Conclusion	7
References	8
Appendix A, Heating Energy Consumption at Installation 1	A-1 to A-33
Appendix B, Heating Energy Consumption at Installation 2	B-1 to B-25
Appendix C, Heating Energy Consumption at Installation 3	C-1 to C-27
Appendix D, Conclusion, Combined Consumption	D-1 to D-25

TABLES AND FIGURES

<u>TITLE</u>	<u>PAGE NO.</u>
Appendix A, Installation No. 1	A-1
EM Barracks	A-2, A-3
BOQ	A-4, A-5
Family Housing for Officers	A-6, A-7
NCO Family Housing	A-8, A-9
Administration Offices	A-10, A-11
General Purpose Warehouse	A-12, A-13
Motor Repair Shop	A-14, A-15
Chapel	A-16, A-17
Laboratories	A-18, A-19
General Inst. Building	A-20, A-21
Enlisted Men's Mess	A-22, A-23
Enlisted Men's Barracks with Mess	A-24, A-25
Post Exchange	A-26
Recreation Center	A-27
Theater	A-28
Bowling Alley	A-29
Commissary	A-30
Field House	A-31
Different Kind of Building	A-32
The Average Heating Consumption for Inst. No. 1	A-33

Appendix B, Installation No. 2	B-1
BOQ	B-2, B-3
Family Housing for Officers	B-4, B-5
NCO Family Housing	B-6, B-7
Administrative Offices	B-8, B-9
General Purpose Warehouse	B-10, B-11
Motor Repair Shop	B-12, B-13
Chapel	B-14
Officer's Mess	B-15
EM Mess	B-16
EM Barracks with Mess	B-17
Gymnasium	B-18
Post Exchange	B-19
Theater	B-20
Library	B-21
Aud, Band	B-22
Fire Station	B-23
Different Kinds of Buildings	B-24
The Average Heating Consumption for Inst. No. 2	B-25
Appendix C, Installation No. 3	C-1
EM Barracks	C-2, C-3
BOQ	C-4, C-5
NCO Family Housing	C-6, C-7
Administrative Offices	C-8, C-9

General Purpose Warehouse	C-10, C-11
Motor Repair Shop	C-12, C-13
Chapel	C-14, C-15
General Inst. Building	C-16, C-17
EM Mess	C-18, C-19
Post Exchange	C-20, C-21
Laboratories	C-22
Recreation Center	C-23
Museum	C-24
Commissary	C-25
Different Kinds of Buildings	C-26
The Average Heating Consumption for Inst. No. 3	C-27
Appendix D, Conclusion and Combined Consumption	D-1
The Baseline of Heating Consumption for 24 types of Bldgs.	D-2 to D-7
The Baseline of EM Barracks	D-8
The Baseline of BOQ	D-9
The Baseline of Family Housing for Officers	D-10
The Baseline of NCO Family Housing	D-11
The Baseline of Administrative Offices	D-12
The Baseline of Warehouse	D-13
The Baseline of Motor Repair Shop	D-14
The Baseline of Chapel	D-15
The Baseline of Laboratories	D-16
The Baseline of General Inst. Building	D-17
The Baseline of EM Mess	D-18
The Baseline of EM Barracks with Mess	D-19

The Baseline of Post Exchange	D-20
The Baseline of Recreation Center	D-21
The Baseline of Theater	D-22
Comparison Between the Baseline and Inst. No. 1	D-23
Comparison Between the Baseline and Inst. No. 2	D-24
Comparison Between the Baseline and Inst. No. 3	D-25

1.0 INTRODUCTION

A major problem in establishing cost effectiveness of energy control systems and energy conservation ideas is to determine how much energy a building consumed before the energy control system or energy conservation concept was implemented. This is especially true at Army fixed facilities where individual buildings are not metered. In order to provide a data base on load demand and energy consumed by building type, an extensive building metering program has been undertaken at Forts Belvoir, Carson and Hood. Energy consumption and load demand data will be available in FY79 as a result of this effort. However, this type of data is required now in order to establish cost effectiveness and payback of energy conservation ideas and energy control systems currently being planned or implemented.

While individual buildings at fixed facilities are not metered, fuel oil is delivered to individual tanks and oil delivery receipts are recorded at the Facilities Engineering Directorate at each facility. As a result of collecting data from oil delivery receipts for FY75 and FY76 at three Army installations in the Washington, DC area, FESA was able to perform an analysis that is indicative of heating energy requirements for different types of buildings.

2.0 DATA COLLECTION AND PREPARATION

The buildings selected were checked for functional occupancy as well as heated space (square footage). The oil delivered to a building was divided by the total square footage to provide a gross consumption per square foot for each building type. Similar buildings were then analyzed to obtain a high value, a low value and the average consumption per square foot per year for each building type for which data were available (Appendixes

A, B, C). The data from the three installations were combined using a weighting factor to obtain the heating energy consumption for a building type in the Washington, DC area (Appendix D). The data presented in this report could be normalized on the basis of heating degree days thus direct consumption or extrapolation of consumption can be made by inference by square footage. Pages D-23, 24, 25 are plots of the three installations compared to the area baselines.

2.1 CALCULATION OF THE HIGH, LOW AND AVERAGE HEATING CONSUMPTION

Oil consumption for each of two years was obtained and combined. The average consumption for each building was obtained by dividing by two giving gallons/year.

This number was then multiplied by the BTU's/gallon yielding BTU's/year.

The BTU's/year then divided by the square footage of the building to obtain BTU's/ft²/year.

All the buildings of a class on an installation were separated to give the high and low consumption. The average for that class of buildings on an installation was obtained by summing the total BTU's consumed per ft²/year and dividing by the total number of the buildings for this area.

If the sample consisted of just one building, (its) consumption is used as the average consumption for that type of building.

2.2 CALCULATION OF THE COMBINED INSTALLATION DATA

The total average heating consumption in BTU/ft²/year for each type of building was calculated using:

$$\text{The total average or the average line} = \frac{\sum_i^n \text{building areas}_i \times \text{average consumption}_i}{\sum_i^n \text{building areas}}$$

i = building

The baseline data were calculated using a weighting factor which is a function of the total square footage of a particular building type at an installation. The use of a weighting factor precluded the information from one installation masking the data from a second installation.

$$\text{The baseline of heating consumption for a specific type of building} = \frac{\sum_{i=1}^{n=3} \text{installation consumption}_i \times \text{weighting factor)}}{\text{weighting factor}}$$

i = installation

weighting factor

Weighting factor = weighting factors were derived for each building type at an installation. The weighting factor is a function of the total square footage of a building type at a specific installation.

3.0 ASSUMPTIONS

The data presented are based on the following assumptions:

1. The oil was actually delivered to the specified building tank and receipts reflect the correct building.
2. There is no leakage from the oil tanks and no spillage.
3. A specific building could be off by two tanks of fuel in the two years studied and is a function of the fuel in the tank at the start and finish of FY75 and FY76.
4. The oil was actually consumed in the time period of interest.

The data and conclusions should be applied cautiously since single building samples do not reflect averages and building consumptions is a function of the mechanical equipment located in a specific building.

4.0 RESULTS

The average heating consumption by building type for the three installations ranked from highest to lowest is given in Table 1:

TABLE 1
Ranked Consumption

Rank	Building Type	Heating Consumption* BTU x 10 ³ /sq ft/year
1	Fire Station	323 single sample
2	Museum	302 single sample
3	Theater	213
4	Gymnasium	213 single sample
5	Band Auditorium	210 single sample
6	Motor Repair Shops	176
7	Field House	169 Single sample
8	Chapels	156
9	EM Barracks	136
10	General Instructional Bldgs.	123
11	Library	117 single sample
12	Post Exchange	106
13	Officer's Mess	102 single sample
14	BOQ	102
15	EM Mess	101
16	Laboratories	100
17	Recreational Center	99
18	Warehouses	93
19	EM Barracks with Mess	89
20	Admin Offices	86
21	Officer's Family Housing	85
22	NCO Family Housing	64
23	Commissary	41
24	Bowling Alley	36 single sample

*Values were rounded

Table 2 delineates the distribution of thermal energy at a typical installation. The percent of building space is given relative to the percent of the total heating space requirement for seven different categories of buildings.

TABLE 2

Building Consumption

<u>Category</u>	<u>% of Total Building Space</u>	<u>Relative Heating Requirement</u>	<u>% of Total Heating Requirement</u>
Troop Housing	32.5	1.00	30
Family Housing	27.9	1.45	36
Administration & Training	11.8	1.10	12
Hospital & Medical	3.7	1.20	4
Community Service & Commercial	7.1	1.30	8
Storage	7.6	.65	4
Maintenance Production & Misc.	9.4	.75	6

The study results indicate that community service and repair facilities are the largest energy consumers. The high energy consumption by fire stations and repair facilities is probably due to high ceilings and large doors at these buildings. The community service category and the maintenance category building types represent 14% of an installation's total thermal requirements, but only a small fraction of the total number of buildings found at a fixed facility. As a result, it is anticipated that the implementation of energy conservation concepts and energy management systems in these types of buildings would have a high payback. The ranking and the energy consumption for a given building type will be affected by the consumption factors in Table 3 and may offer an explanation as to the high or low energy consumption of a specific building type. All of these factors contribute to the diversity in consumption

between types of buildings and within types of buildings. Calculating the consumption on a foot-cubed (ft³) basis would narrow the difference between the highest and lowest ranking. However, for the purpose of this report, this information was not developed.

TABLE 3

(From Reference 1)

Factors of Energy Use

PRIMARY

- Equipment
- Climate
- Population
- Building Volume
- Age and Condition
- Functional Use
- Construction

SECONDARY - Operation, time element, i.e., mode of use

THIRD ORDER - Internal and external effects

- i.e., steam supply, radiant effects

FOURTH ORDER - Parasitic effects - i.e., pilot lights

Troop housing and family housing represent the major consumers of thermal energy at a fixed facility because of the large number of these buildings found at an installation. A review of Table 1 in conjunction with Table 2 indicates that "Barracks" types of buildings would be promising candidates for energy conservation measures and energy control systems.

Family housing was the lowest building consumer category at the three installations examined. This could imply that military families are aware of the energy crisis and are practicing energy conservation. In performing

the analysis a discernible trend was noted in that energy consumption was a function of rank, i.e., the higher the rank the more energy consumed. This effect was noted both in Officer and NCO family housing, however, the data collected were not sufficient to draw any conclusions in this report.

5.0 CONCLUSION

The results of this investigation provide a data base of determining the heat energy requirements for different types of buildings at fixed facilities. While the data is based on oil deliveries to three installations in the Washington, DC area, it can provide a basis for implementing energy conservation concepts and selecting buildings for energy management control systems until better data become available.

From a study like this the baseline of heating consumption for every type of building on Army installations can be estimated and the comparison between the installation's consumption and the baseline consumption can be made.

REFERENCES


1. Characterization of Energy Usage on Military Installations, USA
Facilities Engineering Support Agency, 22 October 1974.

APPENDIX A

INSTALLATION NO. 1

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
EM Barracks	4,720 75,520 ft ²	16	Wood-glass	1941	227.708	125.570	164.862	164 862




AREA SQ. FT. ;
ENLISTEDMEN BKS.

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
80Q	4,720	3	Wood-glass	1941	137.968	114.150	125.693	89.810
	5,385	2	Wood-glass	1940-1941	145.043	132.200	138.622	
	6,962	1	Wood-glass	1941			131.815	
	8,142	1	Wood-glass	1941			113.408	
	13,117	1	Wood-glass	1942			60.709	
	16,800	2	Brick-concrete	1947-1948	68.275	55.154	61.715	
	18,360	2	Brick-concrete	1969	85.357	81.472	83.415	
	<u>22,272</u>	2	Brick-concrete	1956	98.908	82.606	90.757	
	168,015 ft ²							

1000 BTU / FT² / YEAR




AREA SQ. FT.

BOQ.

INSTALLATION NO: 1


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Family housing for officers	2,660	3	Brick-wood	1950-1956	88.368	54.552	68.289	89.394
	3,461	4	Brick-wood	1934-1935	179.195	96.596	128.815	
	4,179	4	Brick-wood	1947	128.509	107.805	116.905	
	<u>12,707</u>	4	Brick-wood	1939	80.995	60.965	72.923	
	89,368 ft ²							



FAMILY HOUSING FOR OFFICERS

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
NCO Family Housing	1,946	4	Brick-wood	1930	174.100	112.661	152.158	69.426
	6,305	3	Brick-wood	1956	57.731	52.935	55.707	
	<u>10,705</u>	3	Brick-wood	1956	58.510	56.614	57.453	
	58,814 ft ²							




NCO FAMILY HOUSING

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Administration General Purpose Offices	2,825	1	Brick-concrete	1960			67.348	
	7,680	1	Wood-concrete	1942			93.023	
	11,080	1	Wood-glass	1943			107.805	
	13,618	1	Concrete-glass	1954			136.638	
	15,237	1	Wood-glass	1941			147.341	
	17,146	1	Brick-concrete	1935			88.947	
	23,513	1	Brick-concrete	1932			50.407	
	23,667	1	Brick-concrete	1964			67.595	
	32,913	1	Brick-concrete	1928			59.361	
	147,679 ft ²							84.431

1000 BTU / FT² / YEAR



AREA SQ. FT.


ADMINISTRATION GENERAL PURP. OFFICES

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
General purp. warehouse	7,982	1	Block-steel	1955			31.290	109.457
	9,120	1	Tile-wood	1944			125.754	
	9,211	1	Tile-wood	1944			55.074	
	9,720	1	Tile-wood	1946			40.581	
	10,126	1	Wood-glass	1917			195.303	
	15,000	1	Block-steel	1946			161.219	
	61,159 ft ²							

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Motor repair shop	1,500	1	Wood-steel	1955			31.733	270.293
	3,108	1	Steel-glass	1941			144.436	
	3,108	3	Wood-glass	1940-1942		205.923	364.477	
	5,060	1	Block-steel	1963			288.826	
	5,103	1	Block-steel	1963			731.099	
	5,151	1	Steel-glass	1966			244.503	
	8,556	1	Brick-wood	1939			122.107	
	9,240	2	Brick-wood	1940		139.272	256.886	
	11,220	1	Wood-glass	1945			187.767	
	67,502 ft ²							




MOTOR REP. SHOP

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Chapel bldg	3,278 16,390 ft ²	5	Wood-glass	1941	194.752	152.492	177.758	


1000 BTU / FT²/YEAR



CHAPEL

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Laboratory General Purposes	1,071	1	Concrete-glass	1963			206.928	98.506
	1,830	1	Brick-concrete	1453			415.754	
	2,320	1	Brick-concrete	1963			344.840	
	5,856	1	Concrete	1965			103.290	
	12,925	1	Brick-concrete	1952			91.560	
	13,294	1	Brick-concrete	1957			113.651	
	21,565	1	Block-steel	1959			84.917	
	43,144	1	Block-concrete	1957			72.670	
	102,005 ft ²							




AREA SQ. FT.

LAB

INST. NO: I


INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
General Inst. Building	2,000	1	Steel-glass	1958			178.955	
	5,414	1	Block-concrete	1952			424.371	
	6,966	1	Block-concrete	1947			199.287	
	7,680	1	Wood-concrete	1942			93.023	
	11,474	1	Block-glass	1953			213.355	
	24,332	3	Brick-concrete	1928-1929	132.705	79.175	104.468	
	33,567	1	Brick-concrete	1928			95.866	
	140,097 ft ²						128.838	



INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Enlisted Men's Mess	1,230	1	Block-glass	1955			118.943	101.589
	2,664	1	Wood-glass	1940			159.129	
	2,892	4	Wood-glass	1940-1941	126.058	98.077	111.662	
	4,428	1	Wood-glass	1942			163.475	
	24,045	1	Brick-glass	1965			67.568	
	38,949	1	Block-glass	1968			108.081	
	82,884 ft ²							




AREA FT. SQ.

ENLISTEDMEN MESS.

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Enlisted Men's Barracks with Mess	24,332	1	Brick-concrete	1929			99.959	87.851
	25,716	1	Brick-concrete	1934			112.082	
	30,426	2	Brick-concrete	1940	80.362	63.075	71.719	
	30,435	1	Brick-concrete	1940			89.952	
	141,335 ft ²							

1000 BTU / FT²/YEAR



ENLISTEDMEN BKS WITH MESS
AREA SQ. FT.

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Post-Exchange	3,800	1	Wood-glass	1944			117.334	

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft/yr
					High	Low	Average	
EM Recreation Center	26,310	1	Concrete-concrete brick	1974			91.915	

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Theater	15,552	1	Brick-concrete	1940			193.465	

INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft/yr
					High	Low	Average	
Bowling Alley	22,400	1	Brick-glass	1965			36.321	


INSTALLATION NO: 1

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr.
					High	Low	Average	
Commissary	128,898	1	Brick-concrete	1974			19.008	

INSTALLATION NO: 1


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Field House	22,778	1	Steel-wood	1947			168.908	

1000 BTU / FT² / YEAR



AREA SQ. FT.


DIFFERENT KINDS OF BUILDING



APPENDIX B
INSTALLATION NO. 2

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
B0Q	10,238	2	Concrete, wood, As Concrete, brick, slate	1940-1944 1906	123.645	86.539	105.092 119.146	111.786
	<u>18,626</u> 39,102 ft ²	1						




AREA SQ. FT.

BOQ.

INSTALLATION NO: 2


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Family Housing for Officers	2,765	1	Brick-slate	1935			55.924	82,553
	3,165	1	Brick-slate	1935			69.248	
	4,481	1	Mсны, brick slate	1903			65.923	
	5,040	4	Concrete, brick-slate	1932	135.458	116.139	123.007	
	5,222	1	Mсны, brick slate	1903			72.922	
	5,748	1	Mсны, brick slate	1899			59.295	
	6,024	2	Mсны, brick slate	1903	89.522	66.665	78.094	
	6,488	2	Mсны, brick slate	1892	61.843	40.836	51.340	
	7,588	2	Mсны, brick slate	1908	68.469	65.507	66.988	
	7,890	4	Mсны, brick slate	1896	100.005	66.274	84.530	
	8,400	1	Stone, brick slate	1903			73.567	
	8,675	1	Mсны, brick slate	1908			86.033	
	10,111	1	Mсны, brick	1899			105.952	
140,487 ft ²								



FAMILY HOUSING FOR OFFICERS

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
NCO Family Housing	4,091	1	Concrete, brick-slate	1934			77.854	79.434
	<u>4,184</u> 29,195 ft ²	6	Concrete, brick-slate	1932	99.880	60.798	79.692	




NCO FAMILY HOUSING

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Administration General Purp. Offices	2,933	1	Concrete, wood, as	1941			182.053	77.101
	4,864	1	Concrete, brick-slate	1934			146.534	
	6,082	1	Concrete, brick-slate	1900			80.335	
	6,980	1	Concrete, brick-slate	1895			141.223	
	8,250	1	Concrete, brick-slate	1900			95.658	
	8,607	1	Concrete, brick-as	1899			54.360	
	9,210	1	Concrete Piers wood, as	1941			110.449	
	15,501	1	Concrete, brick-slate	1900			66.812	
	18,888	1	Concrete, brick-slate	1899			58.793	
	35,969	1	Brick, as	1896			52.857	
	117,284 ft ²							

1000 BTU / FT² / YEAR




AREA SQ. FT.

ADMINISTRATION GENERAL PURP. OFFICES

INSTALLATION NO: 2


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
General Purp. Warehouse	1,722	1	Concrete, brick, wood, as	1896			137.886	129.346
	3,230	1	Concrete, brick-slate	1905			92.712	
	8,375	1	Concrete, brick, as	1926		Cooled storage whse.	22.801	
	9,333	1	Concrete, wood, as	1941			52.247	
	14,232	1	Concrete, brick, slate	1943			78.263	
	16,023	1	Concrete, brick	1893			87.156	
	<u>49,686</u>	1	Concrete, brick, slag	1939			192.111	
	102,601 ft ²							



INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Motor Repair Shop	7,626	1	Concrete, Concrete blk, as	1934			230.974	91.990
	8,221	1	Concrete, brick, as	1906			119.990	
	18,095	1	Concrete, brick, as	1940			16.820	
	22,400	1	Concrete, corrugated steel	1940			106.359	
	<u>27,240</u> 83,582 ft ²	1	Concrete, brick, as	1919			82.748	

1000 BTU / FT² / YEAR



AREA SQ. FT.
MOTOR REP. SHOP

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Chapel	10,127 10,127 ft ²	1	Concrete, brick, as	1935			78.087	78.087

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Officer's Mess	65,000	1	Concrete, brick-slate	1896			102.006	

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
EM Mess	8,080	1	Concrete, wood, as	1918			58.486	

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
EM Barracks with Mess	20,081	1	Concrete, brick, slate	1915			93.373	

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft/yr
					High	Low	Average	
Gymnasium	24,877	1	Concrete, brick, slate	1934			212.527	

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Post Exchange	17,562	1	Concrete, brick, slate	1904			57.345	

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Theater	4,851	1	Concrete, brick, as	1929			274.733	

INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Library	6,464	1	Concrete, asbestos shingle, as	1929			117.064	


INSTALLATION NO: 2

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Aud, Band	7,661	1	Concrete, wood, as	1942			209.854	

INSTALLATION NO: 2


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Fire Station	3,588	1	Concrete, wood, brick slate	1909			322,687	

1000 BTU / FT² / YEAR



AREA SQ. FT.

DIFFERENT KINDS OF BUILDING




APPENDIX C

INSTALLATION NO. 3

INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
EM Barracks	4,720 <u>5,310</u> 105,020 ft ²	20 2	Wood-wood Wood-wood	1941 1942	260.676 172.429	57.038 168.791	109.621 170.61	115.788



ENLISTEDMEN BKS.

INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
B0Q	3,016	1	Concrete-bk	1938	203.392	30.519	251.127	
	7,670	5	Wood-wood	1941-1942			135.882	
	8,614	1	Wood-wood	1941			24.558	
	<u>31,720</u>	1	Wood-wood	1952			107.333	
	81,700 ft ²						117.315	




AREA SQ. FT.

BOQ.

INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
NCO Family Housing	<u>14,427</u> 86,562 ft ²	6	B1k-bk	1950	62.872	47.671	55.854	55.854




INST. NO: 3

THE AVERAGE LINE OF H.C. 55854

NCO FAMILY HOUSING

INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Administration General Purp. Offices	736	1	Wood-wood	1942			233.492	126.222
	1,814	1	Blk-blk	1960			125.375	
	1,828	1	Wood-wood	1942			117.713	
	1,920	1	Steel-st	1959			138.155	
	3,108	1	Wood-wood	1941			210.721	
	4,130	1	Wood-wood	1941			185.898	
	7,060	1	Wood-wood	1943			94.163	
	9,804	1	Wood-wood	1942			88.735	
	30,400 ft ²							



ADMINISTRATION GENERAL PURP OFFICES

INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
General Purp Warehouse	9,267	10	Wood-wood	1941	155.946	14.896	57.389	56.503
	10,080	3	Wood-wood	1918	137.326	13.486	58.965	
	10,368	1	Wood-wood	1918			41.407	
	133,278 ft ²							




AREA SQ. FT.

WAREHOUSE

INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Motor Repair Shop	2,220	1	Wood-wood	1941	317.500	115.090	288.072	
	3,108	10	Wood-wood	1941				
	3,558	1	Wood-wood	1941				
	6,000	1	Steel-steel	1964				
	8,120	1	Steel-steel	1970.				
	50,978 ft ²						187.884	

1000 BTU / FT² / YEAR



INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Chapel	<u>3,537</u> 7,074 ft ²	2	Wood-wood	1941	220.529	213.028	216.779	216.779



CHAPEL

INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
General Inst. Building	3,000	3	Tst-tst, bk-bk Wood-wood	1941-1944 1941	83.603	30.03	58.427 85.077	70.689
	<u>7,670</u> 16,670 ft ²	1						



GENERAL INST. BUILDING

INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
En-Men's Mess	2,208 8,832 ft ²	4	Wood-wood	1941	185.272	87.437	131.528	131.528



AREA FT. SQ.

ENLISTEDMEN MESS.

INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
P.X.	2,200	1	Tst-tst	1932				
	2,331	2	Wood-wood	1941	202.282	147.808	147.127	
	3,663	2	Wood-wood	1941	183.227	134.535	175.045	
	14,188 ft ²							158.881
								162.370

AD-A048 324

ARMY FACILITIES ENGINEERING SUPPORT AGENCY FORT BELV--ETC F/G 13/1
BUILDING HEATING ENERGY CONSUMPTION AT FIXED FACILITIES. (U)
JUN 77 M M BOTROS


UNCLASSIFIED

USAFESA-RT-2034


NL

2 OF 2

AD
A048 324



END
DATE
FILMED
2-78
DDC



INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Lab	<u>2,320</u> 2,320 ft ²	1	Steel-steel	1964			167.155	167.155

INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Buflt	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Recreation Bldg	3,663	1	Wood-wood	1941			147.510	

INSTALLATION NO: 3


Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Museum	1,809	1	Tst-tst	1931			302.559	

INSTALLATION NO: 3

Building Type	Building area sq. ft.	no. of bldg	Structure Type	Year Built	1000 BTU/ft ² /year			The total average of heating consumption in thousands of BTU/ft ² /yr
					High	Low	Average	
Commissary	24,096	1	Bk-bk	1918			159.990	



DIFFERENT KINDS OF BUILDING



• SINGLE SAMPLE

APPENDIX D

CONCLUSIONS - COMBINED CONSUMPTION

Building Type	The average of heating consumption 1000 BTU/ft ² /year			The baseline heating consumption in thousands of BTU/ft ² /year
	Inst. #1	Inst. #2	Inst. #3	
Enlisted Men's Barracks	164.862	--	115.788	136.236
weight	1		1.4	
800	89.810	111.786	117.315	101.840
weight	4.3	1	2.7	
Family Hs. for Officers	89.394	82.553	--	85.184
weight	1	1.6		
NCO	69.426	79.434	55.854	64.308
weight	2	1	3	

Building Type	The average of heating consumption 1000 BTU/ft ² /year			The baseline heating consumption in thousands of BTU/ft ² /year
	Inst. #1	Inst. #2	Inst. #3	
Administration Gen. Purp. Offices	84.431	77.101	126.222	
weight	4.9	3.9	1	85.778
Warehouse	109.457	129.346	56.503	
weight	1	1.7	2.2	92.582
Motor Repair Shop	270.293	91.990	187.884	
weight	1.3	1.6	1	176.013
Chapel	177.758	78.087*	216.779	
weight	2.3	1.4	1	156.371

*One building

Building Type	The average of heating consumption 1000 BTU/ft ² /year			The baseline heating consumption in thousands of BTU/ft ² /year
	Inst. #1	Inst. #2	Inst. #3	
Lab	98.506	--	167.155*	100.032
weight	44		1	
General Inst. Bldg.	128.838	--	70.689	122.652
weight	8.4		1	
Enlisted Men's Mess	101.589	58.486*	131.528	100.769
weight	10.3	1	1.1	
Enlisted Men's Barracks with Mess	87.851	93.373*	--	88.541
weight	7.0	1		

*One building

Building Type	The average of heating consumption 1000 BTU/ft ² /year			The baseline heating consumption in thousands of BTU/ft ² /year
	Inst. #1	Inst. #2	Inst. #3	
Post Exchange	117.334*	57.345*	162.370	
weight	1	4.6	3.7	105.580
Recreation Center	91.915*	--	147.510*	
weight	7.2		1	98.695
Theater	193.465*	274.733*	--	
weight	3.2	1		212.815
Commissary	19.008*	--	159.990*	
weight	5.4		1	41.036


*One building


Building Type	The average of heating consumption 1000 BTU/ft ² /year			The baseline heating consumption in thousands of BTU/ft ² /year
	Inst. #1	Inst. #2	Inst. #3	
Bowling Alley	36.321*	--	--	36.321
weight				
Field House	168.908*			168.908
weight				
Officer's Mess	--	102.006*	--	102.006
weight				
Gymnasium	--	212.527*	--	212.527
weight				

*One building

Building Type	The average of heating consumption 1000 BTU/ft ² /year			The baseline heating consumption in thousands of BTU/ft ² /year
	Inst. #1	Inst. #2	Inst. #3	
Library	--	117.064*	--	117.064
weight				
Aud. Band	--	209.854*	--	209.854
weight				
Fire Station	--	322.687*		322.687
weight				
Museum	--	--	302.559*	302.559
weight				


*One building






AREA SQ. FT.

BOQ.



FAMILY HOUSING FOR OFFICERS




1000 BTU / FT²/YEAR


AREA SQ. FT.


NCO FAMILY HOUSING


THE BASELINE OF HEATING CONSUMPTION 64.308




AREA SQ. FT.
 ADMINISTRATION GENERAL PURP OFFICES











AREA SQ. FT.

LAB




GENERAL INST. BUILDING




AREA FT. SQ. ;
ENLISTEDMEN MESS.

1000 BTU / FT²/YEAR




AREA SQ. FT.
ENLISTEDMEN BKS WITH MESS

1000 BTU / FT²/YEAR




POST EXCHANGE


1000 BTU / FT² / YEAR





AREA SQ. FT.
RECREATION CENTER



THEATER







INST. NO:3
 BASELINE

• SINGLE SAMPLE

FESA DISTRIBUTION

US Military Academy
ATTN: Dept of Mechanics
ATTN: Library
West Point, NY 10996

Chief of Engineers
ATTN: DAEN-ASI-L (2)
ATTN: DAEN-FEB
ATTN: DAEN-FEP
ATTN: DAEN-FEU
ATTN: DAEN-FEZ-A
ATTN: DAEN-MCZ-S
ATTN: DAEN-MCE-U
ATTN: DAEN-MCZ-E
ATTN: DAEN-RDL
Dept of the Army
WASH, DC 20314

Director, USA-WES
ATTN: Library
P.O. Box 631
Vicksburg, MS 39181

Commander, TRADOC
Office of the Engineer
ATTN: ATEN
ATTN: ATEN-FE-U
Ft. Monroe, VA 23651

US Army Engr Dist, New York
ATTN: NANEN-E
26 Federal Plaza
New York, NY 10007

USA Engr Dist, Baltimore
ATTN: Chief, Engr Div
P.O. Box 1715
Baltimore, MD 21203

USA Engr Dist, Charleston
ATTN: Chief, Engr Div
P.O. Box 919
Charleston, SC 29402

USA Engr Dist, Savannah
ATTN: Chief, SASAS-L
P.O. Box 839
Savannah, GA 31402

USA Engr Dist Detroit
P.O. Box 1027
Detroit, MI 48231

USA Engr Dist Kansas City
ATTN: Chief, Engr Div
700 Federal Office Bldg
601 E. 12th St
Kansas City, MO 64106

USA Engr Dist, Omaha
ATTN: Chief, Engr Div
7410 USOP and Courthouse
215 N. 17th St
Omaha, NM 68102

USA Engr Dist, Fort Worth
ATTN: Chief, SWFED-D
ATTN: Chief, SWFED-MA/MR
P.O. Box 17300
Fort Worth, TX 76102

USA Engr Dist, Sacramento
ATTN: Chief, SPKED-D
650 Capitol Mall
Sacramento, CA 95814

USA Engr Dist, Far East
ATTN: Chief, Engr Div
APO San Francisco, CA 96301

USA Engr Dist, Japan
APO San Francisco, CA 96343

USA Engr Div, Europe
European Div, Corps of Engineers
APO New York, NY 09757

USA Engr Div, North Atlantic
ATTN: Chief, NADEN-T
90 Church St
New York, NY 10007

USA Engr Div, South Atlantic
ATTN: Chief, SAEN-TE
510 Title Bldg
30 Pryor St, SW
Atlanta, GA 30300

USA Engr Dist, Mobile
ATTN: Chief, SAMEN-C
P.O. Box 2288
Mobile, AL 36601

USA Engr Dist, Louisville
ATTN: Chief, Engr Div
P.O. Box 59
Louisville, KY 40201

USA Engr Dist, Norfolk
ATTN: Chief, NAOEN-D
803 Front Street
Norfolk, VA 23510

USA Engr Div, Missouri River
ATTN: Chief, Engr Div
P.O. Box 103 Downtown Station
Omaha, NB 68101

USA Engr Div, South Pacific
ATTN: Chief, SPDED-TG
630 Sansome St, Rm 1216
San Francisco, CA 94111

AF Civil Engr Center/XRL
Tyndall AFB, FL 32401

Naval Facilities Engr Command
ATTN: Code 04
200 Stovall St.
Alexandria, VA 22332

Defense Documentation Center
ATTN: TCA (12)
Cameron Station
Alexandria, VA 22314

Commander and Director
USA Cold Regions Research Engineering
Laboratory
Hanover, NH 03755

USA Engr Div, Huntsville
ATTN: Chief, HNDED-ME
P.O. Box 1600 West Station
Huntsville, AL 35807

USA Engr Div, Ohio River
ATTN: Chief, Engr Div
P.O. Box 1159
Cincinnati, OH 45201

USA Engr Div, North Central
ATTN: Chief, Engr Div
536 S. Clark St
Chicago, IL 60605

USA Engr Div, Southwestern
ATTN: Chief, SWDED-TM
Main Tower Bldg, 1200 Main St
Dallas, TX 75202

USA Engr Div, Pacific Ocean
ATTN: Chief, Engr Div
APO San Francisco, CA 96558

FORSCOM
ATTN: AFEN
ATTN: AFEN-FE
Ft. McPherson, GA 30330

Officer in Charge
Civil Engineering Laboratory
Naval Construction Battalion Center
ATTN: Library (Code L08A)
Port Hueneme, CA 93043

Commander and Director
USA Construction Engineering
Research Laboratory
P.O. Box 4005
Champaign, IL 61820