


AD-A048 942

AEROSPACE MEDICAL RESEARCH LAB WRIGHT-PATTERSON AFB OHIO F/G 20/1  
USAF BIOENVIRONMENTAL NOISE DATA HANDBOOK, VOLUME 104, A/M32A-6--ETC(U)  
DEC 76 N A FARINACCI  
AMRL-TR-75-50-VOL-104

UNCLASSIFIED

NL

| OF |  
AD  
A048 942



END  
DATE  
FILMED  
2-78  
DDC

ADA 048942

14 AMRL-TR-75-56-VOL-104  
Volume 104

2  
NW



AD No. 1  
MIC FILE COPY

6  
**USAF BIOENVIRONMENTAL NOISE DATA HANDBOOK**  
  
Volume 104.  
  
A/M32A-60A Generator Set and A/M32C-10 Air  
Conditioner, Combined Unit Operation.

9 Technical rpt.,

11 DEC 1976 10 Nick A. Farinacci

12 64p. 16 7231 17 04

DDC  
RECEIVED  
JAN 25 1976  
AUSGIV 50  
F

Approved for public release; distribution unlimited.

AEROSPACE MEDICAL RESEARCH LABORATORY  
AEROSPACE MEDICAL DIVISION  
AIR FORCE SYSTEMS COMMAND  
WRIGHT-PATTERSON AIR FORCE BASE, OHIO 45433

009 850

mt

## NOTICES

When US Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government thereby incurs no responsibility nor any obligation whatsoever, and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data, is not to be regarded by implication or otherwise, as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Please do not request copies of this report from Aerospace Medical Research Laboratory. Additional copies may be purchased from:

National Technical Information Service  
5285 Port Royal Road  
Springfield, Virginia 22161

Federal Government agencies and their contractors registered with Defense Documentation Center should direct requests for copies of this report to:

Defense Documentation Center  
Cameron Station  
Alexandria, Virginia 22314

## TECHNICAL REVIEW AND APPROVAL

This report has been reviewed by the Information Office (OI) and is releasable to the National Technical Information Service (NTIS). At NTIS, it will be available to the general public, including foreign nations.

This technical report has been reviewed and is approved for publication.

**FOR THE COMMANDER**



HENNING E. VON GIERKE  
Director  
Biodynamics and Bionics Division  
Aerospace Medical Research Laboratory

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER AMRL-TR-75-50, Vol. 104	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) USAF BIOENVIRONMENTAL NOISE DATA HANDBOOK: A/M32A-60A Generator Set and A/M32C-10 Air Conditioner, Combined Unit Operation	5. TYPE OF REPORT & PERIOD COVERED Volume 104 of a series	
	6. PERFORMING ORG. REPORT NUMBER	
7. AUTHOR(s) Nick A. Farinacci, Capt, USAF, BSC	8. CONTRACT OR GRANT NUMBER(s)	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Aerospace Medical Research Laboratory Aerospace Medical Division, Air Force Systems Command, Wright-Patterson AFB OH 45433	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 62202F 7231-04-33 7231-04-36	
11. CONTROLLING OFFICE NAME AND ADDRESS Same as above	12. REPORT DATE December 1976	
	13. NUMBER OF PAGES 64	
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)	15. SECURITY CLASS. (of this report) Unclassified	
	15a. DECLASSIFICATION/DOWNGRADING SCHEDULE	
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Noise A/M32C-10 Air Conditioner Noise Environments Bioenvironmental Noise Ground Support Equipment A/M32A-60A Generator Set, Gas Turbine Engine Driven		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) The A/M32A-60A Generator Set is a gas turbine engine driven source of electrical power with pneumatic capability. The A/M32C-10 Air Conditioner is a pneumatic-driven air conditioner designed to provide conditioned air to the aircraft's interior during ground servicing. This report provides measured and extrapolated data defining the bioacoustic environments produced by these two units simultaneously operated as a unit outdoors on a concrete apron at normal rated/loaded conditions. Near-field data are reported for 72 locations in a		

**DDC**  
**RECEIVED**  
**JAN 25 1978**  
**AF**

wide variety of physical and psychoacoustic measures: overall and band sound pressure levels, C-weighted and A-weighted sound levels, preferred speech interference level, perceived noise level, and limiting times for total daily exposure of personnel with and without standard Air Force ear protectors. Far-field data measured at 36 locations are normalized to standard meteorological conditions and extrapolated from 20-3000 meters to derive sets of equal-value contours for these same seven acoustic measures as functions of angle and distance from the source. Refer to Volume 1 of this handbook, <sup>USAF</sup> Bioenvironmental Noise Data Handbook, Vol 1: Organization, Content and Application, <sup>AMRL-TR-75-50(1) 1975</sup>, for discussion of the objective and design of the handbook, the types of data presented, measurement procedures, instrumentation, data processing, definitions of quantities, symbols, equations, applications, limitations, etc. ↑

## PREFACE

This report was prepared by the Biodynamic Environment Branch, Aerospace Medical Research Laboratory, under Project/Task 723104, Measurement and Prediction of Noise Environments of Air Force Operations.

The author acknowledges the efforts of Mr. Robert G. Powell and Mr. Robert A. Lee who assisted in conducting the field measurements, and Mr. John N. Cole who established the data analysis requirements and assisted in the preparation of this report. Mr. Henry Mohlman and Mr. David Eilerman of the University of Dayton assisted in the mechanics of data processing, and Mrs. Norma Peachey and Mr. Mike Patterson typed and prepared the graphics.

ACCESSION for	
NTIS	White Section <input checked="" type="checkbox"/>
DDC	Buff Section <input type="checkbox"/>
UNANNOUNCED	<input type="checkbox"/>
CLASSIFICATION	
DISTRIBUTION/AVAILABILITY CODES	
SPECIAL	
A	

## Table of Contents

	<i>Page</i>
<b>INTRODUCTION</b> .....	3
<b>NEAR-FIELD NOISE</b> .....	4
<b>FAR-FIELD NOISE</b> .....	5

### List of Tables

<b>A/M32-A60A GENERATOR SET NEAR-FIELD NOISE</b>	
1. Test Condition for Noise Measurements .....	4
2. Measured Sound Pressure Level	
1/3 Octave Band .....	6—8
Octave Band .....	9—11
3. Measures of Human Noise Exposure .....	12—14
<b>A/M32C-10 AIR CONDITIONER NEAR-FIELD NOISE</b>	
1. Test Condition for Noise Measurements .....	4
4. Measured Sound Pressure Level	
1/3 Octave Band .....	15—17
Octave Band .....	18—20
5. Measures of Human Noise Exposure .....	21—23
<b>FAR-FIELD NOISE FOR COMBINED UNIT OPERATION</b>	
6. Measured Sound Pressure Level	
1/3 Octave Band .....	24—25

### List of Figures

<b>NEAR-FIELD NOISE</b>	
1. Measurement Locations .....	27
<b>FAR-FIELD NOISE</b>	
1. Measurement Locations .....	27
2. Normalized Noise Levels .....	28—29
3. Overall Sound Pressure Level — Contours .....	30—31
4. C-Weighted Sound Level — Contours .....	32—33
5. A-Weighted Sound Level — Contours .....	34—35
6. Perceived Noise Level — Contours .....	36—37
7. Speech Interference Level — Contours .....	38—39
8. Permissible Exposure Time — Contours .....	40—43
9. Octave Band Sound Pressure Level — Contours .....	44—61

## INTRODUCTION

The A/M32A-60A Generator Set, which is manufactured by the HOL-GAR Manufacturing Corporation, is a gas turbine engine-driven source of electric power. This unit also provides pneumatic power to drive the A/M32C-10 Air Conditioner, manufactured by United Aircraft Products, Inc., providing conditioned air to an aircraft's interior during ground servicing.

This volume provides measured and extrapolated data defining the bioacoustic environments produced by these units. Such data are essential to evaluate ear protection requirements, limiting personnel exposure times, voice communication capabilities, and annoyance problems associated with the combined simultaneous operation of the A/M32A-60A generator set and the A/M32C-10 air conditioner.

This volume is one of a series published by the Aerospace Medical Research Laboratory (AMRL) under the same report number (AMRL-TR-75-50) as a multi-volume handbook that quantifies the noise environments produced at flight/ground crew locations and in surrounding communities by operations of Air Force aircraft and ground support equipment. The far-field, community-type, noise data in the handbook described the noise produced during *ground operations* of aircraft, ground equipment, and other ground-based equipment or facilities.

Volume 1 of this handbook discusses the objectives and design of the handbook, the types of data presented, measurement procedures, instrumentation, data processing, definitions of quantities, symbols, equations, applications, limitations, etc. Volume 2 provides a method and data for adjusting the handbook's far-field noise data, which are for standard meteorological conditions (15C temperature, 70% rel humidity, 0.760 meters Hg barometric pressure) to derive comparable data for other meteorological conditions. Refer to *Volumes 1 and 2* (references 1 and 2) for such information because it is not repeated in other handbook volumes.

A cumulative index lists those aerospace systems contained in the handbook, and identifies the specific volumes containing each type of environmental noise data available (i.e., inflight/flight crew and passenger noise, near-field/ground crew noise, far-field/community noise). Volume numbers are assigned sequentially as individual volumes are published. This index is periodically updated as individual volumes are published, and is available upon request from AMRL/BBE, Wright-Patterson AFB, OH 45433. Organizations on the distribution list for the handbook will automatically receive a copy of the updated index as it is generated.

Direct any questions concerning the technical data in this report and other handbook volumes to: AMRL/BBE, Wright-Patterson AFB, OH 45433; Autovon 78-53675 or 78-53664; Commercial (513) 255-3675 or (513) 255-3664.

1. Cole, John N., *USAF Bioenvironmental Noise Data Handbook, Volume 1: Organization, Content and Application*, AMRL-TR-75-50 (1), Aerospace Medical Research Laboratory, Wright-Patterson Air Force Base, Ohio, 1975.
2. Cole, John N., *USAF Bioenvironmental Noise Data Handbook, Volume 2: Procedure to Evaluate Effects of Non-standard Meteorological Conditions on Far-Field Noise*, AMRL-TR-75-50 (2), AMRL, WPAFB, OH, 1975.

## NEAR-FIELD NOISE

### MEASUREMENTS

A standard A/M32A-60A Generator Set and a standard A/M32C-10 Air Conditioner (being driven by the generator) were simultaneously operated outdoors on a concrete apron at normal rated conditions. The generator set was loaded at 100 amp, 240 volts AC, 3 phase by an M24T-8 load bank, supplying 40 PSI air to drive the air conditioner, which had an output of 40 lb/min. No significant sound-reflective surfaces were present except the ground plane. The load bank was physically located so as to not interfere with the two unit's noise field. Table 1 notes the surface meteorological conditions at the time of measurement.

Figure 1 identifies 108 noise measurement locations at a height of 1.5 meters above the concrete apron (nominal ear level of ground crew). The 0 degree reference direction passes through the tow bar. The 72 locations on the four inner circles are in the acoustic near-field of the source where the sound wave fronts generally do not spherically diverge and the source appears to be spatially distributed (i.e., not a point source). Consequently, these near-field data cannot be extrapolated to longer distances but do properly define the levels at locations close to the unit.

Table 1 lists the alphabetic designator used on the data pages in this report to identify the test condition. The designator A means test condition A. Such a descriptor is essential in many handbook volumes that involve multiple combinations of location/conditions. It is used in this report to maintain format consistency.

### RESULTS

The measured data presented in Tables 2 and 4 define the sound pressure levels (SPL) produced by the simultaneous operation of the A/M32A-60A and the A/M32C-10 units respectively at the 72 specified, near-field locations. This table includes the overall, 1/3 octave band, and octave band levels. From these data one can calculate the variety of measures in Tables 3 and 5 which are widely used to assess the effects of noise on personnel and their performance.

For data at other intermediate near-field locations (i.e., for radial distances less than 20 meters) you can interpolate between the 108 measured data points. All near-field data are for the meteorological conditions at the time of test but are valid for all typical airbase meteorology because of the short distances over which the sound is propagated.

TABLE 1

#### TEST CONDITION FOR NOISE MEASUREMENTS

Edwards AFB, 3 June 1975

A/M32A-60A Generator Set, Gas Turbine Engine Driven  
FSN 6115-420-8486, Mfr. Part # 69E39110, and

A/M32C-10 Air Conditioner  
FSN 4120-196-5252, Mfr. Part # UA532888-1

#### Operation

A Generator loaded at 100 amp, 240 VAC,  
3 phase by M24T-8 load bank and  
supplying 40 PSI air to drive the air  
conditioner whose output is 40 lb/min.

#### Meteorology

Temperature	29 C
Bar Pressure	0.693 M Hg
Rel Humidity	24 %

## FAR-FIELD NOISE

### MEASUREMENTS

Noise measurements were also made on the same A/M32A-60A and A/M32C-10 units under the same test conditions at the outer circle locations on Figure 1. These 36 locations are assumed to be in the acoustic far-field of the source where the sound wave fronts spherically diverge and the unit may be regarded as a point noise source. Under these far-field conditions, the measured data can be extrapolated to longer distances.

### RESULTS

Table 6 lists the overall and 1/3 octave band SPL measured at the 36 far-field locations under the meteorological conditions at the time of test. These data were normalized to 30 meters distance and standard meteorological conditions (15C temperature, 70% rel humidity, 0.760 meter Hg barometric pressure) and used to derive the graphic data in Figure 2 which provides a compact summary of the far-field noise characteristics of the two simultaneously operating units.

These measured data were also used to derive sets of equal noise contours (Figures 3 through 9) describing seven different measures of noise as functions of angle and distance from the source for standard day meteorology. Note that Figure 8 contours identify limiting exposure time for personnel. Missing data points on any of the contours are the result of eliminating measured data which contained excessive influence of spurious background noise present at the time of measurement. In some cases, contour levels at these missing data points were estimated and indicated with dashed lines.

Volume 2 of the handbook defines the influence of meteorology on far-field noise environments and provides, if required, the factors necessary to adjust the handbook standard meteorological day data.



TABLE: MEASURED SOUND PRESSURE LEVEL (DB)																				
2 1/3 OCTAVE BAND																				
NOISE SOURCE/SUBJECT: ( OPERATION: )																				
A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )																				
AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, )																				
COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )																				
NEAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )																				
IDENTIFICATION: )																				
) OMEGA 3.2																				
) TEST 75-030-001																				
) RUN 02																				
) 10 OCT 75																				
) PAGE F2																				
FREQ (HZ)	DISTANCE (M)-->	ANGLE (DEG)-->	200	300	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	OVERALL
CONDITION----->	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A
	4	4	200	300	400	500	630	800	1000	1250	1600	2000	2500	3150	4000	5000	6300	8000	10000	OVERALL
25	83<	81<	81<	88<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<	81<
31.5	82<	82<	82<	85<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<
40	84<	82<	82<	85<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<	82<
50	86	87	87	85	87	88	88	88	87	88	88	88	88	88	88	88	88	88	88	88
63	90	90	90	91	93	91	91	91	91	91	91	91	91	91	91	91	91	91	91	91
80	93	95	95	96	96	97	97	97	97	97	97	97	97	97	97	97	97	97	97	97
100	88	91	91	96	96	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98
125	90	91	89	89	90	93	93	93	93	93	93	93	93	93	93	93	93	93	93	93
160	90	95	95	95	93	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
200	91	89	89	90	91	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
250	95	95	95	95	96	97	97	97	97	97	97	97	97	97	97	97	97	97	97	97
315	95	95	95	96	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99
400	84	86	86	88	91	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90
500	89	85	85	87	90	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
630	87	88	88	88	91	91	91	91	91	91	91	91	91	91	91	91	91	91	91	91
800	88	87	87	88	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90
1000	82	83	83	85	87	86	86	86	86	86	86	86	86	86	86	86	86	86	86	86
1250	81	80	79	79	82	84	84	84	84	84	84	84	84	84	84	84	84	84	84	84
1600	79	77	77	79	79	79	79	79	79	79	79	79	79	79	79	79	79	79	79	79
2000	79	79	79	81	86	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88
2500	79	80	80	80	85	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87
3150	81	82	84	84	85	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87
4000	81	82	83	83	84	88	88	88	88	88	88	88	88	88	88	88	88	88	88	88
5000	82	82	82	82	86	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85
6300	82	80	81	83	83	83	83	83	83	83	83	83	83	83	83	83	83	83	83	83
8000	79	79	79	80	81	83	83	83	83	83	83	83	83	83	83	83	83	83	83	83
10000	81	82	83	83	85	87	87	87	87	87	87	87	87	87	87	87	87	87	87	87
OVERALL	102	103	104	105	106	110	109	108	107	107	107	107	107	107	107	107	107	107	107	107

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)										
1/3 OCTAVE BAND										
IDENTIFICATION:										
OMEGA 3.2										
TEST 75-030-001										
RUN 03										
10 OCT 75										
PAGE F3										
NOISE SOURCE/SUBJECT: ( OPERATION: )										
A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )										
AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, )										
COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )										
NEAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )										
FREQ (HZ)	DISTANCE (M)-->	2	2	2	2	2	2	2	2	
ANGLE (DEG)-->	160	180	200	220	240	260	280	300	320	
CONDITION----->	A	A	A	A	A	A	A	A	A	
25	93	87<	88<	86<	85<	83<	83<	83<	85<	86<
31.5	90	87	89	85<	84<	82<	82<	82<	85<	86<
40	93	90	90	88	87	86<	87	87	85<	88
50	93	91	91	89	89	91	88	88	89	92
63	97	95	93	91	92	93	93	93	96	96
80	98	96	94	92	91	93	93	95	96	97
100	96	94	94	92	93	93	90	93	93	94
125	100	101	99	96	95	96	96	94	93	93
160	103	104	103	102	101	99	99	101	97	96
200	103	104	102	100	99	99	100	99	99	98
250	107	106	105	100	98	96	96	99	98	99
315	104	106	104	99	97	96	97	96	99	102
400	102	103	101	94	92	90	93	95	97	99
500	101	103	99	93	93	92	93	94	96	99
630	94	99	93	92	92	94	93	93	92	93
800	90	93	96	94	92	93	93	94	95	92
1000	88	89	93	89	88	87	85	88	91	90
1250	89	89	88	85	84	84	84	82	85	88
1600	87	86	84	84	84	82	82	83	82	86
2000	86	85	84	83	85	82	82	87	90	88
2500	84	87	84	82	83	83	83	86	87	88
3150	89	91	89	87	87	89	88	89	88	90
4000	90	93	91	87	88	90	88	88	92	91
5000	88	90	90	88	88	87	85	85	88	91
6300	88	91	92	89	88	88	85	85	87	89
8000	88	90	90	88	87	87	85	85	86	88
10000	90	90	90	89	90	88	88	90	91	92
OVERALL	112	113	111	108	107	107	107	107	108	109

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.



TABLE: MEASURED SOUND PRESSURE LEVEL (DB)										IDENTIFICATION:										
2										OMEGA 3.2										
NOISE SOURCE/SUBJECT:										TEST 75-030-001										
( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )										RUN 82										
( AND A/M32C-18 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, )										10 OCT 75										
( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )										PAGE J2										
( NEAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )																				
FREQ (HZ)	DISTANCE (M)-->	ANGLE (DEG)-->	CONDITION-->	260	280	300	320	340	4	2	2	2	2	2	2	2	2	2	2	2
31.5	86	87	91	91	93	93	93	93	93	91	91	91	91	92	92	94	94	93	95	95
63	95	96	97	99	100	100	100	100	100	101	100	100	100	99	98	98	98	98	99	99
125	94	97	99	99	100	100	100	100	100	100	100	100	100	100	101	101	101	102	104	104
250	98	98	99	101	102	106	106	106	106	104	103	103	103	103	102	102	102	103	106	106
500	91	91	93	95	96	105	105	105	105	104	103	103	103	101	99	97	97	97	99	99
1000	90	89	91	93	91	95	91	91	91	94	93	93	93	93	93	92	92	93	94	94
2000	84	83	85	89	91	91	91	91	91	94	93	93	95	95	91	87	87	87	87	87
4000	86	87	87	90	92	95	91	91	91	96	96	96	93	93	91	90	91	91	91	91
8000	86	85	86	88	89	94	94	94	94	94	94	94	91	91	91	91	91	92	92	92
OVERALL	102	103	104	105	106	110	109	108	108	107	107	107	107	107	107	107	107	108	109	109

=

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)										
2										
NOISE SOURCE/SUBJECT: ( OPERATION: )										
A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )										
AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, )										
COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )										
NEAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )										
IDENTIFICATION: )										
OMEGA 3.2										
TEST 75-030-001										
RUN 03										
10 OCT 75										
PAGE J3										
FREQ (HZ)	DISTANCE (M)-->	2	2	2	2	2	2	2	2	
ANGLE (DEG)-->	160	180	200	220	240	260	280	300	320	
CONDITION-->	A	A	A	A	A	A	A	A	A	
31.5	96	93	94	91	90	89	89	89	90	92
63	101	99	98	95	95	97	96	97	99	100
125	105	106	105	103	102	101	101	102	100	99
250	109	110	108	104	103	102	103	103	103	105
500	105	107	103	98	97	97	98	99	100	102
1000	94	95	98	96	94	94	94	95	96	95
2000	90	91	88	88	89	87	87	90	92	92
4000	94	96	95	92	92	93	92	92	94	95
8000	94	95	95	94	93	92	91	92	93	94
OVERALL	112	113	111	108	107	107	107	107	108	109



MEASURES OF HUMAN NOISE EXPOSURE										IDENTIFICATIONS			
3										OMEGA 3.2			
NOISE SOURCE/SUBJECT: ( OPERATION: )										TEST 75-030-001			
A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )										RUN 02			
AND A/M32C-10 AIR COND. ( 3PH, BY H24T-8 LOAD BANK, )										10 OCT 75			
COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )										PAGE H2			
NEAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )													
HAZARD/PROTECTION													
C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN DBC) AT EAR													
A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN DBA) AT EAR													
MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)													
NO PROTECTION													
OASLC	102	103	104	105	106	110	109	108	106	107	107	107	109
OASLA	96	96	97	99	100	105	105	104	103	101	100	100	102
T	60	60	50	36	30	13	13	15	16	25	30	30	21
MINIMUM QPL EAR MUFFS													
OASLA*	79	80	81	82	83	87	86	85	84	84	84	85	86
T	960	960	807	679	571	285	339	404	460	400	480	484	339
AMERICAN OPTICAL 1700 EAR MUFFS													
OASLA*	74	75	77	77	79	82	81	80	80	79	79	80	82
T	960	960	960	960	960	679	807	960	960	960	960	960	679
V-51R EAR PLUGS													
OASLA*	73	73	75	76	77	82	82	80	79	78	77	78	80
T	960	960	960	960	960	679	679	960	960	960	960	960	960
AMERICAN OPTICAL 1700 EAR MUFFS PLUS V-51R EAR PLUGS													
OASLA*	58	59	60	62	62	66	66	65	64	63	63	63	65
T	960	960	960	960	960	960	960	960	960	960	960	960	960
H-133 GROUND COMMUNICATION UNIT													
OASLA*	69	70	71	72	73	76	76	76	75	74	74	74	76
T	960	960	960	960	960	960	960	960	960	960	960	960	960
COMMUNICATION													
PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN DB)													
PSIL	88	88	90	92	93	97	98	96	97	94	92	92	94
ANNOYANCE													
PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PNOB)													
TONE CORRECTION (C IN DB)													
PNLT	111	111	112	115	116	118	120	119	120	117	115	115	117
C	1	1	1	1	1	0	1	1	3	2	1	1	1

\* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.

TABLE: MEASURES OF HUMAN NOISE EXPOSURE

NOISE SOURCE/SUBJECT:		OPERATION:										IDENTIFICATIONS		
A/M32A-60A GENERATOR SET	(	GEN LOADED 100AMP, 240VAC												OMEGA 3.2
AND A/M32C-10 AIR COND.	(	3PH, BY M24T-8 LOAD BANK,												TEST 75-030-001
COMBINED UNIT OPERATION	(	40 PSI AIR TO A/M32C-10,												RUN 03
NEAR FIELD NOISE LEVELS	(	AC AIR OUTPUT 40 LBS/MIN												10 OCT 75
	(													PAGE H3
			2	2	2	2	2	2	2	2	2	2	2	
			160	180	200	220	240	260	280	300	320	340		
			A	A	A	A	A	A	A	A	A	A		
HAZARD/PROTECTION														
C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN DB) AT EAR														
A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN DB) AT EAR														
MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)														
NO PROTECTION														
			112	113	111	108	107	106	107	107	108	109		
			105	107	105	102	101	101	101	101	103	104		
			13	9	13	21	25	25	25	25	18	15		
MINIMUM OPT EAR MUFFS														
			89	90	88	85	84	83	84	84	84	85		
			202	170	240	404	480	571	480	480	480	404		
AMERICAN OPTICAL 1700 EAR MUFFS														
			85	85	84	81	79	79	79	80	80	81		
			404	404	400	807	960	960	960	960	960	807		
V-51R EAR PLUGS														
			84	85	83	79	78	77	78	78	79	81		
			480	404	571	960	960	960	960	960	960	807		
AMERICAN OPTICAL 1700 EAR MUFFS PLUS V-51R EAR PLUGS														
			68	69	68	64	63	63	63	64	65	65		
			960	960	960	960	960	960	960	960	960	960		
M-133 GROUND COMMUNICATION UNIT														
			78	79	78	75	74	74	74	75	75	76		
			960	960	960	960	960	960	960	960	960	960		
COMMUNICATION														
PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN DB)														
			96	98	97	94	93	93	93	95	96	96		
ANNoyANCE														
PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PHD8)														
TONE CORRECTION (C IN DB)														
			120	121	120	117	116	116	115	117	119	119		
			1	0	1	1	1	0	0	1	2	1		
			1	0	1	1	1	0	0	1	2	1		

\* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)										IDENTIFICATIONS:										
1/3 OCTAVE BAND																				
NOISE SOURCE/SUBJECT:																				
( OPERATION:																				
A/M32C-10 AIR CONDITIONER ( AC AIR OUTPUT 40LBS/MIN,																				
AND A/M32A-60A GEN. SET ( GEN LOADED 100AMP, 240VAC										OMEGA 3-2										
( COMBINED UNIT OPERATION ( 3PH, BY M24T-8 LOAD BANK,										TEST 75-030-001										
( NEAR FIELD NOISE LEVELS ( 40 PSI AIR TO A/M32C-10 )										RUN 04										
										10 OCT 75										
										PAGE F1										
FREQ (HZ)	DISTANCE (M)-->	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
ANGLE (DEG)-->	0	20	40	60	80	100	120	140	160	180	200	220	240							
CONDITION----->	A	A	A	A	A	A	A	A	A	A	A	A	A							
25	79<	83<	84<	83<	83<	80<	76<	80<	83<	83<	81<	80<	79<	81<	80<	79<	81<	80<	79<	81<
31.5	78<	82<	83<	83<	77<	78<	77<	79<	83<	80<	83<	79<	83<	80<	83<	79<	83<	80<	79<	83<
40	76<	79<	79<	80<	80<	80<	79<	82<	84<	82<	84<	82<	84<	82<	84<	82<	84<	82<	84<	82<
50	78<	82<	83<	83<	82<	84	84	85	86	87	86	85	84	83	82	81	80	79	80	81
63	83	84	87	87	88	88	87	90	91	91	91	91	91	91	91	91	91	91	91	91
80	90	88	89	91	93	93	94	95	96	96	96	96	96	96	96	96	96	96	96	96
100	90	88	88	88	93	94	96	96	96	98	95	96	95	96	95	96	95	96	95	96
125	90	86	87	92	91	91	92	91	93	94	93	92	89	93	92	89	93	92	89	93
160	92	89	91	94	96	94	95	96	95	95	94	92	93	94	92	93	94	92	93	94
200	85	84	86	86	88	90	89	90	88	88	86	86	87	88	86	87	88	86	87	88
250	81	80	84	85	85	85	85	90	93	96	91	87	85	91	87	85	91	87	85	91
315	84	82	82	83	85	85	85	91	95	98	97	93	88	97	93	88	97	93	88	97
400	77	78	82	83	83	85	88	93	93	93	91	91	87	91	91	87	91	91	87	91
500	76	77	83	86	86	89	91	96	94	91	90	91	88	91	91	88	91	91	88	91
630	78	77	85	84	87	88	87	87	87	87	85	86	80	87	85	80	87	85	80	87
800	75	79	81	79	83	80	82	82	87	87	85	87	80	87	85	80	87	85	80	87
1000	77	76	77	77	76	76	78	79	80	81	81	84	80	81	84	80	81	84	80	81
1250	74	77	77	77	78	76	78	79	82	80	80	81	80	80	81	80	80	81	80	80
1600	74	74	76	76	79	76	79	79	80	79	78	79	79	78	79	79	78	79	79	79
2000	79	77	79	76	78	79	81	82	85	81	80	85	83	81	80	85	83	81	80	85
2500	78	76	78	77	77	77	81	83	84	82	83	84	82	83	84	82	83	84	82	83
3150	79	78	78	79	78	79	81	81	85	83	84	83	82	84	83	82	84	83	82	84
4000	77	76	77	77	79	80	83	87	84	84	84	83	82	84	83	82	84	83	82	84
5000	58	82	77	77	77	79	84	88	90	89	85	83	81	84	83	82	84	83	81	84
6300	76	76	76	76	76	77	83	84	85	84	80	81	78	84	80	81	78	84	80	81
8000	73	73	74	74	74	75	81	82	84	81	79	78	77	84	81	79	78	77	84	81
10000	76	73	79	78	81	81	87	88	90	84	84	84	81	84	84	81	84	84	81	84
OVERALL	98	97	98	100	101	101	103	104	105	106	104	103	101	106	104	103	101	106	104	103

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

1/3 DELTA 8000  
 1/3 DELTA 2000 SURGEONE GENERAL 1000  
 1/3 DELTA 8000  
 1/3 DELTA 2000 SURGEONE GENERAL 1000

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)										IDENTIFICATION											
4 1/3 OCTAVE BAND																					
NOISE SOURCE/SUBJECT: ( OPERATION: )																					
A/M32C-10 AIR CONDITIONER ( AC AIR OUTPUT 40LBS/MIN, )																					
AND A/M32A-60A GEN. SET ( GEN LOADED 100AMP, 240VAC )																					
COMBINED UNIT OPERATION ( 3PH, BY M24T-6 LOAD BANK, )																					
NEAR FIELD NOISE LEVELS ( 40 PSI AIR TO A/M32C-10 )																					
FREQ (HZ)	DISTANCE (M)-->	4	4	4	4	4	4	4	4	2	2	2	2	2	2	2	2	2	2	2	
	ANGLE (DEG)-->	260	280	300	320	340	0	20	40	60	80	100	120	140	160	180	200	220	240	260	280
	CONDITION-->>	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A
25		79<	81<	85<	85<	85<	81<	79<	77<	77<	77<	77<	77<	77<	77<	77<	77<	77<	77<	77<	77<
31.5		76<	77<	80<	80<	80<	79<	78<	78<	78<	78<	78<	78<	78<	78<	78<	78<	78<	78<	78<	78<
40		83<	80<	80<	80<	80<	81<	80<	80<	80<	80<	80<	80<	80<	80<	80<	80<	80<	80<	80<	80<
63		88	86	83	83	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85
80		92	92	91	90	89	89	89	89	89	89	89	89	89	89	89	89	89	89	89	89
100		93	92	93	89	89	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90
125		93	92	94	93	90	91	90	89	90	91	93	91	90	93	91	90	93	91	90	93
160		87	87	87	86	84	87	87	86	86	86	86	86	86	86	86	86	86	86	86	86
200		85	82	83	83	81	84	83	83	83	83	83	83	83	83	83	83	83	83	83	83
250		88	86	84	87	82	83	83	82	84	86	88	88	88	88	88	88	88	88	88	88
315		85	85	84	83	78	81	82	81	86	88	88	88	88	88	88	88	88	88	88	88
400		88	87	84	84	78	83	80	82	87	90	91	92	92	92	92	92	92	92	92	92
500		88	84	83	83	79	83	79	82	86	86	85	86	86	86	86	86	86	86	86	86
630		89	84	83	81	77	80	81	80	83	83	81	83	81	83	81	83	81	83	81	83
800		79	79	79	78	73	82	85	78	78	77	78	77	78	77	78	77	78	77	78	77
1000		80	78	79	77	71	78	83	75	78	76	76	76	76	76	76	76	76	76	76	76
1250		77	76	75	74	72	75	78	75	75	75	75	75	75	75	75	75	75	75	75	75
1600		82	77	76	77	76	83	86	83	79	75	78	78	78	78	78	78	78	78	78	78
2000		82	78	76	76	76	84	84	81	78	78	80	80	80	80	80	80	80	80	80	80
2500		82	79	74	76	76	84	85	82	80	78	80	81	82	82	82	82	82	82	82	82
3150		80	81	75	75	75	82	83	78	80	78	81	81	83	83	83	83	83	83	83	83
4000		79	77	79	79	74	84	85	82	85	78	79	78	86	86	86	86	86	86	86	86
5000		76	75	73	74	74	84	83	78	81	77	78	78	84	84	84	84	84	84	84	84
6300		74	73	70	73	72	80	80	75	77	75	75	75	81	81	81	81	81	81	81	81
8000		79	78	73	72	71	78	75	75	80	81	80	80	87	87	87	87	87	87	87	87
10000		101	100	96	97	97	99	99	98	100	101	101	101	102	102	102	102	102	102	102	102
OVERALL																					

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

IDENTIFICATION: OMEGA 3.2 TEST 75-030-001 RUN 05 10 OCT 75 PAGE F2

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)		IDENTIFICATIONS:													
1/3 OCTAVE BAND		OMEGA 3.2 TEST 75-038-001 RUN 06 10 OCT 75 PAGE F3													
NOISE SOURCE/SUBJECT:		OPERATION:													
A/M32C-10 AIR CONDITIONER ( AC AIR OUTPUT 40LBS/MIN, )															
AND A/M32A-60A GEN. SET ( GEN LOADED 100AMP, 240VAC )															
COMBINED UNIT OPERATION ( 3PH, BY M24T-8 LOAD BANK, )															
NEAR FIELD NOISE LEVELS ( 40 PSI AIR TO A/M32C-10 )															
FREQ (HZ)	DISTANCE (M)-->	2	2	2	2	2	2	2	2	2	2	2	2	2	2
	ANGLE (DEG)-->	160	200	220	240	260	280	300	320	340					
	CONDITION----->	A	A	A	A	A	A	A	A	A					
25		81<	80<	77<	77<	77<	76<	81<	76<	79<					
31.5		79<	80<	83<	81<	81<	82<	81<	81<	79<					
40		81<	84<	86	87<	87<	86	84	84	85					
50		82<	83<	82<	81<	81<	86	84	84	85					
63		87	89	88	88	87	91	91	89	89					
80		92	91	92	90	91	90	92	90	90					
100		92	91	92	89	89	90	89	89	89					
125		90	89	89	89	89	90	89	89	89					
160		94	95	93	92	92	92	92	92	91					
200		94	93	92	90	92	89	88	86	86					
250		91	90	89	88	84	85	85	83	85					
315		92	92	90	88	88	87	84	84	85					
400		90	92	89	90	86	87	86	86	85					
500		90	90	89	91	89	87	88	88	86					
630		84	86	83	84	83	86	82	80	78					
800		85	85	82	81	80	84	81	81	77					
1000		78	78	78	79	80	78	78	77	75					
1250		82	80	78	79	78	78	77	78	80					
1600		80	79	76	78	76	75	77	75	76					
2000		81	80	80	78	77	78	79	77	79					
2500		83	80	81	78	78	76	77	75	78					
3150		86	82	84	81	80	80	80	77	79					
4000		88	84	85	81	79	80	80	78	79					
5000		95	86	86	82	78	76	79	85	80					
6300		91	84	85	81	77	77	78	79	80					
8000		86	82	83	79	76	75	76	74	76					
10000		91	88	87	84	82	81	80	74	76					
OVERALL		103	102	102	100	100	100	99	98	98					

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

TABLE 1		MEASURED SOUND PRESSURE LEVEL (DB)										IDENTIFICATION:				
OCTAVE BAND		4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
NOISE SOURCE/SUBJECT:		( OPERATION: )														
A/M32C-10 AIR CONDITIONER		( AC AIR OUTPUT 40LBS/MIN, )														
AND A/M32A-68A GEN. SET		( GEN LOADED 100AMP, 240VAC )														
COMBINED UNIT OPERATION		( 3PH, BY M24T-6 LOAD BANK, )														
NEAR FIELD NOISE LEVELS		( 40 PSI AIR TO A/M32C-10 )														
DISTANCE (M)-->		4	4	4	4	4	4	4	4	4	4	4	4	4	4	4
ANGLE (DEG)-->		0	20	40	60	80	100	120	140	160	180	200	220	240		
CONDITION----->		A	A	A	A	A	A	A	A	A	A	A	A	A	A	A
FREQ (HZ)		83	86	87	87	86	84	83	85	88	87	87	87	85	83	
31.5		91	90	92	93	94	93	95	96	97	98	98	98	97	93	
63		95	93	94	98	98	98	99	100	99	101	99	99	98	98	
125		88	87	90	92	92	92	94	97	99	101	98	94	91		
250		82	82	88	89	92	92	94	98	98	97	94	95	93		
500		80	82	83	83	85	82	84	85	89	88	87	89	89		
1000		82	81	82	81	83	82	85	86	88	86	86	88	86		
2000		84	84	82	83	83	84	87	90	92	90	89	88	86		
4000		80	79	81	81	82	83	89	90	92	88	86	86	83		
8000		98	97	98	100	101	101	103	104	105	106	104	104	183	101	
OVERALL																

MEASUREMENTS MADE AT THE UNIVERSITY OF MICHIGAN, ANN ARBOR, MICHIGAN, U.S.A. ON 10 OCTOBER 1975. THE TEST WAS CONDUCTED IN THE ANOISE CHAMBER, 40 PSI AIR TO A/M32C-10 AND A/M32A-68A GEN. SET. THE TEST WAS CONDUCTED IN THE ANOISE CHAMBER, 40 PSI AIR TO A/M32C-10 AND A/M32A-68A GEN. SET. THE TEST WAS CONDUCTED IN THE ANOISE CHAMBER, 40 PSI AIR TO A/M32C-10 AND A/M32A-68A GEN. SET.

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)		IDENTIFICATION:																		
4		OMEGA 3.2																		
		TEST 75-030-001																		
		RUN 05																		
		10 OCT 75																		
		PAGE J2																		
NOISE SOURCE/SUBJECT:		OPERATION:																		
A/M32C-10 AIR CONDITIONER		AC AIR OUTPUT 40LBS/MIN,																		
AND A/M32A-60A GEN. SET		GEN LOADED 100AMP, 240VAC																		
COMBINED UNIT OPERATION		3PH, BY M24T-6 LOAD BANK,																		
NEAR FIELD NOISE LEVELS		40 PSI AIR TO A/M32C-10																		
FREQ (HZ)	DISTANCE (M)-->	4	4	4	4	4	4	4	4	4	4	2	2	2	2	2	2	2	2	2
ANGLE (DEG)---->	CONDITION----->	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A
31.5		83	84	86	87	85	81	81	81	81	81	82	80	80	80	80	80	80	80	80
63		94	92	91	91	91	91	91	91	91	91	91	91	91	91	91	91	91	91	91
125		96	97	95	94	96	95	95	95	95	95	95	94	94	94	94	94	94	94	94
250		91	85	90	87	90	89	89	89	89	89	89	89	89	89	89	89	89	89	89
500		92	88	88	83	86	85	85	85	85	85	86	86	86	86	86	86	86	86	86
1000		89	86	83	79	85	88	88	88	88	88	83	83	83	83	83	83	83	83	83
2000		85	82	80	79	86	89	89	89	89	89	85	85	85	85	85	85	85	85	85
4000		85	84	81	82	81	88	88	88	88	88	86	86	86	86	86	86	86	86	86
8000		81	80	77	77	86	85	85	85	85	85	81	81	81	81	81	81	81	81	81
OVERALL		101	100	100	98	99	99	99	99	99	99	97	100	100	100	101	102	102	102	102

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)		IDENTIFICATION:									
4		OMEGA 3.2									
		TEST 75-030-001									
		RUN 06									
		10 OCT 75									
		PAGE J3									
NOISE SOURCE/SUBJECT:		( OPERATION:									
A/M32C-10 AIR CONDITIONER		( AC AIR OUTPUT 40LBS/MIN,									
AND A/M32A-60A GEN. SET		( GEN LOADED 100AMP, 240VAC									
COMBINED UNIT OPERATION		( 3PH, BY M24T-8 LOAD BANK,									
NEAR FIELD NOISE LEVELS		( 40 PSI AIR TO A/M32C-10									
DISTANCE (M)-->		2	2	2	2	2	2	2	2	2	2
ANGLE (DEG)-->		160	180	200	220	240	260	280	300	320	340
CONDITION----->		A	A	A	A	A	A	A	A	A	A
FREQ (HZ)		85	87	86	84	80	93	92	92	91	82
31.5		93	93	94	94	92	95	96	96	94	90
63		97	97	96	97	95	94	92	90	89	95
125		97	97	95	95	93	94	92	90	89	90
250		94	95	94	93	94	91	91	90	90	89
500		87	87	84	85	84	84	86	84	84	82
1000		86	84	84	84	83	82	81	82	80	82
2000		96	89	90	89	86	83	83	84	86	84
4000		94	90	90	90	87	84	83	83	81	82
8000											
OVERALL		103	102	102	102	100	100	100	99	98	98

MEASURES OF HUMAN NOISE EXPOSURE										IDENTIFICATIONS
5										
NOISE SOURCE/SUBJECT: ( OPERATION )										OMEGA 3.2
A/M32C-10 AIR CONDITIONER ( AC AIR OUTPUT 40LBS/MIN, )										TEST 75-030-001
AND A/M32A-60A GEN. SET ( GEN LOADED 100AMP, 240VAC )										RUN 04
COMBINED UNIT OPERATION ( 3PH, BY M24T-8 LOAD BANK, )										10 OCT 75
NEAR FIELD NOISE LEVELS ( 40 PSI AIR TO A/M32C-10 )										PAGE H1
HAZARD/PROTECTION										
C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN DB) AT EAR										
A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN DB) AT EAR										
MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)										
NO PROTECTION										
MINIMUM QPL EAR MUFFS										
OASLC										
OASLA										
T										
MINIMUM QPL EAR MUFFS										
OASLA*										
T										
AMERICAN OPTICAL 1700 EAR MUFFS										
OASLA*										
T										
V-51R EAR PLUGS										
OASLA*										
T										
AMERICAN OPTICAL 1700 EAR MUFFS PLUS V-51R EAR PLUGS										
OASLA*										
T										
H-133 GROUND COMMUNICATION UNIT										
OASLA*										
T										
COMMUNICATION										
PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN DB)										
PSIL										
ANNoyANCE										
PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PNDB)										
TONE CORRECTION (C IN DB)										
PNLT										
C										

\* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.

TABLE: MEASURES OF HUMAN NOISE EXPOSURE

IDENTIFICATIONS:

OMEGA 3.2  
TEST 75-030-001  
RUN 05  
10 OCT 75  
PAGE H2

NOISE SOURCE/SUBJECT	(	OPERATION:	)	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	
A/M32C-10 AIR CONDITIONER	(	AC AIR OUTPUT 40LBS/MIN,	)	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	
AND A/M32A-60A GEN. SET	(	GEN LOADED 100AMP, 240VAC	)	280	300	320	340	360	380	400	420	440	460	480	500	520	540	560	580	600	
COMBINED UNIT OPERATION	(	3PH, BY M24T-8 LOAD BANK,	)	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	
NEAR FIELD NOISE LEVELS	(	40 PSI AIR TO A/M32C-10	)	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	
DISTANCE (M)-->	4			4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	
ANGLE (DEG)-->	260			280	300	320	340	360	380	400	420	440	460	480	500	520	540	560	580	600	
CONDITION-->	A			A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	A	
HAZARD/PROTECTION																					
C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN OBC) AT EAR																					
A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN OBA) AT EAR																					
MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)																					
NO PROTECTION	100	99	99	98	96	96	96	99	99	99	97	99	99	100	101	101	101	101	101	102	
OASLC	95	92	91	91	88	88	94	94	95	92	92	94	93	94	93	94	94	96	96	97	
OASLA	71	120	143	143	240	240	85	71	120	85	101	85	101	85	101	85	101	85	60	50	
MINIMUM QPL EAR MUFFS	78	77	77	76	74	74	76	76	76	75	75	77	77	78	79	79	79	79	79	79	
OASLA*	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	
T	73	73	73	71	70	71	71	71	71	70	72	72	73	74	74	74	74	74	74	74	
OASLA*	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	
T	71	69	68	67	64	64	67	68	68	66	66	69	71	71	71	72	72	72	72	73	
OASLA*	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	
T	57	56	55	54	52	52	55	56	53	53	56	57	57	57	57	58	58	58	58	58	
OASLA*	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	
T	68	67	67	65	64	64	68	69	66	66	67	67	67	68	68	69	69	69	69	69	
OASLA*	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	960	
T	89	86	84	84	80	80	86	87	85	86	86	87	86	87	87	88	88	88	88	88	
COMMUNICATION																					
PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN DB)																					
PSIL	110	108	107	106	104	104	110	111	109	110	109	110	109	110	109	110	109	110	112	114	
ANNNOYANCE																					
PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PNDB)																					
TONE CORRECTION (C IN DB)	1	1	1	1	1	1	1	2	1	1	1	1	1	1	1	1	1	1	1	1	
PNLT	110	108	107	106	104	104	110	111	109	110	109	110	109	110	109	110	109	110	112	114	
C	1	1	1	1	1	1	1	2	1	1	1	1	1	1	1	1	1	1	2	1	

\* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.

MEASURES OF HUMAN NOISE EXPOSURE										IDENTIFICATION:									
5										OMEGA 3.2									
NOISE SOURCE/SUBJECT: ( OPERATION: )										TEST 75-030-001									
A/M32C-10 AIR CONDITIONER ( AC AIR OUTPUT 40LBS/MIN, )										RUN 06									
AND A/M32A-60A GEN. SET ( GEN LOADED 100AMP, 240VAC )										10 OCT 75									
COMBINED UNIT OPERATION ( 3PH, BY M24T-8 LOAD BANK, )										PAGE M3									
NEAR FIELD NOISE LEVELS ( 40 PSI AIR TO A/M32C-10 )																			
DISTANCE (M)--> 2 2 2 2 2 2 2 2 2 2										2 2 2 2 2 2 2 2 2 2									
ANGLE (DEG)--> 160 180 200 220 240 260 280 300 320 340										340 320 300 280 260 240 220 200 180 160									
CONDITION-->>> A A A A A A A A A A										A A A A A A A A A A									
HAZARD/PROTECTION																			
C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN DBC) AT EAR																			
A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN DBA) AT EAR																			
MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)																			
NO PROTECTION																			
OASLC																			
OASLA																			
T																			
MINIMUM QPL EAR MUFFS																			
OASLA*																			
T																			
AMERICAN OPTICAL 1700 EAR MUFFS																			
OASLA*																			
T																			
V-51R EAR PLUGS																			
OASLA*																			
T																			
AMERICAN OPTICAL 1700 EAR MUFFS PLUS V-51R EAR PLUGS																			
OASLA*																			
T																			
H-133 GROUND COMMUNICATION UNIT																			
OASLA*																			
T																			
COMMUNICATION																			
PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN DB)																			
PSIL																			
ANNOYANCE																			
PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PNOB)																			
TONE CORRECTION (C IN DB)																			
PNLT																			
C																			

\* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)		IDENTIFICATION:																		
1/3 OCTAVE BAND		OMEGA 1.4																		
DISTANCE = 20 METERS		TEST 75-030-001																		
NOISE SOURCE/SUBJECT:		RUN 01																		
( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )		TEMP = 29 C																		
( AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, )		BAR PRESS = .693 M HG																		
( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )		REL HUMID = 24 %																		
( FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )		PAGE 2																		
FREQ (HZ)	ANGLE (DEGREES)	0	10	20	30	40	50	60	70	80	90	100	110	120	130	140	150	160	170	180
25	82<	80<	79<	81<	81<	81<	80<	79<	79<	79<	79<	76<	76<	75<	74<	75<	76<	76<	75<	80<
31.5	80<	80<	80<	79<	79<	78<	78<	77<	77<	77<	77<	79<	79<	79<	79<	78<	78<	78<	78<	80<
40	80<	78<	80<	80<	80<	79<	78<	78<	77<	77<	77<	77<	77<	76<	77<	77<	77<	77<	77<	82<
50	75<	77<	77<	77<	77<	77<	76<	76<	75<	75<	75<	75<	75<	75<	75<	75<	75<	75<	75<	82<
63	79<	77<	78<	78<	78<	79<	79<	78<	77<	77<	77<	77<	77<	77<	77<	77<	77<	77<	77<	82<
80	82	82	79<	83	83	82	82	82	81	81	81	81	81	81	81	81	81	81	81	85
100	85	85	81	84	87	84	83	83	80	79	81	81	81	81	81	81	81	81	81	85
125	84	82	80	84	84	83	83	83	83	82	86	85	82	81	81	81	81	81	81	85
160	86	84	82	88	85	84	83	83	83	82	86	85	82	81	81	81	81	81	81	85
200	78	76	79	81	78	78	79	79	79	79	79	79	79	79	79	79	79	79	79	85
250	80	78	81	83	81	80	80	80	81	81	81	81	81	81	81	81	81	81	81	85
315	83	82	86	87	85	83	82	82	81	81	81	80	77	77	77	77	77	77	77	85
400	77	75	82	81	80	79	78	77	75	74	74	72	71	71	71	71	71	71	71	85
500	78	77	83	81	81	81	80	77	76	76	77	75	72	71	71	71	71	71	71	85
630	71	72	79	77	76	74	73	73	71	70	70	70	70	70	70	70	70	70	70	85
800	68	67	74	70	72	71	71	71	71	71	69	69	73	71	71	71	71	71	71	85
1000	65	64	68	68	69	68	67	66	64	64	68	66	69	68	68	68	68	68	68	85
1250	61	62	68	67	70	68	66	66	64	63	65	66	67	65	65	65	65	65	65	85
1600	58	65	66	66	66	68	67	64	63	64	63	64	62	63	63	63	63	63	63	85
2000	62	67	69	69	68	68	68	68	68	69	69	69	69	69	69	69	69	69	69	85
2500	65	68	72	72	72	71	71	71	71	70	69	67	68	67	66	66	66	66	66	85
3150	67	65	72	71	72	74	75	75	78	71	71	71	70	71	71	71	71	71	71	85
4000	66	69	71	71	73	74	75	77	74	74	72	72	73	72	72	72	72	72	72	85
5000	65	69	69	68	67	67	67	67	66	66	66	68	67	69	69	69	69	69	69	85
6300	63	66	67	68	67	66	65	65	64	63	64	65	66	67	67	67	67	67	67	85
8000	58	64	66	67	68	66	66	64	63	64	64	65	65	65	65	65	65	65	65	85
10000	60	65	67	72	70	69	67	66	65	65	65	66	67	68	68	68	68	68	68	85
OVERALL	93	92	93	95	94	93	92	91	90	91	91	89	89	89	89	90	92	93	94	95

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

TABLE 1		MEASURED SOUND PRESSURE LEVEL (DB)																IDENTIFICATION:			
1/3 OCTAVE BAND																		OMEGA 1-4			
DISTANCE = 20 METERS																		TEST 75-030-001			
NOISE SOURCE/SUBJECT:		METEOROLOGY:																RUN 02			
( A/M32A-60A GENERATOR SET		( OPERATION:																15 OCT 75			
( AND A/M32C-10 AIR COND.		( GEN LOADED 100AMP, 240VAC																TEMP = 29 C			
( COMBINED UNIT OPERATION		( 3PH, BY M2AT-8 LOAD BANK,																BAR PRESS = .693 H MG			
( FAR FIELD NOISE LEVELS		( 40 PSI AIR TO A/M32C-10,																REL HUMID = 24 %			
		( AC AIR OUTPUT 40 LBS/MIN																PAGE 2			
		ANGLE (DEGREES)																			
FREQ (HZ)		190	200	210	220	230	240	250	260	270	280	290	300	310	320	330	340	350			
25																			83<	82<	
31.5																			79<	80<	
40																			80<	80<	
50																			82<	81<	
63		79<	78<	77<	77<	77<	77<	77<	77<	77<	77<	79<	79<	79<	79<	81<	79<	81<	79<	81<	
80		83	82	80<	80<	82	80<	80<	82	82	82	84	82	84	85	84	84	84	84	84	83
100		83	82	80	81	81	79	78	78	80	82	84	84	86	87	85	84	84	84	84	84
125		80	81	81	83	83	83	82	82	79	80	79	81	81	83	84	82	82	82	82	82
160		87	86	83	83	82	83	85	85	85	83	84	84	84	83	84	87	85	84	84	84
200		85	83	83	83	82	81	80	81	82	84	83	82	79	81	81	80	78	80	80	80
250		87	84	84	82	82	82	82	82	82	83	85	84	84	83	83	83	84	80	80	80
315		84	80	80	80	79	79	79	79	79	82	83	84	84	85	85	85	81	81	81	81
400		77	71	71	71	73	72	72	73	73	74	76	77	77	78	80	82	78	80	80	80
500		82	79	73	72	75	71	72	72	73	76	78	76	78	79	81	83	81	83	81	81
630		81	78	75	75	78	76	67	71	74	76	75	75	75	72	73	78	77	77	77	77
800		82	83	84	81	81	78	73	73	71	73	75	76	77	74	75	76	73	73	73	73
1000		76	78	78	75	74	71	70	68	66	66	66	69	69	67	69	69	68	68	68	68
1250		70	69	69	68	69	69	69	69	65	67	64	67	66	64	67	68	65	65	65	65
1600		70	70	68	65	64	64	64	65	66	65	65	64	65	64	65	65	67	63	63	63
2000		70	71	73	69	70	67	67	64	66	67	67	72	72	71	70	70	67	67	67	67
2500		72	71	70	67	68	67	66	67	65	67	68	71	73	70	71	71	69	69	69	69
3150		75	74	71	70	70	70	68	67	69	73	72	70	73	70	70	74	69	69	69	69
4000		76	76	73	72	72	72	72	71	70	73	70	72	70	71	71	73	68	68	68	68
5000		77	76	73	72	70	68	69	68	67	66	66	67	68	71	68	67	67	67	67	67
6300		74	75	72	70	69	67	68	67	66	65	64	65	66	65	67	68	64	64	64	64
8000		71	72	69	67	65	65	65	64	63	62	64	64	64	64	66	66	62	62	62	62
10000		72	70	70	68	67	67	67	65	65	65	66	67	67	66	69	68	68	68	68	68
OVERALL		94	93	92	91	91	91	90	91	91	92	93	92	93	94	94	95	93	93	93	93

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.




Figure 1. Measurement Locations



IDENTIFICATION: OMEGA 1.4  
 TEST 75-030-001  
 RUN 01  
 15 OCT 75  
 PAGE 4

METEOLOGY: TEMP = 15 C  
 BAR PRESS = .760 M HG  
 REL HUMID = 70 %

OPERATIONS: GEN LOADED 100AMP, 240VAC  
 3PH, BY M24T-8 LOAD BANK,  
 40 PSI AIR TO A/M32C-10,  
 AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT: A/M32A-60A GENERATOR SET  
 AND A/M32C-10 AIR COND.  
 COMBINED UNIT OPERATION  
 FAR FIELD NOISE LEVELS

DISTANCE = 30 METERS



( ( FIGURE 1 NORMALIZED FARFIELD NOISE LEVELS  
 ( ( DISTANCE = 30 METERS  
 ( ( NOISE SOURCE/SUBJECT: ( OPERATION:  
 ( ( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC  
 ( ( AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK,  
 ( ( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10,  
 ( ( FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN  
 ( ( METEOROLOGY: ( TEMPERATURE = 15 C  
 ( ( BAR PRESS = .760 M HG  
 ( ( REL HUMID = 70 %  
 ( ( PAGE 4  
 ( ( IDENTIFICATION: ( OMEGA 1.4  
 ( ( TEST 75-030-001  
 ( ( RUN 02  
 ( ( 15 OCT 75  
 ( ( )










FIGURE: OVERALL SOUND PRESSURE LEVEL (OASPL)  
 3 EQUAL LEVEL CONTOURS (DB)

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: )  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, ) BAR PRESS = .760 M HG )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) )

IDENTIFICATION: )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 01 )  
 ) 15 OCT 75 )  
 ) PAGE 11 )



POINT DB  
 A 45  
 B 50  
 C 55  
 D 60  
 E 65  
 F 70  
 G 75  
 H 80  
 I 85  
 J 90  
 K 95


DISTANCE FROM SOURCE (METERS)

FIGURE: OVERALL SOUND PRESSURE LEVEL (OASPL)  
EQUAL LEVEL CONTOURS (DB)

3

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: )  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-6 LOAD BANK, ) BAR PRESS = .760 M HG )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) )

IDENTIFICATION: )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 02 )  
 ) 15 OCT 75 )  
 ) PAGE 11 )



A N G L E I N O E G R E E S


=

DISTANCE FROM SOURCE (METERS)

EDWIN TEST COMPANY  
 STROUS & METCALO BASKET COMPANY (OFFICE)

FIGURE 1 C-WEIGHTED OVERALL SOUND LEVEL (OASLC) EQUAL LEVEL CONTOURS (DBC)

IDENTIFICATION: OMEGA 1.4  
 TEST 75-030-001  
 RUN 01  
 METEOROLOGY: TEMPERATURE = 15 C  
 BAR PRESS = .760 M HG  
 REL HUMID = 70 %  
 OPERATION: GEN LOADED 100AMP, 240VAC  
 3PH, BY M24T-8 LOAD BANK,  
 40 PSI AIR TO A/M32C-10,  
 AC AIR OUTPUT 40 LBS/MIN



A N G L E I N D E G R E E S

D I S T A N C E F R O M S O U R C E (M E T E R S)

FIGURE 4 C-WEIGHTED OVERALL SOUND LEVEL (OASLC) EQUAL LEVEL CONTOURS (DBC)

IDENTIFICATION: OMEGA 1.4  
 TEST 75-030-001  
 RUN 02  
 15 OCT 75  
 PAGE 12

OPERATION: GEN LOADED 100AMP, 2+0VAC  
 3PH, BY M24T-8 LOAD BANK,  
 40 PSI AIR TO A/M32C-10,  
 AC AIR OUTPUT 40 LBS/MIN

METEOROLOGY: TEMP = 15 C  
 BAR PRESS = .760 M HG  
 REL HUMID = 70 %

NOISE SOURCE/SUBJECT: A/M32A-60A GENERATOR SET  
 AND A/M32C-10 AIR COND.  
 COMBINED UNIT OPERATION  
 FAR FIELD NOISE LEVELS





FIGURE: A-WEIGHTED OVERALL SOUND LEVEL (OASLA)  
 EQUAL LEVEL CONTOURS (DBA)

5

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: )  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-6 LOAD BANK, ) BAR PRESS = .760 H HG )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) )

IDENTIFICATION: )  
 OMEGA 1.4 )  
 TEST 75-030-001 )  
 RUN 01 )  
 15 OCT 75 )  
 PAGE 13 )




DISTANCE FROM SOURCE (METERS)

POINT DBA  
 A 45  
 B 50  
 C 55  
 D 60  
 E 65  
 F 70  
 G 75  
 H 80  
 I 85  
 J 90

FIGURE 5 A-WEIGHTED OVERALL SOUND LEVEL (OASLA) EQUAL LEVEL CONTOURS (DBA)

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: )  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-6 LOAD BANK, ) BAR PRESS = .760 M HG )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) )

IDENTIFICATION: )  
 OMEGA 1.4 )  
 TEST 75-030-001 )  
 RUN 02 )  
 15 OCT 75 )  
 PAGE 13 )



DISTANCE FROM SOURCE (METERS)


FIGURE: PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT)  
 EQUAL LEVEL CONTOURS (PNDB)

6

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: )  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, ) BAR PRESS = .760 M HG )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) )

IDENTIFICATION: )  
 OMEGA 1.4 )  
 TEST 75-030-001 )  
 RUN 01 )  
 15 OCT 75 )  
 PAGE 14 )

POINT PNDB )  
 A 60 )  
 B 65 )  
 C 70 )  
 D 75 )  
 E 80 )  
 F 85 )  
 G 90 )  
 H 95 )  
 I 100 )  
 J 105 )



DISTANCE FROM SOURCE (METERS)

A N G L E I N D E G R E E S



FIGURE 7  
PREFERRED SPEECH INTERFERENCE LEVEL (PSIL)  
EQUAL LEVEL CONTOURS (DB)

IDENTIFICATION:  
OMEGA 1.4  
TEST 75-030-001  
RUN 01  
15 OCT 75  
PAGE 15

METEOROLOGY:  
TEMP = 15 C  
BAR PRESS = .760 H HG  
REL HUMID = 70 %

OPERATIONS:  
GEN LOADED 100AMP, 240VAC  
3PH, BY M24T-8 LOAD BANK,  
40 PSI AIR TO A/M32C-10,  
AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT:  
A/M32A-60A GENERATOR SET  
AND A/M32C-10 AIR COND.  
COMBINED UNIT OPERATION  
FAR FIELD NOISE LEVELS





FIGURE 7 PREFERRED SPEECH INTERFERENCE LEVEL (PSIL) EQUAL LEVEL CONTOURS (DB)

IDENTIFICATION: OMEGA 1.4  
 TEST 75-030-001  
 RUN 02  
 15 OCT 75  
 PAGE 15

METEOROLOGY:  
 TEMP = 15 C  
 BAR PRESS = .760 M HG  
 REL HUMID = 70 %

OPERATION:  
 GEN LOADED 100AMP, 240VAC  
 3PH, BY M24T-8 LOAD BANK,  
 40 PSI AIR TO A/M32C-10,  
 AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT:  
 A/M32A-60A GENERATOR SET  
 AND A/M32C-10 AIR COND.  
 COMBINED UNIT OPERATION  
 FAR FIELD NOISE LEVELS



DB	POINT
35	A
40	B
45	C
50	D
55	E
60	F
65	G
70	H
75	I
80	J


DISTANCE FROM SOURCE (METERS)

) IDENTIFICATIONS )  
 ) )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 01 )  
 ) 15 OCT 75 )  
 ) PAGE 5 )

) METEOROLOGY: )  
 ) TEMP = 15 C )  
 ) BAR PRESS = .760 M HG )  
 ) REL HUMID = 70 % )

) OPERATION: )  
 ) GEN LOADED 100AMP, 240VAC )  
 ) 3PH, BY M24T-8 LOAD BANK, )  
 ) 40 PSI AIR TO A/M32C-10, )  
 ) AC AIR OUTPUT 40 LBS/MIN )

) NOISE SOURCE/SUBJECT: )  
 ) A/M32A-60A GENERATOR SET )  
 ) AND A/M32C-10 AIR COND. )  
 ) COMBINED UNIT OPERATION )  
 ) FAR FIELD NOISE LEVELS )




DISTANCE FROM SOURCE (METERS)

ANGLE IN DEGREES

) POINT MIN  
 ) A 960  
 ) B 480  
 ) C 240

( ( FIGURE: MAXIMUM PERMISSIBLE TIME (T) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73) ) IDENTIFICATION: )  
 ( ( 8 EQUAL TIME CONTOURS (MINUTES) ) )  
 ( ( NO PROTECTION ) )  
 ( ( NOISE SOURCE/SUBJECT: ) )  
 ( ( A/M32A-60A GENERATOR SET ) )  
 ( ( AND A/M32C-10 AIR COND. ) )  
 ( ( COMBINED UNIT OPERATION ) )  
 ( ( FAR FIELD NOISE LEVELS ) )  
 ( ( OPERATION: ) )  
 ( ( GEN LOADED 100AMP, 240VAC ) )  
 ( ( 3PH, BY M24T-8 LOAD BANK, ) )  
 ( ( 40 PSI AIR TO A/M32C-10, ) )  
 ( ( AC AIR OUTPUT 40 LBS/MIN ) )  
 ( ( METEOROLOGY: ) )  
 ( ( TEMP = 15 C ) )  
 ( ( BAR PRESS = .760 M HG ) )  
 ( ( REL HUMID = 70 % ) )  
 ( ( PAGE 5 ) )  
 ( ( OMEGA 1.4 ) )  
 ( ( TEST 75-030-001 ) )  
 ( ( RUN 02 ) )  
 ( ( POINT A ) )  
 ( ( POINT B ) )  
 ( ( POINT C ) )



( ( 2 3 4 5 6 0 1 1.5 2 3 4 5 6 0 1 1.5 2 3 4 5 6 0 1 1.5 2 3 ) )  
 ( ( DISTANCE FROM SOURCE (METERS) ) )  
 ( ( 100 ) )  
 ( ( 1000 ) )

( ( NOTE: THE ABOVE IS A REPRESENTATIVE EXAMPLE OF A FAR FIELD NOISE LEVEL ) )  
 ( ( THE ACTUAL NOISE LEVELS WILL VARY WITH THE EXPOSURE PERIOD ) )  
 ( ( OMEGA 1.4 ) )  
 ( ( TEST 75-030-001 ) )  
 ( ( RUN 02 ) )  
 ( ( POINT A ) )  
 ( ( POINT B ) )  
 ( ( POINT C ) )

FIGURE: MAXIMUM PERMISSIBLE TIME (T) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)

8

IDENTIFICATION: OMEGA 1.4  
TEST 75-030-001  
RUN 01  
15 OCT 75  
PAGE 6

NOISE SOURCE/SUBJECT: METEOROLOGY:

A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C  
AND A/M32C-10 AIR COND. ( 3PH, BY M24T-6 LOAD BANK, ) BAR PRESS = .760 M HG  
COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 %  
FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )

PERSONNEL MAY BE EXPOSED UP TO 960 MINUTES PER DAY

AT ALL DISTANCES FROM SOURCE EQUAL TO OR GREATER THAN 20 METERS

FOR ALL ANGLES EVALUATED (INDICATED BY < AT LEFT)


UNDER THE FOLLOWING EAR PROTECTION CONDITIONS:

- MINIMUM QPL EAR MUFFS
- AMERICAN OPTICAL 1700 EAR MUFFS
- V-51R EAR PLUGS
- COMFIT TRIPLE FLANGE EAR PLUGS
- H-133 GROUND COMMUNICATION UNIT

0<	10<	20<	30<	40<	50<	60<	70<	80<	90<	100<	110<	120<	130<	140<	150<	160<	170<	160<
2	3	4	5	6	6	1	1.5	2	3	4	5	6	8	1	1.5	2	3	3
DISTANCE FROM SOURCE (METERS)																		

FIGURE 8 MAXIMUM PERMISSIBLE TIME (T) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)  
 EQUAL TIME CONTOURS (MINUTES)

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: OMEGA 1.4  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C TEST 75-030-001  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, ) BAR PRESS = .760 M HG RUN 02  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % 15 OCT 75  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) PAGE 6



PERSONNEL MAY BE EXPOSED UP TO 960 MINUTES PER DAY  
 AT ALL DISTANCES FROM SOURCE EQUAL TO OR GREATER THAN 20 METERS  
 FOR ALL ANGLES EVALUATED (INDICATED BY < AT LEFT)


UNDER THE FOLLOWING EAR PROTECTION CONDITIONS:

- MINIMUM QPL EAR MUFFS
- AMERICAN OPTICAL 1700 EAR MUFFS
- V-51R EAR PLUGS
- COMFIT TRIPLE FLANGE EAR PLUGS
- M-133 GROUND COMMUNICATION UNIT

DISTANCE FROM SOURCE (METERS)

88 90 92 94 96 98 100 102 104 106 108 110 112 114 116 118 120 122 124 126 128 130 132 134 136 138 140 142 144 146 148 150 152 154 156 158 160 162 164 166 168 170 172 174 176 178 180 182 184 186 188 190 192 194 196 198 200 202 204 206 208 210 212 214 216 218 220 222 224 226 228 230 232 234 236 238 240 242 244 246 248 250 252 254 256 258 260 262 264 266 268 270 272 274 276 278 280 282 284 286 288 290 292 294 296 298 300 302 304 306 308 310 312 314 316 318 320 322 324 326 328 330 332 334 336 338 340 342 344 346 348 350 352 354 356 358 360 362 364 366 368 370 372 374 376 378 380 382 384 386 388 390 392 394 396 398 400 402 404 406 408 410 412 414 416 418 420 422 424 426 428 430 432 434 436 438 440 442 444 446 448 450 452 454 456 458 460 462 464 466 468 470 472 474 476 478 480 482 484 486 488 490 492 494 496 498 500 502 504 506 508 510 512 514 516 518 520 522 524 526 528 530 532 534 536 538 540 542 544 546 548 550 552 554 556 558 560 562 564 566 568 570 572 574 576 578 580 582 584 586 588 590 592 594 596 598 600 602 604 606 608 610 612 614 616 618 620 622 624 626 628 630 632 634 636 638 640 642 644 646 648 650 652 654 656 658 660 662 664 666 668 670 672 674 676 678 680 682 684 686 688 690 692 694 696 698 700 702 704 706 708 710 712 714 716 718 720 722 724 726 728 730 732 734 736 738 740 742 744 746 748 750 752 754 756 758 760 762 764 766 768 770 772 774 776 778 780 782 784 786 788 790 792 794 796 798 800 802 804 806 808 810 812 814 816 818 820 822 824 826 828 830 832 834 836 838 840 842 844 846 848 850 852 854 856 858 860 862 864 866 868 870 872 874 876 878 880 882 884 886 888 890 892 894 896 898 900 902 904 906 908 910 912 914 916 918 920 922 924 926 928 930 932 934 936 938 940 942 944 946 948 950 952 954 956 958 960 962 964 966 968 970 972 974 976 978 980 982 984 986 988 990 992 994 996 998 1000

( FIGURE: SOUND PRESSURE LEVEL (SPL) ) IDENTIFICATION: )  
 ( 9 EQUAL LEVEL CONTOURS (DB) ) )  
 ( 31.5 HZ OCTAVE BAND ) )  
 ( NOISE SOURCE/SUBJECT: ) OPERATION: ) METEOROLOGY: )  
 ( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 ( AND A/M32C-10 AIR COND. ( 3PM, BY M24T-6 LOAD BANK, ) BAR PRESS = .760 M HG )  
 ( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 ( FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) ) PAGE 16 )  
 ( ) TEST 75-030-001 ) RUN 01 )  
 ( ) OMEGA 1.4 )  
 ( ) ) )



DISTANCE FROM SOURCE (METERS)

( FIGURE: SOUND PRESSURE LEVEL (SPL)  
 ( EQUAL LEVEL CONTOURS (DB)  
 ( 31.5 HZ OCTAVE BAND  
 ( NOISE SOURCE/SUBJECT: ( OPERATION: ( METEOROLOGY:  
 ( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C  
 ( AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, ) BAR PRESS = .760 M HG  
 ( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 %  
 ( FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )  
 ( IDENTIFICATION: )  
 ( OMEGA 1.4  
 ( TEST 75-030-001  
 ( RUN 02  
 ( 15 OCT 75  
 ( PAGE 16  
 ( ) POINT DB

POINT	A	B	C	D	E	F	G	H	I	J	K
180											
190											
200											
210											
220											
230											
240											
250											
260											
270											
280											
290											
300											
310											
320											
330											
340											
350											
360											


2 3 4 5 6 8 100 1000  
 DISTANCE FROM SOURCE (METERS)

A N G L E I N D E G R E E S  
 35  
40  
45  
50  
55  
60  
65  
70  
75  
80  
85



FIGURE 9 SOUND PRESSURE LEVEL (SPL) EQUAL LEVEL CONTOURS (DB) 63 HZ OCTAVE BAND

NOISE SOURCE/SUBJECT: ( OPERATION: ) METEOROLOGY: )  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC ) TEMP = 15 C )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, ) BAR PRESS = .760 M HG )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) REL HUMID = 70 % )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) )




DISTANCE FROM SOURCE (METERS)

IDENTIFICATION: )  
 ) OMEGA 1.4  
 ) TEST 75-030-001  
 ) RUN 02  
 ) 15 OCT 75  
 ) PAGE 17

DB 35  
 40  
 45  
 50  
 55  
 60  
 65  
 70  
 75  
 80  
 85

( FIGURE: SOUND PRESSURE LEVEL (SPL)  
 ( 9 EQUAL LEVEL CONTOURS (DB)  
 ( 125 HZ OCTAVE BAND  
 ( NOISE SOURCE/SUBJECT: ( OPERATION:  
 ( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC  
 ( AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK,  
 ( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10,  
 ( FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )  
 ( METEOROLOGY: )  
 ( TEMP = 15 C )  
 ( BAR PRESS = .760 M HG )  
 ( REL HUMID = 70 % )  
 ( OMEGA 1.4 )  
 ( TEST 75-030-001 )  
 ( RUN 01 )  
 ( 15 OCT 75 )  
 ( PAGE 18 )



A N G L E I N D E G R E E S  
 2 3 4 5 6 8 100 1.5 2 3 4 5 6 8 100  
 DISTANCE FROM SOURCE (METERS)  
 POINT DB  
 A 35  
 B 40  
 C 45  
 D 50  
 E 55  
 F 60  
 G 65  
 H 70  
 I 75  
 J 80  
 K 85  
 L 90


FIGURE 1 SOUND PRESSURE LEVEL (SPL) EQUAL LEVEL CONTOURS (DB) 125 HZ OCTAVE BAND

IDENTIFICATION: OMEGA 1.4 TEST 75-030-001 RUN 02

METEOROLOGY: TEMP = 15 C BAR PRESS = .760 M HG REL HUMID = 70 %


OPERATION: GEN LOADED 100AMP, 240VAC 3PH, BY M24T-6 LOAD BANK, 40 PSI AIR TO A/M32C-10, AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT: A/M32A-60A GENERATOR SET AND A/M32C-10 AIR COND. COMBINED UNIT OPERATION FAR FIELD NOISE LEVELS



DISTANCE FROM SOURCE (METERS)

( ( FIGURE: SOUND PRESSURE LEVEL (SPL)  
 ( ( 9 EQUAL LEVEL CONTOURS (DB)  
 ( ( 250 HZ OCTAVE BAND  
 ( ( NOISE SOURCE/SUBJECT: ( OPERATION:  
 ( ( A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC  
 ( ( AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, ) TEMP = 15 C  
 ( ( COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, ) BAR PRESS = .760 M HG  
 ( ( FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN ) REL HUMID = 70 %  
 ( ( ) METEOROLOGY:  
 ( ( ) RUN 01  
 ( ( TEST 75-030-001  
 ( ( OMEGA 1.4  
 ( ( IDENTIFICATION:  
 ( ( ) PAGE 19




DISTANCE FROM SOURCE (METERS)

A N G L E I N D E G R E E S

) IDENTIFICATION: )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 02 )  
 ) 15 OCT 75 )  
 ) PAGE 19 )

) METEOROLOGY: )  
 ) TEMP = 15 C )  
 ) BAR PRESS = .760 M HG )  
 ) REL HUMID = 70 % )  
 ) GEN LOADED 100AMP, 240VAC )  
 ) 3PH, BY M24T-8 LOAD BANK, )  
 ) 40 PSI AIR TO A/M32C-10, )  
 ) AC AIR OUTPUT 40 LBS/MIN )




DISTANCE FROM SOURCE (METERS)

A N G L E I N D O G R E E S

) IDENTIFICATION: )  
 ) )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 01 )  
 ) )  
 ) METEOROLOGY: )  
 ) TEMP = 15 C )  
 ) BAR PRESS = .760 M HG )  
 ) REL HUMID = 70 % )  
 ) )  
 ) 15 OCT 75 )  
 ) )  
 ) PAGE 20 )  
 ) )

) FIGURE: SOUND PRESSURE LEVEL (SPL)  
 ) EQUAL LEVEL CONTOURS (DB)  
 ) 500 HZ OCTAVE BAND  
 ) )  
 ) NOISE SOURCE/SUBJECT: )  
 ) ( OPERATION: )  
 ) ( GEN LOADED 100AMP, 240VAC )  
 ) ( 3PH, BY M24T-8 LOAD BANK, )  
 ) ( 40 PSI AIR TO A/M32C-10, )  
 ) ( AC AIR OUTPUT 40 LBS/MIN )  
 ) )




IDENTIFICATION:  
 OMEGA 1.4  
 TEST 75-030-001  
 RUN 02  
 15 OCT 75  
 PAGE 20

METEOROLOGY:  
 TEMP = 15 C  
 BAR PRESS = .760 M HG  
 REL HUMID = 70 %

OPERATION:  
 GEN LOADED 100AMP, 240VAC  
 3PH, BY M24T-8 LOAD BANK,  
 40 PSI AIR TO A/M32C-10,  
 AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT:  
 A/M32A-60A GENERATOR SET  
 AND A/M32C-10 AIR COND.  
 COMBINED UNIT OPERATION  
 FAR FIELD NOISE LEVELS



POINT DB  
 A 35  
 B 40  
 C 45  
 D 50  
 E 55  
 F 60  
 G 65  
 H 70  
 I 75  
 J 80  
 K 85

DISTANCE FROM SOURCE (METERS)  
 100 1.5 2 3 4 5 6 8 1 1.5 2 3


A N G L E I N D E R E S  
 J K

) IDENTIFICATION: )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 01 )  
 ) 15 OCT 75 )  
 ) PAGE 21 )

) METEOROLOGY: )  
 ) TEMP = 15 C )  
 ) BAR PRESS = .760 M HG )  
 ) REL HUMID = 70 % )

) OPERATION: )  
 ) GEN LOADED 100AMP, 240VAC )  
 ) 3PH, BY M24T-8 LOAD BANK, )  
 ) 40 PSI AIR TO A/M32C-10, )  
 ) AC AIR OUTPUT 40 LBS/MIN )

) NOISE SOURCE/SUBJECT: )  
 ) A/M32A-60A GENERATOR SET )  
 ) AND A/M32C-10 AIR COND. )  
 ) COMBINED UNIT OPERATION )  
 ) FAR FIELD NOISE LEVELS )



) POINT )  
 ) A )  
 ) B )  
 ) C )  
 ) D )  
 ) E )  
 ) F )  
 ) G )  
 ) H )  
 ) I )  
 ) J )  
 ) K )

DB 35  
 40  
 45  
 50  
 55  
 60  
 65  
 70  
 75  
 80  
 85

2 3 4 5 6 8 1 1.5 2 3  
 100 1000  
 DISTANCE FROM SOURCE (METERS)


FIGURE: SOUND PRESSURE LEVEL (SPL) EQUAL LEVEL CONTOURS (DB) 1000 HZ OCTAVE BAND

IDENTIFICATIONS:  
 OMEGA 1.4  
 TEST 75-030-001  
 RUN 02  
 15 OCT 75  
 PAGE 21

METEOROLOGY:  
 TEMP = 15 C  
 BAR PRESS = .760 M HG  
 REL HUMID = 70 %

OPERATIONS:  
 GEN LOADED 100AMP, 240VAC  
 3PH, BY M24T-8 LOAD BANK,  
 40 PSI AIR TO A/M32C-10,  
 AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT:  
 A/M32A-60 GENERATOR SET  
 AND A/M32C-10 AIR COND.  
 COMBINED UNIT OPERATION  
 FAR FIELD NOISE LEVELS



DISTANCE FROM SOURCE (METERS)

3000 WT. OIL VAC. P/100  
 100% PEACH COMPARER (L/D)  
 100% BROWN WELSPRING P/100 (C/D)


FIGURE 1 SOUND PRESSURE LEVEL (SPL) EQUAL LEVEL CONTOURS (DB) 2000 HZ OCTAVE BAND

IDENTIFICATION: OMEGA 1.4 TEST 75-030-001 RUN 01 15 OCT 75 PAGE 22

METEOROLOGY: TEMPERATURE = 15 C BAR PRESS = .760 M HG REL HUMID = 70 %

OPERATION: GEN LOADED 100AMP, 240VAC 3PH, BY M24T-8 LOAD BANK, 40 PSI AIR TO A/M32C-10, AC AIR OUTPUT 40 LBS/MIN

NOISE SOURCE/SUBJECT: A/M32A-60A GENERATOR SET AND A/M32C-10 AIR COND. COMBINED UNIT OPERATION FAR FIELD NOISE LEVELS



POINT	DB
A	35
B	40
C	45
D	50
E	55
F	60
G	65
H	70
I	75

A N G L E I N D E G R E E S

FIGURE: SOUND PRESSURE LEVEL (SPL) EQUAL LEVEL CONTOURS (DB) 2000 HZ OCTAVE BAND

IDENTIFICATION: OMEGA 1.4 TEST 75-030-001 RUN 02


NOISE SOURCE/SUBJECT: OPERATION: METEOROLOGY: TEMPERATURE = 15 C BAR PRESS = .760 M HG REL HUMID = 70 %

A/M32A-60A GENERATOR SET GEN LOADED 100AMP, 240VAC

AND A/M32C-10 AIR COND. 3PH, BY M24T-8 LOAD BANK,

COMBINED UNIT OPERATION 40 PSI AIR TO A/M32C-10,

FAR FIELD NOISE LEVELS AC AIR OUTPUT 40 LBS/MIN



POINT	A	B	C	D	E	F	G	H	I
08									
35									
40									
45									
50									
55									
60									
65									
70									
75									



FIGURE: SOUND PRESSURE LEVEL (SPL)  
 EQUAL LEVEL CONTOURS (DB)  
 4000 HZ OCTAVE BAND

IDENTIFICATION:  
 OMEGA 1.4  
 TEST 75-030-001  
 RUN 02

NOISE SOURCE/SUBJECT: ( OPERATION:  
 A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )  
 AND A/M32C-10 AIR COND. ( 3PH, BY M24T-8 LOAD BANK, )  
 COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )  
 FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )


METEOROLOGY:  
 TEMP = 15 C  
 BAR PRESS = .760 H HG  
 REL HUMID = 70 %



DISTANCE FROM SOURCE (METERS)

) IDENTIFICATION: )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 01 )  
 ) METEOROLOGY: )  
 ) TEMP = 15 C )  
 ) BAR PRESS = .760 M HG )  
 ) REL HUMID = 70 % )  
 ) PAGE 24 )  
 ) POINT )  
 ) DB )

) FIGURE: SOUND PRESSURE LEVEL (SPL)  
 ) EQUAL LEVEL CONTOURS (DB)  
 ) 8000 HZ OCTAVE BAND  
 ) NOISE SOURCE/SUBJECT: ( OPERATION:  
 ) A/M32A-60A GENERATOR SET ( GEN LOADED 100AMP, 240VAC )  
 ) AND A/M32C-10 AIR COND. ( 3PH, 3Y M24T-6 LOAD BANK, )  
 ) COMBINED UNIT OPERATION ( 40 PSI AIR TO A/M32C-10, )  
 ) FAR FIELD NOISE LEVELS ( AC AIR OUTPUT 40 LBS/MIN )



DISTANCE FROM SOURCE (METERS)


ANGL E I N D E G R E E S

) IDENTIFICATION: )  
 ) OMEGA 1.4 )  
 ) TEST 75-030-001 )  
 ) RUN 02 )  
 ) 15 OCT 75 )  
 ) PAGE 24 )  
 ) POINT )  
 ) DB )

) METEOROLOGY: )  
 ) TEMP = 15 C )  
 ) BAR PRESS = .760 M HG )  
 ) REL HUMID = 70 % )

) OPERATION: )  
 ) GEN LOADED 100AMP, 240VAC )  
 ) 3PH, BY M24T-8 LOAD BANK, )  
 ) 40 PSI AIR TO A/M32C-10, )  
 ) AC AIR OUTPUT 40 LBS/MIN )

) NOISE SOURCE/SUBJECT: )  
 ) A/M32A-60A GENERATOR SET )  
 ) AND A/M32C-10 AIR COND. )  
 ) COMBINED UNIT OPERATION )  
 ) FAR FIELD NOISE LEVELS )



DISTANCE FROM SOURCE (METERS)