

AD-A048 944

AEROSPACE MEDICAL RESEARCH LAB WRIGHT-PATTERSON AFB OHIO F/6 20/1
USAF BIOENVIRONMENTAL NOISE DATA HANDBOOK. VOLUME 106. MA-1A AI--ETC(U)
DEC 76 N A FARINACCI

UNCLASSIFIED

AMRL-TR-75-50-VOL-106

NL

| OF |
AD
A048 944



END
DATE
FILED
2 - 78
DDC

AD No.
DDC FILE COPY

AD A 0 48944

(14)

AMRL-TR-75-56-VOL-106

VOLUME 106

(2)
NW



6
**USAF BIOENVIRONMENTAL NOISE DATA
HANDBOOK.**

Volume 106.

MA-1A Air Conditioner

(9) Technical rep't.


(10) Nick A. Farinacci

(11) DEC 1976

(12) 18 p.

(16) 7231

(17) 04



Approved for public release; distribution unlimited.

AEROSPACE MEDICAL RESEARCH LABORATORY
AEROSPACE MEDICAL DIVISION
AIR FORCE SYSTEMS COMMAND
WRIGHT-PATTERSON AIR FORCE BASE, OHIO 45433

009 850

mt

NOTICES

When US Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government thereby incurs no responsibility nor any obligation whatsoever, and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data, is not to be regarded by implication or otherwise, as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

Please do not request copies of this report from Aerospace Medical Research Laboratory. Additional copies may be purchased from:

**National Technical Information Service
5285 Port Royal Road
Springfield, Virginia 22161**

Federal Government agencies and their contractors registered with Defense Documentation Center should direct requests for copies of this report to:


**Defense Documentation Center
Cameron Station
Alexandria, Virginia 22314**

TECHNICAL REVIEW AND APPROVAL

This report has been reviewed by the Information Office (OI) and is releasable to the National Technical Information Service (NTIS). At NTIS, it will be available to the general public, including foreign nations.


This technical report has been reviewed and is approved for publication.

FOR THE COMMANDER


HENNING E. VON GIERKE

**Director
Biodynamics and Bionics Division
Aerospace Medical Research Laboratory**

AIR FORCE/86700/19 December 1977 - 200

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER AMRL-TR-75-50, Vol. 106	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) USAF BIOENVIRONMENTAL NOISE DATA HANDBOOK: MA-1A Air Conditioner		5. TYPE OF REPORT & PERIOD COVERED Volume 106 of a series
7. AUTHOR(s) Nick A. Farinacci, Capt, USAF, BSC		6. PERFORMING ORG. REPORT NUMBER
9. PERFORMING ORGANIZATION NAME AND ADDRESS Aerospace Medical Research Laboratory Aerospace Medical Division, Air Force Systems Command, Wright-Patterson AFB OH 45433		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 7231-04-33 62202F 7231-04-36
11. CONTROLLING OFFICE NAME AND ADDRESS Same as above		12. REPORT DATE December 1976
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		13. NUMBER OF PAGES 18
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report) 		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Noise Noise Environments Bioenvironmental Noise Ground Support Equipment MA-1A Air Conditioner		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) The MA-1A Air Conditioner is an engine-driven air conditioner designed to provide conditioned air to the aircraft's interior during ground servicing. This report provides measured data defining the bioacoustic environments produced by this unit operating outdoors on a concrete apron at normal rated/loaded conditions. Near-field data are reported for 36 locations in a wide variety of physical and psychoacoustic measures: overall and band sound pressure levels, C-weighted and A-weighted sound levels, preferred speech		

interference level, perceived noise level, and limiting times for total daily exposure of personnel with and without standard Air Force ear protectors. Refer to Volume 1 of this handbook, USAF Bioenvironmental Noise Data Handbook, Vol 1: Organization, Content and Application, AMRL-TR-75-50(1) 1975, for discussion of the objective and design of the handbook, the types of data presented, measurement procedures, instrumentation, data processing, definitions of quantities, symbols, equations, applications, limitations, etc.

PREFACE

This report was prepared by the Biodynamic Environment Branch, Aerospace Medical Research Laboratory, under Project/Task 723104, Measurement and Prediction of Noise Environments of Air Force Operations.

The author gratefully acknowledges Mr. Robert T. England and Mr. Carl G. Toler who conducted the field measurements, and Mr. John N. Cole who established the data analysis requirements and assisted in the preparation of this report. Mr. Henry Mohlman and Mr. David Eilerman of the University of Dayton assisted in the mechanics of data processing, and Mrs. Norma Peachey typed and prepared the graphics.

SEARCHED SERIALIZED
INDEXED FILED
FILED FILED

ACCESSION NO.	
NTIS	A. II Section <input checked="" type="checkbox"/>
DDC	B. II Section <input type="checkbox"/>
UNANNOUNCED	
JUL 1 1971	
BY	
DISTRIBUTION/AVAILABILITY CODES	
H	SPECIAL
A	

Table of Contents

	<i>Page</i>
INTRODUCTION	3
NEAR-FIELD NOISE	4

List of Tables

NEAR-FIELD NOISE

1. Meteorological Conditions for Noise Measurements	4
2. Measured Sound Pressure Level	
1/3 Octave Band	6—8
Octave Band	9—11
3. Measures of Human Noise Exposure	12—14

List of Figures

NEAR-FIELD NOISE

1. Measurement Locations	5
--------------------------------	---

INTRODUCTION

The MA-1A Air Conditioner is an engine-driven air conditioner designed to provide conditioned air to the aircraft's interior during ground servicing. This unit is manufactured by Keco Industries, Incorporated.

This volume provides measured data defining bioacoustic environments produced by this unit. Such data are essential to evaluate ear protection requirements, limiting personnel exposure times, voice communication capabilities, and annoyance problems associated with operations of the MA-1A air conditioner.

This volume is one of a series published by the Aerospace Medical Research Laboratory (AMRL) under the same report number (AMRL-TR-75-50) as a multi-volume handbook that quantifies the noise environments produced at flight/ground crew locations and in surrounding communities by operations of Air Force aircraft and ground support equipment. The far-field, community-type noise data in the handbook describe the noise produced during *ground operations* of aircraft, ground support equipment, and other ground-based equipment or facilities.

Volume 1 of this handbook discusses the objectives and design of the handbook, types of data presented, measurement procedures, instrumentation, data processing, definitions of quantities, symbols, equations, applications, limitations, etc. Volume 2 provides a method and data for adjusting the handbook's far-field noise data, which are for standard meteorological conditions (15 C temperature, 70% rel humidity, 0.760 meters Hg barometric pressure), to derive comparable data for other meteorological conditions. Refer to Volumes 1 and 2 (references 1 and 2) for such information because it is not repeated in other handbook volumes.

A cumulative index lists those aerospace systems contained in the handbook, and identifies the specific volumes containing each type of environmental noise data available (i.e., inflight/flight crew and passenger noise, near-field/ground crew noise, far-field/community noise). Volume numbers are assigned sequentially as individual volumes are published. This index is periodically updated as individual volumes are published and is available upon request from AMRL/BBE, Wright-Paterson AFB, OH 45433. Organizations on the distribution list for the handbook will automatically receive a copy of each updated index.

Direct any questions concerning the technical data in this report and other handbook volumes to: AMRL/BBE, Wright-Patterson AFB, OH 45433; Autovon 78-53675 or 78-53664; Commercial (513) 255-3675 or (513) 255-3664.

-
1. Cole, John N., *USAF Bioenvironmental Noise Data Handbook, Volume 1: Organization, Content and Application*, AMRL-TR-75-50 (1), Aerospace Medical Research Laboratory, Wright-Patterson Air Force Base, Ohio, 1975.
 2. Cole, John N., *USAF Bioenvironmental Noise Data Handbook, Volume 2: Procedure to Evaluate Effects of Non-standard Meteorological Conditions on Far-Field Noise*, AMRL-TR-75-50 (2), AMRL, WPAFB, OH, 1975.

NEAR-FIELD NOISE

MEASUREMENTS

A standard MA-1A air conditioner was operated outdoors on a concrete apron at normal rated conditions with no significant sound-reflective surfaces present except the ground plane. Table 1 notes the surface meteorological conditions at the time of measurement.

Figure 1 identifies 36 noise measurement locations at a height of 1.5 meters above the concrete apron (nominal ear level of ground crew). The 0 degree reference direction passes through the tow bar. These locations are in the acoustic near-field of the source where the sound wave fronts generally do not spherically diverge and the source appears to be spatially distributed (i.e., not a point source). Consequently, these near-field data cannot be extrapolated to longer distances but do properly define the levels at locations close to the unit.

RESULTS

The measured data presented in Table 2 define the sound pressure levels (SPL) produced by the MA-1A unit at the 36 specified, near-field locations. This table includes the overall, 1/3 octave band, and octave band levels. From these data one can calculate the variety of measures in Table 3 which are widely used to assess the effects of noise on personnel and their performance.

For data at other intermediate near-field locations (i.e., for radial distances less than 4 meters) you can interpolate between the 36 measured data points. All near-field data are for the meteorological conditions at the time of test but are valid for all typical airbase meteorology because of the short distances over which the sound is propagated.

TABLE 1

METEOROLOGICAL CONDITIONS FOR NOISE MEAUREMENTS

MA-1A Air Conditioner
Wright-Patterson AFB, 5 November 1971

Meteorology

Temperature	17 C
Bar Pressure	0.745 M Hg
Rel Humidity	26 %
Wind — Speed	6.8 M/Sec (13 Kt)




Figure 12. Measurement Locations

TABLE I MEASURED SOUND PRESSURE LEVEL (DB)
1/3 OCTAVE BAND
2

NOISE SOURCE/SUBJECT:		OPERATION:		COMPRESSOR OPERATING		NEAR FIELD NOISE LEVELS		IDENTIFICATIONS:						
FREQ (HZ)	ANGLE (DEG) -->	0	20	40	60	80	100	120	140	160	180	200	220	240
25	76	78	65<	70<	70<	72<	69<	74<	72<	71<	71	69<	69<	79
31.5	75	74	68<	69<	75	74	72	76	75	75	74	72	73	76
40	73	74	72	72	76	76	76	79	78	77	76	76	76	79
50	76	78	78	79	79	79	78	79	78	77	76	76	76	76
63	91	91	90	90	90	88	89	89	89	89	89	89	87	86
80	83	82	81	79	78	80	82	83	82	82	82	82	84	83
100	81	82	81	79	79	77	76	76	76	76	76	76	76	79
125	91	91	90	89	89	86	86	86	86	86	86	86	86	87
160	83	85	84	83	84	84	84	84	84	84	85	83	82	83
200	84	83	84	84	85	82	80	81	84	86	86	86	85	80
250	79	79	80	81	80	79	80	78	78	79	79	79	79	79
315	75	75	76	77	76	77	76	77	77	76	76	76	76	75
400	76	75	77	76	75	75	76	75	76	75	75	75	75	75
500	73	74	74	74	73	72	73	72	73	72	73	72	73	74
630	75	76	77	75	77	76	77	76	77	76	75	75	75	76
800	74	76	76	74	75	74	75	74	75	74	75	74	75	75
1,000	72	75	76	75	73	72	72	76	77	71	84	86	82	75
1250	76	73	74	76	72	73	74	76	75	79	81	84	80	75
1600	74	74	73	71	70	70	70	72	74	77	79	77	73	71
2000	70	70	70	68	69	70	69	70	72	75	77	75	71	69
2500	71	71	70	68	66	65	66	68	70	75	75	74	70	67
3150	67	70	68	67	64	63	65	68	74	74	73	68	65	65
4000	65	66	66	65	63	63	63	65	65	71	72	70	65	63
5000	63	65	63	62	60	60	63	60	63	68	69	67	63	61
6300	63	63	62	61	59	60	59	60	60	60	60	60	60	60
8000	60	61	60	59	57	57	60	58	62	63	62	60	60	60
10000	54	56	56	56	52	54	54	56	55	55	55	55	55	55
OVERALL		95	96	95	95	95	93	93	94	95	96	96	94	93

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

TABLE I
1/3 OCTAVE BAND
2

NOISE SOURCE/SUBJECT		OPERATION		COMPRESSOR OPERATING		NEAR FIELD NOISE LEVELS		IDENTIFICATION	
MA-1A AIR CONDITIONER								TEST 71-020-080	OMEGA 3.2
								RUN 02	
								24 FEB 75	
								PAGE F2	
FREQ (HZ)	DISTANCE (M) ->	4	4	4	4	4	4	2	2
25	ANGLE (DEG) -->	260	300	320	340	0	20	40	60
31.5		79	79	73<	76	79	76	78	78
40		79	75	73	72	75	74	76	79
50		78	77	78	77	76	77	76	77
63		77	77	78	77	75	64	66	61
80		89	87	88	89	89	101	103	93
100		80	81	79	81	83	69	90	91
125		79	81	79	81	80	80	89	88
160		86	88	89	91	92	100	99	97
200		82	82	81	82	82	89	80	81
250		81	84	83	82	83	67	69	67
315		78	82	79	79	79	82	84	86
400		72	75	77	78	81	82	80	81
500		76	77	78	76	76	82	83	82
630		75	77	77	78	76	81	80	81
800		73	74	75	75	74	80	81	80
1000		71	73	74	76	76	79	80	81
1250		71	72	73	73	73	77	77	78
1600		70	72	73	74	74	78	79	78
2000		68	70	71	71	71	75	75	76
2500		67	69	71	72	71	76	74	72
3150		65	67	69	69	69	73	73	72
4000		64	66	68	68	67	71	70	69
5000		63	65	66	65	64	68	70	67
6300		62	64	65	65	64	69	68	66
8000		62	64	66	65	62	68	69	65
10000		58	61	62	60	58	64	63	60
OVERALL	LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.	93	94	94	95	96	104	105	101
									99
									98
									97

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

TEST 71-020-080
RUN 02
FEB 75
PAGE F2

TEST 71-020-080
RUN 02
FEB 75
PAGE F2

TABLE I MEASURED SOUND PRESSURE LEVEL (DB)
2 1/3 OCTAVE BAND

NOISE SOURCE/SUBJECT		OPERATION:		COMPRESSOR OPERATING		NEAR FIELD NOISE LEVELS				2		2		2		2		2		2	
FREQ (HZ)	ANGLE (DEG) -->	160	180	200	220	240	260	280	300	320	340	160	180	200	220	240	260	280	300	320	340
MA-1A AIR CONDITIONER																					
25	80	82	75<	72<	77	73<	78	75	78	76	77	81	77	74<							
31.5	75	79	73	73	78	77	79	82	82	85	85	83	83	83	79	78	78	78	76	76	76
40	77	79	76	77	77	77	79	80	80	81	81	81	81	81	81	81	81	81	81	81	81
50	78	78	78	77	77	77	79	80	80	81	81	81	81	81	81	81	81	81	81	81	81
63	85	85	84	84	84	84	84	86	86	87	87	89	89	89	89	89	89	89	89	89	89
80	84	85	83	83	85	83	85	83	83	84	84	84	84	84	84	84	84	84	84	84	84
100	84	84	84	84	84	82	82	82	83	85	85	86	86	86	86	86	86	86	86	86	86
125	91	92	94	92	92	92	92	94	95	95	95	97	97	97	97	97	97	97	97	97	97
160	89	88	87	87	87	87	87	87	90	92	92	92	92	92	92	92	92	92	92	92	92
200	91	92	94	94	94	94	94	95	95	96	96	96	96	96	96	96	96	96	96	96	96
250	85	85	85	85	85	84	84	84	85	85	85	85	85	85	85	85	85	85	85	85	85
315	82	85	84	84	84	79	79	78	80	82	83	83	83	83	83	83	83	83	83	83	83
400	85	86	87	82	80	81	83	83	83	83	83	83	83	83	83	83	83	83	83	83	83
500	83	88	84	84	81	76	76	80	81	81	81	81	81	81	81	81	81	81	81	81	81
630	88	89	88	88	82	78	79	80	80	81	81	83	82	82	82	82	82	82	82	82	82
800	87	88	86	86	79	75	75	77	77	79	79	79	79	79	79	79	79	79	79	79	79
1000	83	87	85	85	85	77	75	75	77	77	77	77	77	77	77	77	77	77	77	77	77
1250	84	86	82	75	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76	76
1600	82	84	82	74	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73	73
2000	81	82	80	73	70	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72
2500	77	78	79	71	70	71	71	71	71	71	71	71	71	71	71	71	71	71	71	71	71
3150	76	76	77	69	69	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70
4000	73	75	74	67	67	68	68	68	68	71	71	71	71	71	71	71	71	71	71	71	71
5000	71	73	72	65	66	67	66	66	66	72	72	71	71	71	71	71	71	71	71	71	71
6300	66	67	66	64	65	64	63	65	65	70	70	71	71	71	71	71	71	71	71	71	71
8000	64	65	64	63	63	60	58	60	61	66	66	67	67	67	67	67	67	67	67	67	67
10000	59	60	58	58	58	60	60	60	61	61	61	61	61	61	61	61	61	61	61	61	61
OVERALL	99	100	100	97	96	98	98	98	100	100	100	101	103								

< LEVEL CORRECTED TO REMOVE BACKGROUND/ELECTRONIC NOISE.

TABLE I
MEASURED SOUND PRESSURE LEVEL (DB)
OCTAVE BAND

TABLE: MEASURED SOUND PRESSURE LEVEL (DB) 2 OCTAVE BAND		IDENTIFICATION:									
NOISE SOURCE/SUBJECT:		OPERATION:		COMPRESSOR OPERATING		NEAR FIELD NOISE LEVELS		PAGE J1			
MA-1A AIR CONDITIONER											
FREQ (HZ)	DISTANCE (M) -->	ANGLE (DEG) -->	4	4	4	4	4	4	4	4	4
31.5	79	60	73	74	79	79	77	76	76	76	83
63	91	92	91	91	90	88	90	90	90	89	86
125	92	92	91	90	91	89	87	88	90	90	89
250	65	85	66	66	85	84	64	65	67	67	63
500	80	80	81	81	80	80	80	63	66	66	81
1000	79	79	81	80	78	78	80	82	85	86	82
2000	76	77	76	75	73	73	75	77	81	82	78
4000	70	72	71	70	67	67	70	76	77	75	74
8000	65	65	65	65	64	61	62	63	65	65	66
OVERALL	95	96	95	95	93	93	94	95	96	96	94

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)		IDENTIFICATION	
2 OCTAVE BAND		TEST 71-020-060	
NOISE SOURCE/SUBJECT:		RUN 02	
MA-1A AIR CONDITIONER		24 FEB 75	
NEAR FIELD NOISE LEVELS		PAGE J2	
FREQ (HZ)	DISTANCE (M) -> ANGLE (DEG) --->	4 80	2 60
31.5	03 02	00 02	02 02
63	90 69	90 90	101 103
125	65 69	92 93	100 100
250	63 65	64 65	89 91
500	60 62	62 62	86 86
1000	76 79	81 81	83 84
2000	73 75	77 77	81 81
4000	69 71	72 72	76 76
8000	66 68	68 68	72 73
OVERALL	93 94	95 96	105 105

TABLE: MEASURED SOUND PRESSURE LEVEL (DB)
2 OCTAVE BAND

NOISE SOURCE/SUBJECT:		OPERATIONS		COMPRESSOR OPERATING		NEAR FIELD NOISE LEVELS		IDENTIFICATION:	
MA-1A AIR CONDITIONER								TEST 71-020-080	OMEGA 3+2
								RUN 03	24 FEB 75
								PAGE J3	
FREQ (HZ)	DISTANCE (IN) -->	2	2	2	2	2	2	2	2
	ANGLE (DEG) -->	160	180	200	220	240	260	280	300
31.5		63	85	80	79	83	83	85	87
63		66	69	87	88	89	89	91	92
125		93	94	95	93	94	96	97	97
250		92	93	95	90	87	90	91	92
500		90	93	91	86	83	84	86	87
1000		90	91	89	82	80	81	83	82
2000		85	86	85	77	76	77	81	81
4000		79	80	79	72	72	73	77	76
8000		66	70	69	67	68	69	74	75
OVERALL		99	100	100	97	96	96	100	101
									103

TABLE I MEASURES OF HUMAN NOISE EXPOSURE
3

NOISE SOURCE/SUBJECT		OPERATION		IDENTIFICATION										
MA-1A AIR CONDITIONER		COMPRESSOR OPERATING		TEST 71-020-080 RUN 01 24 FEB 75 PAGE H1										
NEAR FIELD NOISE LEVELS														
ANGLE (DEG) -->	DISTANCE (M) -->	0	20	40	60	80	100	120	140	160	180	200	220	240
HAZARD/PROTECTION	C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN DBC) AT EAR A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN DBA) AT EAR MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)													
NO PROTECTION	OASLC OASLA	95 84	95 85	94 84	94 85	94 84	93 83	93 84	94 85	95 86	95 86	95 86	94 86	94 86
T	MINIMUM QPL EAR MUFFS	480	404	404	480	480	571	480	339	202	170	202	285	571
T	OASLA*	72	73	72	72	72	70	69	70	72	72	72	71	70
T	AMERICAN OPTICAL 1700 EAR MUFFS	960	960	960	960	960	960	960	960	960	960	960	960	960
T	OASLA*	69	69	68	68	68	66	66	67	66	66	66	67	66
V-51R EAR PLUGS	960	960	960	960	960	960	960	960	960	960	960	960	960	960
T	OASLA*	61	62	62	61	61	60	61	63	65	67	66	64	60
AMERICAN OPTICAL 1700 EAR MUFFS PLUS V-51R EAR PLUGS	960	960	960	960	960	960	960	960	960	960	960	960	960	960
T	OASLA*	50	51	51	50	50	48	49	50	52	53	52	51	48
H-133 GROUND COMMUNICATION UNIT	960	960	960	960	960	960	960	960	960	960	960	960	960	960
T	OASLA*	62	63	62	62	61	59	60	61	63	64	63	61	60
COMMUNICATION	PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN dB)	78	79	76	77	77	76	61	64	65	64	61	77	
ANNOYANCE	PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PNDB)													
TONE CORRECTION (C IN dB)	PNLT C	101 1	101 1	100 1	100 1	99 2	99 1	99 1	103 1	104 1	104 1	103 1	101 1	98 1

* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.

TABLE I MEASURES OF HUMAN NOISE EXPOSURE
3

NOISE SOURCE/SUBJECT		OPERATION		IDENTIFICATION	
MA-1A AIR CONDITIONER		COMPRESSOR OPERATING		OMEGA 3.2 TEST 71-020-080 RUN 03	
NEAR FIELD NOISE LEVELS				24 FEB 75	
DISTANCE (M) ->	ANGLE (DEG) ->	2	2	2	2
ANGLE (DEG) ->	160	180	200	220	240
HAZARD/PROTECTION		C-WEIGHTED OVERALL SOUND LEVEL (OASLC IN DBC) AT EAR			
		A-WEIGHTED OVERALL SOUND LEVEL (OASLA IN DBA) AT EAR			
		MAXIMUM PERMISSIBLE TIME (T IN MINUTES) FOR ONE EXPOSURE PER DAY (AFR 161-35, JULY 73)			
NO PROTECTION					
OASLC	98	100	99	96	98
OASLA	93	95	94	88	88
T	101	71	65	240	339
MINIMUM QPL EAR MUFFS					
OASLA*	75	76	77	74	76
T	960	960	960	960	960
AMERICAN OPTICAL 1700 EAR MUFFS	71	72	72	69	71
OASLA*	T	960	960	960	960
V-51R EAR PLUGS					
OASLA*	70	72	70	65	63
T	960	960	960	960	960
AMERICAN OPTICAL 1700 EAR MUFFS PLUS	V-51R EAR PLUGS				
OASLA*	56	58	57	52	51
T	960	960	960	960	960
H-133 GROUND COMMUNICATION UNIT					
OASLA*	67	68	68	63	63
T	960	960	960	960	960
COMMUNICATION	PREFERRED SPEECH INTERFERENCE LEVEL (PSIL IN DB)				
PSIL	88	90	88	82	80
ANNOYANCE	PERCEIVED NOISE LEVEL, TONE CORRECTED (PNLT IN PNDB)				
TONE CORRECTION (C IN DB)	PNLT	106	108	100	103
C		1	1	1	1

* BASED ON CALCULATED SPL SPECTRUM UNDER PROTECTIVE DEVICE.