_			Constant Sector Se		an Difference.				New Constants	Î.
						R 185				
						To population				
		Second Second		-	Environment Republication Conservation	And Branciski Market States and			atta	
s'o Din	<u>ei</u> 7-5		and the second se	-			END Date Filmed 4 - 78			



AD A 050916

TECHNICAL REPORT

INTEGRATION OF FIRE PROTECTION INTO LARGE AUTOMATED STORAGE SYSTEMS AT NAVAL SHORE FACILITIES PHASE II

By: P.J. Chicarello and L.M. Krasner

Prepared for: Department of the Navy Naval Facilities Engineering Command 200 Stovall Street Alexandria, Va. 22332 Under NavFac Contract N00025-74-C-0023

> FMRC Serial No. 22415 RC75-T-50

> > March 1976

Approved by:

Cheng Yao, Manager

JAN

27 1978

Applied Research



Factory Mutual Research

1151 Boston-Providence Turnpike Norwood, Massachusetts 02062 DISTRIBUTION STATEMENT A Approved for public release; Distribution Unlimited

JAN _____FIED Security Classification DOCUMENT CONTROL DATA - R&D (Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified) ORIGINATING ACTIVITY (Corporate author) 28. REPORT SECURITY CLASSIFICATION Unclassified Factory Mutual Research Corporation 25 GROUP 1151 Boston-Providence Turnpike Norwood, Massachusetts 02062 Integration of Fire Protection Into Large Automated Storage Systems at Naval Shore Facilities - Phone II DESCRIPTIVE NOTES (Type of report and inclusive dates) Final Report June 1974 through-February 2976 an adl first name, initial) Chicarello, Heter J., Krasner, Lawrence, M. 0 awhence asne PORTOAT 0 59 March 2976 CONTRACT OR GRANT NO. 94. ORIGINATOR'S REPORT NUMBER(S) N00025-74-C-0023 FMRC Series No 22415 96. OTHER RE be assigned RC75-T-59 10 SVAIL ABILITY/LIMITATION NO DISTRIBUTION STATEMENT Availability Unlimited Approved for public release Distribution Unlimited 12. SPONSORING MILITARY ACTIVITY 11 SUPPLEMENTARY NOTES Naval Facilities Engineering Command 200 Stovall Street Alexandria, Va. 22332 13 ABSTRACT Two methods of integrating automatic sprinkler protection into high rise, rack storage systems are described with the aid of detailed sketches. The two schemes are hydraulically analyzed and compared to the performance of conventional systems. A cost effectiveness analysis is made of one system which utilizes tubular rack columns as water conductors. DD . FORM. 1473 133 300 UNCLASSIFIED Security Classification

		LIN	LINK A		LINK B		LINKC	
	KEY WORDS	ROLE	WT	ROLE	WT	ROLE	w	
Fire H Sprink Integr	Protection Aler Systems rated Rack and Materials Handling Systems	S						

INSTRUCTIONS

1. ORIGINATING ACTIVITY: Enter the name and address of the contractor, subcontractor, grantee, Department of Defense activity or other organization (corporate author) issuing the report.

2a. REPORT SECURITY CLASSIFICATION: Enter the overall security classification of the report. Indicate whether "Restricted Data" is included. Marking is to be in accordance with appropriate security regulations.

2b. GROUP: Automatic downgrading is specified in DoD Directive 5200.10 and Armed Forces Industrial Manual. Enter the group number. Also, when applicable, show that optional markings have been used for Group 3 and Group 4 as authorized.

3. REPORT TITLE: Enter the complete report title in all capital letters. Titles in all cases should be unclassified. If a meaningful title cannot be selected without classification, show title classification in all capitals in parenthesis immediately following the title.

4. DESCRIPTIVE NOTES: If appropriate, enter the type of report, e.g., interim, progress, summary, annual, or final. Give the inclusive dates when a specific reporting period is covered.

5. AUTHOR(S): Enter the name(s) of author(s) as shown on or in the report. Enter last name, first name, middle initial. If military, show rank and branch of service. The name of the principal athor is an absolute minimum requirement.

6. REPORT DATE: Enter the date of the report as day, month, year; or month, year. If more than one date appears on the report, use date of publication.

7a. TOTAL NUMBER OF PAGES: The total page count should follow normal pagination procedures, i.e., enter the number of pages containing information.

7b. NUMBER OF REFERENCES: Enter the total number of references cited in the report.

8a. CONTRACT OR GRANT NUMBER: If appropriate, enter the applicable number of the contract or grant under which the report was written.

8b, 8c, & 8d. PROJECT NUMBER: Enter the appropriate military department identification, such as project number, subproject number, system numbers, task number, etc.

a. ORIGINATOR'S REPORT NUMBER(S): Enter the official report number by which the document will be identified and controlled by the originating sctivity. This number must be unque to this report.

9b. OTHER REPORT NUMBER(S): If the report has been assigned any other report numbers (either by the originator or by the sponsor), also enter this number(s).

10. AVAILABILITY/LIMITATION NOTICES: Enter any limtrations on further dissemination of the report, other than those imposed by security classification, using standard statements such as:

- "Qualified requesters may obtain copies of this report from DDC."
- (2) "Foreign announcement and dissemination of this report by DDC is not authorized."
- (3) "U. S. Government agencies may obtain copies of this report directly from DDC. Other qualified DDC users shall request through
- (4) "U. S. military agencies may obtain copies of this report directly from DDC. Other qualified users shall request through
- (5) "All distribution of this report is controlled. Qualified DDC users shall request through

If the report has been furnished to the Office of Technical Services, Department of Commerce, for sale to the public, indicate this fact and enter the price, if known.

11. SUPPLEMENTARY NOTES: Use for additional explanatory notes.

12. SPONSORING MILITARY ACTIVITY: Enter the name of the departmental project office or laboratory sponsoring (paying for) the research and development. Include address.

13. ABSTRACT: Enter an abstract giving a brief and factual summary of the document indicative of the report, even though it may also appear elsewhere in the body of the technical report. If additional space is required, a continuation sheet shall be attached.

It is highly desirable that the abstract of classified reports be unclassified. Each paragraph of the abstract shall end with an indication of the military security classification of the information in the paragraph, represented as (TS), (S), (C), or (U).

There is no limitation on the length of the abstract. However, the suggested length is from 150 to 225 words.

14. KEY WORDS: Key words are technically meaningful terms or short phrases that characterize a report and may be used as index entries for cataloging the report. Key words must be selected so that no security classification is required. Identifiers, such as equipment model designation, trade name, military project code name, geographic location, may be used as key words but will be followed by an indication of technical context. The assignment of links, rules, and weights is optional.

UNCLASSIFIED

Security Classification

ABSTRACT

Two methods of integrating automatic sprinkler protection into high rise, rack storage systems are described with the aid of detailed sketches. The two schemes are hydraulically analyzed and compared to the performance of conventional systems. A cost effectiveness analysis is made of one system which utilizes tubular rack columns as water conductors.

SHI SACTAR	0
all, bad/er 18261	41
1	
	AVAILABELITY SER AIL DAG OF 1210

TABLE OF CONTENTS

. .

Section		Title	Page
ABSTRACT			i
I	INTR	ODUCTION	1
	1.1	Background	1
	1.2	Objective	2
II	LARG	E STORAGE FACILITY WITH HIGH RISE STORAGE RACKS	3
	2.1	Example of a Large Storage Facility	3
	2.2	Type of Protection to be Considered	3
	2.3	Classification of Storage to be Protected	6
	2.4	Location of Automatic Sprinklers	6
	2.5	Integrating In-Rack Sprinklers with a High Rise	7
		Storage System by Utilizing Tubular Rack Columns	
		as Water Conductors	
	2.6	Integrating In-Rack Sprinklers with a High Rise	16
		Storage System by Utilizing Standard Circular Pipes	
	2.7	Fabrication of Rack Frames	24
III	HYDR	AULIC ANALYSES OF INTEGRATED IN-RACK SPRINKLER	25
	SYST	EMS	
	3.1	Analysis of a Conventional System	25
	3.2	Analysis of an Integrated System Utilizing	25
		Standard Circular Pipes	
	3.3	Analysis of an Integrated System Utilizing	27
		Tubular Rack Columns as Water Conductors	
	3.4	Comparison of Results and Conclusions	32
IV	COST	EFFECTIVENESS ANALYSIS OF INTEGRATED SPRINKLER SYSTEMS	37
v	CONC	CLUSIONS	39
APPENDIX	A	Friction Loss in Pipes of Non-Circular Section	40
APPENDIX	B	Data Supplied By Grinnell Fire Protection	45
		Systems Company, Inc.	

LIST OF ILLUSTRATIONS

Number	Title or Description	Page
1.	Example of Large Storage Facility, Plan View	4
2.	Example of Large Storage Facility, Sectional View	5
3.	Location of In-Rack Sprinkler for Integrated	8
	System Utilizing Tubular Rack Columns as Water Conductors	
4.	Pictorial Sketch of Integrated Sprinkler System Utilizing	9
	Tubular Rack Columns as Water Conductors	
5.	Partial Plan View of Integrated System Utilizing Tubular	10
	Rack Columns as Water Conductors in a Double Row Rack	
	Structure.	
6.	End View and Partial Elevation of Integrated System	11
	Utilizing Tubular Rack Columns	
7.	Fabrication of Outside Tubular Rack Columns to be Used	12
	as Water Conductors	
8.	Fabrication of Inside Tubular Rack Columns to be Used	13
	as Water Conductors	
9.	Detail of Face Sprinkler Assembly and Connection to	14
	Rack Column	
10.	Detail of Longitudinal Flue Sprinkler Assembly and	15
	Connection to Rack Column	
11.	Location of In-Rack Sprinklers for Integrated System	17
	Utilizing Standard Circular Pipes	
12.	Pictorial Sketch of Integrated System Utilizing	18
	Standard Circular Pipes	
13.	Partial Plan View of Integrated Sprinkler System Utilizing	19
	Standard Circular Pipes	
14.	End View and Partial Elevation of Integrated System	20
	Utilizing Standard Circular Pipes	

Number	Title or Description	Page
15.	Fabrication of Channel Type Columns to Accommodate Pipes	21
	and Rods	
16.	Detail of Transverse Flue Sprinkler Assembly	22
17.	Detail of Pipe Hangers for Top Line	23
18.	Plan Views of Top Two Levels of Sprinklers for System	26
	Utilizing Standard Circular Pipes	
19.	Plan Views of Top Two Levels of Sprinklers for System	31
	Utilizing Tubular Rack Columns	
20.	Friction Loss in Non-Circular Pipes	42
21.	Friction Loss in Non-Circular Pipes	43
22.	Friction Loss in Non-Circular Pipes	44
23.	Material Costs of Alternative Layouts	48
24.	Grinnell Drawing No. 1	50
25.	Grinnell Drawing No. 2	51
26.	Grinnell Drawing No. 3	52
27.	Grinnell Drawing No. 4	53
28.	Grinnell Drawing No. 5	54

LIST OF TABLES

Number	Title	Page
1	Hydraulic Calculations of Integrated System	28
	Utilizing Standard Circular Pipes	
2	Hydraulic Calculations of Integrated System	33
	Utilizing Tubular Rack Columns	
3	Comparison of Integrated Sprinkler Systems with	36
	Conventional System	
4	Rack System Cost Comparison	49

INTRODUCTION

1.1 BACKGROUND

Whenever large quantities of combustible materials are gathered together, a fire hazard is created; but the degree of hazard depends on the type and geometric arrangement of the materials. If the combustibles are placed in high storage racks, the hazard is severe. In fact, it would be difficult to devise a more efficient way to pile combustibles for burning. Rack storage systems contain vertical flue spaces and horizontal channels that permit a free circulation of air. In case of ignition, the upward spread of fire is rapid because of the chimney effect created by the vertical flue spaces. At the same time, pressure differences force the fire through the horizontal channels and the flames spread quickly in all directions. If the fire is left unchecked, the entire storage system may soon be in flames.

Traditionally, warehouses have been protected from fire by the installation of automatic sprinklers at the ceiling. However, the discharge from ceiling sprinklers cannot readily reach the lower tiers of a storage rack and when pile heights exceed 25 ft, ceiling sprinklers lose effectiveness (in some cases, the loss in effectiveness occurs well below 25 ft). In order for automatic sprinklers to be effective, the ceiling sprinklers must be supplemented by intermediate levels of sprinklers installed at strategic locations in the rack.

Usually, the storage system is designed and fabricated without making allowance for the installation of sprinklers. The in-rack sprinklers must then be fitted into the rack structure as best they can. As a result, the installation of in-rack sprinklers is often difficult and expensive. They may encroach upon storage space and cause interference with automated materials handling equipment. Further, the extinguishing potential of the sprinkler system may also suffer due to the uncoordinated design.

Integrating sprinkler protection into the basic design of large, automated storage systems will optimize both effectiveness and cost.

1

I

This project is a continuation of the work started under NavFac Contract N00025-73-C-0032. The previous work is covered in a report issued under FMRC Serial No. 21289, dated August 1974. In that report, the history and development of rack storage fire protection was reviewed and the state of the art surveyed. Constraints imposed on fire protection by the construction and operational requirements of high rack storage systems were outlined and two methods of integrating sprinkler protection into rack storage systems were suggested.

1.2 OBJECTIVE

The objective of this project is the development of an integrated sprinkler system for the fire protection of future Navy high rise storage systems such as those intended for the TRIDENT and NATIONAL CITY, CA. installations. Specifically, the objective will be reached as follows:

- The two methods of integration suggested in the Phase I report will be revised and developed to the extent necessary for practical implementation.
- 2. The two systems developed under 1 above will be hydraulically analyzed.
- A cost-effectiveness analysis will bmade and compared to the cost of conventional methods of sprinkler protection.

NOTE:

The placement of sprinklers within the rack structure will follow proven arrangements as called for by NFPA Standard 231C. These arrangements have been developed from many large scale fire tests, as explained in the Phase I report. In view of this fact, it is believed that additional fire testing is unnecessary. It is also anticipated that the hydraulic performance of the integrated sprinkler systems will be adequately determined from the analyses conducted under item 2 above and that water flow tests will, therefore, be unnecessary. However, small scale testing will be conducted if unforeseen difficulties arise which make testing advisable.

II LARGE STORAGE FACILITIES WITH HIGH RISE STORAGE RACKS

2.1 EXAMPLE OF A LARGE STORAGE FACILITY

A warehouse may be of almost any size or shape and the storage system may assume a variety of configurations. It is, therefore, impossible to define a "typical" warehouse. Nevertheless; it is helpful, in fixing ideas, to select a specific example as a reference. With this in mind, the storage facility shown in Figures 1 and 2 may be considered to be of a type and size that is of interest in this study.

The high rise storage racks are double row, open steel frame construction with transverse pallet supports. Stacking machinery is of the mobile elevator type and is computer-controlled to deliver and retrieve pallet loads to and from storage. In this particular example, a low bay section of the building contains 20-ft high storage racks that are loaded and unloaded with fork lift trucks; but some facilities may be devoted entirely to high rise storage. In any case, the facility illustrated in Figures 1 and 2 will serve as a model for this project.

2.2 TYPE OF PROTECTION TO BE CONSIDERED

Several methods of protection are described in the Phase I report, but only automatic sprinklers have been proven effective and economical for all storage heights. Since it is desirable to standardize protection without regard for storage height, automatic sprinklers offer the only economical means of achieving the required flexibility. Automatic sprinklers have other desirable qualities (see the Phase I report) that make them an excellent choice for the protection of high rack storages. Therefore, only automatic sprinklers are considered for this application.





2.3 CLASSIFICATION OF STORAGE TO BE PROTECTED

For the purposes of rack storage, materials have been grouped into four classifications (see NFPA 231C). The first group (Class I) is the least hazardous and the fourth group (Class IV) is the most hazardous. Naval storage facilities are likely to contain a variety of materials and it is desirable that the fire protection be arranged to handle all types of storage without placing restrictions on the location of a commodity within the rack structure. Therefore, it should be assumed that all commodities fall within the Class IV designation.

2.4 LOCATION OF AUTOMATIC SPRINKLERS

In order to assure adequate protection, the automatic sprinklers should be located within the rack structure as called for by NFPA Standard 231C. Other arrangements may be satisfactory, but they have not been proven by comprehensive, large scale tests and the consequences of a protection failure are too severe to permit basing the protection on conjectural schemes. Accordingly, the sprinklers should be located as shown by Figure 4152h or Figure 41521 in NFPA Standard 231C.

The two acceptable arrangements for 80-ft high storage are illustrated in Figures 3 and 11. For higher storages, the sprinkler pattern is repeated. The "face" sprinklers are installed in the transverse flue spaces behind the rack columns and must be located not less than 3 in. from the back of the column and not more than 18 in. from the aisle face of storage. The "longitudinal" flue sprinklers must be located a minimum of 2 ft from the rack columns. The deflectors of all sprinklers are to be located a minimum of 6 in. above the top of the storage. Either pendent or upright sprinklers may be used. The orifice size should be nominal 1/2 in. and the temperature rating must be ordinary (approximately 165°F). Water shields are installed above each sprinkler.

Ceiling sprinklers must, of course, be provided in addition to the in-rack sprinklers. The requirements for ceiling sprinklers are detailed in NFPA 231C.

2.5 INTEGRATING IN-RACK SPRINKLERS WITH A HIGH RISE STORAGE SYSTEM BY UTILIZING TUBULAR RACK COLUMNS AS WATER CONDUCTORS

A high rise storage rack may be constructed with tubular columns of square or rectangular cross section. The columns may be sealed and used as pipes to conduct water to automatic sprinklers placed at various points within the rack structure. The sprinklers should be located in accordance with NFPA Standard 231C. An acceptable arrangement of sprinklers for a double row rack structure is shown in Figure 3 (note that the sprinklers are staggered both vertically and horizontally). The sprinklers are connected to the tubular columns by short lengths of pipe and the columns are connected to a water supply through feed pipes connected to the tops of the columns. A pictorial sketch of the arrangement is shown in Figure 4 (for clarity, one of the double rows has been omitted).

The approximate vertical locations for the sprinklers are indicated in Figures 3 and 4. However, the exact locations will vary somewhat depending on the tier height. The sprinkler deflectors should be located at least 6 in. above the top of the storage in each tier (see Figure 9).

A partial plan view of the sprinkler system is shown in Figure 5. The important thing to notice is that only three rows of columns are fed with water. Sprinklers need not be attached to the fourth row. Figure 6 shows an end view and a partial elevation.

Details of column fabrication are indicated in Figures 7 and 8. Steel plates are welded to the top and bottom of the columns. A 2 1/2-in. hole is drilled in the top plate and a 2 1/2-in. half coupling welded in place. The top coupling serves as the means of attaching the feed pipe to the column. One-inch holes are drilled in the sides of the columns and 1-in. half couplings welded in place over the holes. The 1-in. couplings are for attachment of the sprinkler assemblies (see Figures 9 and 10). The plates and couplings are attached to the columns during shop fabrication.

Figures 9 and 10 show the details of the sprinkler assemblies and are self-explanatory. The sprinkler assemblies are attached to the rack columns after the rack structure has been erected at the building site.



Notes:

- I. Sprinklers installed at vertical intervals shown.
- 2. Symbols, X A Indicate automatic sprinklers.
- 3. Water shields to be installed above each sprinkler.



SECTION A.A

Figure No. 3. Location of In-Rack Sprinklers for Integrated System Utilizing Tubular Rack Columns as Water Conductors.



Figure No.4. Pictorial Sketch of Integrated Sprinkler System Utilizing Tubular Rack Columns as Water Conductors. 9



and the second second second second

¹⁰



Figure. No. 6





Figure. No. 8. Fabrication of Inside Tubular Rack Columns to be used as Water Conductors.



Figure No. 9. Detail of Face Sprinkler Assembly and Connection to Rack Column.





2.6 INTEGRATING IN-RACK SPRINKLERS WITH A HIGH RISE STORAGE SYSTEM BY UTILIZING STANDARD CIRCULAR PIPES

Many high rise storage racks are constructed with channel type columns which cannot be sealed to carry water. In this type of storage rack, the sprinkler system must be made up from standard circular pipes. The sprinklers should be located in accordance with NFPA Standard 231C. An acceptable arrangement, which is convenient for a piped system, is shown in Figure 11. The sprinklers are connected to standard circular pipes that are fitted into the rack structure. A pictorial sketch of the arrangement is shown in Figure 12 (for clarity, one of the double rows has been omitted). The "face" sprinklers are connected to the transverse flue sprinkler assemblies (Figure 16) which are built into the upright rack frames during shop fabrication. That is, the 7/8-in. rod, the 1-in. x 1/2-in. x 1-in. tee, and the 1-in. pipe are built into the rack frame. The 1-in. close nipple, water shield, 1-in. x 1/2-in. reducer, and the sprinkler are installed after field erection of the storage rack. The remaining piping and longitudinal flue sprinklers are also installed following erection of the rack structure.

Figures 13 and 14 show a partial plan view, end view and elevation of the arrangement. Figure 15 indicates the approximate location and size of holes to be punched in the columns to accommodate the transverse flue sprinkler assemblies.

Details of the transverse flue sprinkler assembly are shown in Figure 16. The nuts holding the 7/8-in. rod to the rack column are left loose so that the 1-in. pipe may be turned into the pipe fittings which are installed in the longitudinal flue (see Figure 17). The nuts may be tightened after the sprinkler system has been assembled.

Once the rack structure has been erected, the pipe in the longitudinal flue may be installed in sections (see Figure 17). The pipe is held in place by connection to the transverse flue sprinkler assemblies, except for the top line which must be secured by pipe hangers (Figure 17).



Notes:

- I. Sprinklers installed at vertical intervals shown.
- 2. Symbol (•) indicates automatic sprinkler.
- 3. Water shields to be installed above each sprinkler.



Figure No. 11. Location of In-Rack Sprinklers for Integrated System Utilizing Standard Circular Pipes.



Figure No.12. Pictorial Sketch of Integrated Sprinkler System Utilizing Standard Circular Pipes.



Figure. No. 13. Partial Plan View of Integrated Sprinkler System Utilizing Standard Circular Pipes.



Figure. No. 14













Figure No. 17.

2.7 FABRICATION OF RACK FRAMES

The construction of storage racks has become highly standardized and most rack structures are assembled from a few standard components. The upright frames (a pair of load carrying columns connected by horizontal and diagonal bracing members - see Figures 4 and 12) are prefabricated at the factory and transported to the building site where they are assembled into a storage system. The frame columns are rolled from sheet steel into channel shaped sections (see cross section of rack column shown in the plan view of Figure 16). Holes are punched into the columns on 3-in. centers for connecting support members at any multiple of 3-in.

A relatively few standard frame sizes are produced, but they have sufficient flexibility to meet a very large number of storage requirements. Non-standard frames may be fabricated, but the necessary tooling changes may cause a substantial increase in the cost of a storage system.

The method of integrating sprinklers into a storage system by utilizing standard circular pipes, as described in Section 2.6, would necessitate the fabrication of non-standard frames and the increased cost of fabrication would probably offset the savings in the cost of the sprinkler system. Therefore, this method of integration is not practical unless a production line is specially set up to produce a very large number of units.

The method of integrating sprinklers by the use of tubular columns will also necessitate the fabrication of non-standard frames. However, in this case the increased cost of fabrication may be offset by the savings in the cost of the sprinkler system. The overall cost savings may well depend on the load which the rack structure is designed to support. One major manufacturer indicated, if each upright frame is designed to support a load of less than 60,000 lb, the savings will be minimal. If, on the other hand, each frame is designed to carry a load exceeding 60,000 lb, the cost savings will be substantial. The reason is that loads exceeding 60,000 lb per upright frame will require the use of tubular columns for reasons of strength alone. The increased cost of fabrication chargeable to the attachment of the plates and couplings will therefore be minimized.

HYDRAULIC ANALYSES OF INTEGRATED IN-RACK SPRINKLER SYSTEMS

III

The flow and pressure required to supply in-rack sprinklers will depend on the characteristic of the available water supply, the sprinkler system pipe sizes and the size of the rack being protected. Usually, the pipe sizes are selected to match a known water supply characteristic. Since both the water supply characteristic and rack size can vary over wide limits, it is not possible to perform a general analysis that is applicable to a large number of cases. However, the purpose of this section of the study is to compare the hydraulic performance of the two integrated systems described in Sections 2.5 and 2.6 to the performance of a conventional system. A valid comparison can be made by selecting a specific rack structure for study. Therefore, the high rise storage system shown in Figures 1 and 3 has been chosen as a basis for the analyses.

3.1 ANALYSIS OF A CONVENTIONAL SYSTEM

A conventional system would be similar in design to the integrated system described in Section 2.6 and shown in Figure 12, except all piping would be installed following erection of the rack structure. The mechanical details of installation would, of course, differ; but the two systems would be hydraulically similar. Therefore, the calculations outlined in Section 3.2 will apply equally well to a conventional system.

3.2 ANALYSIS OF AN INTEGRATED SYSTEM UTILIZING STANDARD CIRCULAR PIPES

The piping configuration is assumed to be as shown in Figure 12. Plan views of the top two levels of sprinklers are shown in Figure 18.

According to NFPA Standard No. 231-C, sprinklers in racks over 25 ft high shall discharge at a pressure of not less than 30 psi. The water demand for in-rack sprinklers protecting a Class IV commodity shall be based on the



simultaneous operation of the most hydraulically remote 14 sprinklers (seven on each of the top two levels). This means that the seven sprinklers on each of the top two levels must be chosen in a way that will produce the maximum demand.

The small lateral pipes feeding the transverse flue sprinklers will be 1-in. nominal diameter, as shown in Figure 18. The large pipe in the longitudinal flue will vary in size depending on the water supply characteristic. However, for the purposes of this analysis a uniform diameter of 3 1/2 in. was assumed.

According to NFPA requirements, the most remote sprinklers (numbered 1, 2 and 8 in Figure 18) are assumed to be discharging at a pressure of 30 psi. The calculations are carried out in a standard manner (see NFPA Standard No. 13 for details) and result in a demand of 437 gpm at a pressure of 32 psi at the overhead cross main.

The flows in gpm through the various sections of pipe are indicated by arrows in Figure 18. Pressures in psi are also shown at several points in the system. The detailed calculations are given in Table 1.

3.3 ANALYSIS OF AN INTEGRATED SYSTEM UTILIZING TUBULAR RACK COLUMNS AS WATER CONDUCTORS

The piping and tubular rack columns are assumed to be arranged as shown in Figure 4. The pipe connecting the sprinklers to the columns is 1-in. nominal diameter. The columns are assumed to be square in cross section and 4 in. on a side. The size of the feed pipes will vary depending on the water supply characteristic; but, in order to compare the demand for this system with that for the system using standard circular pipes, a uniform diameter of 3 1/2 in. was assumed. Plan views of the system are shown in Figure 19.

The requirements for end head pressure and the number of operating sprinklers are the same as specified in Section 3.2. The seven sprinklers on each of the top two levels have been selected in a way that will produce the maximum demand.

FM

HYDRAULIC CALCULATIONS

TABLE 1

OF INTEGRATED SYSTEM UTILIZING STANDARD CIRCULAR PIPES

See Fig.	No. 18 F	or St.	ation Po	oints			BY	DATE 7/5/75	
SPKR. OR NO77LE IDENT. & LOCATION	FLOW IN G P M	PIPE	PIPE FITTINGS AND DEVICES	EQUIV. PIPE LENGTH	FRICTION LOSS PSI/FT.	PRESSURE SUMMARY	NORMAL PRESSURE	NOTES	
A	q			Lgth Fit		Pt 32.64	Pt Pv	-	
	¢ 62.44	3 1/2	! 	Tot 2	.003	.01	Pn		
3	32.57	1,		Lgth	_	91 32.65	Pt Pv	$q = 5.7 \sqrt{32.65}$	
	95.01	3 1		Tot 2	.006	Pf .61	Pn	-	
B	^q 62.41	1		Lgth Fit	_	Pt 32.66	Pt Pv	$q = 10.92 \sqrt{32.66}$	
	9 157.42	3 2		Tot 2	.015	Pf .03	Pn	See Sheet 3	
6	a 32.59	$3\frac{1}{2}$		Lgth		Pt 32.69	Pt Pv	$q = 5.7 \sqrt{32.69}$	
	° 190.01			Tot 2	.022	.04	Pn	-	
с	۹ 31.24				Lgth	_	Pt 32.73	Pt Pv	$q = 5.46\sqrt{32.73}$
	° 221.25	3 1/2		Tot 192	.029	Pf 5.57	Pn	See Sheet:3	
D	q _	1	CR-17	Lgth 10	_	Pt 38.30 Pe	Pt Pv	$P_{e} = .433 \times 10$	
provid.	° 221.25	3 1/2		17 ^{Tot} 27	.029	-4.33	Pn	= 4.33	
E	q 215.71		T-17	Lgth 15		Pt 34.75	Pt Py	$P_e = .433X15$	
667 9	° 436.96	$\begin{array}{c c} 3 \frac{1}{2} \\ \hline 700 \\ \hline 700 \\ \hline 700 \\ \hline 700 \\ \hline 32 \\ \hline 104 \\ \hline 700 \\ \hline $	-6.50 Pf 3.33	Pn	= 6.50 g from Sheet 2				
K-Main	q			Lgth		Pt 31.58	Pt	At Cross Main	
	Q	-		Tot	_	DI	Dn		

The Total Demand For Rack Sprinklers Is 437 GPM at 32 PSI

At The Cross Main (See Figure No. 18)



HYDRAULIC CALCULATIONS

FACTORY MUTUAL ENGINEERING ASSOCIATION

NavFac							SHEET BY	2 OF 3 22415 DATE
SPKR. OR NO7ZLE IDENT. & LOCATION	FLOW IN G P M	PIPE SIZE	PIPE FITTINGS AND DEVICES	EQUIV. PIPE LENGTH	FRICTION LOSS PSI FT.	PRESSURE SUMMARY	NORMAL	7/5/75 NOTES 1/2 A.S. K = 5.7
8	9 31.22 9	$-3\frac{1}{2}$		Lgth Fit	_	Pt 30	Pt Pv Pn	$q = 5.7 \sqrt{30}$
	31.22			Lgth	.001	Pi	Pt	
9	31.22	$3\frac{1}{2}$		Fit .		30.001	Pv Pn	_ q = 5.7 √30.001
	62.44			Lgth	.003	.01	Pt	
10	31.23	$-3\frac{1}{2}$		Fit Tot		30.01	Pv Pn	$q = 5.7 \sqrt{30.01}$
	93.0/ q			Lgth	.006	.02	Pt	
11	31.24	$-3\frac{1}{2}$		Fit		30.03	Pv	$q = 5.7 \sqrt{30.03}$
	124.91			Lgth	.01	.04	Pt	
12	31.26 °	- 3 ¹ / ₂		Fit	_	30.07	Pv	q = 5.7 √30.07
	156.17	2		Tot 4	.015	.06	Pn	
13	31.29	-3 ¹ / ₂		Fit		Pt 30.13	Pt Pv	$q = 5.7 \sqrt{30.13}$
	187.46	2		Tot 4	.021	.08	Pn	
14	⁹ 31.33	$-3\frac{1}{2}$	CR-17	Lgth 174 Fit 17	-	Pt 30.21	Pt Pv	q = 5.7 √30.21
	218.79	2		^{Tot} 191	.029	^{Pf} 5.54	Pn	
E	Q			Lgth Fit		Pt Pe 35.75	Pt Pv	$q = 218.79 \sqrt{\frac{34.75}{35.75}}$ = 215.71
	q			Lgth	-	Pt	Pn Pt	
Patro at Anna y Sa	Q	-		Fit		Pe	Pv	Flow Corrected For Press. = 215.71 @ E
	9			Leth	-	PI	Pt	
				Fit	-	Pe	Pv	-
	Q	7		Tot	-	PI	Pn	-
	9			Lgth		Pt	Pt	
	9	-		Fit		Pe	Pv Pn	
	1	1				States of States in 1		

FM

HYDRAULIC CALCULATIONS

FACTORY MUTUAL ENGINEERING ASSOCIATION

NavFac							BY	3 3 <u>3</u> 22415 DATE
K Facto	or For Bra	anch 1	Line 2nd	Level				7/5/75
SPKR. OR NO7ZLE IDENT. 4 LOCATION	FLOW IN G P M	PIPE SIZE	PIPE FITTINGS AND DEVICES	EQUIV. PIPE LENGTH	FRICTION LOSS PSI/FT. C =	PRESSURE SUMMARY	NOR MAL PRESSURE	NOTES 1/2" A.S. K = 5
q	31.22		T-5	Lgth 4.0		Pt 30	Pt	$q = 5.7 \sqrt{30}$
1				Fit 5	-	Pe	Pv	1
	31.22	-		Tot 9.0	.293	Pf 2.64	Pn	
9		-		Lgth		Pt	Pt	31.22
A		-		Fit	1	Pe 32.64	Pv	$K = \frac{32.62}{\sqrt{32.64}} = 5.4$
				Tot	4	Pf	Pn	
q				Lgth		Pt	Pt	For Single Line
				Fit	-	Pe	Pv	Tor single line
				Tot	-	P(Pn	
9				Lgth		Pt	Pt	For Double Line
			<u></u>	Fit		Pe	Pv	
	dian -			Tot	-	Pf	Pn	1
q	1	177		Lgth		Pt	Pt	1
				Fit	-	Pe	Pv	$K = \frac{2X31.22}{2} = 1$
	•			Tot	-	Pí	Pn	√32.64
q	ī			Lgth		Pt	Pt	
		_		Fit	-	Pe	Pv	
		1		Tot		Pf	Pn	
q	1		1	Lgth	1	Pt	Pt	
		100-	- Charles	Fit	-	Pe	Pv	-
				Tot	-	Pf	Pn	
q	1		1	Lgth		Pt	Pt	
				Fit		Pe	Pv	
G	,			Tot		Pf	Pn	
q		1		Lgth		Pt	Pt	
		-		Fit	1	Pe	Pv	
Max				Tot	1	Pſ	Pn	
9	í	1-		Lgth		Pt	Pt	
		_		Fit	1	Pe	Pv	
	1			Tot	1	Pf	Pn	1
q				Lgth		Pt	Pt	
				Fit	-	Pe	Pv	
ſ				Tot	-	Pf	Pn	-



The calculations have been carried out in a standard manner, except that Figure 20 in Appendix A has been used to calculate the friction loss in the 4-in. square columns. The demand for this system is 460 gpm at a pressure of 54 psi at the overhead cross main. The flows in gpm through the various sections of the feed pipe are indicated by arrows in Figure 19. The detailed calculations are given in Table 2.

3.4 COMPARISON OF RESULTS AND CONCLUSIONS

The flows and pressures required for a conventional system and the two integrated systems described in Sections 2.5 and 2.6 are given in Table 3 together with other pertinent information.

The flow requirement for the system utilizing tubular rack columns is slightly higher than the requirement for a system using standard circular pipes and the pressure requirement is moderately higher, but well within practical bounds.

Hydraulically, integrated sprinkler systems utilizing tubular rack columns as water conductors are practical. The flow and pressure requirements can be kept well within practical limits.



TABLE 2

HYDRAULIC CALCULATIONS

OF INTEGRATED SYSTEM UTILIZING TUBULAR RACK COLUMNS

	CONT. NO	. NOO	025-74-0				SHEET	1 ^{of} 3	22415		
See Fi	g. No. 19	for	Station	Points				BY		DATE 6/27/75	
SPKR. OR NOZZLE IDENT. & LOCATION	FLOW IN G P M	PIPE SIZE	PIPE FITTINGS AND DEVICES	EQUIV. PIPE LENGTH	FRICTION LOSS PSI/FT. C =	PRESSURE SUMMARY	NO	RMAL SSURE		NOTES	
15	۹ 	1		Lgth Fit	_	Pt 31.19 Pe	Pt Pv	66	K for & Sq.	Sprink. Assemb Column =	
	31.22	5 2		Tot 4	.001	.004	Pn			5.4	
16	۹ 34.08	1		Lgth Fit		31.19 Pe	Pt 40.	28	$q = 5.4 \sqrt{40.28}$		
	¢ 65.30	3 2		Tot 4	.003	9-09 Pí .01	Pn		= 34	.8	
17	⁹ 31.22			Lgth	-	Pt 31.20	^{Pt} 33.	80	q = 31	.22	
	96.52	$3\frac{1}{2}$		Tot 4	.006	2-60 Pf	Pn		-		
18	⁹ 34.10			Lgth	_	Pt 31.22	^{Pt} 40.	31	q = 34	.10	
	° 130.62	$3\frac{1}{2}$		Tot	- 011	9-09 Pf 04	Pn		-		
19	۹ 31.25			Lgth		Pt 31.26	Pt 33.	86	q = 31	.25	
	° 161.87	$-3\frac{1}{2}$		Tot	016	2-60 Pf 06	Pr		-		
20	^q 34.14			Lgth	.010	Pt 31.32	Pt 40.	41	q = 34	.14	
	°196.01	$-3\frac{1}{2}$		Tot	023	Pf 09	Pv		-		
21	g 31.32			Lgih	.025	^{Pt} 31.41	^{Pt} 34.	01	q = 31.3	1.32	
	Q 227.33	3 <u>1</u> 2	ļ	Tot 4	_	Pf 12	Pv		-		
22	⁹ 34.23			Lgth	03	Pt 31.53	^{Pt} 40.	62	q = 3	4.23	
	°261.56	$-3\frac{1}{2}$		Tot 4	- 04	Pr 9+09	Pr		-		
23	⁹ 31.45			Lgth .		Pt 31.69	Pt	29	q = 31	.45	
	ç 203 01	$-3\frac{1}{2}$		Fit Tot	- 040	Pe 2:60	Pv		-		
24	9 34.37			Lgth	.049	Pt 31.89	^{Pt} 40.	98	q = 34	.37	
	° 327.38	3 1 Pit Pe	9-09	Pv Pn		-					
25	q 21 65			Lgth	.06	.24 Pt 32.13	^{Pt} 34.	73	q = 31	.65	
25	°359.03	3 1/2		Fit		Pe 2-60	Pi]		

and successive

FM

HYDRAULIC CALCULATIONS

FACTORY MUTUAL ENGINEERING ASSOCIATION

NavFac	1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999				10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 		SHEET By	2 ^{of} 3	INDEX NO. 22415 DATE 6/27/75
SPKR. OR NO7ZLE IDENT. 4 LOCATION	FLOW IN G P M	DIPE SIZE	PIPE FITTINGS AND DEVICES	EQUIV. PIPE LENGTH	FRICTION LOSS PSI/FT. C =	PRESSURE SUMMARY	NORMAL PRESSURE		NOTES
26	q 24 60			Lgth		^{Pt} 32.41	^{Pt} 41.50	q = 34	.60
20	9 34.00	-, 1		Fit		9-09	Pv		
	393.63 ²	5 2		Tot 4	.086	.34	Pn		
	q	1		Lgth		^{Pt} 32.75	Pt 35.35	q = 31	.93
27	31.93	- 1		Fit	7	Pe 2.60	Pv	1.	
	425.56	3 =	-	Tot 4	.098	PI .39	Pn	-	
	9		2 T -34	Lgth 150		Pt 33.14	Pt 42.23	q = 34	.90
28	34.90	- 1		Fit 34		Pe 9-09	Pv		
	460.46	3 2		Tot 184	.114	Pf 20.98	Pn	1	
	9			Lgth		Pt 54 12	Pt	At Cro	ee Main
29				Fit		Pe	Pv	1 010	ss nain
	Q			Tot	-	Pf	Pn	-	

The Total Demand For Rack Sprinklers Is 460 Gpm at 54 PSI

At The Cross Main (See Fig. No. 19).



HYDRAULIC CALCULATIONS

FACTORY MUTUAL ENGINEERING ASSOCIATION

R NavFac	s						SHEET 3	OF 3 22415 DATE
K Fact	tor For Sp	rink.	Assemb.	& 4" Sq.	Col.			6/27/75
SPKR. OR NO7ZLE IDENT. & LOCATION	FLOW IN G P M	PIPE SIZE	PIPE FITTINGS AND DEVICES	EQUIV. PIPE LENGTH	FRICTION LOSS PSI/FT. C =	PRESSURE SUMMARY	NORMAL PRESSURE	NOTES 1/2" A.S. K=5.7
2	9 31.22 9	1	T-5 E-2	Lgth 2.5 Fit 7 Tot		Pt 30 Pe Pf	Pt Pv Pn	q = 5.7 √30
	31.22	-	Enlrg.	9.5 Lgth 5	.293	2.78 Pt 32.78	Pt	
	Q 21. 22	są.		Fit 11	00040	Pf	Pv Pn	
	9 9	18.5	T-10	Lgth 1	.00042	Pt 32.79	Pt	
·····	9 31.22	2		10 Tot 11	.011	Pf 0.12	Pn	-
16	q			Lgth	-	Pt 32.91 Pe	Pt Pv	At Feed Pipe
	Q		<u> </u>	Tot	-	Pí Pi	Pn	$K = \frac{31.22}{\sqrt{32.91}} = 5.4$
	Q	_		Fit Tot		Pe Pf	Pv Pn	4
1	g 31.22		T-5 E-2	Lgth 2.5 Fit 7	-	Pt 30 Pe	Pt Pv	$q = 5.7 \sqrt{30}$
	31.22			Tot 9.5	.293	Pf 2.78	Pn	1
	Q	4	Enlrg.	20 Fit 11	-	32.78 Pe	Pv	-
	31.22	Sq.		Tot 31	.00042	Pf 0.02	Pn Pt	ļ
	Q	2	T-10	1 Fit 10		92.80	Pv Pn	1
	9			Lgth	.011	0.12 Pt 32.92	Pt	At Feed Pipe
15	Q	-		Fit Tot	-	Pe Pf	Pv Pn	$K = \frac{31.22}{\sqrt{32.92}} = 5.4$
	q		122	Lgth Fit		Pi Pe	Pt Pv	-
	9			Tot	1	Pf Pt	Pn Pt	
	Q	-		Fit		Pe	Pv	
				Tot	35	М	Pn	

TABLE 3

COMPARISON OF INTEGRATED SPRINKLER SYSTEMS

WITH CONVENTIONAL SYSTEM

	Conventional System	Integrated System With Circular Pipes	Integrated System With Tubular Columns
Rack Length ft	400	400	400
Rack Height ft	80	80	80
Commodity Class	IV	N	IV
No. Open Sprinklers	14	14	14
End Head Pressure psi	30	30	30
Total Flow gpm	437	437	460
Total Pressure ps1*	32	32	54

*These are the pressures required at the celling cross main for the pipe sizes shown in Figures 18 and 19. Friction and elevation losses must be added to these pressures in order to obtain the pressures required at ground level.

IV COST EFFECTIVE ANALYSIS OF INTEGRATED SPRINKLER SYSTEMS

In an effort to obtain realistic comparative cost data, several rack manufacturers were first contacted. An attempt was made to determine the relative cost increase associated with the required changes in fabrication of the rack frame itself. Such changes would include the use of tubular columns as required in place of channel sections, welded fittings on the tubular columns as in Figure 10 and modifications to accommodate the feeding of water to the columns. These increased costs were then to be weighed against cost savings, if any, associated with the installation of the sprinkler system (as performed by a sprinkler contractor) such that an overall cost comparison picture could be obtained. Unfortunately, no specific cost information could be obtained from the manufacturers queried, without extensive study on their part. Cost quotations for obtaining the desired information from the manufacturers were solicited and proved to be prohibitive.

In spite of this information void, it was felt that the sprinkler system cost comparison would still provide meaningful information for a total cost comparison overview. The engineering department of Grinnell Fire Protection Systems Company, Inc. was retained to do a complete cost comparison for Factory Mutual Research Corporation's integrated design (Figures 4-10) versus a standard sprinkler system integration with identical sprinkler locations. As mentioned in Section 2.7 it was decided that the method of utilizing standard circular pipe as discussed in Section 2.6 would probably not generate practical savings and was, therefore, not included in this analysis.

The analysis and cost figures do not include consideration of the overhead protection system since the same elements would be required for both alternatives.

Attached as Appendix B is Grinnell's letter report together with their cost comparison summary sheet (Table 4), Sketch A (Figure 23) and five rack layout drawings (Figures 24-28). Based on the data in Table 4, significant cost savings appear possible with the integrated system. Unfortunately, we do not know the costs associated with the couplings and steel plates as discussed in Grinnell's letter or the increased cost of tubular stock over channel stock where required (if not already necessary due to load). However, it seems unlikely that these costs could possibly exceed half the savings noted. It should also be recognized that, if overhead and profit are a direct percentage of labor and materials, the total savings will be even greater.

CONCLUSIONS

- Depending on the expected load per vertical column, the columns may require tubular stock to provide necessary support. In such cases, no additional cost would result solely as an integrated rack fire protection requirement.
- 2. It does not appear that a partially integrated rack fire protection system as described in Section 2.6 would result in a significant overall gain.
- 3. A fully integrated rack fire protection system as described in Section 2.5 is feasible and practical and would result in sprinkler system cost savings of up to 30 percent.
- 4. Because of the much smaller lengths of pipe involved, an integrated rack fire protection system would be less likely to sustain physical damage due 1) to equipment malfunction in a non-fire environment and 2) to falling debris in a fire condition.

APPENDIX A

FRICTION LOSS IN PIPES OF NON-CIRCULAR SECTION

Friction loss in sprinkler system piping is calculated from the William and Hazen formula. In the original form it was written

$$\mathbf{v} = 1.318 \ \mathrm{cR}^{0.63} \ \mathrm{s}^{0.54} \tag{1}$$

where V = mean velocity in feet per second

C = coefficient of roughness

R = hydraulic radius (the ratio of the cross sectional area of the pipe to its wetted perimeter)

S = hydraulic slope (the ratio of lost head to the pipe length)

Introducing the proper conversion factors, the equation may be written in more practical terms as,

$$P = 0.00529LQ^{1.85} / c^{1.85} R^{4.87}$$
 (2)

where P = friction loss in psi

L = length of pipe in feet

2 = flow in gpm

and C and R remain as defined above.

Equation 2 may be used for a pipe of any shape because the hydraulic radius R has been retained as a factor rather than being converted to a diameter for use with circular pipes. The hydraulic radius for a circular pipe is equal to D/4 and if this value is substituted into eq (2), the more familiar form of the equation is obtained as

$$P = 4.52 \text{ LQ}^{1.85} / \text{c}^{1.85} \text{ D}^{4.87}$$
(3)

where D = the diameter for a circular pipe.

With the aid of eq (2), the charts shown in Figures 20, 21 and 22 have been prepared to facilitate the calculation of friction loss in non-circular pipes. A simple example will illustrate their use. Suppose it is desired to find the friction loss per foot for a flow of 100 gpm through a smooth pipe of rectangular section measuring 2 in. by 3 in. The hydraulic radius for the pipe is

 $R = Area \div Perimeter = (2 \times 3)/10 = 0.60 in.$

Entering the chart in Figure 22 at 100 gpm and following upward to the line marked .60, a friction loss of .045 psi per foot is read from the vertical scale.

Equation 2 may be used in preference to the charts, if desired. By the formula:

P = $(0.00529 \times 1 \times 100^{1.85}) / (120^{1.85} \times 0.60^{4.87})$, or P = 0.045 psi per foot, as before.







Figure. No. 21. Friction Loss in Non-Circular Pipes H&W C=120 (Hydraulic Radius = Area + Perimeter)



Figure No. 22. Friction Loss in Non-Circular Pipes H&W C=120 (Hydraulic Radius = Area + Perimeter) 44

: 1

APPENDIX B

DATA SUPPLIED BY GRINNELL FIRE PROTECTION SYSTEMS COMPANY, INC.

. 1

1467 ELMWOOD AVENUE CRANSTON, R. I. 02910 TEL: (401) 781-3800 TELEX: 92 7526

November 18, 1975

Factory Mutual Research 1151 Boston- Providence Turnpike Norwood, MA 02062

Attention: Mr. L. M. Krasner Senior Research Scientist

Subject: Naval Facility Contract N00025-74-C-0023

Gentlemen:

Enclosed is one print each of our drawings No. 1 through 5 showing the proposed rack protection for a standard rack system and Factory Mutual's layout using the 4-inch tubular steel columns on the racks to supply the sprinkler heads.

Both rack systems consisting of 4,553 Grinnell Q-16 sprinklers are supplied by one sprinkler riser with an alarm valve and are hydraulically calculated to deliver 30 psi through the most remote sprinkler on top line with 14 sprinklers operating, 7 each on the top two levels. Pressure available at the base of the riser would be 100 psi with approximately 480 gallons flowing. The standard rack system would require a 6-inch alarm valve and riser and the Factory Mutual system would require a 4-inch alarm valve and riser.

We have estimated the Factory Mutual system would cost \$207,181.00 to install, less overhead and profit, against \$297,259.00 for the standard rack system or approximately 30% less.

We are attaching copies of work sheets showing the costs for each system, plus a summary sheet comparing the engineering, material and labor for each system. The engineering charges for each system would be the same, material for the Factory Mutual system would be approximately \$88,669.00 or 26.9% more than the standard layout. The Factory Mutual system would result in a labor savings of 48.6%.

EXECUTIVE OFFICES PROVIDENCE, R. I. Not included in our cost comparison would be the price of 4553 l-inch couplings welded to the 4-inch tubular supports, 2275 4-inch steel plates with $2\frac{1}{2}$ -inch couplings welded to the top of the tubular supports of the racks and 2275 3/4-inch drain connections installed at the bottom of the tubular supports of the racks if required.

RINNELL FIRE PROTECTION SYSTEMS COMPANY, INC. ractory Mutual Research November 18, 1975 Page 2

The price for the Factory Mutual layout was based on $3\frac{1}{2}$ -inch crossmains at the top of the racks cut five foot on center with a Victaulic coupling before each standard screwed tee. If we could substitute a 20-foot length of 4-inch thin wall pipe with four $2\frac{1}{2}$ -inch grooved brancholet outlets welded five foot on center as shown on our alternate layout of attached sketch "A", we could save approximately \$4,200.00 on the material price over the 5-foot pieces of $3\frac{1}{2}$ -inch main with a grooved coupling.

To use the 20-foot length of 4-inch pipe with the four $2\frac{1}{2}$ -inch outlets welded five foot on center, the 4-inch tubular supports on the racks would have to be spaced exactly five-foot on center.

We are forwarding under separate cover sepias of our five drawings No. 1 through 5 showing the rack layouts.

If you have any questions, please call.

Very truly yours,

GRINNELL FIRE PROTECTION SYSTEMS COMPANY, INC.

A. J./Girard

District Manager

AJG/dab

Enclosures





Material Cost		
1 - 3 1/2" Tee		5.76
1 - 3 1/2" Vic Coup		4.85
5 ft 3 1/2" Pipe @ 1	.8¢ per fi	t 9.18
2 ea. Cuts		1.04
2 ea. Thds.		1.02
2 ea. Grooves		5.28
$1 - 2 \frac{1}{2} \times 1 - 0$ Nip		2.69
	Total	29.82
For 5'-0" Segment		
2275 Conn's @ 29.82	= \$67,840.	.50



ALTERNATE LAYOUT



FIGURE 23 MATERIAL COSTS OF ALTERNATIVE LAYOUTS

FM LA	YOUT	STANDARD LAYOUT	FM LAYOUT Over 2	VS. STANDAR Under	D %	
Engineerin	g \$ 3,600	\$ 3,600	-	-		
Material	88,669	69,841	\$18,828 26.	.9		
Labor	114,912	223,818		\$108,906	48.6	
Total	207,181	297,259		90,078	30	

TABLE 4 RACK SYSTEM COST COMPARISON

Actual Estimated Cost Less Overhead & Profit

•

I shall be the ball of the bal	
	Refer
	19. 74-
	- Los Art
	2 22
	G
	• • • • • • • • • • • • • • • • • • •
	~ ~
	× ×
in a property property of the second property	win.
	Dra BR
	11 III
	- 8
	- alli
	A
	5
	8
	I F ISHIN

-0		1.
A Print Bar Bar Bar Bar A Print Bar A Prant		:
		-
		+
		1.
		+
<u>╶</u> ┥ <u>╶</u> ╎ <u>╴</u> ╎╴┥╖┝╖┝╖┝╖┝╷┝╷┝╷┝╷┝╷┝╷┝╷┝┙┝╖┝╖┝╖┝	<u></u>	
		-
ddddddddddddd		+
		-
a budineed at a budine budine budine and a budine		+.
		+
		-
		-
2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	8 8 8 8 8 8 8	+
		-
		7
	<u>- </u>	+
		ł
		+
		ł
	╶╋╾┢╾┢╾┢┯╋╌╎╌╎╌┝╌┝╶┝╸┝	1
		+
		- 44
- 100 200 40 40 40 40 40 40 40 40 40 40 40 40 4		1
		+-
DECT AVAILABLE FODV		
DLUI AVAILAULL CULI Grimel	Drawing No.3	
		1.5000
		1
		Same a

- but the second of the second	
fass 221 m13' leave	
b & & & & & & & & & & & & & & & & & & &	
╶ <u>┿╺╶</u> ┿╸╬╸╬╸╏╸╏╸╏╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎╸╎	
Lebert Labort Labort 1 a Labort 1	
SFN AVAILABLE LUPY FIGURE 27	
Grinnell Drawing No.4	
	NOV FAC CONF NO NO 0015-74-6-0071
	Freist Mutual Passance
	STANDARD RACK LAYON

