

AD-A056 416

ARMY TROPIC TEST CENTER APO NEW YORK 09827
INTENSIVE TROPIC FUNCTION TESTING, (U)
JUN 78 E M CADY

F/G 15/5

UNCLASSIFIED

NL


| OF |

AD
A056416



END
DATE
FILMED
8-78
DDC






AD A056416

LEVEL II



INTENSIVE TROPIC FUNCTION TESTING

ELDON M. CADY, MR.
US ARMY TROPIC TEST CENTER
APO NEW YORK 09827



JUN 1978

INTRODUCTION:

Tropic testing of US Army materiel includes a storage phase designed to surface the adverse effects of the humid tropics. Failures are sometimes catastrophic, but are usually time dependent. Regulations such as AR 1000-1 (1) require that efforts be made to reduce Development Test time. Project Managers and DARCOM commodity commands have curtailed or foregone Development Tests because of excessive time/cost considerations. It was hypothesized that reducing test calendar time while increasing test functioning time, i.e., increasing the ratio of operational hours to calendar days may yield quicker and still valid test results for some categories of equipment. Large quantities of Reliability, Availability and Maintainability (RAM) data could be generated quickly for immediate analysis using standard RAM data analysis. A methodology investigation was conducted at the US Army Tropic Test Center to validate the intensified testing concept and reassess storage testing.

The tropic storage period results in a relatively long period of dormancy between data generation and the final production of test reports. Because the storage period represents a significant amount of calendar time, it had been repeatedly proposed that the storage phase be shortened or eliminated and that each test item be tested at an intensified functioning rate. Advocates of intensified functioning considered that the same quality of RAM data would be generated in a shorter calendar period. This is based on the assumption that number of operational hours is the only factor required for developing valid RAM data. The Tropic Test Center has observed materiel failures which occurred in the tropic storage phase of Development Tests. Examples of

78 06 12 060

DISTRIBUTION STATEMENT A

Approved for public release;
Distribution Unlimited

AD No. _____
IDC FILE COPY

042 290

JOE

CADY




Figure 1. Test Site with Generators Mounted on a Concrete Pad




Figure 2. Load Bank System for Power Dissipation

CADY




Figure 3. Control Console with Oscilloscope Attached




Figure 4. Shunt Resistor for Measuring Current Levels

CADY

and transient current levels were measured. Voltage and frequency levels for each generator were monitored and recorded on an hourly basis by an operator who reported malfunctions. Close monitoring was intended to identify the onset of a malfunction in order to initiate prompt maintenance action.

DISCUSSION OF RESULTS:

A summary of the data used in the analysis is presented in Tables I, II, and III. These tables present the basic data and computed RAM parameters for each of the functional modes and individual generators. Of these parameters, Mean Time Between Failures (MTBF) and Mean Time Between Maintenance Actions (MTBMA) are the most useful in assessing RAM performance. The discussion is confined to functional modes rather than individual generator performance. To establish a commonality, the data have been normalized to a per 1000 hours of operation basis.

In Tables I, II, and III there are five items of data per functional mode that lend themselves for RAM performance comparisons. These are the MTBF, MTBMA, Number of Chargeable System Failures per 1000 Hours (CSF/1000), Maintenance Actions per 1000 Hours (MA/1000) and Unscheduled Maintenance Time per 1000 Hours (UMT/1000). The MTBF is inversely proportional to CSF/1000 and the MTBMA is inversely proportional to MA/1000; therefore, only the values for the MTBF, MTBMA, and UMT/1000 are used as comparison parameters.

The MTBF was 243.0 hours for the Intensive Function Mode, 176.6 hours for the Storage Mode and 182.4 hours for the Simulated Tactical Use Mode. This indicates that the Intensive Function Mode had the longest operation period between failures, and that the Storage and Simulated Tactical Use Modes were similar, with the Storage Mode being slightly less. The second parameter, the MTBMA for the Intensive Function Mode, was 134.2 hours; the Storage Mode was 56.2 hours; and the Simulated Tactical Use Mode was 94.8 hours. The ranking for MTBMA is the same as for MTBF, except that the difference between the Storage Mode and the Simulated Tactical Use Mode is larger.

The UMT/1000 in Tables I, II, and III for the Intensive Function Mode was 2.8 hours, whereas the Storage and Simulated Tactical Use Modes were both 7.2 hours. Again, the Intensive Function Mode differs considerably from the other modes.

Additional computed RAM data are provided in Table IV for the functional modes. The MTBF and MTBMA data are also presented for convenience. Another useful RAM parameter is the Mean Time to Repair

TABLE I. SUMMARY OF INTENSIVE FUNCTION MODE DATA

Generator Number	Test Hrs	Total Test Hrs	Number Chargeable System Failures	Number Chargeable Maint 1000 Hrs	Number Chargeable System Failures per 1000 Hrs	MTBF (Hrs)	MTBMA (Man-Hrs)	Active Maintenance Time*			Unused Maint Time per 1000 Hrs
								Unused (Man-Hrs)	Scd (Man-Hrs)	Total (Man-Hrs)	
1	878.6	6	4	6.8	4.6	3.6	219.7	146.4	3.0	6.6	4.1
2	2033.0	18	10	8.9	4.9	5.9	203.3	112.9	6.1	12.0	2.9
3	1867.5	17	10	9.1	5.4	5.7	186.8	109.9	6.1	11.8	3.1
4	2077.9	10	4	4.8	1.9	3.4	519.5	207.8	5.1	8.5	1.6
5	2133.1	16	9	7.5	4.2	6.7	237.0	133.3	4.6	11.3	3.1
Total	8990.1	67	37	—	—	25.3	—	25.3	24.9	50.2	—
Mean	1798.0	13.4	7.4	7.5	4.1	5.1	243.0	134.2	5.0	10.0	2.8
Standard Deviation	523.4	5.2	3.1	—	—	1.5	—	1.5	1.3	2.4	—

TABLE II. SUMMARY OF STORAGE MODE DATA

6	502.4	10	4	19.9	8.0	3.0	125.6	50.2	3.0	8.0	11.0	6.0
7	501.3	7	1	14.0	2.0	1.5	501.3	71.6	1.5	8.0	9.5	3.0
8	464.4	11	5	23.7	10.8	10.5	92.9	46.4	10.5	8.0	18.5	10.8
9	502.7	8	2	15.9	4.0	1.4	251.4	62.8	1.4	8.1	9.5	2.8
10	501.5	9	2	17.9	4.0	1.4	250.8	55.7	1.4	7.6	9.0	2.8
Total	2472.3	44	14	—	—	17.8	—	—	17.8	39.7	57.5	—
Mean	494.5	9.0	2.8	17.8	5.7	3.6	176.6	56.2	3.6	7.9	11.5	7.2
Standard Deviation	16.8	1.6	1.6	—	—	3.9	—	—	3.9	0.2	4.0	—

TABLE III. SUMMARY OF SIMULATED TACTICAL USE DATA

11	1024.1	5	1	4.9	1.0	1.0	1024.1	204.8	1.0	2.1	3.1	1.0
12	978.2	13	8	13.3	9.2	13.2	108.7	75.3	13.2	3.0	16.2	13.5
13	732.3	15	10	20.5	13.7	13.5	73.2	48.8	13.5	3.5	17.0	18.4
14	1004.0	11	5	11.0	5.0	4.0	200.8	91.3	4.0	4.0	8.0	4.0
15	1002.8	6	2	6.0	2.0	2.5	501.4	167.1	2.5	3.5	6.0	2.5
Total	4741.4	50	27	—	—	34.2	—	—	34.2	16.1	50.3	—
Mean	948.3	10	5.4	10.5	5.7	6.8	182.4	94.8	6.8	3.2	10.1	7.2
Standard Deviation	121.8	4.4	4.0	—	—	6.0	—	—	6.0	0.7	6.2	—

* Excludes oil changes

CADY

TABLE IV. SUMMARY OF COMPUTED RAM DATA

1	Mean Time Between Failures	
	Test Modes	
	a. Intensive Function	243.0
	b. Storage	176.6
	c. Simulated Tactical Use	182.4
2	Mean Time Between Maintenance Actions	
	Test Modes	
	a. Intensive Function	134.2
	b. Storage	56.2
	c. Simulated Tactical Use	94.8
3	Mean Time To Repair	
	Test Modes	
	a. Intensive Function	0.0
	b. Storage	1.3
	c. Simulated Tactical Use	1.0
4	Mean Time To Repair Unscheduled Maintenance Actions	
	Test Modes	
	a. Intensive Function	0.7
	b. Storage	1.3
	c. Simulated Tactical Use	1.3
5	Maintenance Ratio	
	Test Modes	
	a. Intensive Function	0.006
	b. Storage	0.023
	c. Simulated Tactical Use	0.011
6	Maintenance Ratio For Unscheduled Maintenance Actions	
	Test Modes	
	a. Intensive Function	0.003
	b. Storage	0.007
	c. Simulated Tactical Use	0.007

CADY

(MTTR). It is a measure of the degree of difficulty in performing maintenance actions, and was obtained by dividing the total active maintenance time for that functional mode by the total number of maintenance actions. The MTTR involves all maintenance actions, scheduled and unscheduled. For the MTTR, the Intensive Function Mode is 0.7 hours, the Storage Mode is 1.3 hours, and the Simulated Tactical Use Mode is 1.0 hour. Again, the Intensive Function Mode has required less time for repair than either of the other modes. Another MTTR value is for Un-scheduled Maintenance Actions which is concerned primarily with actions involving generator malfunctions. In this case the Intensive Function value is 0.7 while the Storage and the Simulated Tactical Use values are both 1.3. The Intensive Function Mode required about half the time of the other two functional modes. The two remaining parameters in Table IV are the Maintenance Ratio and the Maintenance Ratio for Un-scheduled Maintenance Actions. These are computed by dividing the active maintenance time, either total or unscheduled, by the total operational hours of each functional mode. The Maintenance Ratio for the Intensive Function Mode was 0.006, the Storage Mode was 0.023, and the Simulated Tactical Use Mode was 0.011. In the Maintenance Ratio for Un-scheduled Maintenance Actions, the results were Intensive Function Mode 0.003, Storage Mode 0.007, and Simulated Tactical Use Mode 0.007. Both types of Maintenance Ratios show that the Intensive Function Mode produces lower values than the other two functional modes, and again the Storage and Simulated Tactical Use Modes had equivalent values.

It was assumed that the computed data (Tables I, II, III, and IV) are measures of the degree of operational severity for each functional mode to permit the construction of an arbitrary matrix for comparative purposes. The matrix (Table V) was based on six parameters (MTBF, MTBMA, UMT/1000, MTTR, MTTR Un-scheduled Maintenance Actions, and Maintenance Ratio for Un-scheduled Maintenance Actions) selected from the previous tables. For each parameter, a numerical value of one was given to the functional mode that was considered least severe; the value of two was given for the median severity; and the value of three for the most severe. In the case of two modes being equal for a given parameter, a value of 1.5 or 2.5 was assigned to both depending on degree of severity. The data are summarized in Table V. For all six parameters the Intensive Function Mode was given the value of one for being least severe. For three (MTBF, MTBMA, and MTTR) of the six parameters, the Storage Mode was the most severe and for the other three parameters it was equal to the Simulated Tactical Use Mode in severity. The ranking from least to most severe was as follows: Intensive Function Mode, Simulated Tactical Use Mode and Storage Mode, with a proportionality of 1:2.3:2.8, respectively.

CADY

TABLE V. SEVERITY OF OCCURRENCE

TEST MODE	SOURCE					Summary Of Rows
	MTBF	MTBMA	Unsed Maint Time per 1000 Hrs	Mean Time to Repair	Mean Time to Repair Unsed Maint Actions	Maint Ratio for Unsed Maint Actions
Intensive Function	1	1	1	1	1	6
Storage	3	3	2.5	3	2.5	16.5
Simulated Tactical Use	2	2	2.5	2	2.5	13.5
1 Least Severe Test						
2 Median Severe Test						
3 Most Severe Test						

NOTE: If equal in value, then assigned value will be 1.5 or 2.5 based on severity rank.

CADY

Tables I, II, and III also provide information on individual generators so that questions may be asked concerning the types of malfunctions that occurred and major differences in the types of malfunctions. To examine these questions, Tables VI and VII were prepared to summarize the data in appropriate form. Table VI is a Summary of Unscheduled Maintenance Actions by type of maintenance action performed and time involved for each functional mode. The number of maintenance actions, in decreasing order, were carburetor, ignition and voltage regulator, regardless of functional mode. To establish a baseline for comparative purposes, Table VII presents Normalized Unscheduled Maintenance Actions. The scheduled maintenance actions were not considered because some involved work unique to each functional mode. This table also includes the average time to perform each action. For carburetors, the Storage Mode had more actions per 1000 hours, thus more time charged per 1000 hours, but the actual time per action for all three modes was about the same. This indicates that similar types of maintenance actions were performed on the carburetors, regardless of the functional mode. However, voltage regulators in the Storage Mode, required the least actions per 1000 hours. The Time Charged per 1000 Hours for the voltage regulator, the Storage Mode is half way between the Intensive Function and the Simulated Tactical Use Modes. However, the Time per Action for the storage mode is the highest. This means that, although the frequency of maintenance actions was less on voltage regulators of the Storage Mode, the amount of time required for that action was greater. For the ignition category, it is found that the Storage Mode had the highest number of maintenance actions performed per 1000 hours but the Simulated Tactical Use Mode had the most time per action. Although the number of actions per 1000 hours for Intensive Function Mode ignition maintenance actions is similar to the other two modes, there is a major difference in its value for the Time Charged per 1000 Hours and also for the Time per Action. This indicates that there is a difference in the type and degree of difficulty involved in the ignition maintenance actions performed during the Intensive Function Mode when compared with the other two modes.

This discussion has dealt with examining the three functional modes by operational hours instead of by calendar time. Because operation hours are rapidly accumulated in the Intensive Function Mode and the Storage Mode involves a long dormant period, it was determined that biased data would result from comparing the two modes by calendar time. Although it is recognized that the Intensive Function Mode produces malfunctions rapidly in a much shorter calendar period and produces RAM data in a shorter time, the rate and types of failure produced differ in comparison with the other two test modes.

TABLE VI. SUMMARY OF UNSCHEDULED MAINTENANCE ACTIONS

Type Of Maintenance Action	Intensive Function			Storage Mode			Sim Tactical Use		
	Number Of Actions	Time Charged	Number Of Actions	Time Charged	Number Of Actions	Time Charged	Number Of Actions	Time Charged	
Carburetor	14	11.5	7	6.0	6	7.1			
Voltage Regulator	5	3.0	1	1.5	5	4.5			
Ignition	11	7.6	4	4.7	6	10.1			
Fuse Breaker	3	0.4	-	-	-	-			
Valve	1	0.1	-	-	2	2.5			
Frequency Meter and Converter	-	-	-	-	3	2.5			
Miscellaneous	3	2.7	2	5.6	4	7.5			
Total	37	25.3	14	17.8	26	34.2			

TABLE VII. SUMMARY OF NORMALIZED UNSCHEDULED MAINTENANCE ACTIONS

TYPE OF MAINTENANCE ACTION	INTENSIVE FUNCTION				STORAGE MODE				SIMULATED TACTICAL USE			
	Unscd Maint Act per 1000 Hrs	Unscd Maint per 1000 Hrs	Time per Action (Hr)	Time per Action (Hr)	Unscd Maint per 1000 Hrs	Unscd Maint per 1000 Hrs	Time per Action (Hr)	Time per Action (Hr)	Unscd Maint per 1000 Hrs	Unscd Maint per 1000 Hrs	Time per Action (Hr)	Time per Action (Hr)
Carburetor	1.6	1.3	0.8	0.8	2.8	2.4	0.9	0.9	1.5	1.5	1.0	1.0
Voltage Regulator	0.6	0.3	0.6	0.6	0.4	0.6	1.5	1.5	1.1	0.9	0.9	0.9
Ignition	1.2	0.8	0.7	0.7	1.6	1.9	1.2	1.2	1.3	2.1	1.7	1.7
Miscellaneous	0.3	0.3	0.9	0.9	0.8	2.3	2.8	2.8	0.8	1.6	1.9	1.9

CADY

CONCLUSIONS:

On the basis of the results of the investigation discussed herein, the following conclusions are offered:

1. In terms of test severity, as depicted by the RAM parameters analyzed, the Intensive Function Mode ranked the least severe, the Simulated Tactical Use Mode next, and the Storage Mode was the most severe.

2. Materiel items having electro-mechanical characteristics similar to the 1.5 KW AC generators and tested in an Intensified Function Mode will probably not produce higher failure rates than Storage or Simulated Tactical Use Modes.

3. Malfunctions which occurred were of similar nature for all three modes (i.e., carburetor, voltage regulator, and ignition); however, the time required to correct the malfunctions was less for the Intensive Function Mode.

4. Pertinence of the findings of this investigation should be explored for other materiel systems such as electronic and various weapon systems.

5. The need for a tropic storage phase in development testing is essential and is supported by results of this investigation. The optimum period for the storage phase requires further investigation.

REFERENCES:

1. AR 1000-1 Basic Policies for System Acquisition by the Department of the Army, 5 Nov 75.

2. US Army Air Defense Board Final Report, DT II, Service Phase, Forward Area Alerting Radar (FAAR) (Tropic Environment) (U), TECOM Project No. 3 EE MPQ 049 034, Mar 74.

3. US Army Aviation Test Board Final Report, Tropic Service Test of OH-58A Helicopter System, TECOM Project No. 4-A1-130-58A-010, 19 Jan 71.

4. US Army Tropic Test Center Final Report, DT II, Tropic Integrated Engineering and Service Phase of Modular Collective Protection Equipment (MCPE), TECOM Project No 2 ES 825 MCP 005, Sep 76.

name of au-
thor(s) here

CADY

Start here
For all
pages of
the first

5. DA Technical Manual, TM-5-6115-323-15, Generator Set,
Gasoline Engine Driven, Skid Mounted, Tubular Frame, 1.5 KW, Single
Phase, AC, 120/240V, 9 September 1970.

first
page of
title of
paper here

where
applied
to by

first line