


REPORT NO. CG-D-75-77

LEVEL

COST EFFECTIVENESS STUDY OF
WASTEWATER MANAGEMENT SYSTEMS FOR
SELECTED U.S. COAST GUARD VESSELS
Volume III - Installation Analysis
Part 5 - WHITE SAGE (133')


AD A0 61 104

Sidney Orbach
BRADFORD NATIONAL CORPORATION
1700 Broadway
New York, N.Y. 10019



February 1977

FINAL REPORT



Document is available to the U. S. public through the
National Technical Information Service,
Springfield, Virginia 22161

FILE COPY

PREPARED FOR
U.S. DEPARTMENT OF TRANSPORTATION
MARINE POLICE COAST GUARD
OFFICE OF RESEARCH AND DEVELOPMENT
WASHINGTON, D.C. 20540

2004 0317 006

78 11 06 086

BEST AVAILABLE COPY

NOTICE

This document is disseminated under the sponsorship of the Department of Transportation in the interest of information exchange. The United States Government assumes no liability for its contents or use thereof.

The United States Government does not endorse products or manufacturers. Trade or manufacturers' names appear herein solely because they are considered essential to the object of this report.

The contents of this report do not necessarily reflect the official view or policy of the U.S. Coast Guard and do not constitute a standard, specification, or regulation.

1. Report No. CG-D-75-77		2. Government Accession No.		3. Recipient's Catalog No.	
4. Title and Subtitle COST EFFECTIVENESS STUDY OF WASTEWATER MANAGEMENT SYSTEMS FOR SELECTED U. S. COAST GUARD VESSELS Volume III - Installation Analysis Part 5 - WHITE SAGE (133')		5. Report Date February 1977		6. Performing Organization Code	
		8. Performing Organization Report No.		10. Work Unit No. (TRAVIS)	
7. Author(s) Sidney Orbach		9. Performing Organization Name and Address BRADFORD NATIONAL CORPORATION 1700 Broadway New York, N. Y. 10019		11. Contract or Grant No. DOT-CG-52180-A	
12. Sponsoring Agency Name and Address U. S. Dept. of Transportation U. S. Coast Guard, Office of Research and Development Washington, D. C. 20590		13. Type of Report and Period Covered FINAL REPORT		14. Sponsoring Agency Code G-DOE-1/TP54	
		15. Supplementary Notes Volume III of a six volume report. Volume III has been published in six parts.			
16. Abstract Each of the 18 candidate Wastewater Management System (WMS) configurations developed in Volume IV was analyzed for installation aboard the WHITE SAGE (WLM - 544). The following information was developed: vessel conditions including locations of black water (sewage and garbage grinder slurry) and gray water (galley and turbid) waste sources, vessel/resources capacities and estimated usage rates, determination of viable candidate systems based on installation guidelines and assumptions developed in Volume IV, black and gray wastewater (or sludge) holding tank capacities which can be fitted, installation cost estimates for each viable candidate system, arrangement drawings for WMS equipment and waste sources, installation related effectiveness attribute data. The analysis was performed in three stages. A preliminary installation analysis was made on the basis of vessel plans available. This was followed by a shipcheck of the vessel to determine the viable candidate systems and obtain required vessel data. The final step consisted of a more detailed analysis of each viable candidate system to develop installation cost estimates and other required installation related information including arrangement drawings and effectiveness attribute data. Cost estimates were developed using a form which analyzes each viable candidate system in terms of standard installation cost elements, each of which has an assumed unit cost.					
17. Key Words Emission Standards Wastewater Management Installation Analysis Systems Marine Sanitary Devices MSD Pollution Abatement			18. Distribution Statement Document is available to the U. S. public through the National Technical Information Service, Springfield Virginia 22161		
19. Security Classif. (of this report) UNCLASSIFIED		20. Security Classif. (of this page) UNCLASSIFIED		21. No. of Pages 159	22. Price

4
4

60 11 0 - 036

6

COST EFFECTIVENESS STUDY OF
WASTEWATER MANAGEMENT SYSTEMS FOR
SELECTED U.S. COAST GUARD VESSELS
 Volume III % Installation Analysis
 Part 5 % WHITE SAGE (133')

12) 162 p.

10) Sidney Orbach

BRADFORD NATIONAL CORPORATION 410 928
 1700 Broadway
 New York, N.Y. 10019

18) 2526

11) February 1977

19) D-75-77-vol-3-pt-5

9) FINAL REPORT

For
 U.S. Dept. of Transportation
 U.S. Coast Guard
 Office of Research and Development
 Washington, D.C. 20590

15) Contract No. DOT-CG-52180-A

1370
706170

410 928

alt

ACKNOWLEDGEMENTS

This study was conducted under the technical direction of Mr. Thomas S. Scarano of the Office of Research and Development, U.S. Coast Guard. Mr. Scarano and Lt. Ed Magsig of the Office of Engineering made available the vessel plans and provided valuable assistance in the formulation of the guidelines and assumptions governing this installation analysis.


The installation analysis was performed in consultation with George G. Sharp, Inc., 100 Church Street, New York, N.Y. 10007.

The cooperation and assistance of the officers of U.S. Coast Guard Cutter WHITE SAGE (WLM-544) in scheduling the shipcheck and providing the requested vessel data is greatly appreciated.

ACCESSION for	
NIS	A. 10 Section <input checked="" type="checkbox"/>
DOC	B. 10 Section <input type="checkbox"/>
J S I 105 104	
DISTRICT HEADQUARTERS CODES	
SPECIAL	
A	

PREFACE

The relationship among the volumes of the report is depicted below. This relationship does not convey all the information contained within each volume.



SUMMARY OF WMS INSTALLATION COSTS

Vessel: WHITE SAGE (133')

WMS No.	Col/Trans Subsys (Black)	TYPE		Holding Capacity		INSTALLATION COST (\$)
		Treatment/Disposal Subsystem		Black (%)	Gray (%)	
		Black	Gray			
1	Gravity Collect.	Holding Tank	Holding Tank	100	100	13,190
2	Oil Recircul. (Chrysler)	Chrysler + Hld Tnk	Holding Tank	100	100	13,800
3		Chrysler + Incin.	Holding Tank	100	100	16,800
4	Gravity Collect. (Grumman)	Grum Flow Thru+HldTk	Holding Tank	100	100	17,000
5		Grumman Flow Thru + Holding Tank		100	100	12,890
6	Gravity Collect.	Holding Tank	Grum Flow Thru+HldTnk	100	100	15,460
7	Gravity Collect. (Grumman)	Grum Flow Thru+Incin.	Holding Tank	100	100	23,080
8		Grumman Flow Thru + Incinerator		100	100	13,100
9	Vacuum Collect. (Jered)	Holding Tank	Holding Tank	100	100	12,730
10		Incinerator	Holding Tank	100	100	16,300
11		GATX Evap.	Holding Tank	100	100	12,220
12		Holding Tank	Grum Flow Thru+Hld Tnk	100	100	10,600
13		Incinerator	Grum Flow Thru + Incin.	100	100	13,640
14		M/T Pump Collect. (GATX)	Holding Tank	Holding Tank	100	100
15		Incinerator	Holding Tank	100	100	15,790
16		GATX Evap.	Holding Tank	100	100	10,930
17		Holding Tank	Grum Flow Thru+Hld Tnk	100	100	10,970
18		Incinerator	Grum Flow Thru + Incin.	100	100	15,640

N/A - Not a viable candidate system for this vessel.



METRIC CONVERSION FACTORS

Approximate Conversions to Metric Measures

Symbol	When You Know	Multiply by	To Find	Symbol
LENGTH				
in	inches	2.5	centimeters	cm
ft	feet	30	centimeters	cm
yd	yards	0.9	meters	m
mi	miles	1.6	kilometers	km
AREA				
sq in	square inches	6.5	square centimeters	cm ²
sq ft	square feet	0.09	square meters	m ²
sq yd	square yards	0.8	square meters	m ²
sq mi	square miles	2.6	square kilometers	km ²
acres	acres	0.4	hectares	ha
MASS (weight)				
oz	ounces	28	grams	g
lb	pounds	0.45	kilograms	kg
	short tons (2000 lb)	0.9	tonnes	t
VOLUME				
tblsp	tablespoons	5	milliliters	ml
fl oz	fluid ounces	30	milliliters	ml
c	cups	0.24	liters	l
pt	pints	0.47	liters	l
qt	quarts	0.95	liters	l
gal	gallons	3.8	liters	l
cu ft	cubic feet	0.03	cubic meters	m ³
cu yd	cubic yards	0.76	cubic meters	m ³
TEMPERATURE (exact)				
°F	Fahrenheit temperature	5/9 (after subtracting 32)	Celsius temperature	°C

Approximate Conversions from Metric Measures

Symbol	When You Know	Multiply by	To Find	Symbol
LENGTH				
mm	millimeters	0.04	inches	in
cm	centimeters	0.4	inches	in
m	meters	3.3	feet	ft
m	meters	1.1	yards	yd
km	kilometers	0.6	miles	mi
AREA				
cm ²	square centimeters	0.16	square inches	in ²
m ²	square meters	1.2	square yards	yd ²
km ²	square kilometers	0.4	square miles	mi ²
ha	hectares (10,000 m ²)	2.5	acres	acres
MASS (weight)				
g	grams	0.035	ounces	oz
kg	kilograms	2.2	pounds	lb
t	tonnes (1000 kg)	1.1	short tons	short tons
VOLUME				
ml	milliliters	0.05	fluid ounces	fl oz
l	liters	2.1	pints	pt
l	liters	1.06	quarts	qt
l	liters	0.26	gallons	gal
m ³	cubic meters	35	cubic feet	ft ³
m ³	cubic meters	1.3	cubic yards	yd ³
TEMPERATURE (exact)				
°C	Celsius temperature	9/5 (then add 32)	Fahrenheit temperature	°F



* In U.S. 254 (Metric), for other metric conversions and more detail, see Metric Units, Pub. 128, U.S. Dept. of Weights and Measures, Price \$2.25, SD Catalog No. C13, 10, 236.

TABLE OF CONTENTS

	<u>Page</u>
ACKNOWLEDGEMENTS	iii
PREFACE	iv
SUMMARY OF WMS INSTALLATION COSTS	v
METRIC CONVERSION FACTORS	vi
INTRODUCTION	1
OBJECTIVES	1
ASSUMPTIONS	2
APPROACH	2
Preliminary Installation Analysis	2
Shipchecks to Determine Viable Candidate Systems ..	2
Installation Cost Analysis	3
LIMITATIONS	7
PERTINENT VESSEL INFORMATION	8
Shipcheck Observations of Existing Vessel Conditions	9
Vessel Resources	12
Location of Black Water Waste Sources	13
Location of Gray Water Waste Sources	14
Arrangement of Black and Gray Wastewater Sources ..	15
WMS EQUIPMENT REQUIREMENTS	17
WMS No. 1 - Discussion of Installation Based on Shipchecks ..	18
Proposed WMS Equipment Arrangement	20
WMS Installation Cost Estimates	22
WMS No. 2 - Discussion of Installation Based on Shipchecks ..	23
Proposed WMS Equipment Arrangement	25
WMS Installation Cost Estimates	27
WMS No. 3 - Discussion of Installation Based on Shipchecks ..	28
Proposed WMS Equipment Arrangement	31
WMS Installation Cost Estimates	33
WMS No. 4 - Discussion of Installation Based on Shipchecks ..	34
Proposed WMS Equipment Arrangement	36
WMS Installation Cost Estimates	37

TABLE OF CONTENTS (Cont'd)

	<u>Page</u>
WMS No. 5 - Discussion of Installation Based on Shipchecks	38
Proposed WMS Equipment Arrangement	40
WMS Installation Cost Estimates	41
WMS No. 6 - Discussion of Installation Based on Shipchecks	42
Proposed WMS Equipment Arrangement	45
WMS Installation Cost Estimates	46
WMS No. 7 - Discussion of Installation	47
Proposed WMS Equipment Arrangement	50
WMS Installation Cost Estimates	52
WMS No. 8 - Discussion of Installation Based on Shipchecks	53
Proposed WMS Equipment Arrangement	55
WMS Installation Cost Estimates	57
WMS No. 9 - Discussion of Installation Based on Shipchecks	58
Proposed WMS Equipment Arrangement	60
WMS Installation Cost Estimates	62
WMS No.10 - Discussion of Installation Based on Shipchecks	63
Proposed WMS Equipment Arrangement	65
WMS Installation Cost Estimates	67
WMS No.11 - Discussion of Installation Based on Shipchecks	68
Proposed WMS Equipment Arrangement	70
WMS Installation Cost Estimates	72
WMS No.12 - Discussion of Installation Based on Shipchecks	73
Proposed WMS Equipment Arrangement	75
WMS Installation Cost Estimates	77
WMS No.13 - Discussion of Installation Based on Shipchecks	78
Proposed WMS Equipment Arrangement	80
WMS Installation Cost Estimates	82
WMS No.14 - Discussion of Installation Based on Shipchecks	83
Proposed WMS Equipment Arrangement	85
WMS Installation Cost Estimates	87
WMS No.15 - Discussion of Installation Based on Shipchecks	88
Proposed WMS Equipment Arrangement	90
WMS Installation Cost Estimates	92
WMS No.16 - Discussion of Installation Based on Shipchecks	93
Proposed WMS Equipment Arrangement	95
WMS Installation Cost Estimates	97

TABLE OF CONTENTS (Cont'd)

	<u>Page</u>
WMS No. 17 - Discussion of Installation Based on Shipchecks	98
Proposed WMS Equipment Arrangement	100
WMS Installation Cost Estimates	101
WMS No. 18 - Discussion of Installation Based on Shipchecks	102
Proposed WMS Equipment Arrangement	105
WMS Installation Cost Estimates	107
INSTALLATION EFFECTIVENESS ATTRIBUTE DATA	108
CONCLUDING REMARKS	118
APPENDIX A - PRELIMINARY INSTALLATION ANALYSIS	A-1
Summary of Preliminary Installation Analysis	A-2
Results	
Pertinent Vessel Information	A-3
Preliminary Installation Analysis of Individual Candidate Systems	A-5

INTRODUCTION

OBJECTIVES

The objectives of the installation analysis are as follows:

- Development of pertinent vessel information necessary for the cost and effectiveness analyses, including the following:
 - Existing physical conditions aboard the vessel, especially in compartments where wastewater management system equipments may be installed.
 - Existing wastewater management equipments/systems aboard the vessel (holding tanks, garbage grinders, sewage treatment systems, etc.).
 - Location of black and gray wastewater sources aboard the vessel.
 - Vessel resource capacities and estimated usage rates (prior to system installation).
- Selection of the viable candidate systems as determined on the basis of the feasibility of installation, using the governing installation guidelines and assumptions.
- Determination of the black/gray wastewater (or sludge) holding tank capacities which can be fitted.
- Development of installation cost estimates for each viable candidate system.
- Development of drawings showing the proposed arrangement of the wastewater management system equipments for each viable candidate as well as the arrangement of the black and gray wastewater sources on board the vessel.
- Development of installation related effectiveness attribute data.

ASSUMPTIONS

The pertinent assumptions and guidelines governing the installation analysis are presented in Volume IV of this report, along with the details of each of the 18 candidate wastewater management system concepts in configurations suitable for each vessel included in this study.

APPROACH

The installation analysis was performed in three stages consisting of a preliminary installation analysis, a shipcheck to establish viable system/vessel combinations, and an installation cost analysis all of which are discussed below. Prior to this analysis, visits were made to a number of vessels to inspect installations of the wastewater management subsystems and equipments included in this study.

Preliminary Installation Analysis

The candidate ship's general arrangement drawings and piping diagrams as furnished by the U.S. Coast Guard were reviewed at length to determine existing conditions so that the WMS requirements delineated in Volume IV could be applied to the vessel and a preliminary installation analysis made prior to an actual visit to the ship. This approach was intended to maximize familiarity with the vessel and to determine any possible questionable areas of interest. Each system was investigated as to space requirements, possible equipment locations, relationship to ship's functions (operation, mission, fuel stowage, water capacity, support systems, etc.) and its relationship to the reportedly existing waste disposal system.

In order to obtain as accurate a picture as possible, arrangement drawings to scale were made from the ship's plans of the possible installation spaces and "dummy cut-outs" of WMS equipment (also to scale) were used to determine if a proposed arrangement was feasible and if any problems could be anticipated. The results of the preliminary installation analysis are presented in Appendix A.

Shipchecks To Determine Viable Candidate Systems

Upon completion of the preliminary installation analysis, a detailed shipcheck of the vessel was made. During this visit various factors bearing on the investigation were considered, e.g., support systems (compressed air, sanitary flushing medium, electrical power generation, salt water systems, fresh water systems, fuel oil systems, etc.), correlation between actual ship arrangement and that shown in ship's drawings furnished for the study, relationship of other ship's systems and equipment to the location

and installation of WMS components to determine interferences and relocations, access for shipping WMS equipment aboard, removals, relocations, etc. The drawings prepared during the preliminary installation study were checked out and modified to reflect actual shipboard conditions.

The discussion of the shipcheck results presents a verbal picture of what conditions actually exist aboard the vessel and how these conditions affect the viability determination of each wastewater management system. The installation acceptance or rejection rationale for each candidate WMS is presented, complete with estimated tank sizes, equipment locations, possible space modifications, relocations, limitations, exclusions, and any other such considerations as may be necessary to obtain a lucid understanding of the situation.

Vessel resource capacities (including the source of fresh water) and estimates of usage rates (prior to WMS installation) were obtained from interviews with cognizant officers. The locations of all black water (sewage and garbage grinder slurry) and gray water (galley and turbid) waste sources were determined.

The shipcheck also provided the necessary information to determine the capacities (in gallons) of required black and gray wastewater (or sludge) holding tanks (not part of manufacturer supplied wastewater treatment equipment) which can be accommodated, as well as their configurations (heights). This information was used to determine the black and gray wastewater holding capacities of each viable candidate system (expressed as a percentage of the required holding time). These results are presented on the WMS Equipment Requirements form together with the other equipment types and quantities required in order to synthesize each viable candidate system on the vessel. This WMS Equipment Requirements form served as the starting point for the cost and effectiveness assessments of each viable candidate system.

Installation Cost Analysis

The following were generated as part of the installation cost analysis:

- WMS equipment arrangement drawings for each viable candidate system and arrangement drawings for the black and gray wastewater sources aboard the vessel.
- Installation related effectiveness attribute data.
- Installation cost estimates for each viable candidate system.

The starting point for the installation cost estimates was the condition of the vessel at the time of the shipcheck inspection. Each viable candidate system installation was then analyzed in terms of a fixed set of installation cost elements. The Installation Cost Estimate Form shown in Figure 1 was used to record the estimated requirements for each cost element and the associated cost was computed. Each installation cost element in Figure 1 is discussed below.

(a) Piping - Wherever possible and applicable, existing piping runs were retained for reuse as installed. Pertinent information contained in the available ship's piping plans was used insofar as practicable. New piping runs were estimated from these drawings and the system equipment arrangement drawing prepared.

For estimating purposes of this nature, it is usual marine practice to use a dollars per pound of material to be installed. Therefore, an estimated present-day price, including material and labor to install, was placed at \$4.50/lb.

For the sake of uniformity and simplification since the WMS evaluations are comparative, the piping material used is copper-nickel. It is recognized that most waste disposal piping systems under consideration in the U.S. Coast Guard vessels are of copper-nickel, although some PVC (plastic) piping and a small amount of steel is used. Since the established guidelines call for the principal piping (drainage) to be of copper-nickel it was considered that for the relatively small additional piping, such as vents, the use of copper-nickel for all piping components would not adversely influence the overall results. Accordingly, the amounts of each size piping were estimated and a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(b) Steel - For this part of the cost estimate only the steel involved in the various shipyard supplied tanks is considered. Foundations are a separately treated item. For these tanks it was considered that one-quarter inch plate would be a good average thickness. Since the tanks would have to be structurally stiffened for proper support, a factor of 30% was added to the plate weight. The weight estimate was derived from the system guideline size requirements translated into configurations as shown on the equipment location and arrangement drawings.

For cost estimating of this nature, it is usual to apply a cost per pound figure. It was considered that a good current price of \$0.55/lb. would cover material and labor for fabrication and placing on board. This does not include the cost of fixing the tanks permanently in place by welding. This is a separate consideration.

WMS INSTALLATION COST ESTIMATES

Vessel _____

WMS No. _____

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/lb. (Materials and Labor)	(2)	
Tank Steel ⁽³⁾	Pounds	\$.55/lb. (Materials and Labor)	(4)	
Foundations	Pounds	\$.92/lb. (Materials and Labor)	(5)	
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)		
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)		
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)		
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)		
Removals	Cutting	\$50.00/Hr. (6) (Labor)		
	Other (miscellaneous handling)	\$15.00/MH (Labor)		
Total Installation Cost (\$)				

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft. /hr.

Figure 1

INSTALLATION COST ESTIMATE FORM

(c) Foundations - Supporting steel structure for all components of each WMS (tanks, pumps, MSD, incinerators, etc.) was estimated as approximately 10% of the weight which has to be carried. This is a usual rule of thumb for this type of installation. Fabrication and installation costs for material and labor were taken as \$0.92/lb. based on consideration of today's average costs. The weights were estimated from the tank configurations and contents as well as the component weights given in Volume IV.

(d) Electrical Power Cable - The amount of footage was estimated from the ship's arrangement plans and the WMS equipment arrangement drawings prepared, with allowances for the devious routings which could be encountered. Since ship alteration work is usually more complex than new construction, allowance as made for less installation per unit time. Therefore a cost of approximately \$2.00/ft. of cable was used to cover material and labor.

(e) Miscellaneous Installations - To cover the installation of various items such as pumps, motors, skid-mounted components, etc. where the activity centers principally around alignments and bolting in place, an estimate was made of the amount of time it would take to perform the tasks for each system installation, since the number and type of components varies. An estimated shipyard labor cost of approximately \$15 per man-hour (MH) was considered representative.

(f) Access Cuts - In order to get material and components into the compartments where they would be fitted it could become necessary to temporarily cut the ship's hull, or deck plating or a bulkhead to provide passageway. The number of feet of cutting was estimated for each system installation based on the approximate size of the largest component anticipated. Estimated shipyard cost for such cutting is approximately \$1.00/ft.

(g) Welding - This consideration includes securing tanks and non-bolted items and welding back any plating temporarily cut to provide access. An estimate of the number of feet of welding was made for each item in each system and a cost factor of \$6.00/ft was considered satisfactory to cover material and labor.

(h) Removals - In cases where some existing equipment would have to be cut and removed from the vessel as no longer required, an estimate was made as to the approximate length of time it would take a team of two men to accomplish certain tasks. Estimated factors of \$50/hour for cutting (based on an estimated cutting note of 50 ft/hour) and \$15/man-hour (MH) for miscellaneous handling labor were considered representative of such costs.

(i) Other Considerations - The installation cost estimates do not include some shipyard costs which yards to include as a matter of quotation to perform a certain ship modification. Such intangibles would include: cleaning and gas-freeing tanks, temporary removals or modifications to ducts, piping, electric cables, machinery, ship's outfit or furnishings, etc. and re-installation to existing state after the basic modification has been completed; cleaning, preparing and repainting the compartments and parts of the steel work disturbed, use of special rigging and shipyard lifting gear; and other work items which are part of a shipyard's everyday business and which are normal for them to price out.

If a complete ship alteration price is desired, it would involve drawing up a complete set of specification and drawings in sufficient detail for a shipyard's estimating department to analyze at length. If possible, yard personnel would prefer to visit the vessel for a more accurate cost estimate to eliminate or minimize costs which it could possibly have to absorb.

One of the most difficult factors to consider and which is not obvious but which is very much a determinant is the shipyard's workload or backlog. If there is a convenient "hole" in the yard's work schedule, the price could be made attractive since it would provide needed economic continuity for its work force and facilities. Certainly if there is little or no other work in the offing, the yard will be inclined to "buy" the job by bidding lower than it normally would.

Thus it can be seen that there will be additional costs to those detailed herein, if one is interested in a "finished product" price than a comparative estimate.

LIMITATIONS

The installation cost estimating procedures used are considered to be fairly general and applicable for study purposes of this type which places greater emphasis on relative cost among candidate systems rather than on the absolute cost for a given system. However, the installation cost estimates developed herein are based on specific vessel conditions, wastewater management system requirements and the governing installation guidelines and assumptions. Therefore, caution is advised in attempting to use these estimates directly for vessels and/or systems other than those specifically included in this study.

PERTINENT VESSEL INFORMATION

WHITE SAGE (133')

Vessel Characteristics	Data
Class	WLM - 544 White Summac (133') Class
Type	Buoy Tender (Coastal)
Crew Size	21
Home Port	Woods Hole, Mass.

SHIPCHECK OBSERVATIONS OF EXISTING VESSEL CONDITIONS

WHITE SAGE (133')

Crew 21 men

Waste Sources

Complete information on the sewage and gray water waste sources is contained in the tabulation sheets forming a part of these introductory remarks.

Existing Arrangement

The sanitary flushing system medium is salt water supplied by a pump/hydroneumatic tank arrangement.

The vessel's fresh water system is also supplied via a pump/hydropneumatic tank arrangement.

Compressed air is supplied via the diesel engine starting air compressor and tank arrangement.

Fire protection is via the fire and bilge pump supply to the fire main and local approved type portable and semi-portable extinguishers.

The following waste management system is fitted aboard the vessel:

(a) A 25 gallon Galley Retention Tank with built-in liquid level controlled pump is located in the aft starboard corner of the Engine Room.

The tank normally receives drains from the Galley and its deck drains and pumps them to the 220 gallon Collection Tank in the forward port corner of the Engine Room.

Galley wastes can gravitate directly overboard independent of any other waste sources. This is done when the tank's pump needs maintenance.

(b) Drains from the drinking fountain on the Main Deck, Frame 14, go directly overboard.

(c) A 220 gallon Collection Tank is located on the port side of the Engine Room, near the forward bulkhead.

All wastes (other than the aforementioned drinking fountain) go to this Collection Tank via separate mains, i.e. the black water mains are separate from the gray water mains.

Although not current practice aboard this vessel, the turbid drains can bypass the 220 gallon Collection Tank and gravitate directly overboard in the Engine Room.

A pump near the tank discharges the mixed wastes forward to Hold No. 2 via a pipe tunnel running fore and aft through the lower portion of the port side fuel oil storage tank which is immediately forward of the Engine Room. Although this pump can discharge overboard or to the pierside connections, it normally discharges to the 810 gallon Retention Tank in the port aft corner of Hold No. 2.

(d) The 810 gallon Retention Tank in Hold No. 2 receives wastes only from the 220 gallon Collection Tank. A pump located just forward of the hold's aft bulkhead and to stbd of the vessel's centerline transfers the waste material to the overboard shell connection on the port side and to the port and stbd pierside connections on deck.

The ship's refrigerated stores are located in a self-contained unit having five (5) upper and lower compartments and straddling the vessel's centerline along the forward bulkhead of Hold No. 2.

The dry stores are located in a wire mesh enclosure in the center of the hold.

The cargo boom hydraulic tank is located in the port aft corner of the hold.

The remainder of the hold is taken up by storage cabinets and racks.

Special Remarks

(1) The drawings used to study the "White Sage" are not in agreement with the actual vessel.

Dwg. 540 WAGL-0103-8 Booklet of General Drawings USCGC
Whitebush, dated 5-30-74

is not applicable. The vessel itself is in possession of the correct drawing which is 544 WLM 0103 CGD1-1 Rev B, dated 12-15-75.

Dwg. 540 WAGL-4000-1 Whitebush Engine Room Rearrangement-
Elevation & Plan, dated 3-18-74

does not reflect the Engine Room arrangement of the "White Sage"

Dwg. 540 WAGL-4808-2 Secondary Drainage System Alterations
Fleet, dated 8-9-71

closely reflects the "White Sage" although the collection and retention tanks are located slightly off from the drawing dimensions. This did not impede its usage.

(2) It should be noted that the drawings indicate that some vessels of this class are fitted with a void space between the fuel oil storage tanks instead of a pipe tunnel through the port side of fuel oil tank. The void space would extend between the forward bulkhead of the Engine Room and the aft bulkhead of Hold No. 2. This void is significant in that it offers the solution to leading incinerator stacks in Hold No. 2 to the weather via the stack in the Engine Room. Under the guidelines for space utilization in this study, fuel oil storage tanks are not to be considered for modification. This deviation in class design will require special consideration and planning on how a stack can be run at the forward end of the vessel's house. The prime considerations involve cargo handling equipment, navigational aids, visibility from the bridge and smoke path from the top of the stack.

This discussion is given to highlight a certain aspect of the systems where incinerators can be located in Hold No. 2 and the viability of these systems as candidates depends on being able to satisfactorily provide a stack arrangement.

VESSEL RESOURCES

VESSEL WHITE SAGE (WLM-544) - White Summac (133') Class

1. Fresh Water
a. Source of supply (i.e., storage tank, evaporator) Supplied from off shore source to (4) storage tanks
b. Capacity (# of gals, etc.) FORWARD PEAK TANK - 3216 gals. PORT WING TANK - 1675 gals.
AFTER PEAK TANK - 3500 gals. STARBOARD WING TANK - 1675 gals.
c. Usage rate (# of gal, etc.) FRESH WATER - 135 gals. per day
SALT WATER FOR FLUSHING - 16.5 per day

2. Fuel Oil
a. Tank capacity (# of gals) PORT & STARBOARD TANKS - Each has capacity of 6432 gals. = Total capacity = 12,864 gals.
b. Usage rate (gpl, etc.) Fuel Underway for 24 hours Period = 720 gals per day. Average Underway Period = 285 gals.
In Port - Winter - 30 gals per day In Port - Summer - None

3. Electric Power
a. Capacity kw (2) - 60 KW Diesel Generators -
b. Usage rate (when) Underway - Constant In Port - Use Shore Facilities
c. Maximum kw used All electrical systems can generate off one (1) generator
d. Average kw/h per day 1000kwh per day -

4. Compressed Air
a. Capacity 2 Air compressors - Service Air - 100psi.
Starting Engine Air Pressure - 250psi Controlled Air - 125psi (Separate Systems)
b. Usage rate Starting Engine; Pneumatic Tools; Air Horn; Air Driven Pumps -
c. No. of hours compressors run per day or percentage of time 50-60% AVERAGE - Under way.

5. Capacity of Ventilation Air in CFM
a. Size of fan 2 Supply Vents In Main Engine Room - Total of 4000 CFM; Exhaust Fan In Engine Room - 1000 CFM
Supply & Exhaust In No. 2 Hold - 2360 CFM; Supply - After Bulkhd. 19 = 2200 CFM Galley Hood - 100 CFM
b. Location of incinerator for each system considered Present Stack: No. 2 Hold -

6. Ship has only single drainage system.

LOCATION OF BLACK WATER* WASTE SOURCES ABOARD A VESSEL
 Vessel WHITE SAGE - (WLM-544) - White Summac (133') Class

Bulkhead Identification Frame #/ To #	Level Identification	Compartment Location	Compartment Name	Number of Water Closets	Number of Urinals	Estimate of Number of People Served	Comments
11-19	01	CL	C.O. SR, WR, WC	1	0	1	
11-19	1	P	Crew's WR and WC	2	1	18	
11-19	1	S	C.P.O. WC	1	0	2	


* Sewage (output from commodes and urinals) and garbage grinder slurry.


LOCATION OF GRAY WATER* WASTE SOURCES ABOARD A VESSEL
 Vessel WHITE SAGE - (WLM-544) - White Summac (133') Class

Bulhead Identification Frame #/To #	Level Identification	Compartment Location	Compartment Name	Waste Source	Comments
11-19	01	CL	C.O. WR	Shower (1)	
11-19	01	CL	C.O. WR	Lavatory (1)	
11-19	1	P	Crew's WR	Showers (2)	
11-19	1	P	Crew's WR	Lavatories (3)	
11-19	1	S	CPO WR	Shower (1)	
11-19	1	S	CPO WR	Lavatory (1)	
11-19	1	S	Galley	Sinks (2)	
11-19	1	S	Galley	Dishwasher (1)	
11-19	1	S	Galley	Drain from Refrig. to Deck to CHT.	
11-19	1	S	Galley	Range Hood to CHT.	
17	1	S	Engine Room	Drinking Fountain Drain to Bilge	
14-15	1	CL	Main Deck	Drinking Fountain Drain to Bilge	
1- 4	1	CL	Laundry	Washing Machine	
11-19	2	P	Hold	Drain from Air Cond. Chiller	
8-11	2	P	Hold	Drain from Refrig.	
17	2	S	Engine Room	Galley Ret. Tank - 25 Gal.	
12-19	2	P	Engine Room	Collection Tank 220 Gal.	
8-11	2	CL	Hold No. 2	Retention Tank 8 Gal.	

* Galley and turbid wastewater.

ARRANGEMENT OF BLACK AND GRAY WASTEWATER SOURCES





WMS EQUIPMENT REQUIREMENTS

Vessel WHITE SAGE (133')

WMS NUMBER	WMS ACCEPTABILITY		NUMBER OF FIXTURES			NUMBER OF VCT'S (Sized By Gallons)		NUMBER OF INCINERATORS			GATX NUMBER OF YEARS Treatment Sections	COLLECTION AND RECYCL. SUBSYSTEM			INCINERATOR SUBSYSTEM			TANKS (4)	
	For Installation (Vessel No.)	Grey (Vessel No.)	Black (Vessel No.)	Commode (2)	Urinals (3)	Small Boat	Large Boat	Incinerator	Number of P&FM Packages	Number of Sturge Tanks		Number of Separator Tanks	Number of P&FM Packages	Number of Sturge Tanks	Number of Separator Tanks	Number of Models	Number of Models	Number of Models	BLACK (Gallons Each Tank)
1	Yes	100	100	4S	1S												722B	2063B	
2	Yes	100	100	4S	1S											1	135C	2063B	
3	Yes	100	100	4S	1S											1		2063B	
4	Yes	100	100	4S	1S												110A, 60C	2063B	
5	Yes	100	100	4S	1S												432A, 232C		
6	Yes	100	100	4S	1S												722B	323A, 172C	
7	Yes	100	100	4S	1S												110A	2063B	
8	Yes	100	100	4S	1S												432A		
9	Yes	100	100	4G	1S/2J	1											260B	2063B	
10	Yes	100	100	4J	1S/2J		1											2063B	
11	Yes	100	100	4J	1S/2J	1												2063B	
12	Yes	100	100	4J	1S/2J	1											200B	172C, 323A	
13	Yes	100	100	4J	1S/2J	1												323A	
14	Yes	100	100	4G	1S/1G												232B	2063B	
15	Yes	100	100	4G	1S/1G		1											2063B	
16	Yes	100	100	4G	1S/1G													2063B	
17	Yes	100	100	4G	1S/1G		3										232B	323A, 172C	
18	Yes	100	100	4G	1S/1G		3										43D	323A	

WMS - Wastewater Management System
P&FM - Pressurization and Fluid Maintenance

(1) Does WMS meet all applicable safety standards?

(2) Letter following entered number means: S = Standard, J = JERED, G = GATX

(3) Letter following entered numbers mean: S = Standard urinal only, S/J = Standard urinals with indicated number of GATX flushometers.

(4) Letter following entered gallonage denotes tank usage: A = Influent Surge, B = Wastewater holding, C = Sludge holding, D = Intermediate tank not supplied with MSD.

WMS No.	1, 5, 14	2, 9, 12	4	6	17
Tank Height	5'-6"	3'-0"	2'-0"	6'-0"	5'-0"

NOTE: WMS No. 18 - Intermediate tank used as Influent surge tank.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 1 Full Volume Flush Gravity Collection/Holding Tank for
Black Water/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Sewage Holding Tank	722 gal. (97 cu. ft.)	6' x 3' x 5' - 6"
Galley/Turbid Holding Tank	2063 gal. (276 cu.ft.)	7' x 6' x 7'
Sewage Holding Tank Discharge Pumps	Two (2)	
Galley/Turbid Holding Tank Discharge Pumps	Two (2)	

Discussion

The system is considered to be a viable candidate.

The components would be located as follows:

(a) Sewage Holding Tank in the Engine Room, Port Side, Frame 14, just aft of location of existing collecting tank.

(b) Sewage Holding Tank Discharge Pumps (overboard/pierside) just forward of the tank.

(c) Galley/Turbid Holding Tank in Hold No. 2, Starboard side, in the location of the existing retention tank.

(d) Galley/Turbid Holding Tank Discharge Pumps (overboard/pierside) just forward of the tank.

(e) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Staboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

Vessel: WHITE SAGE (133')

System No. 1 (Cont'd)

Drainage would be as follows:

(a) Sewage would drain by gravity to the Sewage Holding Tank. The tank discharge pumps' discharge line would be led to Hold No. 2 via the existing pipe tunnel passing through the lower inboard side of the Port Fuel Oil Tank. From there it would run to the existing overboard shell connection and to the existing weather deck discharge connections to pierside, port and starboard.


(b) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(c) Drain from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(d) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pumps would be capable of discharging the tank contents overboard and to pierside.


To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES: 1. TANK WEIGHT TAKEN FROM SUPPLY PLATES
2. PUMPS NOT TO SCALE

1/8" G.G. WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 1
SCALE: 1/8" = 1'-0" SHEET No. 1 OF 2



WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 1

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)	
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,105 ⁽²⁾	4,568	
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	5,340 ⁽⁴⁾	2,937	
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,970 ⁽⁵⁾	2,733	
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	250	500	
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	35	525	
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50	
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	125	750	
Removals	Cutting	Hours	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	Man-Hours	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				13,188	

- (1) Copper-nickel assumed.
- (2) Estimate includes a factor of 80% added to allow for valves, flanges, fittings, take-down joints, etc.
- (3) One-quarter inch plate assumed.
- (4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.
- (5) Estimated on the basis of 10% of the weight which has to be supported.
- (6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 2 Full Volume Flush Oil Recirculation and Gravity Collection/
Chrysler System with Sludge Holding Tank for
Sewage/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Sewage Holding Tank	135 gal. (18 cu. ft.)	2' x 3' x 3'
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)	7' x 6' x 7'
Chrysler Model and Quantity	One (1) Model A Separation Tank and One (1) Model A Pump and Fluid Maintenance Package	
Sewage Holding Tank Discharge Pumps	Two (2)	
Galley/Turbid Holding Tank Discharge Pumps	Two (2)	

Discussion

The system is considered to be a viable candidate.

The components would be located as follows:

(a) Sewage Holding Tank in the Engine Room, Port side, Frame 13, in place of the existing collecting tank.

(b) Sewage Holding Tank Discharge Pumps (overboard/pierside) just forward and outboard of the tank.

(c) Chrysler Separation Tank and Pump and Fluid Maintenance Package in the Engine Room, just aft of the Sewage Holding Tank.

(d) Galley/Turbid Holding Tank in Hold No. 2, Starboard side, in the location of the existing retention tank (Same as in System No. 1)

(e) Galley/Turbid Holding Tank Discharge Pumps (overboard/pierside) just forward of the tank (Same as in System No. 1).

Vessel: WHITE SAGE (133')

System No. 2 (Cont'd)

(f) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

Drainage would be as follows:

(a) Sewage would drain by gravity to the Chrysler Separation Tank.

(b) The effluent from the Separation Tank would be pumped to the Sewage Holding Tank.

(c) The Sewage Holding Tank Discharge Pump piping would be led to Hold No. 2 via the existing pipe tunnel passing through the lower inboard side of the Port Fuel Oil Tank. From there it would run to the existing overboard shell connection and to the existing weather deck discharge connection to pierside, port and starboard.


(d) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(e) Drains from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(f) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pumps would be capable of discharging the tank contents overboard and to pierside.


To accommodate the equipment in Hold No. 2, there may be minor modification required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES: 1. TANK HEIGHT TAKEN FROM THE FLOOR PLATES
 2. PUMPS NOT TO SCALE

USCGC WHITE SAGE (193 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 2
SCALE: 1/8" = 1'-0" SHEET No. 1 OF 2



NOTES: 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
 2. PUMPS NOT TO SCALE

USCGC WHITESAGE
 (133 FOOT CLASS)
 HOLD No. 2
 PLAN
 SYSTEM No. 2
 SCALE: 1/2"=1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 2

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)	
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,220 ⁽²⁾	5,490	
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	4,100 ⁽⁴⁾	2,255	
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	3,160 ⁽⁵⁾	2,908	
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	300	600	
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	35	525	
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50	
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	140	840	
Removals	Cutting	Hours	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	Man-Hours	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				13,793	

- (1) Copper-nickel assumed.
- (2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.
- (3) One-quarter inch plate assumed.
- (4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.
- (5) Estimated on the basis of 10% of the weight which has to be supported.
- (6) Based on an assumed cutting rate of 50 ft. /hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 3 Full Volume Flush Oil Recirculation and Gravity Collection/
Chrysler System with Incinerator for
Sewage/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions(L x W x H)</u>
Galley/Turbid Holding Tank	2063 gal. (276 cu.ft.)	7' x 6' x 7'
Sludge Ejection Tank	50 gal. (6.7 cu.ft.)	24" dia. x 60" L
Chrysler Model and Quantity	One (1) Model A Separation Tank and One (1) Model A Pump and Fluid Maintenance Package	
Incinerator Model and Quantity	One (1) - A	
Sludge Ejection Tank Transfer Pump	One (1)	
Sludge Ejection Tank Discharge Pump	One (1)	
Galley/Turbid Holding Tank Discharge Pumps	Two (2)	

Discussion

The system is considered to be a viable candidate.

The components would be located as follows:

(a) Chrysler Pump and Fluid Maintenance Package, and Separation Tank followed by the Sludge Ejection Tank would be located in that order (fwd to aft) on the port side of the Engine Room, from the location of the existing collecting tank aft to the stanchion (Frames 13 to 15).

(b) The incinerator would be located in the Engine Room, port side, between Frames 14 and 15 just inboard of the ejection tank. Its stack would run inboard and up to the weather alongside the diesel engine exhaust pipes in the ship's stack.

Vessel: WHITE SAGE (133')

System No. 3 (Cont'd)

(c) The Sludge Ejection Tank Pumps would be located in the Engine Room, just forward of the incinerator.

(d) The incinerator fuel tank could be located on the Engine Room forward bulkhead, port side.

(e) Galley/Turbid Holding Tank in Hold No. 2, Starboard side, in the location of the existing retention tank (Same as System Nos. 1 and 2).

(f) Galley/Turbid Holding Tank Discharge Pumps (overboard/pierside) just forward of the tank (Same as System Nos. 1 and 2).

(g) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Starboard corner would be retained. The tank has a built-in liquid level controlled discharge pump.

Drainage would be as follows:

(a) Sewage would drain by gravity to the Chrysler Separation Tank and pass on to the incinerator via the Sludge Ejection Tank and the Transfer Pump.

(b) The Sludge Ejection Tank would be pumped overboard and to pierside via the tank's discharge pump. The discharge piping would be led to Hold No. 2 via the existing pipe tunnel through the Port Fuel Oil Tank and then to the ship's existing overboard and pierside connections.

(c) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(d) Drain from the drinking fountain on the Main Deck, Frame 14 to starboard of the ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

Vessel: WHITE SAGE (133')


System No. 3 (Cont'd)

(e) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pumps would be capable of discharging the tank contents overboard and to pierside.

To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).


Due to the incinerator installation additional fire protection will have to be provided and the ventilation system will have to be modified.

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTE: PUMPS NOT TO SCALE.

15366. WHITE SAGE (193 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 3
SCALE: 1/8" = 1'-0" SHEET NO. 1 OF 2.



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES.
 2. PUMPS NOT TO SCALE.

UL-LGC WHITE SAGE
 (133 FOOT CLASS)

HOLD No. 2
 PLAN

SYSTEM No. 3

SCALE: 1/2" = 1'-0" OF SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 3

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,930 ⁽²⁾	8,685
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	4,360 ⁽⁴⁾	2,398
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,620 ⁽⁵⁾	2,411
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	350	700
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	35	525
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	150	900
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				16,794

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 4 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Holding Tank for Black Water/ Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions(L x W x H)</u>
Sewage Influent Surge Tank	110 gal. (15 cu. ft.)	2' x 2' x 4'
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)	7' x 6' x 7'
Sludge Holding Tank	60 gal. (8 cu. ft.)	2' x 2' x 2'
Grumman Unit without Incinerator	One (1)	
Surge Tank Pumps	One (1)	
Surge Tank Overboard Pump	Two (2)	
Sludge Transfer Pump	One (1)	
Galley/Turbid Holding Tank Discharge Pump	Two (2)	

Discussion

The system is considered to be a viable candidate.

The components would be located as follows:

(a) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

(b) Due to the lack of adequate space in the Engine Room and for a better piping arrangement, the Sewage Influent Surge Tank, Sludge Holding Tank, Grumman Unit and Galley/Turbid Holding Tank would all be located on the starboard side of Hold No. 2. The G/T Holding Tank would be located where the retention tank is fitted (Frames 10 - 11). The Grumman Unit would be located forward of the G/T Holding Tank, with the Sludge Holding Tank adjacent and outboard (Frames 8-9). The Influent Surge Tank would be located just forward of Bhd 11 and to Starboard of the ship's centerline (Frames 10 - 11) near the G/T Holding Tank.

Vessel: WHITE SAGE (133')

System No. 4 (Cont'd)

(c) The independent pumps associated with the tanks would be distributed in the area between Frames 9 - 10 1/2 Starboard of the ship's centerline and near the Sludge Holding Tank.

Drainage would be as follows:

(a) All drainage piping aft of Bhd No. 12, sewage as well as galley/turbid, would be led to Hold No. 2 via separate mains through a new pipe tunnel passing through the upper part of the Port Fuel Oil Tank (similar to the existing one which passes through the lower part of the tank).

(b) Sewage would gravitate to the Influent Surge Tank, from which it would be pumped by the Surge Tank Pump to the Grumman Feed Tank. The Surge Tank would be pumped overboard and to pierside via the tank's overboard pumps.


(c) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via the new pipe tunnel through the Port Fuel Oil Tank mentioned above.

(d) Drains from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(e) Remaining Galley/Turbid drains would gravitate overboard and to their Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pumps would be capable of discharging the tank contents overboard and to pierside.

To accommodate equipment locations the existing shelving arrangement along the starboard shell would have to be modified, the ship's dry stores enclosure would have to be relocated from the ship's centerline to some place on the Port side, and the ship's stores refrigerator would have to be moved slightly to Port to clear the Grumman unit. The refrigerator has its own two air-cooled compressors mounted on top of the refrigerator.

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK BRIGHT TAKEN FROM VUOR PLATES.
 2. PUMPS NOT TO SCALE.

USCGC WHITE SAGE (133 FOOT CLASS)
HOLD NO. 2 PLAN
SYSTEM NO. 4
SCALE: 1/2" = 1'-0" SHEET NO. 1 OF 1

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 4

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,830 ⁽²⁾	8,235
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	4,395 ⁽⁴⁾	2,418
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,705 ⁽⁵⁾	2,489
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	525	1,050
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	50	750
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	35	35
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	150	900
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				17,002

- (1) Copper-nickel assumed.
- (2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.
- (3) One-quarter inch plate assumed.
- (4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.
- (5) Estimated on the basis of 10% of the weight which has to be supported.
- (6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 5 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Holding Tank for Combined Black and Gray Waters

	<u>Required</u>	<u>Approximate Dimensions(L x W x H)</u>
Influent Surge Tank	432 gal. (58 cu.ft.)	3' x 3' x 6' - 5"
Sludge Holding Tank	232 gal. (31 cu.ft.)	3' x 2' x 5' - 6"
Grumman Unit without Incinerator	One (1)	
Surge Tank Pump	One (1)	
Surge Tank Overboard Pump	Two (2)	
Sludge Transfer Pump	One (1)	

Discussion

The system is considered to be a viable candidate.

The components would be located as follows:

(a) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

(b) Due to the lack of adequate space in the Engine Room and for a better piping arrangement, the Sewage Influent Surge Tank, Sludge Holding Tank, and the Grumman Unit would all be located on the starboard side of Hold No. 2. The Grumman treatment sub-system would be located where the retention tank is presently fitted. The Sludge Holding Tank would be located just outboard of the Grumman unit. The influent surge tank would be located just forward of Bhd 11, to starboard of the ship's centerline.

(c) The independent pumps would be functionally located around the Grumman unit and Surge Tank.

Vessel: WHITE SAGE (133')

System No. 5 (Cont'd)

Drainage would be as follows:


(a) All drainage piping aft of Bhd No. 12, sewage as well as Galley/Turbid, would be led to Hold No. 2 via separate mains through a new pipe tunnel passing through the upper part of the Port Fuel Oil Tank (similar to the existing one which passes through the lower part of the tank).

(b) Sewage and Galley/Turbid drains would gravitate to the Influent Surge Tank, from which they would be pumped by the Surge Tank Pump to the Grumman Feed Tank. The Surge Tank would be pumped overboard and to pierside via the tank's overboard pumps.

(c) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Influent Surge Tank in Hold No. 2 via the new pipe tunnel through the Port Fuel Oil Tank mentioned above.

To accommodate the equipment in Hold No. 2, minor modifications will be required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10) will have to be moved further to Port.

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES.
2. PUMPS NOT TO SCALE.

USCGC WHITE SAGE
(133 FOOT CLASS)
HOLD No. 2
PLAN

SYSTEM No. 5

SCALE: 1/2" = 1'-0" SHEET No. 1 OF 1

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 5

Installation Cost Element		Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾		Pounds	\$ 4.50/Lb. (Materials and Labor)	1,635 ⁽²⁾	7,358
Tank Steel ⁽³⁾		Pounds	\$.55/Lb. (Materials and Labor)	2,170 ⁽⁴⁾	1,194
Foundations		Pounds	\$.92/Lb. (Materials and Labor)	1,120 ⁽⁵⁾	1,031
Electric Cables		Feet	\$ 2.00/Ft. (Materials and Labor)	450	900
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)		Man-Hours	\$15.00/MH (Labor)	35	525
Access Cuts (in hull, deck plating or bulkhead to provide passageway)		Feet	\$ 1.00/Ft. (Labor)	35	35
Welding		Feet	\$ 6.00/Ft. (Materials and Labor)	120	720
Removals	Cutting	Hours	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	Man-Hours	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)					12,888

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 6 Full Volume Flush Gravity Collection/Holding Tank for
Black Water/Grumman Flow Through System with
Sludge Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions(L x W x H)</u>
G/T Influent Surge Tank	323 gal. (43 cu.ft.)	3' x 3' x 5'
Sewage Holding Tank	722 gal. (97 cu.ft.)	4' x 4' x 6'
Sludge Holding Tank	172 gal. (23 cu.ft.)	2'-6" x 2'-6" x 4'
Optional Combined Sewage/ Sludge Holding Tank	894 gal. (120 cu.ft.)	5' x 5' x 5'
Grumman Unit without Incinerator	One (1)	
G/T Influent Surge Tank Pump	One (1)	
G/T Influent Surge Tank Transfer pump	One (1)	
Sewage Holding Tank Overboard Pump	Two (2)	
Sludge Holding Tank Transfer Pump		

Discussion

The system is considered to be a viable candidate.

The components would be located as follows:

(a) The existing 25 gallon Galley Collecting Tank located on the operating level of the Engine Room, in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

(b) Due to the lack of adequate space in the Engine Room and for a better piping arrangement the remaining components would all be located on the starboard side of Hold No. 2. The G/T Influent Surge Tank would be fitted near the ship's centerline, just forward of Bhd No. 11. The Sewage Holding Tank would be located where the existing retention

Vessel: WHITE SAGE (133')

System No. 6 (Cont'd)

tank is fitted. The Grumann treatment subsystem would be fitted forward (Frames 9-10) with the Sludge Holding Tank forward and outboard.

The Optional Combined Sewage/Sludge Holding Tank can be located in place of the Sewage Holding Tank.

(c) The independent pumps associated with the tanks would be distributed functionally near the equipment served.

Drainage would be as follows:

(a) All drainage piping aft of Bhd No. 12, sewage as well as galley/turbid, would be led to Hold No. 2 via separate mains through a new pipe tunnel passing through the upper part of the Port Fuel Oil Tank (similar to the existing one which passes through the lower part of the tank).

(b) Sewage would gravitate to the Sewage Holding Tank from which it would be pumped overboard or to pier side by the tank's overboard discharge pumps.

(c) The Sludge Holding Tank Transfer Pump would transfer effluent from the tank to the Sewage Holding Tank for discharge overboard and to pier side via the Sewage Holding Tank Overboard Pumps.

(d) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Influent Surge Tank in Hold No. 2 via the new pipe tunnel through the Port Fuel Oil Tank mentioned above.

(e) Drain from the drinking fountain on the Main Deck, Frame 14 to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.


(f) Remaining Galley/Turbid drains would gravitate overboard and to the G/T Influent Surge Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank transfer pump would discharge the tank contents to the Sewage Holding Tank for discharge overboard and to pier side.

Vessel: WHITE SAGE (133')

System No. 6 (Cont'd)

To accommodate equipment locations the existing shelving arrangement along the starboard shell would have to be modified, the ship's dry stores enclosure would have to be relocated from the ship's centerline to some place on the Port side, and the ship's stores refrigerator along the forward bulkhead would have to be moved to Port to clear the Grumman unit. The refrigerator has its own two air-cooled compressors mounted on top of the refrigerator.

PROPOSED WMS EQUIPMENT ARRANGEMENT



USGCC WHITE SAGE
(193 FOOT CLASS)

HOLD No. 2
PLAN

SYSTEM No. 6

SCALE: 1/2"=1'-0" SHEET No. 1 OF 1

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 6

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)	
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,830 ⁽²⁾	8,235	
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	3,445 ⁽⁴⁾	1,895	
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	1,760 ⁽⁵⁾	1,620	
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	450	900	
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	50	750	
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	35	35	
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	150	900	
Removals	Cutting	Hours	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	Man-Hours	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				15,460	

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 60 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 7 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Incinerator for Black Water/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Galley/Turbid Holding Tank	2063 gal. (276 cu.ft.)	7' x 6' x 7'
Sewage Influent Surge Tank	110 gal. (15 cu. ft.)	2' x 2' x 4'
Fuel Oil Day Tank	25 gal. (3.3 cu. ft.)	1'-6" x 1'-6" x 1'-6"
Grumman Unit with Incinerator	One (1) with One (1) Thiokol Incinerator	
Influent Surge Tank Pump	One (1)	
Influent Surge Tank Overboard Pump	Two (2)	
Galley/Turbid Holding Tank Overboard Pump	Two (2)	

Discussion

The system is a viable candidate with certain considerations.

The components would be located as follows:

(a) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

(b) The Sewage Influent Surge Tank, Surge Tank Pump, and the tank's overboard pumps would be located in the Engine Room, Port side in place of the existing collecting tank.

(c) The Galley/Turbid Holding Tank would be fitted in Hold No. 2 where the existing retention tank is located. The Grumman MSD with the incinerator would be located just forward of the G/T Holding Tank; the Fuel Oil Day Tank would be located in the Starboard aft corner of the hold near the G/T Holding Tank.

Vessel: WHITE SAGE (133')

System No. 7 (Cont'd)

(d) The G/T Holding Tank pumps for overboard/pierside discharge would be located inboard of the tank.

(e) In view of the arrangement of the vessel as described in the discussion of existing conditions at the beginning of this section, the incinerator stack run to the weather seems to be severely limited. The only apparent solution is to run it up through the Main Deck alongside the port or starboard sheer leg of the cargo boom tripod support structure. The structure legs begin near the overhead in Hold No. 2. Care would have to be exercised due to tight house access arrangements on the Main Deck and the navigational and operations clearance needed.

Drainage would be as follows:

(a) Sewage would gravitate to the Sewage Influent Surge tank in the Engine Room from which it would be pumped to the Grumman feed tank by the surge tank pump. The surge tank would be pumped overboard or to pierside by the tank's overboard pumps. The Surge tank pump and the tank overboard/pierside discharge pump would discharge via the existing pipe tunnel through the lower part of the Port Fuel Oil Tank.

(b) Galley and Turbid drainage piping aft of Bhd No. 12 would be led to the G/T Holding Tank in Hold No. 2 through a new pipe tunnel passing through the upper part of the Port Fuel Oil Tank (similar to the existing one which passes through the lower part of the tank).

(c) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via the aforementioned new pipe tunnel through the Port Fuel Oil Tank.

(d) Drains from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(e) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 directly. The tank discharge pumps would be capable of discharging the tank contents overboard and to pierside.


Vessel: WHITE SAGE (133')

System No. 7 (Cont'd)

To accommodate the equipment in Hold No. 2, minor modifications would be required to the shelving on the starboard side (along the shell of the vessel); the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10) would have to be moved to port of the ship's centerline; the ship's stores refrigerator along the forward bulkhead would have to be moved to port to clear the Grumman unit. The refrigerator has its own two air-cooled compressors mounted on top of the refrigerator.


Due to the incinerator installation additional fire protection will have to be provided and the ventilation system for Hold No. 2 will have to be modified.

PROPOSED WMS EQUIPMENT ARRANGEMENT



- NOTES :
1. TANK HEIGHT TAKEN FROM FLOOR PLATES.
 2. PUMPS NOT TO SCALE.

(ISCCG WHITE SAGE (133 FOOT CLASS))
ENGINE ROOM PLAN
SYSTEM No. 7
SCALE: 1/8" = 1'-0" SHEET NO. 1 OF 2.



WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 7

Installation Cost Element		Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾		Pounds	\$ 4.50/Lb. (Materials and Labor)	3,775 ⁽²⁾	16,988
Tank Steel ⁽³⁾		Pounds	\$.55/Lb. (Materials and Labor)	2,525 ⁽⁴⁾	1,389
Foundations		Pounds	\$.92/Lb. (Materials and Labor)	1,505 ⁽⁵⁾	1,385
Electric Cables		Feet	\$ 2.00/Ft. (Materials and Labor)	375	750
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)		Man-Hours	\$15.00/MH (Labor)	40	600
Access Cuts (in hull, deck plating or bulkhead to provide passageway)		Feet	\$ 1.00/Ft. (Labor)	35	35
Welding		Feet	\$ 6.00/Ft. (Materials and Labor)	135	810
Removals	Cutting	Hours	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	Man-Hours	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)					23,082

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 8 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Incinerator for Combined Black and Gray Waters

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Influent Surge Tank	432 gal. (58 cu. ft.)	3'-9" x 4' x 4'
Fuel Oil Day Tank	25 gal. (3.3 cu. ft.)	1'-6" x 1'-6" x 1'-6"
Grumman Units with Incinerators	One (1) with One (1) Thiokol Incinerator	
Influent Surge Tank Pump	One (1)	
Influent Surge Tank Overboard Pumps	Two (2)	

Discussion

The system is a viable candidate with certain considerations.

The system is very similar to System No. 7 except that the Galley/Turbid Holding Tank and its overboard/pierside discharge pumps have been deleted.

The components would be located as follows:

(a) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

(b) The Influent Surge Tank, Surge Tank Pump, and the tank's overboard pumps would be located in the Engine Room, Port side in place of the existing collecting tank.

(c) The Grumman MSD with the incinerator would be located in Hold No. 2 in place of the existing retention tank.

Vessel: WHITE SAGE (133')

System No. 8 (Cont'd)

(d) In view of the arrangement of the vessel as described in the discussion of existing conditions at the beginning of this section, the incinerator stack run to the weather seems to be severely limited. The only apparent solution is to run it up through the Main Deck alongside the port or starboard sheer leg of the cargo boom tripod support structure. The structure legs begin near the overhead in Hold No. 2. Care would have to be exercised due to tight house access arrangements on the Main Deck and the navigational and operational clearances needed.

Drainage would be as follows:

(a) Sewage and Galley/Turbid water would go to the Influent Surge Tank from which it would be pumped by the surge tank pump to the Grumman feed tank via the existing pipe tunnel through the Port Fuel Oil Tank. The Influent Surge Tank overboard pump would discharge overboard/pierside via the same pipe tunnel to the existing connections.


(b) The effluent from the existing 25 gallon Galley Sink/deck drain collecting tank would be pumped to the influent surge tank.

(c) Drains from the drinking fountain on the Main Deck, Frame 14, would have to be re-routed to drain into the 25 gallon collecting tank.

To accommodate the equipment in Hold No. 2, shelving may have to be modified and the wire mesh enclosure for ship's dry stores may have to be moved to port.


Due to the incinerator installation additional fire protection will have to be provided and the ventilation system for Hold No. 2 will have to be modified.

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
 2. PUMPS NOT TO SCALE

15CGG WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 8
SCALE: 1/8" = 1'-0" SHEET NO. 1 OF 2



USCGC WHITE SAGE
(133 FOOT CLASS)

HOLD No. 2
PLAN

SYSTEM No. 8

SCALE: 1/2" = 1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 8

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,075 ⁽²⁾	4,838
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	1,415 ⁽⁴⁾	779
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	1,005 ⁽⁵⁾	925
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	225	450
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	35	525
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	135	810
Removals	Cutting	\$50.00/Hr. (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				13,102

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 9 JERED Reduced Volume Flush Vacuum Collection/Holding Tank for Concentrated Black Water/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions(L x W x H)</u>
Vacuum Collection Tank	30 gal. (4.4 cu.ft.)	16" dia. x 38" H
Sanitary Holding Tank	200 gal. (27 cu.ft.)	3' x 3' x 3'
Galley/Turbid Holding Tank	2063 gal. (276 cu.ft.)	7' x 6' x 7'
Sanitary Holding Tank Overboard Pumps	Two (2)	
Galley/Turbid Holding Tank Overboard Pumps	Two (2)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system would be required.

The components would be located as follows:

(a) The Vacuum Collection Tank and its pumps would be located in the Engine Room, port side, where the existing collection tank is fitted.

(b) The Sanitary Holding Tank and its overboard pumps would be located just aft of the vacuum collection tank.

(c) The Galley/Turbid Holding Tank and its overboard discharge pumps would be located in Hold No. 2 in place of the existing retention tank.

(d) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

Vessel: WHITE SAGE (133')

System No. 9 (Cont'd)

Drainage would be as follows:

(a) Sewage would be collected in the Vacuum Collection Tank and transferred to the Sanitary Holding Tank. The holding tank discharge pump's discharge line would be led to Hold No. 2 via the existing pipe tunnel passing through the lower inboard side of the Port Fuel Oil Tank. From there it would run to the existing overboard shell connection and to the existing weather deck discharge connections to pierside, port and starboard.


(b) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(c) Drain from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(d) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pump would be capable of discharging the tank contents overboard and to pierside.

To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT




NOTES : 1. TANK WEIGHT TAKEN FROM FLOOR PLATES
2. PUMPS NOT TO SCALE

USCGC WHITE SAGE
(193 FOOT CLASS)
ENGINE ROOM
PLAN

SYSTEM No. 9

SCALE: 1/8" = 1'-0" SHEET No. 1 OF 2



WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 9

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,120 ⁽²⁾	5,040
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	4,260 ⁽⁴⁾	2,343
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,425 ⁽⁵⁾	2,231
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	300	600
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	35	525
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	135	810
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				12,724

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 10 JERED Reduced Volume Flush Vacuum Collection/Incinerator
for Concentrated Black Water/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Vacuum Collection Tank	120 gal. (18 cu. ft.)	2' dia. x 5'-9" L
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)	7' x 6' x 7'
Incinerator Feed Tank (Sludge)	50 gal. (6.5 cu. ft.)	2'-6" x 1' x 2'-7"
Fuel Oil Day Tank	22 gal. (3.0 cu. ft.)	1'-6" x 1'-6" x 1'-6"
Incinerator	One (1) Thiokol	
Vacuum Collection Tank Overboard Pump	One (1)	
G/T Holding Tank Overboard Pump	Two (2)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system will be required.

The components would be located as follows:

(a) The Vacuum Collection Tank and its pumps would be located in the Engine Room, port side, where the existing collection tank is fitted.

(b) The incinerator and blower would be fitted aft of the VCT.

The fuel oil day tank would be located on the Engine Room forward bulkhead near the VCT.

The incinerator stack would go up the ship's stack alongside the diesel engine exhausts.

(c) The Galley/Turbid Holding Tank would be located in Hold No. 2 in place of the existing retention tank. Its overboard pumps would be located inboard of the tank.

(d) The existing 25 gallon Galley Retention Tank (with internal sump pump) located in the starboard aft corner of the Engine Room would be retained.

Vessel: WHITE SAGE (133')

System No. 10 (Cont'd)

Drainage would be as follows:

(a) Sewage would be collected in the Vacuum Collection Tank (VCT) and transferred to the incinerator via the feed (Sludge) tank.

(b) The VCT would be pumped overboard and pier side by its overboard pump via the existing pipe tunnel through the lower part of the Port Fuel Oil Tank to the existing connections in Hold No. 2.


(c) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(d) Drain from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.


(e) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pump would be capable of discharging the tank contents overboard and to pier side.

To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT



USCGC WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 10
SCALE: 1/8" = 1'-0" SHEET No. 1 OF 2



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
 2. PUMPS NOT TO SCALE

USGCC WHITE SAGE (193 FOOT CLASS)
HOLD NO. 2 PLAN
SYSTEM No. 10
SCALE: 1/2" = 1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 10

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	2,025 ⁽²⁾	9,113
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	3,780 ⁽⁴⁾	2,079
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,457 ⁽⁵⁾	2,277
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	250	500
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	25	375
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	130	780
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				16,299

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft. /hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 11 JERED Reduced Volume Flush Vacuum Collection/GATX
Evaporator for Concentrated Black Water/Holding Tank
for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Vacuum Collection Tank	30 gal. (4.4 cu. ft.)	16" dia. x 38" L
Galley/Turbid Holding Tank	2063 gal. (276 cu.ft.)	7' x 6' x 7'
Evaporator (GATX)	One (1) - 80 gal.	
Catalytic Oxidizer	One (1)	
Galley/Turbid Holding Tank Overboard Pumps	Two (2)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system would be required.

The equipment would be located as follows:

(a) The Vacuum Collection Tank and its pumps would be located in the Engine Room, port side, where the existing collection tank is fitted.

(b) The GATX Evaporator would be located just aft of the VCT.

(c) The existing 25 gallon Galley Collecting Tank located in the starboard aft corner of the Engine Room would be retained. The tank has a built-in liquid level controlled discharge pump.

(d) The Galley/Turbid Holding Tank would be located in Hold No. 2 in place of the existing retention tank. Its overboard pumps would be located inboard of the tank.

Vessel: WHITE SAGE (133')

System No. 11 (Cont'd)

Drainage would be as follows:

(a) Sewage would be collected in the Vacuum Collection Tank (VCT) and transferred to the evaporator.

(b) The pumps forming a part of the VCT assembly would discharge the sewage overboard or pierside via the existing pipe tunnel passing through the lower part of the Port Fuel Oil Tank to the existing connections in Hold No. 2.

(c) Sludge from the evaporator would be pumped overboard/pierside by its own pump via the same route as for the VCT.


(d) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(e) Drain from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(f) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pumps would be capable of discharging the tank contents overboard and to pierside.


To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTE: PUMPS NOT TO SCALE

USCGC WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 11
SCALE: 1/8" = 1'-0"
SHEET No. 1 OF 2



NOTES: 1. TANK HEIGHT TAKEN FROM FLOOR PLATES.
 2. PUMPS NOT TO SCALE.

LIST OF WHITE SMOKE 1933 FOOT CLASS
HOLD NO. 2 PLAN
SYSTEM NO. 31
SCALE: 1/8" = 1' 0" SHEET NO. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 11

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,280 ⁽²⁾	5,760
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	3,540 ⁽⁴⁾	1,947
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,340 ⁽⁵⁾	2,153
Electric Cables	Foot	\$ 2.00/ft. (Materials and Labor)	200	400
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	20	300
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Foot	\$ 1.00/ft. (Labor)	50	50
Welding	Foot	\$ 6.00/ft. (Materials and Labor)	80	480
Repairs	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				12,215

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 80% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) Low-carbon mild plate assumed.

(4) Estimate includes a factor of 80% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 1% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 84 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 12 JERED Reduced Volume Flush Vacuum Collection/Holding Tank for Concentrated Black Water/Grumman Flow Through System with Sludge Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Galley/Turbid Influent Surge Tank	322 gal. (43 cu. ft.)	3'-6" dia. x 5' H
Sludge Holding Tank	172 gal. (23 cu. ft.)	2'-6" x 2'-6" x 4'
Sewage Vacuum Collection Tank	30 gal. (4.4 cu. ft.)	16" dia. x 28" L
Sewage Holding Tank	200 gal. (27 cu. ft.)	3' x 3' x 3'
Grumman Unit without Incinerator	One (1)	
Sewage Holding Tank Overboard Pumps	Two (2)	
Sludge Holding Tank Transfer Pump	One (1)	
Influent Surge Tank Transfer Pump	One (1)	
Influent Surge Tank Pump	One (1)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system will be required.

The components would be located as follows:

(a) The Galley/Turbid Influent Surge Tank and its pumps would be located in the Engine Room, port side, in place of the existing collection tank.

(b) The Vacuum Collection Tank and pumps would be located aft of the G/T Holding Tank.

Vessel: WHITE SAGE (133')

System No. 12 (Cont'd)

(c) The Sewage Holding Tank would be located aft of the VCT. The tank overboard pumps would be located forward and inboard of the Sewage Holding Tank.

(d) The existing 25 gallon Galley Retention Tank located in the starboard aft corner of the Engine Room would be retained. The tank has a built-in liquid level controlled discharge pump.

(e) The Grumman MSD, Sludge Holding Tank and its transfer pump would be located in Hold No. 2 in place of the existing retention tank.

Drainage would be as follows:

(a) Sewage would be collected in the Vacuum Collection Tank and transferred to the Sewage Holding Tank which would be pumped overboard or to pier side by the overboard pumps via the existing pipe tunnel through the Port Fuel Oil Tank to Hold No. 2 and then overboard using the existing connections.

(b) The 25 gallon Galley Retention Tank would discharge to the G/T Influent Surge Tank. The remaining G/T drains would gravitate to the tank. All gray water would also be capable of being discharged or gravitated overboard.

(c) Drains from the drinking fountain on the Main Deck, Frame 14, would have to be re-routed to the 25 gallon retention tank.


(d) The Surge Tank Transfer Pump would pump from the tank to the Sewage Holding Tank for discharge overboard or to pier side.

(e) The Surge Tank Pump would discharge to the Grumman Feed Tank in Hold No. 2 via the aforementioned existing pipe tunnel.

(f) The Sludge Holding Tank would be pumped back to the Sewage Holding Tank for off-loading via the aforementioned existing pipe tunnel.


To accommodate the equipment in Hold No. 2 the shelving along the starboard side would require modification as well as the wire mesh dry stores enclosure on the ship's centerline.

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
2. PUMPS NOT TO SCALE

15CGG WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 12
SCALE: 1/8"=1'-0"
SHEET NO. 1 OF 2



NOTES: 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
 2. TANKS NOT TO SOLID

USCGC WHITE SAGE (133 FOOT CLASS)
HOLD NO. 2 PLAN
SYSTEM NO. 72
SCALE: 1/2" = 1'-0" SHEET NO. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 12

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,150 ⁽²⁾	5,175
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	2,410 ⁽⁴⁾	1,326
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	1,235 ⁽⁵⁾	1,137
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	325	650
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MIH (Labor)	40	600
Access Cuts (in hull), deck plating or bulkhead to provide passageway	Feet	\$ 1.00/Ft. (Labor)	40	40
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	90	540
Repairs	Cutting	\$40.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$16.00/MIH (Labor)	25	375
Total Installation Cost (\$)				10,601

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 60% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) 1/4" quarter inch plate assumed.

(4) Estimate includes a factor of 80% added to allow for required structural stiffening for deck support.

(5) Estimate on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 60 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 13 JERED Reduced Volume Flush Vacuum Collection/Grumman Flow Through System for Gray Water/Incinerator for both Concentrated Black Water and Gray Water Sludge

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Galley/Turbid Surge Tank	323 gal. (43 cu.ft.)	3'-6" dia. x 5' H
Vacuum Collection Tank	30 gal. (4.4 cu. ft.)	16" dia. x 38" H
Fuel Oil Day Tank	40 gal. (5.3 cu. ft.)	2' x 2' x 1'-6"
Grumman Unit with Incinerator	One (1) with One (1) Thiokol Incinerator	
Galley/Turbid Surge Tank Overboard Pump	One (1)	
G/T Surge Tank Pump	One (1)	

Discussion

The system is a viable candidate with certain considerations.

A fresh water sanitary flushing system would be required.

The components would be located as follows:

(a) The Galley/Turbid Surge Tank would be located in the Engine Room, Port side, in place of the existing collection tank. The tank overboard pumps would be fitted outboard of the tank.

(b) The Vacuum Collection Tank and its pumps would be located just aft of the G/T Surge Tank.

(c) The existing 25 gallon Galley Retention Tank located in the aft Starboard corner of the Engine Room would be retained. The tank has a low liquid level controlled discharge pump.

Vessel: WHITE SAGE (133')

System No. 13 (Cont'd)

(c) The Grumman MSD with the incinerator would be located on the Starboard side of Hold No. 2 in place of the existing retention tank.

(e) In view of the arrangement of the vessel as described in the discussion of existing conditions at the beginning of this section, the incinerator stack run to the weather seems to be severely limited. The only apparent solution is to run it up through the Main Deck alongside the port or starboard sheer leg of the cargo boom tripod support structure. The structure legs begin near the overhead in Hold No. 2. Care would have to be exercised due to tight house access arrangements on the Main Deck and the navigational and operational clearances needed.

Drainage would be as follows:

(a) Sewage would be collected in the Vacuum Collecting Tank for transfer to the Grumman Sludge Feed Tank or to overboard and pierside. Piping from the VCT pumps would pass into Hold No. 2 via the existing pipe tunnel through the lower part of the Port Fuel Oil Tank. The existing overboard and pierside connections would be re-used.

(b) The existing 25 gallon Galley Retention Tank would discharge into the G/T Influent Surge Tank. Remaining G/T drains would gravitate to the surge tank.

(c) Drain from the drinking fountain on the Main Deck, Frame 14, would have to be re-routed to the 25 gallon retention tank.


(d) The G/T Surge Tank Pump would discharge to the Grumman feed tank via the aforementioned pipe tunnel to Hold No. 2.

The G/T Surge Tank Overboard Pump would discharge via the same pipe tunnel to Hold No. 2 and then to the existing overboard and pierside connections.


To accommodate the equipment in Hold No. 2, the shelving along the starboard shell will have to be modified and the ship's stores wire mesh enclosure on the centerline moved to port.

Due to the incinerator installation additional fire protection will have to be provided and the ventilation system for Hold No. 2 will have to be modified.

PROPOSED WMS EQUIPMENT ARRANGEMENT



15266 WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 13
SCALE: 1/2" = 1'-0"
SHEET No. 1 OF 2



USCGC WHITE SAGE
(133 FOOT CLASS)

HOLD No 2
PLAN

SYSTEM No. 13

SCALE: 1/2" = 1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 13

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	2,130 ⁽²⁾	9,585
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	1,255 ⁽⁴⁾	691
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	950 ⁽⁵⁾	874
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	200	400
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	25	375
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	90	540
Removals	Cutting	\$50.00/Hr. (Labor) ⁽⁶⁾	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				13,640

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 14 GATX Reduced Volume Flush M/T Pump Collection/Holding Tank for Concentrated Black Water/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Sewage Holding Tank	232 gal. (31 cu. ft.)	2' x 3' x 5'-6"
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)	7' x 6' x 7'
Sewage Holding Tank Discharge Pumps	Two (2)	
Galley Turbid Holding Tank Discharge Pumps	Two (2)	
Macerator/Transfer Pumps	Three (3)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system would be required.

The components would be located as follows:

(a) Sewage Holding Tank in the Engine Room, Port Side, Frame 14, just aft of location of existing collecting tank.

(b) Sewage Holding Tank Discharge Pumps (overboard/pierside) just fwd of the tank.

(c) Galley/Turbid Holding Tank in Hold No. 2, Starboard side, in the location of the existing retention tank.

(d) Galley/Turbid Holding Tank Discharge Pumps (overboard/pierside) just forward of the tank.

Vessel: WHITE SAGE (133')

System No. 14 (Cont'd)

(e) The existing 25 gallon Galley Retention Tank located on the operating level of the Engine Room, in the aft Starboard corner, would be retained. The tank has a built-in liquid level controlled discharge pump.

Drainage would be as follows:

(a) Sewage would be pumped to the Sewage Holding Tank by macerator/transfer pumps. The tank discharge pump's discharge line would be led to Hold No. 2 via the existing pipe tunnel passing through the lower inboard side of the Port Fuel Oil Tank. From there it would run to the existing overboard shell connection and to the existing weather deck discharge connections to pierside, port and starboard.


(b) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(c) Drains from the drinking fountain on the Main Deck, Frame 14 to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(d) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pump would be capable of discharging the tank contents overboard and to pierside.


To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES.
2. PUMPS NOT TO SCALE.

115766 WHITE SAGE (1133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 14
SCALE: 1/8" = 1'-0" SHEET No. 1 OF 2



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES.
 2. PUMPS NOT TO SCALE.

USCGC WHITE WAGE (183 FOOT CLASS)
HOLD No. 2 PLAN
SYSTEM No. 14
SCALE: 1/2" = 1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 14

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,000 ⁽²⁾	4,500
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	4,430 ⁽⁴⁾	2,437
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,475 ⁽⁵⁾	2,277
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	250	500
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	35	525
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	95	570
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				11,984

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft./hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 15 GATX Reduced Volume Flush M/T Pump Collection/Incinerator
for Concentrated Black Water/Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Incinerator Feed Tank	50 gal. (6.7 cu. ft.)	2'-6" x 1' x 2'-7"
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)	7' x 6' x 7'
Fuel Oil Day Tank	22 gal. (3 cu. ft.)	1'-6" x 1'-6" x 1'-6"
Incinerator	One (1) Thiokol	
Incinerator Feed Pump	One (1)	
Incinerator Feed Tank Overboard Pump	One (1)	
Galley/Turbid Holding Tank Overboard Pump	Two (2)	
Macerator/Transfer Pumps	Three (3)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system would be required.

The components would be located as follows:

(a) The Incinerator Feed Tank and feed pump would be located in the Engine Room, port side, where the existing collection tank is fitted.

(b) The incinerator and blower would be located aft of the Incinerator Feed Tank.

The fuel oil day tank would be located on the Engine Room forward bulkhead near the feed tank.

The incinerator stack would go up the ship's stack alongside the diesel engine exhausts.

Vessel: WHITE SAGE (133)

System No. 15 (Cont'd)

(c) The existing 25 gallon Galley Retention Tank located in the starboard aft corner of the Engine Room would be retained. The tank has a built-in liquid level controlled discharge pump.

(d) The Galley/Turbid Holding Tank and its discharge pumps would be located in Hold No. 2 in place of the existing retention tank.

Drainage would be as follows:

(a) Sewage would be pumped by the macerator/transfer pumps to the Incinerator Feed Tank and fed to the incinerator.

(b) The Incinerator Feed Tank would be pumped overboard and pierside by its overboard pump via the existing pipe tunnel through the lower part of the Port Fuel Oil Tank to the existing connections in Hold No. 2.


(c) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(d) Drains from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(e) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pump would be capable of discharging the tank contents overboard and to pierside.


To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK LIGHT TAKEN FROM FLOOR PLATES
2. PUMPS NOT TO SCALE

USCGC WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 15
SCALE: 1/8" = 1'-0"
SHEET No. 1 OF 2



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
 2. PUMPS NOT TO SCALE

USCGC WHITE SAGE (183 FOOT CLASS)	
HOLD No. 2 PLAN	
SYSTEM No. 15	SCALE: 1/2"=1'-0"
SHEET No. 2 OF 2	

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 15

Installation Cost Element		Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾		Pounds	\$ 4.50/Lb. (Materials and Labor)	1,875 ⁽²⁾	8,438
Tank Steel ⁽³⁾		Pounds	\$.55/Lb. (Materials and Labor)	4,035 ⁽⁴⁾	2,220
Foundations		Pounds	\$.92/Lb. (Materials and Labor)	2,390 ⁽⁵⁾	2,199
Electric Cables		Feet	\$ 2.00/Ft. (Materials and Labor)	300	600
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)		Man-Hours	\$15.00/MH (Labor)	25	375
Access Cuts (in hull, deck plating or bulkhead to provide passageway)		Feet	\$ 1.00/Ft. (Labor)	50	50
Welding		Feet	\$ 6.00/Ft. (Materials and Labor)	130	780
Removals	Cutting	Hours	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	Man-Hours	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)					15,787

(1) Copper-nickel assumed.

(2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.

(3) One-quarter inch plate assumed.

(4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.

(5) Estimated on the basis of 10% of the weight which has to be supported.

(6) Based on an assumed cutting rate of 50 ft. /hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 16 GATX Reduced Volume Flush M/T Pump Collection/GATX
Evaporator for Concentrated Black Water/Holding Tank
for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Galley/Turbid Holding Tank	2063 gal. (276 cu.ft.)	7' x 6' x 7'
Evaporator (GATX)	One (1) - 80 gal.	
Catalytic Oxidizer	One (1)	
Galley/Turbid Holding Tank Overboard Pumps	Two (2)	
Macerator/Transfer Pumps	Three (3)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system would be required.

The equipment would be located as follows:

(a) The GATX Evaporator and its catalytic oxidizer would be located in the Engine Room, Port side, in place of the existing collecting tank.

(b) The existing 25 gallon Galley Retention Tank located in the starboard aft corner of the Engine Room would be retained. The tank has a built-in liquid level controlled discharge pump.

(c) The Galley/Turbid Holding Tank would be located in Hold No. 2 in place of the existing retention tank. Its overboard pumps would be located inboard of the tank.

Drainage would be as follows:

(a) Sewage would be collected and discharged to the evaporator by macerator/transfer pumps.

Vessel: WHITE SAGE (133')

System No. 16 (Cont'd)

(b) The macerator/transfer pumps would also be capable of discharging directly overboard or to pierside via existing connections.

(c) Sludge from the evaporator would be pumped overboard by the evaporator's sludge pump.

(d) The overboard and pierside discharge piping would pass from the Engine Room to Hold No. 2 via the existing pipe tunnel in the lower part of the Port Fuel Oil Tank.


(e) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Holding Tank in Hold No. 2 via a new pipe tunnel through the Port Fuel Oil Tank similar to the existing one, but located through the upper part of the tank.

(f) Drains from the drinking fountain on the Main Deck, Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.


(g) Remaining Galley/Turbid drains would gravitate overboard and to the Holding Tank in Hold No. 2 via the new pipe tunnel indicated above. The tank discharge pump would be capable of discharging the tank contents overboard and to pierside.

To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10).

PROPOSEL WMS EQUIPMENT ARRANGEMENT



15CGC WHITE SAGE (133 FOOT CLASS)
ENGINE ROOM PLAN
SYSTEM No. 16
SCALE: 1/8" = 1'-0"
SHEET NO. 1 OF 2



NOTES : 1. TANK HEIGHT TIKGH
FROM FLOOR PLAYS
2. DIMPS NOT TO SCALE

USCGC WHITE SAGE (133 FOOT CLASS)
HOLD No ? PLAN
SYSTEM No. 16
SCALE: 1/2" = 1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 16

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,000 ⁽²⁾	4,500
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	3,540 ⁽⁴⁾	1,947
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	2,305 ⁽⁵⁾	2,121
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	200	400
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	20	300
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	80	480
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				10,923

- (1) Copper-nickel assumed.
- (2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.
- (3) One-quarter inch plate assumed.
- (4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.
- (5) Estimated on the basis of 10% of the weight which has to be supported.
- (6) Based on an assumed cutting rate of 50 ft. /hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 17 GATX Reduced Volume Flush M/T Pump Collection/Holding Tank for Concentrated Black Water/Grumman Flow Through System with Sludge Holding Tank for Gray Water

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Sewage Holding Tank	232 gal. (31 cu.ft.)	2'-6" x 2'-6" x 5'
Galley/Turbid Influent Surge Tank	323 gal. (43 cu.ft.)	3' x 3' x 5'
Sludge Holding Tank	172 gal. (23 cu.ft.)	2'-6" x 2'-6" x 4'
Grumman Unit without Incinerator	One (1)	
Sewage Holding Tank Overboard Pumps	Two (2)	
Sludge Tank Transfer Pump	One (1)	
Influent Surge Tank Pumps	Two (2)	
Macerator/Transfer Pumps	Three (3)	

Discussion

The system is considered to be a viable candidate.

A fresh water sanitary flushing system will be required.

The existing 25 gallon Galley Retention Tank in the starboard corner of the Engine Room would be retained. The tank has a built-in level controlled discharge pump.

Components would be located in Hold No. 2 as follows:

(a) The Sewage Holding Tank would be just forward of Bhd No. 11, to starboard of the ship's centerline.

(b) The Galley/Turbid Influent Surge Tank would be in place of the existing retention tank.

Vessel: WHITE SAGE (133')

System No. 17 (Cont'd)

(c) The Grumman MSD and Sludge Holding Tank would be forward of the Galley/Turbid Influent Surge Tank.

(d) Independent pumps would be grouped near the equipment served.

Drainage would be as follows:

(a) Sewage would be pumped by the macerator/transfer pumps to the Sewage Holding Tank in Hold No. 2. The sewage main would be led to Hold No. 2 via a new pipe tunnel (similar to the existing) passing through the upper inboard side of the Port Fuel Oil Tank. From there it would run to the existing overboard shell connection and to the existing weather deck discharge connection to pierside, port and starboard.

(b) Existing galley sink and deck drains would continue to drain to the 25 gallon retention tank from which they would be pumped to the Galley/Turbid Influent Surge Tank Hold No. 2 via the new pipe tunnel mentioned above.


(c) drains from the drinking fountain on the Main Deck Frame 14, to starboard of ship's centerline would have to be re-routed to drain into the existing 25 gallon retention tank.

(d) Remaining Galley/Turbid drains would gravitate overboard and to the Influent Surge Tank in Hold No. 2 via the new pipe tunnel indicated above. One tank transfer pump would discharge to the Sewage Holding Tank, the other would discharge to the Grumman Feed Tank.

(e) The Sludge Holding Tank Transfer Pump would discharge to the Sewage Holding Tank for discharge overboard and to pierside.

To accommodate the equipment in Hold No. 2, there may be minor modifications required to the shelving on the starboard side (along the shell of the vessel) and the wire mesh enclosure for the ship's dry stores on the centerline of the vessel (between Frames 9 and 10). The ship stores refrigerator will have to be moved slightly to port.

PROPOSED WMS EQUIPMENT ARRANGEMENT



USCGC WHITE SAGE (123 FOOT CLASS)
HOLD No. 2 PLAN
SYSTEM No. 17
SCALE: 1/2" = 1'-0" SHEET NO. 1 OF 1

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 17

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	1,195 ⁽²⁾	5,378
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	2,585 ⁽⁴⁾	1,422
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	1,280 ⁽⁵⁾	1,178
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	375	750
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	40	600
Access Cuts (In hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	35	35
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	80	480
Removals	Cutting	\$50.00/Hr. ⁽⁶⁾ (Labor)	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				10,968

- (1) Copper-nickel assumed.
- (2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.
- (3) One-quarter inch plate assumed.
- (4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.
- (5) Estimated on the basis of 10% of the weight which has to be supported.
- (6) Based on an assumed cutting rate of 50 ft. /hr.

DISCUSSION OF INSTALLATION BASED ON SHIPCHECKS

Vessel: WHITE SAGE (133')

WMS No. 18 GATX Reduced Volume Flush M/T Pump Collection/Grumman Flow Through System for Gray Water/Incinerator for both Concentrated Black Water and Gray Water Sludge

	<u>Required</u>	<u>Approximate Dimensions (L x W x H)</u>
Sewage Surge Tank	43 gal. (5.7 cu.ft.)	18" dia. x 48" H
Galley/Turbid Surge Tank	323 gal. (43 cu.ft.)	3' x 3' x 5'
Fuel Oil Day Tank	22 gal. (3 cu. ft.)	1'-6" x 1'-6" x 1'-6"
Grumman Unit with Incinerator	One (1) with One (1) Thiokol Incinerator	
Sewage Surge Tank Transfer Pump	One (1)	
Sewage Surge Tank Overboard Pump	One (1)	
Galley/Turbid Surge Tank Pump	One (1)	
Galley/Turbid Surge Tank Overboard Pump	One (1)	
Macerator/Transfer Pump	Three (3)	

Discussion

The system is a viable candidate with certain considerations.

A fresh water sanitary flushing system would be required.

The components would be located as follows:

(a) The Galley/Turbid Surge Tank and the Sewage Surge Tank would be located in the Engine Room, Port side, in place of the existing collecting tank. Their associated transfer and overboard pumps would be located aft of each tank.

Vessel: WHITE SAGE (133')

System No. 18 (Cont'd)

(b) The existing 25 gallon Galley Retention Tank located in the aft Starboard corner of the Engine Room would be retained. The tank has a built-in liquid level controlled pump.

(c) The Grumman MSD with the incinerator would be located on the Starboard side of Hold No. 2 in place of the existing retention tank.

(d) In view of the arrangement of the vessel as described in the discussion of existing conditions at the beginning of this section, the incinerator stack run to the weather seems to be severely limited. The only apparent solution is to run it up through the Main Deck alongside the port or starboard sheer leg of the cargo boom tripod support structure. The structure legs begin near the overhead in Hold No. 2. Cargo would have to be exercised due to tight house access arrangements on the Main Deck and the navigational and operational clearances needed.

Drainage would be as follows:

(a) Sewage would be collected and pumped to the Sewage Surge Tank by the macerator/transfer pumps. The transfer pump would discharge the tank contents to the Grumman Sludge Feed Tank. The overboard pump would discharge overboard and to pierside via the existing connections. Both discharge lines would go to Hold No. 2 via the existing pipe tunnel through the lower part of the Port Fuel Oil Tank.

(b) The existing 25 gallon Galley Retention Tank would discharge to the G/T Influent Surge Tank. Remaining G/T drains would gravitate to the surge tank.

(c) Drains from the drinking fountain on the Main Deck, Frame 14, would have to be re-routed to the 25 gallon retention tank.

(d) The G/T Surge Tank Pump would discharge to the Grumman Feed Tank via the aforementioned pipe tunnel to Hold No. 2.

Vessel: WHITE SAGE (133')


System No. 18 (Cont'd)

The G/T Surge Tank Overboard Pump would discharge via the same pipe tunnel to Hold No. 2 and then to the existing overboard and pierside connections.

To accommodate the equipment in Hold No. 2, the shelving along the starboard shell will have to be modified and the ship's stores wire mesh enclosure on the centerline moved to port.


Due to the incinerator installation, additional fire protection will have to be provided and the ventilation system for Hold No. 2 will have to be modified.

PROPOSED WMS EQUIPMENT ARRANGEMENT



NOTES : 1. TANK HEIGHT TAKEN FROM FLOOR PLATES
2. PUMPS NOT TO SCALE.

115/113 WHITE SAGE 1133 FDOT (CLASS)
ENGINE ROOM PLAN
SYSTEM No. 18
SCALE: 1/8" = 1'-0"
SHEET No. 1 OF 2



USCGC WHITE SAGE (193 ROOT CLASS)
HOLD No. 2 PLAN
SYSTEM No. 1 B
SCALE: 1/2"=1'-0" SHEET No. 2 OF 2

WMS INSTALLATION COST ESTIMATES

Vessel WHITE SAGE (133')

WMS No. 18

Installation Cost Element	Unit	Assumed Unit Cost	Quantity Required (estimated number of units)	Cost (\$)
Piping ⁽¹⁾	Pounds	\$ 4.50/Lb. (Materials and Labor)	2,460 ⁽²⁾	11,070
Tank Steel ⁽³⁾	Pounds	\$.55/Lb. (Materials and Labor)	1,540 ⁽⁴⁾	847
Foundations	Pounds	\$.92/Lb. (Materials and Labor)	990 ⁽⁵⁾	911
Electric Cables	Feet	\$ 2.00/Ft. (Materials and Labor)	275	550
Miscellaneous Installations (pumps, motors, skid-mounted components, etc.)	Man-Hours	\$15.00/MH (Labor)	40	600
Access Cuts (in hull, deck plating or bulkhead to provide passageway)	Feet	\$ 1.00/Ft. (Labor)	50	50
Welding	Feet	\$ 6.00/Ft. (Materials and Labor)	80	480
Removals	Cutting	\$50.00/Hr. (Labor) ⁽⁶⁾	15	750
	Other (miscellaneous handling)	\$15.00/MH (Labor)	25	375
Total Installation Cost (\$)				15,633

- (1) Copper-nickel assumed.
- (2) Estimate includes a factor of 50% added to allow for valves, flanges, fittings, take-down joints, etc.
- (3) One-quarter inch plate assumed.
- (4) Estimate includes a factor of 30% added to allow for required structural stiffening for proper support.
- (5) Estimated on the basis of 10% of the weight which has to be supported.
- (6) Based on an assumed cutting rate of 50 ft. /hr.

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 1 of 10

M/E I - ADAPTABILITY FOR SHIPBOARD INSTALLATION	
INSTALLATION CHARACTERISTIC	
111	Required black water handling capacity for vessel versus actual capacity of WMS (a) Actual capacity of WMS equals or exceeds required capacity for vessel. (b) WMS marginally suitable for vessel (has 95-99% of required capacity). (c) WMS capacity insufficient for vessel (less than 95% of required capacity).
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a a a a a a a a a a a a
112	Required gray water handling capacity for vessel versus actual capacity of WMS (a) Actual capacity of WMS equals or exceeds required capacity for vessel. (b) WMS marginally suitable for vessel (has 95-99% of required capacity). (c) WMS capacity insufficient for vessel (less than 95% of required capacity).
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a a a a a a a a a a a a
13	Extent of additional support systems or equipment required to accommodate WMS ⁽¹⁾ (a) No additional support systems or equipments required. (b) Some additional support systems or equipments required. ⁽²⁾ (c) Many additional support systems or equipments required. ⁽³⁾ ⁽¹⁾ Examples: . Firefighting system must be installed with incinerator. . Bilge alarm required if large tank is installed above bilge. . Compressor required on vessels that do not already have one. . Detectors of toxic or noxious gases should be installed with any system that, as an inherent design feature, uses such gases in processing wastes. ⁽²⁾ Need for support system/equipment does not significantly reduce WMS suitability for on-board installation. ⁽³⁾ Suitability of WMS for installation on vessel significantly reduced.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	b b b b b b b b b b b b b b b b b b b
21	Extent of fixture modifications required for WMS installation (a) No fixtures need modification or replacement. (b) Some fixtures need modification or replacement. (c) All commodes need replacement and modification of urinal-associated equipment (e.g., urinal discharge valves) is required. (d) All fixtures need replacement or modification (e.g., replacement or commodes and urinal flushometers). (e) All fixtures need replacement or modification and each fixture has additional hookup requirements associated with it.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a c c c c c e e e e e

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 2 of 10

Factor/Subfactor Ident. No.		M/E I - ADAPTABILITY FOR SHIPBOARD INSTALLATION (Cont'd)																	
		INSTALLATION CHARACTERISTIC																	
22	Extent of flush medium supply modifications required for WMS installation (a) Existing flush medium is used. (b) WMS requires conversion of flush medium to potable water. (c) WMS requires conversion of flush medium to recirculating non-aqueous medium. (d) WMS requires conversion of flush medium to salt water. ⁽¹⁾ (1) Conversion to salt water requires pump re-sizing, tapping into the sea-chest and provision for its corrosive properties. For PAMLICO, salt water would be used if the drain system were converted to a standard flush system (C.G. supplied information).																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	c	c	a	a	a	a	a	b	b	b	b	b	b	b	b	b	b	
231	Hookup requirements ⁽¹⁾ for WMS Collection/Transport subsystem installation (a) No additional hookup requirements beyond existing ones. (b) Requires piping for recirculation of flush medium (in existing gravity drain system). (c) Special and centralized Collection/Transport subsystem required. (d) Special and non-centralized Collection/Transport subsystem required (includes conversion from reduced flush vacuum collection to a standard gravity drain system, with or without recirculation). (1) Drain piping; electric cables connecting commode, M/T pump and control panel in GATX, but not in JERED, etc.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	b	b	a	a	a	a	a	c	c	c	c	c	d	d	d	d	d	
232	Routing flexibility for drain piping modifications ⁽¹⁾ associated with WMS Collection/Transport subsystem installation ⁽²⁾ (a) Routing is highly flexible. ⁽³⁾ (b) Routing is moderately flexible, with some restrictions. (c) Routing is highly inflexible. (1) Of the three relevant categories of routing of lines (piping, ventilation, electrical), piping is the most important for assessing use of WMS installation. (2) <u>Notes:</u> . With gravity drainage, lines must always slope downward and require venting. . Smaller size lines are inherently more flexible. . With the pump or vacuum Collection/Transport subsystem, sharp bends, rises and long runs can be accommodated in piping. (3) In all cases, WMS installation is to be considered from the point of view of modifications required to existing conditions.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	a	a	a	a	a	a	a	b	b	b	b	b	b	b	b	b	b	

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133)

Sheet 3 of 10

Factor/Subfactor Ident. No.		M/E I - ADAPTABILITY FOR SHIPBOARD INSTALLATION (Cont'd)																	
INSTALLATION CHARACTERISTIC																			
233	Space requirements for WMS Collection/Transport subsystem installation.																		
	(a) No additional space required. ⁽¹⁾ (b) Some additional space required. ⁽²⁾ (c) Large amount of additional space required.																		
	(1) E.g., M/T pumps in GATX; or small influent surge tank. (2) E.g., large VCT in JERED; or large influent surge tank, if not already installed.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	b	b	a	a	a	a	a	a	b	b	b	b	a	a	a	a	a	
234	Modularity of WMS Collection/Transport subsystem (as it affects installation) ⁽¹⁾																		
	(a) Degree of modularity of subsystem aids in installation of C/T subsystem. (b) Degree of modularity of subsystem results in some (minimal) difficulty in installation of C/T subsystem. (c) Degree of modularity of subsystem results in moderate difficulty in installation of C/T subsystem.																		
	(1) On vessels that do not currently have a WMS, a high degree of modularity aids in installation, and a high degree of subsystem centralization (as in the JERED) results in difficulties for installation.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	
235	Vent requirements for WMS Collection/Transport subsystem installation																		
	(a) No vents are required other than the existing vents. (b) Few vents are required in addition to the existing vents. (c) Many vents are required in addition to existing vents.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	b	b	a	a	a	b	b	b	b	b	b	b	a	a	a	a	a	
241	Space requirements for WMS waste Treatment/Disposal subsystem installation																		
	(a) Volume required is minimal and dimensions ⁽¹⁾ of equipment present no problems in fitting equipment into available compartment space. (b) Volume required is moderate and dimensions ⁽¹⁾ of equipment present no problems in fitting equipment into available compartment space. (c) Volume and dimension ⁽¹⁾ of equipment do present problem in fitting equipment into available compartment space. (d) Large volume required and dimension ⁽¹⁾ of equipment do present problem in fitting equipment into available compartment space.																		
	(1) The two main factors are (i) deck area required and (ii) height required.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	b	b	b	a	b	b	b	a	b	b	b	b	b	b	b	b	b	

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 4 of 10

M/E I - ADAPTABILITY FOR SHIPBOARD INSTALLATION (Cont'd)

INSTALLATION CHARACTERISTIC

Factor/Subfactor Ident. No. 242 Hookup requirements⁽¹⁾ for WMS waste Treatment/Disposal subsystem installation

(a) Pipes, ducts and/or cable requirements are minimal.
 (b) Pipes, ducts and/or cable requirements are moderate.
 (c) Pipes, ducts and/or cable requirements are extensive.

⁽¹⁾ Piping for fuel oil, fresh water, cooling water, compressed air, interconnecting remotely located equipment, overboard discharge line, etc.; electric cables for power supply, remote control panels, etc.; ducting for ventilation, etc.

WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Data	a	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b

243 Degree of modularity of WMS waste Treatment/Disposal (as it affects installation)⁽¹⁾

(a) Degree of modularity of subsystem aids in installation of T/D subsystem.
 (b) Degree of modularity of subsystem results in some (minimal) difficulty in installation of T/D subsystem.
 (c) Degree of modularity of subsystem results in moderate difficulty in installation of T/D subsystem.

⁽¹⁾ Decentralization of components may require additional hookups and piping runs.

WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Data	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a	a

244 Vent requirements for WMS waste Treatment/Disposal subsystem installation⁽¹⁾

(a) No vents are required.
 (b) Vents are required.

⁽¹⁾ Vents that are only internal to the compartment in which subsystem is located are not considered here.

WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Data	a	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b

245 Exhaust stack requirements for WMS waste Treatment/Disposal subsystem installation⁽¹⁾

(a) Exhaust not required.
 (b) Exhaust required, size of stack relatively small and stack can be run via existing ship's stack enclosure (fiddley).
 (c) Exhaust required, size of stack relatively large and stack can be run via existing ship's stack enclosure.
 (d) Exhaust required, size of stack relatively small and stack cannot be run via existing ship's stack enclosure.
 (e) Exhaust required, size of stack relatively large and stack cannot be run via existing ship's stack enclosure.

⁽¹⁾ Notes: . Electric incinerator requires small (2") exhaust.
 . Fuel incinerator requires large (10") exhaust.

WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Data	a	a	c	a	a	a	e	e	a	c	a	a	e	a	c	a	a	e

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 5 of 10

Factor/Subfactor Ident. No.		M/R I - ADAPTABILITY FOR SHIPBOARD INSTALLATION (Cont'd)																	
INSTALLATION CHARACTERISTIC																			
25	Ease of installing WMS support equipment ⁽¹⁾																		
	(a) No support equipment required. (b) Some support equipment required but easy to install. (c) Much support equipment required and difficult to install.																		
(1) Examples: <ul style="list-style-type: none"> . Firefighting system must be installed with incinerator. . Bilge alarm required if large tank is installed above bilge. . Compressor required on vessels that do not already have one. . Detectors of toxic or noxious gases should be installed with any system that, as an inherent design feature, uses such gases in processing wastes. 																			
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	b	
26	Ease of compensating for added weight of WMS																		
	(a) No or minimal compensation for added weight required. (b) Moderate compensation for added weight required. (c) Extensive compensation for added weight required.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	a	a	b	a	a	a	a	a	a	a	a	a	a	a	a	a	a	
271	Extent of SHIPALTS (permanent modifications) required for WMS installation ⁽¹⁾																		
	(a) No SHIPALTS required. (b) Minor SHIPALTS required. (c) Extent of SHIPALTS required is moderate. (d) Extensive SHIPALTS required.																		
(1) Foundations, enlarged doors/hatches, increased capacity requirements for air compressor, etc.																			
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	b	c	c	c	b	b	b	b	b	c	c	c	c	b	b	b	b	c	
272	Extent of temporary modification ⁽¹⁾ required for WMS installation																		
	(a) No temporary modifications required. (b) Temporary modifications required are minor. (c) Extent of temporary modifications required are moderate. (d) Temporary modifications required are extensive.																		
(1) Cutting access openings, etc.																			
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	b	c	c	c	c	c	c	c	b	b	b	c	c	b	c	c	c	c	

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 6 of 10

M/E I - ADAPTABILITY FOR SHIPBOARD INSTALLATION (Cont'd)	
INSTALLATION CHARACTERISTIC	
31	Effect of WMS on vessel stability (a) No effect on existing stability characteristics of vessel. (b) Some effect on existing stability characteristics of vessel, easily compensated for. (c) Severe effect on existing stability characteristics of vessel, compensation required extensive modifications to vessel (e.g., no tankage in Point Heron).
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a a a a a a a a a a a a
32	Effect of WMS on vessel trim and list (a) No effect on trim or on list. (b) Some easily compensated for effect on trim or list. (c) Compensation for effect on trim or list requires extensive modification to vessel.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a b b b b a a a a a a a a a b a
33	Effect of WMS on normal range of vessel Vessel resource capacity and usage rates.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	- Presented on Vessel Resource Data Sheet -
34	Degree of space trade-off/reallocation required for WMS installation (a) No space trade-off/reallocation required. (b) Minimal degree of space trade-off/reallocation required. (c) Moderate degree of space trade-off/reallocation required. (d) High degree of space trade-off/reallocation required.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a a a a a a a a a a a
M/E II - PERFORMANCE	
PERFORMANCE CHARACTERISTIC	
12	WMS per capita wet weight (lb) ⁽¹⁾ - W_1 (1) Drain piping material is assumed to be copper-nickel (Cu-Ni).
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	1892 1467 1493 1574 719 1068 1074 870 1387 1467 1333 746 872 1441 1462 1361 818 718

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 7 of 10

M/E II - PERFORMANCE (Cont'd)	
PERFORMANCE CHARACTERISTIC	
13	<p>WMS per capita volume (ft³)⁽¹⁾ - V_1</p> <p>(1) Volumes are calculated as follows:</p> <ul style="list-style-type: none"> • Fixture volumes are calculated using smallest space envelopes. • Pipe volume is the volume of a square tube with side = outside diameter of pipe. • Other equipment: Deck area: smallest rectangle enclosing all equipment in a single package plus extra dimension area required for operation and maintenance. <p style="text-align: center;">Height: either maximum height of equipment, or full compartment height, if space above package is not usable for any other purposes.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	89.7 100.7 103.8 109.8 92.2 117.1 137.3 89.7 103.9 97.9 91.4 98.9 80.6 77.7 86.3 71.6 116.6 88.9
21	<p>Adequacy of WMS black water holding times</p> <p>HT_b - % of required black water holding time met by WMS⁽¹⁾</p> <p>(1) A WMS which employs an incinerator is considered to meet 100% of the required holding time. The holding time of a WMS which employs a holding tank (for wastewater or sludge) is determined by the ratio of available tank capacity to required capacity.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	100 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100
22	<p>Adequacy of WMS gray water holding times</p> <p>HT_g - % of required gray water holding time met by WMS⁽¹⁾</p> <p>(1) A WMS which employs an incinerator is considered to meet 100% of the required holding time. The holding time of a WMS which employs a holding tank (for wastewater or sludge) is determined by the ratio of available tank capacity to required capacity.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	100 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100 100
311	<p>Effect of peak hydraulic loads in black water stream on WMS performance</p> <p>$GIST_b$ - % of required Grumman (or other) influent surge tank capacity in black water stream met by installation.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	-- -- -- 100 100 -- 100 100 -- -- -- -- -- -- -- -- -- 100
312	<p>Effect of peak hydraulic loads in gray water stream on WMS performance</p> <p>$GIST_g$ - % of required Grumman influent surge tank capacity in gray water stream met by installation.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	-- -- -- -- 100 100 -- 100 -- -- -- 100 100 -- -- -- 100 100
331	<p>Ability of black water portion of WMS to handle additional personnel (on a long-term basis)</p> <p>HTC_b - % of required black water (or sludge) holding tank capacity met by installation.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	100 100 -- 100 100 100 -- -- 100 -- -- 100 -- 100 -- -- 100 --

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 8 of 10

M/E II - PERFORMANCE (Cont'd)	
PERFORMANCE CHARACTERISTIC	
332	Ability of gray water portion of WMS to handle additional personnel (on a long term basis) HTC _g = % of required gray water (or sludge) holding tank capacity met by installation.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	100 100 100 100 100 100 100 -- 100 100 100 100 -- 100 100 100 100 --
M/E IV - PERSONNEL SAFETY	
SAFETY CHARACTERISTIC	
21	Hazard of explosive potential for operator/maintainer due to inherent WMS design. <u>I - Installation index (for personnel safety)</u> (a) Likelihood of hazardous situation is not increased due to location of any portion of WMS. (b) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to working or berthing area. (c) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to fuel storage area.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a c c a a a a c a b a a c
22	Hazard of explosive potential for operator/maintainer due to procedural error/equipment failures of WMS. <u>I - Installation index (for personnel safety)</u> (a) Likelihood of hazardous situation is not increased due to location of any portion of WMS. (b) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to working or berthing area. (c) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to fuel storage area.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a c c a a a a c a b a a c
31	Hazard of fire ignition potential due to inherent WMS design <u>I - Installation index (for personnel safety)</u> (a) Likelihood of hazardous situation is not increased due to location of any portion of WMS. (b) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to working or berthing area. (c) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to fuel storage area.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a c c a a a a c a b a a c
32	Hazard of fire ignition potential due to procedural errors/equipment failures of WMS. <u>I - Installation index (for personnel safety)</u> (a) Likelihood of hazardous situation is not increased due to location of any portion of WMS. (b) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to working or berthing area. (c) Likelihood of hazardous situation is increased due to proximity of any portion of WMS to fuel storage area.
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a c c a a a a c a b a a c

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 9 of 10

M/E V - HABITABILITY	
HABITABILITY CHARACTERISTIC	
41	<p>Heat generation for nearby personnel⁽¹⁾ due to inherent WMS design</p> <p><u>I - Installation index (for heat)</u></p> <p>(a) Location of WMS is not likely to raise heat level due to proximity to working and berthing areas. (b) Location of WMS is likely to raise heat level due to proximity to working and berthing areas.</p> <p>(1) For operator/maintainer/adjacent berthing and working areas.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a b a a a b b a b a a b a b a a b
42	<p>Heat generation for nearby personnel⁽¹⁾ due to procedural errors/equipment failures of WMS</p> <p><u>I - Installation index (for heat)</u></p> <p>(a) Location of WMS is not likely to raise heat level due to proximity to working and berthing areas. (b) Location of WMS is likely to raise heat level due to proximity to working and berthing areas.</p> <p>(1) For operator/maintainer/adjacent berthing and working areas.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a b a a a b b a b a a b a b a a b
5	<p>Noise level for personnel in vicinity of WMS⁽¹⁾</p> <p><u>I - Installation index (for noise)</u></p> <p>(a) Location of WMS is not likely to raise noise level due to proximity to working and berthing areas. (b) Location of WMS is likely to raise noise level due to proximity to working and berthing areas.</p> <p>(1) For operator/maintainer/adjacent berthing and working areas.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a a a a a a a a a a b
6	<p>Vibration levels for nearby personnel⁽¹⁾ produced by WMS machinery</p> <p><u>I - Installation index (for vibration)</u></p> <p>(a) Location of WMS is not likely to raise vibration level due to proximity to working and berthing areas. (b) Location of WMS is likely to raise vibration level due to proximity to working and berthing areas.</p> <p>(1) For operator/maintainer/adjacent berthing and working areas.</p>
WMS #	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18
Data	a a a a a a a a a a a a a a a a a b

WMS INSTALLATION EFFECTIVENESS ATTRIBUTE DATA

Vessel WHITE SAGE (133')

Sheet 10 of 10

Factor / Subfactor Ident. No.	M/E VI - RELIABILITY																		
	RELIABILITY CHARACTERISTIC																		
22	Extent of WMS configuration redundancy WMS equipment requirements.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data																			
- Presented on WMS Equipment Resources Data Form -																			
M/E VII - MAINTAINABILITY																			
MAINTAINABILITY CHARACTERISTIC																			
131	Accessibility of replaceable WMS components <u>I - Installation index (for accessibility)</u> (a) High degree of physical clearance around WMS equipment. (b) Moderate degree of clearance around WMS equipment. (c) Very tight, i.e., very little clearance around WMS equipment.																		
WMS #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Data	a	b	c	b	a	a	a	a	a	c	a	b	a	a	b	a	b	b	

CONCLUDING REMARKS

The following are points of consideration and observation relevant to this vessel, some of which have been included in the shipcheck observations, and are reiterated for emphasis and convenience.

(a) The vessel is presently fitted with a CHT system, components of which occupy space in the Engine Room and in Hold No. 2 just forward of the Engine Room. The piping runs and space for equipment locations are convenient and well arranged for the most part with separate black and gray water mains lending themselves readily adaptable to the WMS configurations studied.

(b) Possibly the only major problem for which there is no readily apparent solution is the manner in which incinerator stacks can be led to the weather when the arrangement does not permit them to go up via the Engine Room fidley along with the existing diesel exhaust piping. The general arrangement of the ship seemingly precludes the possibility of making these runs due to interference with cargo handling equipment, navigational aids, visibility from the bridge and the undesirable path the smoke could take from the top of the incinerator stack.

(c) Present waste disposal system equipment in the Engine Room offer no apparent problem into removals. In Hold No. 2 however, the 810 gallon retention tank installation is quite substantial with a very large supporting foundation. This would require a large amount of labor and cutting up to remove from the vessel.

(d) The ship's dry stores in Hold No. 2 are contained in an expanded metal enclosure on the ship's centerline. This would have to be relocated, most likely to the port side of the vessel.

(e) The ship's stores refrigerator is a free-standing self-contained unit in Hold No. 2. For some proposed WMS installations the refrigerator would have to be shifted to port to provide more space for system components. This would involve foundation extension.

(f) Most of the remaining existing equipment on Hold No. 2 involves storage shelving and miscellaneous cabinetry which should offer no real problem. There is ample space in the hold for relocation.

WHITE SAGE (133')

(g) In order to pass piping between the Engine Room and Hold No. 2, another pipe tunnel through the port side fuel oil tank would be required, similar to the one already existing for this purpose. This would involve tank washing and gas freeing before any hot work can be done.

(h) The ship is outfitted with the required support systems, flushing water, fuel, compressed air, etc. It would be required that for some WMS proposals the present salt water flushing system be changed over to fresh water.

(i) Existing piping runs and connections lend themselves readily to reuse for many of the WMS proposals.

(j) For systems involving installation of incinerators, the existing ventilation system would have to be studied for adequacy.

The same would apply to the fire extinguishing apparatus.

(k) Access cuts for shipping WMS components would have to be made in the deck head or in the ship's side.

(l) There are no ballasting provisions per se aboard the vessel. Therefore any weight compensations required would have to be at the expense of on-board existing material.

APPENDIX A

PRELIMINARY INSTALLATION ANALYSIS

WHITE SAGE (133')

Vessel Characteristics	Data
Class	WLM - 544 White Summac (133') Class
Type	Buoy Tender (Coastal)
Crew Size	21
Home Port	Woods Hole, Mass.

SUMMARY OF PRELIMINARY INSTALLATION ANALYSIS RESULTS

WHITE SAGE (133')

WMS No.	Col/Trans Subsys (Black)	TYPE		SYSTEM ACCEPTABILITY FOR INSTALLATION ⁽¹⁾
		Treatment/Disposal Subsystem		
		Black	Gray	
1	Gravity Collect.	Holding Tank	Holding Tank	Yes
2	Oil Recircul. (Chrysler)	Chrysler + Hld Trk	Holding Tank	Yes
3		Chrysler + Incin.	Holding Tank	Yes
4	Gravity Collect. (Grumman)	Grum Flow Thru+HldTk	Holding Tank	Yes
5		Grumman Flow Thru + Holding Tank		Yes
6	Gravity Collect.	Holding Tank	Grum Flow Thru+HldTnk	Yes
7	Gravity Collect. (Grumman)	Grum Flow Thru+Incin.	Holding Tank	Yes
8		Grumman Flow Thru + Incinerator		Yes
9	Vacuum Collect. (Jered)	Holding Tank(2)	Holding Tank	Yes
10		Incinerator	Holding Tank	Yes
11		GATX Evap.	Holding Tank	Yes
12		Holding Tank(3)	Grum Flow Thru+ Hld Tnk	Yes
13		Incinerator	Grum Flow Thru + Incin.	Yes
14		M/T Pump Collect. (GATX)	Holding Tank	Holding Tank
15	Incinerator		Holding Tank	Yes
16	GATX Evap.		Holding Tank	Yes
17	Holding Tank		Grum Flow Thru+Hld Tnk	Yes
18	Incinerator		Grum Flow Thru + Incin.	Yes

(1) Based on:

- . Information contained in available vessel plans,
- . WMS installation requirements,
- . WMS installation criteria and guidelines.

(2) Two subchoices available for WMS No. 9 as follows:

- . 9a - Concentrated black water transferred from VCT to holding tank (acceptable for all vessels),
- . 9b - Concentrated black water held in VCT (acceptable for Point Herron only).

(3) Two subchoices available for WMS No. 12 as follows:

- . 12a - Concentrated black water transferred from VCT to holding tank (acceptable for all vessels),
- . 12b - Concentrated black water held in VCT (acceptable for Point Herron only).

PERTINENT VESSEL INFORMATION

WHITE SAGE (133')

Crew: 21 men

Sanitary Fixtures: 4 Waterclosets, 1 Urinal, 4 showers, 5 lavatories

Existing Arrangement:

- (a) One (1) 25 gallon Galley Retention Tank in aft Machinery Compartment receives drainage from galley sinks, galley deck drain and drinking fountain.
- (b) Galley drains can discharge overboard via gravity or drain to the Galley Retention Tank. The tank can pumpout to a 220 gallon Collection Tank in the Engine Room.
- (c) The 220 gallon Collection Tank also receives all Sewage and turbid drains via separate piping systems. The turbid drain system can also discharge directly overboard.
- (d) The 220 gallon Collection Tank can pumpout to a 810 gallon Retention Tank located in Hold No. 2 Storeroom, forward of the Engine Room. It can also pumpout overboard or to the deck discharge connections.
- (e) The 810 gallon Retention Tank receives only the 220 gallon Collection Tank pumpout. It can pumpout to the deck discharge connections or directly overboard.
- (f) The Retention and Collection Tank pump piping is so arranged that either pump can serve either tank, thereby providing a standby pump for each tank.

Note:

The drawings of the existing ship that were provided to accomplish this work are contradictory regarding the location of the Collection and Retention Tanks and other items of machinery:

- (1) 540 WAGL - 4808-2 Secondary Drainage System
Alterations Fleet - Dated 8-9-71
- (2) 540 WAGL - 0103-8 Booklet of General Drawings
U.S.C.G.C. Whitebush - Dated 5-30-74
- (3) 540 WAGL - 4000-1 Whitebush Engine Room
Rearrangement - Elevation & Plan - Dated 3-18-74

Vessel: WHITE SAGE (133')

Existing Arrangement (Cont'd)

Drawing (1) locates the collecting and retention tanks a considerable distance from the location shown on drawings (2) and (3). In view of the fact that drawing (1) is a piping system installation plan that involves the tanks and is intended as a Fleet Alteration, it was decided to use this drawing as applicable to the Whitesage. Further, drawings (2) and (3) apply specifically to the Whitebush which is not the subject ship in this discussion. As a result of the above, the conclusions that are arrived in the following discussions must be considered with somewhat below average accuracy.

PRELIMINARY INSTALLATION ANALYSIS OF INDIVIDUAL CANDIDATE SYSTEMS

Vessel: WHITE SAGE (133')

WMS No. 1 Full Volume Flush Gravity Collection/Holding Tank for
Black Water/Holding Tank for Gray Water

Required

Sewage Holding Tank.	722 gal. (97 cu. ft.)
Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm

Discussion

The system installation appears to be acceptable as follows:

It is advisable to locate two pumps and a Sewage Holding Tank in the location presently occupied by the Collecting Tank in the Engine Room with very minor rearrangement of existing equipment. Very minor modifications in the sewage and garbage grinder piping will be necessary.

A Galley/Turbid Holding Tank and two pumps could be located in the area presently occupied by the existing Retention Tank in the Hold No. 2 storeroom with very minor rearrangement of the space.

It will be necessary to run the Galley/Turbid piping mains from the Engine Room to the Hold No. 2 storeroom area in order to connect to the G/T Holding tank. This piping can run through a void space separating the Fresh Water and Fuel Oil Tanks (if fitted) or through a pipe tunnel in the Fuel Oil Tank.

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the G/T Holding Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the G/T Holding Tank. The overboard discharge is to be blanked off.

Existing overboard discharge connections and deck discharge connections can be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 2 Full Volume Flush Oil Recirculation and Gravity Collection/
Chrysler System with Sludge Holding Tank for
Sewage/Holding Tank for Gray Water

Required

Sewage Holding Tank	135 gal. (18 cu. ft.)
Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm.
Chrysler Model and Quantity	Model A One (1)

Discussion

The system installation is acceptable subject to the following:

The Galley/Turbid Holding Tank plus two discharge pumps can be located in the area presently occupied by the existing Retention Tank in the Hold No. 2 storeroom with very minor rearrangement of existing equipment.

The Sewage Holding Tank with two discharge pumps, Separation Unit and the Pressurization and Fluid Package can be located in the area presently occupied by the existing Collecting Tank in the Engine Room and in the area in-board of the boiler and fire & bilge pump on the port side.

This arrangement will require the routing of the Galley/Turbid piping mains from the Engine Room to the Hold No. 2 storeroom area in order to connect to the new G/T Holding Tank. The piping can run through a void space separating the Fresh Water and Fuel Oil Tanks (if fitted) or through a pipe tunnel in the Fuel Oil Tank.

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the G/T Holding Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the G/T Holding Tank. This overboard discharge is to be blanked off.

The existing overboard discharge shell connections and deck discharge connections can be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 3 Full Volume Flush Oil Recirculation and Gravity Collection/
Chrysler System with Incinerator for
Sewage/Holding Tank for Gray Water

Required

Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Sludge Ejection Tank	50 gal. (6.7 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm
Chrysler Model and Quantity	Model A One (1)
Incinerator Model and Quantity	Model A One (1)

Discussion

The system installation appears to be acceptable as follows:

The Galley/Turbid Holding Tank plus two discharge pumps could be located in the space presently occupied by the existing Retention Tank in the Hold No. 2 storeroom with possible minor rearrangement of existing equipment.

The Separation Unit Pressurization and Fluid Package and the Sludge Ejection Tank can be located in the Engine Room in the area presently occupied by the existing Collecting Tank and in the area inboard of the boiler and fire & bilge pump on the port side.

The Incinerator can be located on or near the centerline at Frame 15 under the casing opening in order to facilitate routing the incinerator stack up the stack along with the diesel engine exhaust pipes.

This arrangement will necessitate the running of the Galley/Turbid piping mains from the Engine Room to the Hold No. 2 storeroom area in order to connect to the new G/T Holding Tank. The piping can be run through a void space between the Fresh Water and Fuel Oil Tanks (if fitted) or through a pipe tunnel in the Fuel Oil Tank.

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the G/T Holding Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the G/T Holding Tank. The overboard discharge can be blanked off.

Existing overboard discharge shell connections and deck discharge connections can be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 4 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Holding Tank for Black Water/ Holding Tank for Gray Water

	<u>Required</u>
Sewage Influent Surge Tank	110 gal. (15 cu. ft.)
Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Sludge Holding Tank	60 gal. (8 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm
 Grumman Unit	 One (1)

Discussion

The system installation is acceptable as follows:

It appears that the Sewage Influent Surge Tank and the Sludge Holding Tank plus four discharge pumps can be located in the space presently occupied by the existing Collecting Tank in the Engine Room with some minor equipment relocation.

The Grumman Unit can be located in the Engine Room on the port side of the center line between frames 14 and 15. The stack can run up the machinery casing. This will require the relocation of the Log Desk and Telephone Booth plus other minor items of machinery and possibly the Air Cond. Water Chiller.

The Galley/Turbid Holding Tank plus two discharge pumps can be located in the area presently occupied by the existing Retention Tank in the Hold No. 2 storeroom with possible minor rearrangement of existing equipment.

An alternative location for the Grumman unit is the Hold No. 2 Storeroom area near the G/T Holding Tank, thereby placing all treatment equipment in the same vicinity.

This will require the extension of the Galley/Turbid piping mains from the Engine Room to the Hold No. 2 Storeroom area in order to connect to the G/T Holding Tank. The G/T piping can be run through a void space between the Fresh Water and Fuel Oil Tanks (if fitted) or through a pipe tunnel in the Fuel Oil Tank.

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the G/T Holding Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the G/T Holding Tank. The overboard discharge could be blanked off.

Vessel: WHITE SAGE (133')

System No. 4 (Cont'd)

The existing overboard discharge deck and shell connections can remain for use in the new installation.

Vessel: WHITE SAGE (133')

WMS No. 5 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Holding Tank for Combined Black and Gray Waters

	<u>Required</u>
Sludge Holding Tank	232 gal. (31 cu. ft.)
Influent Surge Tank	432 gal. (58 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm
 Grumman Unit	 One (1)

Discussion

The system installation appears to be acceptable as described in the following:

The Sludge Holding Tank and the Influent Surge Tank plus pumps can be located in the area presently occupied by the existing Collecting Tank in the Engine Room. Minor rearrangement of equipment may be required for this installation.

The Grumman Unit can be located in the Engine Room port side near the centerline between frames 14 and 15. This location will require the relocation of the Log Desk and Telephone Booth plus other minor machinery items.

Fewer items of existing equipment will require relocation if the Influent Surge Tank is installed in the area presently occupied by the Retention Tank in the Hold No. 2 Storeroom area. This will require the extension of the combined waste piping mains from the Engine Room to the Hold No. 2 Storeroom area via a pipe tunnel or through a void space, if fitted.

An alternate location for the Grumman Unit and the Sludge Holding Tank is the Hold No. 2 Storeroom in the general area presently occupied by the Retention Tank. This location can accommodate all the required components thereby having all treatment equipment together in Hold No. 2. Minor modifications will be necessary to the space.

Vessel: WHITE SAGE (133')

System No. 5 (Cont'd)

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the Influent Surge Tank. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the Influent Surge Tank. The overboard discharge would be blanked off.

Existing deck and shell overboard discharge connections can remain for use with the new equipment.

Vessel: WHITE SAGE (133')

**WMS No. 6 Full Volume Flush Gravity Collection/Holding Tank for
Black Water/Grumman Flow Through System with
Sludge Holding Tank for Gray Water**

	<u>Required</u>
Influent Surge Tank	323 gal. (43 cu. ft.)
Sludge Holding Tank	172 gal. (23 cu. ft.)
Sewage Holding Tank	722 gal. (97 cu. ft.)
Optional Comb. Sewage/Sludge Holding Tank	894 gal. (120 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm
Grumman Unit	One (1)

Description

The system installation appears to be acceptable as described in the following:

Although it is possible to locate the Grumman Unit in the Engine Room between frames 14 and 15, port side near centerline, it may be advisable to locate this unit and the Sludge Holding Tank (2.5' x 2.5' x 4' H) in the Hold No. 2 Storeroom area in the location of the present Retention Tank because the size of the associated tanks makes it impossible to locate all equipment in the Engine Room without considerable rearrangement.

The Influent Surge Tank (3' W x 3' L x 5' H) and the Sewage Holding Tank or the Optional Combined Holding Tank can be located in the Engine Room in the area presently occupied by the existing Collecting Tank. It may be necessary to relocate the Log Desk and Telephone Booth. As an alternate the tanks can be located in Hold No. 2 Storeroom area thereby keeping all related equipment in the same space. Only minor rearrangement of the existing space will be required.

The 25 gal. Galley Drain Tank could remain in use and the pump piping revised to discharge to the Influent Surge Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the Influent Surge Tank. The overboard discharge is to be blanked off.

Existing shell and deck discharge connections can remain for use with the new equipment.

Vessel: WHITE SAGE (133')

WMS No. 7 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Incinerator for Black Water/Holding Tank for Gray Water

	<u>Required</u>
Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Sewage Influent Surge Tank	110 gal. (15 cu. ft.)
Fuel Oil Day Tank	25 gal. (3.3 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm
Grumman Unit	One (1)
Thiokol Incinerator	One (1)

Discussion

The system installation appears to be acceptable subject to certain limitations as follows:

The Galley/Turbid Holding Tank can be located in the Hold No. 2 Store-room area in the space presently occupied by the existing Retention Tank with very minor rearrangement of the space.

The Grumman MSD fitted with an Incinerator can be installed in the Engine Room between frames No. 14 and 15 port side near the centerline. The incinerator stack can be led up the machinery casing along with the existing diesel engine exhaust pipes. This location will require the rearrangement of the Log Desk and Telephone Booth and perhaps the Air Conditioning Water Chiller.

The Sewage Influent Surge Tank can be located in the Engine Room in the area presently occupied by the Collecting Tank. The Incinerator Fuel Tank can be located in the overhead in the same area.

This arrangement will require that the Galley/Turbid main be routed to the No. 2 Hold Storeroom area via the void space between Fuel Oil and Fresh Water Tanks (if fitted) or through a pipe tunnel in the Fuel Oil Tank.

Vessel: WHITE SAGE (133')

System No. 7 (Cont'd)

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the G/T Holding Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the G/T Holding Tank. This overboard discharge is to be blanked off.

The existing shell and deck connections can remain for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 8 Full Volume Flush Gravity Collection/Grumman Flow Through System with Sludge Incinerator for Combined Black and Gray Waters

Required

Influent Surge Tank	432 gal. (58 cu. ft.)
Fuel Oil Day Tank	25 gal. (3.3 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm
Grumman Unit	One (1)
Thiokol Incinerator	One (1)

Discussion

The system installation is acceptable within the following limitations:

The Influent Surge Tank can be located in the area presently occupied by the existing Collecting Tank in the Engine Room.

The Grumman Unit with the Thiokol Incinerator can be located in the Engine Room between Frames No. 14 and 15, Port Side near the centerline. This will require the relocation of the Telephone Booth, Log Desk and probably the Air Conditioning Water Chiller.

The Fuel Oil Day Tank can be located overhead near the Grumman Unit.

The incinerator stack can be led up the machinery casing along with the existing diesel engine exhaust pipes.

The 25 gal. Galley Drain Tank should remain in use and the pump piping revised to discharge to the Influent Surge Tank in Hold No. 2. The single drinking fountain (Frames 14/15) discharging overboard should be reconnected to drain to the gravity G/T drain line to the Influent Surge Tank. This overboard discharge is to be blanked off.

The existing overboard discharge shell and deck connections can remain for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 9 JERED Reduced Volume Flush Vacuum Collection/Holding
Tank for Concentrated Black Water/Holding Tank
for Gray Water

Required

Vacuum Collection Tank	30 gal. (4.4 cu. ft.)
Sewage Holding Tank	200 gal. (27 cu. ft.)
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)

Discussion

The system installation appear to be acceptable subject to certain limitations.

Reuse of existing piping arrangement should be considered. A fresh water flushing system is required for this system.

The Vacuum Collection Tank, its vacuum equipment, Sewage Holding Tank and sewage overboard pumps can be located in the Engine Room in the area where the existing Collecting Tank is presently installed.

The Galley/Turbid Holding Tank and overboard pumps can be located in the Hold No. 2 Storeroom area where the Retention Tank is presently installed.

Minor rearrangements of existing equipment may be necessary in both compartments.

The Galley/Turbid drains in the Engine Room must be manifolded and led to the G/T Holding Tank via a pipe tunnel through the fuel oil tanks or the void space (depending on the vessel's arrangement) between the Engine Room and Hold No. 2.

It is recommended that the galley and turbid drains aft of Frame 17 continue to utilize the existing 25 gallon collecting tank and pump. This must be rearranged to discharge forward to the new G/T Holding Tank in Hold No. 2. The single drinking fountain drain between Frames 14 and 15 must be tied in to the gravity system going forward instead of retaining its own independent overboard discharge. This overboard connection could be blanked off.

Vessel: WHITE SAGE (133')

System No. 9 (Cont'd)

The existing pipe tunnel between the Engine Room and Hold No. 2 could be retained for sewage transfer to the existing overboard discharge connection in Hold No. 2 or to the existing pierside deck connection.

Existing overboard discharge connections and deck discharge connections can be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 10 JERED Reduced Volume Flush Vacuum Collection/Incinerator
for Concentrated Black Water/Holding Tank for Gray Water

Required

Vacuum Collection Tank	120 gal. (18 cu. ft.)
Galley/Turbid Holding Tank	2063 gal. (276 cu. ft.)
Incinerator Feed Tank (Sludge)	50 gal. (6.5 cu. ft.)
Fuel Oil Day Tank	22 gal. (3.0 cu. ft.)
Incinerator	One (1) Thiokol

Discussion

The system installation appears to be acceptable subject to certain limitations.

Reuse of existing piping arrangements should be considered. A fresh water sanitary flushing system is required.

The Vacuum Collection Tank, vacuum equipment and overboard discharge pump could be located in the Engine Room in the area where the existing Collecting Tank is fitted. The Incinerator, its feed (sludge) tank, blower, fuel tank, controls, etc. would be located just aft of the Vacuum Collection Tank. The incinerator stack can be run to the weather alongside the exhausts from the existing diesel engines up the machinery casing.

The Galley/Turbid Holding Tank and its overboard pumps would be located in the Hold No. 2 Storeroom area where the present Retention Tank is installed.

Minor rearrangements of existing spaces and machinery may be necessary in both compartments to accommodate the new units.

The existing 25 gallon Galley Drain Tank should remain in use and the pump discharge piping revised to discharge to the Galley/Turbid Holding Tank in Hold No. 2. The single drinking fountain drain between Frames 14 and 15 should be connected to the gravity Galley/Turbid drain running to the G/T Holding Tank and the independent overboard discharge disconnected and blanked off.

VESSEL: WHITE SAGE (133')

System No. 10 (Cont'd)

The existing pipe tunnel between the Engine Room and Hold No. 2 would be used for the piping necessary to pump out the Vacuum Collection Tank.

The existing overboard shell and deck connections should be retained for use with the new system.

The G/T drain main in the Engine Room should be run to the G/T Holding Tank in Hold No. 2 via the pipe tunnel.

Vessel: WHITE SAGE (133')

WMS No. 11 JERED Reduced Volume Flush Vacuum Collection/GATX
Evaporator for Concentrated Black Water/Holding Tank
for Gray Water

Required

Vacuum Collection Tank	30 gal. (4.4 cu. ft.)
Galley/Turbid Holding Tank	2063 ga. (276 cu. ft.)
Evaporator (GATX)	One (1) - 80 gal.
Catalytic Oxidizer	One (1)

Discussion

The system installation appears to be acceptable as follows:

Reuse of existing piping arrangements would have to be considered. A fresh water sanitary flushing system is required with this system.

The Vacuum Collection Tank, Evaporator and Catalytic Oxidizer can be located in the area presently occupied by the Collection Tank in the Engine Room.

The Galley/Turbid Holding Tank could be located in the Hold No. 2 Store-room area presently occupied by the Retention Tank.

The existing 25 gallon Galley Drain Tank should remain in use and the pump piping revised to discharge to the Galley/Turbid Holding Tank in Hold No. 2. The single drinking fountain discharging overboard at frames 14/15 should be reconnected to the gravity G/T drain to the G/T Holding Tank. The overboard discharge should be blanked off.

Existing overboard shell and pierside deck connections should remain for use by the new system.

The pipe tunnel between Engine Room and Hold No. 2 would be used for the piping necessary to pump out the Vacuum Collection Tank.

The G/T drain main in the Engine Room should be run to the G/T Holding Tank in Hold No. 2 via the pipe tunnel.

Vessel: WHITE SAGE (133')

WMS No. 12 JERED Reduced Volume Flush Vacuum Collection/Holding
Tank for Concentrated Black Water/Grumman Flow
Through System with Sludge Holding Tank for Gray Water

	<u>Required</u>
G/T Influent Surge Tank	323 gal. (43 cu. ft.)
Sludge Holding Tank	172 gal. (23 cu. ft.)
Sewage Vacuum Collection Tank	30 gal. (4.4 cu. ft.)
Sewage Holding Tank	200 gal. (27 cu. ft.)
 Grumman Unit	 One (1)

Discussion

The system installation appears to be acceptable subject to certain limitations.

Reuse of existing piping arrangements would have to be considered. A fresh water sanitary flushing system would be required.

The Vacuum Collection Tank, Vacuum equipment, Sewage Holding Tank and sewage overboard pumps could be located in the Engine Room in the area where the existing Collecting Tank is fitted.

The Galley/Turbid Influent Surge Tank and its pump would be located just aft of the aforementioned sewage equipment, also in the Engine Room. This will require minor rearrangement of existing equipment.

The Grumman MSD, Sludge Holding Tank (and its discharge pump) could be located in the Hold No. 2 Storeroom area in where the existing Retention Tank is fitted. Some rearrangement of this compartment may be necessary.

The existing 25 gallon Galley Drain Tank should remain in use and discharge to the Influent Surge Tank. The single drinking fountain drain between Frames 14 and 15 should be connected to the gravity G/T drain to the Influent Surge tank and the independent overboard connection disconnected and blanked off.

Vessel: WHITE SAGE (133')

System No. 12 (Cont'd)

The pipe tunnel between the Engine Room and Hold No. 2 would be used to transfer wastes from the Sludge Holding Tank to the Sewage Holding Tank (for pierside discharge) and from the Sewage Holding Tank to overboard and pierside discharge.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 13 JERED Reduced Volume Flush Vacuum Collection/Grumman
Flow Through System for Gray Water/Incinerator for both
Concentrated Black Water and Gray Water Sludge

Required

Galley/Turbid Surge Tank	323 gal. (43 cu. ft.)
Vacuum Collection Tank	30 gal. (4.4 cu. ft.)
Fuel Oil Day Tank	40 gal. (5.3 cu. ft.)
Grumman Unit	One (1)
Incinerator	One (1) Thiokol

Discussion

The system installation appears acceptable as follows:

Reuse of existing piping arrangements would have to be considered. A fresh water sanitary flushing system would be required for this system.

The Vacuum Collection Tank and vacuum equipment would be located in the Engine Room in the area where the existing 220 gallon Collecting Tank is fitted. The Galley/Turbid Surge Tank and its pump would be located just aft of the Vacuum Collection Tank and equipment. This may require some relocation of existing equipment.

There are two possible locations to be considered for the location of the Grumman MSD and its incinerator. One location would be in the Engine Room just aft of the Vacuum Collection arrangement near the centerline, with its stack going to the weather alongside the existing diesel engine exhausts. The other location would be in Hold No. 2 in the place occupied by the 810 gallon Retention Tank in the storeroom area, with the Incinerator stack running to the weather alongside the kingpost.

There would be some equipment relocations to be considered.

The existing pipe tunnel between the Engine Room and Hold No. 2 would be used for piping runs to overboard and pierside connections and the Grumman MSD, if located in Hold No. 2.

Vessel: WHITE SAGE (133')

System No. 13 (Cont'd)

The existing 25 gallon Galley Drain Tank will remain in use with the pump discharge piping revised to connect to the G/T Surge Tank. The single drinking fountain at frames 14/15 would be reconnected to the gravity G/T drain to the G/T Surge Tank. The overboard discharge should be blanked off.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 14 GATX Reduced Volume Flush M/T Pump Collection/Holding
Tank for Concentrated Black Water/Holding Tank
for Gray Water

Required

Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Sewage Holding Tank	232 gal. (31 cu. ft.)
Discharge Pumps (4)	10 - 30 gpm

Discussion

The system installation appears to be acceptable as follows:

Reuse of existing piping arrangements should be considered. A fresh water flushing system is required for this system.

The Galley/Turbid Holding Tank could be located in the Hold No. 2 Storeroom area in the space presently occupied by the Retention Tank.

The Sewage Holding Tank can be located in the Engine Room in the space now occupied by the Collection Tank.

The existing pipe tunnel between the Engine Room and Hold No. 2 would be used for piping runs to overboard and pierside connections and from G/T Holding Tank to the Sewage Holding Tank.

The existing 25 gallon Galley Drain Tank will remain in use with the pump discharge piping revised to connect to the G/T Holding Tank. The single drinking fountain at frames 14/15 would be reconnected to the gravity G/T drain to the G/T Holding Tank. The overboard discharge should be blanked off.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 15 GATX Reduced Volume Flush M/T Pump Collection/Incinerator
for Concentrated Black Water/Holding Tank for Gray Water

Required

Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Incinerator Feed Tank	50 gal. (6.7 cu. ft.)
Fuel Oil Day Tank	22 gal. (3 cu. ft.)
Incinerator	One (1) Thiokol

Discussion

The system installation appears to be acceptable subject to the following:

Reuse of existing piping arrangements should be considered. A fresh water flushing system is required for this system.

The Galley/Turbid Holding Tank can be located in the Hold No. 2 Store-room area where the existing Retention Tank is located. Minor space rearrangement may be necessary.

The Incinerator, Fuel Oil Day Tank and Incinerator Feed Tank can be installed in the area presently occupied by the Collecting Tank in the Engine Room. Minor equipment rearrangement may be required. Stack can run up the casing.

The pipe tunnel between the Engine Room and Hold No. 2 would be used for piping runs to overboard and plierside connections.

The existing 25 gallon Galley Drain Tank will remain in use with the pump discharge piping revised to connect to the G/T Holding Tank. The single drinking fountain at frames 14/15 would be reconnected to the gravity G/T drain to the G/T Holding Tank. The overboard discharge should be blanked off.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 16 GATX Reduced Volume Flush M/T Pump Collection/GATX
Evaporator for Concentrated Black Water/Holding Tank
for Gray Water

	<u>Required</u>
Galley/Turbid Holding Tank	2,063 gal. (276 cu. ft.)
Catalytic Oxidizer	One (1)
Evaporator (GATX)	One (1) 80 gal.
Discharge Pumps (4)	10 - 30 gpm
Macerator/Transfer Pumps (2)	

Discussion

The system installation appears to be acceptable within certain limitations:

Reuse of existing piping arrangement should be considered. A fresh water flushing system is required for this system.

The Galley/Turbid Holding Tank and pumps can be located in the Hold No. 2 Storeroom area to replace the existing Retention Tank. Minor space rearrangement may be necessary.

The Evaporator, Catalytic Oxidizer and pumps can be installed in the Engine Room in the area where the existing Collecting Tank is located. Minor machinery rearrangement may be required.

The existing pipe tunnel between the Engine Room and Hold No. 2 would be used for piping runs to overboard and pier side connections.

The existing 25 gallon Galley Drain Tank will remain in use with the pump discharge piping revised to connect to the G/T Holding Tank. The overboard discharge should be blanked off.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.

Vessel: WHITE SAGE (133')

WMS No. 17 GATX Reduced Volume Flush M/T Pump Collection/Holding Tank for Concentrated Black Water/Grumman Flow Through System with Sludge Holding Tank for Gray Water

	<u>Required</u>
Sewage Holding Tank	232 gal. (31 cu. ft.)
Influent Surge Tank	323 gal. (43 cu. ft.)
Sludge Holding Tank	172 gal. (23 cu. ft.)
Grumman Unit	One (1)
Macerator/Transfer Pumps (2)	
Discharge Pumps (4)	• 10 - 30 gpm

Discussion

The system installation appears to be acceptable within certain limitations and alternatives:

Reuse of existing piping arrangement should be considered. A fresh water flushing system is required for this system.

In view of the close piping interconnection between the components, and the fact that pierside discharge is via Hold No. 2, it appears advisable to locate the Grumman Unit, Sludge Holding Tank, Sewage Holding Tank and Influent Surge Tank in the Hold No. 2 Storeroom area presently occupied by the Retention Tank. This will probably require minor rearrangement of the space.

An alternate is to locate the Sewage Holding Tank in the Engine Room in the space now filled by the Collection Tank. This will, however, require extra lengths of piping between Hold No. 2 and the Engine Room for Sludge Tank discharge and Influent Tank discharge to the Sewage Tank and Sewage Tank discharge to pierside connections.

The Galley/Turbid drain main in the Engine Room must be led to the Influent Surge Tank in Hold No. 2 via a pipe tunnel through the fuel oil tanks or the void space between the fresh water tanks and the fuel oil tanks (if fitted).

Vessel: WHITE SAGE (133')

System No. 17 (Gal'd)

The existing 25 gallon Galley Drain Tank will remain in use with the pump discharge piping revised to connect to the G/T Surge Tank. The single drinking fountain at frames 14/15 would be reconnected to the gravity G/T drain to the G/T Surge Tank. The overboard discharge should be blanked off.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.

Vessel: WHITE SAGE (133')

**WMS No. 18 GATX Reduced Volume Flush M/T Pump Collection/Grumman
Flow Through System for Gray Water/Incinerator for both
Concentrated Black Water and Gray Water Sludge**

Required

Sewage Surge Tank	43 gal. (5.7 cu. ft.)
Galley/Turbid Surge Tank	323 gal. (43 cu. ft.)
Fuel Oil Day Tank	22 gal. (3.0 cu. ft.)

Grumman Unit	One (1)
Incinerator	One (1) Thiokol

Discussion

The system installation appears to be acceptable as follows:

Reuse of existing piping arrangement should be considered. A fresh water flushing system is required for this system.

The Galley/Turbid Surge Tank and the Sewage Surge Tank can be located in the Engine Room in the space now occupied by the Collecting Tank.

The Grumman Unit, Incinerator and Fuel Oil Day Tank can be located in the Engine Room between Frames 14 and 15, port side near the centerline. This will require the relocation of the Log Desk, Telephone Booth and possibly the Air Conditioning Water Chiller. The incinerator stack could run up the casing to the weather with the existing Diesel engine exhaust piping. In this arrangement, the pipe tunnel between the Engine Room and Hold No. 2 would be used for piping runs to overboard and pierside connections.

An alternate would be to locate the Grumman Unit, Incinerator and Fuel Oil Day Tank in the Hold No. 2 Storeroom area in the space now occupied by the Retention Tank. The stack could be led up the side of the kingpost up to the towing light.

In this arrangement the pipe tunnel would be used for overboard and pierside discharge piping plus feed piping to the Grumman Unit.

Vessel: WHITE SAGE (133')

System No. 18 (Cont'd)

Possibly the best arrangement is to locate all of the equipment in the Hold No. 2 Storeroom area. In this arrangement the separate Sewage and G/T mains must be led from the Engine Room to the Hold No. 2 Storeroom area via the pipe tunnel.

The existing 25 gallon Galley Drain Tank will remain in use with the pump discharge piping revised to connect to the G/T Surge Tank. The single drinking fountain at frames 14/15 would be reconnected to the gravity G/T drain to the G/T Surge Tank. The overboard discharge should be blanked off.

Existing overboard discharge connections and deck discharge connections could be retained for use with the new installation.