AD-A	063 322	A C SEP	AL POST OMPUTER	GRADUA SIMUL P FINI	TE SCH	DOL MON	VAL BO	CALIF			F.	/6 13/1	
	1 OF 2 AD03322						E CONTRACTOR DE LA CONT	in and the second s	100 100 100 100 100 100 100 100	• Mail Manufacture • • • • • • •		C description of a first of a fir	 Transfer Transfer<
A Martin Anna Anna Anna Anna Anna Anna Anna An	1 2000 2 2000	A second			Contraction of the second seco		gaznani.	¹ TATALA TATAL				E CONTRACTOR DE LA CONTRACTÓR DE LA CONT	
Internet of the second			Environmental Second Se	(And a second sec			And And	The second secon			Here and the second sec	
					And a second sec		Harden and Arriver	A start The second sec		A management of the second sec	A CONTRACTOR OF A CONTRACTOR OF A CONTRACTOR OF A CONTRACTOR A CONTRAC		
		1		Real Provide P	%	Ē	12	14	2	°.	1		Å
M	M			0		•	10	2	M	0			Ż
D	4	1	-		M	•	A REAL		F	Lund		Val.	F
A REAL													/





UNCLASSIFT	EI	
------------	----	--

SECURITY CLASSIFICATION OF THIS PAGE (When Date Entered)

REPORT DOCUMENTATION PAGE	BEFORE COMPLETING FORM
REPORT NUMBER 2. GOVT ACCESSION I	NO. 3. RECIPIENT'S CATALOG NUMBER
TITLE (and Subtitio)	S. TYPE OF REPORT & PERIOD COVERED
Computer Simulation of a Naval Boiler	Engineer's Thesis;
	6. PERFORMING ORG. REPORT NUMBER
AUTHOR(a)	S. CONTRACT OR GRANT NUMBER(e)
Wallace Paul Fini	
PERFORMING ORGANIZATION NAME AND ADDRESS	10. PROGRAM ELEMENT, PROJECT, TASK
Naval Postgraduate School	
Monterey, California 93940	
CONTROLLING OFFICE NAME AND ADDRESS	12. REPORT DATE
	September 1978
Naval Postgraduate School	13. NUMBER OF PAGES
MONITORING AGENCY NAME & ADDRESS(I different from Controlling Office) 15. SECURITY CLASS. (of this report)
	Unclassified
	15. DECLASSIFICATION DOWNGRADING
	SCHEDULE
DISTRIBUTION STATEMENT (of the electrons entered in Block 20, If different	n unlimited.
Approved for public release; distribution 7. DISTRIBUTION STATEMENT (of the electrect entered in Block 20, 11 different	n unlimited.
Approved for public release; distribution 7. DISTRIBUTION STATEMENT (of the ebstreet entered in Block 20, 11 different 9. SUPPLEMENTARY NOTES	n unlimited.
Approved for public release; distribution 7. DISTRIBUTION STATEMENT (of the obstreet entered in Block 20, if different 8. SUPPLEMENTARY NOTES	n unlimited.
Approved for public release; distribution 7. DISTRIBUTION STATEMENT (of the abstract entered in Black 20, if different 9. SUPPLEMENTARY NOTES 9. KEY WORDS (Continue on reverse olds if necessary and identify by block manual Navy D-Type Boiler Computer Simulation Naval Poiler	n unlimited.
Approved for public release; distribution DISTRIBUTION STATEMENT (of the ebetrect entered in Block 20, if different SUPPLEMENTARY NOTES KEY WORDS (Continue on reverse olds if necessary and identify by block number Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V=2M Boiley	h unlimited.
Approved for public release; distribution DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different SUPPLEMENTARY NOTES KEY WORDS (Continue on reverse olds if necessary and identify by block manual Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V-2M Boiler ABSTRACT (Continue on reverse olds if necessary and identify by block manual Naval Boiler	h unlimited.
Approved for public release; distribution DISTRIBUTION STATEMENT (of the electroci entered in Block 20, if different SUPPLEMENTARY NOTES KEY WORDS (Continue on reverse olds if necessary and identify by block number Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V-2M Boiler ABSTRACT (Continue on reverse olds if necessary and identify by block number A non-linear computer model of a U.S.	her)
Approved for public release; distribution DISTRIBUTION STATEMENT (of the electroci entered in Block 30, if different SUPPLEMENTARY NOTES KEY WORDS (Continue on reverse elde if necessary and identify by block mass Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V-2M Boiler ASSTRACT (Continue on reverse elde if necessary and identify by block mass A non-linear computer model of a U.S. Soiler was developed using lumped paramet	h unlimited.
Approved for public release; distribution 7. DISTRIBUTION STATEMENT (of the ebstreet entered in Block 20, if different 8. SUPPLEMENTARY NOTES 8. SUPPLEMENTARY NOTES 8. KEY WORDS (Continue on reverse side if necessary and identify by block much Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V-2M Boiler 8. ABSTRACT (Continue on reverse side if necessary and identify by block much 1. ABSTRACT (Continue on reverse side if necessary and identify by block much 1. ABSTRACT (Continue on reverse side if necessary and identify by block much 2. ABSTRACT (Continue on reverse side if necessary and identify by block much 2. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if necessary and identify by block much 3. ABSTRACT (Continue on reverse side if n	her) Navy D-Type ers. The program yuage. A companion
Approved for public release; distribution T. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different SUPPLEMENTARY NOTES . SUPPLEMENTARY NOTES . KEY WORDS (Continue on correct oids if necessary and identify by block number Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V-2M Boiler . ABSTRACT (Continue on correct oids if necessary and identify by block number A non-linear computer model of a U.S. Noiler was developed using lumped parameter as coded in IBM CSMP-III simulation langer Outine was also coded to permit the user	n unlimited.
Approved for public release; distribution T. DISTRIBUTION STATEMENT (of the obstreet entered in Block 20, if different B. SUPPLEMENTARY NOTES E. SUPPLEMENTARY NOTES E. KEY WORDS (Continue on reverse olds if necessary and identify by block music Navy D-Type Boiler Computer Simulation Naval Boiler Combustion Engineering Type V-2M Boiler D. ASSTRACT (Continue on reverse olds if necessary and identify by block music A non-linear computer model of a U.S. Boiler was developed using lumped paramet vas coded in IBM CSMP-III simulation lang Coutine was also coded to permit the user D. 1007-014-0001	n unlimited. Tree Report) her; Navy D-Type ers. The program uage. A companion to implement the CLASSIFIED

UNCLASSIFIED

SUCUMTY CLASSIFICATION OF THIS PAGE/When Date Entered.

(20. ABSTRACT Continued)

4 model for a particular boiler using only readily accessible data. The model was adapted for a Combustion Engineering Type V-2M boiler for analysis.



DD Form 1473 5/N 0102-014-6601 Approved for public release; distribution unlimited

A Computer Simulation of a Naval Boiler

by

Wallace Paul Fini Lieutenant Commander, United States Navy B.S.E.E., Worcester Polytechnic Institute, 1967

Submitted in partial fulfillment of the requirements for the degrees of

MASTER OF SCIENCE IN MECHANICAL ENGINEERING

and

MECHANICAL ENGINEER

from the

NAVAL POSTGRADUATE SCHOOL September 1978

allace Approved by: Thesis Advisor Chairm hanical Engineering 01 Science and Engineering

3

01 15

Author

ABSTRACT

A non-linear computer model of a U.S. Navy D-Type boiler was developed using lumped parameters. The program was coded in IBM CSMP-III simulation language. A companion routine was also coded to permit the user to implement the model for a particular boiler using only readily accessible data. The model was adapted for a Combustion Engineering Type V-2M boiler for analysis.

A STATE AND A STAT

TABLE OF CONTENTS

I.	INTRODUCTION	17
11.	DESIGN CONSIDERATIONS	20
	A. D-TYPE BOILER	20
	B. MODEL FLEXIBILITY	21
	C. ASSUMPTIONS	22
111.	MODEL ANALYSIS	24
	A. GENERAL	24
	B. FLUE GAS AND COMBUSTION SYSTEM	24
	C. WATER-STEAM CIRCULATION SYSTEM	27
	D. WATER-STEAM HEAT TRANSFER	33
	1. Risers	33
	2. Desuperheater	34
	3. Economizer	35
	4. Superheater	35
	E. PRESSURE DROP CALCULATIONS	36
	F. EQUATIONS OF STATE	38
IV.	DETERMINATIONS OF CONSTANTS AND INITIAL CONDITIONS	39
	A. GENERAL	39
	B. PROGRAM EQUATIONS	40
	C. CIRCULATION BALANCE	47
v.	RESULTS AND CONCLUSIONS	51
	A. OPEN LOOP RESPONSES	51
	B. CONCLUSIONS	54
VI.	FIGURES	56

APPENDI	CA. INTERFACE PROGRAM LISTING AND SAMPLE OUTPUT	89
LIST OF	REFERENCES	99
INITIAL	DISTRIBUTION LIST	101

LIST OF FIGURES

1.	Simplified Boiler Schematic	56
2.	Combustion Engineering Type V-2M Boiler	57
3.	Control Volume Arrangement	58
4.	Flue Gas and Combustion Schematic	59
5.	Basic Circulation System	60
6.	Water Level Response to a 10% Increase in Throttle Setting	61
7.	Drum Pressure Response to a 10% Increase in Throttle Setting	62
8.	Steam Flow Rate Response to a 10% Increase in Throttle Setting	63
9.	Main Bank Circulation Response to a 10% Increase in Throttle Setting	64
10.	Screen Circulation Response to a 10% Increase in Throttle Setting	65
11.	Riser Exit Quality Response to a 10% Increase in Throttle Setting	66
12.	Average Riser Density Response to a 10% Increase in Throttle Setting	67
13.	Water Level Response to a 10% Decrease in Throttle Setting	68
14.	Drum Pressure Response to a 10% Decrease in Throttle Setting	69
15.	Steam Flow Rate Response to a 10% Decrease in Throttle Setting	70
16.	Main Bank Circulation Response to a 10% Decrease in Throttle Setting	71
17.	Screen Circulation Response to a 10% Decrease in Throttle Setting	72
18.	Riser Exit Quality Response to a 10% Decrease in Throttle Setting	73

and the state

19.	Average Riser Density Response to a 10% Decrease in Throttle Setting	74
20.	Water Level Response to a 10% Increase in Fuel Flow	75
21.	Drum Pressure Response to a 10% Increase in Fuel Flow	76
22.	Steam Flow Rate Response to a 10% Increase in Fuel Flow	77
23.	Main Bank Circulation Response to a 10% Increase in Fuel Flow	78
24.	Screen Circulation Response to a 10% Increase in Fuel Flow	79
25.	Riser Exit Quality Response to a 10% Increase in Fuel Flow	80
26.	Average Riser Density Response to a 10% Increase in Fuel Flow	81
27.	Water Level Response to a 10% Decrease in Fuel Flow	82
28.	Drum Pressure Response to a 10% Decrease in Fuel Flow	83
29.	Steam Flow Rate Response to a 10% Decrease in Fuel Flow	84
30.	Main Bank Circulation Response to a 10% Decrease in Fuel Flow	85
31.	Screen Circulation Response to a 10% Decrease in Fuel Flow	86
32.	Riser Exit Quality Response to a 10% Decrease in Fuel Flow	87
33.	Average Riser Density Response to a	88

NOMENCLATURE

English Symbols

A	-	Area (ft ²)
Adr	-	Drum Downcomer Total Cross Sectional Area (ft ²)
Ads	-	Header Downcomer Total Cross Sectional Area (ft ²)
AMB	-	Main Bank Heat Transfer Surface Area (ft ²)
A _r	-	Main Bank Riser Total Cross Sectional Area (ft ²)
As	-	Screen Riser Total Cross Sectional Area (ft ²)
Be	-	Becker's Factor
с	-	A General Constant
Cl	-	Specific Heat of Liquid (Btu/lbm/°F)
C _m	-	Specific Heat of Tube Metal (Btu/lbm/°F)
cp	-	Specific Heat (Btu/lbm/°F)
CRI	-	Specific Heat of Flue Gas in the Furnace (Btu/lbm/°F)
C _{Rla}	-	Specific Heat of Flue Gas at the Furnace Exit (Btu/lbm/°F)
C _{R2}	-	Specific Heat of Flue Gas at Superheater Exit (Btu/lbm/°F)
C _{R3}	-	Specific Heat of Flue Gas at Main Bank Exit (Btu/lbm/°F)
C _{st}	-	Constant used in Rohsenow Correlation
c3-c11	-	Constants Used in Various Equations
đ	-	Diameter (ft)
D _{dr}	-	Sum of the Diameters of the Drum Downcomers (ft)
Dds	-	Sum of the Diameters of the Screen Downcomers

Sec.

Dr	-	Sum of the Diameters of the Main Bank Tubes (ft)
D _s	-	Sum of the Diameters of the Screen Tubes (ft)
EB	-	Total Heat Input to the Furnace (Btu/sec)
ED1	-	Heat Transferred from the Desuperheated Steam to the Tubes (Btu/sec)
ED2	-	Heat Transferred from the Superheater Tubes to the Steam (Btu/sec)
ERl	-	Heat Transfer Rate from the Flue Gas to the Screen Tubes (Btu/sec)
ER2	-	Heat Transfer Rate from the Flue Gas to the Superheater (Btu/sec)
ER3	-	Heat Transfer Rate from the Flue Gas to the Main Bank (Btu/sec)
ER4	-	Heat Transfer Rate from the Flue Gas to the Economizer (Btu/sec)
Ewr	-	Heat Transfer Rate to the Riser Liquid (Btu/sec)
EW1	-	Heat Transfer Rate from the Economizer Tubes to the Feed Water (Btu/sec)
EW2	-	Heat Transfer Rate from the Desuperheater Tubes to the Drum (Btu/sec)
EW3	-	Heat Transfer Rate to the Screen Riser Liquid (Btu/sec)
EW4	-	Heat Transfer Rate to the Main Bank Riser Liquid (Btu/sec)
f	-	Friction Factor
Fdr	-	Drum Downcomer Friction Factor
Fds	-	Heater Downcomer Friction Factor
Fr	-	Main Bank Riser Friction Factor
Fs	-	Screen Riser Friction Factor
g	-	Acceleration of Gravity - 32.2 ft/sec ²
G	-	Mass Flow Rate (1bm/sec)

GB	-	Fuel Flow Rate (lbm/sec)
GD1	-	Total Steam Flow Rate from Boiler (lbm/sec)
GD2	-	Desuperheated Steam Flow Rate (lbm/sec)
GD3	-	Steam Condensing from Vapor to Liquid in the Steam Drum (1bm/sec)
GD4	-	Superheated Steam Flow (lbm/sec)
GL	-	Air Mass Flow Rate (1bm/sec)
GR	-	Total Flue Gas Flow Rate (lbm/sec)
GS	-	Screen Riser Circulation Flow Rate (1bm/sec)
Gr	-	Riser Circulation Flow Rate (lbm/sec)
Gw	-	Downcomer Circulation Flow Rate (lbm/sec)
Gø	-	Main Bank Riser Mass Flow Rate (1bm/sec)
Gwr	-	Drum Downcomer Circulation Flow Rate (lbm/sec)
Gws	-	Header Downcomer Circulation Flow Rate (1bm/sec)
HD1	-	Enthalpy of Saturated Steam (Btu/lbm)
Hfg	-	Heat of Vaporization (Btu/lbm)
Но	-	Heating Value of Fuel Oil (Btu/lbm)
HNB	-	Non-boiling Height (ft)
HNBR	-	Main Bank Riser Non-boiling Height (ft)
HNBS	-	Screen Riser Non-boiling height (ft)
HWl	-	Enthalpy of Saturated Water (Btu/lbm)
HW2	-	Enthalpy of Downcomer Liquid (Btu/1bm)
HW3	-	Enthalpy of Feed at Economizer Inlet (Btu/lbm)
HW4	-	Enthalpy of Feed at Economizer Outlet (Btu/lbm)
HW6	-	Enthalpy of Water in Lower Drum (Btu/lbm)

Hxr	-	Effective Height of Main Bank/Drum Downcomer Circuit (ft)
Hxs	-	Effective Height of Screen/Header Downcomer Circuit (ft)
k	-	Thermal Conductivity (Btu/hr-ft-°F)
К	-	a general constant
Ks	-	Equivalent Sand Roughness (in)
KR1-KR4	-	Constants Used in the Gas Heat Transfer Equations
l.	-	Length (ft)
L	-	Tube Length (ft)
LB	-	Boiling Length (ft)
Ldr	-	Total Length of Drum Downcomer Tubes (ft)
Lds	-	Total Length of Header Downcomer Tubes (ft)
Ldlr	-	Avg. Length of Drum Downcomer Tubes (ft)
Ldls	-	Avg. Length of Header Downcomer Tubes (ft)
Lr	-	Total Length of Main Bank Tubes (ft)
Lrl	-	Avg. Length of Main Bank Tubes (ft)
Ls	-	Total Length of Screen Tubes (ft)
Lsl	-	Avg. Length of Screen Tubes (ft)
LMTD	-	Log Mean Temperature Difference (°F)
м	-	Mass (1bm)
MM1	-	Mass of Screen Tube Metal (1bm)
MM2	-	Mass of Superheater Tube Metal (1bm)
ммз	-	Mass of Riser Tube Metal (1bm)
MM4	-	Mass of Economizer Tube Metal (1bm)
MM5	-	Mass of Desuperheater Tube Metal (1bm)
MR1	-	Mass of Flue Gas in Furnace (1bm)
MW1	-	Mass of Water in Steam Drum (1bm)

Р	-	Pressure (psia)
PD	-	Pressure of Steam Volume in Steam Drum (psi)
PD1	-	Saturation Pressure Corresponding to Enthalpy of Water in the Steam Drum (psi)
PD2	-	Pressure at Superheater Outlet (psia)
PD2	-	Pressure at Desuperheater Outlet (psia)
Pr	-	Prandtl Number
Psat	-	Saturation Pressure (psia)
PW1	-	Pressure in Water Drum (psi)
PW2	-	Pressure in Screen Header (psi)
q	-	Heat Transfer Rate (Btu/sec)
R	-	Tube Radius (in)
Ral	-	Average Density in the Main Bank Risers (lbm/ft ³)
Ra2	-	Average Density in the Screen Risers (1bm/ft ³)
RD1	-	Density of Saturated Steam (1bm/ft ³)
Re	-	Reynolds Number
RW	-	Density of Saturated Water (lbm/ft ³)
RS	-	Density of Two-Phase Mixture at Screen Outlet (lbm/ft ³)
Rø	-	Density of Two ₃ Phase Mixture at Main Bank Outlet (lbm/ft ³)
t	-	Time (sec)
T	-	Temperature (°F)
Tsat	-	Saturation Temperature (°F)
TD	-	Temperature of Steam Drum Vapor (°F)
TD1	-	Temperature of Saturated Steam Corresponding to Drum Enthalpy (°F)
TD2	-	Superheater Outlet Temperature (°F)

TD3	-	Desuperheater Outlet Temperature (°F)	
TMl	-	Screen Metal Temperature (°F)	
TM2	-	Superheater Metal Temperature (°F)	
тмз	-	Main Bank Metal Temperature (°F)	
TM4	-	Economizer Metal Temperature (°F)	
TM5	-	Desuperheater Metal Temperature (°F)	
TRL	-	Temperature of Flue Gas in Furnace (°F)	
TR2	-	Temperature of Flue Gas Leaving Furnace (°F)	
TR3	-	Temperature of Flue Gas Leaving Superheater (°F)	
TR4	-	Temperature of Flue Gas Leaving Main Bank (°F)	
TR5	-	Temperature of Flue Gas Leaving Economizer (°F)	
TRa2	-	Average Flue Gas Temperature Across the Superheater (°F)	
TRa3	-	Average Flue Gas Temperature Across the Main Bank (°F)	
TRa4	-	Average Flue Gas Temperature Across the Economizer (°F)	
TW3	-	Feed Inlet Temperature (°F)	
TW4	-	Feed Outlet Temperature (°F)	
То	-	Ambient Temperature	
U,	-	Bubble Rise Velocity (ft/sec)	
Um		Mean Velocity (ft/sec)	
v	-	Volume (ft ³)	
VB	-	Boiling Volume (ft ³)	
VD1	-	Volume of Steam in Steam Drum (ft ³)	
VENT	-	Percent Throttle Valve Opening	
VNDR	-	Water Drum Volume (ft ³)	
VR	-	Main Riser Bank Fluid Volume (ft ³)	
VS	-	Screen Riser Bank Fluid Volume (ft ³)	

and in

v -	Specific Volume (ft ³ /1bm)
x -	Quality (percent)
Xø –	Quality at Main Bank Riser Outlet (percent)
Xs -	Quality at Screen Riser Outlet (percent)
Xe -	Quality at Riser Exit (percent)
z1 -	Drum Downcomer Bend Loss Factor
z2 -	Drum Downcomer Exit Loss Factor
z3 -	Main Bank Riser Bend Loss Factor
z4 -	Main Bank Riser Exit Loss Factor
z5 -	Screen Riser Bend Loss Factor
Z6 -	Screen Riser Exit Loss Factor
27 -	Header Downcomer Bend Loss Factor
z8 -	Header Downcomer Exit Loss Factor

Greek Letters

μ	- Viscosity (lbm/ft-sec)
ρ	- Density (lbm/ft ³)
σ	- Surface Tension (lbf/ft)
⁰ Dal	- Average Density in Superheater (lbm/ft ³)
^p Da2	- Average Density in Desuperheater (lbm/ft ³)

Subscripts

a	-	Average
l,f	-	Liquid
g	-	Vapor
M.m	-	Metal

80	-	Far Field Average
r	-	Main Bank
s	-	Screen
dr	-	Drum Downcomer
ds	-	Header Downcomer
D	-	Steam
R	-	Flue Gas
W	-	Water

I. INTRODUCTION

The increasing attractiveness and efficiency of computeraided design techniques have established a need for reasonably accurate computer models of all types of engineering systems. The design of multivariable controllers, in particular, requires the availability of state information about a system which is not available from conventional transfer function simulations. A number of computer models of marine boilers have been proposed [1,2,3,4]. All of these efforts share one or more of the following features:

- a. Lumped parameters are used.
- Bubble formation effects with respect to shrink and swell are not modeled.
- c. The furnace screen and main riser bank are lumped together as are their respective downcomers [1,3,4].
- d. The model is linearized using a Taylor expansion or perturbation technique [3].

Use of lumped parameters is dictated by the need to maintain computational efficiency, particularly when the model is used in control system design and optimization schemes. In the past, effects due to vapor formation in the drum have not been included due to the lack of a suitable model. A simple model based on the Rohsenow correlation [5] was developed for use in the current simulation. However, its contribution to shrink and swell effects was negligible and

it was eliminated from the equation set. Regarding the tube banks, Haraguchi and Akasara [2] split out the various riser and downcomer loops, including intermediate headers. Considering the general level of uncertainty inherent in the correlations used in this model, this appears to be an excessive degree of complication. A compromise position was taken in the present effort in that the screen and main riser bank and their associated downcomers were modeled separately, but intermediate headers within the screen circuit were not addressed individually since their configuration varies widely from one boiler to another.

The objective of this thesis was to develop a general, non-linear model of a Navy boiler for use in simulations covering the full operating range of the propulsion plant. However, since a linearized version is normally needed for multivariable controller design, CENTRL, a computer code developed locally for use with CSMP models, could be used to generate linearized state space representations described by the matrix equations:

 ${\dot{x}} = [A] {\Delta x} + [B] {\Delta u} {\Delta u} {\Delta u} = [C] {\Delta x} + [D] {\Delta u}$

This approach would produce linearized representations covering the entire boiler operating range in a piecewise

fashion, rather than attempting to extend the range of applicability of a single state space or linear model.

Since this author found the notation used in Reference [1] particularly readable, it was adopted for use in this document.

. . .

II. DESIGN CONSIDERATIONS

A. D-TYPE BOILER

The single furnace (D-Type), uncontrolled-superheat boiler was chosen as the basis for the model since it is the predominant design in the current U.S. Navy inventory. The nominal operating pressures range from 600 to 1200 psi, and all designs are conceptually similar. A basic schematic is shown in Figure 1. These boilers are typified by relatively fast response times for use in high speed maneuvering vessels. This puts heavy emphasis on properly designed control systems. Manual control of these boilers is essentially infeasible except under the most favorable circumstances, e.g. steady steaming at low speeds. Current conventional control systems used by the Navy are of the same generic type with relatively minor customization except in hardware from one installation to the next. These designs have been based on analog models intended to provide reasonable dynamic responses for pressure, water level, and steam flow which are the only state parameters measured by conventional controllers. Although these control systems have in general proven satisfactory, there is some indication [6] that multivariable control systems can effect significant improvement in both response time and demands on auxiliary equipment.

A typical boiler of this type, the Combustion Engineering Type V-2M is shown in Figure 2. The main components of the boiler are the furnace which is surrounded on all sides except the floor by screen tubes, the superheater, main riser banks, economizer, water drum, steam drum, desuperheater, downcomers, and screen headers. Navy boilers do not include air heaters and the only air preheating which occurs is accomplished by passing the incoming air over the exhaust stack liner. This procedure generally produces an air temperature of about 100-130°F for an ambient of 70°F. In contrast to the boilers used as the basis for previous models, the desuperheater is located in the water drum rather than in the steam drum. All of the steam generated passes through the superheater prior to being split out as main superheated steam and auxiliary desuperheated steam.

All of these boilers are of the natural circulation type. The "throttle valve" was considered to be in the superheated main steam line.

B. MODEL FLEXIBILITY

The model was designed to be as flexible as possible to permit its relatively simple adaptation to a particular boiler. Since the boiler technical manual or equivalent, the steam and gas tables, and standard engineering handbooks may be presumed to be available, the model was designed to utilize data only from these sources for implementation.

To convert this input data into the form required by the model, an interface program was developed to adjust parameters and determine initial conditions at the operating point for which the input data were extracted. This approach was taken to avoid the necessity of redesigning the model for each operating range or specific boiler design being considered.

C. ASSUMPTIONS

To permit tractable computation, a number of simplifying assumptions were made in the formulation of the model:

- Feed water entering the drum mixes thoroughly with the drum liquid.
- 2. No steam generation occurs in the steam drum except through mass transfer at the water-vapor interface.
- There is a uniform distribution of heat flux in the generating tubes.
- The mixture of steam and water in the generating tubes is homogeneous.
- 5. Quality varies linearly in the generating tubes.
- Heat losses to the ambient except through the exhaust gases are neglected.
- 7. All downcomers and risers in a particular circuit have the same length as the average length, and the shapes and diameters are equal. Also the number of tubes is the same as in the actual boiler.
- 8. The slip ratio is 1.0 (no slip).

Since the feed enters through a long, horizontal feed pipe, and the drum liquid is in a state of turbulence, the first assumption is well justified. Although the second assumption is not strictly correct during transients when there is a significant change in drum pressure, and hence saturation temperature, the effect of steam generated at the drum wall-liquid interface appears to be negligible based on an analysis of this factor in connection with this study. The assumption of uniform heat flux is recommended by Reference [7] as a reasonable alternative to a stepwise integration over the tube height. The assumption of a linear change in quality is a consequence of the assumption of a linear heat load. For a well designed boiler, heat losses through the casing are small compared to the total energy generated. The effects of any such losses will be reflected in small errors in the computed heat capacities of the gas and in the heat transfer coefficients. The assumptions regarding tube geometry are made primarily for computational simplification. The last assumption regarding slip is not an essential one, and higher slip ratios could easily be considered if necessary to the analysis of a particular boiler design. In addition to these explicitly stated assumptions, those inherent in the correlations employed in the model formulation are also considered to have been made.

III. MODEL ANALYSIS

A. GENERAL

The model was envisioned as an assemblage of control volumes for which the rates of energy transfer are described by appropriate equations to obtain the rate of change of energy storage. The resulting differential equations were integrated to obtain the "state" of the system. In this way, the states can be chosen to have specific physical interpretations. The system is shown diagrammatically in Figure 3.

The following control volumes were considered in the model formulation:

- 1. Riser tube walls
- 2. Superheater tube walls
- 3. Economizer mass
- 4. Desuperheater tube walls
- 5. Riser fluid (kinetic energy)
- 6. Riser fluid (thermal energy)
- 7. Steam drum water volume
- 8. Steam drum steam volume
- 9. Water drum
- 10. Furnace

B. FLUE GAS AND COMBUSTION SYSTEM

The flue gas and combustion system is shown schematically in Figure 4. Heat is carried into the furnace through the

sensible heat of the air and fuel, and the heat released in combustion. Since the fuel-air ratio is relatively constant, and the fuel and air have relatively constant inlet temperatures, the sensible heats were lumped with the heating value of the fuel. The mass flow rate into the furnace is given by

and the total heat input is

The heat transfer to the furnace screen is primarily through radiation, i.e.,

$$E_{R1} = K_{R1} \left\{ \left(\frac{T_{R1} + 460}{100} \right)^{4} - \left(\frac{T_{M1} + 460}{100} \right)^{4} \right\}$$

The heat balance for the mass of flue gas in the furnace is

where the last term represents the heat carried off by the flue gas. Heat transfer to the remaining tube banks is primarily through convection. The heat given up by the flue gas is given by the general relation

8 5as - M CP AT

and the heat transfer to the tubes may be estimated with the Grimson Correlation [8]

Since the physical properties in the above equation do not change significantly over the expected range of temperature variations, the correlation is used in the form

Since the tube geometry is not known in advance, an n = 0.6 was used as a reasonable average for most geometries found in practice. The equations for the tube banks were:

1. Superheater

 $ER_{2} = G_{R} C_{R1a} (T_{R2} - T_{R1})$ $ER_{2} = K_{R2} G_{R}^{.6} (T_{Ra2} - T_{M2})$ $T_{Ra2} = (T_{R2} + T_{R3}) / 2.0$

2. Main Bank

$$E_{R3} = G_R C_{R2} (T_{R3} - T_{R4})$$

 $E_{R3} = K_{R3} G_R^{6} (T_{Ra3} - T_{M3})$
 $T_{Ra3} = (T_{R3} + T_{R4}) / 2.0$

3. Economizer

$$E_{RY} = G_R C_{R3} (T_{RY} - T_{RS})$$

$$E_{R4} = K_{R4} G_R^{6} (T_{RA4} - T_{M4})$$

$$T_{RA4} = (T_{R4} + T_{RS}) / 2.0$$

The arithmetic average temperature for the gas was used in the driving potential ΔT rather than the log mean temperature differences (LMTD), because a comparison of the results obtained for the two methods indicated the differences were slight for the temperatures involved and the simpler average was more computationally efficient.

C. WATER-STEAM CIRCULATION SYSTEM

As is shown in Figure 5, the basic circulation system consists of the steam drum, water drum or header, and the riser and downcomer tubes. The driving force for circulation

is the difference in density between the riser and downcomer loops. The pressure loss around the circuit balances this driving force. For the downcomers, the force balance is

$$Pw1 - Po1 = Rwg Hxr - (FJr \frac{Ldr}{Dyr} + Z_1 + Z_2 + 1) \frac{Gwr^2}{2AJr^2 Rw}$$

for the drum downcomers, and

$$Pw_2 - P_{D1} = Rwg Hxs - (F_{Js} \frac{Lds}{D_{Js}} + Z_7 + Z_8 + 2) \frac{Gws^2}{2A_{Js}^2 Rw}$$

for the screen downcomer.

For the risers, the equations are:

$$P_{w1} - P_{b1} = \left(F_r \frac{L_r}{D_r} + 1\right) \frac{G_o^2 R_{a1}}{J A_r^2 R_o^2} + Z_s \frac{G_w r^2}{2 A_r^2 R_w} + Z_y \frac{G_o^2}{2 A_r^2 R_o} + R_{a1} g H_{xr} + R_{a1} \frac{L_{rs}}{A_r} \frac{J}{J_t} \left(\frac{G_o}{R_o}\right)$$

$$P_{w2} - P_{D1} = (F_{s} \frac{L_{s}}{D_{s}} + 1) \frac{G_{s}^{2} R_{a2}}{2A_{s}^{2} R_{s}^{2}} + Z_{s} \frac{G_{ws}^{2}}{2A_{s}^{2} R_{w}} + Z_{b} \frac{G_{s}^{2}}{2A_{s}^{2} R_{s}} + Ra_{2} \frac{G_{s}}{A_{s}} \frac{G_{s}}{R_{s}} + Ra_{2} \frac{G_{s}}{A_{s}} \frac{d}{dt} \left(\frac{G_{s}}{R_{s}}\right)$$

for the screen and main bank, respectively. The friction factors are calculated from [9]

$$\frac{f}{f} = \left[\frac{1}{(1.74 - 2\log^2 R/k_a)}\right]$$

The friction factors for the risers are multiplied by Becker's factor [10] to account for two-phase effects

$$B_e = 1 + 16078.58 \left(\frac{X}{P_{D1}}\right)^{.96}$$

The relationship between riser and downcomer mass flow rates is given by the continuity equation

The average density in the risers is found from

$$f_{av} = \frac{1}{L} \left[\int_{H_{NB}} f(l) \, dl + f_{W} \, H_{NB} \right]$$

From the assumption that the quality varies linearly, the density may be obtained as a function of ℓ from

$$f(l) = \frac{1}{V_f + \frac{X_e}{L_B} (l - H_{N_e}) V_{fg}} \quad H_{N_B} \leq l \leq L$$

Regrouping the terms we get

$$f(t) = \frac{1}{\left(v_{f} - \frac{v_{e}}{v_{e}} + w_{e} v_{fg}\right) + \frac{v_{e}}{v_{e}} v_{fg} t}$$

This expression can be integrated in closed form to yield

$$\int_{HHB}^{L} P(L) dL = \frac{L_B}{X_e V_{fg}} \ln \left[\frac{\frac{X_a L}{L_B} V_{fg} + V_f - \frac{X_e}{L_B} H_{HB} V_{fg}}{\frac{X_e H_{HB} V_{fg} + V_f - \frac{X_e}{L_B} H_{HB} V_{fg}} \right]$$

Combining terms and simplifying finally yields

$$\int_{Hus}^{L} P(l) dl = \frac{Ls}{X_c V_{fg}} \ln \left[\frac{X_c V_{fg}}{V_f} + 1 \right]$$

From this result, ρ_{av} is obtained as

$$P_{av} = \frac{1}{L} \left[\frac{L_{B}}{X_{e} v_{fg}} \ln \left[\frac{X_{e} V_{fg}}{V_{f}} + 1 \right] + P_{w} H_{He} \right]$$

An energy balance on the riser tube banks yields the quality

$$\frac{d}{dt} \left\{ \int_{av} \left(Hw_1 + \frac{\chi_e}{2} H_{fg} \right) \right\} V_8$$

= Gw Hw_1 - Gr (Hw_1 + Xe Hfg) + Ewr - Gw (Hw_1 - Hwr)

where VB is the boiling volume, and the last term on the right accounts for heat added in the non-boiling height to raise the enthalpy to saturated conditions.

The non-boiling height is obtained from

$$H_{NO} = L \frac{9_{s}}{9_{*}}$$

where q_s is the sensible heat added to the liquid in the non-boiling height, and q_t is the total heat input. The ratio q_s/q_t is given by

Hws - Hwr (Hws + Xe Hfg) - Hwr

The boiling volume is related to the non-boiling height by

$$V_B = \frac{L - H_{NB}}{L} V$$

With substitution of the appropriate parameters, the above equations were applied to both circulation loops.

The mass balance of the water in the steam drum is

$$\frac{dMws}{dt} = Go(1-X_0) + Gs(1-X_s) + Gos + Gwa - Gwr - Gws$$

and the energy balance is given by

$$\frac{d}{dt} (Hws Mws) = Go (1-X_0) Hws + Gs (1-X_s) Hws + Gos Htg + Gwz Hwq - Gwr Hws - Gws Hws$$

Since all the incoming feed must be passed through the riser tubes to be heated, an energy balance on the downcomers gives

$$Gw_{2} Hw_{4} + (Gw_{7} + Gw_{8} - Gw_{2})Hw_{1}$$

$$= (Gw_{7} + Gw_{8})Hw_{2}$$

$$Gw_{2} (Hw_{4} - Hw_{1}) + (Gw_{7} + Gw_{8})Hw_{1}$$

$$= (Gw_{7} + Gw_{8})Hw_{2}$$

Solving for HW2, the downcomer enthalpy, we obtain

$$Hw_2 = \frac{Gw_2}{Gw_r + Gw_s} (Hw_4 - Hw_1) + Hw_1$$

D. WATER-STEAM HEAT TRANSFER

1. Risers

The heat transferred to the riser tubers is used to bring the incoming flow to saturation conditions in the non-boiling height, and then generate steam in the remaining portion of the tube. To permit a tractable equation set, however, the tube walls were assumed to be at a uniform temperature, and all the heat was assumed to have been transferred under fully developed flow boiling conditions. Since the non-boiling height for the main bank was found to be small, the assumption was reasonable for that circuit. The non-boiling heights were higher in the screen circuit; however, the error in temperature introduced was less than three percent which was deemed an acceptable level. For fully developed flow boiling, Tong [11] recommends

$$q = \frac{A P_{sat}}{1.782 \times 10^6} \Delta T_{sat}^3$$

Therefore the heat transfer to the risers was given by

 $Ews = Kws Poi^{4/3} (Tmi - Toi)^3$ $Ewy = Kwy Poi^{4/3} (Tmi - Toi)^3$

The tube metal temperatures were obtained from an energy balance,
for the screen, and for the main bank

$$\mathsf{Mms}\,\mathsf{Cm}\,\frac{\mathsf{d}\,\mathsf{Tms}}{\mathsf{d}\,\mathsf{t}}=\mathsf{Ers}-\mathsf{Ewq}$$

2. Desuperheater

The Dittus-Boelter correlation [12] was used to determine the heat transfer from the steam to the tubes, i.e.,

The log mean temperature difference was

$$MTD = \frac{(T_{D2} - T_{D3})}{\ln \left[\frac{(T_{D2} - T_{MS})}{(T_{D3} - T_{MS})}\right]}$$

The energy given up by the steam was obtained from

The heat transfer to the water in the drum was

The metal temperature was obtained from the energy balance

. . .

$$\mathsf{Mms}\,\mathsf{Cm}\frac{\mathsf{d}\mathsf{Tm}\mathsf{s}}{\mathsf{d}\mathsf{t}}=\mathsf{E}\mathsf{D}_2-\mathsf{E}\mathsf{w}\mathsf{z}$$

3. Economizer

The Dittus-Boelter correlation gives the heat transfer from the tubes to the water as

$$LMTD = \frac{Twy - Tw3}{\ln\left\{\frac{Tmy - Tw3}{Tmy - Tw4}\right\}}$$

The heat absorbed by the water was

4. Superheater

The heat transfer to the steam was given by

and the heat transferred from the metal in the tubes was

 $LMTD = \frac{T_{D2} - T_{D1}}{ln \left[\frac{T_{M2} - T_{D2}}{T_{M2} - T_{D2}} \right]}$

The metal temperature was found from

$$Mm_2 Cm \frac{dTm_2}{dt} = ER2 - E01$$

E. PRESSURE DROP CALCULATIONS

For turbulent tube flow, the pressure drop is given by

$$\Delta P = f \frac{1}{6} gar \frac{Um^2}{2gc}$$

Now

SO

$$\Delta P = f \frac{1}{6} \frac{G^2}{A^2} \frac{G^2}{Pau}$$

Lumping the constants we get

$$\Delta P = C \frac{G^2}{P_{av}}$$

Therefore the pressure drops in the superheater and desuperheater were given by

$$P_{01} - P_{02} = C_{\gamma} \frac{G_{01}^2}{P_{01}}$$

and

The average densities were found from the ideal gas law under the assumption that the temperature variation can be neglected, i.e., density is a function of pressure only. This assumption is motivated solely by the need for computational efficiency. It is reasonable for the desuperheater since the temperature excursions there are small. Although errors are larger for the superheater density values, they are still within accuracy overall limits for the model. The flow through the throttle value was given by

GOY = C3 PO2 VENT

F. EQUATIONS OF STATE

The following equations, obtained from Reference [13], were used to determine state properties. Within the range of pressures for which the model is valid (300-1500 psi), the results were within a few percent of tabular values in the worst case.

$$P_{sat} = Exp \left\{ (\ln H_{sat} - 4.4670B) / .26452 \right\}$$

$$T_{sat} = Exp \left\{ .22151 \ln P_{sat} + 4.77123 \right\}$$

$$P_{f} = 63.8 - 0.01781 T_{sat} + 1.132 E - 5 T_{sat}^{2}$$

$$- 6.786 E - 8 T_{sat}^{3}$$

$$V_{fg} = 524 / P_{sat} - 0.1$$

$$h_{fg} = 922.13 - .40516 P_{sat} + 1.717 E - 4 P_{sat}^{2}$$

$$- 4.219 E - 8 P_{sat}^{3}$$

IV. DETERMINATION OF CONSTANTS AND INITIAL CONDITIONS

A. GENERAL

For the model to be useful, it should be possible to obtain the necessary constants and initial conditions from the data supplied in the boiler Technical Manual augmented with reasonable engineering estimates and tabular data from standard handbooks.

The primary items of interest are heat transfer coefficients and initial conditions such as steam flow rates, inlet and outlet temperatures, circulation rates, etc. While some of these were directly obtainable from the boiler Technical Manual, others such as tube wall temperatures and riser exit quality were not. Therefore, a program was developed to permit the user to enter known data elements from the Technical Manual and other sources, and to obtain as an output the necessary values for the constants and initial conditions to ensure static balance at the specified operating point.

The basic premise under which the program operates is that the model equations with all derivatives set to zero form a determinant set with the addition of several relations which apply under equilibrium conditions. These relations are:

a. Riser and downcomer mass flow rates in each circuit are equal.

b. Total steam flow from the boiler equals the incoming feed flow rate.

c. Total heat transfer to the incoming feed equals the heat transfer to the screen and the main bank, and the heat removed from the steam passing through the desuperheater.

d. The net mass transfer at the steam liquid interface in the drum is zero.

B. PROGRAM EQUATIONS

The total heat input to the boiler was given by

EB = HEAT RELEASE (Bto/sec-ft3) × FURNACE Volume (ft3)

If the sensible heats of the oil and air are lumped with the heating value of the fuel, the heating value is

The heat absorbed by the furnace screen at steady state was calculated from

ER1 = FURMACE HEAT ABSORPTION (Btu/sec-ft²) × Radiant Heat Absorbing Surface (ft²).

Since the flue gas temperature and the screen tube wall temperatures were provided, the heat transfer coefficient for radiant heat transfer to the screen could be determined from

$$K_{R1} = E_{R1} / \left\{ \left(\frac{T_{R1} + 460}{100} \right)^{4} - \left(\frac{T_{R1} + 460}{100} \right)^{4} \right\}$$

This result holds for the conditions reported in the manufacturers technical manual. Degredation due to age or fouling must be accounted for through the use of appropriate correlations.

With the enthalpy of the feed water at the economizer outlet and the enthalpy of the steam leaving the dry pipe, and the change in enthalpy of the steam flowing through the desuperheater, the heat transfer to the main bank was calculated from

The metal temperature of the main bank risers were obtained by calculating the constant

$$Kwy = \frac{Amb}{1.782 \times 10^6}$$

and solving the heat transfer equation

The specific heat of the flue gas passing the main bank was

$$CR_{2} = ER_{3} / GR(TR_{3} - TRV)$$

and the unknown constant in the gas side heat transfer relation was determined from

In a similar manner, the specific heat of the furnace flue gas is

and the water side heat transfer coefficient is

The heat transferred in the desuperheater was:

With this value and the temperature difference the specific heat of the steam was computed from

The heat transfer coefficient was calculated from the Dittus-Boelter correlation [11]

$$K_{02} = \frac{k}{d} (.023) \left(\frac{4.0}{\pi \mu d}\right)^{1.8} P_r^{1.3} A$$

The log mean temperature difference was

and the metal temperature was determined by

$$T_{MS} = (T_{02} - QT_{03}) / (1 - Q)$$

where:

$$Q = Exp \left\{ LMTO / (TO2 - TO3) \right\}$$

With the metal temperature, the water side heat transfer constant was obtained from

Analysis of the Economizer is more complicated since it is a multipass heat exchanger with finned tubes. Additionally, since we are concerned with energy storage within the metal of the economizer, the internal and external heat transfer must be considered separately.

The heat transferred was given by the change in enthalpy of the feed water, i.e.,

$$Ew1 = Go1 (Hw4 - Hw3)$$

The specific heat of the water was

$$Cw = Ew1/G01(Twy-Tws)$$
.

As in the case of the desuperheater, the inside heat transfer coefficient was calculated from the Dittus-Boelter correlation as

$$Kws = \frac{\kappa}{4} (.023) \left(\frac{4}{\pi m d}\right)^{B} P_{n}^{4} A$$

From this the LMTD was obtained as

Finally the metal temperature was determined from

$$T_{my} = (T_{W4} - \beta T_{W3}) / (1 - \beta)$$

$$\beta = exp \left\{ LmTD / (T_{W4} - T_{W2}) \right\}$$

The outside heat transfer constant was

where

The specific heat of the flue gas passing the economizer was

The superheater heat transfer was obtained from the change in enthalpy of the steam, i.e.,

With this value and the known metal and gas temperatures, the specific heat of steam, the specific heat of the flue gas passing the superheater, and the inside and outside heat transfer constants were determined as

$$C_{01} = E_{01} / G_{01} (T_{02} - T_{01})$$

$$C_{R1A} = E_{01} / G_{R} (T_{R2} - T_{R3})$$

$$K_{01} = E_{01} / G_{01}'^{B} L_{MT0}$$

$$K_{R2} = E_{01} / G_{R}'^{b} (T_{RA1} - T_{M2})$$

where:

$$LMT0 = \frac{T_{02} - T_{01}}{\ln \left\{ \frac{T_{M2} - T_{01}}{T_{M2} - T_{02}} \right\}}$$

and

The superheater and desuperheater pressure drop constants were evaluated from the known equilibrium pressures as

$$C_{7} = (Po_{1} - Po_{2}) Po_{ax} / Go_{1}^{2}$$

 $C_{q} = (Po_{2} - Po_{3}) Po_{ax} / Go_{2}^{2}$

Similarly, the constants used in the calculation of the average steam densities were obtained from:

and

$$C_{10} = (P_{02} + P_{03}) / (P_{02} + P_{03})$$

Finally the steam value flow constant was computed from

C. CIRCULATION BALANCE

Since they are not normally provided by the manufacturer, values for the friction factors, and bend and entrance loss coefficients must be assumed. The values do not appear to be particularly critical, and tables found in engineering handbooks may be used to determine reasonable values for these parameters.

An iterative procedure must be used to adjust the various flow values involved to achieve a steady state balance. Since the riser exit quality for boilers of this type generally lies in the range of .02 to .04, a starting trial value for the circulation flow rate may be obtained from:

Er = Xe Gr Hig

where X_E is the exit quality, E'_r is the heat transfer to the riser, G_r is the flow rate, and HFG is the heat of vaporization. With this trial value, the following balancing procedure is used:

1. Set HW2 (Downcomer Enthalpy) = HW1

- 2. Calculate HWG = HW2 + ED2/Gø
- 3. Calculate the riser exit quality:

Xo = ERS / (Hfg + Hws - Hwo) Go

4. Determine the non-boiling height:

5. Compute the average riser density:

$$P_{a1} = \frac{1}{H_{XR}} \left\{ \frac{H_{XR} - H_{MBR}}{X_0 V_{Fg}} \ln \left(\frac{X_0 V_{Fg}}{V_f} + 1 \right) + f_w H_{WBR} \right\}$$

6. Obtain the outlet density:

7. Compute the friction factor:

$$F_{R} = \left\{ \frac{1}{1.74 - 2\log(R/k_{0})} \right\}^{2} \left\{ 1 + 16078.58 \left(\frac{X_{0}}{PD_{1}} \right)^{.96} \right\}$$

8. Next the riser loss factor is computed:

..

9. Finally we may calculate Gø':

where Cl00 is the downcomer loss factor.

 Compare Gø and Gø' if equal go on, otherwise update Gø:

$$Go = \frac{Go' - Go}{2} + Go$$

and return to step 2.

11. Assume a trial value for Gs (first pass only).

12. Compute Xs:

$$X_6 = (G_{01} - G_0 X_0)/G_5$$

13-19 Same as for the main bank risers. Return to 12 if reiteration necessary.

20. Obtain HW2' from:

$$Hw_2' = \frac{Gw_2}{G_5 + G_0} (Hw_4 - Hw_1) + Hw_1$$

21. If HW2' = HW2 go on, otherwise update HW2:

$$Hw_2 = \frac{Hw_2' - Hw_2}{2} + Hw_2$$

and return to step 2.

Upon exit from the iteration loop, equilibrium values of the flow parameters will have been established. With these and the previously calculated heat transfer parameters, the program generates the list of constants and integration initial conditions required by the dynamic model. The program listing and a sample output is given in Appendix B.

V. RESULTS AND CONCLUSIONS

A. OPEN LOOP RESPONSES

The output curves for 10% increases and decreases in throttle valve opening and fuel flow are given in Figures 6-33. Ramp inputs of approximately 1.5% per second were used to simulate flexibility test conditions. Only one input parameter was varied for each run with all others held constant. The results were similar to those presented in [3] and [4] insofar as general trends were concerned. Since the boilers involved were of widely different geometries and sizes, a quantitative comparison was not possible. Since CSMP uses only single precision arithmetic packages and integration algorithms, the high frequency noise in the outputs is attributable to the roundoff error inherent in the wide variations in magnitudes of numbers used in the model, e.g., quality (order of 0.01) and riser mass flow rate (order of 1000). In common with the results of [3] and [4], the "swell effect" in response to an increase in throttle opening is negligible. It should be noted that the swell exhibited in the data of Whalley [3] is more apparent than real, inasmuch as the scales in his graphs are very magnified and the rise is actually only 0.01 inches. The sudden increase in riser mass flow rate shown in [3] is also not present in the current model.

Since "shrink" and "swell" effects are of some concern to controls designers, an attempt was made to model for such effects. Four possible causes for the phenomenon were considered.

1. Homogeneous Nucleation in the Steam Drum Liquid

This effect is caused by a difference between the saturation temperature corresponding to the actual drum pressure, and the actual liquid temperature. The superheat required for such nucleation is quite high however and nucleation will occur at the heating surfaces at much lower superheats. Therefore this was considered to be an unlikely cause for the effect.

2. Nucleate Boiling at the Drum Wall-liquid Interface

The driving force for this phenomenon is also the temperature difference between the drum surface and the saturation temperature. Since the temperature difference will be slight except under large drum pressure excursions, the impact of this factor should be slight. The Rohsenow correlation [5] may be solved in terms of a rate of vapor generation to yield

$$8/h_{fg} = \left\{ \frac{C_{\ell} \Delta T}{C_{sf} h_{fg} P_{r_{\ell}}^{h_{T}}} \right\}^{3} \sqrt{\frac{g(P_{\ell} - P_{\upsilon})}{g_{c} \sigma}} M_{\ell} A$$

It was assumed that the vapor formed would be uniformly distributed bubbles which would rise to the surface with a

velocity given by [14]

 $U_b = \frac{1}{3}\sqrt{2g} b$

which is a conservative estimate since interaction effects tend to increase the rise velocity. The bubble diameter is given by [14]

This gives U_b as .25 ft/sec. The average liquid depth is 15 inches, so the transit time is \approx 5 seconds. The effect was modeled crudely by assuming the entrained bubble mass was 5.0(q/hfg) lbm. The impact of this model on shrink and swell values was negligible, since no large pressure excursions were developed.

3. Expansion and Contraction of Varpor Bubbles Entrained in the Riser Fluid

An attempt was made to model this effect by including the riser tubes in the control volume used as the basis for liquid level determination. The equation used was

where Ralx and Ra2x are the average riser densities computed using the specific volume for the saturated vapor corresponding to drum pressure, while Ral and Ra2 were computed from the liquid temperature saturation conditions. The effects were insignificant.

4. <u>Transient Deviation of Riser and Downcomer Mass</u> Flow Rates

The small swell effect obtained by Whalley [3] can be attributed to the temporary increase of riser mass flow rate over downcomer mass flow rate. The period over which this imbalance could be sustained is short and would fail to account for the longer duration of "shrink" and "swell" effects observed in practice. It may, however trigger one of the two phase flow instabilities common to natural circulation loops e.g., flow oscillations [10,13]. The analysis of these effects was not exhaustive, and the modeling attempts were crude. In the case of the first two, however, the contribution to swell is probably not significant. Modeling difficulties with the latter two effects precluded any specific conclusions.

B. CONCLUSIONS

As with all simulations, the information available from the model is extensive. Notably, in this study, main bank and water-screen circulation values can be separately evaluated. Hence, the contribution of each of these elements to overall boiler operational response and efficiency can be determined.

The model simulates the responses of a Naval boiler quite well. Unfortunately, open loop data is unavailable

for the actual boiler and insufficient information was available to develop a model of the <u>existing</u> LHA-1 control system as a basis for comparison studies. As such, however, the model forms a basis upon which future studies involving modern control system designs can be established. Moreover, while considerable refinement of the model is possible, the advantages of greater accuracy must always be weighed against increased computation costs. In this regard, the implementation of more efficient integration algorithms would be particularly beneficial.



FIGURE 1. SIMPLIFIED BOILER SCHEMATIC



FIGURE 2. COMBUSTION ENGINEERING TYPE V-2M BOILER







FIGURE 4. FLUE GAS AND COMBUSTION SCHEMATIC



FIGURE 5. BASIC CIRCULATION SYSTEM



..


















.







...





















DRUM PRESSURE RESPONSE TO A 10% DECREASE IN FUEL FLOW













THIS PAGE IS BEST QUALITY PRACTICABLE

FROM COPY FURNISHED TO DDC

APPENDIX A

THIS FROGRAM CALCULATES THE CONSTANTS AND INITIAL CONCITIONS FOR A US NAVY DETYPE BOILER GIVEN THE INPUT DATA COTAINED FROM THE ECILER TECHNICAL MANUAL, STEAM TAELES, AND STANDARD ENGINEER ING FANDBODKS. THE INPUT DATA ARE ENTERED IN NAME LIST FORMAT. NAMELIST DESIGNATIONS AND INPUT NEMCNICS FOLLOW CPERATING FCINT(PERCENT) * TOTAL STEAM FLCW(LB/HR) SUPERHEATER STEAM FLCW (LB/HR) DISUPERHEATER STEAM FLCW (LB/HR) DISUPERHEATER CUTLET TEMPERATURE (CEG-F) SUPERHEATER CUTLET PRESSURE (PSIG) DESUPERHEATER CUTLET TEMPERATURE (CEG-F) DESUPERHEATER CUTLET TEMPERATURE (CEG-F) DESUPERHEATER CUTLET TEMPERATURE (CEG-F) CONCMIZER FEEC OUTLET TEMPERATURE (CEG-F) AIR INLET TEMPERATURE TO REGISTERS (LEG-F) AIR INLET TEMPERATURE AT BLRNER INLET (DEG-F) AIRFLOW RATE (LB/HR) EXCESS AIR (PERCENT) * PRAFT LCSS (IN-H2O) FLUE GAS TEMPERATURE LEAVING SCREEN (CEG-F) SCREEN TUBE WALL TEMPERATURE (CEG-F) SCREEN TUBE WALL TEMPERATURE (CEG-F) SCREEN TUBE WALL TEMPERATURE (CEG-F) FLOR ACCE HEAT ABSORBTICN (KETU/HR/SQ FT PADIANT HEAT ABSORBING APEA) PERCENT" VALUES ARE TO BE LCGGED AS DECLMALS. INCON1: NCTE: "PERCENT" VALLES ARE TO BE LOGGED AS DECIMALS. SCREEN DTLBSC LAVSC NTLBSC RF455C MASSSC AVERAGE INSIDE DIAMETER OF SCREEN TUBES (IN) AVERAGE LENGTH OF SCREEN TUBES (FT) NUMBER OF SCREEN TUBES RADIANT HEAT AESORBING AREA OF FURNACE SCREEN (SC FT) TGTAL WEIGHT OF SCREEN TUBES (LB) \$ SPHTR MASSSH TOTAL SUPERHEATER HEAT TRANSFER AREA (SC FT) TOTAL WEIGHT OF SUPERHEATER TUBES SPNEANK CTUEMB LAVMB NTLOMB MASSMB ARZAME AVERAGE INSIDE DIAMETER OF MAIN BANK TUBES (IN) AVERAGE LENGTH OF MAIN BANK TUBE (IN) NUMBER OG MAIN BANK TUBES TOTAL WEIGHT OG MAIN BANK TUBES (LE) TCTAL HEAT TRANSFER AREA (SC FT) \$ECCN DTLBEC NFASSE NTLBEC MASSEC INSICE CLAMETER OF ECONOMIZER TUBES(IN) NUMBER OF TUBE PASSES NUMBER OF TUBES PER PASS AVERAGE LENGTH OF ECONUMIZER TUBE (FT) TOTAL WEIGHT OF ECONOMIZER (LE)

\$CESPH

 ϕ

THIS PAGE IS BEST QUALITY PRACTICABLE FROM COPY FURNISHED TO DDC

NTLBDS	NUMBER OF CE	SUPERHEATER T	LESS PER PASS	
LTLADS	LENGTH OF CE	SUPERHEATER T	LET PASSES LET (FT)	
MASSOS	TCTAL WEIGHT	CF DESUPERFE	ATER ASSEMBLY (LB)	
SCRMCCR				
CTLECC	AVERAGE DIAM	TTER OF DRUM	CCWNCOMER TLRES (IN)	
NTLECO	NUMBER OF CP	UM DOWNCOMER	TLEES	
SHERECR				
CTLEFC	AVERAGE INST	DE CIAMATER C	F HEADER CONNED AER (IN)	
NTI BHO	NUMBER OF FS	ACER DEWNCOME	RS (FT)	
SECILER				
CSIMON	CIAMSTER OF	STEAM DRUN (I	NI	
CWIRCM	CIAMETER OF	WATER DRUM (FT)	N)	
HNCRM	FEIGHT OF NO	ADER USCREEN	ABOVE BENCH MARK (FT)	
HWTRDM	FURNACE VOLU	TER DRUM ABOV	E BENCH MARK (FT)	
NCTE: 0	CHUICE OF BEN	CH MARK IS AR	BITRAPY	
STHERMC				
HSHCUT	ECONCHIZER C	UTLET ENTHALP	Y (BTU/LBM)	
HECIN	ENTHALPY OF	ECONOMIZER FE	EC DUTLET (BTU/L3M)	•
(1)KH2C (1)PRF2C	THERMAL CONC PRANETL NUMB	UCTIVITY OF WATER	ATER (BTU/FR.FT.DEG-F)	
(1)VSCF20 (2)KSTM	KINEMATIC VI	SC CSITY FOR W	ATSR (LBM/FT-SSC) STEAM (BTU/FR.FT.CEG-F)	
2 IVSCSTM	KINEMATIC VI	SCCSITY FOR S	TEAM (LBM/E1-SEC)	
RESCUT	LESUPERHEATE	R CUTLET DENSI	ITY (LBM/CL FT)	
NOTES:	(1) FVALUATE	D AT AVERAGE	ECONOMIZER WATER TEMPERATURE	
	(2) EVALUATE	D AT AVERAGE	CESUPERHEATER STEAP TEMPERATO	UFE
\$LCSSES KSCSC	REUGHNESS RA	TICN (SAND SC	LIVALENT) FCR SCREEN TUPES	
KSCED	ROUGHNESS RA	TIO (SAND EQL	IVALENT) FOF DRUM DEWNCOMER	
ENTSC	SCREEN TUPE	ENTRANCE LOSS	IVALENT) FUR FRADER LUNNULVES	*
PENCMB	MAIN BANK EN	TRANCE LOSS	c	
BENCED	DRUM DOWNCCM	ER ENTRANCE L	CSS FACTOR	
BENDHD	HEADER DOWNC	CHER ENTRANCE	LOSS FACTOR S FACTOR	
IMELICIT, RS	EAL (A-Z)			
INTECER J.K	A MAN			
ANT WORK NPA	1000			

THIS PAGE IS BEST QUALITY PRACTICABLE

FROM COPY FURNISHED TO DDC

CCC CEFINE NAMGLISTS NAMGLIST/INCCNJ/CPPNT,TCTSTM,SPESTM,CSESTM,POPUM,SHCT,SHCP,CSHCT, 105FDP,GCONIT,ECCNOT,AIPTMP,OILFLO,AIRFLO,XCSAIR,CRAFT,TGASSC, 21 GASSE,TGASMB,TGASEC,TSCRN,TSPHTR,FRFVCL,FHAS,CILTMP NAMGLIST/SCREEN/DTUBSC,LAVSC,NTUBSC,FFASSC,MASSSC NAMGLIST/SCREEN/DTUBSC,LAVSC,NTUBSC,FFASSC,MASSSC NAMGLIST/SCREEN/DTUBSC,LAVSC,NTUBSC,FFASSC,MASSSC NAMGLIST/SCREEN/DTUBSC,NPASSF,NTUBIC,LTLEEC,MASSC NAMGLIST/CON/DTUBEC,NPASSF,NTUBIC,LTLEEC,MASSC NAMGLIST/CON/DTUBEC,NPASSF,NTUBIC,LTLEEC,MASSC NAMGLIST/CON/DTUBEC,LAVDD,NTUBMB,MASSMB,AREAME NAMGLIST/CON/DTUBEC,LAVDD,NTUBMD NAMGLIST/FORDCR/LTUBDS,NTUBOS,NPASSD,LTLBDS,AFFALS,MASSCS NAMGLIST/FORDCR/LTUBDS,LAVMD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVDD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVDD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVDD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVDD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVDD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVHD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVHD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVHD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVHD,NTUBHD NAMGLIST/FORDCR/LTUBDC,LAVHD,NTUBHD NAMGLIST/INCONZ/FKA10,CCKSCMB,KSCDD,KSCFC,ENTSC,EENTME, SBENDME,STNDC,BENCDD,FNTHD,BENDHC NAMGLIST/INCONZ/HM10,TM20,TM30,TM40,TM50,GCKC,GSRC,CXCC,QXSC NAMGLIST/INCONZ/HM10,TM20,TM30,TM40,TM50,GCKC,GSRC,CXCC,QXSC NAMGLIST/INCONZ/HM10,TM20,TM30,TM40,TM50,GCKC,GSRC,CXCC,QXSC NAMGLIST/CONST3/FRA10,CC420,GD15,RA12C,RA2X0,GWFC,GGSC NAMGLIST/CONST3/FRA10,CC420,GD15,RA12C,RA2X0,GWFC,GSC NAMGLIST/CONST3/FRA10,CC420,GD15,RA12C,RA2X0,GWFC,GSCC NAMGLIST/CONST3/FRA10,CC420,C3,A3,LP,CL,CA2X0,GWFC,GSCC NAMGLIST/CONST3/FRA10,CC420,C3,C1,CC2,CW,KC1,KC1,KC2,KR1,KK2,KR2 NAMGLIST/CONST3/FXS,MK1,VR,VS,VNDP,VLF,LD1R,LC15 NAMGLIST/CONST3/FXS,MK1,VR,VS,VNDP,VLF,LD1R,LC15 NAMGLIST/CONST5/KR4,Z1,Z2,Z3,Z4,Z5,Z6,Z7,Z8,HW2,GC10,CC2,C8,C5,C10 NAMGLIST/CONST5/KR4,Z1,Z2,Z3,Z4,Z5,Z6,Z7,Z8,HW2,GC10,CC2,C8,C5,C10 NAMGLIST/CONST5/KR4,Z1,Z2,Z3,Z4,Z5,Z6,Z7,Z8,HW2,GC10,CC2,C8,C5,C10 NAMGLIST/CONST6/C11,C7,CSL,KW1,KW2,KW1,KW4,HC NAMGLIST/CONST6/C11,C7,CSL,KW1,KW2,KW1,KW4,HC NAMGLIST/CONST6/C11,C7,CSL, CEFINE NAMELISTS C ç PI=3.1415527 G=32.2 CM=.11 DRA10=0.0 DRA2C=0.0 ZERD=C.C VENT=CPPNT

DIMENSION THEO(20), CPASS (20)

HIS PAGE IS BEST QUAL FROM COPY FURNISHED TO FOR FOR FURNISHED TO FOR FOR FURNISHED TO FOR COPY FURNISHED TO FOR FOR FURNISHED FURNISHED FOR COPY FURNISHED TO FOR FOR FURNISHED FOR FURNISHED FOR COPY FURNISHED TO FOR FOR FURNISHED FOR FURNISHED FOR COPY FURNISHED FOR FOR COPY FURNISHED FOR COPY FURNIS THIS PAGE IS BEST QUALITY PRACTICABLE FROM COPY FURNISHED TO DDC

THIS PAGE IS BEST QUALITY PRACTICABLE FROM COPY FURNISHED TO DDC

CZ2=(CSTMDM/12.C)*LSTMDM*(1.0/12.0) CCCC CALCULATE LOWER FEATING VALUE OF FUEL CIL HO=EB/GB CCC CCMPLTE STOICHICMETRIC AIR/FUEL RATIC CSL=(1.O-XCSAIR)*GL/GB ç RACIATION HEAT TRANSFER COEFFICIENT KF1=EF1/(((TR10+460.0)/100.0)**4-((TM1C+460.0)/10C.C)**4) ĉ CCMPUTE HEAT TRANSFER TO THE MAIN TUBE BANK ER3=GC1*(HD1-HW4)-GD2*(HSHOUT-HDSOUT)-ER1 CCC COMPUTE MAIN BANK AVERAGE METAL TEMPERATURE K+4=(1.C/1.7829C6)*AREAME TM3D=(ER3/(KW4*FD1**(4.0/3.0)))**(1.C/3.0)+TD1 c CCMPLIE MAIN BANK GAS SIDE HEAT TRANSFER COEFFICIENT KR3=EF3/(((TR3+TR4)/2.0-TM30)*GR**.6) CCMPUTE SCREEN EANK WATER SIDE HEAT TRANSFER (CEFFICIENT KW3=EF1/((PD1**(4.0/3.0))*(TM10-TD1)**3) HEAT TRANSFER TO THE SUPERHEATER ER2=GC1*(HSHCUT-HD1) С С ç SUPERFEATER GAS SIDE FEAT TRANSFER CCEFFICIENT KR2=ER2/(((TR2+TR3)/2.0-TM20)*GR**.6) HEAT TRANSFER TC THE ECONOMIZER ER4=CC1*(FW4-FW3) CCMPUTE SPECIFIC HEATS OF FLUE GAS С HEAT TRANSFER TC THE ECONOMIZER EF4=CCI#(+W+-HW2) CCPPUTE SPECIFIC HEATS OF FLUE GAS FURMACE CF1=(Ef=ER1)/((TP10-8C.0)*GR) SUFFAHEATER CF1=(Ef=ER1)/((TP10-8C.0)*GR) CC1=EC2/(GD1*(TP2-TR3)) CR2=ER2/(GR*(TP2-TR4)) CR2=ER4/(GR*(TP2-TR4)) CR2=ER4/(GR*(TP2-TR4)) CCPPUTE AVERACE HEAT TRANSFER COEFFICIENT CEC1=(TUEEC/12.C AREAEC=NTU3EC*(IUBEC*PI*CEC1*NPASSE Kw1=AREAEC*(KH2C/DEC1**1.8)*.023*(4.0/(PI*VSCH2C*NTUBEC))**.8* SPRF2C**.4 LMTCEC=ER4/(KW1*GD1**.6) XXXX1=EXP((TW4-TW3)/LMTCEC) TW40=(TW3-TW4)/LMTCEC) TW40=(TW3-TW4*XXX11)/(1.0-XXXX11) CC=EC2/(GD2*(HAHOUT+HOSCLT)) SFCIFIC HEAT OF STEAM AT AVERAGE COEFFICIENT DESUPERHEATER STCAM SICE HEAT TRANSFER COEFFICIENT MTDS=C2=SCP((Sh07-OF)/(1.0-XXX02)) TM50=SUPERHEATER STCAM SICE HEAT TRANSFER COEFFICIENT KW2=EC2/(TM50-TW1) CESUPERHEATER STCAM SICE HEAT TRANSFER COEFFICIENT KW2=EC2/(TM50-TW1) CESUPERHEATER STCAM SICE HEAT TRANSFER COEFFICIENT KW2=EC2/(CB02***.8*MTCES) SUPERHEATER STCAM SICE HEAT TRANSFER COEFFICIENT KC2=EC2/(GD2***.8*MTCES) CALCULATE THE THFOTTLE VALVE FLCW CCNSTANT CC C C С С С С C C С С C C C

<pre>THIS PAGE IS BEST QUALITY FINANCE C Clister Field Content of the content of</pre>			PRACTICABLE
<pre>c Classified Collign Density Prove Collign Density Classified C</pre>		C11-CC4/(D22#VENT)	THIS PAGE IS BEST QUALITY FRACT
<pre>RAVES:(RE2*RD3)/2.3 GC CS=(FE2-PD3)*RAVES/CD1**2 GC CS=(FE2-PD3)*RAVES/CD1**2 GIRCLLATION SYSTEM CALCULATIONS CCMPUTE LOSS CDEFFICIENTS FOR DEWNECMERS FEE=11.0/(1.74-2.0CALCG10(KSDD0))**2 GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*ARW) FES=11.0/(1.74-2.0*ALCG10(KSDD0))**2 GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*27241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/D05*274241:0)/(2.0*AES*2*RW) GIRCLAFESKLOS/CONSTITUTION COOP AESTERLE (CSAESTERLESKLOS/D05*2581:0)/(1.0*1673558*X0/FC1)**.5C) PSIME:(FR2CQ/CD4 GIRCLAFESKLOS/CSAESTERLESKLOS/CONSTITUTE: ELSE REITEFATS IF(AESCCO-GOX).UT.O)/(1.0*141/(2.0*AES*2*RW)+ S2/72/2.0*AES*2*RC) GC GIRCLAFESKLOS/CSAESTERLESKLOS/CONTINUE: ELSE REITEFATS IF(AESCCO-GOX).UT.O)/CONSTITUTE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONSTITUTE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONSTITUTE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONSTITUTE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONSTITUTE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONTO START THRO ITERATION LOOP AEXERCLAFSKLONE GUALSSINTIAL GOESS, CONTINUE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONTO IFFCCACKAVALUE EOUNCSINTIAL GOESS, CONTINUE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONTO IFFCCACKAVALUE EOUNCSINTIAL GOESS, CONTINUE: ELSE REITEFATE. IF(AESCCO-GOX).UT.O)/CONTO IFFCCACKAVALUE EOUNCSINTIA</pre>	с	SLPSRFEATER OLTLET DENSITY Ca=(FC1+PO2)/(RC1+RD2) C10=(FC2+PO3)/(RC2+RD3) RAVSF=(RC1+RD2)/2+0	From
<pre>C CIRCLLATION SYSTEM CALCULATIONS C CCMPUTE LOSS COEFFICIENTS FOR DEWNECMERS FEB-(1-C/(1.74-2.0*ALCGIO(KSODD)))**2 CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) FC CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(2.0*AEC**2*RW) CIG1=FEC*LDS/DES*C7+ZE+1.0)/(CHW1+XC*+FE0)-FW6) FEC*LD*FEC*LDS/DES*C7+ZE+1.0)/(CHW1+XC*+FE0)-FW6) FEC*LD*FEC*LDS/DES*C7+ZE+1.0)/(CHW1+XC*+FE0)-FW6) FEC*LD*FEC*LDS/DES*C7+ZE+1.0)/(CHW1+XC*+FE0)-FW6) FEC*LD*FEC*LD*FEC*LDS/DES*C7+ZE+1.0)/(CO*AR**2*RW)+ FEC*LD*FEC*LD*FEC*LDS/DES*C7+ZE+1.0)/(CO*AR**2*RW)+ FEC*LD*FEC*LD*FEC*LD*FEC*LDS/DES*CENTINUE; ELSE REITEFATS ICLAEC*CFTLC**CF0]/CS FEC*LD*FEC*LD*FEC*LD*FEC*LD*FEG}FFEG}FFEGFFEGFFEC*LD*FFEGFFEGFFEC*LD*FFEFFEC*LD*FFEGF</pre>	~	RAVES = (RE2+RD3)/2.0 C7=(FE1-PD2)*RAVSH/GE1**2 C5=(FE2-PD3)*RAVES/GD2**2	
<pre>C CCMPUTS LOSS COEFFICIENTS FOR DCWNCCMERS FDB=(1,C/(1,74-2, CTALCG10(KS00D)))**2 G10=FCBACB/CF/DE*1+22+10)/(2:0*ACS**2*RW) FDS=(1,0)/(1,74-2,0*ALCG10(KS0HD))**2 G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) G11=FC54L05/D527+22+.c)/(2:0*ACS**2*RW) FDS=FC52/FO FX5</pre>		CIRCULATION SYSTEM CALCULATION	S
<pre>C FCR=(1=c/(1,74=2.c%AL_COLO (KSDOD))**2 Cl01=(FCRCER/DEP/1+22+10)(2)(2)(3)(5)(5)(5)(5)(5)(5)(5)(5)(5)(5)(5)(5)(5)</pre>	CCC	COMPUTE LOSS COEFFICIENTS FOR (DCWNCCMERS
<pre>CC CC CC CC CC CC CC CC CC CC CC CC CC</pre>		FCR=(1.C/(1.74-2.C*ALCC10(KSDD) C10J=(FCR*LCR/DCP+Z1+Z2+1.0)/(FCS=(1.0/(1.74-2.0*ALCG10(KSDH) C1C1=(FCS*LDS/DCS+Z7+Z8+1.C)/(D)))**2 2 · G*ACF**2*RW) D)))**2 2 · O*ACS**2*RW;
<pre>CC SET INITIAL TRIAL VALUES GC SET INITIAL TRIAL VALUES GC SET INITIAL TRIAL TRIAL VALUES GC START FIRST ITERATICN LOOP 1</pre>	C	ITERATIVE PROCEEURE FOR BALANCE	ING CIRCULATION LCOPS
<pre>G G = 2 G C 0 G S = 2 G C 0 F W 2 = H 1 = EC 2 / G 0 F W 2 = H 1 = EC 2 / G 0 F W 2 = H 1 = EC 2 / G 0 F W 2 = H 1 = EC 2 / G 0 F W 2 = H 1 = EC 2 / G 0 F W 2 = H 1 = H W 2 + EC 2 / G 0 F W 2 = H 2 + W A X 1 (H W 1 = H W 2 + O 0 - 0) / ((H W 1 + X C + F G) = H W 3 H M B = X X R A M X 1 (H W 1 = H W 2 + O 0 - 0) / ((H W 1 + X C + F G) = H W 3 F W 2 + I (X Y X Y F G) J * A L C G (X O * Y F G) / Y F + 1 - 0) + R W 3 + H N E P) / H X R R C = 1 ((L X / (X O * Y F G)) * A L C G ((X O * Y F G) / Y F + 1 - 0) + R W 3 + H N E P) / H X R R C = 1 ((L X / (X O * Y F G)) * A L C G ((X O * Y F G) / Y F + 1 - 0) + C 7 B 5 8 * (X O / F C)) * *</pre>		SET INITIAL TRIAL VALUES	
<pre>C START FIRST ITERATICN LOOP</pre>	с с	GC=2CC.0 GS=200.0 HW2=HW1-EC2/GO	
<pre>1</pre>	Č	START FIRST ITERATION LOOP	
<pre>RAI=((LXP/(UO*VFG))*ALCG((XO*VFG)/VF+1.))*RW*PNER)/HXR RC=1.c/V(1.74-2.0*ALOGIO(KSDM3))*2*4(1.0+16C78.58*(XO/FCI)**.56) PSIMB=(FR=Lq/LR+1.0)*FAI/(2.0*AR*2*RC)*2)*Z3/(2.0*AR*2*RW)* S24/(2.C*AR*2*RC) G3X=SCHT((RW=RA1)*FXR*G/(C130+PSIMB)) CFWAI(H0,G15-5) IF CFSCK VALUE SQUALS INITIAL GUESS, CCNTINUF; ELSE REITEPATS GC=(GC+GC)/2.0+G0 GC=(G(X-GC)/2.0+G0 GC=(G(X-GC)/2.0+G0 CCNTINUE XS=(CC1-G0*XC)/GS FXS=FNORM-HFCR FNS=HXS*MAX1((HW1-HW2).0.0)/((HW1+XS*FFG)-HW2) LXS=FXS-FNBS RA2=((LXS/(XS*VFG))*ALCG((XS*VFG)/VF+1.0)+RW*FNES)/(HXS) RS=1.c/V(1.74-2.0*ALOG10(KSDSC))*2*(1.0+16078.56*(XS/FCI)**.96) PSIC=(FSLS/DS*1.0)*PA2/(2.0*AS*2*FS*2)+Z5/(2.0*AS*2*RW)* SZ=(CXAS*2*RS) CSTART SECOND ITERATION LOOP CSTART THRO ITERATION LOOP CATTACT CSTART THRO ITERATION CONTACT CSTART THRO ITERATION CONTACT CSTART THRO ITERATION CO</pre>	1	<pre>Fw6=Fw2+ED2/G0 XC=(ER3-G0*(Fw1-Hw6))/(G0*HFG) FXF=FNCRM-HwTRCM HN8R=FXR*AMAX1((Hw1-Hw6),0.0)/ LXR=FXR-HN8R</pre>	((Hw1+XC*FG)-FW6)
<pre>C START SECONC ITERATION LOOP 2 CCNTINUE XS=(CCI-GO*XC)/GS +XS=+NORM-H+CR +NBS=HXS*AMAX1((HW1-HW2),0.0)/((HW1+XS*FFG)-HW2) LXS=+XS-HNBS RA2=((LXS/(XS*VFG))*ALCG((XS*VFG)/VF+1.0)+RW*FNES)/(HXS) RS=1.(/(VF+XS*VFG) FS=(1.0/(1.74-2.0*ALOG10(KSDSC)))**2*(1.0+16078.5E*(XS/FCI)**.96) PSISC=(FS*LS/DS+1.0)*PA2/(2.0*AS**2*FS**2)+Z5/(2.0*AS**2*RW)+ \$ZE/(2.0*AS**2*RS) GSX=SCRT((RW-RA2)*HXS*G/(C101+PSISC)) C IF CHECK VALUE EQUALS INITIAL GUESS; CONTINUE; ELSE REITERATE. IF(ABS(GS-GSX).LT.0)CO TO 3 GS=(GX-GS)/2.0+GS GC TC 2 C START THIRD ITERATION LOOP C HW2X=(GW2/(GS+GC))*(H*4-HW1)+HW1 IF CHECK VALUE EQUALS INITIAL GUESS; CONTINUE; ELSF REITERATE. IF(ABS(HW2-FW2X).LT.1)GO TO 4 HW2Z=(CH2/CS+GC))*(H*4-HW1)+HW1 C IF CHECK VALUE EQUALS INITIAL GUESS; CONTINUE; ELSF REITERATE. IF(ABS(HW2-FW2X).LT.1)GO TO 4 HW2Z=(CH2/CS+GC))*(H*4-HW1)+HW1 C IF CHECK VALUE EQUALS INITIAL GUESS; CONTINUE; ELSF REITERATE. IF(ABS(HW2-FW2X).LT.1)GO TO 4 HW2Z=(CH2/CS+GC))*(H*4-HW1)+HW1 C C IF CHECK VALUE EQUALS INITIAL GUESS; CONTINUE; ELSF REITERATE. IF(ABS(HW2-FW2X).LT.1)GO TO 4 HW2Z=(CH2/CS+GC))*(HW2/CO+HW2) C C C C C C C C C C C C C C C C C C C</pre>	c ⁴⁰⁰	RA1=((LXR/(XO*VFG))*ALCG((XO*VF RC=1.C/(VF+X)*VFG) FR=(1.0/(1.74-2.0*AL0G10(KSDM3) PSIMB=(FR*LR/CR+1.0)*FA1/(2.0*/ \$24/(2.C*AR**2*RC) GOX=SCRT((RW-RA1)*HXR*G/(C100+F FCRMAI(1H0,G15.5) IF CFSCK VALUE SQUALS INITIAL (IF (AES(G0-G0X).LT01)G0 TO 2 GC TO 1	-G)/VF+1.))+RW*PNER)/HXR)))**2*(1.0+16C78.58*(XO/FE1)**.96) AR**2*RC**2)+Z3/(2.0*AR**2*RW)+ PSIMB)) GUESS, CONTINUE; ELSE REITERATE
<pre>2 CCNTINUE XS=(CC1-G0*XC)/GS +XS=+NORM-HFCR +NBS=HXS*AMAX1((HN1-HW2),0.0)/((HW1+XS*FFG)-HW2) LXS=FXS-FNBS RA2=((LXS/(XS*VFG))*ALCG((XS*VFG)/VF+1.0)+RW*FNES)/(HXS) RS=1.(/(VF+XS*VFG) FS=(1.0/(1.74-2.0*ALOG10(KSDSC)))**2*(1.0+16078.5E*(XS/FC1)**.96) PSISC=(FS*LS/DS+1.0)*PA2/(2.0*AS**2*FS**2)+Z5/(2.0*AS**2*RW)+ \$Z6/(2.0*AS**2*RS) GSX=SCRT((RW-RA2)*HXS*G/(C101+PSISC)) IF CHECK VALUE EQUALS INITIAL GUESS, CONTINUE; ELSE REITERATE. IF(ABS(GS-GSX).LT01)CD TO 3 GSTART THIRD ITERATION LOOP C START THIRD ITERATION LOOP C START THIRD ITERATION LOOP C HW2X=(GW2/(GS+GC))*(HW4-HW1)+HW1 IF CHECK VALUE EQUALS INITIAL GUESS, CONTINUE; ELSE REITERATE. IF(ABS(HW2-FW2X)+LT1)GO TO 4 HW22=(FW2X-HW2)/2.0+HW2 GC TC 1 C CONTINUE</pre>		START SECOND ITERATION LOOP	
<pre>\$ZE/(2.C#AS*#2*RS) GSX=SCRT((RW-RA2)*HXS*G/(C101+PSISC)) IF CHECK VALUE EQUALS INITIAL GUESS, CONTINUE; ELSE REITERATE. IF (ABS(GS-GSX).LT01)GD TO 3 GS=(GSX-GS)/2.0+GS GC TC 2 C START THIRD ITERATION LOOP C HN2X=(GW2/(GS+GC))*(H+4-HN1)+HW1 C IF CHECK VALUE EQUALS INITIAL GUESS, CONTINUE; ELSE REITERATE. IF (ABS(HW2-HW2X).LT1)GO TO 4 HW2=(FW2X-HW2)/2.0+HW2 GC TC 1 4 CONTINUE</pre>	2	CCNTINUE XS=(GC1-GO*XC)/GS HXS=HNORM-HHCR HNBS=HXS*AMAX1((Hh1-Hh2),0.0)/(LXS=FXS-HNBS RA2=((LXS/(XS*VFG))*ALCG((XS*VF RS=1.C/(VF+XS*VFG)) FS=(1.0/(1.74-2.0*ALOG10(KSDSC)) PSISC=(FS*LS/DS+1.0)*PA2/(2.0*A	((HW1+XS*FFG)-HW2) FG)/VF+1.0)+RW*FNES)/(HXS) ())**2*(1.0+16778.58*(XS/FE1)**.96) AS**2*FS**2)+Z5/(2.C*AS**2*RW)+
C START THIRD ITERATION LOOP C HW2X=(GW2/(GS+GC))*(HW4-HW1)+HW1 C IF CHECK VALUE EQUALS INITIAL GUESS, CONTINUE; ELSE REITERATE. IF(ABS(HW2-HW2X)+LT1)GO TO 4 HW2=(FW2X-HW2)/2.0+HW2 GC TC 1 4 CONTINUE	c	\$Z¢/(2.C*AS**2*RS) GSX=SCRT((RW-RA2)*HXS*G/(C101+F IF CHECK VALUE EQUALS INITIAL C IF(ABS(CS-GSX).LT01)CO TO 3 GS (CSX-GS)/2.0+GS GC TC 2	SISC)) GUESS, CONTINUS; ELSE REITERATE.
<pre>H 2X=(GW2/(GS+GC))*(H +4-Hw1)+HW1 C IF CFECK VALUE SOUALS INITIAL GUESS, CONTINUE; ELSE REITERATE. IF(ABS(Hw2-Fw2X)+LT+1)GO TO 4 Hw2=(Fw2X-Hw2)/2.0+HW2 GC TC 1 4 CONTINUE</pre>		START THIRD ITERATION LOOP	
	c ³	Hw2X=(GW2/(GS+GC))*(H+4-Hw1)+HW IF CHECK VALUE EQUALS INITIAL C IF(ABS(HW2-HW2X).LT1)GO TO 4 Hw2=(FW2X-HW2)/2.0+HW2 GC TC 1 CONTINCE	UESS, CONTINUE; ELSE REITERATE.

THIS PAGE IS BEST QUALITY PRACTICABLE FROM COPY FURNISHED TO DDC

CALCULATE INITIAL CONDITIONS GORO=GC/RC GSRO=GS/RS MwiC=vCR*Rw/2.0 HMIO=twi*MwiO GxCD=twi+xD*HFG/2.0 GxCD=twi+xD*HFG/2.0 VFCD=(vDR/2.0)*RC1 Hw6D=twe GCIO=GC1 GwRD=GO GwSD=GS RAIXC=(RA1*HXR-FW*HNBF)/LXR R42xD=(RA2*+XS-FW*HNBS)/LXS LCIS=LAVHD WFITE(6,601) FCFWAT(1H1) wFITE(6,601) FCFWAT(1H0) WFITE(6,601) WFITE(6,00NST2) WFITE(6,601) WFITE(6,00NST3) WFITE(6,601) WFITE(6,00NST5) WFITE(6,00NST5) WFITE(7,CONST1) WFITE(7,CONST1) WFITE(7,CONST3) WFITE(7,CONST3) WFITE(7,CONST3) WFITE(7,CONST4) WFITE(7,CONST4) WFITE(7,CONST5) WFITE(7,CONST6) STCP ENC CALCULATE INITIAL CONDITIONS 600 601

CCC





. GORO= -19. .GhR0= 844.25098 +TM50= 630.99576 .TH3- 254.90300 RA2X0= 37.804260 TP40= 360.36450 .GCIE= 0.449955755-02.RAI20+ 34.425558 .CEA2C= 0.0 EINCCN3 EALC= 536.31556

KCCNST 5555551E-34,KS= 0.25559996E-34,KDR= 0.4599999E-05,KCS= 0.45955559E-05,KR= 10.678426, 1LR= 28420.00 ,LCR= K8-0.51566 ,LR1= 10.00000 .AS= 4.0646057 9.1S= 162.2596 ,D3= AS.AS-0.45146 ,LS1= 12.700000 ,LCR= 5.500 ,CCCCCC , ACR= 1.4451323

- THH.

-LOLA-. WOR- 56.174744 . VOP- 327.31445 +VS= 51.620483 6CCNST3 FX2 12.5CCCCC 6.5C 6.5C

,225= C.555555564E-01,26= KG CNST 5 NG CNST 5 0.55555564E-01.21= 0.559559645-C1.22= 0.5599964E-01.23= 0.55995564E-01.24= 0.14555598 0.55555564E-01.21= 0.55955544E-01.22= 0.55995564E-01.4W2= 3221.00000C 6.62.423574

*KW3= 0.327696585-05 KW4n *Kh2= 14.930669 *#N1= 10.C37349

THIS PAGE IS BEST QUALITY PRACTICABLE FROM COPY FURNISHED TO DDC

FROM COPY FURNISHED TO DDC 6[[55F5 keloc 24555556=04.ksD#e=0.55999591E-04.ksCDD=0.4999959596=05.kSCFC=0.45555556=(5.ENTSC=0.4595564E-01.8ENDSC= keloc c.4555544E-01 kenoc c.455544E-01 kenoc EPCCNC EPCCNC EFCCNC EFT = 0.5(555555 AIRTAGE AIRTAG .MASSOS= . ++0R= .AREADS- 116.COC00 . hACRP- 16.750003 +MASSSC= 7551.3564 .AREAME= 6537.CCC0 24442.000 .MASSEC= +LTUBDS= 5.3299595 .LHTRDF= 20.00000 . Fr ASSC= 567.0000 . PASSMB= 28152.000 .LTUEEC- 15.500000 *NTUBSC= 245.C0000 COCC000.4 =025844. .NTUBMB= 2842.0030 ,NTUBOD= 2.00CC000 6-000000 12. ATUBEC= 14.0000C0 . NTUBHD= .NTLEDS- 6.COCODOO 10752.990 .LAVSC - 12.70000 .LAVPE- 10.09000 .LAVPD= 15.75000 .LAVCD= 12.500000 *HASSSH. .APASSE-6505556 1.7255555 676550- 1.7255555 6660 CTLECS 1.5555555 1617.0000 1617.00000 45 1476 1564.0000 66640C6 11.565995 6+CACCR 5.3355552 CTLEPE C.E255558 660Ch CTUBEC 1.6355554 66NC

THIS PAGE IS BEST QUALITY PRACTICABLE

THIS PAGE IS BEST QUALITY PRACTICABLE FROM COPY FURNISHED TO DDC 561-715 .x0=.5455 15662-514 x5= 05835 750187.137 . 5845 15965.0000 . 55524429.0789 . 2605 244.25998 . 555526126 5559118955 . 40.265875615-01814 . 555911895 . 40.264824 . 40.264824 . 40.264824 . 40.26582 . 465828 . 465826126

LIST OF REFERENCES

- Rydland, K., Oyvang, K., and Gloersen, T. C., "A Mathematical Model for Dynamic Analysis of a Boiler," International Marine and Shipping Conference (IMAS 73) London, England, June 1973.
- 2. Haraguchi, O. and Akasaka, N., "A Mathematical Model of a Main Boiler for a 60,000 KW Container Ship," International Marine and Shipping Conference (IMAS 73) London, England, June 1973.
- 3. Whalley, R., <u>The Control of Marine Propulsion Plant</u>, Ph.D. Thesis, University of Manchester, Manchester, England, 1976.
- Chien, K. L., and others, "Dynamic Analysis of A Boiler," Transactions of the ASME, V. 80, p. 1809-1819, November, 1958.
- Rohsenow, W. M., and P. Griffith, "Correlation of Maximum Heat Flux Data for Boiling of Saturated Liquids," AICHE-ASME Heat Transfer Symp., Louisville, Ky., 1955.
- Miller, M. L., <u>Multivariable Control of A Marine Boiler</u>, Masters Thesis, Naval Postgraduate School, Monterey, Ca., 1978.
- 7. Babcok and Wilcox Company, Steam, 1972.
- Grimson, E. D., "Correlation and Utilization of New Data on Flow Resistance and Heat Transfer for Cross Flow of Gases over Tube Banks," Trans. ASME, Vol. 59, pp. 583-594, 1937.
- 9. Schlichting, H., <u>Boundary Layer Theory</u>, 6th ed., McGraw Hill, 1968.
- Becker, M., Hernborg, G. and Bode, M., "An Experimental Study of Pressure Gradients for Flow of Boiling Water in a Vertical Round Duct," Part II, Aktiebolaget Atomenergi, Stockholm, 1964.
- Tong, L. S., <u>Boiling Heat Transfer and Two Phase Flow</u>, p. 118, Wiley, 1965.
- Dittus, F. W., and Boelter, L. M. K., Univ. of Calif. (Berkeley) Pub. Eng., Vol. 2, P. 443, 1936.

- Oak Ridge National Laboratory Report ORNL-TM-4248 ORCON 1: A FORTRAN Code for the Calculation of a Steam Condenser of Circular Cross Section, by J. A. Hafford, July 1973.
- 14. Hsu, Y. Y., and Granam, R. W., <u>Transport Processes in</u> <u>Boiling and Two-Phase Systems</u>, p. 34-39, Hemisphere, 1976.

INITIAL DISTRIBUTION LIST

2

2

2

1

- 1. Defense Documentation Center Cameron Station Alexandria, Virginia 22314
- Library, Code 0142
 Naval Postgraduate School Monterey, California 93940
- 3. Department Chairman, Code 69Mx Department of Mechanical Engineering Naval Postgraduate School Monterey, California 93940
- Associate Professor Thomas M. Houlihan, Code 69Hm 5 Department of Mechanical Engineering Naval Postgraduate School Monterey, California 93940
- 5. Curricular Officer, Code 34 Department of Mechanical Engineering Naval Postgradute School Monterey, California 93940
- 6. LCDR Wallace P. Fini Commander Naval Forces Mariannas FPO San Francisco, California 96601
- 7. Associate Professor Robert H. Nunn, Code 69Nn 1 Department of Mechanical Engineering Naval Postgraduate School Monterey, California 93940

