

AD-A066 200

AIR FORCE INST OF TECH WRIGHT-PATTERSON AFB OHIO SCH--ETC F/6 18/12
ISOTOPIC CORRELATION TECHNIQUES AS AN OFF-SITE REACTOR MONITOR.(U)

OCT 78 J L CLARK

AFIT/ONE/PH/78-12


NL

UNCLASSIFIED

1 of 2

AD
A066200





AD A0 66200

LEVEL 1 DDC Cy

P

THIS DOCUMENT IS BEST QUALITY PRACTICE.
THE COPY FURNISHED TO DDC CONTAINED A
SIGNIFICANT NUMBER OF PAGES WHICH DO NOT
REPRODUCE LEGIBLY.



DDC FILE COPY

This document has been approved
for public release and sale; its
distribution is unlimited.

DDDC
RECEIVED
MAR 22 1979
C

79 03 19 019

DISCLAIMER NOTICE

**THIS DOCUMENT IS BEST QUALITY
PRACTICABLE. THE COPY FURNISHED
TO DDC CONTAINED A SIGNIFICANT
NUMBER OF PAGES WHICH DO NOT
REPRODUCE LEGIBLY.**

1

DDC
MAR 22 1979
R
C

6
ISOTOPIC CORRELATION TECHNIQUES
AS AN OFF-SITE REACTOR MONITOR

9
Master's THESIS

14
AFIT/GNE/PH/78-12

10
James L. Clark Jr.
Capt. USMC

11
Oct 78

12
103p.

1473

Approved for public release; distribution unlimited

012 225

JB

79 03 19 019

ISOTOPIC CORRELATION TECHNIQUES
AS AN OFF-SITE REACTOR MONITOR

THESIS

Presented to the Faculty of the School of Engineering
of the Air Force Institute of Technology
Air University
in Partial Fulfillment of the
Requirements for the Degree of
Master of Science

By

James L. Clark Jr., B.S.
Captain USMC
Graduate Nuclear Effects

October 1978

Approved for public release; distribution unlimited

PREFACE

I would like to express my appreciation to my advisors, Lt. David Hardin and Professor Richard Hagee, for their guidance in the development of this thesis.

A debt of gratitude is owed to Eleanor Bonsteel for her patience in typing this work.

J. L. Clark

ACCESSION for	
NTIS	White Section <input checked="" type="checkbox"/>
DOC	Buff Section <input type="checkbox"/>
UNANNOUNCED	<input type="checkbox"/>
IDENTIFICATION _____	
BY _____	
DISTRIBUTION IN AGENCY CODES	
SPECIAL	
A	23 E.L.

Contents

	Page
Preface	ii
List of Figures	iv
List of Tables	vi
Abstract	vii
I. Introduction	1
II. Theoretical Analysis of ICT	5
III. Experimental Validation of Cesium and Neodymium Ratios	13
IV. Power History Dependence of the Activity Ratio Cs134/Cs137 as an indicator of Burnup	29
V. Escape from Fuel to Environment	51
Escape from Fuel Matrix	51
Breach of Fuel Cladding	58
Escape from Primary Coolant to Environment	63
VI. Detection	66
VII. Results, Conclusions and Recommendations.	70
Bibliography	72
Appendix A: Krypton and Xenon Effluent Concen- trations versus Background Concentrations	77
Appendix B: Cesium Production Equations	80
Appendix C: Program TEST	82
Appendix D: Program YCSFOUR	85

List of Figures

Figure	Page
1 Cs134/137 activity ratio at shutdown versus integrated neutron flux for different values of neutron flux and irradiation time	12
2 Partial Gamma Spectrum for Vak Fuel Assembly	16
3 Burnup versus Cs134/Cs137 activity ratio at 0.42 years cooling time for different gamma lines of Cs134	18
4 U235 depletion versus Cs134/137 activity ratio at 0.42 years cooling time for different gamma lines of Cs134	19
5 Burnup versus Cs134/137 activity ratio for different gamma lines of Cs134	21
6 Influence of the fuel enrichment on the correlation between Cs134/Cs137 and Pu/U	25
7 Influence of the power rating on the correlation between Cs134/Cs137 and Pu/U	25
8 Burnup versus Nd146/Nd145	28
9 Production scheme for Cs134	31
10 MACSYMA 272 solution of a differential equation	37
11 Production scheme for Cs137	38
12 Cs134 buildup versus time for codes TEST and ORIGEN	42
13 Cs137 buildup versus time for codes TEST and ORIGEN	44
14 Cs134/Cs137 versus time for codes TEST and ORIGEN	45
15 Fission product escape mechanisms from fuel to primary coolant	52

16	Fractional release versus time	57
17	Fission product escape mechanisms from primary coolant to environment	64

List of Tables

Table	Page
I. Nuclear Data for Fissile Isotopes	32
II. Nuclear Data for Cesium Isotopes and Their Precursors	33
III. Symbology and Sources of Nuclear Data	34
IV. Isotopic Concentrations of Actinides and Their Daughters as a Function of Irradiation Time	40
V. Isotopic Concentrations of Fission Products as a Function of Irradiation Time	41
VI. Activity Ratio Cs_{134}/Cs_{137} for Different Power Histories	47
VII. Activity Ratio Cs_{134}/Cs_{137} for Different Power Histories	47

Abstract

↓

The feasibility of using the mass ratio $Nd146/Nd145$ and the activity ratio $Cs134/Cs137$ as off-site indicators of bomb-grade plutonium production in commercial light water reactors is examined. The theoretical basis of these ratios as on-site indicators of fluence is developed and experimental validation of their utility as such is examined. The escape rate of cesium and neodymium is approximated and detection limits determined. Although both ratios are experimentally validated as indicators of fluence, neither cesium nor neodymium escapes a reactor in great enough concentration to be accurately measured off-site. ↙

ISOTOPIIC CORRELATION TECHNIQUES
AS AN OFF-SITE REACTOR MONITOR

I. Introduction

The United States would like to export nuclear reactor technology and fuel without contributing to the proliferation of nuclear weapons. Prospective third world customers do not possess the technology to convert commercial uranium fuel to bomb-grade uranium; this requires an inversion of the ratio of U238/U235, which is 97/3 for a representative light water reactor (LWR) fuel. However, absorption of fast neutrons from fissioning U235 converts U238 into Pu239. Pu239 has nuclear properties similar to those of U235; it can be used as reactor fuel or weapon fuel. The continuous conversion of U238 to Pu239 in a power reactor burning U235 is the proliferation concern.

If the Pu239 is not removed from the reactor core soon after its formation, it too absorbs neutrons and is converted to Pu240. Substantial amounts of Pu240 in a mixture of the two plutonium isotopes makes the plutonium unusable in a weapon; moreover, the separation of these isotopes is even more difficult than the enrichment of uranium. Economical generation of power requires a long, sustained fission cycle; production of bomb-grade plutonium, hereafter referred to as Pu239 isolation, requires frequent

shutdown for Pu239 removal. Obviously, on-site inspection to determine length of fission cycle is the most straightforward method for determining whether a reactor is being used for production of power or Pu239 isolation.

Another method for determining Pu239 isolation involves examination of irradiated fuel elements. Weitkamp has demonstrated a linear relationship between U235 depletion and the ratio Pu240/Pu239 (Ref 1:212). Data generated by Origen, the Oak Ridge National Laboratories Isotope Generation and Depletion Code, verifies this relationship; U235 depletion and the ratio Pu240/Pu239 have a linear correlation factor of 0.9995 (Ref 2:106). Determination of U235 depletion, or burnup, of a fuel element indicates the relative amounts of Pu240 and Pu239; low burnup infers Pu239 isolation. One method of determining fuel burnup is called isotopic correlation techniques (ICT); it is based on the fact that the ratio of certain fission product nuclides varies systematically with fuel burnup. Use of a ratio eliminates the need for knowledge of the original fuel mass.

ICT have demonstrated their utility as an on-site safeguards technique for determining Pu239 isolation; they are also used at fuel recycling facilities to verify fissile content of incoming shipments. The problem addressed herein is the feasibility of using isotopic correlation techniques to monitor, off-site, for production of bomb-grade plutonium in a power reactor.

Goodwin, dealing with the same problem, developed a set of criteria which a nuclide ratio must meet if off-site application of ICT is to be possible (Ref 3:10). The essential elements of those criteria are:

- (1) The nuclides must be isotopes of the same element.
- (2) This element's chemical properties must enable it to escape from the fuel and reactor.
- (3) The isotopic ratio must be measurable off-site.

Goodwin predicts that in 1982, 75% of the world's reactors will be LWR's, and that 92% of the world's reactors will be using slightly enriched (1-3%) uranium dioxide (Ref 3:13,15). Only LWR's burning slightly enriched uranium dioxide will be considered.

Isotopic correlations have been the subject of both theoretical and experimental investigation (Ref 4:426). Theoretical investigation is generally carried out by performing accurate burnup calculations, from which correlations are derived. Experimental investigation is based on detailed measurement of irradiated fuel isotopic composition, from which correlations are derived.

Analysis of the off-site application of ICT began with a literature survey of theoretical correlation investigations. Isotopic ratios thereby identified were evaluated against Goodwin's criteria; the ratios Cs134/Cs137 and Nd146/Nd145 were judged suitable. A literature survey of experimental investigations of these two ratios was

conducted to validate them as indicators of fuel depletion. The literature revealed a power history dependence of the cesium ratio, but the degree of this dependence and its impact on the utility of the cesium ratio as a burnup indicator, independent of knowledge about power history, were not clear. Calculations were performed to determine the degree and impact of this dependence. The escape mechanisms from fuel to environment were examined and escape rates estimated. These escape rates were coupled to the dilution processes operating on the two reactor effluents considered, stack gas and coolant water, and limits of ratio measurability predicted.

II. Theoretical Analysis of ICT

The evolution of isotopic correlation techniques began with W. J. Maeck's proposal, in 1965, that ratios of fission product nuclides be used for determination of nuclear fuel burnup (Ref 5). At that time, determination of burnup by fission product analysis was based on the quantitative measurement of a selected fission product nuclide. Use of a ratio instead of an absolute atom abundance circumvented the requirements for complete sample dissolution and volume measurements.

Maeck's method was based on the premise that for stable fission product A, with large capture cross section, and stable fission product A+1, with small capture cross section, the ratio A+1/A increases exponentially with irradiation time. His calculations indicated that the ratios Nd144/Nd143, Kr84/Kr83, and Xe132/Xe131 were suitable for burnup determination.

The first interest in radionuclide ratios as indicators of fuel burnup was demonstrated in 1968 by Hick and Lammer (Ref 6). They developed a computer code, IRREL, for calculation of fission product activities as a function of fluence and determined that the activity ratio Cs134/Cs137 was an effective measure of fluence. Fluence is a measure of fuel exposure; fuel depletion

is easily calculated from the relationships:

$$N_{235}^U = N_{235}^{(0)U} e^{-(\sigma_a \Phi)} \quad (1)$$

$$U_{235} \text{ DEPLETION} = \left(N_{235}^{(0)U} - N_{235}^U \right) / N_{235}^{(0)U} \quad (2)$$

where

$$N_{235}^{(0)U} = \text{initial amount of U235}$$

$$N_{235}^U = \text{amount of U235 at fluence } \Phi$$

$$\sigma_a = \text{absorption cross section of U235}$$

$$\Phi = \text{fluence}$$

The most complete compilation of isotopic ratios for LWR fuels is that of the Joint Research Center of Euratom (Ref 4:427). They identify the following ratios as indicators of U235 depletion: Cs134/Cs137, Kr84/Kr86, Kr86/Kr83, Kr84/Kr83, Xe132/Xe131, Xe134/Xe131, Xe132/Xe134, Nd146/Nd145, Nd146/Nd148, Nd148/Nd145. Two ratios of neodymium isotopes identified by Maeck (Ref 5:15) are ignored in the preceding compilation; they are Nd144/Nd143 and Nd146/Nd143. These twelve ratios meet the first of Goodwin's criteria. Their escape potential and off-site measurability must be determined. Since escape potential is determined by chemical characteristics, use of same-

element ratios simplifies escape-path analysis. The important determinants of escape potential are state (solid, liquid, gas) and chemical reactivity. Escape potential increases as state changes from solid to gas and decreases as reactivity increases.

Krypton and xenon are inert gases; their escape potential is extremely high. However, all their isotopes of interest herein are naturally occurring. Kr83 and Xe131 have isomeric states, but the half-life of Kr83m is less than two hours and only 8×10^{-3} of the Xe131 passes through the isomeric state (Ref 7). Disregarding these isomeric states, calculations were performed to compare expected effluent concentrations of the three krypton isotopes and the three xenon isotopes to environmental background concentrations. Using data from the BWR at Oyster Creek, N. J., it was determined that the stack gas contained concentrations on the order of 1×10^6 per cc of the Krypton isotopes and 1×10^7 per cc of the Xenon isotopes. The atmospheric background concentrations were calculated to be on the order of 1×10^{12} per cc for krypton isotopes and 1×10^{11} for xenon isotopes. These calculations are contained in Appendix A. Krypton and xenon are not present in measurable amount in coolant water effluent. Clearly, krypton and xenon do not meet the off-site measurability criteria; they will not be considered further.

The escape potential of the neodymium isotopes would appear to be low; neodymium is a non-volatile reactive rare-earth metal. Its melting point is 1024 degrees (centigrade) and its boiling point is 3027 degrees (Ref 8:B 121). Escape data kept by reactor operators and agencies regulating them deal only with radionuclides (Ref 9). Of the neodymium isotopes of concern herein, only Nd144 is radioactive, but its half-life of 5E15 years causes its radioactivity to be commonly disregarded. As demonstrated in Appendix A, measured concentrations of one isotope can be used to infer concentrations of other isotopes of that element. The only indication of neodymium escape found in the literature was a Nd147 concentration of 3E-7 Curies per liter of coolant in a BWR (Ref 10:8). This activity concentration equates to a number density of 1.54E10 atoms of Nd147 per liter. Thermal-neutron fission of U235 results in the following yields:

6.03% Nd143, 5.62% Nd144, 3.98% Nd145,
3.07% Nd146, 2.70% Nd147, 1.71% Nd148

(Ref 11:98). All these isotopes could be expected to have been present in the coolant with concentrations of the same order of magnitude as Nd147.

Although 1E10 atoms per liter is certainly a measurable amount, neodymium's ability to escape from the coolant to the environment is uncertain. If neodymium does escape to the environment, its off-site measurability will be complicated by the natural occurrence of all isotopes of

interest (Ref 8:B51). Further consideration of neodymium's escape potential and off-site measurability is deferred until the analysis of escape mechanisms is completed. Since the neodymium ratios are, at this point, of questionable utility, experimental validation for only one of the ratios will be considered. In addition to being cited as an indicator of U235 depletion, the ratio Nd146/Nd145 shows a direct relationship to Pu240 content (Ref 1:212); only this neodymium ratio will be considered further.

The chemical characteristics of cesium do not immediately categorize its escape potential; although volatile (boiling point of 690 degrees), it is the most electropositive (reactive) element (Ref 8:B106). However, one environmental study has shown that Cs134 and Cs137 can be found in measurable concentrations in both the stack gas and discharge canal of a PWR (Ref 12). Since neither Cs134 nor Cs137 occur naturally (Ref 8:B46), off-site measurability will not be complicated by natural background concentrations. The cesium ratio appears to be the best candidate for off-site application.

The literature survey of theoretical investigations of ICT upon which the preceding selection of ratios was based revealed three other items of interest. The first of these items is the creation by the International Atomic Energy Agency (IAEA) of an ICT data bank; data has been collected from reprocessing plants and analytical laboratories and stored with a common format for ease of subse-

quent retrieval (Ref 13). The ratio chosen as an on-site indicator of U235 depletion was Cs134/Cs137. A code (ISOCORR) has been developed which performs the theoretical analysis of correlations and compares the calculated data with the experimental data stored in this bank(Ref 14).

The second item of interest is a wide concern over the sensitivity of theoretical isotopic correlations to fission product nuclear data (FPND) accuracies (Ref 1, 15-17). Weitkamp identifies the yield of Cs137 as the only significant FPND involved in the production scheme of Cs137 (Ref 17:201). He apparently disregards the short-lived precursors of Cs137 (I137 and Xe137). Weitkamp lists the yield and capture cross section of Cs133 and the capture cross section of Cs134 as the significant FPND in the production scheme of Cs134; again, he has disregarded the precursors of Cs133. As the uncertainties in cross sections are greater than the uncertainties in yields, the accuracy of the cross sections of Cs133 and Cs134 is the limiting factor in calculating a Cs134/Cs137 ratio. A 1% error in the cross section of Cs133 causes a 1% error in the amount of Cs134 (Ref 17:200). The important FPND in the calculation of the Nd146/Nd145 ratio are capture cross sections of Nd144, Nd145 and yields of Nd145, Nd146 (Ref 17:205).

The final item is an indirect reference to the power dependency of the Cs134/Cs137 ratio as a measure of fluence; this dependency was to become a concern during examination of the experimental investigations of ICT. Fig. 1 shows the

theoretical variation of the Cs134/Cs137 activity ratio with irradiation time and neutron flux for fission of U235. The intersections of the flux and time lines are the plotted points. The two circled points both represent the same fluence; varying the flux by a factor of two changes the Cs134/Cs137 ratio by 27%.




Fig. 1. Cs134/Cs137 Activity Ratio at Shutdown Versus Integrated Neutron Flux for Different values of Neutron Flux and Irradiation Time (Ref. 15:241)

III. Experimental Validation of Cesium and Neodymium Ratios

Selection of the ratios $Cs134/Cs137$ and $Nd146/Nd145$ as prospective off-site indicators of fuel burnup is based on their theoretical utility as on-site burnup indicators; experimental validation of their on-site utility was the subject of a second literature survey. The work of Hick and Lammer (Ref 18) demonstrates an interesting application of both the theoretical and experimental aspects of isotopic correlations; they combine gamma-spectrometric measurements and theoretical calculations to establish a fission product inventory which is more accurate and complete than is possible with either experiment or calculation alone. Their code (IRREL) for calculation of fission product inventory requires neutron flux input data (value and spectral shape) of unavailable accuracy. On the other hand, gamma-spectrometric measurements are sufficiently accurate for only a limited set of fission products; due to mutual line interference or absence of gamma lines, many isotopes cannot be measured accurately. Hick and Lammer use experimental results for $Cs134$ and $Cs137$ and a knowledge of the irradiation history to derive proper neutron flux input data for IRREL; IRREL then is able to compute a fission product inventory of any desired degree of completeness.

The relationship between fluence and fuel depletion is defined in the preceding chapter; another measure of fuel depletion, or burnup, is preferred in experimental work. This unit is the megawatt-day per tonne (MWD/T). As the name suggests, fuel in a reactor operating at a specific power level of one megawatt (thermal) per tonne (1000 Kilograms) of fuel initially present will be depleted by one MWD/T in one day. The fuel is considered to consist of heavy elements only; in fuel elements of uranium dioxide with stainless steel cladding, only the weight of the uranium dioxide is considered in the unit MWD/T (Ref 19:260).

Dragnev and Beets examine the feasibility of using non-destructive gamma spectrometry measurements of irradiated fuel assemblies to determine the type of fuel (pre-irradiation enrichment), the history of its irradiation, and the operational history of the reactor during the period when the measured fuel was in the core of the reactor (Ref 20). The irradiated fuel is from the German Vak reactor; the fuel elements are made of pellets with 1.27 cm outer diameter and 1.59 cm length. A fuel rod is composed of two 48-pellet sections; the rod diameter is 1.45 cm. The fuel consists of 2.33% enriched uranium in the form of sintered uranium dioxide; cladding is 0.85 mm Zircaloy-2.

Since it was planned to measure each fuel assembly in only one spot along its axis, measurements of the axial distribution of burnup are made to determine the best spot for measurement. The ratios between the intensities of the

605KeV gamma peak (Cs134) versus the 663 KeV peak (Cs137) and the 796 KeV peak (Cs134) versus the 663 KeV peak (Cs137) are used as burnup monitors. The results can be summarized as follows:

- (1) The axial distributions of the activity ratios follow qualitatively the distribution of the integrated neutron flux at different points of the reactor core.
- (2) The axial distribution of Cs134 activities decreases steeply to the ends of the fuel assemblies; this rapid decrease is caused by the fact that Cs134 accumulation is nearly proportional to the second degree of the integrated neutron flux.
- (3) The activity ratio Cs134/Cs137 as a burnup monitor gives the correct burnup value despite the lack of fuel in the center of the rod (void between the two sections described above)

Fig. 2 shows the results of a single point measurement of the gamma spectrum of a Vak fuel assembly after 1.58 years cooling time. The peak labeled 605 is the 605 KeV peak of Cs134; the other peaks of interest are 662 (Cs137) and 796 (Cs134, but mislabeled as Cs137). The quality of the figure is poor because it was duplicated from microfiche. The areas under the full-energy peaks are related to the amount of corresponding gamma radioactive fission products in the measured fuel assembly.




Fig. 2. Partial Gamma Spectrum for Vak Fuel Assembly (Ref. 20:34)

Single point measurements of the activity ratios $Cs134(605 \text{ KeV})/Cs137$ and $Cs134(796 \text{ KeV})/Cs137$ for eleven Vak fuel assemblies with cooling time of 0.42 years are reported. Fig. 3 plots these measurements against the calculated burnup of each fuel assembly; the circled points represent the reported data. As the reported data represents a limited range of burnups, a linear least-squares fit of the data was calculated (Ref 21:43). The points marked by x represent a projection of this fit. The data associated with the 605 KeV peak has a linear correlation coefficient (R) of 0.737, while for the 796 KeV data, $R=0.899$.

Both the initial and final amounts of U235 for each fuel assembly are reported, permitting calculation of U235 depletion. Fig. 4 plots U235 depletion against the two activity ratios. Again, circled points represent reported data, and x's represent a least-squares fit. For the 605 KeV data, $R=0.706$; for the 796 KeV data, $R=0.896$.

Using the 796 KeV data, Dragnev and Beets formulated a method for making the $Cs134/Cs137$ ratio appear to be a far better indicator of burnup than demonstrated by Fig. 3. Their treatment involves dividing each activity ratio by the activity ratio of the fuel assembly with highest burnup, and dividing each burnup by the highest burnup; they calculate a linear correlation factor of 0.993 for the relationship between relative burnup and relative activity ratio.

Bresesti and Peroni report on experimental work corre-




Fig. 3. Burnup Versus Cs134/Cs137 Activity Ratio at 0.42 Years Cooling Time for Different Gamma Lines of Cs134




Fig. 4. U235 depletion versus Cs134/Cs137 activity ratio at 0.42 years cooling time for different gamma lines of Cs134

lating the Cs134/Cs137 activity ratio to the ratio Pu/U in irradiated fuel assemblies (Ref 23); fortunately, their results are presented in a manner which permits the Cs134/Cs137 activity ratio to be correlated to burnup. They measure the gamma spectrum of twelve fuel assemblies in the spent fuel pond of the Trino PWR reactor; cooling time is not reported. The burnup values are generated by a two-dimensional burnup code (BQRSQUID) using three neutron energy groups (2 thermal, 1 fast); previous experiments validate the accuracy of the code. While Dragnev and Beets measure each assembly at only a single point, Bresesti and Peroni measure each corner of the assembly at nine levels. The countings for the nine points are summed, and then the areas of the photopeaks for the four corners are summed to give an integral value for the entire fuel assembly. This integral spectrum for the fuel assembly corresponds to a total counting time of 96 minutes.

Three sets of activity ratios are reported: Cs134(605 KeV)/Cs137 (663KeV), Cs134 (796+802)/Cs137(662), Cs134 (1365)/Cs137(662). These ratios are plotted versus burnup in Fig. 5; the circles represent data from fuel assemblies with an initial enrichment of 3.13%, and the x's represent fuel assemblies with an initial enrichment of 3.90%. The lines represent a least squares fit to the data; R values are: 0.8393 for the 605 KeV data, 0.5679 for the (796+802) KeV data, 0.6946 for the 1365 KeV data.

Bresesti and Peroni also correlate Cs137 activity to




Fig. 5. Burnup Versus Cs134/Cs137 Activity Ratio for different Gamma Lines of Cs134

burnup; R is 0.865 for this correlation. This relationship is of interest because the next experiment to be examined deals with correlation of the activity ratio Cs_{134}/Cs_{137} to Cs_{137} activity.

Leender assumes a linear relationship between burnup and Cs_{137} activity; his experiment examines the relationship between Cs_{137} activity and the activity ratio Cs_{134}/Cs_{137} (Ref 24). He measures the gamma spectrum of two sets of fuel rods from the Sena reactor; one set has half the burnup of the other (actual burnups not specified). Cs_{134} activity is considered to be given by the mean of the 605 and 796 KeV peaks. The relationship between Cs_{137} activity and the Cs_{134}/Cs_{137} activity ratio for fuel rods with the lesser burnup has an R of 0.9934. R for the greater burnup rods is 0.9955.

Beets, Bemelmans and Pirard examine the Cs_{134}/Cs_{137} activity ratio correlation to burnup in two phases (Ref 25). The first phase involves the non-destructive gamma spectrometric measurement of fuel assemblies in the spent fuel pool, while the second phase deals with destructive measurement (fuel is decladded and dissolved). This experiment was intended to determine the effect of mutual shielding and attenuation when entire fuel assemblies are measured. In the non-destructive phase, the gamma spectrum for each fuel assembly is measured in a single point, at the middle of the active length; the time of measurement is 15 minutes. To account for attenuation and detector efficiency effects,

a correction factor F is determined for each measurement. F is given by the relation

$$F = 0.93(C_{796} + C_{802}) / C_{605} \quad (3)$$

where the C's are the areas under the Cs134 peaks. A linear correction is then applied to the measured Cs137 activity (662 KeV peak) using the relation

$$A_{CALC}^{137} = F[(C_{662} - C_{605}) / (C_{796} + C_{802} - C_{605})] A_{MEAS}^{137} \quad (4)$$

where A is activity, and C662 is the area under the 662 KeV peak of Cs137. The activity ratio Cs134/Cs137 refers to the measured Cs134 activity, which is determined using the 605 KeV peak, and the calculated Cs137 activity, which is defined by Eq(4). This activity ratio is correlated to the weighted burnup, where weighted burnup is defined by the expression:

$$BW = \sum_{i=1}^n B(W_i/W) e^{(t_i - t_m)} \quad (5)$$

where

- BW = weighted burnup
- n = number of months of fuel cycle
- B = burnup
- W_i = monthly integrated power
- W = total integrated power
- t_i = time of irradiation
- t_m = time of measurement

The non-destructive phase of this experiment results in an R of 0.9946 for the relationship between the Cs134/Cs137 activity ratio and the weighted burnup.

The destructive phase involves chemical decladding and dissolution of the fuel with nitric acid; the gamma spectrum of the solution is then measured. The activity ratio and weighted burnup are determined in the same manner as in the non-destructive phase; R for the destructive measurement phase is 0.9894.

Gualandi presents interesting results on the correlation between the Cs134/Cs137 activity ratio and the mass ratio Pu/U (Ref 26). Unfortunately, his reported data is too incomplete to permit its application to a burnup correlation as was done with the work of Bresesti. However, reexamination of the Bresesti data (Ref 23:4) demonstrates a linear relationship between burnup and the Pu/U ratio (R=0.9992); this justifies qualitative application of Gualandi's results to the correlation between the Cs134/Cs137 activity ratio and burnup. Gualandi shows that initial fuel enrichment has only a slight influence on the Cs134/Cs137 and Pu/U correlation (Fig. 6), while power history has a strong influence (Fig. 7). He concludes that safeguards application (on-site) of the Cs134/Cs137 activity ratio requires a thorough knowledge of power history. Since the absence of information about power history is the premise upon which the requirement for an off-site monitor is based, the degree of power history dependence is of fundamental




Fig. 6. Influence of the Fuel Enrichment on the Correlation Between Cs134/Cs137 and Pu/U (Ref 26:618)




Fig. 7. Influence of the Power Rating on the Correlation between Cs134/Cs137 and Pu/U (Ref. 26:619)

importance. The power history dependence of the Cs134/Cs137 activity ratio as an indicator of burnup is analyzed in the following chapter.

Further information on the on-site application of the Cs134/Cs137 activity ratio is available in references 27 and 28; Ursu examines this ratio as an indicator of cooling time (Ref 29).

The literature survey yielded only one experiment dealing with a neodymium ratio as a burnup monitor; fortunately it examined the one ratio of interest herein, Nd146/Nd145. Before presenting an analysis of that experiment, it is necessary to define a third measure of burnup, atom percent fission. Atom percent fission (F_T) is defined as the number of fissions divided by the initial number of heavy atoms times 100(Ref 16:164). Determination of F_T burnup requires measurement of the number of atoms of a fission product monitor and the number of residual heavy atoms; the fuel specimen is dissolved and mass spectrometry used for measurement of number densities. Burnup is then calculated from the relationship:

$$F_T = 100 \left[\frac{(M/Y)}{(H + M/Y)} \right] \quad (6)$$

where

M = number of atoms of fission product monitor

Y = fractional fission yield of M

H = number of residual heavy atoms

The most exact fission product monitor is Nd148 (Ref 22:59).

Koch examines the correlation between Ft and the mass ratio Nd146/Nd145 (Ref 30); he uses Nd148 as the fission product monitor in determining Ft. Koch calculates a least-squares fit for measurements made on Trino fuel samples and reports the equation; his results are shown in Fig. 8. The circles represent data for the Trino fuel samples; the x's represent data for Sena fuel samples. The Sena fuel data is not used in the linear regression.

In summary, the linear relationship between the Cs134/Cs137 activity ratio and U235 depletion is well documented experimentally, although many measures of U235 depletion are used. Experimental validation of a linear relationship between the mass ratio Nd146/Nd145 and U235 depletion is sparse but convincing.

Gualandi (Ref 26) raises the issue of a power history dependence when examining the value of the cesium ratio as a burnup indicator; power history dependence is best defined by using fluence as a measure of burnup. For constant flux, fluence is the product of flux and time; a particular fluence can be obtained by different combinations of flux and time. Gualandi contends that the Cs134/Cs137 activity ratio is a function of flux and time rather than an independent function of fluence. The degree of this power history dependence is critical to the utility of the cesium ratio as an off-site indicator of burnup.




Fig. 8. Burnup versus Nd146/Nd145

IV. Power History Dependence of the Activity Ratio
Cs134/Cs137 as an Indicator of Burnup

Determination of the degree of power history dependence of the activity ratio Cs134/Cs137 as an indicator of burnup requires a computer code which can calculate the accumulation and decay of fission products for varying power histories. The accumulation and decay of fission products in fuel elements can be described by a set of linear differential equations of the form (Ref 18:19):

$$dN_j^i/dt = \sum_f N_l^k \sigma_f \delta_j^i \phi + N_{j-1}^i \sigma_c \phi + \lambda N_j^{i-1} - N_j^i \sigma_c \phi - \lambda N_j^i \quad (7)$$

where

- N_j^i = number of atoms of isotope of atomic number i and mass j
 \sum_f = sum over all fissile isotopes present in fuel
 N_l^k = number of atoms of fissile isotope of atomic number k and mass l
 σ_f = fission cross section (barns)
 δ_j^i = direct fission yield of fission product (i,j)
 ϕ = neutron flux ($\text{cm}^{-2}\text{sec}^{-1}$)
 σ_c = thermal capture cross section (barns)
 λ = decay constant (sec^{-1})

For each fission product isotope a separate differential equation exists and these equations are coupled via N_{j-1}^i and

N_j^{i-1} ; these differential equations can be solved analytically by Laplace Transform for a time constant ϕ .

Several assumptions are required to develop a simple fission product inventory code; the first of these assumptions is that the neutron flux is time constant. Actually, the irradiation history in a reactor consists of a series of constant power cycles with the neutron flux varying as a function of the fissile inventory. The second necessary assumption is that U235 is the only fissile isotope in the fuel; this assumption disregards fast fission of U238 and also the fission of accumulating plutonium.

Fig. 9 shows the production scheme for Cs134 (Ref 31). Tables I and II show the nuclear data required; Table III defines the symbols used in the two preceding tables (Ref 2:65,72,79).

The final assumption is that capture cross sections less than one barn can be disregarded; the validity of this assumption will be examined when the code is completed. The largest capture cross section in the mass 132 chain (Fig. 9) is that of Xe132; since this cross section is less than 1 barn, only the mass 133 chain is required in the production scheme of Cs134. The coupled equations which must be solved are

$$\begin{aligned} dN_{133}^{56}/dt = & N_{235}^U \sigma_f \delta_{133}^{56} \phi + N_{132}^{56} \sigma_c \phi + \lambda N_{133}^{56} \\ & - N_{133}^{56} \sigma_c \phi - \lambda N_{133}^{56} \end{aligned} \quad (8)$$

Cs-134

Cs-133

Xe

I

Te

Sb-133

Fig. 9. Production Scheme for Cs134

TABLE I

Nuclear Data for Fissile/Isotopes (Ref. 2:72)

NUCL	DLAM	FD1	FP	FP1	YT	PA	FSF P+6	SIGK6	YMG21	STGF	SIGK2H	SIGK3H	O	PG
PA230	2.85E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.533	0.79
U232	3.05E-10	0.0	0.0	0.0	0.0	1.000	0.0	1.43E 02 0.0	0.0	1.55E 02 5.20E-03	6.00E-05	6.00E-05	5.818	0.0
U233	1.36E-13	0.0	0.0	0.0	0.0	1.000	0.0	7.99E 01 0.0	0.0	5.80E 02 6.60E-03	1.26E-05	1.26E-05	8.910	0.00
U238	8.89E-14	0.0	0.0	0.0	0.0	1.000	0.0	2.81E 02 0.0	0.0	3.86E 00 1.44E-02	8.80E-05	8.80E-05	8.856	0.0
U235	3.09E-17	0.0	0.0	0.0	0.0	1.000	0.0	1.05E 02 0.0	0.0	4.09E 02 3.00E-02	9.40E-05	9.40E-05	4.681	0.0
U236	9.19E-16	0.0	0.0	0.0	0.0	1.000	0.0	7.37E 01 0.0	0.0	3.24E 00 1.30E-02	1.44E-04	1.44E-04	4.573	0.0
U237	1.19E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.76E 00 0.0	0.0	0.0	0.112	0.07
U238	4.87E-18	0.0	0.0	0.0	0.0	1.000	0.0	8.35E 00 0.0	0.0	5.98E-01 3.00E-02	3.00E-04	3.00E-04	8.259	0.0
U239	4.92E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.400	0.0
U240	1.37E-05	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.211	0.21
U236	8.75E-06	0.0	0.830	0.0	0.0	0.0	0.0	0.0	0.0	3.58E 00 0.0	0.0	0.0	0.476	0.0
U237	1.03E-14	0.0	0.0	0.0	0.0	1.000	0.0	3.59E 02 0.0	0.0	2.45E 00 2.60E-03	1.90E-05	1.90E-05	8.556	0.0
U238	3.82E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.01E 03 0.0	0.0	0.0	0.839	0.68
U239	3.41E-06	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.228	0.23
U240H	1.58E-03	0.0	0.0	0.0	0.0	0.0	0.0	1.76E 02 0.0	0.0	0.0	0.0	0.0	1.065	0.32
U240	1.83E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.280	0.0
U236	7.71E-09	0.0	0.0	0.0	0.0	1.000	0.0	0.0	0.0	1.07E 02 0.0	0.0	0.0	5.870	0.0
U238	2.47E-10	0.0	0.0	0.0	0.0	1.000	0.0	3.66E 02 0.0	0.0	1.94E 01 5.20E-03	6.00E-05	6.00E-05	5.587	0.0
U239	9.00E-13	0.0	0.0	0.0	0.0	1.000	0.0	4.43E 02 0.0	0.0	1.08E 03 1.00E-02	1.16E-04	1.16E-04	5.243	0.0
U240	3.25E-12	0.0	0.0	0.0	0.0	1.000	0.0	8.97E 02 0.0	0.0	2.46E 00 7.00E-03	7.00E-05	7.00E-05	5.255	0.0
U241	1.50E-09	0.0	0.0	0.0	0.0	0.000	0.0	3.94E 02 0.0	0.0	1.11E 03 1.58E-02	1.58E-04	1.58E-04	0.007	0.0
U242	5.80E-14	0.0	0.0	0.0	0.0	1.000	5.3	4.35E 02 0.0	0.0	2.22E-01 1.48E-02	1.48E-04	1.48E-04	8.980	0.0
U243	3.87E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.58E 00 0.0	0.0	0.0	0.239	0.01
U244	2.65E-16	0.0	0.0	0.0	0.0	0.999	1260.0	1.01E 00 0.0	0.0	0.0	0.0	0.0	4.690	0.0
U245	1.82E-05	0.0	0.0	0.0	0.0	0.0	0.0	1.75E 02 0.0	0.0	0.0	0.0	0.0	0.400	0.0
U241	5.07E-11	0.0	0.0	0.0	0.0	1.000	0.0	1.30E 03 0.162	0.0	4.19E 00 1.00E-03	1.00E-05	1.00E-05	5.630	0.0
U242H	1.45E-10	0.0	0.0	0.0	1.000	0.0	0.0	1.26E 03 0.0	0.0	3.80E 03 3.70E-02	3.80E-04	3.80E-04	0.048	0.0
U242	1.20E-05	0.0	0.180	0.0	0.0	0.0	0.0	0.0	0.0	1.83E 03 3.70E-02	3.80E-04	3.80E-04	0.225	0.0
U243	2.87E-12	0.0	0.0	0.0	0.0	1.000	0.0	5.66E 02 0.0	0.0	7.84E-01 0.0	0.0	0.0	6.158	0.12
U244	4.40E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.45E 03 0.0	0.0	0.0	1.256	0.57
U245	9.30E-05	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.313	0.0
U242	4.32E-08	0.0	0.0	0.0	0.0	1.000	0.0	1.90E 01 0.0	0.0	3.16E 00 0.0	0.0	0.0	6.217	0.0
U243	6.86E-10	0.0	0.0	0.0	0.0	1.000	0.0	2.93E 02 0.0	0.0	9.95E 00 1.00E-02	1.00E-04	1.00E-04	6.201	0.01
U244	1.21E-09	0.0	0.0	0.0	0.0	1.000	0.0	2.23E 02 0.0	0.0	4.92E 00 0.0	0.0	0.0	5.902	0.0
U245	2.66E-12	0.0	0.0	0.0	0.0	1.000	0.0	2.57E 02 0.0	0.0	1.47E 03 0.0	0.0	0.0	5.295	0.01
U246	4.66E-12	0.0	0.0	0.0	0.0	1.000	262.0	4.11E 01 0.0	0.0	0.0	0.0	0.0	5.536	0.00
U247	1.34E-15	0.0	0.0	0.0	0.0	1.000	0.0	2.04E 02 0.0	0.0	8.29E 02 0.0	0.0	0.0	5.300	0.0
U248	6.24E-14	0.0	0.0	0.0	0.0	0.917	83300.0	5.89E 01 0.0	0.0	3.16E 01 0.0	0.0	0.0	21.410	0.00
U249	1.80E-04	0.0	0.0	0.0	0.0	0.0	0.0	1.77E 00 0.0	0.0	0.0	0.0	0.0	0.300	0.0
U250	1.26E-12	0.0	0.0	0.0	0.0	0.0	100000.0	1.26E 00 0.0	0.0	0.0	0.0	0.0	195.000	0.0
U249	2.55E-08	0.0	0.0	0.0	0.0	0.000	0.0	1.33E 03 0.0	0.0	1.90E 03 0.0	0.0	0.0	0.082	0.00
U250	5.98E-05	0.0	0.0	0.0	0.0	0.0	0.0	2.21E 02 0.0	0.0	1.90E 03 0.0	0.0	0.0	1.507	0.61
U249	6.24E-11	0.0	0.0	0.0	0.0	1.000	0.0	2.85E 02 0.0	0.0	2.05E 03 0.0	0.0	0.0	6.637	0.05
U250	1.68E-09	0.0	0.0	0.0	0.0	0.992	793.0	5.06E 03 0.0	0.0	0.0	0.0	0.0	6.290	0.00
U251	2.84E-11	0.0	0.0	0.0	0.0	1.000	0.0	2.33E 03 0.0	0.0	4.17E 03 0.0	0.0	0.0	6.039	0.02
U252	8.30E-09	0.0	0.0	0.0	0.0	0.969	31000.0	2.72E 01 0.0	0.0	5.69E 01 0.0	0.0	0.0	12.260	0.0
U253	4.50E-07	0.0	0.0	0.0	0.0	0.003	0.0	7.96E 00 0.0	0.0	8.22E 02 0.0	0.0	0.0	0.109	0.0
U254	1.33E-07	0.0	0.0	0.0	0.0	0.003	996900.0	5.81E 02 0.0	0.0	0.0	0.0	0.0	194.400	0.0
U253	3.87E-07	0.0	0.0	0.0	0.0	1.000	0.0	2.18E 02 0.0	0.0	0.0	0.0	0.0	6.737	0.0

TABLE II
Nuclear Data for Cesium Isotopes and their Precursors
(Ref 2:79)

NUCL	DLAN	FBI	FP	FPI	FT	SIGMG	FMG1	Y23	Y25	Y02	Y28	Y89	Q	FG
SB131	3.40E-03	0.0	0.0	0.0	0.0	0.0	0.0	2.90E 00	2.93E 00	1.20E 00	1.92E 00	3.78E 00	2.000 0.0	0.0
SB131	5.02E-04	0.150	0.0	0.0	0.0	0.0	0.500 0.0	0.0	0.0	0.0	1.11E 00	0.0	1.599 0.433	0.0
TE131H	6.42E-06	0.0	0.0	0.0	0.180	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.398 0.867	0.0
TE131	4.62E-08	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.02E-01	0.0	1.277 0.325	0.0
I131	9.97E-07	0.008	0.0	0.0	0.0	3.11E 00	0.0	0.0	0.0	0.0	0.0	0.0	0.589 0.678	0.0
XP131H	6.80E-07	0.0	0.0	0.0	1.000	0.0	0.0	4.90E-01	0.0	0.0	0.0	0.0	0.328 0.500	0.0
XP131	0.0	0.0	0.0	0.0	0.0	3.40E 02	0.0	4.30E 00	4.24E 00	4.20E-01	2.77E 00	5.10E 00	2.000 0.0	0.0
SB132	5.25E-03	0.0	0.0	0.0	0.0	0.0	0.0	4.30E 00	0.0	0.0	0.0	0.0	3.360 0.0	0.0
SB132H	1.58E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.62E 00	0.0	3.360 0.0	0.0
SB132	5.50E-03	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.383 0.627	0.0
TE132	2.47E-06	0.0	0.0	0.0	0.0	0.0	0.500 0.0	0.0	0.0	0.0	4.04E-01	0.0	0.383 0.627	0.0
I132	8.37E-05	0.0	0.0	0.0	0.0	9.46E-01	0.090 0.0	1.40E-01	1.40E-01	1.00E-01	3.03E-01	1.60E-01	2.907 0.817	0.0
XP132	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.38E 00	3.87E 00	2.86E 00	4.54E 00	4.04E 00	2.760 0.0	0.0
SB133	2.75E-03	0.720	0.0	0.0	0.130	0.0	0.0	1.96E 00	2.28E 00	1.82E 00	1.01E 00	2.34E 00	3.038 0.698	0.0
TE133H	2.31E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.736 0.775	0.0
TE133	9.24E-04	0.0	0.0	0.0	0.0	0.0	0.0	4.40E-01	5.00E-01	3.20E-01	0.0	1.53E-01	1.177 0.580	0.0
XP133H	3.55E-06	0.0	0.0	0.0	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.466 0.500	0.0
XP133	1.52E-06	0.0	0.0	0.0	0.0	1.51E 02	0.0	0.0	0.0	0.0	0.0	0.0	0.268 0.310	0.0
CS133	0.0	0.0	0.0	0.0	0.0	1.73E 02	0.085 0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0
SB134	4.62E-01	0.0	0.0	0.0	0.0	0.0	0.0	5.09E 00	6.90E 00	4.60E 00	3.74E 00	6.39E 00	3.878 0.052	0.0
TE134	2.75E-04	0.0	0.0	0.0	0.0	6.32E-02	0.0	0.0	0.0	0.0	2.42E 00	0.0	2.800 0.0	0.0
I134	2.19E-04	0.0	0.0	0.0	0.0	0.0	0.0	6.60E-01	9.00E-01	6.00E-01	5.05E-01	8.30E-01	3.141 0.807	0.0
XP134	0.0	0.0	0.0	0.0	0.0	7.27E-01	0.960 0.0	1.90E-01	2.60E-01	1.70E-01	0.0	2.80E-01	0.0 0.0	0.0
CS134H	6.64E-05	0.0	0.0	0.0	0.990	1.64E 00	0.500 0.0	0.0	0.0	0.0	0.0	0.0	0.291 0.526	0.0
CS134	1.07E-08	0.0	0.0	0.0	0.0	1.07E 02	0.500 0.0	0.0	0.0	0.0	0.0	0.0	1.787 0.891	0.0
BA134	0.0	0.0	0.0	0.0	0.0	6.32E-01	0.160 0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0
TE135	2.39E-02	0.0	0.0	0.0	0.0	0.0	0.0	5.05E 00	6.09E 00	4.50E 00	3.10E 00	5.70E 00	2.630 0.0	0.0
I135	2.87E-05	0.300	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.81E 00	0.0	2.112 0.827	0.0
XP135H	7.41E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.527 1.000	0.0
XP135	2.09E-05	0.0	0.0	0.0	0.0	2.28E 06	0.0	1.11E 00	3.20E-01	1.00E 00	1.01E-01	1.47E 00	0.567 0.840	0.0
CS135H	2.18E-04	0.0	0.0	0.0	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.621 1.000	0.0
CS135	7.32E-15	0.0	0.0	0.0	0.0	3.23E 01	0.0	0.0	0.0	0.0	0.0	0.0	0.092 0.0	0.0
BA135H	6.71E-06	0.0	0.0	0.0	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.054 1.000	0.0
BA135	0.0	0.0	0.0	0.0	0.0	3.16E 00	0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0
I136	8.35E-03	0.0	0.0	0.0	0.0	0.0	0.0	1.80E 00	3.10E 00	2.71E 00	0.0	2.10E 00	8.527 0.589	0.0
TE136	0.0	0.0	0.0	0.0	0.0	1.78E-01	0.0	4.83E 00	3.36E 00	2.94E 00	5.96E 00	8.53E 00	0.0 0.0	0.0
CS136	6.17E-07	0.0	0.0	0.0	0.0	0.0	0.0	1.20E-01	6.80E-03	1.00E-01	3.33E-02	1.10E-01	2.317 0.932	0.0
BA136	0.0	0.0	0.0	0.0	0.0	4.58E 00	0.050 0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0
I137	3.01E-02	0.0	0.0	0.0	0.0	0.0	0.0	6.42E 00	6.00E 00	6.18E 00	0.0	6.47E 00	0.176 0.0	0.0
CS137	2.96E-03	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.26E 00	0.0	2.057 0.198	0.0
CS137	7.32E-10	0.935	0.0	0.0	0.0	1.69E-01	0.0	1.60E-01	1.50E-01	1.50E-01	1.01E-01	1.60E-01	0.276 0.011	0.0
BA137H	8.53E-03	0.0	0.0	0.0	1.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.663 1.000	0.0
BA137	0.0	0.0	0.0	0.0	0.0	3.89E 00	0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0
I138	1.17E-01	0.0	0.0	0.0	0.0	0.0	0.0	6.31E 00	5.74E 00	6.60E 00	0.0	6.31E 00	8.919 0.305	0.0
TE138	6.80E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.56E 00	0.0	1.416 0.297	0.0
CS138	3.59E-04	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.227 0.652	0.0
BA138	0.0	0.0	0.0	0.0	0.0	5.54E-01	0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0
I139	3.87E-01	0.0	0.0	0.0	0.0	0.0	0.0	5.32E 00	5.80E 00	5.69E 00	0.0	8.84E 00	2.000 0.0	0.0
TE139	1.61E-02	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.85E 00	0.0	2.730 0.267	0.0

$$dN_{133}^{Te}/dt = N_{235}^U \sigma_f \delta_{133}^{Te} \phi + N_{132}^{Te} \sigma_c \phi + \lambda N_{133}^{Sb} - N_{133}^{Te} \sigma_a \phi - \lambda N_{133}^{Te} \quad (9)$$

$$dN_{133}^I/dt = N_{235}^U \sigma_f \delta_{133}^I \phi + N_{132}^I \sigma_c \phi + \lambda N_{133}^{Te} - N_{133}^I \sigma_c \phi - \lambda N_{133}^I \quad (10)$$

$$dN_{133}^{Xe}/dt = N_{235}^U \sigma_f \delta_{133}^{Xe} \phi + N_{132}^{Xe} \sigma_c \phi + \lambda N_{133}^I - N_{133}^{Xe} \sigma_c \phi - \lambda N_{133}^{Xe} \quad (11)$$

$$dN_{133}^{Cs}/dt = N_{235}^U \sigma_f \delta_{133}^{Cs} \phi + N_{132}^{Cs} \sigma_c \phi + \lambda N_{133}^{Xe} - N_{133}^{Cs} \sigma_c \phi - \lambda N_{133}^{Cs} \quad (12)$$

$$dN_{134}^{Cs}/dt = N_{235}^U \sigma_f \delta_{134}^{Cs} \phi + N_{133}^{Cs} \sigma_c \phi + \lambda N_{134}^{Xe} - N_{134}^{Cs} \sigma_c \phi - \lambda N_{134}^{Cs} \quad (13)$$

$$dN_{235}^U/dt = -N_{235}^U \sigma_a \phi \quad (14)$$

where σ_a is the absorption cross section. These equations are solved in Appendix B. These tedious hand calculations can be avoided by using the MIT code MACSYMA 272; this code's solution of Eq (14) is shown in Fig. 10.

The production scheme for Cs137 is shown in Fig. 11 (Ref 31). Since the capture cross sections for the members of the mass 136 chain are all less than 1 barn, only the mass 136 chain is required in the production scheme of Cs137. In addition to Eq (14), the coupled equations which must be solved are:

$$dN_{133}^I/dt = N_{235}^U \sigma_f \delta_{137}^I \phi + N_{136}^I \sigma_c \phi + \lambda N_{137}^{Te} - N_{137}^I \sigma_c \phi - \lambda N_{137}^I \quad (15)$$

$$dN_{137}^{Xe}/dt = N_{235}^U \sigma_f \delta_{137}^{Xe} \phi + N_{136}^{Xe} \sigma_c \phi + \lambda N_{137}^I - N_{137}^{Xe} \sigma_c \phi - \lambda N_{137}^{Xe} \quad (16)$$

$$dN_{137}^{Cs}/dt = N_{235}^U \sigma_f \delta_{137}^{Cs} \phi + N_{136}^{Cs} \sigma_c \phi + \lambda N_{137}^{Xe} - N_{137}^{Cs} \sigma_c \phi - \lambda N_{137}^{Cs} \quad (17)$$

The solution to these equations is contained in Appendix B. The instantaneous number of Cs134 and Cs137 atoms are given by the expressions

$$N_{134}^{Cs} = C_{66} e^{-c_2 t} - C_{68} e^{-c_3 t} + C_{70} e^{-c_{10} t} + C_{72} e^{-c_{20} t} + C_{74} e^{-c_{29} t} + C_{76} e^{-c_{40} t} + C_{78} e^{-c_{64} t} \quad (18)$$

```

(C0) 'DIFF(N235(T),T)=-SIGA235*FLUX+N235(T);
      D
      -- N235(T) = - FLUX SIGA235 N235(T)
      DT

(C1) LAPLACE(D1,T,S);
LAPLAC FASL DSK MACSYM BEING LOADED
LOADING DONE
AT FASL DSK MPADUT BEING LOADED
LOADING DONE
(C2) 'LAPLACE(N235(T),T,S) - N235(0) =
      - FLUX SIGA235 LAPLACE(N235(T),T,S)

(C3) LINSOLVE(C2),[LAPLACE(N235(T),T,S)];
SOLVE FASL DSK MACSYM BEING LOADED
LOADING DONE
SOLUTION
      LAPLACE(N235(T),T,S) = -----
                                N235(0)
                                FLUX SIGA235 + S
      (E3)
      (D3)

(C4) ILT(E3,S,T);
      (D4)
      N235(T) = N235(0) %E

```

Fig. 10 MACSYMA 272 Solution of a Differential Equation

Cs-137

Zr-137

I-137

Fig. 11. Production Scheme for Cs137

$$N_{137}^{Cs} = D_{26} e^{-D_2 t} + D_{25} e^{-D_5 t} + D_{24} e^{-D_9 t} + D_{23} e^{-D_{17} t} \quad (19)$$

where the C's and D's represent constants defined in Appendix B, and t represents time.

Using these expressions for the number of Cs134 and Cs137 atoms, a cesium inventory code (TEST) was written which calculates the amount or activity of each of these isotopes with input parameters of initial amount of U235, neutron flux and time. The first application of the code was to compare it to ORIGEN (Ref 2); ORIGEN is the model used for PWR's and BWR's by the U. S. Nuclear Regulatory Commission (Ref3:28). Tables IV and V are output from ORIGEN being used to model a PWR running at a constant average specific power of 30 MW per metric ton of uranium charged to the core. The same input parameters used by ORIGEN were used in TEST; the listing and output are contained in Appendix C. The output of both programs is for 110 day increments. The depletion of U235 shown by TEST is within 1% of the depletion of U235 given by ORIGEN for the entire fuel cycle (1100 days). Fig. 12 compares the amount of Cs134 calculated by each code. TEST's result is 36% higher than ORIGEN's at 110 days; the difference decreases to 13% at 1100 days. Since all the assumptions made to

TABLE IV

Isotopic Concentrations (G-Atom/Metricton of U) of Actinides and Their Daughters as a function of Irradiation Time (Days) (Ref 2:106)

	CHARGE	110. D	220. D	330. D	440. D	550. D	660. D	770. D	880. D	990. D	1100. D
PA238	0.0	8.30E-13	1.33E-12	2.05E-12	3.03E-12	4.27E-12	5.76E-12	7.50E-12	9.49E-12	1.17E-11	1.40E-11
U232	0.0	2.50E-00	5.53E-08	9.78E-08	1.50E-07	2.42E-07	3.69E-07	5.09E-07	7.02E-07	9.10E-07	1.22E-06
U233	0.0	6.36E-06	1.12E-05	1.49E-05	1.76E-05	2.07E-05	2.07E-05	2.18E-05	2.15E-05	2.12E-05	2.06E-05
U234	1.13E 00	1.05E 00	9.94E-01	9.17E-01	8.53E-01	7.91E-01	7.31E-01	6.74E-01	6.20E-01	5.68E-01	5.19E-01
U235	1.80E 02	1.24E 02	1.09E 02	9.61E 01	8.42E 01	7.32E 01	6.38E 01	5.50E 01	4.71E 01	4.01E 01	3.40E 01
U236	0.0	3.37E 00	6.29E 00	8.80E 00	1.11E 01	1.31E 01	1.88E 01	1.62E 01	1.75E 01	1.85E 01	1.93E 01
U237	0.0	8.04E-03	1.27E-02	1.72E-02	2.15E-02	2.57E-02	2.98E-02	3.38E-02	3.77E-02	4.13E-02	4.47E-02
U238	4.06E 03	4.05E 03	4.04E 03	4.00E 03	4.03E 03	4.02E 03	4.01E 03	4.00E 03	3.99E 03	3.97E 03	3.96E 03
U239	0.0	1.78E-03	1.77E-03	1.81E-03	1.86E-03	1.92E-03	1.99E-03	2.07E-03	2.15E-03	2.24E-03	2.32E-03
U240	0.0	1.22E-34	2.06E-31	1.58E-29	3.48E-28	3.87E-27	8.80E-26	1.51E-25	6.49E-25	2.36E-24	7.51E-24
NP236	0.0	8.11E-10	1.23E-09	2.80E-09	3.94E-09	5.84E-09	8.12E-09	1.07E-08	1.37E-08	1.69E-08	2.04E-08
NP237	0.0	5.37E-02	1.60E-01	3.07E-01	4.88E-01	6.99E-01	9.32E-01	1.18E 00	1.45E 00	1.72E 00	1.99E 00
NP238	0.0	1.29E-04	3.85E-04	7.55E-04	1.28E-03	1.88E-03	2.55E-03	3.38E-03	4.30E-03	5.32E-03	6.41E-03
NP239	0.0	2.56E-01	2.55E-01	2.60E-01	2.67E-01	2.76E-01	2.86E-01	2.98E-01	3.09E-01	3.21E-01	3.33E-01
NP240M	0.0	1.05E-36	1.77E-33	1.36E-31	3.00E-30	3.30E-29	2.42E-28	1.30E-27	5.60E-27	2.04E-26	6.48E-26
NP240	0.0	6.33E-06	6.33E-06	6.57E-06	6.96E-06	7.46E-06	8.06E-06	8.72E-06	9.45E-06	1.02E-05	1.10E-05
PU236	0.0	7.89E-09	8.45E-08	1.24E-07	4.62E-07	7.44E-07	1.11E-06	1.57E-06	2.13E-06	2.79E-06	3.54E-06
PU238	0.0	1.88E-03	1.07E-02	2.99E-02	6.27E-02	1.12E-01	1.81E-01	2.71E-01	3.94E-01	5.19E-01	6.78E-01
PU239	0.0	6.73E 00	1.15E 01	1.89E 01	2.73E 01	3.53E 01	4.20E 01	4.71E 01	5.07E 01	5.25E 01	5.31E 01
PU240	0.0	3.69E-01	1.23E 00	2.38E 00	4.71E 00	5.82E 00	6.82E 00	7.69E 00	8.42E 00	9.02E 00	9.42E 00
PU241	0.0	2.61E-02	1.65E-01	4.89E-01	1.39E 00	1.98E 00	2.59E 00	3.20E 00	3.77E 00	4.29E 00	4.76E 00
PU242	0.0	6.57E-04	8.42E-03	3.55E-02	9.47E-02	1.97E-01	3.50E-01	5.56E-01	8.15E-01	1.12E 00	1.46E 00
PU243	0.0	1.92E-07	2.86E-06	1.06E-05	2.91E-05	6.28E-05	1.16E-04	1.92E-04	2.94E-04	4.20E-04	5.71E-04
PU244	0.0	6.28E-24	1.06E-20	8.18E-19	1.79E-17	2.00E-16	1.84E-15	7.76E-15	3.35E-14	1.22E-13	3.87E-13
PU245	0.0	9.03E-30	1.52E-26	1.19E-26	2.71E-23	3.13E-22	3.61E-21	1.32E-20	5.92E-20	2.25E-19	7.82E-19
AM241	0.0	9.30E-05	1.14E-03	4.51E-03	1.12E-02	3.64E-02	3.64E-02	5.17E-02	6.93E-02	8.71E-02	1.08E-01
AM242M	0.0	8.31E-07	1.76E-05	9.26E-05	2.76E-04	6.04E-04	1.08E-03	1.70E-03	2.41E-03	3.16E-03	3.89E-03
AM242	0.0	2.17E-07	2.66E-06	1.07E-05	2.75E-05	5.50E-05	9.36E-05	1.42E-04	1.99E-04	2.61E-04	3.24E-04
AM243	0.0	1.45E-05	3.73E-04	3.92E-03	8.71E-03	2.32E-02	5.07E-02	9.64E-02	1.65E-01	2.62E-01	3.88E-01
AM244	0.0	4.75E-10	1.23E-08	8.09E-08	3.01E-07	8.32E-07	1.89E-06	3.74E-06	6.69E-06	1.10E-05	1.70E-05
AM245	0.0	6.65E-28	1.06E-24	7.93E-23	1.72E-21	1.89E-20	1.46E-19	7.28E-19	3.12E-18	1.13E-17	3.56E-17
AM246	0.0	3.93E-06	9.23E-05	5.37E-04	1.76E-03	4.22E-03	8.29E-03	1.42E-02	2.19E-02	3.12E-02	4.17E-02
CM243	0.0	3.07E-09	1.43E-07	1.25E-06	5.49E-06	1.65E-05	3.92E-05	7.87E-05	1.39E-04	2.20E-04	3.32E-04
CM244	0.0	3.85E-07	1.80E-05	1.77E-04	8.86E-04	3.05E-03	8.28E-03	1.91E-02	3.89E-02	7.21E-02	1.24E-01
CM245	0.0	2.64E-09	2.66E-07	3.83E-06	2.50E-05	1.06E-04	3.38E-04	8.95E-04	2.05E-03	4.21E-03	7.89E-03
CM246	0.0	2.15E-11	4.40E-09	9.77E-08	8.78E-07	8.81E-06	1.93E-05	6.21E-05	1.70E-04	4.12E-04	9.01E-04
CM247	0.0	2.44E-16	9.97E-12	3.34E-10	4.05E-09	2.82E-08	1.38E-07	5.28E-07	1.69E-06	4.68E-06	1.16E-05
CM248	0.0	1.26E-16	1.04E-13	5.32E-12	8.82E-11	7.90E-10	4.79E-09	2.22E-08	8.40E-08	2.72E-07	7.78E-07
CM249	0.0	1.06E-21	8.73E-19	4.57E-17	7.81E-16	7.25E-15	4.82E-14	2.21E-13	8.71E-13	2.94E-12	8.75E-12
CM250	0.0	0.0	7.12E-23	5.69E-21	1.33E-19	1.58E-18	1.23E-17	7.16E-17	3.34E-16	1.31E-15	4.89E-15
CM251	0.0	1.61E-19	2.56E-16	1.92E-14	4.16E-13	4.58E-12	3.29E-11	1.76E-10	7.55E-10	2.73E-09	8.61E-09
CM252	0.0	9.23E-23	1.47E-19	1.12E-17	2.51E-16	2.82E-15	1.84E-14	1.19E-13	5.34E-13	2.01E-12	6.60E-12
CM253	0.0	3.20E-21	9.85E-18	1.06E-15	2.92E-14	3.82E-13	3.13E-12	1.85E-11	8.58E-11	3.31E-10	1.10E-09
CM254	0.0	8.09E-21	1.21E-17	1.27E-15	3.48E-14	4.56E-13	3.75E-12	2.23E-11	1.05E-10	4.09E-10	1.37E-09
CM255	0.0	3.60E-22	1.94E-18	2.85E-16	7.71E-15	1.89E-13	1.39E-12	9.13E-12	4.64E-11	1.94E-10	6.90E-10
CM256	0.0	1.51E-23	1.55E-19	3.72E-17	1.03E-15	3.42E-14	3.98E-13	3.12E-12	1.88E-11	9.11E-11	3.73E-10
CM257	0.0	0.0	2.79E-20	1.54E-18	3.43E-17	8.40E-16	2.50E-15	3.80E-15	2.47E-14	1.29E-13	5.63E-13
CM258	0.0	0.0	8.86E-24	6.29E-22	1.71E-20	2.55E-19	2.55E-18	2.53E-18	1.85E-17	1.07E-16	5.11E-16
CM259	0.0	0.0	1.40E-20	9.01E-19	2.82E-17	3.09E-16	3.09E-16	2.83E-15	1.93E-14	1.04E-13	4.69E-13
TOTALS	4.20E 03	4.19E 03	4.16E 03	4.16E 03	4.16E 03	4.13E 03	4.11E 03	4.10E 03	4.09E 03	4.07E 03	4.06E 03
PL02		2.58E 13	2.58E 13	2.63E 13	2.71E 13	2.81E 13	2.93E 13	3.05E 13	3.18E 13	3.31E 13	3.45E 13

TABLE V

Isotopic Concentrations/G-Atom/Metricton of U) of Fission Products as a Function of Irradiation Time (Days) Ref 2:113)

	110. D	220. D	330. D	440. D	550. D	660. D	770. D	880. D	990. D	1100. D
KA132	6.46E-01	1.37E-00	2.14E-00	2.95E-00	3.80E-00	4.70E-00	5.60E-00	6.63E-00	7.65E-00	8.72E-00
SB133	2.21E-05	2.20E-05	2.19E-05	2.19E-05	2.19E-05	2.20E-05	2.20E-05	2.20E-05	2.21E-05	2.21E-05
TP133H	3.00E-05	3.33E-04	3.32E-04	3.31E-04	3.31E-04	3.32E-04	3.32E-04	3.32E-04	3.33E-04	3.33E-04
Y133	1.11E-00	1.00E-02	1.09E-02	1.09E-02	1.08E-02	1.08E-02	1.08E-02	1.08E-02	1.08E-02	1.08E-02
XA133H	6.89E-04	6.11E-04	6.77E-04	6.75E-04	6.74E-04	6.73E-04	6.73E-04	6.73E-04	6.73E-04	6.74E-04
XE133	6.67E-02	6.60E-02	6.56E-02	6.53E-02	6.51E-02	6.50E-02	6.49E-02	6.49E-02	6.48E-02	6.48E-02
CS133	8.72E-01	1.78E-00	2.65E-00	3.48E-00	4.27E-00	5.02E-00	5.71E-00	6.36E-00	6.97E-00	7.52E-00
SB134	2.26E-07	2.22E-07	2.19E-07	2.17E-07	2.16E-07	2.14E-07	2.12E-07	2.12E-07	2.11E-07	2.10E-07
TP134	3.84E-04	3.78E-04	3.74E-04	3.71E-04	3.68E-04	3.66E-04	3.65E-04	3.63E-04	3.62E-04	3.61E-04
Y134	5.25E-04	5.36E-04	5.30E-04	5.25E-04	5.22E-04	5.19E-04	5.17E-04	5.15E-04	5.13E-04	5.12E-04
XA134	1.18E-00	2.34E-00	3.50E-00	4.66E-00	5.81E-00	6.95E-00	8.09E-00	9.23E-00	1.04E-01	1.15E-01
CS134H	4.69E-06	1.02E-05	1.55E-05	2.10E-05	2.67E-05	3.26E-05	3.86E-05	4.49E-05	5.12E-05	5.75E-05
CS134	1.78E-02	7.07E-02	1.55E-01	2.67E-01	4.04E-01	5.66E-01	7.50E-01	9.54E-01	1.18E-01	1.41E-01
BA134	6.32E-04	4.95E-03	1.63E-02	3.77E-02	7.19E-02	1.21E-01	1.89E-01	2.76E-01	3.84E-01	5.16E-01
Y135	3.85E-06	3.76E-06	3.74E-06	3.71E-06	3.69E-06	3.67E-06	3.65E-06	3.64E-06	3.62E-06	3.61E-06
TP135H	3.23E-03	3.18E-03	3.15E-03	3.13E-03	3.10E-03	3.09E-03	3.07E-03	3.06E-03	3.05E-03	3.04E-03
XE135H	3.76E-05	3.70E-05	3.67E-05	3.65E-05	3.63E-05	3.61E-05	3.60E-05	3.59E-05	3.58E-05	3.58E-05
CS135H	1.25E-03	1.25E-03	1.24E-03	1.22E-03	1.19E-03	1.16E-03	1.13E-03	1.10E-03	1.07E-03	1.04E-03
CS135	1.13E-07	6.47E-07	9.96E-07	1.77E-06	2.79E-06	4.06E-06	5.60E-06	7.42E-06	9.53E-06	1.19E-05
BA135H	2.85E-10	1.93E-09	6.47E-09	1.59E-08	3.05E-08	5.36E-08	8.67E-08	1.32E-07	1.92E-07	2.68E-07
BA135	3.32E-08	4.21E-07	2.03E-06	6.33E-06	1.55E-05	3.23E-05	6.04E-05	1.06E-04	1.70E-04	2.62E-04
Y136	5.31E-06	5.09E-06	4.92E-06	4.78E-06	4.66E-06	4.55E-06	4.45E-06	4.36E-06	4.27E-06	4.18E-06
KA136	1.64E-00	3.30E-00	4.97E-00	6.65E-00	8.35E-00	1.01E-01	1.18E-01	1.35E-01	1.51E-01	1.70E-01
CS136	7.35E-04	1.31E-03	1.86E-03	2.40E-03	2.95E-03	3.51E-03	4.11E-03	4.73E-03	5.39E-03	6.05E-03
BA136	2.35E-03	4.42E-03	1.78E-02	3.03E-02	4.62E-02	6.54E-02	8.80E-02	1.14E-01	1.44E-01	1.78E-01
Y137	3.00E-06	2.98E-06	2.98E-06	2.98E-06	2.98E-06	2.99E-06	2.99E-06	2.99E-06	3.00E-06	3.01E-06
CS137	3.48E-05	3.17E-05	3.17E-05	3.16E-05	3.15E-05	3.14E-05	3.13E-05	3.12E-05	3.11E-05	3.10E-05
BA137H	1.37E-07	2.75E-07	4.13E-07	5.50E-07	6.87E-07	8.24E-07	9.60E-07	1.10E-06	1.23E-06	1.37E-06
Y137	3.16E-03	1.27E-02	2.85E-02	5.07E-02	7.92E-02	1.14E-01	1.52E-01	2.02E-01	2.56E-01	3.15E-01
TP138	7.37E-07	7.36E-07								
KA138	1.33E-04	1.32E-04	1.33E-04	1.33E-04	1.33E-04	1.34E-04	1.34E-04	1.35E-04	1.35E-04	1.36E-04
CS138	2.52E-04	2.51E-04	2.52E-04	2.53E-04	2.54E-04	2.55E-04	2.56E-04	2.57E-04	2.58E-04	2.59E-04
BA138	8.53E-01	1.72E-00	2.58E-00	3.46E-00	4.34E-00	5.23E-00	6.12E-00	7.01E-00	7.91E-00	8.81E-00
Y139	5.12E-06	5.01E-06	4.95E-06	4.90E-06	4.86E-06	4.82E-06	4.79E-06	4.77E-06	4.74E-06	4.72E-06
CS139	8.13E-05	7.97E-05	7.87E-05	7.79E-05	7.72E-05	7.67E-05	7.62E-05	7.58E-05	7.55E-05	7.51E-05
BA139	7.19E-04	7.04E-04	6.95E-04	6.89E-04	6.83E-04	6.78E-04	6.74E-04	6.71E-04	6.68E-04	6.65E-04
LA139	9.55E-01	1.90E-00	2.83E-00	3.78E-00	4.67E-00	5.58E-00	6.48E-00	7.38E-00	8.26E-00	9.14E-00
Y140	1.34E-06	1.31E-06	1.29E-06	1.28E-06	1.27E-06	1.26E-06	1.25E-06	1.24E-06	1.23E-06	1.23E-06
CS140	8.73E-06	8.53E-06	8.41E-06	8.31E-06	8.23E-06	8.17E-06	8.11E-06	8.06E-06	8.01E-06	7.97E-06
BA140	1.55E-01	1.52E-01	1.50E-01	1.49E-01	1.47E-01	1.46E-01	1.45E-01	1.44E-01	1.43E-01	1.42E-01
LA140	2.03E-02	2.00E-02	1.98E-02	1.96E-02	1.95E-02	1.94E-02	1.93E-02	1.93E-02	1.92E-02	1.92E-02
CS140	7.86E-01	1.74E-00	2.68E-00	3.62E-00	4.55E-00	5.48E-00	6.41E-00	7.33E-00	8.25E-00	9.17E-00
Y141	6.08E-08	5.95E-08	5.88E-08	5.82E-08	5.78E-08	5.75E-08	5.72E-08	5.70E-08	5.68E-08	5.67E-08
CS141	2.81E-06	2.33E-06	2.27E-06	2.23E-06	2.19E-06	2.16E-06	2.13E-06	2.10E-06	2.08E-06	2.05E-06
BA141	1.88E-04	1.84E-04	1.81E-04	1.79E-04	1.78E-04	1.77E-04	1.76E-04	1.75E-04	1.74E-04	1.73E-04
LA141	1.92E-03	1.90E-03	1.86E-03	1.83E-03	1.80E-03	1.77E-03	1.75E-03	1.73E-03	1.72E-03	1.70E-03
CS141	3.54E-01	3.79E-01	3.75E-01	3.69E-01	3.64E-01	3.60E-01	3.56E-01	3.52E-01	3.48E-01	3.45E-01
PP141	5.69E-01	1.45E-00	2.33E-00	3.21E-00	4.07E-00	4.91E-00	5.76E-00	6.56E-00	7.37E-00	8.16E-00




Fig. 12. Cs134 Buildup Versus Time for Codes TEST and ORIGIN

simplify TEST tend to decrease the production rate of Cs134, TEST was expected to calculate a lower value of Cs134 than ORIGEN. That TEST calculates a higher value than ORIGEN causes the accuracy of the mathematical methods used in ORIGEN to be suspect. The relative decrease in amount of Cs134 (+36% to +13%) with increasing time is as expected. ORIGEN accounts for the fission of accumulating Pu239, while TEST considers only U235 fission.

Fig. 13 compares the amount of Cs137 calculated by each code. TEST's result is 35% higher than ORIGEN's at 110 days and 4% lower at 1100 days. Again, the relative decrease in amount of Cs137 (+35% to -4%) is due to the fact that TEST disregards the fission of accumulating Pu239.

Fig. 14 compares the Cs134/Cs137 mass ratios calculated by TEST and ORIGEN; there is less than 0.1% difference at 110 days and 16% difference at 1100 days. The comparison between TEST and ORIGEN can be summarized as follows. There is close agreement on U235 depletion and Cs134/Cs137 mass ratio. TEST is 35% higher than ORIGEN for both isotopes at 110 days, but the ratio (TEST value/ORIGEN value) decreases with time for both isotopes. It is concluded that TEST is an acceptable code for examining the power history dependence of the cesium ratio as an indicator of burnup.

The results of the comparison between TEST and ORIGEN can also be used to examine the impact of disregarding capture




Fig. 13. Cs137 Buildup Versus Time for Codes TEST and ORIGIN




Fig. 14. Cs134/Cs137 Versus Time for Codes TEST and ORIGIN

cross sections of less than one barn in the design of the code TEST. Appendix C shows that TEST calculates $8.08E5$ grams of Cs137 after 110 days and $5.00E6$ grams after 1100 days. Eq (17), which is the production rate equation for Cs137, has two loss terms. One loss term is for capture, and the other is for decay. TEST disregards the capture term because the capture cross section of Cs137 is 0.169 barns. Using the above values for number of Cs137 atoms and Eq (17), loss rates due to capture and decay were calculated. At 110 days, the capture loss rate is $3.52E-6$ (grams/sec) and the decay rate is $5.92E-4$; at 1100 days, the capture loss rate is $2.18E-5$ and the decay rate is $3.66E-3$. In both cases, the capture loss rate is two orders of magnitude less than the decay rate.

All applications of the code TEST hereafter described use nuclear data from Tables I and II and an initial U235 charge of $1.40E2$ metric tons (same as ORIGEN PWR model). The first application of TEST to the question of power history dependence involved constant flux runs to a fluence of $8.94 E20$ (neutrons per square cm). Nine flux levels (from ORIGEN PWR model operating at 30 MW per metric ton of U) were used; irradiation time required for the desired fluence was 300 days for the highest flux and 400 days for the lowest flux. Table VI lists the flux, time, and activity ratio Cs134/Cs137 for a fluence of $8.94 E20$; a 25% change in flux shows only a 1.5% change in activity ratio.

TABLE VI

Activity Ratio Cs134/Cs137 (R) for Different Power Histories to a Fluence ($\phi \times t$) of $8.94 \text{ E}20$ (ϕ in neutrons per square cm sec; t in sec)

PHI=3.45E+13	T=25920000.	R=1.056383825606
PHI=3.31E+13	T=27016314.	R=1.054751593548
PHI=3.18E+13	T=29120774.	R=1.052910049049
PHI=3.05E+13	T=29319344.	R=1.050901147463
PHI=2.93E+13	T=30920136.	R=1.048686246339
PHI=2.81E+13	T=31823487.	R=1.046152616613
PHI=2.71E+13	T=32957785.	R=1.04379955784
PHI=2.63E+13	T=34001521.	R=1.041656638467
PHI=2.58E+13	T=34650465.	R=1.04026422534

TABLE VII

Activity Ratio Cs134/Cs137 (R) for Different Power Histories

PHI=2.58E+13	T=2592000.	R=.05589902334553
PHI=2.63E+13	T=2592000.	R=.1436468570634
PHI=2.71E+13	T=2592000.	R=.2368905735182
PHI=1.	T=2592000.	R=.230837920167
PHI=2.81E+13	T=2592000.	R=.3323650543424
PHI=2.93E+13	T=2592000.	R=.4318343262277
PHI=3.05E+13	T=2592000.	R=.533813233759
PHI=3.18E+13	T=2592000.	R=.6386032743066
PHI=3.31E+13	T=2592000.	R=.7460829384687
PHI=3.45E+13	T=2592000.	R=.8564672733371
PHI=2.58E+13	T=2592000.	R=.05589902334553
PHI=2.63E+13	T=2592000.	R=.1436468570634
PHI=2.71E+13	T=2592000.	R=.2368905735182
PHI=2.81E+13	T=2592000.	R=.3330854275706
PHI=2.93E+13	T=2592000.	R=.4322140683922
PHI=3.05E+13	T=2592000.	R=.534012130081
PHI=1.	T=2592000.	R=.2303796324693
PHI=3.18E+13	T=2592000.	R=.6298911881417
PHI=3.31E+13	T=2592000.	R=.7368579490282
PHI=3.45E+13	T=2592000.	R=.8503762160465

A second application of TEST examined more extreme variations in flux level; a listing and the output of this program are contained in Appendix D. The purpose of this program was two-fold; only the odd lines of output are addressed at this point. Ten flux levels, from $1E13$ to $1E14$ (neutrons per square cm sec), were run for ten time periods each; the time periods ran from 30 to 300 days, in increments of 30 days. The output lists the flux, time (sec), and activity ratio $Cs134/Cs137$. Recalling the theoretical correlation between fluence and $Cs134/Cs137$ activity ratio addressed in Chapter II, it is interesting to note that TEST shows a linear correlation coefficient of 0.9999 for this relationship for a constant flux. Returning to power history dependence, Appendix D shows that for a fluence of $2.59E20$, changing the flux by a factor of 2 changes the activity ratio by 0.7%. For the same fluence, changing the flux by a factor of 5 changes the activity ratio by 12%, and a factor of 10 changes the activity by 23%. In other words, if the $Cs134/Cs137$ activity ratio is used as a monitor of fluence and the uncertainty in flux level is a factor of 5, then the uncertainty in fluence will be 12%.

Another way in which power history can vary is the sequence and duration of power shutdowns in fuel cycle. Table VII shows the TEST output for two power cycles with terminal fluence of $6.91E20$; the flux levels are those used by the ORIGEN PWR model. Case 1 has a 30-day shutdown in the fourth month, while Case 2 has a 30-day shutdown

in the seventh month. The output lists the activity ratio at the end of each month; the difference in activity ratios at the terminal fluence is 0.7%. A similar program was run to determine the effect of shutdowns of different lengths; two fuel cycles of constant flux and 300-day duration were modeled. The first case had a flux of $7E13$ with a 30-day shutdown in the fourth month; terminal fluence and activity ratio for case 1 were $1.633E21$ and 1.97, respectively. Case 2 used a flux of $8E13$ with a 60-day shutdown in the fourth and fifth months; terminal fluence and activity ratio were $1.659E21$ and 1.99, respectively. The greater fluence (1.6%) has an activity ratio 1% higher.

The power history dependence of the $Cs134/Cs137$ activity ratio as an indicator of fluence can be summarized as follows. Shutdowns whose length is short compared to the half-life of $Cs134$ (2 yrs.) have an insignificant impact on the accuracy of the cesium ratio as an indicator of fluence. However, an order of magnitude uncertainty in the flux level of the reactor results in a 23% uncertainty in the fluence indicated by a particular cesium ratio.

As mentioned earlier, the program contained in Appendix D was designed to serve a dual purpose. The odd lines of output are for a $Cs134$ direct fission yield of zero, and the even lines of output are for a $Cs134$ direct fission yield of $5.2E-6$. Goodwin cites the $5.2E-6$ value (Ref 3:112); ORIGEN uses zero. The difference in amount of $Cs134$ calculated by TEST using these two values is

significant for low fluences; a flux of $1E13$ for 30 days results in a 5% difference in Cs134 calculated. An order of magnitude increase in fluence decreases the difference in Cs134 calculated by an order of magnitude.

V. Escape from Fuel to Environment

Analysis of the escape from fuel to environment of the isotopes of interest, Cs134/137 and Nd145/146, is addressed in three parts: escape from fuel matrix, breach of fuel cladding, escape from coolant to environment. The rate at which fission products are able to breach the cladding is determined by the burnup of the fuel; since burnup detection is the ultimate goal, breach of cladding will be examined most thoroughly.

Escape from Fuel Matrix

Fig. 15 shows the possible fission product escape mechanisms from the fuel matrix to the fuel rod plenum (Ref 32:5). The fuel matrix is a ceramic, sintered uranium dioxide; this ceramic is formed into pellets and stacked inside a Zircaloy tube. A helium-filled plenum is provided at the top of the tube (rod) to collect fission product gases. The ends of the tube are sealed with welded plugs (Ref 33:0). Prior to sealing, a helical compression spring is placed to bear on top of the pellet stack to prevent shifting of fuel pellets during handling (Ref 34:47). A temperature as high as 1800 degrees C can exist in the center of a new fuel pellet operating at a linear heat generation rate of 13.4 kW/ft (Ref 35:310), while the primary coolant in a typical LWR operates at 300 degrees C.




Fig. 15. Fission Product Escape Mechanisms for Fuel Matrix to Primary Coolant (Ref. 32:5)

There are four possible escape mechanisms from fuel to plenum (Ref 32:7):

- (1) diffusion, trapping, and release from traps
- (2) knockout release and surface effects
- (3) bubble migration
- (4) release through cracks in the fuel matrix

In the temperature range 800 to 1800 degrees C, fission product movement occurs by a complex diffusion trapping mechanism; the fission product atom diffuses through the fuel material until trapped. There are two categories of traps, intrinsic traps and point defects. Intrinsic traps are flaws, such as grain boundaries, in the fuel material; they are an inherent property of the material. Point defects are formed by irradiation and annealed out by heat. The trapped fission product atom is eventually released as a result of thermal agitation. This process continues until the fission product atom reaches the outside of the fuel material. The diffusion trapping mechanism is the dominant escape mode because it occurs in the temperature range where LWR fuels operate.

If a fission occurs within 20 Angstroms (A) of the surface of the fuel material, the kinetic energy of a fission fragment may drive it through the surface; some of the surface molecules are knocked out and trapped fission products released. This escape mechanism is called knockout release; below 700 degrees C, knockout release is the dominant escape mode.

Bubble migration occurs at high fuel temperatures (above 1800 degrees) when the fuel matrix begins to lose strength; bubbles form when diffusing atoms joint together. Bubble migration occurs along a thermal gradient by a mechanism called surface diffusion. The formation and movement of these bubbles causes swelling in the fuel matrix. Bubble migration is not a significant escape mode because LWR fuels do not reach a high enough temperature.

Rapid temperature changes in the fuel matrix can cause the low tensile strength ceramic to crack; diffusing fission products can then be released to the plenum by these cracks. Since rapid reactor start-up or shutdown is not a normal practice, release through cracks is not a significant escape mechanism during routine reactor operation.

Since diffusion (including trapping and release) is the dominant escape mode from fuel matrix to plenum, it is appropriate at this point to examine the diffusivity of cesium, neodymium and their precursors. Goodwin's assumption that the use of a same-element ratio ensures uniform fractional release from the fuel matrix (Ref 3:49) is not justified; the fractional release of any member of a decay chain is not simply and exclusively determined by its own diffusivity (Ref 36:89). The fact that each precursor is able to diffuse before decaying will increase the fractional release of a particular isotope above the level which estimates ignoring the mobility of precursors


would suggest. Decay products having precursors with relatively high diffusivities and half-lives which are a significant fraction of irradiation time will experience the greatest increase in fractional release.

The precursors of both neodymium isotopes of interest are cerium (Ce) and praseodymium (Pr); only Pr¹⁴⁵ has a half-life of significant length, 6 hours (Ref 11:98). There is little to be found in the literature about the diffusivity of non-volatiles; the boiling point of neodymium and both its precursors is over 3000 degrees C. However, Brown and Faircloth state that cerium is relatively immobile (Ref 37:31), and they conclude that cerium escapes the fuel matrix only as a recoiling fission fragment. This conclusion implies that only cerium atoms produced within 10A of the surface of the fuel matrix have a chance of escaping (Ref 32:9). It is logical to assume, based on non-volatility, that Pr and Nd are as immobile as Ce. Since neither Pr nor Nd is a direct fission product (Ref 2:80), the only Nd to be found outside the fuel matrix is that formed by decaying Ce which has escaped by recoil as a fission fragment. For one of the Vak fuel pellets described in Chapter III, only 3.15E-7 of the volume lies within 10A of the surface. Even if one assumes that all cerium atoms produced in this volume recoil outward, only 3.15E-7 of the cerium atoms produced within the fuel can escape the fuel matrix. From the standpoint of escape rate, this effectively reduces the neodymium


fission yield by a factor of $3.15E-7$.

The volatility of cesium gives it great mobility within the fuel matrix; it migrates radially and axially in the direction of decreasing temperature (Ref 38). Both cesium isotopes of interest have iodine and xenon as precursors, but the only half-lives of significant length in either chain are those of $I133$ (21 hr.) and $Xe133$ (5.27d). Since both iodine, a halogen, and xenon, a noble gas, have greater diffusivities than cesium (Ref 39), the fractional release of $Cs134$ should be greater than that of $Cs137$; Brown and Faircloth investigate and verify this experimentally (Ref 37). Friskney and Speight perform calculations to quantify this difference in fractional release (Ref 36:90); their results are shown in Fig. 16. Curves (7) and (8) apply to $Cs137$ because of the short half-lives of its precursors. The other curves apply to $Cs134$. $D1$ represents the diffusion coefficient of $I133$, and $D2$ refers to $Xe133$. $D3$ refers to $Cs134$, and the unsubscripted D refers to $Cs137$. Since a diffusion coefficient is a function of grain radius and temperature, two arbitrary D 's are investigated, $1E-13$ and $1E-14$ (square cm/sec). For the worst case, $D1$ and $D2$ both an order of magnitude greater than $D3$, there is a difference of 27% in fractional release of the two isotopes at 100 days; this case is represented by curves (3) and (7).

The calculations of Friskney and Speight involve a simple diffusion model; it neglects both the trapping-release



Fractional release vs time for the final stable isotope (3) in the chain:



(for the case of $^{133}\text{I}, ^{133}\text{Xe}, ^{133}\text{Cs}$, $\lambda_1 = 9.255 \times 10^{-6}$, $\lambda_2 = 1.522 \times 10^{-6}/\text{sec}$).

Fig. 16. Fractional Release Versus Time for the Final Isotope (3) in the Chain

mechanism involved in diffusion and the fact that cesium's movement is actually a migration to lower temperature. However, their relative values of fractional release should be valid if the correct absolute diffusion coefficients are used. The unavailability of these diffusion coefficients prevents resolution of the issue of different fractional release of Cs134 and Cs137.

In summary, only a very small fraction of the neodymium (cerium) atoms can escape from the fuel matrix, while the cesium isotopes have a high, but apparently different, escape rate.

Breach of Fuel Cladding

The fuel rod cladding acts as a barrier for fission product transport and as a container for the fission gas pressure buildup; it is designed to prevent fission products from escaping to the primary coolant. Fig. 15 shows the possible escape mechanisms through the fuel cladding. Eckart calculates diffusion rate of $1.3E-4$ cm/year for a noble gas in the fuel clad (Ref 32:29); the thickness of cladding on the Vak fuel described earlier is $8.5E-2$ cm. It would take even the most mobile fission product 600 years to diffuse through the fuel clad; examination of the fission product content of a reactor's primary coolant demonstrates that fission product release must take place through defects in the fuel rod cladding. Stainless steel was used as fuel cladding in early LWR's, but only zirconium alloys have been used since 1968 (Ref 40).

The causes of fuel failures (clad defects) for slightly enriched uranium dioxide clad with Zircaloy are reviewed by Robertson (Ref 40); he groups the causes of fuel failure into three categories: manufacturing defects, external causes, fuel-cladding interactions.

Manufacturing defects include faulty components, faulty content and faulty assembly. Faulty components shows a very low incidence because of the simplicity of the fuel rod's design; of the 700,000 rods irradiated in 1971, none showed a fabrication defect of any kind (Ref 41:185). The most significant type of faulty content defect is contamination of the fuel by a hydrogenous compound such as water; hydrogen interacts with the Zircaloy cladding by a process called hydriding. The formation of zirconium hydride makes the clad brittle and causes a clad volume increase; these two changes in the clad can lead to cracking. The most frequent incidence of faulty assembly involved end-plug welds; but these are an insignificant contributor to fuel failure as they are usually detected by the quality control measures of the manufacturer.

External causes of clad failure include the following: fuel handling, foreign bodies, fuel overpower, vibration and fretting, cladding corrosion. In many power reactors fuel management requires that irradiated fuel assemblies be repositioned at the end of a cycle; these assemblies are then irradiated again in a subsequent cycle. This repositioning subjects the cladding to mechanical forces

when it is most susceptible to damage, i.e. when embrittled by irradiation damage and some degree of hydriding. The current design of fuel handling equipment has practically eliminated fuel handling as a cause of failure.

If a foreign body is trapped between fuel rods, it may be excited into vibration by the flow of coolant; the relatively thin cladding is then susceptible to fretting (chafing) damage. Start-up cleanliness of the primary coolant circuit precludes this failure mechanism.

Since in operation the fuel expands more than the cladding, some voidage is usually provided within the fuel rod to allow for this differential expansion. The magnitude and location of the voidage is at least roughly matched to the expected temperature distribution of the fuel, which in turn depends on the power developed in the fuel. If the power developed is considerably greater than that for which the fuel rod was designed, the cladding can be overstressed to the point of failure.

In some power reactors, vibration of the fuel assemblies has resulted in severe fretting, and even penetration of the cladding. In some instances a complete string of fuel assemblies has vibrated against a tube containing it, while in others a spacer grid or similar component has vibrated against the fuel rods.

Cladding corrosion is assigned to external causes since the corrosion resistance of Zircaloy is adequate to ensure good fuel rod performance as long as the coolant

chemistry is well controlled. Where corrosion-induced fuel failures have been reported the basic cause has been a heavy build-up of deposits on the cladding surface, resulting in the Zircaloy corrosion occurring at a much higher temperature than expected on the clad outer surface.

Fuel-cladding interactions include the following mechanisms: rod elongation, fuel densification, cladding fatigue, power ramp failures. Rod elongation and fuel densification shorten the useful life of a fuel rod, but do not actually constitute defect mechanisms; neither of these mechanisms has directly caused a reported clad rupture. Cladding fatigue also has yet to be blamed for any fuel failures in power reactors, but clad failure by fatigue was demonstrated by some early steel-clad experimental fuel rods. Power ramp failures, however, have been the direct cause of reported clad ruptures.

When reactor power is raised initially the cladding is undamaged by irradiation and fuel-cladding clearances are available to accommodate differential thermal expansion. If the power is subsequently increased from a low level to a high level, the cladding is somewhat embrittled by irradiation damage while the clearances have been at least partly taken up by fuel swelling and by the cladding creeping inward; most cladding will slowly deform under the coolant pressure by irradiation-accelerated creep. Thus there exists the potential for power ramps to crack the cladding; defect probability in ramping failures increases

with power, power increase, burnup, and dwell time at high power (Ref 42).

A fuel-cladding interaction not discussed by Robertson is fission product induced corrosion of cladding; Wood identifies iodine corrosion as a contributor to power ramp failures (Ref 42:157). Cesium has also been associated with cladding corrosion (Ref 38:144).

Of greater importance than clad failure cause is clad failure rate. Multer summarizes European fuel performance (Ref 43). For PWR's with Westinghouse stainless steel clad fuel rods and a burnup of 28,000 MWD/T, the average failure rate has been 0.02%. Zircaloy cladding has reduced the failure rate to 0.01% in some cases, but for PWR's the average failure rate remains close to 0.02%. BWR fuel has shown an average failure rate of 0.01%.

Williamson and Proebstle examine American BWR experience and recent BWR fuel improvements (Ref 44); they conclude that the newest General Electric BWR fuel is demonstrating a failure rate of 0.006%. Kramer examines the American experience with PWR fuel (Ref 45); he shows an average failure rate of 0.02% and forecasts no foreseeable improvement. The lower failure rate in BWR fuel can be attributed to the thicker cladding (.025 inch for PWR, .033 inch for BWR) and to the lower coolant pressure (2000 PSI for PWR, 1000 PSI for BWR).

In summary, breach of fuel cladding is a result of clad failure. Current clad failures are usually attributed

to hydriding and power ramps, and fission product corrosion is recognized as a contributor to power ramp failures. The current clad failure rate is 0.02% for PWR's and 0.01% for BWR's; a slight improvement in BWR fuel is forecast. Data on Combustion Engineering Inc. (C-E) and Kraftwerf Union (KWU) fuels shows similar failure rates (Ref 46).

Escape from Primary Coolant to Environment

Fig. 17 shows fission product escape mechanisms from primary coolant to environment. Environmental Protection Agency (EPA) surveillance studies describe the radwaste systems designed to prevent this escape and analyze their effectiveness (Ref 47, 48). The relative abundances of radionuclides in waste effluents are functions of (Ref 49:3):

- (1) their abundance in the primary coolant
- (2) their respective half-lives
- (3) design of the radwaste treatment system
- (4) waste treatment practices

Radwaste systems in use in American LWR's are a compromise between cost and effectiveness. The release rate of cesium by a current BWR could be reduced by a factor of 1000 with a "maximum" radwaste system costing twice as much as a current radwaste system (Ref 50:49,52); a radwaste system described by the EPA as a "minimum treatment" system would have half the cost of a current system and a cesium release rate 100 times greater. For a PWR, a "minimum treatment" radwaste system would have one-fourth the cost of a current system and a cesium release




Fig. 17. Fission Product Escape Mechanisms for Primary Coolant to Environment (Ref. 32:6)

rate 100 times greater (Ref 50:59, 61).

The maximum coolant canal concentrations of Cs134 and Cs137 measured by the EPA at Dresden I, a BWR with 0.01% fuel failure rate, are $1.6E-12$ Curies/L and $4.3E-12$ Curies/L, respectively (Ref 10). The maximum stack release rate of Cs137 measured at Dresden is $5.5E-11$ Curies/sec; no measurement is reported for Cs134. These measurements were made just before the end of a fuel cycle; some of the fuel rods were approaching maximum rated burnup.

The maximum coolant canal concentrations of Cs134 and Cs137 measured by the EPA at Haddam Neck, a PWR with 0.02% fuel failure rate, are $4.0E-13$ Curies/L and $3.0E-13$ Curies/L, respectively (Ref 12). The maximum stack release rates of Cs134 and Cs137 measured at Haddam Neck are $4.8E-11$ Curies/sec and $3.3E-11$ Curies/sec, respectively. Again, these measurements were made well into the fuel cycle when some fuel had attained high burnup.

Of the cesium concentrations reported above, the BWR has the higher reported values for both coolant canal and stack gas; the BWR values will now be used to determine the limiting distance at which the Cs134/Cs137 activity ratio could be measured.

VI. Detection

Cesium escaping through the reactor stack is a very fine particulate; particulate samples are normally collected on a filter medium with an air pump and a flow-measuring device. Gamma-spectrometric analysis for Cs134 and Cs137 requires collection of at least 1200 cubic meters of air; the minimum detectable level for both isotopes is $1\text{E-}14$ Curies/cubic meter (Ref 51:10). Since the clandestine collection of such a large volume of air would require a reasonable distance between reactor and collection point, a collection point at 1500 m (1 mile) will be assumed.

Goodwin (Ref 3:70) gives a good review of various models of atmospheric dispersion; EPA uses the following generalized Guassian diffusion equation (Ref 10:97):

$$X = Q / \pi \sigma_y \sigma_z \bar{u} e^{-(h^2 / 2 \sigma_z^2)} \quad (20)$$

where

X = ground-level centerline concentration
(Curies/cubic meter)

Q = release rate (Curies/sec)

σ_y, σ_z = lateral and vertical dispersion coefficients (m)

\bar{u} = mean wind speed at height of release (m/sec)

h = effective release height (m)

Normalized concentrations ($X\bar{u}/Q$) as a function of distance from the stack developed by Brookhaven are used in the

solution of this equation.

The maximum measured release rate of Cs137 at Dresden is $5.5E-11$ Curies/sec. Cs134 is not reported, but can be assumed to escape with a release rate of the same order of magnitude as Cs137. The EPA reports highest ground-level centerline effluent concentrations for neutral atmospheric stability and 6 m/sec windspeed at release height (Ref 10:48); the stack height at Dresden is 91 m. Using the dispersion coefficients for these conditions, solution of Eq(20) gives a Cs137 concentration of $1.59E-16$ Curies/cubic meter at 1 mile from the stack; this concentration is two orders of magnitude less than the EPA's minimum detectable level. Clearly, there are other ways to approach the detectability of a given release rate; given the atmospheric conditions, the point of maximum ground-level concentration can be calculated and assumed to be the collection point. However, the preceding calculation is so biased in favor of a high Cs137 concentration (particulate settling disregarded) that further treatment is unnecessary.

The EPA recommends a sample size of 3.5L for gamma-spectrometric analysis of cesium in water (Ref 51:10); the minimum detectable concentration is $1E-11$ Curies/L. Clandestine collection of a sample of this size precludes use of the discharge canal itself; dilution by the body of water receiving the discharge canal must be assumed.

The maximum measured coolant canal concentrations at Dresden are $1.6E-12$ Curies/L for Cs134 and $4.3E-12$

Curies/L for Cs137. The coolant canal discharges into a river whose average flow rate is 11,000 cubic feet/sec (cfs); the dilution rate in such a situation is a function of an unmanageable number of variables. EPA, however, uses a very simplistic approach to arrive at a dilution factor of 50 (Ref 10:60). Another EPA report calculates a dilution factor of 25 for a river with average flow rate of 18,000 cfs (Ref 12:67). The lower dilution factor will be used in the interest of maximizing the cesium concentration at the collection point. Dilution of the canal concentrations by a factor of 25 results in sample concentrations of $6.4E-14$ Curies/L for Cs134 and $1.72E-13$ Curies/L for Cs137; these concentrations are two orders of magnitude less than EPA's minimum detectable level. Again, this calculation has been biased toward a high cesium concentration.

The fact that the EPA's minimum detectable level (MDL) for cesium in water is an order of magnitude greater than the reported coolant canal level is explained by the fact that the MDL required for measuring a cesium ratio is an order of magnitude greater than the MDL required for simple measurement of cesium. The canal levels are just above the MDL for simple measurement of cesium.

The accuracy of this type of measurement is addressed by Gans (Ref 52); he submitted identical samples containing on the order of $1E-9$ Curies/L of Cs134 and Cs137 to 28 laboratories in Germany and Holland that routinely perform

analytical work for the nuclear industry. He reports a 10% variation in the measurements reported; furthermore, he predicts errors on the order of 100% when measuring concentrations close to the MDL's used herein.

VII. Results, Conclusions and Recommendations

Using measured effluent concentrations of Cs134 and Cs137 from an American BWR with a characteristic fuel failure rate of 0.01%, calculated concentrations at assumed sample collection points are two orders of magnitude less than EPA prescribed minimum detectable levels. These calculations are biased toward the high side, and the problem of different release rates of the cesium isotopes from the fuel matrix is disregarded. If minimum radwaste systems are assumed, the sample concentrations might approach minimum detectable level, but measurements at this low level of concentration are of questionable accuracy. It is concluded that the activity ratio Cs134/Cs137 is not an acceptable off-site indicator of burnup.

The neodymium isotopes, Nd145 and Nd146, have fission yields of the same order of magnitude as Cs137, but only $3.15E-7$ of neodymium's precursor is able to escape the fuel matrix. Clearly, the collection point concentration of neodymium will be far less than that of cesium; conversion of the expected Cs137 concentration (using minimum radwaste system) to a number density and reduction of this number density by a factor of $3.15E-7$ gives an expected neodymium number density on the order of 1 atom/L for a liquid sample and 10 atoms/L for an air sample. Measurement of such levels is not possible; the ratio Nd146/Nd145 is not acceptable as an off-site indicator of burnup.

Radioactive noble gases have been successfully measured by the EPA at 1 mile from the stack; it is recommended that radioactive isotopes of Xenon and Krypton be examined as indicators of burnup.

Bibliography

1. Weitcamp, C., et al. "The role of Nuclear Data in Nuclear Material Safeguards," Nuclear Data in Science and Technology, pp. 197-216. Vienna: IAEA, 1973.
2. Bell, M. J. Origen - The ORNL Isotope Generation and Depletion Code. Oak Ridge: Union Carbide Corporation, 1973.
3. Goodwin, R.C. "Nuclear Safeguards Implications of Off-Site Fission Product Monitoring of Commercial Power Reactors." MS thesis, AFIT/GNE/PH/78-4.
4. Foggi, C. "Isotope Correlations Based on Fission-Product Nuclides in LWR Fuels," Safeguarding Nuclear Materials, pp 425-438. Vienna: IAEA, 1976.
5. Maeck, W. J. Proposed Determination of Nuclear Fuel Burnup Based on the Ratio of Two Stable Fission Products of the Same Element. Idaho Falls, Id.: Phillips Petroleum Co., 1965.
6. Hick, H. and M. Lammer. "Interpretation of Gamma-spectrometric Measurements on Burnt Fuel Elements," Proceedings of Int. Conf. Progress in Safeguards Techniques. Vienna: IAEA, 1970.
7. Lederer, C. M. Table of Isotopes, 6th ed. New York: Wiley and Sons, 1967.
8. Weast, R. C. Handbook of Chemistry and Physics, 49th ed. Cleveland: Chemical Rubber Co., 1968.
9. RG1.21. U. S. Atomic Energy Commission Regulatory Guide. Washington: USAEC, 1974.
10. Kahn, B., et al. Radiological Surveillance Studies at a Boiling Water Nuclear Power Reactor. Cincinnati: Environmental Protection Agency, 1971.
11. Hyde, E. K., et al. Nuclear Properties of the Heavy Elements, III. Englewood Cliffs, N. J.: Prentice Hall, 1964.
12. Kahn, B., et al. Radiological Surveillance Study at the Haddam Neck PWR Nuclear Power Station. Cincinnati: USEPA, 1974.
13. Sanatani, S. and P. Siwy. "IAEA Bank of Correlated Isotopic Composition Data," Safeguarding Nuclear Materials, pp 439-448. Vienna: IAEA, 1976.

14. Foggi, C. and W. L. Zijp. "Data Treatment for the Isotopic Correlation Technique," Safeguarding Nuclear Materials, pp 405-424. Vienna: IAEA, 1976.
15. Eder, O. J. and M. Lammer. "Influence of Uncertainties in Fission Product Nuclear Data on the Interpretation of Gamma-spectrometric measurements on Burnt Fuel Elements," Nuclear Data in Science and Technology, pp 233-268. Vienna: IAEA, 1973.
16. Maeck, W. J. "Fission Product Nuclear Data Requirements for the Determination of Nuclear Fuel Burnup," Fission Product Nuclear Data, pp 163-190. Vienna: IAEA, 1974.
17. Weitkamp, C. "Importance of Fission Product Nuclear Data for Safeguards Techniques," Fission Product Nuclear Data, pp 191-212. Vienna: IAEA, 1974.
18. Hick, H., et al. The Establishment of Complete Fission Product Inventories for Irradiated Fuel Fuel Elements. D. P. Report 754. Dorchester, England: A.E.E. Winfrith, 1971.
19. Henry, A. F. Nuclear Reactor Analysis. Cambridge, Mass.: MIT Press, 1975.
20. Dragnev, T. and C. Beets. "Identification of Irradiated Fuel Elements," Joint Integral Safeguards Experiment (JEX 70), pp 12-44. Mol, Belgium: Euratom, 1971.
21. 1013059-2C. SR56 Applications Library. Dallas: Texas Instruments Inc., 1976.
22. Robin, M. "The Importance of Fission Product Nuclear Data in Burnup Determination," Fission Product Nuclear Data, pp 59-75. Vienna: IAEA, 1974.
23. Bresesti, M. and P. Peroni. "Gamma Measurements on Trino Fuel Assemblies," Joint Safeguards Experiment Mol IV. Vienna: IAEA, 1975.
24. Leender, L. "Contribution to the Investigation of Isotopic Correlations among Non-Destructive Measurements on Fuel Rods," Joint Safeguards Experiment Mol IV. Vienna: IAEA, 1975.
25. Beets, C., et al. "Gamma Measurements on Sena Spent Fuel Assemblies and Dissolver Solutions," Joint Safeguards Experiment Mol IV. Vienna: IAEA, 1975.
26. Paoletti Gualandi, M., et al. "Determination of Burnup and Plutonium Content in Irradiated Fuels by Gamma-spectrometry measurements of Radioactive Fission Products," Safeguarding Nuclear Materials. Vienna: IAEA, 1975.

27. Koch, L., et al. "Improvements and Experience in the Analysis of Reprocessing Samples," Safeguarding Nuclear Materials. Vienna: IAEA, 1976.
28. Hsue, T. "Passive Gamma Assay of Irradiated Fuel," LA-6849-PR. Los Alamos: LASL, 1977.
29. URSU, I., et al. "Cooling-Time Determination of the Nuclear Fuel For a VVR-S Reactor," Safeguarding Nuclear Materials. Vienna: IAEA, 1976.
30. Koch, L., et al. "Fission Gas Correlations," Joint Safeguards Experiment Mol IV. Vienna: IAEA, 1975.
31. Goldman, D. and J. Roesser. Chart of the Nuclides. Schenectady, N. Y.: Knolls Atomic Power Laboratory, 1966.
32. Eckart, L. "The Relative Environmental Hazard of Fission Products Released from Defective Fuel Rods." PHD Dissertation, Univ. Cincinnati, 1971.
33. Lish, K. Nuclear Power Plant Systems and Equipment. New York: Industrial Press Inc., 1972.
34. "Sequoyah Nuclear Station," Nuclear Engineering International. (October 1971).
35. 6BWR. General Description of a Boiling Water Reactor. San Jose, Calif.: General Electric, 1973.
36. Friskney, C. and M. Sepeight. "A calculation on the In-Pile Diffusional Release of Fission Products Forming a General Decay Chain," Journal of Nuclear Materials, 62: 89-94 (February 1976).
37. Brown, P. and R. Faircloth. "Metal Fission Product Behavior in High Temperature Reactors," Journal of Nuclear Materials, 59: 29-41 (August 1975).
38. Lawrence, L., et al. "Cesium Relocation in Mixed Oxide Fuel Pins Resulting from Increased Temperature Reirradiation," Transactions of the American Nuclear Society, 23: 144-146 (1976).
39. Erdman, C. Radionuclide Production Transport and Release from Normal Operation of a LMFBR. Charlottesville: Univ. Virginia Press, 1975.
40. Robertson, J. "Nuclear Fuel Failures, Their Causes and Remedies," Proceedings of Joint Topical Meeting on Commercial Nuclear Fuel Technology Today. Toronto: American Nuclear Society, 1975.

41. Haywood, L., et al. Proceedings of the Fourth United Nations International Conference on Peaceful Uses of Atomic Energy, 8. Geneva; U.N., 1971.
42. Wood, J. "Environmentally Influenced Failure of Uranium Dioxide Zircaloy Fuel," Transactions of the American Nuclear Society, 23: 157-158 (1976).
43. Multer, M. "European Operating Experience," Proceedings of Joint Topical Meeting on Commercial Nuclear Fuel Technology Today. Toronto: American Nuclear Society, 1975.
44. Williamson, H. and R. Proebstle. "Results with BWR Fuel Improvements," Proceedings of Joint Topical Meeting on Commercial Nuclear Fuel Technology Today. Toronto: American Nuclear Society, 1975.
45. Kramer, F. "PWR Fuel Performance - The Westinghouse View," Proceedings of Joint Topical Meeting on Commercial Nuclear Fuel Technology Today. Toronto: American Nuclear Society, 1975.
46. Smerd, P. and H. Stehle. "C-E/KWU Operating Experience with LWR Fuel," Transactions of the American Nuclear Society, 23: 256-257 (1976).
47. Kahn, B., et al. Radiological Surveillance Studies at a Pressurized Water Nuclear Power Reactor. Cincinnati: EPA, 1971.
48. Blanchard, R., et al. Radiological Surveillance Studies at the Oyster Creek BWR Generating Station. Cincinnati: EPA, 1976.
49. Logsdon, J. and R. Chissler. Radioactive Waste Discharges to the Environment from Nuclear Power Facilities. Rockville, Md.: U. S. Dept. of Health, Education and Welfare, 1970.
50. EPA-520/9-73-003-C. Environmental Analysis of the Uranium Fuel Cycle, II. Washington: EPA, 1973.
51. ORP/SID 72-2. Environmental Radioactivity Surveillance Guide. Washington: EPA, 1972.
52. Gans, I. "Experiences in Round Robin Tests with Samples of Liquid Effluents from Nuclear Power Stations in Germany," Environment International, 1:101-102 (1978).

Vita

James L. Clark Jr. was born 29 Jan 43 in Joplin, Missouri. He graduated from Lincoln-Sudbury Regional High School in Lincoln, Mass. in 1961 and from the University of Georgia in 1968. He then entered the U. S. Marine Corps as a Second Lieutenant and upon completion of training served as a rifle platoon commander in the Republic of Vietnam. Subsequent to this tour with the Third Marine Division he was assigned as security officer of the Philadelphia Naval Base. After 3 years in Philadelphia, he was transferred to Camp Lejeune, N. C. and served as a rifle company commander in the Second Marine Division. He then attended the Advanced Infantry Officer course at Ft. Benning, Ga. Upon graduation, he was assigned as commanding officer of the Marine Detachment aboard USS Constellation (CV-64).

In June of 1977, Captain Clark entered the Graduate Nuclear Effects program, Air Force Institute of Technology.

Permanent address: Lavonia, Ga.

Appendix A

Krypton and Xenon Effluent Concentrations
Versus Background Concentrations

Molecular Fraction of Kr in Air: 1.0 E-6
Number Density of Air: 2.548 E19 cm-3
Number Density of Kr: 2.548 E13 cm-3
Kr84 Natural Abundance: 0.5690
Kr83 Natural Abundance: 0.1155
Kr84 Number Density: 1.45 E13 cm-3
Kr83 Number Density: 2.94 E12 cm-3

Molecular Fraction of Xe in Air: 8.0 E-8
Number Density of Xe: 2.04 E12 cm-3
Xe131 Natural Abundance: 0.2118
Xe132 Natural Abundance: 0.2689
Xe134 Natural Abundance: 0.1044
Xe136 Natural Abundance: 0.0887
Xe131 Number Density: 4.32 E11 cm-3

Xe132 Number Density: 5.49 E11 cm⁻³

Xe134 Number Density: 2.13 E11 cm⁻³

Xe136 Number Density: 1.81 E11 cm⁻³

Maximum Observed Stack Gas Concentration of Kr85 at
Oyster Creek: 3.2 E-7 $\mu\text{Ci/cc}$

Maximum Observed Stack Gas Concentration of Xe133 at
Oyster Creek: 1.9 E-4 $\mu\text{Ci/cc}$

$$\text{Activity} = \lambda N$$

$$\lambda_{\text{Kr85}} = 2 \text{ E-}9 \text{ sec}^{-1}$$

$$\lambda_{\text{Xe133}} = 1.52 \text{ E-}6 \text{ sec}^{-1}$$

$$N = \text{Activity} / \lambda$$

$$N_{\text{Kr85}} = 5.92 \text{ E}6 \text{ cm}^{-3}$$

$$N_{\text{Xe133}} = 4.63 \text{ E}6 \text{ cm}^{-3}$$

For every 100 atoms of U_{235} thermally fissioned, following
number of atoms created:

Kr83	-	0.48
Kr84	-	1.10
Kr85	-	1.50
Xel31	-	2.64
Xel32	-	4.35
Xel33	-	0.360
Xel34	-	7.60
Xel36	-	6.30

Kr83 and Kr84 can be expected to be present in stack gas in concentration on the order of $1E6$ per cubic centimeter.

Xel31, 132, 133, 134, 136 can be expected to be present in stack gas in concentration on the order of $1E7$ per cubic centimeter.

Appendix B

Cesium Production Equations

$$\frac{dN_{235}^U}{dt} = -N_{235}^U \sigma_a \phi$$

$$C_{1A} = -\sigma_a \phi$$

$$L\{N'\} = sL\{N\} - N(0)$$

$$L\{C_{1A}N\} = C_{1A}L\{N\}$$

$$sL\{N\} - N(0) = C_{1A}L\{N\}$$

$$sL\{N\} - C_{1A}L\{N\} = N(0)$$

$$L\{N\} = N(0) / (s - C_{1A})$$

$$L\{e^{kt}\} = 1 / (s - k)$$

$$N = N(0) e^{C_{1A}t}$$

$$N_{235}^U = N_{235}^U(0) e^{-\sigma_a \phi t}$$

By similar calculations, the following solutions were determined. The constants are defined in Appendix C.

$$N_{133}^{sb} = C_5 e^{-c_2 t} - C_6 e^{-c_3 t}$$

$$N_{133}^{Te} = C_{13} e^{-c_{10} t} + C_{14} e^{-c_2 t} - C_{15} e^{-c_3 t}$$

$$N_{153}^I = C_{23} e^{-c_2 t} - C_{24} e^{-c_3 t} + C_{25} e^{-c_{10} t} + C_{26} e^{-c_{20} t}$$

$$N_{153}^{Xe} = C_{35} e^{-c_2 t} - C_{36} e^{-c_3 t} + C_{37} e^{-c_{10} t} + C_{38} e^{-c_{20} t} + C_{39} e^{-c_{29} t}$$

$$N_{153}^{Cs} = C_{47} e^{-c_2 t} - C_{48} e^{-c_3 t} + C_{49} e^{-c_{10} t} + C_{50} e^{-c_{20} t} + C_{51} e^{-c_{29} t} + C_{52} e^{-c_{40} t}$$

$$N_{134}^{Cs} = C_{66} e^{c_{67}} - C_{68} e^{c_{69}} + C_{70} e^{c_{71}} + C_{72} e^{c_{73}} + C_{74} e^{c_{75}} + C_{76} e^{c_{77}} + C_{78} e^{c_{79}}$$

$$N_{137}^I = D_7 e^{-D_2 t} + D_8 e^{-D_5 t}$$

$$N_{157}^{Xe} = D_{13} e^{-D_2 t} + D_{14} e^{-D_5 t} + D_{15} e^{-D_9 t}$$

$$N_{187}^{Cs} = D_{26} e^{D_{27}} + D_{25} e^{D_{28}} + D_{24} e^{D_{29}} + D_{23} e^{D_{20}}$$

Appendix C
Program Test

```
PROGRAM TEST(INPUT,OUTPUT)
REAL I133I,I137I
DIMENSION INTEGR(6)
DATA INTEGR/3*(-0),0,2*(-0)/
CALL SYSTEMC(115,INTEGR)
READ*,U235I,SIGF,SIGA
READ*,S3133I,YSB133,DSB133
READ*,TE133I,YTE133,DTE133
READ*,I133I,YI133,OI133
READ*,XE133I,XE133C,DXE133
READ*,CS133I,CS133C
READ*,CS134I,YCS134,DCS134,CS134C
READ*,I137I,YI137,OI137
READ*,XE137I,DXE137
READ*,CS137I,YCS137,DCS137,CS137C
READ*,T
DO 101 I=1,10
READ*,PHI
C1A=U235I*SIGF*PHI
C1=YSB133*C1A
C2=SIGA*PHI
C3=DSB133
C4=S3133I
C5=C1/(C3-C2)
C6=(C1+(C2*C4)-(C3*C4))/(C3-C2)
C7=YTE133*C1A
C8=C3*C5
C9=C3*C6
C10=DTE133
C11=C7+C3
C12=TE133I
C13=C11/(C2-C10)+C12-C9/(C3-C10)
C14=C11/(C10-C2)
C15=C9/(C10-C3)
C16=YI133*C1A
C17=C10*C13
C18=C10*C14
C19=C10*C15
C20=OI133
C21=C16+C18
C22=I133I
C23=C21/(C20-C2)
C24=C19/(C20-C3)
C25=C17/(C20-C10)
C26=C22+C17/(C10-C20)-C19/(C3-C20)
C27=XE133C*PHI
C28=DXE133
C29=C27+C28
C30=C20*C23
C31=C20*C24
C32=C20*C25
C33=C20*C26
C34=XE133I
C35=C30/(C29-C2)
C36=C31/(C29-C3)
C37=C32/(C29-C10)
C38=C33/(C29-C20)
```

C39=C30/(C2-C29)-C31/(C3-C29)+C32/(C10-C29)+C33/(C20-C29)+C34
 C40=C3133C*PHI
 C41=C29*035
 C42=C28*036
 C43=C26*037
 C44=C28*038
 C45=C26*039
 C46=CS133I
 C47=C41/(C40-C2)
 C48=C42/(C40-C3)
 C49=C43/(C40-C10)
 C50=C44/(C40-C20)
 C51=C45/(C40-C29)
 C52=C41/(C2-C40)-C42/(C3-C40)+C43/(C10-C40)+C44/(C20-C40)+
 1C45/(C23-C40)+C46
 C53=YCS134*C1A
 C54=CS133C*PHI
 C55=CS134C*PHI
 C56=DCS134
 C57=C54*047
 C58=C54*048
 C59=C54*049
 C60=C54*050
 C61=C54*051
 C62=C54*052
 C63=CS134I
 C64=C55+056
 C65=C53+057
 C66=C65/(C64-C2)
 C67=-C2*T
 C68=C58/(C64-C3)
 C69=-C3*T
 C70=C59/(C64-C10)
 C71=-C10*T
 C72=C60/(C64-C20)
 C73=-C20*T
 C74=C61/(C64-C29)
 C75=-C23*T
 C76=C62/(C64-C40)
 C77=-C40*T
 C78=C65/(C2-C64)-C58/(C3-C64)+C59/(C10-C64)+C60/(C20-C64)+
 1C61/(C23-C64)+C62/(C40-C64)+C63
 C79=-C64*T
 AMT134=C56*EXP(C67)-C68*EXP(C69)+C70*EXP(C71)+C72*EXP(C73)+
 1C74*EXP(C75)+C76*EXP(C77)+C78*EXP(C79)
 D1=C1A
 D2=C2
 D3=YI137
 D4=D1*03
 D5=DI137
 D6=I137I
 D7=D4/(D5-D2)
 D8=D6+D4/(D2-D5)
 D9=DXE137
 D10=D5*07
 D11=D5*03
 D12=XE137I

```
D13=D10/(D9-D2)
D14=D11/(D9-D5)
D15=D10/(D2-D3)+D11/(D5-D9)+D12
D16=YCS137*D1
D17=DCS137
D18=D9*D13
D19=D9*D14
D20=D9*D15
D21=D16+D18
D22=CS137I
D23=D21/(D2-D17)+D19/(D5-D17)+D20/(D9-D17)+D22
D24=D20/(D17-D9)
D25=D19/(D17-D5)
D26=D21/(D17-D2)
D27=-D2*T
D28=-D5*T
D29=-D9*T
D30=-D17*T
AMT137=D26*EXP(D27)+D25*EXP(D28)+D24*EXP(D29)+D23*EXP(D30)
ACT134=AMT134*DCS134
ACT137=AMT137*DCS137
R=ACT134/ACT137
PRINT*,"PHI=",PHI," T=",T," AMT134=",AMT134," AMT137=",AMT137
U235I=U235I*EXP(-C2*T)
PRINT*,"U235I=",U235I
SB133I=C5*EXP(-C2*T)-C6*EXP(-C3*T)
TE133I=D13*EXP(-D10*T)+C14*EXP(-C2*T)-C15*EXP(-C3*T)
I133I=C23*EXP(-C2*T)-C24*EXP(-C3*T)+C25*EXP(-C10*T)+
1C26*EXP(-C20*T)
XE133I=C35*EXP(-C2*T)-C36*EXP(-C3*T)+C37*EXP(-C10*T)+
1C38*EXP(-C20*T)+C39*EXP(-C29*T)
CS133I=C47*EXP(-C2*T)-C48*EXP(-C3*T)+C49*EXP(-C10*T)+
1C50*EXP(-C20*T)+C51*EXP(-C29*T)+C52*EXP(-C40*T)
CS134I=AMT134
I137I=D7*EXP(-D2*T)+D8*EXP(-D5*T)
XE137I=D13*EXP(-D2*T)+D14*EXP(-D5*T)+D15*EXP(-D9*T)
CS137I=AMT137
101 CONTINUE
STOP"END OF PROGRAM"
END
```

PHI=2.58E+13	T=3504000.	AMT134=15613.54278132	AMT137=808378.9137188
U235I=123421827.2363			
PHI=2.58E+13	T=3504000.	AMT134=61007.09069415	AMT137=1515457.695977
U235I=103606767.4168			
PHI=2.63E+13	T=9504000.	AMT134=129223.0384943	AMT137=2144651.409578
U235I=95688350.35563			
PHI=2.71E+13	T=3504000.	AMT134=215315.9192732	AMT137=2708360.659031
U235I=63323344.43414			
PHI=2.91E+13	T=3504000.	AMT134=315358.9269831	AMT137=3213168.312299
U235I=73071723.24519			
PHI=2.33E+13	T=3504000.	AMT134=426204.1643204	AMT137=3666777.531047
U235I=63326044.83113			
PHI=3.05E+13	T=3504000.	AMT134=544137.6154911	AMT137=4068316.037954
U235I=54560763.66557			
PHI=3.18E+13	T=3504000.	AMT134=666212.5866371	AMT137=4423405.501187
U235I=46710563.55466			
PHI=3.31E+13	T=3504000.	AMT134=739190.2450973	AMT137=4732903.049116
U235I=39736691.73048			
PHI=3.45E+13	T=3504000.	AMT134=910626.0885073	AMT137=5000517.907307
U235I=33573617.12123			

Program YCSFOUR

```
PROGRAM YCSFOUR(INPUT,OUTPUT)
REAL I133I,I137I
DIMENSION INTEGR(6),ARRAY1(10),ARRAY2(10),ARRAY3(4,2)
DATA INTEGR/3*(-0),0,2*(-0)/
CALL SYSTEMC(115,INTEGR)
READ*,U235I,SIGF,SIGA
READ*,SB133I,YSB133,DSB133
READ*,TE133I,YTE133,DTE133
READ*,I133I,YI133,DI133
READ*,XE133I,XE133C,DXE133
READ*,CS133I,CS133C
READ*,I137I,YI137,DI137
READ*,XE137I,DXE137
READ*,CS137I,YCS137,DCS137,CS137C
READ*,ARRAY1,ARRAY2,ARRAY3
PRINT*,ARRAY1
PRINT*,ARRAY2
PRINT*,ARRAY3
DO 101 I=1,10
PHI=ARRAY1(I)
DO 101 J=1,10
T=ARRAY2(J)
DO 101 K=1,2
CS134I=ARRAY3(1,K)
YCS134=ARRAY3(2,K)
DCS134=ARRAY3(3,K)
CS134C=ARRAY3(4,K)
C1A=U235I*SIGF*PHI
C1=YSB133*C1A
C2=SIGA*PHI
C3=DSB133
C4=SB133I
C5=C1/(C3-C2)
C6=(C1+(C2*C4)-(C3*C4))/(C3-C2)
C7=YTE133*C1A
C8=C3*C5
C9=C3*C6
C10=DTE133
C11=C7+C8
C12=TE133I
C13=C11/(C2-C10)+C12-C9/(C3-C10)
C14=C11/(C10-C2)
C15=C9/(C10-C3)
C16=YI133*C1A
C17=C10*C13
C18=C10*C14
C19=C10*C15
C20=DI133
C21=C16+C18
C22=I133I
C23=C21/(C20-C2)
C24=C19/(C20-C3)
C25=C17/(C20-C10)
C26=C22+C17/(C10-C20)-C19/(C3-C20)
C27=XE133C*PHI
C28=DXE133
C29=C27+C28
```

AD-A066 200


AIR FORCE INST OF TECH WRIGHT-PATTERSON AFB OHIO SCH--ETC F/6 18/12
ISOTOPIC CORRELATION TECHNIQUES AS AN OFF-SITE REACTOR MONITOR.(U)

OCT 78 J L CLARK
AFIT/ONE/PH/78-12


UNCLASSIFIED

NL

2 OF 2
AD
A066200



END
DATE
FILMED
5 -79
DDC



C30=C20*C23
 C31=C20*C24
 C32=C20*C25
 C33=C20*C26
 C34=XF133I
 C35=C30/(C29-C2)
 C36=C31/(C29-C3)
 C37=C32/(C29-C10)
 C38=C33/(C29-C20)
 C39=C38/(C2-C29)-C31/(C3-C29)+C32/(C10-C29)+C33/(C20-C29)+C34
 C40=CS133C*PHI
 C41=C28*C35
 C42=C28*C36
 C43=C28*C37
 C44=C28*C38
 C45=C28*C39
 C46=CS133I
 C47=C41/(C40-C2)
 C48=C42/(C40-C3)
 C49=C43/(C40-C10)
 C50=C44/(C40-C20)
 C51=C45/(C40-C29)
 C52=C41/(C2-C40)-C42/(C3-C40)+C43/(C10-C40)+C44/(C20-C40)+
 1C45/(C29-C40)+C46
 C53=YCS134*C1A
 C54=CS133C*PHI
 C55=CS134C*PHI
 C56=DCS134
 C57=C54*C47
 C58=C54*C48
 C59=C54*C49
 C60=C54*C50
 C61=C54*C51
 C62=C54*C52
 C63=CS134I
 C64=C55+C56
 C65=C53+C57
 C66=C65/(C64-C2)
 C67=-C2*T
 C68=C58/(C64-C3)
 C69=-C3*T
 C70=C59/(C64-C10)
 C71=-C10*T
 C72=C60/(C64-C20)
 C73=-C20*T
 C74=C61/(C64-C29)
 C75=-C29*T
 C76=C62/(C64-C40)
 C77=-C40*T
 C78=C65/(C2-C64)-C53/(C3-C64)+C59/(C10-C64)+C60/(C20-C64)+
 1C61/(C29-C64)+C52/(C40-C64)+C63
 C79=-C64*T
 AMT134=C66*EXP(C67)-C68*EXP(C69)+C70*EXP(C71)+C72*EXP(C73)+
 1C74*EXP(C75)+C76*EXP(C77)+C78*EXP(C79)
 P1=C1A
 D2=C2
 Q3=YI137

```

D4=D1*D3
D5=DI137
D6=I137I
D7=D4/(D5-D2)
D8=D6+D4/(D2-D5)
D9=DXE137
D10=D5*D7
D11=D5+D5
D12=XE137I
D13=D10/(D9-D2)
D14=D11/(D9-D5)
D15=D10/(D2-D9)+D11/(D5-D9)+D12
D16=YCS137*D1
D17=DCS137
D18=D9*D13
D19=D9*D14
D20=D9*D15
D21=D16+D13
D22=CS137I
D23=D21/(D2-D17)+D19/(D5-D17)+D20/(D9-D17)+D22
D24=D20/(D17-D9)
D25=D19/(D17-D5)
D26=D21/(D17-D2)
D27=-D2*T
D28=-D5*T
D29=-D9*T
D30=-D17*T
AMT137=D26*EXP(D27)+D25*EXP(D28)+D24*EXP(D29)+D23*EXP(D30)
ACT134=AMT134*DCS134
ACT137=AMT137*DCS137
R=ACT134/ACT137
PRINT*,"PHI=",PHI," T=",T," YCS134=",YCS134," AMT134=",AMT134,
1" R=",R
191 CONTINUE
STOP"END OF PROGRAM"
END

```

1.E+13 2.E+13 3.F+13 4.F+13 5.E+13 6.E+13 7.E+13 8.E+13 9.E+13 1.E+14
 2592000. 5134000. 7775000. 10770000. 12930000. 15550000. 18140000. 20740000. 2337
 0. 3. 1.07E-9 1.07E-22 0. .0000052 1.07E-9 1.07E-22
 PHI=1.E+13 T=2592000. YCS134=0. AMT134=174.085705041 R=.0216399666001
 PHI=1.E+13 T=2592000. YCS134=.0000052 AMT134=141.8362723073 R=.02255863921847
 PHI=1.E+13 T=5134000. YCS134=0. AMT134=564.7615422134 R=.05404770635951
 PHI=1.E+13 T=5134000. YCS134=.0000052 AMT134=679.5757980852 R=.05524395443508
 PHI=1.E+13 T=7775000. YCS134=0. AMT134=1539.756332261 R=.08721439543246
 PHI=1.E+13 T=7775000. YCS134=.0000052 AMT134=1620.432659107 R=.08849855227346
 PHI=1.E+13 T=10770000. YCS134=0. AMT134=2319.154727737 R=.1204135491626
 PHI=1.E+13 T=10770000. YCS134=.0000052 AMT134=2946.445235274 R=.1215309172149
 PHI=1.E+13 T=12930000. YCS134=0. AMT134=4500.581272240 R=.1530494274535
 PHI=1.E+13 T=12930000. YCS134=.0000052 AMT134=4635.17532954 R=.1542002906337
 PHI=1.E+13 T=15550000. YCS134=0. AMT134=6329.591926959 R=.1852059375773
 PHI=1.E+13 T=15550000. YCS134=.0000052 AMT134=6670.206175706 R=.186340547344
 PHI=1.E+13 T=18140000. YCS134=0. AMT134=8347.649419537 R=.2164591255195
 PHI=1.E+13 T=18140000. YCS134=.0000052 AMT134=9074.009515974 R=.2179777263355
 PHI=1.E+13 T=20740000. YCS134=0. AMT134=11561.7398923 R=.2481204958776
 PHI=1.E+13 T=20740000. YCS134=.0000052 AMT134=11770.40193173 R=.2492232731384
 PHI=1.E+13 T=23330000. YCS134=0. AMT134=14535.83648877 R=.2787489710367
 PHI=1.E+13 T=23330000. YCS134=.0000052 AMT134=14892.97325712 R=.2793362217447
 PHI=1.E+13 T=25920000. YCS134=0. AMT134=17463.1047353 R=.3065506727052
 PHI=1.E+13 T=25920000. YCS134=.0000052 AMT134=17965.15347373 R=.3099405301505
 PHI=2.E+13 T=2592000. YCS134=0. AMT134=573.204738688 R=.0437133739597
 PHI=2.E+13 T=2592000. YCS134=.0000052 AMT134=544.146539332 R=.04457021952307
 PHI=2.E+13 T=5134000. YCS134=0. AMT134=2475.789704189 R=.1081655957296
 PHI=2.E+13 T=5134000. YCS134=.0000052 AMT134=2654.345273259 R=.1093673209625
 PHI=2.E+13 T=7775000. YCS134=0. AMT134=4272.146402633 R=.1746995155767
 PHI=2.E+13 T=7775000. YCS134=.0000052 AMT134=4314.472583157 R=.175377327604
 PHI=2.E+13 T=10770000. YCS134=0. AMT134=11370.25087813 R=.2403471223308

PHI=2.E+13	T=10370000.	YCS134=.0000052	AMT134=114250.07333902	R=.2429074632295
PHI=2.E+13	T=12780000.	YCS134=0.	AMT134=17507.30435277	R=.300010530343-
PHI=2.E+13	T=12780000.	YCS134=.0000052	AMT134=17769.7637094	R=.3071525685415
PHI=2.E+13	T=15550000.	YCS134=0.	AMT134=27470.86949707	R=.3701493054393
PHI=2.E+13	T=15550000.	YCS134=.0000052	AMT134=25557.74037566	R=.3712733680001
PHI=2.E+13	T=18140000.	YCS134=0.	AMT134=34396.50620023	R=.433205927081
PHI=2.E+13	T=18140000.	YCS134=.0000052	AMT134=34394.10740136	R=.4743150694775
PHI=2.E+13	T=20740000.	YCS134=0.	AMT134=44274.4095553	R=.4954042173144
PHI=2.E+13	T=20740000.	YCS134=.0000052	AMT134=44331.67351111	R=.4969276950379
PHI=2.E+13	T=23330000.	YCS134=0.	AMT134=55107.64226141	R=.5562454434136
PHI=2.E+13	T=23330000.	YCS134=.0000052	AMT134=55206.7755349	R=.5573205540491
PHI=2.E+13	T=25920000.	YCS134=0.	AMT134=65566.94474297	R=.6154553787900
PHI=2.E+13	T=25920000.	YCS134=.0000052	AMT134=66981.37517943	R=.61703568-99207
PHI=3.E+13	T=29920000.	YCS134=0.	AMT134=1132.095608597	R=.0050135897318
PHI=3.E+13	T=29920000.	YCS134=.0000052	AMT134=1214.962747297	R=.00623470379126
PHI=3.E+13	T=51940000.	YCS134=0.	AMT134=5834.153341327	R=.162745960175
PHI=3.E+13	T=51940000.	YCS134=.0000052	AMT134=5877.069352058	R=.1675412007973
PHI=3.E+13	T=77750000.	YCS134=0.	AMT134=13341.74922344	R=.2621294381352
PHI=3.E+13	T=77750000.	YCS134=.0000052	AMT134=13903.72317558	R=.2673031373189
PHI=3.E+13	T=10370000.	YCS134=0.	AMT134=24927.27341133	R=.3612429310952
PHI=3.E+13	T=10370000.	YCS134=.0000052	AMT134=25001.8755135	R=.3623362354673
PHI=3.E+13	T=12950000.	YCS134=0.	AMT134=31759.22332904	R=.4567596756163
PHI=3.E+13	T=12950000.	YCS134=.0000052	AMT134=30653.95799913	R=.4593027393717
PHI=3.E+13	T=15550000.	YCS134=0.	AMT134=59997.3455012	R=.5541339154065
PHI=3.E+13	T=15550000.	YCS134=.0000052	AMT134=55204.92523541	R=.55557471239402
PHI=3.E+13	T=18140000.	YCS134=0.	AMT134=73577.49030077	R=.6487384925535
PHI=3.E+13	T=18140000.	YCS134=.0000052	AMT134=73801.6325341	R=.6498320190741
PHI=3.E+13	T=20740000.	YCS134=0.	AMT134=94357.61102843	R=.7413590002944
PHI=3.E+13	T=20740000.	YCS134=.0000052	AMT134=94490.36256291	R=.7424570652549
PHI=3.E+13	T=23330000.	YCS134=0.	AMT134=116741.2754724	R=.8718484294377
PHI=3.E+13	T=23330000.	YCS134=.0000052	AMT134=116659.7373926	R=.8729031703716
PHI=3.E+13	T=25920000.	YCS134=0.	AMT134=140708.5652136	R=.9204535110559
PHI=3.E+13	T=25920000.	YCS134=.0010052	AMT134=140866.0175954	R=.9214993303535
PHI=4.E+13	T=25920000.	YCS134=0.	AMT134=2117.062364356	R=.08675797737152
PHI=4.E+13	T=25920000.	YCS134=.0000052	AMT134=2137.447062235	R=.08797175041476
PHI=4.E+13	T=51940000.	YCS134=0.	AMT134=10742.40326651	R=.2156352384579
PHI=4.E+13	T=51940000.	YCS134=.0000052	AMT134=10258.71755796	R=.2177759723902
PHI=4.E+13	T=77750000.	YCS134=0.	AMT134=24136.76151951	R=.3495325104626
PHI=4.E+13	T=77750000.	YCS134=.0000052	AMT134=24217.42933995	R=.3507509396197
PHI=4.E+13	T=10370000.	YCS134=0.	AMT134=43165.16590694	R=.4815473090007
PHI=4.E+13	T=10370000.	YCS134=.0000052	AMT134=43267.20233231	R=.4825894162282
PHI=4.E+13	T=12950000.	YCS134=0.	AMT134=56574.726756	R=.5112132700037
PHI=4.E+13	T=12950000.	YCS134=.0000052	AMT134=66799.42573264	R=.6123373955173
PHI=4.E+13	T=15550000.	YCS134=0.	AMT134=94147.02952977	R=.7384535433244
PHI=4.E+13	T=15550000.	YCS134=.0000052	AMT134=94283.55152914	R=.73950568954931
PHI=4.E+13	T=18140000.	YCS134=0.	AMT134=125072.5553117	R=.86313355177503
PHI=4.E+13	T=18140000.	YCS134=.0000052	AMT134=125209.1539032	R=.8642192328134
PHI=4.E+13	T=20740000.	YCS134=0.	AMT134=159070.3013116	R=.9355157341671
PHI=4.E+13	T=20740000.	YCS134=.0000052	AMT134=159241.2530784	R=.93663781043693
PHI=4.E+13	T=23330000.	YCS134=0.	AMT134=135499.4785041	R=1.104900542548
PHI=4.E+13	T=23330000.	YCS134=.0000052	AMT134=135623.1503938	R=1.105938707549
PHI=4.E+13	T=25920000.	YCS134=0.	AMT134=234046.9495729	R=1.221427625566
PHI=4.E+13	T=25920000.	YCS134=.0010052	AMT134=234261.939116	R=1.222444358586
PHI=5.E+13	T=25920000.	YCS134=0.	AMT134=3274.463954606	R=.1082739006335
PHI=5.E+13	T=25920000.	YCS134=.0000052	AMT134=3311.621034003	R=.1047395400489
PHI=5.E+13	T=51940000.	YCS134=0.	AMT134=15304.33043453	R=.2708738060877
PHI=5.E+13	T=51940000.	YCS134=.0000052	AMT134=15373.60719372	R=.2720310174565
PHI=5.E+13	T=77750000.	YCS134=0.	AMT134=36433.70277732	R=.4370342739277
PHI=5.E+13	T=77750000.	YCS134=.0000052	AMT134=37022.14513395	R=.4351972649292
PHI=5.E+13	T=10370000.	YCS134=0.	AMT134=65713.5217483	R=.6015902917521
PHI=5.E+13	T=10370000.	YCS134=.0000052	AMT134=65837.21053745	R=.6028252015347
PHI=5.E+13	T=12950000.	YCS134=0.	AMT134=139877.8097201	R=.7632250234379
PHI=5.E+13	T=12950000.	YCS134=.0000052	AMT134=139975.1131177	R=.764343074114
PHI=5.E+13	T=15550000.	YCS134=0.	AMT134=161412.4230093	R=.9214434725656
PHI=5.E+13	T=15550000.	YCS134=.0010052	AMT134=161579.7421514	R=.9227368344804
PHI=5.E+13	T=18140000.	YCS134=0.	AMT134=145593.6104679	R=1.075102681477

PHI=5.E+13	T=14140000.	YCS134=0.0000052	AMT134=196778.7753443	R=1.077170550237
PHI=5.E+13	T=20740000.	YCS134=0.	AMT134=235775.0560173	R=1.227335431997
PHI=5.E+13	T=20740000.	YCS134=0.0000052	AMT134=235975.5532024	R=1.223079970701
PHI=5.E+13	T=23340000.	YCS134=0.	AMT134=237200.1900055	R=1.774772704225
PHI=5.E+13	T=27770000.	YCS134=0.0000052	AMT134=222074.455501	R=1.375734113601
PHI=5.E+13	T=27770000.	YCS134=0.	AMT134=742345.177657	R=1.516025210151
PHI=5.E+13	T=27770000.	YCS134=0.0000052	AMT134=342510.355097	R=1.5193233143
PHI=6.E+13	T=27770000.	YCS134=0.	AMT134=4637.23280603	R=1.130727192952
PHI=6.E+13	T=27770000.	YCS134=0.0000052	AMT134=4731.241752148	R=1.1315785149096
PHI=6.E+13	T=51340000.	YCS134=0.	AMT134=22.750715256	R=1.3252050200949
PHI=6.E+13	T=51340000.	YCS134=0.0000052	AMT134=22556.3735957	R=1.7263306932564
PHI=6.E+13	T=77750000.	YCS134=0.	AMT134=52256.12797032	R=1.5244605042736
PHI=6.E+13	T=77750000.	YCS134=0.0000052	AMT134=52371.46995214	R=1.5256152163223
PHI=6.E+13	T=10770000.	YCS134=0.	AMT134=92204.35942513	R=1.721625203792
PHI=6.E+13	T=10770000.	YCS134=0.0000052	AMT134=92343.9545343	R=1.7227578555735
PHI=6.E+13	T=12360000.	YCS134=0.	AMT134=140573.6571453	R=1.9147012271122
PHI=6.E+13	T=12360000.	YCS134=0.0000052	AMT134=140707.5537444	R=1.9156071119045
PHI=6.E+13	T=15550000.	YCS134=0.	AMT134=135795.466291	R=1.107370578555
PHI=6.E+13	T=15550000.	YCS134=0.0000052	AMT134=195792.1575372	R=1.104460959093
PHI=6.E+13	T=19140000.	YCS134=0.	AMT134=255642.851153	R=1.2673289959
PHI=6.E+13	T=19140000.	YCS134=0.0000052	AMT134=256863.1541787	R=1.259763644355
PHI=6.E+13	T=20740000.	YCS134=0.	AMT134=322169.3713603	R=1.467002336777
PHI=6.E+13	T=20740000.	YCS134=0.0000052	AMT134=322395.7237578	R=1.459031580665
PHI=6.E+13	T=23340000.	YCS134=0.	AMT134=330778.253907	R=1.640843692554
PHI=6.E+13	T=23340000.	YCS134=0.0000052	AMT134=391017.4929572	R=1.641633175085
PHI=6.E+13	T=24520000.	YCS134=0.	AMT134=451737.5560951	R=1.309432932259
PHI=6.E+13	T=24520000.	YCS134=0.0000052	AMT134=462337.5956097	R=1.810412617434
PHI=7.E+13	T=25920000.	YCS134=0.	AMT134=5343.721665912	R=1.1521597913774
PHI=7.E+13	T=25920000.	YCS134=0.0000052	AMT134=5393.68753277	R=1.1533675391093
PHI=7.E+13	T=51340000.	YCS134=0.	AMT134=30210.97612348	R=1.3795752215423
PHI=7.E+13	T=51340000.	YCS134=0.0000052	AMT134=30304.90405199	R=1.3807557411027
PHI=7.E+13	T=77750000.	YCS134=0.	AMT134=69774.15455027	R=1.511675922345
PHI=7.E+13	T=77750000.	YCS134=0.0000052	AMT134=69905.75735336	R=1.529999914257
PHI=7.E+13	T=10770000.	YCS134=0.	AMT134=122205.9196593	R=1.8412335151537
PHI=7.E+13	T=10770000.	YCS134=0.0000052	AMT134=122459.7553308	R=1.8424179559951
PHI=7.E+13	T=12360000.	YCS134=0.	AMT134=135146.77575611	R=1.105570944033
PHI=7.E+13	T=12360000.	YCS134=0.0000052	AMT134=135357.3354318	R=1.056517603411
PHI=7.E+13	T=15550000.	YCS134=0.	AMT134=255247.7757313	R=1.281084542339
PHI=7.E+13	T=15550000.	YCS134=0.0000052	AMT134=256501.7551031	R=1.285153546925
PHI=7.E+13	T=19140000.	YCS134=0.	AMT134=333755.490123	R=1.498521116931
PHI=7.E+13	T=19140000.	YCS134=0.0000052	AMT134=333957.9143508	R=1.497962631368
PHI=7.E+13	T=20740000.	YCS134=0.	AMT134=416270.3574797	R=1.703296094024
PHI=7.E+13	T=20740000.	YCS134=0.0000052	AMT134=416474.7432123	R=1.704300505469
PHI=7.E+13	T=23340000.	YCS134=0.	AMT134=501624.3694931	R=1.902533390356
PHI=7.E+13	T=23340000.	YCS134=0.0000052	AMT134=501884.7154259	R=1.903520820531
PHI=7.E+13	T=25920000.	YCS134=0.	AMT134=539900.0134217	R=2.094652977308
PHI=7.E+13	T=25920000.	YCS134=0.0000052	AMT134=539926.1206137	R=2.095323666217
PHI=8.E+13	T=27750000.	YCS134=0.	AMT134=8236.499032272	R=1.1740204725317
PHI=8.E+13	T=27750000.	YCS134=0.0000052	AMT134=8294.001272613	R=1.1752258651323
PHI=8.E+13	T=51340000.	YCS134=0.	AMT134=33359.05550636	R=1.4339747330199
PHI=8.E+13	T=51340000.	YCS134=0.0000052	AMT134=33975.30630504	R=1.4351512887737
PHI=8.E+13	T=77750000.	YCS134=0.	AMT134=89405.1976908	R=1.6991416435505
PHI=8.E+13	T=77750000.	YCS134=0.0000052	AMT134=89551.8475363	R=1.7002334627029
PHI=8.E+13	T=10770000.	YCS134=0.	AMT134=155606.5581987	R=1.9505749199903
PHI=8.E+13	T=10770000.	YCS134=0.0000052	AMT134=155847.5622177	R=1.9617519150912
PHI=8.E+13	T=12360000.	YCS134=0.	AMT134=274146.3067605	R=1.215576351669
PHI=8.E+13	T=12360000.	YCS134=0.0000052	AMT134=274355.7555176	R=1.215663710619
PHI=8.E+13	T=15550000.	YCS134=0.	AMT134=321989.979645	R=1.453357456497
PHI=8.E+13	T=15550000.	YCS134=0.0000052	AMT134=322202.0377222	R=1.454425297824
PHI=8.E+13	T=19140000.	YCS134=0.	AMT134=415573.4351463	R=1.703389604377
PHI=8.E+13	T=19140000.	YCS134=0.0000052	AMT134=415834.9565508	R=1.704418094172
PHI=8.E+13	T=20740000.	YCS134=0.	AMT134=515145.704708	R=1.938050195935
PHI=8.E+13	T=20740000.	YCS134=0.0000052	AMT134=515452.055495	R=1.937068396244
PHI=9.E+13	T=23340000.	YCS134=0.	AMT134=612175.2184637	R=2.159216815925
PHI=9.E+13	T=23340000.	YCS134=0.0000052	AMT134=612442.9773748	R=2.160227077457
PHI=9.E+13	T=25920000.	YCS134=0.	AMT134=721271.1729676	R=2.37757906154

PHI=9.E+13	T=25020000.	YCS174=.0000052	AMT134=721507.735493	R=2.374511650412
PHI=9.E+13	T=25320000.	YCS174=.0.	AMT134=10764.1732059	R=1.1999101167332
PHI=9.E+13	T=25920000.	YCS174=.0000052	AMT134=10427.8817551	R=1.1971147561667
PHI=9.E+13	T=51240000.	YCS174=.0.	AMT134=8709.90121952	R=4.432372850074
PHI=9.E+13	T=51040000.	YCS174=.0000052	AMT134=46826.69792022	R=4.4395704529991
PHI=9.E+13	T=77750000.	YCS174=.0.	AMT134=111011.7162958	R=7.7863436034125
PHI=9.E+13	T=77750000.	YCS174=.0000052	AMT134=111172.3351546	R=7.774996971013
PHI=9.E+13	T=103700000.	YCS174=.0.	AMT134=132013.710293	R=1.079593475495
PHI=9.E+13	T=103700000.	YCS174=.0000052	AMT134=192211.159354	R=1.040703067251
PHI=9.E+13	T=129500000.	YCS174=.0.	AMT134=295975.1730739	R=1.364757915517
PHI=9.E+13	T=129500000.	YCS174=.0000052	AMT134=297161.7671507	R=1.365335909391
PHI=9.E+13	T=155300000.	YCS174=.0.	AMT134=332010.2624017	R=1.541043413072
PHI=9.E+13	T=155300000.	YCS174=.0000052	AMT134=392260.2580955	R=1.642051310922
PHI=9.E+13	T=171400000.	YCS174=.0.	AMT134=513960.2067657	R=1.507653122517
PHI=9.E+13	T=171400000.	YCS174=.0000052	AMT134=504228.9653952	R=1.503682765594
PHI=9.E+13	T=207400000.	YCS174=.0.	AMT134=620442.794902	R=2.164950273333
PHI=9.E+13	T=207400000.	YCS174=.0000052	AMT134=620754.767363	R=2.155334132452
PHI=9.E+13	T=233300000.	YCS174=.0.	AMT134=738359.5626354	R=2.41047773025
PHI=9.E+13	T=233300000.	YCS174=.0000052	AMT134=738661.462091	R=2.411430736056
PHI=9.E+13	T=259200000.	YCS174=.0.	AMT134=875615.7601391	R=2.644356725507
PHI=9.E+13	T=259200000.	YCS174=.0000052	AMT134=836452.351321	R=2.545775143035
PHI=1.E+14	T=25920000.	YCS174=.0.	AMT134=12720.93920892	R=2.7178250755061
PHI=1.E+14	T=25920000.	YCS174=.0000052	AMT134=12791.0855539	R=2.193309547316
PHI=1.E+14	T=51240000.	YCS174=.0.	AMT134=59371.70098243	R=2.5428379733541
PHI=1.E+14	T=51240000.	YCS174=.0000052	AMT134=59519.6411531	R=2.5440073418715
PHI=1.E+14	T=77750000.	YCS174=.0.	AMT134=13462.9661429	R=2.8734347868443
PHI=1.E+14	T=77750000.	YCS174=.0000052	AMT134=134637.3139119	R=2.8745705755975
PHI=1.E+14	T=103700000.	YCS174=.0.	AMT134=231052.3470094	R=1.199112657726
PHI=1.E+14	T=103700000.	YCS174=.0000052	AMT134=231265.321179	R=1.199714799457
PHI=1.E+14	T=129500000.	YCS174=.0.	AMT134=743076.7752985	R=1.512357561553
PHI=1.E+14	T=129500000.	YCS174=.0000052	AMT134=743279.0543503	R=1.514026229357
PHI=1.E+14	T=155300000.	YCS174=.0.	AMT134=455663.0967079	R=1.515338564334
PHI=1.E+14	T=155300000.	YCS174=.0000052	AMT134=465918.3713314	R=1.617973647377
PHI=1.E+14	T=181400000.	YCS174=.0.	AMT134=5748.05314627	R=2.103079554204
PHI=1.E+14	T=181400000.	YCS174=.0000052	AMT134=595127.0592725	R=2.110241317741
PHI=1.E+14	T=207400000.	YCS174=.0.	AMT134=727717.1065179	R=2.383565527926
PHI=1.E+14	T=207400000.	YCS174=.0000052	AMT134=726062.0792295	R=2.390514339425
PHI=1.E+14	T=233300000.	YCS174=.0.	AMT134=650669.1637847	R=2.655526634931
PHI=1.E+14	T=233300000.	YCS174=.0000052	AMT134=669972.051593	R=2.656622571343
PHI=1.E+14	T=259200000.	YCS174=.0.	AMT134=3919.50459887	R=2.903078192479
PHI=1.E+14	T=259200000.	YCS174=.0000052	AMT134=992153.1317538	R=2.909981399721

ERRJR SUMMARY

ERROR	TIMES
0115	0000

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER AFIT/GNE/PH/78D-12	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) ISOTOPIC CORRELATION TECHNIQUES AS AN OFF-SITE REACTOR MONITOR		5. TYPE OF REPORT & PERIOD COVERED MS Thesis
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) James L. Clark, Jr.		8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS Air Force Institute of Technology (AFIT/EN) Wright-Patterson AFB, Ohio 45433		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS
11. CONTROLLING OFFICE NAME AND ADDRESS		12. REPORT DATE October 1978
		13. NUMBER OF PAGES 101
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES Approved for public release; IAW AFR 190-17  JOSEPH P. HIPPS, Major, USAF Director of Information FEB 8 1979		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Isotopic Correlations Cesium 134 Cesium 137 Neodymium		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) The feasibility of using the mass ratio Nd146/Nd145 and the activity ratio Cs134/Cs137 as off-site indicators of bomb-grade plutonium production in commercial light water reactors is examined. The theoretical basis of these ratios as on-site indicators of fluence is developed and experimental validation of their utility as such is examined. The escape rate of cesium and neodymium is approximated and detection limits determined. Although both ratios are experimentally validated as indicators of fluence, neither (Continued on Reverse)		

DD FORM 1473
1 JAN 73

EDITION OF 1 NOV 65 IS OBSOLETE

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

BLOCK 20 (Continued):

cesium nor neodymium escapes a reactor in great enough concentration to be accurately measured off-site.