

AD-A109 788

HYDROLOGIC ENGINEERING CENTER DAVIS CA  
USE OF NON-SEQUENTIAL TECHNIQUES IN THE ANALYSIS OF POWER POTEN--ETC(U)

F/G 10/2

JUN 81 G M FRANC


UNCLASSIFIED

HEC-TP-80

NL

1 11 1  
AD A  
10/1/81

END  
DATE  
FILMED  
02 82  
DTIC



MICROCOPY RESOLUTION TEST CHART  
NBS 1963-A

7w

TECHNICAL PAPER NO. 80

AD A109788

LEVEL II

13


USE OF NON-SEQUENTIAL TECHNIQUES  
IN THE ANALYSIS OF POWER POTENTIAL  
AT STORAGE PROJECTS

by

GARY M. FRANC

DTIC  
ELECTE  
S JAN 20 1982 D

D



THE HYDROLOGIC  
ENGINEERING CENTER

- research
- training
- application

U.S. Army Corps of Engineers  
Water Resources Support Center

DTIC FILE COPY

DISTRIBUTION STATEMENT A

Approved for public release;  
Distribution Unlimited

01 19 82 020

Papers in this series have resulted from technical activities of The Hydrologic Engineering Center. Versions of some of these have been published in technical journals or in conference proceedings. The purpose of this series is to make the information available for use in the Center's training program and for distribution within the Corps of Engineers.

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)


REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER Technical Paper No. 80	2. GOVT ACCESSION NO. AD-A109788	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) USE OF NON-SEQUENTIAL TECHNIQUES IN THE ANALYSIS OF POWER POTENTIAL AT STORAGE PROJECTS	5. TYPE OF REPORT & PERIOD COVERED	
	6. PERFORMING ORG. REPORT NUMBER	
7. AUTHOR(s) Gary M. Franc	8. CONTRACT OR GRANT NUMBER(s)	
9. PERFORMING ORGANIZATION NAME AND ADDRESS US Army Corps of Engineers The Hydrologic Engineering Center 602 Second Street, Davis, CA 95616	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS	
11. CONTROLLING OFFICE NAME AND ADDRESS	12. REPORT DATE June 1981	
	13. NUMBER OF PAGES 13	
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)	15. SECURITY CLASS. (of this report) Unclassified	
	15a. DECLASSIFICATION/DOWNGRADING SCHEDULE	
16. DISTRIBUTION STATEMENT (of this Report) Distribution of this publication is unlimited		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES Presented at "Waterpower 81 Conference", Washington, D.C., June 81		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Non-sequential Analysis, Critical Drawdown Period, Storage Adjustment, Regression Analysis, Reservoir Reallocation, Dependable Capacity, Average Annual Energy.		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) An electronic computer procedure is described that uses an estimate of power storage available at a dam site to make estimates of average annual energy and dependable capacity using a non-sequential methodology. Comparisons of this method against the more traditional sequential routing analysis are performed.		

DD FORM 1473  
1 JAN 73

EDITION OF 1 NOV 68 IS OBSOLETE

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

**SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)**



**SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)**

USE OF NON-SEQUENTIAL TECHNIQUES  
IN THE ANALYSIS OF POWER POTENTIAL  
AT STORAGE PROJECTS

Gary M. Franc<sup>1</sup>

INTRODUCTION

The analysis of hydropower storage projects has traditionally been performed by use of sequential reservoir routing techniques, whereas the use of non-sequential techniques has been traditionally limited to the study of run-of-river type projects.

While individual power storage projects should be analyzed by detailed sequential routings when sufficient funds and detail are available, the non-sequential or flow-duration technique (as modified herein) can be made to somewhat approximate the results of a sequential routing by modifying the flow duration curve to represent outflow conditions.

The intent of this paper is to briefly outline the technique developed to enable the analysis of power storage projects using a non-sequential approach and, more importantly, to illustrate the improvement in estimates of energy and capacity from employing the technique.

FLOW-DURATION CURVE ADJUSTMENT

A storage project, in general, accumulates excessive inflows for future use during low flow periods, thereby transforming the inflow-duration curve, based on inflows into the project, into a flatter outflow-duration curve, reflecting the operation and effect of the project's storage as depicted below:

Accession For	
NTIS GRA&I	X
DTIC TAB	
Unannounced	
Justification	
By _____	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A	

<sup>1</sup>Hydraulic Engineer, Hydrologic Engineering Center, U. S. Army  
Corps of Engineers, Davis, CA 95616




Figure 1

Superimposing the curves in Figure 1 results in the combined curve in Figure 2.




Figure 2

The area ( $A_0$ ) under the original flow-duration curve is preserved and the modified flow-duration curve passes through points  $C_1$  and  $C_2$ .

Where:

$C_1$  represents a discharge corresponding to 100% exceedence;

$C_2$  represents a point of intersection between the two curves.

An analytical technique was developed to transform the shape of the inflow-duration curve to the form of the outflow-duration curve. This mathematical algorithm will generate an outflow-duration curve and meet the following conditions:

- 1) the value of the function (flow-duration ordinate) at 100 percent exceedence must be  $C_1$ ;
- 2) the value of the function (flow-duration ordinate) at some percent exceedence  $p$  must be  $C_2$ , where  $0 < p < 1.0$ ;
- 3) the area under the modified outflow-duration curve must equal the area under the original inflow-duration curve ( $A_0$ ).

#### PARAMETER DETERMINATION

Attention is now focused on making estimates for parameters  $C_1$ ,  $C_2$  and  $p$ .

The selected discharge value of  $C_2$ , corresponding to the percent exceedence point of intersection between the two duration curves, is critical in the mathematical algorithm for allowing feasible development of the outflow-duration curve. Comparison of inflow and outflow-duration curves for various storage projects tested revealed that the point of intersection between the two duration curves deviated unappreciably from the percent exceedence value corresponding to the average annual inflow  $A_0$ . Therefore,  $C_2$  is assumed to be equal to  $A_0$ , which generally corresponds to percent exceedences ranging in value from 15 to 35 percent. The value of  $A_0$  is a constant and represents the area underneath the original inflow-duration curve, which is easily determined by integration. The selection for  $C_2$  will automatically determine the value of  $p$  because  $C_2$  and  $p$  are functionally related through use of the flow-duration relationship.

The value of  $C_1$  is dependent on the storage capability of the site being analyzed. Accordingly, it seems reasonable to assume that  $C_1$  can be estimated by considering the base flow component

of the flow regime and the minimum flow contribution due to reservoir regulation during adverse flow conditions as follows:

$$C_1 = QMC + QMSC \dots \dots \dots \text{Eq. 1}$$

where:

$C_1$  = the minimum flow value on the outflow-duration curve corresponding to 100 percent exceedence;

QMC = the minimum flow value on the original inflow-duration curve without regard to storage effects (100% exceedence value);

QMSC = the minimum flow contribution attributed to reservoir operation under critical low inflow conditions.

Critical low flow conditions occur whenever, over a sustained period of time, a reservoir is regulated to release additional flow in excess of upstream inflows as a means of satisfying designed project purposes. With regard to hydropower, this operational policy, if continued, can actually exaggerate the situation since depletion of power storage reduces the effective headwater and correspondingly the operating power head; requiring a continually increasing amount of flow to sustain energy requirements. The period of maximum draw-down can be defined as the period of time which begins with full power storage and ends when the power storage remaining is at a minimum. By definition, the period of maximum drawdown will then contain the most adverse streamflow conditions and will require the maximum withdrawal of water from the power storage. An estimate of QMSC can now be approximated by determining the depletion rate occurring throughout this period.

As an initial step, the power storage can be converted from units of volume, typically in acre-feet, to units of flow rate (cfs). To perform this conversion, a time period, say one year, must be selected. The resulting value expresses the power storage potential as the average amount of flow that can be extracted from an initially full power pool throughout a period of one year.

However, as defined above, the period of maximum drawdown is unconstrained with regard to the length of time required to complete the process, and actual reservoir operations have demonstrated this period of time varies from a few weeks to several years in length. Accordingly, the initial depletion rate (assuming a one-year length in the period of maximum drawdown) must be adjusted by a factor to

reflect the project's actual length in time to minimum pool level as shown below:

$$QMSC = PS * ACF * ADJF \dots \dots \dots Eq. 2$$

where

PS = power storage expressed as a volume (acre-feet);

ACF = a conversion factor (0.00138) which when multiplied by (PS) expresses the amount of power storages in terms of an average annual flow rate (cfs-yr);

ADJF = adjustment factor applied to the power storage to correct for variation in the length of the period of maximum drawdown.

From Equation 2, one can conclude that a length of the period of maximum drawdown exceeding one year requires the adjustment factor (ADJF) to be less than one. Conversely, a length in the period of maximum drawdown less than one year requires ADJF to exceed unity. In effect, ADJF can be alternatively defined as the reciprocal of the length in the period of maximum drawdown, when time is measured in years.

Several attempts at establishing a relationship to determine a value for ADJF were performed. The regression equation finally selected is based upon 113 existing and proposed hydro sites throughout the United States and is shown below:

$$ADJF = 0.65 + 1.113 * LOG(1/PSR) \dots \dots \dots Eq. 3$$

where PSR represents a project's power storage to mean annual flow ratio.

Statistically, the above equation resulted in a R-squared value of 0.49 and a standard error of 0.45. A plot of this relationship can be seen in Figure 3.

The PSR is a dimensionless parameter which expresses the relative size of power storage to average annual inflow and is determined by converting power storage to an average one year flow rate, as previously suggested, and then dividing the result by the project's expected average annual inflow. In addition, this parameter is a relative measure of the ability to control the length of the period of maximum drawdown through regulation of project storage.




Figure 3 PLOT OF REGRESSION ANALYSIS RESULT

A relatively large PSR, say greater than 1.0, indicates sufficient storage capacity so that, on the average, there exists the capability of extending the period of maximum drawdown during sustained periods of low inflow. As the PSR falls below 1.0, this capability to attenuate diversity between inflow availability and project demands decreases, causing the average length of the period of maximum drawdown to decrease, accordingly. Another observation from Figure 3, substantiating this conclusion, is that as the PSR falls below 1.0, considerable increase in scatter of the data occurs. This implies that the storage effect is becoming relatively less important than the effect of diversity between inflow supply and energy demand. A direct determination of parameter  $C_1$  is now possible by successive use of Equations 3, 2, and 1; allowing for a plausible solution to systematically produce a synthetic outflow-duration relationship for projects exhibiting power storage.

The substitution of the synthetic outflow-duration relationship for the original inflow-duration curve should substantially improve any estimate of average annual energy and should additionally enable an approximation of dependable capacity to be performed when used in a non-sequential power potential analysis.

#### AVERAGE ANNUAL ENERGY COMPARISON

Tables 1 and 2 illustrate the effect of using the flow-duration adjustment technique in the estimate of average annual energy.

Table 1 is comprised of twenty-six existing storage projects, each of which is currently installed and operating for energy production. Each project, defined by a site identification number and a project name, has been simulated on computer by using a computer program called HYDUR<sup>(1)</sup>. This program is design to perform power potential analyses using a non-sequential methodology. HYDUR can be operated in the traditional fashion or can be operated using the flow-duration adjustment option based on user input. Column 1 displays average annual energy estimates based on using standard non-sequential techniques. Column 2 contains energy estimates based on using the adjustment option. Column 3 represents the percent increase resulting from estimating average annual energy using the adjustment option as compared to standard non-sequential methods. In two cases where a decrease in the estimate of average annual energy occurred, the corresponding PSR's were 0.021 and 0.009; both relatively insignificant amounts of power storage. In general however, the use of the adjustment option resulted in an appreciable increase in the estimate of average annual energy. On the average, the increase was 13 percent. This trend is expected because the effect of the flow-duration adjustment is to produce a flatter and less "peaky" outflow-duration curve, thereby reducing the amount of average spill and increasing the amount of average annual energy.

TABLE 1 AVERAGE ANNUAL ENERGY ESTIMATE (GWH)

Site	Name of Project	PSR	Column 1	Column 2	Column 3
			No Storage effect	Storage effect	% Increase
SWT0418	Broken Bow	0.539	114.63	132.86	16
SWT0419	Eufaula	0.388	200.51	261.56	30
SWT0457	Keystone	0.069	203.66	232.55	14
SWF0015	Whitney	0.251	61.99	88.68	43
SWF0092	Sam Rayburn	0.817	99.09	106.09	7
SWL0005	Bull Shoals	0.482	633.14	636.77	1
SWL0013	Greers Ferry	0.445	198.76	249.91	26
SWL0010	Beaver	0.863	151.55	179.84	19
SWL0126	Table Rock	0.667	454.84	502.48	10
SWT0513	Fort Gibson	*0.009	190.40	178.46	-6
LMK0003	DeGrey Lake	0.740	83.20	89.56	8
LMK0008	Quachita Lake	1.075	147.57	169.73	15
LMK0026	Greeson	0.642	32.66	36.24	11
MRK0060	Harry S. Truman	*0.021	184.25	181.51	-1
MRK0067	Stockton Lake	0.714	47.58	50.61	6
MRO0123	Big Horn Lake	0.140	922.45	1000.64	8
MRO0158	Canyon Ferry	0.171	352.93	375.64	6
MRO0215	Lake McConaughy	0.838	114.79	115.53	1
MRO0274	Lake Francis Case	0.093	1976.93	2081.48	5
MRO0326	Boysen Reservoir	0.406	80.03	86.16	8
MRO0366	Glendo Reservoir	0.344	95.15	122.03	28
SAW0100	John H. Kerr	0.190	428.36	442.88	3
SAW0101	Philpott	0.557	29.81	30.37	2
SWL0004	Norfork	0.270	157.08	222.42	42
SWF0001	Toledo Bend	0.376	242.68	256.11	6
SWT0302	TanKiller	0.343	103.59	132.01	27
Average					13

Tables 2A and 2B compare average annual energy estimates derived by sequential routing methods using computer program HEC-5<sup>(2)</sup>, the non-sequential adjustment technique, and traditional non-sequential techniques; both latter estimates using computer program HYDUR. For each of the twenty-six existing power projects, three separate simulations were performed to evaluate the effect of reallocating additional storage volume to the production of energy. The first simulation estimates the average annual energy potential of the existing power project. Simulations two and three estimate the average annual energy potential after reallocating ten and twenty percent of the existing flood control storage to power, respectively.

The results indicate that the non-sequential flow-duration adjustment estimates of average annual energy were generally larger than the energy estimates resulting from sequential routing efforts. Conversely, the standard non-sequential estimates were generally smaller than the energy estimates resulting from sequential routings. On the average the fractional differences were 1.046 and 0.960 for the existing project comparison; 1.054 and 0.956 for the 10 percent reallocation comparison, and 1.059 and 0.952 for the 20 percent reallocation comparison, respectively.

TABLE 2A COMPARISON OF AVERAGE ANNUAL ENERGY USING SEQUENTIAL AND STANDARD NON-SEQUENTIAL TECHNIQUES

SITE	NAME OF PROJECT	AVERAGE ANNUAL ENERGY (GWH)											
		EXISTING				10 PERCENT FRACTIONAL DIFFERENCE				20 PERCENT FRACTIONAL DIFFERENCE			
		HEC-5	HYDUR	FRACTIONAL DIFFERENCE		HEC-5	HYDUR	FRACTIONAL DIFFERENCE		HEC-5	HYDUR	FRACTIONAL DIFFERENCE	
LMK0003	DeGrey Lake	87.63	83.20	0.949	88.37	83.86	0.949		89.08	84.51	0.949		
LMK0008	Quachita Lake	167.99	147.56	0.878	168.95	148.52	0.879		170.22	149.56	0.879		
LMK0026	Greeson	37.13	32.66	0.880	37.53	32.97	0.878		37.94	33.30	0.878		
MRK0060	Harry S. Truman	178.20	184.25	1.034	203.30	205.53	1.011		220.90	221.69	1.004		
MRK0067	Stockton Lake	47.96	47.58	0.992	49.39	48.51	0.982		50.66	49.49	0.977		
MR00123	Big Horn Lake	933.40	922.46	0.988	942.60	931.36	0.988		951.61	940.06	0.988		
MR00158	Canyon Ferry	359.40	352.93	0.982	367.50	359.83	0.979		374.80	365.82	0.976		
MR00215	Lake McConaughy	109.20	114.79	1.051	109.10	116.12	1.064		113.60	117.54	1.035		
MR00274	Lake Francis Case	2033.80	1976.93	0.972	2064.20	1995.46	0.967		2093.80	2008.26	0.959		
MR00326	Boysen Reserv.	78.80	80.03	1.016	81.50	82.85	1.017		84.30	85.96	1.020		
MR00366	Glendo Reserv.	100.37	95.15	0.948	102.98	96.81	0.940		105.47	98.68	0.936		
SAW0100	John H. Kerr	435.96	428.36	0.983	448.11	442.71	0.988		459.44	451.31	0.982		
SAW0101	Philpott	27.84	29.81	1.071	28.10	29.98	1.067		28.25	30.18	1.068		
SWL0004	Norfolk	201.70	157.08	0.779	204.80	159.00	0.776		208.10	160.80	0.773		
SWF0001	Toledo Bend	255.80	242.68	0.949	256.10	243.62	0.951		256.20	244.20	0.953		
SWT0302	TanKiller	116.80	103.59	0.887	119.30	105.66	0.886		121.40	107.57	0.886		
SWT0418	Broken Bow	129.20	114.63	0.887	131.20	116.62	0.889		132.70	118.49	0.893		
SWT0419	Eufaula	226.70	200.50	0.884	229.30	202.31	0.882		231.80	203.89	0.880		
SWT0457	Keystone	234.40	203.65	0.869	244.70	211.60	0.865		252.80	218.20	0.863		
SWF0015	Whitney	73.30	61.99	0.846	75.60	63.39	0.838		77.20	64.76	0.839		
SWF0092	Sam Rayburn	100.50	99.09	0.986	101.90	100.92	0.990		103.10	101.86	0.988		
SWL0005	Bull Shoals	598.78	633.14	1.057	616.92	646.48	1.048		637.41	662.39	1.039		
SWL0013	Greers Ferry	236.29	198.76	0.841	239.72	200.86	0.838		242.98	203.05	0.836		
SWL0010	Beaver	171.63	151.56	0.883	172.76	152.16	0.881		173.73	152.83	0.880		
SWL0126	Table Rock	456.30	454.84	0.997	472.33	457.63	0.969		473.82	460.41	0.972		
SWT0513	Fort Gibson	212.76	190.40	0.895	222.66	198.84	0.893		230.16	206.20	0.896		
Total		7611.84	7307.62	0.960	7778.94	7433.60	0.956		7921.47	7541.11	0.952		

TABLE 2B COMPARISON OF AVERAGE ANNUAL ENERGY  
USING SEQUENTIAL AND NON-SEQUENTIAL ADJUSTMENT TECHNIQUES

SITE	NAME OF PROJECT	AVERAGE ANNUAL ENERGY (GWH)								
		EXISTING			10 PERCENT			20 PERCENT		
		HEC-5	HYDUR	FRACTIONAL DIFFERENCE	HEC-5	HYDUR	FRACTIONAL DIFFERENCE	HEC-5	HYDUR	FRACTIONAL DIFFERENCE
LMK0003	DeGrey Lake	87.63	89.56	1.022	88.37	90.38	1.023	89.08	91.15	1.023
LMK0008	Quachita Lake	167.99	169.73	1.010	168.95	170.99	1.012	170.22	172.36	1.013
LMK0026	Greesson	37.13	36.24	0.976	37.53	36.62	0.976	37.94	37.04	0.976
MRK0060	Harry S. Truman	178.20	181.51	1.019	203.30	211.27	1.039	220.90	233.29	1.056
MRK0067	Stockton Lake	47.96	50.61	1.055	49.39	51.92	1.051	50.66	53.38	1.054
MR00123	Big Horn Lake	933.40	1000.64	1.072	942.60	1013.27	1.075	951.61	1025.54	1.078
MR00158	Canyon Ferry	359.40	375.64	1.045	367.50	387.87	1.055	374.80	399.02	1.065
MR00215	Lake McConaughy	109.20	115.53	1.058	109.10	116.97	1.072	113.60	118.51	1.043
MR00274	Lake Francis Case	2033.80	2081.48	1.023	2064.20	2124.57	1.029	2093.80	2159.83	1.032
MR00326	Boysen Reserv.	78.80	86.16	1.093	81.50	90.23	1.107	84.30	94.56	1.122
MR00366	Glendo Reserv.	100.37	122.03	1.216	102.98	127.09	1.234	105.47	131.96	1.251
SAW0100	John H. Kerr	435.96	442.88	1.016	448.11	455.31	1.016	459.44	466.59	1.016
SAW0101	Philpott	27.84	30.37	1.091	28.10	30.56	1.088	28.25	30.77	1.089
SWL0004	Norfolk	201.70	222.42	1.103	204.80	228.41	1.115	208.10	233.93	1.124
SWF0001	Toledo Bend	255.80	256.11	1.001	256.10	258.38	1.009	256.20	259.75	1.014
SWT0302	TanKiller	116.80	132.01	1.130	119.30	136.60	1.145	121.40	140.94	1.161
SWT0418	Broken Bow	129.20	132.86	1.028	131.20	135.23	1.031	132.70	137.56	1.037
SWT0419	Eufaula	226.70	261.56	1.154	229.30	266.00	1.160	231.80	270.20	1.166
SWT0457	Keystone	234.40	232.55	0.992	244.70	249.65	1.020	252.80	264.80	1.047
SWF0015	Whitney	73.30	88.68	1.210	75.60	95.95	1.269	77.20	101.17	1.310
SWF0092	Sam Rayburn	100.50	106.09	1.056	101.90	107.54	1.055	103.10	109.16	1.059
SWL0005	Bull Shoals	598.78	636.77	1.063	616.92	656.22	1.064	637.41	675.67	1.060
SWL0013	Greers Ferry	236.29	249.91	1.058	239.72	254.12	1.060	242.98	258.36	1.063
SWL0010	Beaver	171.63	179.84	1.048	172.76	180.81	1.047	173.73	181.87	1.047
SWL0126	Table Rock	456.30	502.48	1.101	472.33	506.97	1.073	473.82	511.46	1.079
SWT0513	Fort Gibson	212.76	178.46	0.839	222.66	217.76	0.978	230.16	231.05	1.004
Total		7611.84	7962.12	1.046	7778.94	8200.69	1.054	7921.47	8389.92	1.059

Additionally, comparison of average annual energy estimates calculated by both the sequential and non-sequential methods resulted in fairly constant deviations in the energy estimates for all three cases tested for each of the twenty-six projects. Although the absolute energy estimates differ on the average by five percent, the estimates of incremental energy gained from reallocating additional storage to power are averaging within about one percent.

These observations suggest that the flow-duration adjustment option is adequately redistributing the available streamflow for power potential analysis and therefore indicates that the primary cause of the difference in energy estimates is due to a difference in power head between the two techniques. This was expected because the average headwater elevation in all the non-sequential simulations was assumed to be at the top of power pool. A more practical selection would be to choose the normal pool headwater level as a fractional percent of the total power pool available. If the project is existing, past operation of the project may give a clue in establishing this fractional percent value. For proposed projects, results from Table 2B indicate that a fractional percent ranging between 0.85 to 0.95 is appropriate for projects exhibiting sufficient power storage (power storage to mean annual flow ratio greater than 0.10).

#### DEPENDABLE CAPACITY COMPARISON

Dependable capacity can be defined as the capacity which under the most adverse flow conditions on record, can be relied upon to carry system load, provide dependable reserve capacity, and meet firm power obligations, taking into account seasonal variations and other characteristics of the load to be supplied<sup>(3)</sup>. The association to the "most adverse flow conditions on record," in the definition of dependable capacity strongly supports the notion that parameter  $C_1$  might be valuable as an indicator in approximating this capacity value. This assumption was tested and it was found that dependable capacity could be estimated by using the power equation as follows:

$$DCAP = C(C_1/PF) H_e \dots \dots \dots \text{Eq.4}$$

Where:

DCAP = dependable capacity in kilowatts:

C = .084603 conversion factor which expresses power in kilowatts;

$C_1$  = the minimum flow parameter as previously defined;

PF = the average annual plant factor relating dependable capacity to its firm energy requirement;





H = net power head in feet;

e = overall efficiency (assumed equal to a constant 0.86)

The quantity  $(C_1/PF)$  represents the expected minimum flow adjusted for average time of hydropower plant operation.

Equation 4 was employed with data from all 113 projects used to develop the parameter ADJF and the resulting estimates of dependable capacity were compared to corresponding dependable capacity values estimated from sequential routing techniques (HEC-5). This comparison, depicted in Figure 4, resulted in an R-squared value of 0.985 and a standard error of 10,700 kilowatts. Comparison of empirical (non-sequential) to sequentially determined capacities varied over a range of 100 kilowatts to 650 megawatts. A departure in plotting position above an imaginary  $45^\circ$  line represents an underestimate of dependable capacity determined empirical as compared to dependable capacity estimated using sequential routing techniques. Conversely, a departure below this line represents an exaggeration of dependable capacity. Maximum departure about this line, in terms of percent difference, occurs for small installations (i.e., projects having installed capacities less than 2 megawatts). Small installations are generally associated with projects possessing limited storage capacity and correspondingly small power storage to mean annual flow ratios (PSR). Since the regression equation used to estimate ADJF (Equation 3) was incorporated in the empirical determination of dependable capacity, the problem of increased scatter associated with small PSR's is most probably the underlying influence causing these maximum departures to occur in this capacity range.

An approach to alleviate this problem of increased scatter is to introduce a parameter into the regression analysis for determining ADJF which represents a measure of the diversity associated between energy demand requirements and inflow availability at a project. Although this approach was not performed for this paper, an initial attempt at defining this parameter can be suggested by plotting the firm energy demand requirements of a project against project inflow in the form of normalized distributions. As an illustration, assume the monthly distributions of inflow and firm energy demand can be determined from available data and are as follows:



DEPENDABLE CAPACITY (KW)  
ESTIMATED USING SEQUENTIAL ROUTING TECHNIQUE

DEPENDABLE CAPACITY (KW)  
ESTIMATED USING SEQUENTIAL ROUTING TECHNIQUE

EMPIRICALLY CALCULATED DEPENDABLE CAPACITY (KW)

EMPIRICALLY CALCULATED DEPENDABLE CAPACITY (KW)

Figure 4 COMPARISON OF EMPIRICAL TO SEQUENTIALY DETERMINED CAPACITIES

Monthly

Inflow	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
(cfsm)	175	150	75	175	250	375	325	300	250	175	125	125

Monthly

Firm Energy Required

(MWH)	80	75	60	60	70	80	90	110	110	100	80	85
-------	----	----	----	----	----	----	----	-----	-----	-----	----	----

The distributions can be normalized by dividing the monthly values by annual inflow (2,500 cfsm) and annual firm energy (1,000MWH), respectively. Figure 5 is a superimposed plot of these normalized distributions, where the area under each distribution is unity. The plot graphically displays the diversity between energy demand and flow availability. In general, from April through August, this project will have sufficient storage available to meet all energy demands and might actually be accumulating storage and experiencing spill. From September to March, inflow recedes and storage depletion occurs to supplement flow needed for power generation. Therefore, an initial definition of the diversity parameter might be to accumulate the percent differences between the distributions throughout the year whenever percent of energy demand exceeds percent of annual inflow. This suggestion is only one of several alternatives which can be conceived to measure diversity. Future funding may allow for further investigation in this area.

In conclusion, the non-sequential adjustment technique has been shown to be a viable alternative to use in estimating energy and capacity values associated with power storage projects. It is recommended that this option be employed (through the use of computer program HYDUR) throughout the screening process of any basin wide power potential study. Once project alternatives become manageable, a more detailed sequential routing effort should be undertaken.




Figure 5 COMPARISON OF ANNUAL FLOW AND ANNUAL FIRM ENERGY DISTRIBUTIONS

## References

- 1) Hydrologic Engineering Center, U.S. Army Corps of Engineers, "HYDUR-Hydropower Analysis Using Streamflow Duration Procedures", August 1980.
- 2) Hydrologic Engineering Center, U.S. Army Corps of Engineers, "HEC5-Simulation of Flood Control and Conservation Systems", June 1979.
- 3) Federal Energy Regulatory Commission, "Hydroelectric Power Evaluation", August 1979.

ATE  
LME