

METRIC CONVERSION FACTORS

6

C

	Symbol		. <u>E</u>	. <u>c</u>	£	þ	Ē		24	245	N.E	I			5 1	3		fi 0.7	ž t	15	5	÷ بر	۷۵۷		4				{a	72 72	R	ဦးပ
. Meatsures	To Find		inches	inches	feet	yards	miles		and and a second	Aquare vards	square yellos soliare miles	acres			SHOUND	short tons		fluid ounce	nuru ounces ninte	ouarta	gelions	cubic feet	cubic yards		Fahrenheit	temperature					20, 190,	08,09
sions from Metric	Multiply by	LENGTH	0.04	0.4	3.3	1.1	0.6	AREA			1 4	2.5	MASS (weight)			12	VOLUME	500		106	0.26	8	1.3	TEMPERATURE (exact)	9/5 (then	add 32)				36 .0		20
Approximate Conversions from Metric Measures	When You Know	ㅋ	millimeters	centimeters	meters	meters	kilometers			aquera taritinaciana eruara meters	equare industa equare kilomotore	hectares $(10,000 \text{ m}^2)$	MAS		grams	tonnes (1,000 kg)		millihere	lih ers	liters	liters	cubic meters	cubic meters	TEMPER	Celsius	temperature				de Se		-40 -20 p
	Symbol		шш	Ê	٤	E	к,		2	=0 5 f	د2 1	2			D .	2 + 2		Ĩ	٤_		_	n E	າ E		ပိ							
55 53 26 53	51	50	61				(1 	9		91 91			3	۱ 	5			01		6		3	4		9	9			3			L L L
																																l
) ð , ,	' ' ' 	' '' ''	٢ľ	1	' ' ' 7	 '1'	' 'I	' ''		ייי אין	ľ	٩ų		ๆ" 5	11.	rr ['I' 	']'[4	ľ	1	[1] ·	' 3	' [']	"	·[1	' ' 2	['1'	11	T	1 1	יויי וייי ו	
9 9 	Symbol Symbol	.	<u>8</u> ۱,۱,			Ē	"	ייין גע	, , , , , , , , , , , , , , , , , , ,	' ' } }	" " 	יוי ב פ				ןיין { ב- פ	11	17	ייי 1	''''	')' : T		- 1,1	'[' 	' ''' _~_		['1'	ייי גי		'' ,		ġ
-	-		•	S.	E	kilometers km			rters			thectares has been by the the	1		ο.	tionaria kg (1)	'''''	''''				_	_		athic meters m ³	Ē	("")	Celsius °C	rature	' {'{ ,		ġ
-	Symbol	LENGTH	, E	centimeters cm	E				square centimeters	square meters	square meters	1000000	eieht)	5	d suest	5		A PLUME	معيازا		milliliters	24 liters	liters		litters Gubic meters	Ē	PERATURE (exect)		g temperature	۲۲ ,		ġ
6	To Find Symbol	TENGTH	centimeters cm	30 centimeters cm	i 0.9 meters m	kilometers	APCA		es 6.5 square centimeters	0.09 square meters	2.6 square merers	square knometers hectares	MASS (weight)		28 grams p	Kulograms tonnes		A NOLUME	معيازا	te 15 millithere	30 millifers	0.24 liters	0.47 liters l	0.96	litters Gubic meters	is 0.78 cubic meters m ³	TEMPERATURE (exact)	Celsius	ire subtracting temperature		*1 in = 2.54 (exactly). For other exact conversions and more detailed tables, see NBS	ġ

hes


ţ

53 11

TABLE OF CONTENTS

		TABLE OF C	CONTENTS
	1.0	Summary	
	2.0	Field Survey Data	
		2.1 Field Information Chec	cklist
	3.0	Data Development	
		3.1 Climate - Based Factor	ſs
		3.2 Building - Specific Fa	actors
	8	3.3 Miscellaneous Factors	
	4.0	Savings Calculations Algori	thms
		4.1 Scheduled Start/Stop	
		4.2 Duty Cycling	
ġ.		4.3 Demand Limiting	
	5	4.4 Optimum Start/Stop	
1		4.5 Outside Air Limit Shut	off
		4.6 Ventilation And Recirc	culation
		4.7 Economizer (Dry Bulb o	or Enthalpy)
×.		4.8 Day/Night Setback	
		4.9 Reheat Coil Reset	
		4.10 Hot Deck/Cold Deck Tem	nperature Reset
	4	4.11 Hot Water Outside Air	Reset
		4.12 Boiler Optimization	
E .		4.13 Chiller Optimization	
		4.14 Chiller Water Temperat	ure Reset
		4.15 Condenser Water Temper	ature Reset
		4.16 Chiller Demand Limit	
		4.17 Lighting Control	Accession For
		4.18 Run Time Recording	MITS GRIAT
		4.19 Safety Alarm	DTIC T/B
	5.0	Sample Calculations	Unpumo saced Jatificetion
			B7
			Distribution/

ter Temperature Reset 59 62 62 Accession For 63 MITS GRIAT DTIG T/B 63 Unparation 66 Jatification 87. Distribution/ Availability Codes Avail and/or Special Dist



PAGE

1 2

6 11

11

28

35

36

38 44

45

46

47

48

50

50

52


54

56

57

58


58











FIGURES

1.	Building Description Data Form	3
2.	System Description Data Form	4
3.	Energy Conservation Program Applications	5
4.	Climate-based Factors Form	13
5.	Sample Weather Data - Cooling Season	14
6.	Sample Weather Data - Heating Season	15
7.	Percent Runtime (PRT) vs. Heating Degree Days	26
8.	Building-specific Factors Form	29
9.	Equipment Runtime vs. Heating Degree Days	33
	for Light Construction	
10	Equipment Runtime vs. Heating Degree Days	34
	for Heavy Construction	
11.	DHW Offtime Temperature Drop	43
12.	Percent Efficiency Increase of Chiller vs.	61
	Reduction in Condenser Water Temperature	
13.	Primary System - Savings Calculations	64
	and Costs Reference Form	
14.	Secondary System - Savings Calculations	65
	and Costs Reference Form	

APPENDICES

A.1	Blank Forms						
A.2	Enthalpy of Air at Given Wet Bulb Temperatures	140					
A.3	Variable Glossary	141					



REPORT DOCUMENTATION PAGE	READ INSTRUCTIONS BEFORE COMPLETING FORM
	N NO. 3. RECIPIENT'S CATALOG NUMBER
CR 82.030	
	5. TYPE OF REPORT & PERIOD COVERED
Standardized EMCS Energy Savings	
Calculations	6. PERFORMING ORG. REPORT NUMBER
AUTHOR(a)	8. CONTRACT OF GRANT NUMBER(S)
Catherine Cornelius	NC0474 01 0 0000
	N62474-81-C-9382
PERFORMING ORGANIZATION NAME AND ADDRESS_	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS
Newcomb & Boyd, Consulting Engineers	
One Northside 75	Z0371-01-221D
Atlanta, GA 30318	
Naval Civil Engineering Laboratory	12. REPORT DATE Sep 1982
Port Hueneme, CA 93043	13. NUMBER OF PAGES
-	144
4. MONITORING AGENCY NAME & ADDRESS(II different from Controlling Of	
	Unclassified
	15a. DECLASSIFICATION DOWNGRADING SCHEDULE
Approved for public release; distribut	
5. DISTRIBUTION STATEMENT (of the Report) Approved for public release; distribut 7. DISTRIBUTION STATEMENT (of the obstract entered in Block 20, if differ 8. SUPPLEMENTARY NOTES	
Approved for public release; distribut D. DISTRIBUTION STATEMENT (of the obstract entered in Block 20, if differ B. SUPPLEMENTARY NOTES D. KEY WORDS (Continue on reverse side if necessary and identify by block nu	mt from Report)
Approved for public release; distribut 7. DISTRIBUTION STATEMENT (of the obsirect entered in Block 20, if differ 8. SUPPLEMENTARY NOTES	mt from Report) umber)
Approved for public release; distribut D. DISTRIBUTION STATEMENT (of the obstract entered in Block 20, if differ B. SUPPLEMENTARY NOTES D. KEY WORDS (Continue on reverse side if necessary and identify by block nu Calculations, EMCS, Energy	mber) mber) ed methods for determining plications programs using he methods will provide
Approved for public release; distribut DISTRIBUTION STATEMENT (of the obstract entered in Block 20, if differ SUPPLEMENTARY NOTES KEY WORDS (Continue on reverse side if necessary and identify by block nu Calculations, EMCS, Energy DARSTRACT (Continue on reverse side if necessary and identify by block nu This report describes standardize energy savings obtainable from EMCS ap manual and computerized algorithms. T reasonable approximations of savings b analyses of building operations.	mber) mber) ed methods for determining plications programs using he methods will provide

1.0 SUMMARY

This document is prepared in accordance with Contract N62474-81-C-9382, Task 3, from the Civil Engineering Laboratory, Port Hueneme, California. It describes standardized time-based and climate-based methods for determining energy savings obtainable from EMCS energy conservation programs utilizing manual and computerized algorithms. It is intended that these methods will provide reasonable approximations of savings and not detailed energy analyses of each building. When applicable, computer methods are recommended over manual methods to provide better accuracy. For energy conservation strategies, for which computer adgorithms exist and manual methods are unreliable, use of a computer is required. These circumstances are spelled out in Section 3 of ths report. The methods are applied to typical examples of the systems identified in the Tri-Service Design Manual for EMCS, TM 5-815-2/AFM 88-36/NAVFAC DM-4.9. Field data required for these calculations and forms which may be used in recording the field data and performing the savings calculations are included. General information about Energy Monitoring and Control Systems, descriptions of the energy conservation programs, and schematics of the typical systems may be found in the Tri-Service Design Manual referenced Section 5 details a hypothetical installation and completed above. sample forms using the manual methods discussed in this report.

2.0 FIELD SURVEY DATA

A field survey of the facility under study is required to determine what systems are present in each building being considered for EMCS connection. As-built drawings and equipment lists obtained from facility personnel need to be verified. The operation of each system and the building it serves must be determined in sufficient detail to determine which EMCS functions may be applicable to each system. These and other tasks to be performed during the field survey are listed on page 200 of the Tri-Service Design Manual for EMCS, TM 5-815-2/AFM 88-36/NAVFAC DM-4.9. Building and system survey forms which may be used in this endeavor are shown on the following two pages, in Figures 1 and 2. Blank forms are also included in Appendix A.1.

Twenty-nine typical HVAC systems to which EMCS conservation programs may be applied have been identified. System schematics and I/O summary tables for these systems may be found in the Tri-Service Design Manual for EMCS, TM 5-815-2/AFM 88-36/NAVFAC DM-4.9, pages 105 to 163.

Figure 3 lists those energy programs which may be applied to a particular system type and a page reference where the calculation method may be found. Information, specific to system type, which is required for calculation of energy savings is shown on the checklist on pages 6 to 8.

mennenen en	
FIGURE 1	
BUILDING DESCRIPTION DATA	
BUILDING NUMBER:	
BUILDING DESCRIPTION:	
GROSS AREA (SQUARE FEET):	
NUMBER OF FLOORS:	
TYPE CONSTRUCTION:	بر المراجع 1997 - مراجع المراجع (1997) 1997 - مراجع المراجع (1997)
APPROX. FLOOR TO FLOOR HEIGHT (FT):	
GLASS TYPE:	
CRITICAL AREAS:	
OCCUPANCY SCHEDULE:	
	• *
3.	

SYSTEM DESCRIPTION DATA	BUILDING NUMBER
SYS #	
TYPE	
MFGR. MOD. #	
CAPACITY	
HP (TYPE)	
HP (TYPE)	
HP (TYPE)	HP (TYPE)
AREA SERVED	
CONTROLS	
NOTES:	NOTES:
SYS #	SVS #
TYPE	
MrGK. MOD. Ŧ	MFGR. MOD. #
CAPACITY	CAPACITY
CAPACITY	CAPACITY
CAPACITY HP (TYPE) HP (TYPE)	CAPACITY
MFGR. MOD. # CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED	CAPACITY HP (TYPE) HP (TYPE) HP (TYPE)
CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED	CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED
CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED	CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED CONTROLS
CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED CONTROLS	CAPACITY HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED CONTROLS NOTES:

したないないでは必要ななした。

FIGURE 3

ENERGY CONSERVATION PROGRAM APPLICATIONS

· - · -

47.87.81.8

REFERENCE PAGE	38	7	ž	8	9	9	3	۶	3	\$	5	87	87	63	8	\ ⊐
	[[Τ	Π
				_									Ē		Ē	+
				Vent. Recirculation				Ę	1	Reset		Boiler Optimization	Chiller Optimization	Reset	Condenser Water Reset	Limit
		. .		cule	•	er *	ť	S/S Optimization	Reheat Coil Roset			ul za	Imiz	er M	ater	Pu
	Schedule	1	Limit	L L	alpv	Cm [z	Setback	t m i z	10	Å	set	bt f	Ъ Э	Water	1	Dem
	Sch	Duty Cycle	Demand Limit	<u>م</u>	OA Enthalpv	Economizer	ي د	0 D	t i	Hot/Cold Deck	OA Reset	1	Ę	Chilled	enso	1
HVAC No. System Type	s/s	Dut	Dem	Veni	VO	VO	Night	s/s	Rehe	Hot/	E O	Bo11	Chil	CHI	Cond	Chiller Demand
1 Single Zone AHU	•	•	•	•	•	•	•	•							1	\square
2 Terminal Re- heat AHU	•	•	•	•	•	٠	•	•	•						†	┼╌┨
3 Variable Air Volume AHU	•	•	•	•	•	•	•								\vdash	
4 Multi-Zone	•	•	•		•	•				•						┼─┨
AHU 5 Single Zone								•		-					┼─	H
DX-A/C 6 Multi-Zone															┢	$\left - \right $
DX-A/C 7 Two Pipe Fan					_	-				•					┣	┡┻┥
Coil Unit 8 Four Pipe Fam															┝	
Coil Unit 9 Heating Vent-			귀													
ilating Unit 10 Steam Unit	•	-	•	-			•	-							 	
Heat 11 Electric		_				{	-	-								\square
Unit Heater	•	•	•				•	•								
12 Hot Water Unit Heater			\square				•									
13 Steam Radiation							•	•								
14 Electric Radiation	ullet	•	•				•	•								
15 Hot Water Radiation			Τ	Τ	T	1	•	•			•					
16 Steam Boiler			1		1	-1			7			•	-			
17 Hot Water Boiler		\neg	1	1	1	-1		-	-	-1	1	•	-1			
18 Direct Fired Furnace	•	•	•	•	- 1	-1	•	•	-1	-1	\neg	-†				
19 Direct Fired Boiler	•	•	•	•	-+	{	•	•	\neg		\neg	-†				\neg
20 Steam HW	•	-+	-	-+	†	-+	-		-†		•	-†				\neg
Converter 21 MTHW Steam		-+	-†		-+		-+	-+	-+	\dashv	•	\neg	-			$\neg \uparrow$
Converter 22 HTHW HW	•	\neg	-+		-+	-+	-		-+	-+	-	-+				
23 Water Cooled	•	•		-+	-+	{	-		-+		4	+				{
DX Compressor 24 Air Cooled		<u> </u>	-+			{	-	-	-	{					•	_
DX Compressor 25 Air Cooled	•	-	•	-		_+		-	-+		\dashv	\dashv	_			{
Chiller 26 Water Coolea		-	•			+		•	\rightarrow		_	-+	•	•		┛
Chiller 27 Lighting		<u> </u>	•	$ \rightarrow $				•		$ \downarrow$	$ \downarrow$	$ \downarrow$	•	•	•	•
Control	•	$ \rightarrow $	•	$-\downarrow$	$ \downarrow$		$ \rightarrow $				$ \downarrow$	$ \downarrow$				
26 Domestic HW Electric	•	•	•		\square			•								
29 Domestic HW Gas or Oil	•			T	T		Ţ	•	Ţ	T	T	T	T		Π	7
المستقت فيستسمعه	,			1											1	

*Select Economizer or Enthalpy +Centrifugal Chillers only

2.1 FIELD INFORMATION CHECKLIST

All Systems

- --- area being served by the system
- --- required schedule of operation if different from normal building occupancy schedule
- --- reliability and schedule of any existing start/stop control (manual or timeclock)
- --- manufacturer's model number

Types 1 to 6 Air Handlers

	 required summer setpoint if different tl 78°F
	 required winter setpoint if different t 🌧 58°F
	 required unoccupied low temperature limit if
	different than 55°F
	 sources of heating and cooling media
	 cfm capacity
	 percent minimum outside air
	 OA damper control and revisions necessary to
	convert to economizer control
	 supply and return (if any) fan horsepower
	 required unoccupied period setpoints if system
	cannot be shutdown
*	 reasonable reheat system reset (°F) based on coil
	capacity and space loads or use suggested estimates
	from Section 4.
ł	 reasonable hot and cold deck resets (°F) based on
	coil capacities and space loads or use suggested
	estimates from Section 4.
t	 percent of system cfm passing through hot and cold
	decks

* Terminal Reheat AHU only

+ Multizone AHU and DX-A/C systems only

Types 7, 8, 11, 14 Systems with no outside air

 required	summer	setpoint	if	different	than	78°F							
 required	winter	setpoint	if	different	than	68°F							
 required	unoccup	ied low te	empe	rature limi	it if								
different than 55°F													
 sources o	of heatin	ng and/or	coo	ling media									
 supply fa	an horse	power											
 required	unoccuj	pied peri	od	setpoints	is s	ystem							

cannot be shutdown

Types 9, 18, 19 Heating only fan units

- --- required winter setpoint if different than 68°F
- --- required unoccupied low temperature limit if different than 55°F
- --- source of heating medium
- --- cfm capacity

- --- percent minimum outside air
- --- OA damper control
- --- supply and return (if any) fan horsepower
- --- required unoccupied period setpoints if system cannot be shutdown

Types 10, 12, 13, 15 Heating Systems

- --- required winter setpoint if different than 68°F
- --- source of heating medium
- --- required unoccupied period setpoint
- * --- total maximum output of hot water radiators

* Only needed for consideration of hot water temperature reset on an independent hot water radiation loop; otherwise, it will be reset at the hot water source.

Types 16, 17 Steam or Hot Water Boiler

maximum capacity of each bo:	iler
------------------------------	------

- --- type of energy source (fuel)
- --- conditions of operation for estimation of efficiency

Types 20, 21, 22 Converters

- --- maximum heat transfer capacity of converter
- --- horsepower rating of all associated pumps
- --- source of steam or hot water
- --- conversion efficiency (or assume 90%)

Types 23, 24, 25, 26 DX Compressors and Chillers

	type	of	compressor(s))
--	------	----	-------------	----	---

- --- horsepower of compressor motor(s) and any auxiliary pumps
- --- staging control
- --- refrigeration capacity (tons)
- * --- entering condenser water temperature setpoint
- * --- cycling or continuously running tower fan
- * * --- cold water setpoint
- * * --- capacity control
 - --- double bundle condenser
 - * Water cooled systems only
 - ** Chillers only

Type 27 Lighting Control

--- total KW per lighting zone

Type 28, 29 Domestic Hot Water

--- type energy source (fuel)

- --- tank height and diameter
- --- insulation thickness
- --- hot water temperature setpoint
- --- average temperature of surroundings
- --- possible shutdown schedule

The savings calculations use motor horsepowers in calculation of auxiliary savings. If horsepower is not listed on the motor nameplates then calculate it based on the electrical data as follows:

$$HP = \frac{V \times A \times \sqrt{\beta} \times 0.85}{1000 \text{ watts/kw} \times 0.746 \text{ kw/hp}}$$

where,

Ċ,

V = voltage
A = full load or rated amperage
Ø = number of phases

For motors 25 HP or greater, it is preferable to take field measurements of the electrical consumption.

The air handling capacity in cubic feet per minute (cfm) is required for analysis of most air handler systems. If this information cannot be determined from the equipment nameplate, catalog data or as-built mechanical plans, then assume a cfm value equal to the square feet of area being served.

3.0 DATA DEVELOPMENT

H

Many factors which affect the magnitude of energy savings achievable from the conservation programs are only dependent on the climate of a particular location or the building design and load characteristics. The determination of these constant factors is discussed in this section.

3.1 Climate-based factors

Before beginning the savings analysis at a particular location, those factors which are solely related to climate should be calculated. The derived values of the climatebased factors may be entered into the table shown in Figure 4, for easy reference while performing the system analyses. A blank form is also included in Appendix A.1. The page reference indicates the page in this report where a method of determining the data is outlined. If actual weather data for the facility under study is available it should be used in preference to calculated data. For example, if a base has a yearly schedule for turning central cooling equipment on May 20 and off September 30 then that time period should be used for the weeks of summer (WKS).

Several factors may be derived from weather data located in Chapter 3 of the <u>Engineering Weather Data</u>, NAVFAC P-89/AFM 88-29/TM 5-785. The following pages demonstrate methods for calculating each of the Climate-Based Factors using weather data for Springfield MAP, Missouri. In each case, the columns in the data tables are derived from the weather data reproduced in Figures 5 and 6, from Chapter 3, pages 3-20 and 3-21, of the <u>Engineering Weather Data</u>. The column letter indices in each procedure correspond to the letters on the columns in Figures 5 and 6. The Climate-Based Factors for any location in the <u>Engineering Weather Data</u> can be derived in a similar fashion.

FIGURE 4

CLIMATE - BASED FACTORS

LOCATION:

SYMBOL	DESCRIPTION	PAGE REF.	VALUE	UNITS
ACWT	Average Condenser Water Temperature	16		۴F
AND	Annual Number of Days for Warmup	18		Days/Yr.
AST*	Average Summer Temperature	19		°F
AWT*	Average Winter Temperature	19		°F
CFLH	Annual Equiv. Full-Load Hrs. For Cooling	20		Ers/Yr.
HFLH	Annual Equiv. Full-Load Hrs. for Heating	22		Ers/Yr.
HS	Hrs. of Temp. Limit Shut-off for Summer	23		Hrs/Yr
HW	Hrs. of Temp. Limit Shut-off for Winter	23		Hrs/Yr
одн*	Average Outside Air Enthalpy	24		Btu/lb.
PRT*	Percent Run Time for Low Temp. Limit	25		%
WKS*	Weeks of Summer	27		Wks/Yr.
WKW*	Weeks of Winter	27		Wks/Yr.

* Data not necessary if computer methods are used.

.

SPRINGFIELD MAP MISSOURI

LAT 37 14N LONG 93 23W ELEV 1268 FT

MEAN FREQUENCY OF OCCUMPENCE OF ONY BAUD TENEERATURE (DECREES F) WITH REAN COINCIDENT NET BAUD TENEERA


3		= .		{	323	22833	****	22	
2	_	10 20		1	12	93 532	5 x x x z	~ 0	
RATUR	OCTOBER		= = :	1	0 11	*****	~ * # 5 A	•	
TENPE	S	5 5 8 13 1	8 2 :		3~~	****	22224		
MILMLE UP UNT BAUD TEMPERATURE (DEGREES F) VITH REAR COINCIDENT WET BULD TEMPERATURE (DECREES F) FOR EACH DRY BULD TEMPERATURE RANGE			5 = 1	3		04554	*****	~ •	
		=	> •		88883	****	\$ \$ 3 3		······································
3	Ř	Tetal Bes		1	o . 7 4 8	2 6 5 5 8	4900		
5	SEPTEMBER		= = :		6 .	****	2 - 0		
FEES .	SEPI	Obsin Hour Go	8 2 3	-	0 ° Z R Z	****	N 0		20
DECI DECI		-	5 2 8	5	0 7	****	2000		
ATURE		ت ¥			22222	58288	34		
ENPER	-	Tetal Obu]	~ ~ ~ ~ ~ ~ ~	52 5 9 51	*		
	AUGUST		2 2 2		04524	3 5 8 1 7	•		
÷ ÿ	A	Obsn Hour Gp	8 2 2		~ = 4 2 %	M N N O			TE
DEMT		-	5 2 8	s	0		*		
OINCI		۲ پ		==	22525	2 8 8 8 8	5		
	≻	terat Na		° -	13 13 13 13 13 13	145 105 28 28 28 28 28	-		
	JULY			°	0 n ii % Ç	338°-			1.
2			822	0-	22252				16
CINES			5 ° 8	<u> </u>	007 N	-2882			
Ĕ Ĕ					52252	2 2 2 3 2 2	59 FF		
		Tetal Ara			* 5 3 2 °	39 2 2 2	<u> 4</u> 0 0		
	Ĭ		= = = =		9 2 9 2 2	8842-	~ • •		1.
5	1		8 2 2		0 6 2 4 5	\$ <u>2</u> 2 2 2 2	~~ <u>~~</u>		64
5			5 ° 8		~ •	28282	0 ~ 0		
5 2		E U			5 C 69	22222	\$ \$ \$ % %		
	ſ	leis) Nan			~ ~ % %	2 2 2 S 2 S	2224-		
i i	₹		2 2 2		0	22222	200		
		5 10 X	5 2 2		4	***	~~-0		44
			5 2 8		•	*****	8.5 * *~~		
-			¥.	110/114	100/104 95/99 90/94 85/89	75/79 70/78 65/69 60/64 55/59	50/54 45/49 40/44 35/39	25/29 20/24	

Sample Weather Data - Cooling Season

FIGURE 5

SPRINGFIELD MAP MISSOURI

Ţ



SAMPLE WEATHER DATA-HEATING SEASON

9

FIGURE

.

Average entering condenser water temperature (ACWT):

The purpose of this procedure is to find the average entering condenser water temperature which can be obtained from a cooling tower during the cooling season at a given location. This value can then be used in the Condenser Water Temperature Reset savings calculations for any cooling tower in the same geographic location.

Using the <u>Engineering Weather Data</u>, compile a data table like the one below for Springfield, Missouri. Find the Mean Coincident Wet Bulb Temperatures corresponding to Temperature Ranges <u>above 55°F.</u> (Column A). Assume an approach temperature (the difference in temperature between the outside air wet bulb temperature and the entering condenser water temperature) of 10° F. Add this to the Mean Coincident Wet Bulb Temperatures (Column B). For normal office hours of operation consider the annual hours of occurrence during the 09 to 16 period (Column C) and perform the following calculations:

A. Me Co	an incident	в.	Condenser Water Temp.	c.	09 to 16 Hours of	D.	Temperature Hours
	t Bulb °F		(A + 10°)		Occurrence		(B x C)
	77		87		0		0
	74		84		1		84
	74		84		4		336
	74		84		39		3276
	74		84		121		10164
	72		82		232		19024
	70		80		295		23600
	68		78		279		21762
	66		76		272		20672
	62		72		228		16416
	57		67		204		13668
	52		62		<u>181</u>		11222
					1856		140224

Average condenser water temperature = ACWT

- = Total of D/Total of C
- = 140221/1856 = 75.6°F.

Annual number of days requiring morning warmup (AND):

Results of this procedure will be used in savings calculations for Ventilation and Recirculation and Optimum Start/ Stop. Assuming the start-up time is early morning consider only those hours of occurrence 01 to 08 for temperatures <u>below 60°F.</u> (Column F). Derive the following information from the weather data:

E.	Temperature	F. 01 to 08	G. Annual
	Range °F	Hours of	No. Of
		Occurrence	Days
			(F ÷ 8)
	55/59	235	30
	50/54	208	26
	45/49	206	26
	40/44	219	28
	35/39	235	30
	30/34	237	30
	25/29	195	25
	20/24	107	14
	15/19	74	10
	10/14	4 6	6
	5/9	19	3
	0/4	13	2
	-5/-1	4	1
	-10/-6	1	1
	-11 & below	0	0

Total

232

The annual number of days that warmup is required is the total of column G: AND = 232.

Average summer temperature (AST):

Results of this procedure will be used in the savings calculations for Scheduled Start/Stop. Find the annual hours observed for time periods 01 to 08 and 17 to 24 (Columns F and I), which correspond to the mean temperature in the 5° ranges (Column H) <u>above 75°F</u>. Compile a table as follows:

H.	Mean °F	F. 01 to 08	I. 17 to 24	J. Annual Summer
	In Range	Hours of	Hours of	Degree Hours
		Occurence	Occurrence	$(H + I) \times G$
	112	0	0	0
	107	0	0	0
	102	0	0	0
	97	0	9	873
	92	0	32	2,944
	87	4	78	7,134
	82	29	151	14,760
	77	<u>105</u>	<u>252</u>	27,489
	TOTALS	138 hr.	522 hr.	53,200 hr°F

The average summer temperature is equal to:

AST = Total of J/(Total of F + Total of I) = 53,200/(138 + 522) = 80.6°F

Average winter temperature (AWT):

Results of this procedure will be used in the savings calculations for Scheduled Start/ Stop and Ventilation/Recirculation. Find the annual total hours observed (Column K) at temperatures <u>below 65°F</u> (column H) and compile a data table as follows:

•

H.	Mean °F In Range	K.	Annual Total Hours	L.	Annual Winter Degree Hours
	62		768		47,616
	57		619		35,283
	52		598		31,096
	47		608		28,576
	42		603		25,326
	37		606		22,422
	32		577		18,464
	27		412		11,124
	22		240		5,280
	17		141		2,397
	12		85		1,020
	7		39		273
	2		21		· 42
	-3		6		-18
	-8		1		-8
TOT	ALS		5,324 hr/yr		228,893 °F-hr/yr

The average winter temperature is equal to:

AWT = Total of L/Total of K = 228,893/5,324 = 43.0°F

Annual equivalent full-load hours for cooling (CFLH):

Cooling full-load hours (CFLH) will be used in savings calculations for Chiller Water Temperature Reset and and Condenser Water Temperature Reset. A value can be chosen from Table 3, p. 43.11, in the <u>1980 Systems ASHRAE Handbook</u>, or the following procedure can be used to determine the value of the parameter. FInd the 2.5% Summer Design Data Dry Bulb temperature for the location under study in Chapter 1 of the Engineering Weather Data, AFM 88-29/TM 5-785/NAVFAC P-89. For Sprinfield MAP, Missouri it is 93°F. For daytime operation of the cooling systems consider the annual hours of occurence <u>above and equal to 65°F</u> for the 09 to 16 period (Column C), as in the example. For 24-hour operation consider the total observed annual hours of occurrence (Column K). Develop the following data table from the weather data:

C

Ĵ

H. Mean °F	C. 09 to 16	M. Degree
In Range	Hours of	Hours
	Occurence	<u>C(H-65°)</u>
112	0	0
107	1	42
102	4	148
97	39	1,248
92	121	3,267
87	232	5,104
82	295	5,015
77	279	3,348
72	272	1,904
67	228	456
TOTAL		20,532 °F-hr.

Annual equivalent full-load hours for cooling is calculated as follows:

CFLH = <u>Total of M</u> Cooling design temperature - 65°

 $= 20,532/(93^{\circ}-65^{\circ}) = 733 \text{ hr/yr}.$

Annual equivalent full-load hours for heating (HFLH):

Results of this procedure will be used in savings calculations for Hot Water Outside Air Reset. Find the 97.5% Heating Design Data Dry Bulb Temperature for the location under study in Chapter 1 of the <u>Engineering Weather Data</u>, AFM 88-29/ TM5-785/ NAVFAC P-89. For Springfield MAP, Missouri the heating design temperature is listed as 9°F. For daytime operation of a heating system consider the annual hours of occurrence <u>below 65°F</u> for the 09 to 16 period; this was assumed for the example. For 24-hour operation consider the total observed annual hours of occurrence. Develop the following data table from the weather data:

H. Mean °F	с.	09 to 16	N.	Degree
In Range		Hours Of		Hours
		Occurence		<u>C(65°-H)</u>
62		204		612
57		181		1448
52		182		2366
4 7		191		3438
42		173		3979
37		160		44 80
32		149		4917
27		92		3496
22		54		2322
17		28		1344
12		18		954
7		8		464
2		4		252
-3		1		68
-8		0		

Total

C

). L

U

30140 °F-hr.

Annual equivalent full-load hours for heating is calculated as follows:

HFLH	=				al of N	
		65°	-	heating	design	temperature

 $= 30140/(65^{\circ} - 9^{\circ}) = 538 hr/yr$

Hours for outside air temperature shutoff (HS and HW):

Results of this procedure will be used in savings calculations for Outside Air Shutoff Limit. For the heating savings consider the months during which heating auxiliaries such as hot water pumps are scheduled to operate at the facility under study and from the weather data determine the total number of hours during that period that the temperature is above or equal to 65°F. In a similar fashion determine the number of hours below the cooling season temperature limit. Cooling season shut off should only be considered for small skin-dominated buildings (low internal heat gains compared to heat transfer through walls and roof) and the temperature limit should be chosen accordingly. For the Springfield example assume the heating pumps operate November through April based on the 23.4 week winter determined on page 27. Assume the chiller for a skin-dominated building with operable windows is turned on the 15th of May and runs through September. A summer temperature limit of 75°F is used. Only the 09 to 16 time periods are considered The actual seasonal schedule for heating for the example. equipment and cooling equipment should be used when known for a facility.

Hours in summer outside temperature is below summer limit = HS = 1/3(144) + 64 + 31 + 31 + 99 = 273 hr/yr

Hours in winter outside temperature is above winter limit = HW = 40 + 5 + 8 + 9 + 35 + 107 = 204 hr/yr

Average outside air enthalpy (OAH):

The results of this procedure will be used in the savings calculations for Scheduled Start/Stop. For normal daytime hours of operation of the HVAC equipment consider the hours of occurrence for the time periods 01 to 08 and 17 to 24 <u>above 75°F</u> dry bulb temperature. Develop the following data table from the weather data:

A.	Mean	F. 01 to 08	I. 17 to 24 0.	Degree
	Coincident	Hours of	Hours of	Hours
	Wet Bulb (°F)	Occurrence	Occurrence	<u>Ax(B+C)</u>
	77	0	0	0
	74	0	0	0
	74	0	0	0
	74	0	9	666
	74	0	32	2368
	72	4	78	5904
	70	29	151	12600
	68	105	252	25276
	Totals	138 hrs.	522 hrs.	45814 hrs-°F

Average wet bulb temperature =

Total of O/(total of F + total of I) =

 $45814/(138 + 522) = 69.4^{\circ}F.$

The corresponding outside air enthalpy (OAH) can be obtained by consulting Appendix A.2. For this example the OAH which corresponds to $69.4^{\circ}F$ - WB is 33.34 Btu/lb.

Percent runtime for low temperature limit (PRT):

The percent runtime (PRT) is the percentage of scheduled off time during unoccupied periods when the fans and pumps must come back on in order to maintain a 55°F setback temperature. The determined value will be used in Scheduled Start/ Stop savings calculations. Find the annual Heating Degree Days for the location under study in Chapter 1 of <u>Engineering</u> <u>Weather Data</u>, AFM 88-29/TM 5-785/ NAVFAC P-89. The corresponding percent run time (PRT) can be found on Figure 7, page 26. For the Springfield example the number of heating degree days are 4570, and the corresponding PRT is 15%.

301 25% (PRT) UN TIME (PR' 20% RUN PERCENT FAN R (BASED ON 55 15% 10% 5% 10,000 12,000 2000 4000 6000 8000 0 HEATING DEGREE DAYS

FIGURE 7

Weeks of summer (WKS) and Weeks of winter (WKW):

Results of this procedure will be used in the savings calculations for Scheduled Start/Stop, Ventilation/Recirculation, Day/Night Setback, Reheat Coil Reset, and Hot Deck/Cold Deck Temperature Reset. Find the annual total hours observed <u>below 55°F</u> (Column K) and make the calculations shown below:

Ε.	Temperature	к.	Annual
	Range, °F		<u>Total Hours</u>
	50/54		598
	45/49		608
	40/44		603
	35/39		606
	30/34		577
	25/29		412
	20/24		240
	15/19		141
	10/14		85
	5/9		39
	0/4		21
	-5/-1		6
	-10/-6		1
	Total		3937 hr/yr

The weeks of winter are equal to:

WKW = (Total of K) hr/yr (24 hr/dy)(7 dy/wk) = 3937/(24)(7) = 23.4 wk/yr

The weeks of summer are equal to:

WKS = 52 wk/yr - WKW = 52 - 23.4 = 28.6 wk/yr

3.2 Building-specific Factors

Before beginning the savings for each system in a given building it is best to calculate those factors which are constant for that building. It is important when deriving thermal parameters of a building to take account of any proposed architectural modifications. These factors may be entered in forms like the one shown in Figure 8 for easy reference. A blank form is included in Appendix A.1. Following is a discussion of those factors and their derivations.

Building thermal transmission (BTT):

This factor is not needed if computer methods are used. The resultant answer for BTT in Btu/hr°F-ft² is used in the Scheduled Start/Stop and Day/Night Setback savings calculations.

BTT = $[(Uo \times AW) + (I \times 1.08 Btu/cfm°F-hr)]/AF$

Where,

*	Uo	=	combined U-factor for all exterior surfaces
			(walls, windows, doors, roof) in Btu/ft ² hr°F
	AW	=	total area of exterior surfaces in ft ²
*	I	=	total infiltration for building in cfm
	AF	=	total floor area of the building in ft ²

* The values for these factors may be calculated by methods discussed in <u>ASHRAE Handbook</u>, 1981 Fundamentals, Chapters 22 and 23.

<u>FI</u>	GURE 8		
BUILDING-	SPECIFIC FACTORS		
BUILDING:			
* BTT = Building Thermal Transmission			
-)/Total Elect	* 4.400
= (U-factor X exterior area) +			
= $(\Btu/hr^F-ft^2Xf$	(cfm X	1.08)/	_ft ²
=Btu/hr°F-ft ²			
ERT = Annual Run Time of Equipment fo	or Morning Warmup		
Heating Degree Days =	°F-days		
Combined U-factor, Uo =	Btu/hr°F-ft ²		
From Figure 9 or 10:	ERT =	hr/yr	
Primary Sources of Cooling Medium			
Sys. No System Type	Systems Served	CPT	
		· ·· · · ·	
		·	
		. <u></u>	
Primary Sources of Heating Medium			
Sys. No System Type	Systems Served	HEFF	<u>HV</u>
			<u></u>
			

* Data not necessary if computer method is used.

Annual equipment runtime for morning warmup (ERT):

The equipment runtime (ERT) is the number of hours per year that a system must run in the mornings before occupancy to bring the temperature up to comfort conditions. The calculated value will be used in savings calculations for Optimum Start/Stop. Calculate the combined wall Uo factor by standard methods such as described in the <u>ASHRAE Handbook</u> <u>1981 Fundamentals</u>, Chapter 23. Find the annual Heating Degree Days for the location under study in Chapter 1 of <u>Engineering Weather Data</u>, AFM 88-29/TM 5-785/NAVFAC P-89. The corresponding equipment runtime (ERT) can be found on Figure 9 or 10, page 33 or 34. For a brick building with an overall U-factor of .21 in Springfield, Missouri (HDD of 4570), the corresponding ERT from Figure 10 is 290 hours per year.

Following are factors which may sometimes be the same for all systems in a given building.

CPT = rate of energy consumption per ton of refrigeration in kw/ton or lb/ton-hr.

> This figure will be the same for all air handling systems using chilled water from the same central chiller. DX units or package units will be exceptions. Use a value derived from manufacturer's catalog or nameplate data for the particular model if available; or use the approximate power inputs for compressors listed in Table 2, p. 43.10 of the ASHRAE Handbook, 1980 Systems.

For steam-driven refirgeration machines use:

steam	absorption machine	-	18	lb/ton-hr
steam	turbine driven machine	-	40	lb/ton-hr

HEFF = heating efficiency of the system

When calculating heating savings for boilers and domestic hot water heaters, use manufacturer's data on efficiencies if available. Typically, the seasonal efficiency of an oil or gas fired boiler and hot water heating system is between .60 and .70, and for coal fired boilers, somewhat lower. For separate domestic hot water heaters, seasonal efficiencies are about .70 for oil fired heaters, .75 for gas fired heaters, and .95 for electric water heaters.

When calculating heating savings for converters, heat exchanger effectiveness must be included. Use a factor of 0.90 combined with the efficiency of the boiler which serves the converter if actual equipment data is not available. For example, if a boiler with an efficiency of 0.65 supplies steam to a steam/hot water converter, then the total heating efficiency (HEFF) of the converter will be .65 times .90 or .585.

When calculating heating savings for secondary systems, the distribution losses also must be taken into account. The distribution efficiencies of hot water systems may be estimated based on the flow rate and the temperature difference between the outlet of the boiler or converter and the inlet to the air handler heating coil. If this data is not available, assume a distribution

efficiency of 0.90. This must be multiplied by the boiler or converter efficiency to determine the combined heating efficiency (HEFF) of the secondary system.

For electrical resistance duct heaters assume a heating efficiency of 1.0.

HV = heating value of fuel.


Actual heating values should be used when known; otherwise, use the following values to convert heating load in BTU's to actual fuel consumed at the building. These numbers will be used for calculating the actual amount of fuel saved in gallons, cubic feet, etc., which then will be used to determine dollar savings, based on the price per unit of fuel. Therefore, the numbers listed below for Purchased Steam and Electrical Source Fuel must be differentiated from the values for off-site generated fuel (1390 Btu/lb and 11,600 But/Kwh), which are recommended for calculation of energy to cost (E/C) ratios in Energy Conservation Investment Program (ECIP) economic analyses.

Distillate Fuel Oil138,700	BTU/gal
Residual Fuel Oil150,000	BTU/gal
Natural Gas1,031,000	BTU/1000 cu.ft
LPG, Propane, Butane	BTU/gal
Bituminous Coal	BTU/Short Ton
Purchased Steam1,060	BTU/1b
Electrical Source Fuel	BTU/KWH

600 U=.25 500 U=.21 EQUIPMENT RUN TIME FOR WARM-UP (ERT) HOURS/YEAR U=.18 400 U=.15 U=.12 300 200 100 2000 12000 4000 6000 8000 10000 HEATING DEGREE DAYS

G

LIGHT CONSTRUCTION FIGURE 9



Ĩ

HEATING DEGREE DAYS

HEAVY CONSTRUCTION FIGURE 10

3.3 Miscellaneous Factors

C

L = load factor

This takes into account the efficiency and partial load of motors. For conservation savings estimation use 0.8 based on,

L = partial load = .68 = 0.8efficiency at part load .85 = 0.8

Other values should be used if information on a particular motor indicates such.

- LTL = low temperature limit in °F for shutdown periods, usually is 50°F or 55°F.
- SSP = summer thermostat setpoint in °F; 78°F is recommended
 for normal occupancy
- WSP = winter thermostat setpoint in °F; 65°F is recommended for normal occupancy

4.0 Savings Calculation Algorithms

T

When calculating energy savings for systems on which more than one EMCS function may be applied, care must be taken not to duplicate savings. For example, the potential cooling savings from cold/hot deck reset is affected by the operation of an economizer cycle. Therefore, it is necessary to include an economizer cycle in the computer simulation runs used for considering hot/cold deck reset savings if the economizer cycle program is also going to be used on the system. These type considerations are discussed with the savings calculations for each energy saving function.

Also, care must be taken not to calculate the same heating or cooling savings for both the secondary system and primary system serving it. For example, both an air handler and the chiller providing chilled water to the AHU coil may be considered for Scheduled Start/Stop. The cooling savings for the space being served may be calculated in the savings analysis for either system but not both.

The time event programs Scheduled Start/Stop, Day/Night Setback, Ventilation/Recirculation, and Optimum Start/Stop are closely related and the savings attributable to each is dependent on how the function is defined. An attempt has been made in the development of standard methods of determining energy savings to differentiate among these programs based on the descriptions found in Section II of the <u>Energy Monitoring and Control Systems(EMCS) Technical Manual</u>, TM 5-815-2/AFM 88-36/NAVFAC DM-4.9.

Scheduled Start/Stop may be applied to systems which can be shut down during unoccupied hours, such as chillers and air handlers serving non-critical areas. Day/Night Setback is to be applied to systems which cannot be completely shut down during unoccupied hours, but can have thermostat setpoints set back. Optimum Start/Stop calculations are applicable only in conjunction with Scheduled Start/Stop for systems having auxiliary pumps and/or fans. Some heating and cooling energy may be saved by Optimum Start/Stop applied to night setback scheduling, however, estimation of these savings would be difficult; therefore, only auxiliary savings are considered. The Ventilation and Recirculation program is applicable in conjunction with Scheduled Start/ Stop or Day/Night Setback for air handlers which have or are to be retrofitted with outside air damper control.

Standard methods for calculating yearly savings from each energy conservation strategy, as they apply to individual systems, have been developed. Computer methods are recommended for better accuracy, when a building energy simulation computer program is available. The standard methods are discussed in the following pages. A master variable glossary of all the parameters used in the calculations is included in Appendix A.3.

Each equation below results in an answer with units of energy per year. In most cases, cooling savings will be in kwh per year, except where an absorption or steam turbine driven chiller is in operation. In that case, cooling savings will be in pounds of steam per year and needs to be converted to the primary fuel source units for the on-site boiler, taking boiler efficiency into consideration. Heating savings calculations will result in an answer with units of fuel consumption per year. The units could be cubic feet of natural gas per year or gallons of fuel oil per year or any other primary source of heat on the facility.

4.1 SCHEDULED START/STOP

Manual Method:

The following savings calculations for HVAC equipment assume a low temperature override to system shutdown. If no low temperature limit is desired than use the average winter temperature (AWT) in place of the low temperature limit (LTL) and let percent runtime (PRT) equal zero.

Cooling savings =

BTT x AZ x (AST-SSP) x (168 hr/wk - H) x WKS x CPT x F 12,000 Btu/ton-hr

```
Heating savings =

<u>BTT x AZ x (WSP-LTL*) x (168 hr/wk - H) x WKW x F</u>

HEFF x HV
```

Ventilation cooling savings =
 [CFM x POA x (4.5 lb/cfm-hr) x (OAH-RAH) x (168 hr/wk - H)
 x WKS x CPT x F]/(12,000 Btu/ton-hr)

Ventilation heating savings =
 [CFM x POA x (1.08 Btu/cfm°F-hr) x (WSP-AWT)
 x (168 hr/wk - H) x WKW x F]/(HEFF x HV)

Auxiliary savings = HP x L x (0.746 kw/hp) x (168 hr/wk - H) x [WKS + (WKW x (1-PRT)] x F

Where,

AST = average summer temperature in °F (See page 19)

AWT	z	average winter temperature in °F (See page 19)
AZ	=	area of zone being served in ft. ²
BTT	=	building thermal transmission in Btu/hr°F-ft ² (See page 28)
CFM	=	air handling capacity in ft ³ /min
CPT	=	energy consumption per ton of refrigeration
		in Kw/ton or lb/ton-hr (See page 30)
F	=	fraction of savings attributable to EMCS (See page 42)
H	Ξ	hours of operation per week (use present time
		clock schedule or occupied hours plus two
		hours each morning).
HEFF	=	heating efficiency of the system (total
		system, including converters, transmission
		system, boilers see page 31).
ΗP	=	motor nameplate horsepower (total of conti-
		nuously running fans and pumps).
HV	=	heating value of fuel (in Btu/gal, Btu/kwh,
		etc. See page 32).
L	=	load factor (See page 35)
LTL	=	low temperature limit in °F; usually 50°F or
		55°F. *Use the average winter temperature in
		place of LTL if $AWT > LTL$.
OAH	=	average outside air enthalpy in Btu/lb (See page 24)
POA	=	present percent minimum outside air expressed
1011		as a decimal
PRT	=	percent run time during heating season shut-
		down period required to maintain a low limit
		temperature of 55°F expressed as a decimal
		(See page 25). Use PRT = 0 if no low tempe-
		rature limit is planned.
RAH	=	return air enthalpy during normal operating
		hours. Use 29.91 Btu/lb for 78°F and 50%
		humidity. For other conditions, obtain
		values from a psychrometric chart.

Û

39.

- -

SSP	=	summer thermostat setpoint in °F
WKS	=	length of summer cooling season in weeks per
		year (See page 27)
WKW	=	length of winter heatng season in weeks per
		year (See page 27)
WSP	=	winter thermostat setpoint in °F

Computer Method:

Simulate building loads and system operation using a computerized energy analysis program. In the initial run assume that the systems run 24 hrs/day, 7 days/week. In the second run, assume that systems run only during occupied hours plus two hours in the morning for warm up or cool down. Include desired low limit temperatures when applicable. Do not include fan KW in computer runs so that the difference in results is representative only of heating and cooling energy reduction. This heating and cooling energy savings can then be proportioned on a per ft^2 basis to other similar systems serving zones with similar building loads.

Cooling Savings	=	Difference in electrical consumption
		of computer analysis runs.
Heating Savings	=	Difference in heating consumption
		of computer analysis runs.
Auxiliary Savings	=	(See manual method)

The following procedure determines the yearly savings from Scheduled Start/Stop of a domestic hot water heater.

1. Calculate tank volume and surface area:

$$V = 0.785 \times D^2 \times HT$$

A = (1.571 x D²) + (3.14 x D x HT)

2. Use Figure 11, page 43, to determine the quantity:

$$E = \frac{T - Ts}{To - Ts}$$

3. Calculate the energy savings:

DHW heating savings =
[(A x (To-Ts) x LSD x (.285 Btu-in/ft²hr°F/INS))
- (V x 62.4 Btu/ft³°F x (To-Ts) x (1-E))] x NSD
x F/(HEFF x HV)

4. Repeat steps 2 and 3 for each different length of shutdown period and then total the savings.


Where,

A	=	surface area of tank in ft ²
D	=	diameter of tank in ft
Ε	=	parameter determined from Figure 11
F	=	fraction of savings attributable to EMCS (See page 42)
HEFF	=	heating efficiency of the system (See page 31)
HT	=	height of tank in ft
HV	=	heating value of fuel in Btu/gal, Btu/kwh,
		etc. (See page 32)
INS	=	thickness of insulation in inches
LSD	=	length of shutdown period in hours
NSD	=	number of shutdown periods per year of a
		given length
T	=	water temperature at end of shutdown period
		in °F
То	=	hot water temperature setpoint in °F
Ts	=	average temperature of surroundings in °F
V	=	volume of tank in ft ³

If the system is currently started and stopped by a time switch or manually, full credit cannot be taken for the above savings for the EMCS. Determining what savings may be attributed to the EMCS becomes a function of the reliability of the time switch system. Time switches can be effective devices for the reduction of energy consumption; however, they have several disadvantages. They do not take into account holiday operation, seasonal changes, or daily weather variations. They are also easily tampered with, bypassed, or overridden. The pins which activate actions may slide, thus causing system operation and energy consumption at unnecessary times. They must be checked often to ensure proper operation and must be reset manually every time a power outage occurs for any appreciable time period. Manual operation is subject to human error and forgetfulness.

The EMCS is capable of performing the same operations but without most of the difficulties described, since it is not within the reach of tampering, and system operations are monitored constantly by the console operator. Therefore, the EMCS should be credited with some portion of these savings due to the increased reliability and the EMCS' ability to adjust and optimize start and stop times.

The fraction of savings attributable to the EMCS (F) shall be used to account for present timeclock or manual operation and future use of extended service capability of the system. Let F equal 1.0 if the system is presently operating around the clock and no extended service is projected. Otherwise, the value shall be between 0 and 1.0 depending on extension of operation and the reliability of the present control as determined during the field survey.



•

(•

ĺ,

.

4.2 DUTY CYCLING

This function is applicable to electrical loads under 30 hp nameplate rating; however, the savings calculations apply only to <u>constant</u> loads. Duty cycling of loads which already cycle under local controls may save energy by essentially overriding the local thermostat setting, but these savings would be difficult to estimate and so are not included in the analysis. For motors above 30 hp, the savings are offset by added maintenance cost due to excessive wear on belts and bearings caused by frequent cycling.

Manual method:

Assume the system may be shut down for an average of 10 minutes per hour. The savings resulting from this function are fan or other auxiliary energy and outside air heating and cooling energy. Outside air loads are difficult to determine since they actually depend on space load conditions. If there is a net cooling load in the space, and the outside air is below 75°F, the outside air actually reduces energy consumption, which is often the case in commercial buildings during the heating season. Therefore, ventilation savings will not be credited by the manual method.

Auxiliary savings = HP x L x 10/60 x (.746 Kw/hp) x H x (52 wk/yr)

Where,

- H = Hours of operation per week (use number of hours of occupancy assuming duty cycling is not desirable during warmup)
- HP = motor nameplate horsepower (total of all continuously running fans and pumps)

= load factor (see page 35)

10/60 = fraction of time system is shut down (assumes ten minutes out of each hour)

Computer Method:

L

Q

Ű

Simulate building loads and systems operation using a computerized energy analysis program capable of calculating annual energy consumption. In the initial run schedule the system to run during occupied hours plus two hours in the morning. On the second run, schedule the system to run for only 50 minutes of each hour except the first two. It is important to use accurate actual ventilation air quantities as input to the program if possible. Include dry bulb or enthalpy economizer in both runs if either exists or is to be implemented for the system by the EMCS. Do not include fan KW input in the computer runs so that the difference in results only represents heating and cooling energy reductions.

Cooling Savings	=	Difference in electrical consump-
		tion of computer analysis runs.
Heating Savings	=	Difference in heating consumption
		of computer analysis runs.
Auxiliary Savings	=	(See manual method)

4.3 DEMAND LIMITING

Assume by using a rotating group load shed scheme that the system can be shed 25% of time under peak load conditions.

KW Savings = HP x L x $(0.746 \text{ kw/hp}) \times 0.25$

Where,

L = load factor (see page 35)

4.4 OPTIMUM START/STOP

Auxiliary savings from this function are derived by minimizing the necessary warm-up or cool-down time prior to occupancy and by shut down of the system as early as possible before the end of the occupancy period. Early shutdown is applicable only where ventilation is not critical and most of the occupants vacate the building at the scheduled time. Cooling and heating savings obtainable by keeping OA dampers closed during warm-up/cool-down times are accounted for in the Ventilation and Recirculation savings calculations. While a small amount of energy may be saved due to less run time of cycling loads (cooling tower fans or unit heaters), it is difficult to estimate and is not included in this analysis.

```
Warm-up Auxiliary Savings =
    HP x L x (0.746 kw/hp) x ((WH x AND) - ERT) x (DAY/7 dy/wk)
```

* Cool-down Auxiliary Savings =
 HP x L x (0.746 kw/hp) x (CH - .75 hr/dy) x (365 dy/yr AND) x (DAY/7 dy/wk)

Where,

- AND = annual number of days total that warmup is required in days per year (See page 18)
- CH = present cool-down time before occupancy in hours
 per day. Use either the actual time presently
 scheduled for cool-down by an existing timeclock
 or 2 hours to correspond to Scheduled Start/Stop
 savings calculations.

DAY = equipment operation in days per week

ERT = equipment run time total required for warm up in hours per year (See page 30)

- HP = motor nameplate horsepower (total of continuously running fans and pumps)
- L = load factor (See page 35)
- WH = present warm-up time before occupancy in hours per day. Use either the actual time presently scheduled for warmup by an existing timeclock or 2 hours to correspond to Scheduled Start/Stop savings calculations.

*This calculation assumes a 45 minute (.75 hours) cool-down time is required per day during the days of the year not requiring warmup. This is a conservative estimate; in most parts of the country, a fifteen minute purge would probably be sufficient in mild weather.

4.5 OUTSIDE AIR LIMIT SHUTOFF

Savings are derived from reduced hours of operation of auxiliary equipment and reduction of system losses (heat transfer through pipe walls, leaking steam traps, etc.). Whenever the system loss savings can be identified they should be included in the analysis. However, generally it is not possible to reasonably estimate what those losses are. Auxiliary savings are derived from the shutting off of pumps, fans, etc. The auxiliaries may be shut down whenever the outside temperature crosses limits which, according to the time of year, indicate that heating or cooling is not required. Fans which provide necessary ventilation should not be considered for these savings. Also cooling to interior zones should not be shutoff by this function.

Auxiliary Savings = HP x L x (0.746 kw/hp) x (HS + HW)

Where,

C

1

HP	=	motor nameplate horsepower (total of continuously
		running fans and pumps)
HS	=	hours in summer outside temperature is below
		summer limit in hours per year (See page 23)
HW	=	hours in winter outside temperature is above
		winter limit in hours per year (See page 23)
L	=	load factor

4.6 VENTILATION AND RECIRCULATION

Savings from this function are a result of control of OA dampers. All calculations assume that a 15 minute purge of ventilation air is necessary prior to occupancy.

The following calculation is applicable to systems which are shut down by the Scheduled Start/Stop function and is restricted to the period of time during warm-up or cool-down prior to occupancy. No cool-down ventilation savings is included in the analysis based on the assumption that early morning outside air adds a negligible amount to the cooling load and in fact may lessen the load through an economizer effect.

Warmup ventilation heating savings = <u>CFM x POA x (WSP-AWT) x (1.08 Btu/cfm°F-hr) x AND x (WH-.25 hr/day)</u> HEFF x HV

The next two calculations are applicable to fan systems which must maintain environmental conditions but may eliminate outside air during building unoccupied periods.

Ventilation cooling savings =
[CFM x POA x (4.5 lb/cfm-hr) x (OAH-RAH) x (UH-(.25 hr/dy x DAY))
x WKS x CPT]/(12,000 Btu/ton-hr)

Ventilating beating savings -					
Ventilating heating savings =					
[CFM x POA x (1.08 Btu/cfm°F-hr) x (WSP-AWT) x (UH-(.25 hr/dy					
x DAY)) x WKW]/(HEFF x HV)					
Where,					
AND = annual number of days total that warmup is re-					
quired in days per year (See page 18)					
AWT = average winter temperature in °F (See page 19)					
CFM = air handling capacity in ft3/min.					
CPT = energy consumption per ton of refrigeration in					
kw/ton or lb/ton-hr (See page 30)					
DAY = equipment operation in days per week					
HEFF = heating efficiency of the system (total system,					
including converters, transmission system,					
boilers. See page 31)					
HV = heating value of fuel in Btu/gal, Btu/kwh, etc.					
(See page 32)					
OAH = average outside air enthalpy in Btu/lb (See page					
24)					
POA = present percent minimum outside air expressed as a					
decimal					
RAH = return air enthalpy during unoccupied hours. Use					
29.91 Btu/lb for 78°F and 50% humidity. For other					
conditions obtain values from a psychrometric					
chart.					
UH = uncccupied hours per week					
WH = present warmup hours before occupancy each day.					
Use either the actual time presently scheduled for					
warmup by an existing timeclock or 2 hours to					
correspond to Scheduled Start/Stop savings calcu-					
lations.					
WKW = weeks of winter per year (See page 27)					
WKS = length of summer cooling season in weeks per year					
(See page 27)					
WSP = winter thermostat setpoint temperature in °F					

D

4.7 ECONOMIZER (DRY BULB OR ENTHALPY)

Either the OA dry bulb economizer strategy or the OA enthalpy economizer strategy is applicable to air systems with outside air and exhaust air dampers. Use of a computer simulation is required for accurate determination of savings from economizer control; therefore, no manual method is discussed here. Economizer control will not be economically feasible for air handlers below about 12,000 cfm and may not be feasible for systems even as large as 300,000 cfm. More savings are obtained from economizers installed on energy inefficient systems such as reheat systems, and also in large buildings with high internal gains.

Computer Method:

Simulate building loads and system operation using a computerized building energy analysis program. In the initial run assume that no economizer is operable. In the second run, simulate savings either from a dry bulb or enthalpy economizer operation. The runs should be made assuming the system is operating the minimum number of hours necessary. Savings may be proportioned for similar systems serving zones with similar building loads on a per ft² basis.

Cooling Savings = Difference in electrical consumption of computer analysis runs. Heating Savings = Should be negligible

4.8 DAY/NIGHT SETBACK

This strategy would be applied, instead of Scheduled Start/ Stop, to systems with no auxiliaries such as steam radiation. It is also applicable to systems which serve critical areas with temperature, humidity, or pressure requirements that will allow a small setpoint adjustment, but the system cannot be stopped altogether. If OA dampers can be closed during the setback period, ventilation savings are possible and should be calculated under the Ventilation and Recirculation strategy.

•

Manual Method:

Cooling savings = $\underline{BTT \times AZ \times SU \times (168-H) \times WKS \times CPT}$ 12,00[°] Btu/ton-hr

Heating savings = $\underline{BTT \ x \ AZ \ x \ SD \ x \ (168-H) \ x \ WKW}$ HEFF x HV

Where,

C

C

Ż

AZ	=	area of zone being served in ft ²
BTT	=	building thermal transmission in Btu/hr°F-ft ² (see
		page 28)
CPT	=	energy consumption per ton of refrigeration in
		kw/ton or lb/ton-hr (See page 30)
H	=	hours of operation per week during which the
		normal setpoint applies
HEFF	=	heating efficiency of the system (total system,
		including converters, transmission system,
		boilers. See page 31)
HV	=	heating value of fuel in Btu/gal, Btu/kwh etc.,
		(see page 32)
SD	Ŧ	thermostat setdown for unoccupied periods during
		the heating season in °F
SU	=	thermostat setup for unoccupied periods during the
		cooling season in °F
WKS	Ξ	length of summer cooling season in weeks per year
		(See page 27)
WKW	=	length of winter cooling season in weeks per year
		(See page 27)

2

Computer Method:

Simulate building loads and system operation using a computerized energy analysis program. In the initial run assume the systems run 24 hrs/day, 7 day/week at present heating and cooling setpoints. In the second run, assume that the systems operate under control of the setback temperatures during unoccupied hours plus one hour for warm-up or cooldown. This heating and cooling energy savings can be proportioned on a per ft^2 basis to similar systems serving zones with similar building loads and the same setback requirements.

Cooling savings = difference in electrical consumption of computer analysis runs

Heating savings = difference in heating consumption of computer analysis runs

4.9 REHEAT COIL RESET

Manual method:

A computer simulation is recommended for these savings calculations and is required for accurately determining the savings from Reheat Coil Reset, when economizer control is also applied to the system. The cooling savings with an economizer will be one-third to four-fifths of the savings without an economizer due to the reduction of mechanical cooling already obtained by the economizer control.

*Cooling savings (no economizer) =

 $\frac{\text{H x CFM x (4.5 min.lb/hr.ft^3) x WKS x RHR x (0.6 Btu/lb) x CPT}{(12,000 Btu/ton-hr)}$

** Heating savings =

<u>H x CFM x (1.08 Btu/cfm-hr°F) x (52 wk/yr) x RHR</u> HEFF x HV

Where,

- CFM = air handling capacity in ft³/min
- CPT = energy consumption per ton of refrigeration (see page 30)
- HEFF = heating efficiency of the system, (total system, including converters, transmission system, boilers. See page 31)
- HV = heating value of fuel in Btu/gal, Btu/Kwh, etc. (See page 32)
- RHR = reheat system cooling coil discharge reset in °F. Up to 5° or 6° is possible, dependent on the system. If a better estimate of possible reset is not available use 3°F.
- WKS = length of summer cooling season in weeks per year (see page 27)

*This equation assumes a 1°F cooling coil temperature increase is equivalent to a 0.6 Btu/lb change in enthalpy.

**To account for holiday shutdown or for a system that does not operate year-round, the 52 wk/yr term can be adjusted accordingly.

Computer method:

Simulate building loads and system operation with a computerized energy analysis program. Preferably the program used should have simulation routines for selecting the zones with

the greatest cooling demand and calculating the necessary cooling coil leaving air temperature or at least the capability of a reset schedule. In order to approximate the savings from this function, run the program once using a constant cooling coil setpoint temperature and then a second time simulating variable reset based on a discriminator scheme or a reset schedule. Be sure to include economizer control when applicable.

Cooling savings = Difference in electrical consumption of computer analysis runs Heating savings = Difference in heating consumption

of computer analysis runs

4.10 HOT DECK/COLD DECK TEMPERATURE RESET

Manual Method:

A computer simulation is recommended for these savings calculations, and is required for accurately determining the savings from Hot Deck/ Cold Deck Temperature Reset when economizer control is also applied to the system. The cooling savngs with an economizer can be as little as onefifth of the savings without an economizer due to the reduction of mechanical cooling already obtained by the economizer control.

* Cooling savings (no economizer) =

 $\frac{\text{H x CFM x CD x (4.5 min.lb./hr.ft}^3) \text{ x WKS x SCDR x (0.6 Btu/lb) x CPT}}{(12,000 Btu/ton-hr)}$

Heating savings =

H x CFM x HD x (1.08 min. Btu/hr ft³°F) x (WKS x SHDR + WKW x WHDR) HEFF x HV

Where,

C

ĩ

٦

 \cdot

CD =	fraction of total air passing through the cold
	deck. Assume .50 if no other information is avail-
	able.
CFM =	air handling capacity in ft ³ /min
CPT =	energy consumption per ton of refrigeration in
	kw/ton or lb/ton-hr (See page 30)
н =	required number of hours of operation per week
	(assume hours of occupancy plus one per day)
HID =	fraction of total air passing through the hot
	deck. Assume .50 if no other information is
	available.
HEFF =	heating efficiency of the system (total including
	converters, transmission system, boilers. (See
	page 31)
HV =	heating value of fuel in Btu/gal, Btu/Kwh etc.
	(see page 32)
SCDR =	summer cold deck reset in °F (The average reset is
	a function of the system. If an estimate is not
	available, use 2°F.)
SHDR =	summer hot deck reset in °F (The average reset
	that will result from this function is dependent
	on the air handler capacity relative to the loads
	in the space it serves. If an estimate of the
	possible reset is not available use 3°F.)
WHDR =	winter hot deck reset in °F (Again, the average
	reset is a function of the system. If an estimate
	is not available use 2°F)
WKS =	length of summer cooling season in weeks per year
HUD ~	
	(See page 27)

WKW = length of winter heating season in weeks per year (See page 27)

*This equation assumes a 1°F cold deck temperature increase is equivalent to a 0.6 BTU/lb change in enthalpy.

Computer method:

5

Simulate building loads and system operation with a computerized energy analysis program. The program used should have simulation routines necessary to select the zones with the greatest heating and cooling demands and then calculate the necessary hot and cold deck leaving temperatures. In order to approximate the savings from this function, run the program once using constant deck setpoint temperatures and then a second time simulating variable deck temperatures based on a discriminator control scheme. Be sure to include economizer control when applicable.

Cooling savings	=	Difference	in	electrical	consumption
		of computer	anal	ysis runs	
Heating savings	=	Difference in heating consumption			
		of computer	anal	ysis runs	

4.11 HOT WATER OUTSIDE AIR RESET

Boiler temperature reset saves energy by reducing heat losses through the heating system and flue gases and by providing more exact control at the end use point. This last item provides savings by reducing overheating of spaces at less than maximum loads due to control valve insensitivity in those operating ranges. Reset of hot water supply temperature from a converter produces savings similarly. No exact means of quantifying these savings is known, however experience indicates these savings should be a function of

the annual equivalent full load hours of system operation and the total capacity of the system.

Heating savings = $HFLH \times EI \times CAP/(HEFF \times HV)$

Where,

G

Ľ

CAP	=	maximum capacity of device(s) in Btu/hour.
ΕI	=	efficiency increase expressed as a decimal.
		(use .01 if no better estimate is available.)
HEFF	=	heating efficiency of the system.
		(Total system, including converters, transmission
		system, boilers. See page 31)
HFLH	=	annual equivalent full load hours for heating in
		hr/yr (see page 22)
7777	_	heating many of field in Dty (and Dty (and

HV = heating vaue of fuel in Btu/gal, Btu/kwh, etc. (see page 32)

4.12 BOILER OPTIMIZATION

EMCS monitoring of boiler operation aids the maintenance personnel in keeping the boilers operating at peak efficiency.

Heating Savings = HFLH x EI x CAP/(HEFF x HV)

hr/yr (See page 22)

Where,

CAP	=	maximum capacity of device(s) in Btu/hour.
EI	=	efficiency increase expressed as a decimal.
		(use .01 for one boiler and .02 for multiple
		boilers, if no better estimate is available.)
HEFF	=	heating efficiency of the system.
		(efficiency of boiler(s). See page 31)
HFLH	=	annual equivalent full load hours for heating in

HV = heating value of fuel in Btu/gal, Btu/kwh, etc. (See page 32)

4.13 CHILLER OPTIMIZATION

These savings are applicable only to chilled water plants with multiple chillers. The calculations assume a 1% increase in efficiency attributable to the EMCS.

Cooling savings = CPT x TON x CFLH x 0.01

- CFLH = annual equivalent full-load hours for cooling in hr/yr (See page 20)
- CPT = consumption of energy per ton of refrigeration in kw/ton or lb/ton-hr (See page 30)
- TON = total capacity of chilled water plant in tons

4.14 CHILLER WATER TEMPERATURE RESET

Reset of chilled water supply temperatures results in energy savings due to the increased efficiency of the refrigeration machine. Check to be sure that a chilled water controller may be applied to the particular manufacturer's chiller being considered. The savings will vary depending on the machine, the amount of reset, and the load on the equipment. The amount of reset generally ranges between $2^{\circ}F$ and $5^{\circ}F$, so a conservative estimate of $2^{\circ}F$ was used in the calculation.

Cooling Savings = TON x CPT x CFLH x $2^{\circ}F$ x REI

Where,

- CFLH = equivalent full-load hours for cooling in hours/ year (See page 20)
- CPT = energy consumption per ton of refrigeration in
 kw/ton or lb/ton-hr (See page 30)
- **REI = rate of efficiency increase per °F increase of chilled water temperature.**

Use for:

screw compressor machine - .024 per °F
centrifugal (elec. or turbine) machine - .017 per °F
reciprocal machine - .012 per °F
absorption machine - .006 per °F

TON = chiller capacity in tons. If chiller capacity is not available and nameplate electrical data on the chiller motor is, use the full-load KW input in place of (TON x CPT).

4.15 CONDENSER WATER TEMPERATURE RESET

ī

Decreasing the condenser water temperature also increases the efficiency of chillers, but care must be taken not to exceed the equipments' limitations, particularly in absorption machines. The implementation of condenser water reset may result in greater fan energy consumption. If a cooling tower fan cycles on and off, the on time will be increased consuming more auxiliary energy. If it runs continuously with valve bypass control to maintain constant entering condenser water temperature and can be cycled when the EMCS function is applied, then additional auxiliary energy can be saved. An adjustment to account for these conditions has been included in the savings analysis.

The calculation procedure requires four steps:

 Calculate the average reduction in condenser water temperature which is achievable:

RCWT = PCWT - ACWT

2. Use Figure 12, page 61, to determine the percent efficiency increase (PEI) of the chiller based on RCWT from above. 3. Determine the adjusted efficiency increase (AEI) of the chiller:

If fan runs continuously, but will be cycled, AEI = PEI + 5.5100

4. Calculate the cooling savings:

Cooling savings = TON x CPT x CFLH x AEI


Where,

C

ACWT	=	average condenser water temperature possible in °F
		(See page 16)
AEI	=	adjusted efficiency increase of the chiller due to
		condenser water reset.
CFLH	=	equivalent full load hours for cooling in hours/
		year (See page 20)
CPT	=	consumption of energy per ton of refrigeration in
		kw/ton or lb/ton-hr (See page 30)
PCWT	=	present condenser water temperature in °F (usually
		set at 85°F.)
PEI	=	percent efficiency increase of the chiller
TON	=	chiller capacity in tons. If chiller tonnage is
		not available for compression refrigeration
		machines, but nameplate electrical data is, then
		use the total full-load KW rating of the com-
		pressor and auxiliary motors in place of
		(TON x CPT).
RCWT	=	reduction in condenser water temperature which is
		achievable, in °F



١



REDUCTION IN CONDENSER WATER TEMPERATURE (RCWT)

FIGURE 12

4.16 CHILLER DEMAND LIMIT

These savings may be considered for centrifugal chillers that are equipped with an adjustable control system for limiting the available cooling capacity. The calculation assumes by using a rotating group load shed scheme that the chiller can be stepped down by 20% of its maximum cooling capacity 25% of the time under peak load conditions.

* KW savings = (HP/0.9) x (0.746 KW/hp) x 0.20 x 0.25

Where,

C

HP = motor nameplate horsepower (of compressor)

*The 0.9 factor accounts for a 90% motor efficiency.

4.17 LIGHTING CONTROL

This function is applicable to relay operated zoned lighting. The following calculation is for one zone of lighting.

Electrical savings = KW x (168 hr/wk-H) x 52 wk/yr x F

Where,

*F = fraction of savings attributable to EMCS (see page 42)
H = hours of operation per week (use hours of occupancy)
KW = total KW consumption of lights in the zone

*This factor is a subjective measure of how diligently the lights are turned off manually at the present.

4.18 RUN TIME RECORDING

By scheduling maintenance based on actual operation, assume the EMCS is able to save one man-visit per year to the system being monitored by the EMCS. Assume this man-visit is 2 hours in duration. To which systems these savings should be applied, if any, is a judgement decision based on present facility maintenance procedures.

Labor savings = 2 man-hours

4.19 SAFETY ALARM

The EMCS can save facility personnel from time spent conveying alarm information and diagnosing problems. Assume a total of 2 hours per system per year. Whether credit is taken for this savings is dependent on the individual system and on facility policies.

Labor savings = 2 man-hours

To aid in the use of the calculation methods, forms have been designed to simplify the analysis of each system. There is one form to be used for primary systems, such as boilers and chillers and one for secondary (or unitary) air distribution systems. Blank Savings Calculations and Costs forms are included in Appendix A.2.

The forms provide a simplified version of each equation used in the manual methods with blanks to be filled in with the appropriate values. The variable symbols have been inserted in the blanks of sample forms in Figures 13 and 14 on the following two pages. They can be used for reference, along with the Variable Glossary, while filling in the blank Savings Calculations and Costs Sheets. FIGURE 13 PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

C

E

BUILDING NO. SYSTEM NO. SYSTEM TYPE

			SAVINGS	NGS		
FUNCTION	SAVINGS CALCULATIONS	KW	КWH		HM	COST
Scheduled Start/Stop	Clg: * x BTT Btu/ft ² hr °F x AZ ft ² x(168 - H) x F x CPT /ton Htg: * x BTT Btu/ft ² hr °F x AZ ft ² x(168 - H) x F /(HEFF x HV) Aux: * x HP hp x (168 - H) x P					BASIC FUNCTIONS
Duty Cycling	Aux: <u>* x HP</u> hp x <u>H</u> hr					
Demand Limit	KW: <u>*</u> X <u>HP</u> hp					
Optimum Start/Stop	WU Aux: * x HP hp x((WH hr x AND) - ERT hr)x DAYdays/wk CD Aux: * x HP hp x (CH hr75) x DAY days/wk					
OA Limit	Aux: <u>*</u> x HP hp x (<u>HS</u> + HW)					
Run Time	Labor: 2 Manhours					
HW OA Reset	Htg: HFLH hr/yr x EI x CAP Btu/hr/(HEFFx HV)					
Boiler Opt.	Htg: HFLH hr/yr x EI x CAP Btu/hr/(HEFFx HV)					
Chiller Opt.	Clg: CFLH hr/yr x CPT /ton x TON T x 0.01					
CHW Reset	Clg: CFLH hr/yr x CPT /ton x TON T x REI /°F x 2°F					
Cond. Reset	Clg: CFLH hr/yr x CPT /ton x TON T x (AEI)					
Chiller Demand Kw:	Kw: 0.6414 x HP hp					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM					

*Derived constants for the specific location.

FUNCTION	SAVINGS CALCULATIONS	SAVINGS KWH M	MH COST
Scheduled Start/Stop	Clg: * x BTT Btu/ft ² hr ^o F x AZ ft ² x(168 - H) x F x CPT /ton Htg: * x BTT Btu/ft ² hr ^o F x AZ ft ² x(168 - H) x P / HEPP x HV) V-Clg: * x CFM cfm x POA x (168 - H) x P x CPT /ton V-Htg: * x CFM cfm x POA x (168 - H) x P x P / HEFF x HV) Aux: * x HP hp x (168 - H) x F		FUNCTIONS
Duty Cycling	Aux: <u>* x HP</u> hp x H hr		T
Demand Limit	KW: * x HP hp		1
Opti mum Start/Stop	WU Aux: * x HP hp x ((WH hr x AND) - ERT hr)x DAYJays/wk CD Aux: * x HP hp x (CH hr75) x DAY days/wk		1
0A Limit	Aux: <u>*</u> x <u>HP</u> hp x (<u>HS</u> + <u>HW</u>)		1
Run Time	Labor: 2 Manhours		T
Ventilation/ Recirculation	WU V-htg: <u>* x CFM</u> cfm x <u>POA</u> x (<u>WH</u> 25)/(<u>HEFF x HV</u>) V-clg: <u>* x CFM</u> cfm x <u>POA</u> x((<u>UH</u> -(.25x <u>DAY</u> dy/wk)) x <u>CPT</u> /ton V-htg: <u>* x CFM</u> cfm x <u>POA</u> x((<u>UH</u> -(.25x <u>DAY</u> dy/wk))/(<u>HEFF x HV</u>)		
Economizer	(Computer simulation required. See page xx).		
Day/Night Setback	Clg: * x BTTBtu/ft ² hr°FxAZ ft ² x SU ⁰ F x (168 - H) x CPT /ton Htg: * x BTTBtu/ft ² hr°FxAZ ft ² x SD ⁰ F x (168 - H)/HEFF x HV)		
Reheat Coll Reset	Clg: <u>* x H hr/wk x CFM</u> cfm x <u>RHR</u> [°] F x <u>CPT</u> /ton Htg: <u>* x H hr/wk x CFM</u> cfm x <u>RHR</u> [°] F/(HEFF x HV)		
Hot/Cold Deck Reset	Clg: <u>x x H hr/wk x CFM</u> cfm x <u>CD x SCDR</u> [®] F x <u>CPT</u> / ton Htg: <u>x x H</u> hr/wk x <u>CFM</u> cfm x <u>HD</u> x(<u>MKS x SHDR[*] HKW x WHDR</u>) / HEFFx HV)		
Safety Alarms	Labor: 2 Manhours		
	TOTALS FOR SYSTEM		
	*Nerived constants for the snerific location		

Ţ

FICURE 14 SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS

*Derived constants for the specific location.

5.0 SAMPLE CALCULATIONS

In order to demonstrate the manual analyses methods discussed in this report, sample calculations have been performed on each type of system discussed in the Tri-Service Design Manual for EMCS, TM 5-815-2/AFM 88-36/NAVFAC DM-4.9, hypothetical Navy facility located assuming а in It is not possible to describe Springfield, Missouri. completely all activities involved in an engineering design process. For this reason, this section is meant only to be used as a framework for EMCS analysis. Every military base is different, and parts of the process described herein must be adapted, added to, or ignored as the situation requires. The judgement required to make these decisions requires professional engineering personnel familiar with the mechanical and electrical systems an EMCS is to control and how that control is to be accomplished.

The buildings which comprise the hypothetical Naval Base and the systems within each building are listed below:

> BUILDING NUMBER: 100 USAGE : PUBLIC WORKS SYSTEMS : Electric Unit Heater Electric Radiation Multizone DX-A/C Water Cooled DX Compressor Direct Fired Boiler BUILDING NUMBER: 200 USAGE: BASE PERSONNEL SYSTEMS: HTHW/Steam Converter Heating and Ventilating Unit Single Zone DX-A/C Multizone Air Handler Air Cooled DX Compressor Domestic HW - Gas Direct Fired Furnace BUILDING NUMBER: 300 USAGE: BASE HEADQUARTERS SYSTEMS: HTHW/HW Converter Water Cooled Chiller Single Zone Air Handler 45 Two Pipe Fan Coil Units Hot Water Unit Heater Domestic HW - Electric BUILDING NUMBER: 400 USAGE : WAREHOUSE SYSTEMS: 4 Steam Unit Heaters Steam Radiation Steam Boiler BUILDING NUMBER: 500 USAGE : ADMINISTRATION BUILDING SYSTEMS: Steam/HW Converter Air Cooled Chiller Terminal Reheat Air Handler Variable Air Volume AHU 15 Four Pipe Fan Coil Units Hot Water Radiation BUILDING NUMBER: 600 USAGE: HEATING PLANT SYSTEMS: 3 Hot Water Boilers (High Temp.)

Completed survey forms for the hypothetical facility are included on the following pages.

The first step in the procedure is to derive the climate based factors. The location of the hypothetical Naval facility was chosen as Springfield, Missouri to correspond with the factors derived on pages 11-27 from weather data. These values and the other climate-based data have been entered in a sample form shown on page 69.

Next, the climate-based and miscellaneous factors should be substituted into the equations for calculating savings. The equations can be simplified and the constants entered onto standard Savings Calculations and Cost sheets. This process is demonstrated below for those conservation strategies which can be simplified. The Savings Calculations and Costs sheets with the simplified constants for the example are shown on pages 73 and 74.

-1

CLIMATE - BASED FACTORS

LOCATION:

D

..

Ł

-

ľ

11

SYMBOL	DESCRIPTION	PAGE REF.	VALUE	UNITS
ACWT	Average Condenser Water Temperature	16	75.6	°F
AND	Annual Number of Days for Warmup	18	232	Days/Yr.
AST*	Average Summer Temperature	19	80.6	°F
AWT*	Average Winter Temperature	19	43.0	°F
CFLH	Annual Equiv. Full-Load Hrs. For Cooling	20	733	Hrs/Yr.
HFLH	Annual Equiv. Full-Load Hrs. for Heating	22	538	Hrs/Yr.
HS	Hrs. of Temp. Limit Shut-off for Summer	23	273	Hrs/Yr
HW	Hrs. of Temp. Limit Shut-off for Winter	23	204	Hrs/Yr
OAH*	Average Outside Air Enthalpy	24	33.34	Btu/lb.
PRT*	Percent Run Time for Low Temp. Limit	25	15	%
WKS*	Weeks of Summer	27	23.4	Wks/Yr.
wkw*	Weeks of Winter	27	28.6	Wks/Yr.

.

* Data not necessary if computer methods are used.

SCHEDULED START/STOP

Clg:		BTT x AZ x (80.6°F-78°F) x (168-H) x 23.4 wks/yr
		x CPT x F/(12,000 Btu/ton-hr)
	=	0.00507 x BTT x AZ x (168 - H) x CPT x F
Htg:		BTT x AZ x (65°F-55°F) x (168-H) x 28.6 wks/yr
		x F/(HEFF x HV)
	=	286 x BTT x AZ x (168 - H) x F/(HEFF x HV)
V-clg:		CFM x POA x (4.5 lb/cfm-hr) x (33.34 - 29.91 Btu/lb)
		x (168 - H) x 23.4 wks/yr x CPT x F/(12,000 Btu/ton-hr)
	=	.0301 x CFM x POA x (168-H) x CPT x F
V-htg:		CFM x POA x (1.08 Btu/cfm°F-hr) x (65°F-43.0°F) x
		(168-H) x 28.6 wks/yr x CPT x F/(HEFF x HV)
	=	679 x CFM x POA x (168-H) x F/(HEFF x HV)
Aux:		HP x 0.8 x (0.746 Kw/hp) x (168-H) x [23.4 wks/yr
		+ (28.6 wk/yr x (115))] x F
	Ŧ	28.5 x HP x (168-H) x F

DUTY CYCLING

Aux: HP x 0.8 x 10/60 x (.746 Kw/hp) x H x (52 wk/yr) = $5.17 \times HP \times H$

DEMAND LIMITING

KW: HP x .8 x (0.746 Kw/hp) x 0.25 = 0.149 x HP

OPTIMUM START/STOP

- WU Aux: HP x 0.8 x (0.746 Kw/hp) x ((WH x 232) ERT) x (DAY/7 day/wk) = $0.0852 \times HP \times ((WH \times 232) - ERT) \times DAY$
- CD Aux: HP x 0.8 x (0.746 Kw/hp) x (CH-.75 hr/day) x (365-232 day/yr) x (DAY/7 day/wk) = 11.3 x HP x (CH-.75) x DAY

OUTSIDE AIR LIMIT SHUTOFF

Aux: HP x 0.8 x (0.746 Kw/hp) x (225 + 164) = $0.597 \times HP \times (273 + 204)$

VENTILATION AND RECIRCULATION

- WU V-htg: CFM x POA x (65° 43.0°) x (1.08 Btu/cfm°F-hr) x 232 days/yr x (WH-.25 hr/day)/(HEFF X HV) = $5512 \times CFM \times POA \times (WH-.25)/(HEFF \times HV)$
- V-clg: CFM x POA x (4.5 lb/cfm-hr) x (33.34-29.91 Btu/lb) x (UH-(.25 hr/day x DAY)) x 23.4 wks/yr x CPT /(12,000 Btu/ton-hr)

= $0.0301 \times CFM \times POA \times (UH-.25 \times DAY) \times CPT$

- V-htg: CFM x POA x (1.08 Btu/cfm °F-hr) x (65°-43.0°) x (UH-(.25 hr/day x DAY)) x 28.6 wks/yr/(HEFF x HV)
 - = $679 \times CFM \times POA \times (UH-.25 \times DAY)/(HEFF \times HV)$

DAY/NIGHT SETBACK

Clg: <u>BTT x AZ x SU x (168-H) x 23.4 wks/yr x CPT</u> 12,000 Btu/ton-hr

= .00195 x BTT x AZ x SU x (168-H) x CPT

Htg: BTT x AZ x SD x (168-H) x 28.6 wks/yr/(HEFF x HV) = 28.6 x BTT x AZ x SD x (168-H)/(HEFF x HV)

REHEAT COIL RESET

- Clg: H x CFM x (4.5 min.lb/hr-ft³) x (23.4 wks/yr) x RHR x (0.6 Btu/lb) x CPT/(12,000 Btu/Ton-hr)
 - = $.00526 \times H \times CFM \times RHR \times CPT$
- Htg: H x CFM x (1.08 Btu/crm-hr°F) x (52 wk/yr) x RHR/(HEFF x HV)
 - = 56.16 x H x CFM x RHR/(HEFF x HV)

HOT DECK/COLD DECK TEMPERATURE RESET

- Clg: H x CFM x CD x (4.5 min.lb/hr-ft³) x (23.4 wks/yr) x SCDR x (0.6 Btu/lb) x CPT/(12,000 Btu/Ton-hr) = .00526 x H x CFM x CD x SCDR x CPT
- Htg: H x CFM x HD x (1.08 min.Btu/hr-ft³°F) x (23.4 x SHDR + 28.6 x WHDR)/(HEFF x HV)
 - = 1.08 x H x CFM x HD X ((23.4 x SHDR) + (28.6 x WHDR))/(HEFF x HV)

	COSTS
Æ	AND
PRIMARY SYSTEM	CALCULATIONS
	SAVINGS

1

C

BUILDING NO. SYSTEM NO. SYSTEM TYPE

		SAVINGS	łGS	
FUNCTION	SAVINGS CALCULATIONS	KW KWH	HM	COST
Scheduled Start/Stop	Clg: <u>.00507x</u> Btu/ft ² hr °F x ft ² x(168 -) x x /ton Htg: <u>286x</u> Btu/ft ² hr °F x ft ² x(168 -) x /(x) Aux: <u>28.5 x hp x (168 -) x</u>			BASIC FUNCTIONS
Duty Cycling	Aux: 5.17 x hp x hr			
Demand Limit	KW: 0.149 x hp			r
Optimum Start/Stop	WU Aux: .0852 x hp x((hr x 232) - hr)x days/wk CD Aux: <u>11.3 x</u> hp x (hr75) x days/wk			
OA Limit	Aux: 0.597 x hp x (273 + 204)			
Run Time	Labor: 2 Manhours			
HW OA Reset	Htg: 538 hr/yr x x Btu/hr/(x)			
Boiler Opt.	Htg: 538 hr/yr x x Btu/hr/(x)			
Chiller Opt.	Clg: 733 hr/yr x /ton x T x 0.01			
CHW Reset	Clg: 733 hr/yr x /ton x T x /°F x 2°F			
Cond. Reset	Clg: 733 hr/yr x /ton x T x ()			
Chiller Demand	Kw: 0.0414 x hp			
Safety Alarms	Labor: 2 Manhours			
-	TOTALS FOR SYSTEM			

BUILDIRG NOSYSTEM NOSYSTEM TYPE		SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS			
SAVINGS <	BU	SYSTEM NO.			
NH SAVINGS CALCULATIONS KW KM KM KM MM 0 V:E8:26X Btu/ft ² hr*Px $fr^{2}x(168 -)$ x					
$ \begin{array}{c} Clg: 0050/x Btu/ft^{2} hr^{e}F x ft^{2}x(166 -) x / (x / 10) \\ Wet: 246x Btu/ft^{2} hr^{e}F x ft^{2}x(168 -) x / (x / 10) \\ Wet: 24.5x fto x / 168 -) x / (x / 10) \\ Aux: 28.5x fto y x (168 -) x / (x / 10) \\ Aux: 28.5x fto y x (168 -) x / (x / 10) \\ Aux: 24.5x fto y x (168 -) x / (x / 10) \\ Aux: 24.5x fto y x (168 -) x / (x / 10) \\ WV Aux: 24.5x fto y x (168 -) x / (x / 10) \\ MV Aux: 24.5x fto y x (168 -) x / (x / 10) \\ Aux: 0.149 x (1.1.3 x hp x (1 - 1.25x dy/wk)) x / (4yw) \\ Aux: 0.132 x hp x (1 - 1.25x dy/wk)) x / (10) \\ Aux: 0.301 x / (1 - 1.25x dy/wk)) x / (10) \\ Huber: 2 Hanhours \\ MV Vetg: 2512 x C fm x / ((-1.25x dy/wk)) x / (10) \\ Heg: 22.5x fto y wh(ft^{2}hr^{2}F x (128 -) / (x / 10) \\ Heg: 2002 x hr/wk x C fm x / (168 -) / (x / 10) \\ Heg: 2003 x hr/wk x C fm x / (23.4x - F x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 7 + 20.4x) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 7 + 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 7 + 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 7 + 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/wk x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg: 1003 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg = 1000 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg = 1000 x hr/w x C fm x / (23.4x - 10) / (1 x / 10) \\ Heg = 1000 x hr/w x C fm x / (23.4x - 10) / (1 x / $	FUNCTION		\rightarrow	Ð	COST
Ing Aux: 5.17 x hp hr ait KW: 0.149 x hp x hp wU Aux: 0.852 hp x hr hp x days/wk wU Aux: 0.149 x hp x hr hr days/wk wU Aux: 0.597 x hp x 213 + 204) Aux: 0.591 x days/wk ays/wk ays/wk m/ WU V-htg: 551.2 x days/wk i m/ WU V-htg: 551.2 x dy/wk))/(x i i m/ WU V-htg: 6.09.1 x i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i i	Scheduled Start/Stop	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$			BASIC
Ht KW: 0.149 x hp x hp x hp x days/w NU Mux:: .0852.x hp x hp x hr - 75) x days/w NU WU Mux:: .0852.x hp x (hr - 75) x days/w NU WU Mux:: .0852.x hp x (hr - .75) x days/w Nu WU Verte: .0132 monures .204) Nn WU Verte: .212 x <	Duty Cycling	x dy x			
WU Aux: .0852 x hp x ((hr75) x) days/wk OCD Aux: JL.3 x hp x ((273 + .75) x) days/wk Aux: 0.592 x hp x (.273 + .204) days/wk Aux: 0.591 x by x (.273 + .204) days/wk Iabor: 2 Manhours x (253 dy/wk))/(x x (255 dy/wk))/(x N/ WU V-htg: .5512 x cfm x x((-(.25x dy/wk))/(x)/(x N/ WU V-htg: .5512 x cfm x x x((-(.25x dy/wk))/(x)/(x)/(x N/ WU V-htg: .5512 x cfm x x x((-(.25x dy/wk))/(x)/(x)/(x)/(x)/(x)/(x)/(x)/(Demand Limit	0.149 x			
Aux: 0.597 x hp x (273 + 204) Labor: 2 Manhours Labor: 2 Manhours nn/ WU V-htg: 5512 x cfm x x ((255 dy/wk))) x / (x / tr) void V-cig: 0301 x cfm x x (((.255 dy/wk))) (x / tr) viton V-cig: 0301 x cfm x x (((.255 dy/wk))) (x / tr) viton V-cig: 0301 x cfm x x (((.255 dy/wk))) (x / tr) viton V-cig: 0301 x cfm x x (((.255 dy/wk))) (x / tr) viton V-cig: 0301 x cfm x x / (((.255 dy/wk))) (x / tr) viton V-cig: 00195x Btu/ft2hr°Fx ft2x - v F x (168 -) (x / tr) vitos: 28.6 x ht/wk x cfm x - v f ft2x - v F x (168 -) (/ tr) vitos: 28.6 x ht/wk x cfm x - v ft2x - v F x (168 -) (/ tr) vitos: 28.6 x ht/wk x cfm x - v ft2x - v F x (168 -) (/ tr) vitos: 28.6 x ht/s ft2x - v F x (168 -) (/ tr) vitos: 28.6 x ht/s ft2x - v F x (168 -) (/ tr) vitos: 28.6 x vitos - v C m x - v F x - (168 -) / (/ tr) vitos: 28.6 x vitos - v C m x - v 2 v 2 v 2 v 2 v 2 v 2 v 2 v 2 v 2 v	Opt imum Start/Stop	hp x ((hr x 232)hr)x hp x (hr75) xdays/wk			
Labor: 2 Manhours nn/ WU V-htg: 5512 x cfm x x((25)/(x / t / t / t / t / t / t / t / t / t /	OA Limit	x hp x (+			
n/ WU V-htg: 5512 x cfm x x (25)/(x :10n V-clg: 0301 x cfm x x(25)/(x iton V-clg: 0301 x cfm x x(-(.25x dy/wk))/(x iton V-htg: 679 x cfm x x(-(.25x dy/wk))/(x // r (Computer s1mulation required.) r -(.25x dy/wk))/(x // r (Computer s1mulation required.) r r r r r r (Computer s1mulation required.) r r r r r r r (Computer s1mulation required.) r r r r r r r (Computer s1mulation required.) r r r r r r r (Computer s1mulation required.) r r r r r r r (Computer s1mulation required.) r r r r r r r (Clg: 28.6 fr/context r r r r r	Run Time	~			
 (Computer simulation required.) C1g:.00195x Btu/ft²hr^oFx ft²x ^oF x (168 -) x //(x // x // tgs: 28.6 x hr/wk x cfm x ^oF x (168 -)/(x // x // x // tgs: 56.16 x hr/wk x cfm x ^oF x (168 -)/(x // tgs // tgs: 56.16 x hr/wk x cfm x ^oF x // tgs // tgs	Ventilation/ Recirculation	<u>5512 x cfm x x (25)/(x)</u> 01 x cfm x x((-(.25x dy/wk)) x // // // // // // // // // // x // //			
C1g:.00195x Btu/ft ² hr°Fx ft ² x °F x (168 -) x) x / Htg:: 28.6 x Btu/ft ² hr°Fx ft ² x °F x (168 -))/(x) I C1g:.00526 x hr/wk x cfm x °F x /ton I C1g:.00526 x hr/wk x cfm x °F x /ton I Htg:: 56.16x hr/wk x cfm x °F x /ton I Htg:: 0526 x hr/wk x cfm x °F x /ton I Htg:: 1.08x hr/wk x cfm x x(23.4x +28.6x)/(x Itums Labor: 2 Manhours ToTALS FOR SYSTEM TOTALS FOR SYSTEM	Economizer				
011 Clg: <u>00526</u> x hr/wk x cfm x °F x /ton Htg: <u>56.16</u> x hr/wk x cfm x °F x 'F/(x Clg: <u>00526</u> x hr/wk x cfm x x °F x 'F/(x Htg: <u>1.08</u> x hr/wk x cfm x x(<u>23.4</u> x + <u>28.6</u> x)/(larws Labor: 2 Manhours TOTALS FOR SYSTEM	Day/N1ght Setback	<u>00195</u> x Btu/ft ² hr ^o Fx ft ² x ^o F x (168 -) x ⁻ / x			
clg: .00526. x hr/wk x cfm x x °F x // et Htg: L_08x hr/wk x cfm x x(23,4x +28,6x)/(larms Labor: 2 Manhours ToTALS FOR SYSTEM	ا س ا	00526 × hr/wk × cfm × °F × 56.16× hr/wk × cfm × °F/(×			
Alarus Labor: 2 TOTALS FOR	Hot/Cold Deck Reset	<u>.00526 x hr/wk x cfm x x °F x 'I / 1.08x hr/wk x cfm x x(23.4x +28.6x)/(</u>			
TOTALS FOR SYSTEM		~			
		TOTALS FOR SYSTEM		-	

E

The usual procedure would be to step through the analysis building by building; first, deriving the building specific factors and then proceeding through the system savings for that building. However, for ease of reference to the sample calculations, all of the Building-specific Factors sheets are grouped together after the Field Survey Data. Then, the System Savings Calculations and Costs sheets follow, by system type, in the same order as in the <u>EMCS Design Manual</u>, TM5-815-2/AFM 88-36/NAVFAC DM-4.9.

BUILDING DESCRIPTION DATA

BUILDING NUMBER:
BUILDING DESCRIPTION: Public Works
BUILDING DESCRIPTION:
GROSS AREA (SQUARE FEET): 14,000 (140' x 100')
NUMBER OF FLOORS:
TYPE CONSTRUCTION: Brick exterior, plaster interior, no insulation;
Built-up flat roof with acoustic tile and
ceiling space; 30% windows (double hung wood)
APPROX. FLOOR TO FLOOR HEIGHT (FT): 12'
GLASS TYPE: <u>Single pane, clear</u>
CRITICAL AREAS: None
OCCUPANCY SCHEDULE: 730 to 1630 M-F for the entire
building

SYSTEM DESCRIPTION DATA SYS # / TYPE Electric Unit Heater MFGR. MOD. # CAPACITY HP (TYPE) <u>4 hp fan (cycles</u>) HP (TYPE)_____ HP (TYPE) AREA SERVED <u>Storage room 102</u> CONTROLS Thermostat control only (60°F); no night shutdown or setback NOTES: <u>no OA</u> SYS # <u>3</u> TYPE Multizone DX-A/C___ MFGR. MOD. #_____ CAPACITY <u>B,000 cfm (8% 0A)</u> HP (TYPE) 5 hp supply fan HP (TYPE) 2 hp return fan

HP (TYPE) <u>2 hp return fan</u> HP (TYPE) AREA SERVED <u>5. end (7000 H²)</u> CONTROLS <u>Tork 7-day fimeclock</u>; <u>locked</u>; weekdays 4:00 to 16:30; <u>pneumatic damper actuators</u> NOTES: <u>Electric heating coil</u>; <u>DX coil supplied by Trane</u> <u>Compressor (Sys.#4)</u>

BUILDING NUMBER /00 SYS # 2 TYPE <u>Electric Radiation</u> MFGR. MOD. # CAPACITY 20 radiators at 500 Weach HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED Perimeter of South end CONTROLS Thermostat control only (68°F); no night shutdown or setback NOTES: OK, to setback at night

sys # _____4 TYPE Water Cooled DX Compressor MFGR. MOD. # TRANE RWOA DZO-FCOMP. CAPACITY 20 TON (BAC FXT-19 C.T.) нр (туре) <u>1/2 ир ритр</u> HP (TYPE) 1 hp fan (cycles) HP (TYPE) <u>20 hp compressor</u> AREA SERVED 545. # 3 multizone AHU CONTROLS No time clock

NOTES: <u>Reciprocal compressor (single</u> stage)

SYSTEM DESCRIPTION DATA
SYS # <u>5</u>
TYPE Direct fired boiler
MFGR. MOD. #
CAPACITY 7000 cfm (5% 0A)
HP (TYPE) <u>5 hp supply fan</u>
HP (TYPE)
HP (TYPE)
AREA SERVED <u>No. end</u> (6700 ft ²)
CONTROLS Thermostat is setback to
55°F at night. Small OA through wall
ducted down hall; no damper control.
NOTES: Area. cooled by window units.
Fucled by natural gas.
5 0

C

T

BUILDING NUMBER 100
SYS #
ТҮРЕ
MFGR. MOD. #
CAPACITY
HP (TYPE)
HP (TYPE)
HP (TYPE)
AREA SERVED
CONTROLS
NOTES:

SYS #	5125 #
TYPE	
MFGR. MOD. #	MFGR. MOD. #_
CAPACITY	
HP (TYPE)	HP (TYPE)
HP (TYPE)	
HP (TYPE)	
AREA SERVED	AREA SERVED
CONTROLS	CONTROLS
NOTES:	NOTES:
NOTES:	

515 #
ТУРЕ
MFGR. MOD. #
CAPACITY
HP (TYPE)
HP (TYPE)
HP (TYPE)
AREA SERVED
CONTROLS
······
NOTES:

BUILDING DESCRIPTION DATA

BUILDING NUMBER: ________

BUILDING DESCRIPTION: Base Personnel

GROSS AREA (SQUARE FEET): 12,000 (40' × 100')

NUMBER OF FLOORS: 2 plus basement

TYPE CONSTRUCTION: Walls: 1" Stucco, 4" L.W. Conc. block, 1" Ins.,

3/4" plaster; Roof: 1/2" slag, 3/8" membrane, 1" Ens.,

2" H.W. Conc., Plenum, ceiling file; 25% windows

DX air handler.

occupancy schedule: 7:30 to 16:30 weekdays

BUILDING NUMBER 200 SYSTEM DESCRIPTION DATA SYS # / SYS # _2____ TYPE Heating and Ventilating Unit TYPE <u>HTHW/Steam Converter</u> MFGR. MOD. #_____ MFGR. MOD. #_____ CAPACITY 60,000 Btu/hr CAPACITY HP (TYPE) 1/2 hp supply fan____ HP (TYPE)_____ HP (TYPE) 1/2 hp exhaust fan HP (TYPE)_____ HP (TYPE) (400 H²) AREA SERVED 1st & 2nd floor restrooms HP (TYPE) AREA SERVED <u>Sys. # 2, 3, 5</u> CONTROLS No on/off control at present. CONTROLS no DA damper control, damper opens when fans run NOTES: Steam coil served from Sys. #1 NOTES: HTHW from Boiler in heating plant About 15% OA SYS # 4 sys # 3 TYPE Single Zone DX-A/C TYPE Air Cooled DK Compressor MFGR. MOD. # MFGR. MOD. # CAPACITY 400 cfm (8%0A) CAPACITY_____ HP (TYPE) 1/2 hp supply fan HP (TYPE) 2 hp compressor HP (TYPE) 4 hp cond. fan HP (TYPE)_____ HP (TYPE)_____ HP (TYPE)_____ AREA SERVED <u>Computer Room</u> (260 H2) area served Sys. # 3 AHU CONTROLS no damper control CONTROLS NOTES: Constant setpoint of NOTES: <u>Reciproca</u> compressor 65°F required. DX coil served by Sys. # 4; usual occupancy

SYSTEM DESCRIPTION DATA BUILDING NUMBER 200 sys # <u>5</u>_____ sys # ____6____ TYPE <u>Multizone Air Handler</u> TYPE Domestic HW- Gas MFGR. MOD. #_____ CAPACITY <u>4' high, 1/2' diameter, 1/2"ins</u>. MFGR. MOD. #_____ CAPACITY <u>8000 cfm (~10% 0A)</u> HP (TYPE) <u>5 hp Supply fan</u> HP (TYPE)_____ HP (TYPE) / hp return fan HP (TYPE)_____ HP (TYPE)_____ HP (TYPE) AREA SERVED Restrooms (normal occupancy) AREA SERVED 7340 ft^2 CONTROLS preumatic damper 5; CONTROLS 130° F setpoint; Runs 60% cold deck air, 40% hot continuously deck air; not turned off at present. NOTES: Located in basement furnace NOTES: Steam heat from bldg. room (~70°F) converter; CHW from Bldg. 300 chiller sys # 7 SYS # _____ TYPE Direct fired furnace ТҮРЕ _____ MFGR. MOD. #_____ MFGR. MOD. # CAPACITY ~ 4000 cfm (~ 20% 0A) CAPACITY HP (TYPE) 21/2 hp supply fan HP (TYPE)_____ HP (TYPE)_____ HP (TYPE)_____ HP (TYPE)_____ HP (TYPE) AREA SERVED Basement (4000 ft2) AREA SERVED_____ CONTROLS No damper control; CONTROLS no shut down NOTES: Basement offices cooled NOTES:_____ with window units; gas-fired

BUILDING DESCRIPTION DATA

C

2.

BUILDING NUMBER: 300
BUILDING DESCRIPTION: Base Headquarters
GROSS AREA (SQUARE FEET): $10,200$ ft^2 $50'$ $30'$
NUMBER OF FLOORS: 2
TYPE CONSTRUCTION: Wall: 4" common brick, 1" insulation, 4" conc.
block; 20% windows; Roof: built-up with
gravel, 2" ins., steel decking, acoustic tile
APPROX. FLOOR TO FLOOR HEIGHT (FT): 12'
GLASS TYPE: Single pane, clear; Casement windows
CRITICAL AREAS:
occupancy schedule: 730 to 1630, weekdays, most of bldg.;
24 hr, 7-day occupancy in security
office; 530 to 1500, weekdays in
Kitchen and snack bar

SYSTEM DESCRIPTION DATA SYS # _____ TYPE HTHW/ HW Converter MFGR. MOD. #_____ CAPACITY <u>350,000 Btv/hv</u> нр (туре) <u>2 hp pump</u> HP (TYPE)_____ HP (TYPE) AREA SERVED <u>Sqs. # 3,4,5</u> CONTROLS NOTES: HTHW from heating plant

SYS # <u>3</u> TYPE <u>Single Zone Air Handler</u> MFGR. MOD. # CAPACITY <u>5000 cfm (50% 0A)</u> HP (TYPE) <u>2½ hp Supply fan</u> HP (TYPE) <u>3/4 hp each of</u> HP (TYPE) <u>3/4 hp each of</u> HP (TYPE) <u>2 ethaust fans</u> MFGR. MOD. # (3000 H²) AREA SERVED <u>Snack bar & Kitchen</u> CONTROLS <u>Aamper actuators exist</u> <u>but presently no operable;</u> <u>turned on & off manually</u> NOTES: <u>CHW coil from Sys # 2</u> <u>Chiller; HW coil from Sys # 1;</u> OA aucted through window

BUILDING NUMBER 300 sys # <u>2</u> TYPE Water Cooled Chiller MFGR. MOD. # CAPACITY 50 tons HP (TYPE) 60 hp compressor HP (TYPE) 5 hp CHW pump. I hp cond. pump HP (TYPE) 3/4 hp fan (cycles) AREA SERVED Sys # 3,4 CONTROLS Has 3-way CHW value, has capability of vane control; no shut down at present NOTES: Small centrifugal; Condenser water temperature fixed at 85°F

sys # <u>4</u> TYPE Two Pipe Fan Coil Units (45) MFGR. MOD. # CAPACITY HP (TYPE) 1/4 hp fan (each) HP (TYPE) <u>4 hp pump each of</u> HP (TYPE) <u>4 zones</u> AREA SERVED 6950 f4² CONTROLS Some manual shutdown at present; summer/winter value manual changeover based on OA temp. NOTES: One unit serves security office (150 ft2); CHW from Sys #2; HW from Sus. #1; 24 hr AC unnecessary

BUILDING NUMBER 300 SYSTEM DESCRIPTION DATA sys # 5 sys # 6 TYPE Hot Water Unit Heater TYPE Domestic HW- Electric MFGR. MOD. #_____ CAPACITY_6'ht., 2'diam., 2"ins.___ MFGR. MOD. #_____ CAPACITY HP (TYPE) 1/3 hp fan (cycles) HP (TYPE) 2 KW heating coil HP (TYPE)_____ HP (TYPE) HP (TYPE) HP (TYPE)_____ AREA SERVED <u>Storeroom</u> (250 ft²) AREA SERVED CONTROLS On a timeclock. 400 to 1600 CONTROLS daily; 140°F setpoint; serves snack bar and testrooms NOTES: Hew from Sys # 1, NOTES: <u>average surroundings - 75°</u>F Can setback at night to 50°F from 65°F SYS #_____ SYS # TYPE ТҮРЕ _____ MFGR. MOD. #_____ MFGR. MOD. # CAPACITY CAPACITY HP (TYPE) HP (TYPE) _____ HP (TYPE)_____ HP (TYPE)_____ HP (TYPE) HP (TYPE) AREA SERVED AREA SERVED CONTROLS CONTROLS NOTES: NOTES:

BUILDING DESCRIPTION DATA

BUILDING NUMBER 400 SYSTEM DESCRIPTION DATA sys # <u>2</u>____ SYS # / TYPE Steam Unit Heaters (4) TYPE Steam Radiation MFGR. MOD. #_____ MFGR. MOD. #_____ САРАСІТУ _____ CAPACITY_____ HP (TYPE) 1/4 hp fans (cach) HP (TYPE)_____ HP (TYPE) Cycle HP (TYPE)_____ HP (TYPE)_____ HP (TYPE) area served 3000 ft² AREA SERVED Office - 200 ft² CONTRULS Can be setback from CONTROLS May be setback from 65° F to 55° F at night 65°F to 50°F at might NOTES: Steam from Seys. # 3 NOTES: Steam from Sys. #3 sys # <u>3</u>_____ SYS # TYPE Steam boiler TYPE MFGR. MOD. # MFGR. MOD. #_____ CAPACITY 225,000 Btu/hr CAPACITY_____ HP (T'LPE)_____ HP (TYPE)_____ HP (TYPE)_____ HP (TYPE)_____ HP (TYPE)_____ HP (TYPE) AREA SERVED Sus. # 1,2 AREA SERVED CONTROLS CONTROLS NOTES: Fueled by natural NOTES: gas 86.

BUILDING DESCRIPTION DATA

0

BUILDING NUMBER: 500
BUILDING DESCRIPTION: <u>Administration Building</u>
GROSS AREA (SQUARE FEET): 13,500 ft ² (30' x 150')
NUMBER OF FLOORS: 3
TYPE CONSTRUCTION: Wall: 4" common brick, 1" insulation, 4" conc.
block; 20% windows; Roof: built-up with
gravel, 2"ins., steel decking, acoustic tile
APPROX. FLOOR TO FLOOR HEIGHT (FT): 12'
GLASS TYPE: Single pane, clear; sliding, aluminium frame
CRITICAL AREAS:
occupancy schedule: 730 to 1630, week days for majority
of building; Frequent weekend occupancy
on first floor

SYSTEM DESCRIPTION DATA SYS # ____/ TYPE <u>Steam/HW Converter</u> MFGR. MOD. #_____ CAPACITY HP (TYPE) 1/2 hp pump HP (TYPE)_____ HP (TYPE) AREA SERVED 1st floor fan coils CONTROLS No shutdown at present except for seasonal shutdown NOTES: Steam from Bldg. 400 -Sys. # 3 boiler

BUILDING NUMBER 500 sys # 2 TYPE Air Cooled Chiller MFGR. MOD. # CAPACITY <u>35</u> ton HP (TYPE) 20 hp (each of 2) comp. HP (TYPE) 5 hp CHW pump HP (TYPE)______ AREA SERVED <u>SqS. # 3, 4, 5</u>____ CONTROLS NOTES: 2 reciprocal compressors sys # 4 TYPE Variable Air Volume AHU MFGR. MOD. #_____ CAPACITY 4000 cfm max (10% 0A) HP (TYPE) 3 hp supply tan HP (TYPE) HP (TYPE)

TYPE <u>Terminal Reheat AHU</u> MFGR. MOD. #_____ CAPACITY <u>3500 cfm (15%0A)</u> HP (TYPE) <u>2½ hp Supply fan</u> HP (TYPE) HP (TYPE) HP (TYPE) AREA SERVED <u>2nd floor - South</u> CONTROLS <u>Existing timeclock</u>, <u>pins have been pulled</u>; <u>pnermatic damper actuators</u> NOTES: <u>HTHW from heating</u> <u>plant</u>; CHW from Sys #2

SYS # 3

AREA SERVED <u>3rd floor (4500 fl²)</u> CONTROLS <u>EXISTING time clock</u>, set <u>approx.</u> 430 to 1600 weekdays. NOTES: <u>HTHW from heabing plant</u>; <u>CHW from Sys.</u> # 2

BUILDING NUMBER 500 SYSTEM DESCRIPTION DATA sys # 6 sys # <u>5</u> TYPE Four Pipe Fan Coil Units (15) TYPE Hot Water Radiation MFGR. MOD. #_____ MFGR. MOD. # CAPACITY 10 radiators @ 2500 Bh/hr CAPACITY HP (TYPE) 4 hp fan (each) HP (TYPE) <u>1/2 hp pump</u> HP (TYPE)_____ HP (TYPE)_____ HP (TYPE) HP (TYPE) AREA SERVED 2nd floor - north (1500 ft²) AREA SERVED First floor (4500 ft2) CONTROLS Manual shut down but CONTROLS 3-way bypass value from heating plant Hu loop not very diligent; control value for htg. & clg. coils at each unit NOTES: Area cooled by window units, NOTES: HW from Sys. #1, HTHW from heating plant CHW from Sys. # 2; no OA SYS # _____ SYS #_____ TYPE ТҮРЕ_____ MFGR. MOD. #_____ MFGR. MOD. #_____ CAPACITY_____ CAPACITY HP (TYPE) HP (TYPE) HP (TYPE)_____ HP (TYPE) HP (TYPE)_____ HP (TYPE)_____ AREA SERVED_____ AREA SERVED_____ CONTROLS CONTROLS NOTES:_____ NOTES:_____ 89.

BUILDING DESCRIPTION DATA

C


C


BUILDING NUMBER	:600
BUILDING DESCRI	PTION: <u>Heating Plant</u>
CDOSS ADEA (SOU	ARE FEET):
GRUSS AREA (SQU	ARE FEET):
NUMBER OF FLOOR	S:
TYPE CONSTRUCTI	ON: Concrete block construction
	<u></u>
APPROX. FLOOR 1	O FLOOR HEIGHT (FT):
GLASS TYPE:	
CRITICAL AREAS:	
	21 - hr accupied by at least ane
OCCUPANCY SCHEI	DULE: <u>24-hr occupied by at least one</u>
	boiler operator

SYSTE	EM DESCRIPTION DATA
SYS #	<u> </u>
TYPE	Hot Water Boilers (3)
MFGR.	MOD. #
CAPAC	MOD. # CITY <u>150,000 Btu/hr (each</u>)
	YPE)
HP (T	YPE)
HP (1	200 - 2,3,5; 300 - 3,4,5; SERVED 500 - 3, 4, 6
AREA	200 - 2,3,5; 300-3,4,5; SERVED <u>500 - 3,4,6</u>
CONTR	ROLS
<u> </u>	
NOTES	: High temperature hot
wak	: <u>High temperature hot</u> r; fueled by Distillate oil
fuel	'oil
1	_ <u></u>
SYS #	۶
TYPE	
MFGR.	MOD. #
	CITY
	YPE)
	YPE)
	SERVED
	ROLS
<u></u>	
NOTES	5:

7

h,





• • • •

Ì

۰.

ŧ.

MICROCOPY RESOLUTION TEST CHART NATIONAL BUREAU OF STANDARDS-1963-A

فجوريا

BUILDING-SPECIFIC FACTORS

BUILDING:	100		

* BTT = Building Thermal Transmission

- = (U-factor X exterior area) + (Infiltration X 1.08)/Total Floor Area
- = $(.172 \text{ Btu/hr}^{\circ}\text{F-ft}^{2}\text{X}_{19}, 760 \text{ft}^{2}) + (.912 \text{ cfm X } 1.08)/14000 \text{ ft}^{2}$
- = .3/3 Btu/hr°F-ft²

ERT = Annual Run Time of Equipment for Morning Warmup

Heating Degree Days = 4570 °F-days

Combined U-factor, Uo = .172 Btu/hr°F-ft²

From Figure	9 or 10 :	ert = <u>238</u>	hr/yr
-------------	-----------	------------------	-------

Primary Sources of Cooling Medium

Sys. No	System Type	Systems Served	CPT
_4	DX RECIP. COMP (20T)	3	1.2 KW/TON
mary Source	of Heating Medium		

Primary Sources of Heating Medium

Sys. No	System Type	Systems Served	HEFF	HV
5	DIRECT FIRED BOILER	5	.63	<u>1031 Błu/cf</u>
	ELECTRIC HEAT	1, 2, 3	1.0	<u>3413 Btu/K</u> wh
				<u></u>

served The second management

* Data not necessary if computer method is used.

00 00 00 00 00 00 00 00 00 00 00 00 00			
	J-factors: <u>R(ft²</u>	ft ² hr°F/Btu)	Calculation of infiltration:
	Outside surface	0.17	Valls:
	8" brick	1.59	(0.3 cfh/ft ²)(.70)(5760 ft ²)/(60 min/hr)
5760 ft ²) Air	Air space	0.91	
3/4	3/4" plaster	0.149	
Ins	Inside surface	0.685	
		3.504	Windows:
			<u>(.30)(5760 ft²)(21 ft/window)(.4 cfm/ft)</u>
	Outside surface	0.17	18 ft ⁻ /window
(30%) Sin	Single pane glass	0.88	= 806 cfm
Ins	Inside surface	0.685	
		1.735	
Roof: Out	Outside surface	0.17	Doors:
(14,000 ft ²) 1/2" slag	" slag	0.050	Assume 6 average size doors
3/8	3/8" membrane	0.285	(6 doors)(18 ft/door)(0.8 cfm/ft)
2"	2" insulation	6.68	
1" V	1" wood	1.19	
cei.	ceiling space	1.0	
acoi	acoustic tile	1.786	I = 20 + 806 + 86
		11.161	= 912 cfm
Uo = (0.70)(576((3.504)(19,	$\frac{(0.70)(5760)}{(3.504)(19,760)} + \frac{(0.30)(5760)}{(1.735)(19,760)}$	+ (11.	<u>14,000</u> 161)(19,760)
= 0.172 Btu/ft ² hr°F	ft ² hr°F		

, **.** .

BUILDING-SPECIFIC FACTORS

200 BUILDING:

* BTT = Building Thermal Transmission

- = (U-factor X exterior area) + (Infiltration X 1.08)/Total Floor Area
- = (<u>./80</u> Btu/hr°F-ft²X/0/60 ft²) + (<u>/57</u> cfm X 1.08)//2,000 ft² = <u>./66</u> Btu/hr°F-ft²

ERT = Annual Run Time of Equipment for Morning Warmup

Heating Degree Days = 4570 °F-days Combined U-factor, Uo = 80 Btu/hr°F-ft² From Figure 9 or 10 : ERT = 245 hr/yr

Primary Sources of Cooling Medium

Sys. No	System Type	Systems Served	CPT
_4	AIR COOLED DX COMP	3	1.49 KW/TON
<u>BLDG 300-</u> 2	WATER COOLED CHILLER	5	<u>.94 kw/ton</u>

Primary Sources of Heating Medium

Sys. No	System Type	Systems Served	HEFF	HV
	HTHN/STEAM CONVER	TER 2, 3, 5	.53 **	<u>138,700 Btv/</u> Gal.
_7	DIRECT FIRED FURN	ACE7	.65	1031 Btv/cf
			<u></u>	

* Data not necessary if computer method is used.

* * INCLUDES DISTRIBUTION LOSSES OF PIPES GOING TO AHU'S.

Calculation	<u>Building 200</u> Calculation of N-factors.		
		R(ft ² hr°F/Btu)	CALCULATION OF INFILTRATION:
Walls: Ou	Outside surface	0.17	.s[[E3]
	1" stucco	0.208	(0.24 cfh/f+ ²)(.75)(6160 f+ ²)/(60 min/hr)
6160 ft ²) 4"	4" L.W. conc. block	1.51	
1"	1" insulation	3.32	
3/	3/4" plaster	0.149	Windows:
II	Inside surface	0.685	(.25)(6160 ft ²)(16 ft/window)(3 cfh/ft)
		6.042	(15 ft ² /window)(60 min/hr)
			= 82 cfm
Windows: Ou	Outside surface	0.17	
(25 %) Th	Thermopane window	2.08	Doors:
II	Inside surface	0.685	(4 doors)(18 ft/door)(0.8 cfm/ft)
		2.935	= 57 cfm
Roof: Ou	Outside surface	0.17	
(4000 ft ²) 1	ft ²) 1/2"slag	0.050	I = 18 + 82 + 57
3/	3/8" membrane	0.285	= 157 cfm
1"	insulation	3.32	
2"	2" H.W. Concrete	0.168	
Ple	Plenum	1.0	
Ü	Ceiling tile	1.786	
In	Inside surface	0.685	
		7.463	

95.

۰. .

BUILDING-SPECIFIC FACTORS

BUILDING:	300
-----------	-----

* BTT = Building Thermal Transmission

- = (U-factor X exterior area) + (Infiltration X 1.08)/Total Floor Area

ERT = Annual Run Time of Equipment for Morning Warmup

Heating Degree Days = 4570 °F-days Combined U-factor, Uo = ./87 Btu/hr°F-ft² From Figure 9 or 10 : ERT = 250 hr/yr

Primary Sources of Cooling Medium

Sys. No	System Type	Systems Served	CPT	
2	WATER COOLED CHILLER	3,4	0.94 Kw/	TON
		•		
		<u> </u>		
Primary Source	es of Heating Medium			
Sys. No	System Type	Systems Served	HEFF	HV
	<u>HTHW/HW CONVERTER</u>	3,4,5	.53**	138,700 Bt Ga

* Data not necessary if computer method is used.

** INCLUDES DISTRIBUTION LOSSES FROM PIPES GOING TO AHU'S.

R(ft^2hr^pF/Btu)Walls:Walls:Outside surface0.17(0.24)(total = Brick (4")0.79= 27(total = Brick (4")0.79= 278640 ft^2)1" insulation3.32Window $4"$ conc. block1.51Window $3/4"$ gypsum board0.149(.20) $74"$ gypsum board0.149(.20) $74"$ gypsum board0.149(.20) $74"$ gypsum board0.1349(.20) $74"$ gypsum board0.1349(.20) $74"$ gypsum board0.177(.20) $74"$ gypsum board0.285(.4 doc $74"$ gypsum board0.177(.5100 ft²) $74"$ gypsum board0.285(.4 doc $74"$	Calculation of infiltration:
(total = Brick (4") 0.79 $= 27$ 8640 ft ²)1" insulation 3.32 Window $4"$ conc. block 1.51 $window$ $3/4"$ gypsum board 0.149 $(.20)($ $3/4"$ gypsum board 0.149 $(.20)($ $3/4"$ gypsum board 0.149 $(.20)($ $1nside surface0.17(.20)(mindows:0.1860.685(.20)(1nside surface0.17(.20)((20\%)single pane glass0.88Doors:notside surface0.17(.20\%)(.4 doors:(20\%)single surface0.17(.5100 \text{ ft}^2)1/2" \text{ slag}(.5100 \text{ ft}^2)1/2" \text{ slag}0.050(.285)= 578cof:0utside surface0.17(.205)= 578cof:0utside surface0.17(.205)= 578cof:0utside surface0.17(.205)= 578cof:0utside surface0.050(.4 doorsi)2" insulation6.641.7861 = 571rside surface0.0500.008= 571rside surface0.0080.008= 571rside surface0.0081.786= 571rside surface0.0081.7861.786$	cfh/ft ²)(.80)(8640 ft ²)/(60 min/hr)
1" insulation3.324" conc. block1.513/4" gypsum board0.149Inside surface0.149Inside surface0.175.6240.685f.17350.88Inside surface0.171.7350.6851.7350.173/8" membrane0.173/8" membrane0.2852" insulation0.2852" insulation0.285Acoustic tile1.786Inside surface0.665	
4" conc. block1.513/4" gypsum board0.1491nside surface0.6855.6245.624Windows:0utside surface0.17(20%)Single pane glass0.881.735Inside surface0.17(20%)1/2" slag0.6851.7351.735Roof:Outside surface0.17(5100 ft²)1/2" slag0.2852" insulation6.642" insulation6.64Steel decking1.786Acoustic tile1.786Inside surface0.685	
3/4" gypsum board0.149Inside surface0.685Inside surface0.17%indows:Outside surface0.17(20%)Single pane glass0.88Inside surface0.17(20%)Inside surface0.17(20%)Single pane glass0.685Inside surface0.17(20%)J/8" membrane0.050800f:Outside surface0.17(5100 ft2)1/2" slag0.2853/8" membrane0.2852" insulation0.008Acoustic tile1.786Inside surface0.685Inside surface0.685	
Inside surface 0.685 $(20 \text{ ft}^2/\text{windo})$ Windows:Outside surface 0.17 $= 596 \text{ cfm}$ Windows:Outside surface 0.17 $= 596 \text{ cfm}$ Windows:Nutside surface 0.17 $= 596 \text{ cfm}$ (20%)Single pane glass 0.88 $Doors:$ Inside surface 0.17 $= 57 \text{ cfm}$ Roof:Outside surface 0.17 $= 560 \text{ cfm}$ Steel decking 0.060 $= 6.64$ $= 27 \pm 59$ Acoustic tile 1.786 $= 680 \text{ cfm}$ Inside surface 0.685 $= 680 \text{ cfm}$	(.20)(8640 ft ²)(23 ft/window)(.3 cfm/ft)
6.624= 596 cfmWindows: 0.13 0.17 0.088 0.0685 (20%)Single pane glass 0.88 $000rs:$ Inside surface 0.088 0.0685 $(4 \ doors)(18$ (20%)Single surface 0.17 $= 57 \ cfm$ Roof:Outside surface 0.050 $= 57 \ cfm$ Steel decking 0.050 0.285 $I = 27 \ + 59$ Steel decking 0.008 $= 680 \ cfm$ Acoustic tile 1.786 $I = 27 \ + 59$ Inside surface 0.685 $I = 27 \ + 59$	(mopu
Windows:Outside surface 0.17 Doors:(20%)Single pane glass 0.88 $Doors:$ Inside surface 0.685 1.735 $(4 \text{ doors})(18)$ Roof:Outside surface 0.17 $= 57 \text{ cfm}$ Roof:Outside surface 0.050 $= 57 \text{ cfm}$ Roof:I/2" slag 0.050 $= 57 \text{ cfm}$ Roof:Outside surface 0.17 $= 57 \text{ cfm}$ Roustic tile 1.786 $= 680 \text{ cfm}$ Inside surface 0.685 $= 680 \text{ cfm}$	
Single pane glass 0.88 Doors: Inside surface 0.685 (4 doors)(18 1.735 $(4 \text{ doors})(18)$ = 57 cfm Outside surface 0.17 $= 57 \text{ cfm}$ 3/8" membrane 0.285 $1/2" slag$ 0.050 0.285 $2" insulation$ 0.285 $1 = 27 + 592" insulation$ 0.285 $1 = 27 + 59Steel decking 0.008 1.786 I = 680 \text{ cfm}Acoustic tile 1.786 0.685$	
Inside surface 0.685 1.735 (4 doors)(18 1.735 $(4 doors)(18)= 57 cfmft^2) 1/2" slag0.0503/8"$ membrane $0.2852"$ insulation $0.2852"$ insulation $0.2851 = 27 + 595 teel decking$ $1.7861.786Inside surface 0.685$	
$ \begin{array}{llllllllllllllllllllllllllllllllllll$	
$ft^{2}) 1/2" slag 0.17$ $ft^{2}) 1/2" slag 0.17$ $3/8" membrane 0.17 0.285 3/8" membrane 0.285 0.285 2" insulation 6.64 1 = 27 + 52m 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.486 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.786 1.7$	18 ft/door)(0.8 cfm/ft)
$ft^{2}) 1/2" slag 0.17$ $ft^{2}) 1/2" slag 0.050$ $3/8" membrane 0.285$ $3/8" membrane 0.285$ $2" insulation 6.64 I = 27 + 52 + 1786$ Steel decking 1.786 = 680 c Inside surface 0.685	
<pre>ft²) 1/2" slag 0.050 3/8" membrane 0.285 2" insulation 6.64 I = 27 + 2" insulation 0.286 2" insulation 0.285 Acoustic tile 1.786 Inside surface 0.685</pre>	
0.285 6.64 I = 27 + .0008 = 680 c 1.786 0.685	
6.64 I = 27 + .0008 = 680 c 1.786 = 680 c	
.0008 = 680 1.786 e <u>0.685</u>	
Ø	cfm
9.617	

BUIL	DING-	SPECI	FIC	FACTORS

400 BUILDING:

* BTT = Building Thermal Transmission

- = (U-factor X exterior area) + (Infiltration X 1.08)/Total Floor Area
- = $(.239 \text{ Btu/hr}^{\circ}\text{F-ft}^{2}\text{X} . 8/60 \text{ ft}^{2}) + (.48 \text{ cfm X } 1.08)/.3200 \text{ ft}^{2}$
- = .625 Btu/hr°F-ft²

ERT = Annual Run Time of Equipment for Morning Warmup

Heating Degree Days =	4570	°F-days	5	
Combined U-factor, Uo =	.239	Btu/hi	°F-ft ²	
From Figure 9 or 10 :		ERT =	260	_ hr/yr

Primary Sources of Cooling Medium

Sys. No	System Type	Systems Served	CPT	
<u> </u>				
Primary Sources	of Heating Medium			
Sys. No	System Type	Systems Served	HEFF	<u>hv</u>

_3	STEAM BOILER		. <u>68(.61)</u> ** <u>1031 Bh/</u> cf
<u> </u>		······	

THE FREE CONTRACTOR STREET

* Data not necessary if computer method is used.

* * NUMBER IN PARENTHESES INCLUDES DISTRIBUTION LOSSES OF PIPING TO AHU'S

Calcuation of infiltration:	<pre>Walls and roof: (longest wall)(K)(Fo)(Q/AwKFo) = (1600 ft²) (1.0)(.75)(0.04 cfm/ft² = 48 cfm </pre>
<u>R(ft²hr°F/Btu)</u>	0.17 0.0002 3.32 0.0002 4.172 4.172 0.0002 0.0002 4.172 4.172
Building 400 Calculations of U-factors:	Walls: outside air (total = Metal panel 4800 ft ²) 1" insulation Metal panel Inside surface (3360 ft ²) Metal panel 1" insulation Metal panel Inside surface $Uo = \frac{1}{R} = \frac{1}{4.172}$ = 0.239 Btu/ft ² hr ^o F

.

Ī

BUILDING-S	PECIFIC	FACTORS
the second se		

500 BUILDING:

* BTT = Building Thermal Transmission

- = (U-factor X exterior area) + (Infiltration X 1.08)/Total Floor Area
- = $(.149 \text{ Btu/hr}^{\circ}\text{F-ft}^{2}X/7.460 \text{ ft}^{2}) + (.1133 \text{ cfm} X 1.08)/13.500 \text{ ft}^{2}$
- = <u>.283</u> Btu/hr°F-ft²

ERT = Annual Run Time of Equipment for Morning Warmup

Heating Degree Days = 4570 °F-days Combined U-factor, Uo = ./49 Btu/hr°F-ft² From Figure 9 or 10 : ERT = 220 hr/yr

Primary Sources of Cooling Medium

<u>Sys. No</u>	System Type	Systems Served	CPT
_2	AIR COOLED CHILLER	3,4,5	1.18 KW/TON
Primary Source	s of Heating Medium	<u> </u>	
Sys. No	System Type	Systems Served	<u>HEFF</u> <u>HV</u>
	STEAM/HW CONVERTER	5	<u>.55** 1031 Btu/cf</u>
BLOG 600-1	HTHW BOILERS (3)	_3,4,6	.65 (.58 *) 138, 700 Btv/Ga!

* Data not necessary if computer method is used.

** INCLUDES DISTRIBUTION LOSSES OF PIPING TO AHU'S.

Calculation	Calculation of U-factors:		Calculation of infiltration:
	R	R(ft ² hr°F/Btu)	
Walls:	Outside surface	0.17	
(total =	4" CCMMCX brich		
		0.433	(longest_wall)(K)(Fo)(Q/AwKFo) =
12,960ft ⁻)		1.11	(5400 ft ²)(0.66)(.75)(.04)
	1" insulation	9.96	= 107 cfm
	3/4" gypsum board	0.149	
	Inside surface	0.685	
		12.507	Windows:
Windows:	Outside surface	0.17	(.20)(12.960ft ²)(20 5 ft/window)(0 226m/64)
(20%)	Single pane glass	0.88	
	Inside surface		= 911 cfm
		1.735	
Roof:	Outside surface	0.17	Doors:
(4500 ft ²)	ft ²) 1/2" slag	0.050	(8 doors)/18 ft/3002/10 8 _ft/5t)
	3/8" membrane	0.285	10 20013/110 10/2001/010 CIM/IC) = 115 rfm
	2" insulation	13.28) † 1
	Steel decking	.0008	I = 107 + 911 + 115
	Ceiling tile	1.786	
		15.572	
$Uo = \frac{(.80)}{(12.)}$	$\frac{(.80)(12,960)}{(12.507)(17,460)} \frac{(0.20)(3}{(1.735)}$	$\frac{(0.20)(12,960)}{(1.735)(17,460)}^{+}$	(4500) (15.572)(17,460)
≈ 0.14	0.149 Btu/ft ² hr°F		

F

	SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS					
BUI	BUILDING NO. 300 SYSTEM NO. 3 SYSTEM TYPE SINGLE ZONE AIR HANDLER	HAND	LER ()		
GINCTION	SAUTACE CALCUS	11	SAVINGS	S		COCH
	×		201		E	BASIC
Scheduled	00 ft ² x(168 - 525) x.20/(.53 x138		1	83.3		
9(9 (1)9(0)	-		1563	510.3		
Duty Cycling	Aux: 5.12 xhp xhr					
Demand Limit	KW: 0.149 x 4 hp	e.				
Opt i nue Start/Stop	WU Aux: .0852 x 4 hp x ((2 hr x 232) - 250 hr)x 5 daya/wk CD Aux: 11.3 x 4 hp x (2 hr75) x 5 daya/wk		364			
OA Limit	Aux: 0.597 x hp x (225 + 164)					
Run Time	Lebor: 2 Manhours				え	
Ventilation/ Recirculation	WU V-htg: 5512 x 5000 cfm x .50 x (225)/(.53 x /38,200) V-c1g: 0301 x cfm x x((-(.25x dy/wk)) x /ton V-htg: 679 x cfm x x((-(.25x dy/wk))/(x)			328.0		
Economizer	(Computer simulation required.)		*			
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ^e Fx ft ² x ^e F x (168 -) x /ton Htg: <u>28.6</u> x <u>Btu/ft²hr^eFx ft²x ^eF x (168 -)/(x)</u>					-
Reheat Coll Reset	Clg:. <u>00526</u> x hr/wk x cfm x °F x /ton Htg: <u>56.16</u> x hr/wk x cfm x °F/(x)					
Hot/Cold Deck Reset	Clg: <u>.00526 x hr/wk x cfm x x °F x</u> Htg: <u>L.08x hr/wk x cfm x x(x + x </u>)					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	é.	4848	921.6	N	
	* Too small a system to be economically feasible.					

`.'· · · · .

نيه . ٠.

and a standard standard and

. . . • Contraction of the second s

	SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS					
BUI	BUILDING NO. 500 SYSTEM NO. 3 SYSTEM TYPE JERMINAL REHEMT		AHU (Z			
FUNCTION	SAVINGS CALCULATIONS	КW	SAVINGS KWH		Ŧ	COST
Scheduled	* x 3000 ft ² x(168 - 55) x.5 000 ft ² x(168 - 55) x.5/(<u> </u>	286	170.5	<u> </u>	BASIC
Start/Stop	$\frac{V-Clg: 0.301x 35200 cfm x x (168 - 35) x x x / f ton}{V-Htg: 679 x 35200 cfm x x (168 - 55) x x x (1 38.200) Aux: 28.5 x 2.5 hp x (168 - 55) x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x x$		1053 4025	250.3		
Duty Cycling	Aux: 5.17 x 2.5 hp x 45 hr		501			
Demand Limit	KW: 0.149 × Z.5 hp	. 3				
Opt imum Start/Stop	WU Aux: <u>0852 x 2.5</u> hp x ((<u>2</u> hr x <u>232</u>) - <u>220</u> hr)x <u>5</u> daya/wk CD Aux: 11.3 x 2.5 hp x (<u>2</u> hr75) x <u>5</u> daya/wk		260			
OA Limit		\uparrow	712			
Run Tise	Labor: 2 Manhours					
Ventilation/ Recirculation	WU V-htg: <u>5512</u> x <u>3500</u> cfm x <u>./5</u> x (<u>z</u> 25)/(<u>.58 x/38700</u>) V-clg: <u>0301</u> x cfm x <u>x((-(.25x dy/wk)) x /ton</u> V-htg: <u>679</u> x cfm x <u>x((-(.25x dy/wk))/(x)</u>)			62.9		
Economizer	(Computer simulation required.)		*			
Day/N1ght Setback	Clg:. <u>00195</u> x Btu/ft ² hr [•] Fx ft ² x [•] F x (168 -) x /ton Htg: <u>28.6</u> x Btu/ft ² hr [•] Fx <u>f</u> t ² x [•] F x (168 -)/(<u>x</u>)					
Reheat Coll Reset	Clg:. <u>00525 x 50 hr/wk x3500</u> cfm x 3 °F x <u>/./8 ku</u> /ton Htg: <u>56.16</u> x <u>50 hr/wk x 3500</u> cfm x <u>3 °F/(.58 x (38,700</u>)		3258	366.5		
Hot/Cold Deck Reset	Clg: <u>00526 x hr/wk x cfm x x °F x /ton</u> Htg: <u>1.08x hr/wk x cfm x a(x + x)/(x)</u>					
Safety Alarms	Labor: 2 Manhours			<u>}</u>	<u> </u>	
	TOTALS FOR SYSTEM	.3	10,351	850.2	0	
	* Too small of a system to be economically feasible.		- 			

.

. •

- -•••

١.

103.

SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS

N

...

•.

SYSTEM TYPE VARIABLE AIR VOLUME AHU (3) 4 BUILDING NO. 500 SYSTEM NO. 4

.

÷.,

			SAVINGS	S		
FUNCTION	SAVINGS CALCULATIONS	ΚW	KWH	GAL.	Ę	COST
scheduled Scheduled	Clg:.00507x.293Btu/ft ² hr ^e F x 4500 ft ² x(168 - 525) x.20x //f /ton		168	0.001		BASIC FUNCTIONS
Start/Stop	V-Clg: 0101x 3000 cfm x ./0 x (168 - 575) x .20 x ./g / ton V-Hto: 410 x 3000 cfm x ./0 x (168 - 575) x .20 / f 58 x 38700)		235			
	<u> </u>	,	945	55.4		
Duty Cycling	Aux: 5.17 x hp x hr					
Demand Limit	KW: 0.149 x //5 hp	.2				
Optimum	<u>2 × /5</u> hp × ((<u>25</u> hr × <u>232</u>) -		230			-
Start/Stop	×		148			
OA Limit	Aux: 0.597 x //5 hp x (273 + 204)		427			
Run Time	Labor: 2 Manhours					
Ventilation/ Recirculation	WU V-htg: <u>5512</u> x <u>3000</u> cfm x ./0 x (<u>2.5</u> 25)/(.58 x /38700) V-clg: <u>0301</u> x cfm x x((-(.25x dy/wk)) x /ton V-htg: <u>679</u> x cfm x x((-(.25x dy/wk))/(x)			46.2		
Economizer	(Computer simulation required.)		**			
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr [•] Fx ft ² x [•] F x (168 -) x /ton Htg: <u>28.6</u> x Btu/ft ² hr [•] Fx ft ² x [•] F x (168 -)/(x /)					
Reheat Coil Reaet	Clg:. <u>00526 × hr/wk × cfm × °F × /ton</u> Htg: <u>56.16</u> × hr/wk × cfm × °F/(×)					
Hot/Cold Deck Reset	Clg: <u>00526 × hr/wk × cfm × × °F × /ton</u> Htg: <u>1.08× hr/wk × cfm × ×(× + ×)/(×)</u>					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	.2	2/53	202.1	0	
*	* Assumed a 75% of capacity for average operating point (3000 cfm, 1.5 hp) ** Too small of a system to be economically trasible.	1 (3	000 CI	Fm, 1.5	(dy s	
		•			2	•

•

SECONDARY SYSTEM SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS

.

SYSTEM NO. 5 SYSTEM TYPE MULHZONE AIT HANDLER (4) BUILDING NO. 200

5

.

			SAVINGS	S		
FUNCTION	SAVINGS CALCULATIONS	KW	KWH	GAL	E	COST
Scheduled	Clg:.00507x./66 Btu/ft2 hr6F x 7340 ft2x(168 - 55) x/0x.94 /tonHtg: 286x./66 Btu/ft2hr6Fx 7340 ft2x(168 - 55) x/.0/(.53 x/38 700)		656	535.6		BASIC FUNCTIONS
Start/Stop	x (168 - <u>55</u>) x (168 - <u>55</u>)		2557			
	<u> </u>	`	19,323			
Duty Cycling	Aux: 5.17 × 6 hp x 45 hr		1395			
Demand Limit	KW: 0.149 × 6 hp	8.				
Opt inum	6 hp x ((2 hr x 232) - 2		560			
Start/Stop	Z x (c/· - u Z) x du		424			
OA Limit	Aux: 0.597 x hp x (_273 + 204)					
Run Time	Lebor: 2 Manhours				2	
Ventilation/ Recirculation	WU V-htg: <u>5512</u> x <u>8000</u> cfm x <u>./0</u> x (<u>2</u> 25)/(<u>.53 x/38 700</u>) V-c1g: <u>0301</u> x cfm x <u>x((</u> -(.25x dy/wk)) x /ton V-htg: <u>679</u> x cfm x <u>x((</u> -(.25x dy/wk))/(<u>x</u>)			6401		
Economizer	(Computer simulation required.)		*			
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ^e Fx ft ² x [•] F x (168 -) x /ton Htg: <u>28.6</u> x Btu/ft ² hr ^e Fx ft ² x [•] F x (168 -)/(x /)					
Reheat Coil Reset	Clg:. <u>00526</u> x hr/wk x cfm x [•] F x /ton Htg: <u>56.16</u> mr/wk x cfm x [•] F/(x)					
Hot/Cold Deck Reset	Clg: _00526 x 50 hr/wk x 8000 cfm x 60 x 3 °F x .94 kw /ton Htg: 1_08x50 hr/wk x8000 cfm x 40 x(23.4x 3° +28.6x 2°)/(53x/38700)		3560	299.5		
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	8.	28,475	28,475 17750	2	

ne ha taita ha taita a

`_·["]*_·

 .

 · · ·

۰. ا

FUNCTIONS COST BASIC N H 2 36.0 36.0 ZONE DX-A/C (5) SAVINGS 175 175 KWH 0 R /ton days/wk days/wk x 1.49 /ton V-c1g: <u>0301 x 400 cfm x .08 x((125 -(.25x 5 dy/wk)), x 1.49 /ton</u> V-htg: <u>679 x 400 cfm x .08 x((125 -(.25x 5 dy/wk)))(153 x/582m</u>) /ton /ton × × ton STATUS $\widetilde{}$ SYSTEM TYPE SMCLE /ton SAVINGS CALCULATIONS AND COSTS hr)x ____ft^ax ____F x (168 - ____ -.25)/(× SAVINGS CALCULATIONS FRN е F Х SECONDARY SYSTEM × •F x (168 °F × + ft²x(168 -`•F/(× × × V Btu/ft² hr⁶F x 1t ... hr - .75) × × × TEMP. SENSOR × + <u>x (168 - ____</u> hr x ft²x cfm x cfm x Ę cfm x × (168 cfm x x(η (Computer simulation required.) cfm x Btu/ft²hr[•]Fx hp x (hp x (168 -Btu/ft²hr⁶Fx hr/vk x___ hp x hp × ((SYSTEM NO. hr/vk × hp × (hr/wk x Btu/ft²hr°Fx cfn x å cfa x Htg: LOBX hr/vk x Labor: 2 Manhours 2 Manhours WU V-htg: 5512 x TOTALS FOR SYSTEM BUILDING NO. 200 WU Aux: 0852 x × -00526 X AUX: 0.597 XUA × × Htg: 28.6 × V-C18: _0301x_ V-Htg: 679 X 2112 Htg: 56.16× C18: .00195× Clg:.00507x KH: 0.149 C18:.00526 Aux: 28.5 X Htg:<u>286</u>x__ Labor: clg: :xnv Safety Alarma Recirculation Duty Cycling Demand Limit Ventilation/ Reheat Coll Economizer Deck Reset Start/Stop Start/Stop Day/Night Setback Scheduled OA Limit Run Time Hot/Cold FUNCTION Opt imum Reset

•

SAVINGS CALCULATIONS AND COSTS

SYSTEM TYPE MU/LIZENE DX - A/C (6) 3 BUILDING NO. 100 SYSTEM NO.

					ľ	
			SAVINGS			
FUNCTION	SAVINGS CALCULATIONS	КW	KWH		B	COST
Scheduled Start/Stop	Clg: .00507x. 3/3 Btu/ft2 hr+F x 7000 ft2x(168 - 62.5) x.2 x /2 /tonHtg: 286x. 3/3 Btu/ft2hr+Fx 7000 ft2x(168 - 62.5) x.2 /(/.0 x 34/3)V-Clg: 0301x 8000 cfm x .08 x (168 - 62.5) x .2 x /2 /tonV-Htg: 679 x 8000 cfm x .08 x (168 - 62.5) x .2 /(/.0 x 34/3)Aux: 28.5 x 7 hp x (168 - 62.5) x .2		281 3874 487 2686 4209			BASIC
Duty Cycling	Aux: 5.17 x 7 hp x 45 hr		1628			
Demand Limit	KW: 0.149 x 7 hp	1.0				
Opti mum Start/Stop	WU Aux: .0852 x 7 hp x ((<u>35</u> hr x 232) - 238 hr)x 5 days/wk CD Aux: 11.3 x 7 hp x (<u>35</u> hr75) x 5 days/wk		8891 2111			
OA Limit	Aux: 0.592 x 7 hp x (7x6 + 204) winter savings		852			
Run Time	Labor: 2 Manhours				2	
Ventilation/ Recirculation	WU V-htg: 5512 x <u>8000</u> cfm x <u>.08</u> x (<u>35</u> 25)/(<u>/0 x 34/3</u>) V-c1g: <u>.0301 x cfm x x((-(.25x dy/wk)) x //ton</u> V-htg: <u>679</u> x cfm x x((-(.25x dy/wk))/(x))		3359			
Economizer	(Computer simulation required.)		*			
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ^e Fx ft ² x ^e F x (168 -) x /ton Htg: <u>28.6</u> x Btu/ft ² hr ^e Fx ft ² x ⁻ F x (168 -)/(x)					
Reheat Coil Reset	Clg:. <u>00526 x hr/wk x cfm x *F x /ton</u> Htg: <u>56.16</u> x hr/wk x cfm x *F/(x x)					
Hot/Cold Deck Reset	Clg: <u>00526 x 50</u> hr/wk x 2000 cfm x <u>50 x 3 °F x /2 Kw</u> /ton Htg: <u>1.08 x 50</u> hr/wk x 2000 cfm x 50 x (<u>23.4x 3° + 28.6x 2°</u>)/(<u>/0 x 34/3</u>)		3787 8063			
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	0%	32,026	0	2	

.

 .

* Too small of a system to be economically feasible.

	SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS					
10 9	BUILDING NO. 300 SYSTEM NO. 4 SYSTEM TYPE TWO Pipe Fan Coil Units (1) - 45 Units, Atal	hits	· (L)	- <u>45</u> un	ıHs,	total
FUNCTION	SAVINGS CALCULATIONS	КW	SAVINGS KUH	6AL	Ę	COST
Scheduled Start/Stop		1	591			BASIC
Duty Cycling	Aux: 5.17 × 11.75 hp x 45 hr		2733		1	
Demand Limit	KW: 0.149 x //.75 hp	1.7				
Opti aun Start/Stop	WU Aux: <u>0852 x //.75</u> hp x ((<u>2</u> hr x <u>232</u>) - <u>250</u> hr)x <u>5</u> daye/wk CD Aux: <u>11.3 x //.75</u> hp x (<u>2</u> hr75) x <u>5</u> daye/wk		1071 830			
OA Limit	Aux: 0.597 x //.75 hp x (273 + 204)		3346			
Run Time	Lebor: 2 Manhours				8	
Ventilation/ Recirculation	WU V-htg: 5512 x cfm x x (25)/(x) V-clg: 0301 x cfm x x((-(.25x dy/wk)) x /ton V-htg: 679 x cfm x x((-(.25x dy/wk))/(x))					
Economizer	(Computer simulation required.)					
Day/N1ght Setback	C1g:. <u>00195</u> x Btu/ft ² hr ^e Fx ft ² x ^e F x (168 -) x / ton Htg: <u>28.6</u> x Btu/ft ² hr ^e Fx ft ² x ⁻ F x (168 -)/(x)					
Reheat Coil Reset	Clg:. <u>00526 x hr/wk x cfm x [•]F x /ton</u> Htg: <u>56.16</u> x hr/wk x cfm x [•] F/(<u>x</u>)					
Hot/Cold Deck Reset	Clg: <u>00526 x hr/wk x cfm x x *F x /ton</u> Htg: <u>1.08x hr/wk x cfm x x(23.4x +28.6x)/(x</u>)					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	1.7	27,491 482.8	482.8	2	
					ł	

.

٠.

٠.,

•.•

٠,٠ · · · ·

· .

•--

•

T

s

· . .

J,
G
÷
N.
Ť
×.
İ
<u>-</u> -
÷-
÷
7
g.
3
M.
1
6
tu. Bu
1.
Ŀ
j
2
ŧ.
Į.
hų.
1
F.
5
1
2
F
Ľ,
F
K.
È
ĥ
F
F
1

SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS SYSTEM TYPE FOUR Pipe Fan Goils (B) (15 Units total) S BUILDING NO. 500 SYSTEM NO.

		L	SAVINGS	SS		
FUNCTION	SAVINGS CALCULATIONS	Μ	Кин	-cE	Ŧ	COST
Scheduled Start/Stop	$\begin{array}{c} \text{Clg:.00507x.283} \\ \text{Btu/ft}^{2} \text{hr}^{P} \text{r} \underline{4500} \text{ft}^{2} \text{x}(168 - \underline{55}) & \underline{3.40} \text{x}/\underline{18}/\text{ton} \\ \text{Htg:.286x.283} & \underline{3} \text{Btu/ft}^{2} \text{hr}^{P} \text{Fx} \underline{4500} \text{ft}^{2} \text{x}(168 - \underline{55}) & \underline{3.40}/(\underline{.55} \text{ x}/\underline{03}/\text{1}) \\ \text{V-Clg:.0301x} & \text{cfm} & x & (168 - 0) & x & x \\ \text{V-Htg:.679} & x & \text{cfm} & x & (168 - 0) & x & x \\ \text{V-Htg:.679} & x & (168 - 55) & x & \underline{40} \\ \text{Aux:.28.5} & \underline{3.75} \text{ hp} & x & (168 - 55) & x & \underline{40} \end{array}$	<u></u>	344 4830	29,032	!	BASIC
Duty Cycling	Aux: 5.12 x 3.75 hp x 45 hr		872			
Demand Limit	KW: 0.149 x 3.75 hp	Ņ				
Optimum Start/Stop	WU Aux: <u>.0852 x 3.75</u> hp x ((<u>2</u> hr x <u>232</u>) - <u>220</u> hr)x <u>5</u> days/wk CD Aux: <u>11.3 x 3.75</u> hp x (<u>2</u> hr75) x <u>5</u> days/wk		389 264			
OA Limit	Aux: 0.597 x 3.75 hp x (273 + 204)		1901			
Run Time	Labor: 2 Manhours					
Ventilation/ Recirculation	WU V-htg: <u>5512</u> x cfm x x (25)/(x) V-clg: <u>0301</u> x cfm x x((-(.25x dy/wk)) x / ton V-htg: <u>679</u> x cfm x x((-(.25x dy/wk))/(x))					
Economizer	(Computer simulation required.)					
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ^e Fx ft ² x [•] F x (168 -) x /ton Htg: <u>28.6</u> x Btu/ft ² hr ^e Fx ft ² x [•] F x (168 -)/(x)					
Reheat Coil Reset	Cl8:. <u>00526 x hr/wk x cfm x °F x /ton</u> Htg: <u>56.16</u> x <u>hr/wk x cfm x °F/(x</u>)					
Hot/Cold Deck Reset	Clg: <u>00526 x hr/wk x cfm x x *F x /ton</u> Htg: <u>1.08x hr/wk x cfm x x(23.4x +28.6x)/(x</u>)					
Safety Alarma	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	Ś	7766	29,032	0	

· • • • •

.

.

•

1

FUNCTIONS COST BASIC HH 0 29.2 62.6 9.6 7.8 6AL SAVINGS SYSTEM TYPE Heating & Ventilating Unit (9) 33/3 3220 KWH 63 КW ~ he Needs ventilation in restrooms /ton /ton -.25)/(.53 × /38.700 ton/ hp x ((Z hr x 232) - 245 hr)x 5 days/wk hp x (<u>hr - .75) x</u> days/wk Clg:.00507x Btu/ft² hr^eF x ft²x(168 -) x x /ton Htg:<u>286x //66</u> Btu/ft²hr^eFx 400 ft³x(168 - <u>55</u>) x/0 /(.53 x/38 700) V-Clg: 0.101x cfm x x (168 -) x x / ton V-Htg: 6.79 x 400 cfm x ./5 x (168 - 55) x <u>{0 /(.53 x /38 700)</u> Aux: 28.5 x / hp x (168 - 55) x <u>{0 /(.53 x /38 700)</u> /ton × × × X ž dy/wk)) x /ton dy/wk))/(× •F x (168 -+28.6x I SAVINGS CALCULATIONS • • •F x (168 -(.25x • ¥ _•F/(+ 204 × _x(<u>23.4</u>x ./5 ft²x cfm x cfm x hp x (<u>273</u> cfm x)× X 2 (Computer simulation required.) 400 cfm x cfm x Btu/ft²hr*Fx ____Btu/ft²hr[•]Fx x dy 200 SYSTEM NO. cfm x cfa x Å hr/wk x hr/vk x Clg: 00526 x nr/wk ? Htg: 56.16x hr/wk x hr/wk x Labor: 2 Manhours Labor: 2 Manhours WU V-htg: _____X l TOTALS FOR SYSTEM V-clg: _0301 x V-htg: _629 x WU Aux: .0852 x CD Aux: 11.3 x × Aux: LL.3 x KW: 0.149 X AUX: 0.597 X C18: _00526 × Cls: .00195% _ Hts: _28.6 % _ 2115 Htg: 1.08x_ Aux: <u>28.5 x</u> BUILDING NO. :xny Safety Alarms Recirculation Demand Limit Duty Cycling Ventilation/ Reheat Coll Start/Stop Start/Stop Economizer Deck Reset Scheduled Day/Night Run Time FUNCTION DA Limit Hot/Cold Setback Opt fimum Reset

·. ·.

. .

. \cdot -۰..

÷.,'

SECONDARY SYSTEM

SAVINGS CALCULATIONS AND COSTS

FUNCTIONS COST BASIC SYSTEM TYPE Steam Unit Heaters (10). 4 units total HH 0 144,527 144,527 6 SAVINGS KWH 0 КW 0 Clg:.<u>00195</u>x Btu/ft²hr⁶Fx ft²x ⁶F x (168 -) x /ton Htg: <u>28.6</u> x.<u>625</u>Btu/ft²hr⁹Fx<u>3000</u>ft²x <u>/5</u>⁶F x (168 - <u>55</u>)/(.<u>6/x /03/</u>) /ton /ton days/wk /ton × × days/wk ton /ton SAVINGS CALCULATIONS AND COSTS × hr)x dy/uk))/(dy/wk)) -.25)/(× +28.6× SAVINGS CALCULATIONS × 4 SECONDARY SYSTEM × t ч Ч $ft^{2}x(168 -$)/J. 204 -(.25x -(.25x $\frac{hr \times 232}{hr - .75}$ $Btu/ft^{2} hr^{0}F \times \frac{1}{ft^{2}}(168 - \frac{1}{t})$ × × x(23.4x × × + ___cfm x cfm x hr hp x (273 cfm x x (168 -- × (168 ž (Computer simulation required.) cfm x cfm x SYSTEM NO. cfn x hp × (168 -)) × × 4 hp x cf**m** x hr/vk x hr/wk x Btu/ft²hr[•]Fx Å hr/wk x z' ugo cfm x Htg: LOBX hr/vk x Labor: 2 Manhours Labor: 2 Manhours WU V-htg: 5512 X TOTALS FOR SYSTEM BUILDING NO. 400 WU Aux: 0852 x CD Aux: 11.3 x V-cl8: _0301 x V-htg: 679 x × Htg: 56.16x X 265-0 :XNV × C18: .00526 x × V-C18: _0301x_ C1g:.00507x V-Htg: 679 X KW: 0.149 C18:.00526 5.17 Aux: 28.5 x Htg: 286x__ :xnY Recirculation Safety Alaras Duty Cycling Demand Limit Ventilation/ Reheat Coil Deck Reset Start/Stop Economizer Start/Stop Scheduled Day/N1ght OA Limit Hot/Cold Run Time FUNCTION Setback Opt imum Reset

`.· ٠. · · · · ·

· • • •

•

.

_

۰.

FUNCTIONS COST BASIC N Ħ 2 0 SAVINGS 296 296 KWH SYSTEM TYPE Electric Unit Heater (11) 0 KW /ton /ton /ton days/vk 10 × 34/3) /ton × × tan cucles days/wk ton × × $\widetilde{}$ × /ton hr)x _dy/wk))/(×.0/(dy/wk) •F x (168 -(tan cycles) -.25)/(× +28.6x SAVINGS CALCULATIONS • F х 1 Clg:.00507x Btu/ft² hr[•]F x ft²x(168 -Htg:<u>/d7x.3/3</u>Btu/ft²hr[•]Fx <u>200 ft²x(168 - 55</u>) × 4. 204 -F/($\frac{hr \times 232}{hr - .75) \times}$ -(.<u>25x</u> -(.25x × × _x(<u>23.4</u>x _ft²x ___ × × + ft²x cfm x Ę cfm x hp x (<u>273</u> cfm x x (168 x (168 ž))× (Computer simulation required.) cfm x cfm x Btu/ft²hr[•]Fx cfa x Btu/ft²hr[•]Fx 1)) × × 4 hr/wk x____ BUILDING NO. 100 SYSTEM NO. hp x hp x (168 cfm x hr/wk x cfn x Å hr/vk x cfm x hr/wk x Labor: 2 Manhours Labor: 2 Manhoure WU V-htg: 5512 X TOTALS FOR SYSTEM V-c1g: _0301 x × 679 WU Aux: 0852 x CD Aux: 11.3 x × × Clg: _00526 X Htg: 1_08X P × X 265.0 :XNV V-Htg: 679 X Clg:.00195x _ Htg: 28.6 x _ Clg: .00526 7 Htg: 56.16x V-C18:_0301x_ KW: 0.149 5.17 Aux: 28.5 x V-htg: Aux: * Recirculation Safety Alarms Demand Limit Duty Cycling Ventilation/ Reheat Coil Scheduled Start/Stop Economizer Start/Stop Deck Reset Day/Night Run Time Hot/Cold OA Limit **FUNCTION** Setback Opt faun Reset

SAVINGS CALCULATIONS AND COSTS

SECONDARY SYSTEM

* Different derived constant, based on 60°F Schpoint rather than 65°F.

.

SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS

Ë

h

٠.,

.

.'

5 SYSTEM TYPE Hot Water Unit Heater (12) BUILDING NO. 300 SYSTEM NO.

					ł	
		ł	SAVINCS		٦	
FUNCTION	SAVINGS CALCULATIONS	KW KI	KWH	G42 函	┥	COST
Scheduled Start/Stop	Clg:.00507x Btu/ft ² hr ⁶ F x ft ² x(168 -) x x /ton Htg:28.6x Btu/ft ² hr ⁶ Fx ft ³ x(168 -) x x /(x) V-Clg:.0301x cfm x x (168 -) x x /(n) V-Htg: 679 x cfm x x (168 -) x x /ton Aux: 28.5x hp x (168 -) x x x /ton					BASIC
Duty Cycling	Aux: 5.17 × hp × hr					
Demand Limit	KW: 0.149 × hp					
Optimum Start/Stop	WU Aux: <u>.0852 x hp x ((hr x 232</u>) - hr)x daya/wk CD Aux: <u>11.3 x</u> hp x (<u>hr75) x</u> days/wk					
OA Limit	Aux: 0.597 x hp x (273 + 204)					
Run Time	Labor: 2 Manhours					
Ventilation/ Recirculation	WU V-htg: <u>5512</u> x cfm x x (<u>25)/(x</u>) V-clg: <u>0301</u> x cfm x x((-(.25x dy/wk)) x /ton V-htg: <u>679</u> x cfm x x((-(.25x dy/wk))/(x))					·
Economizer	(Computer simulation required.)					
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ⁶ Fx ft ² x ⁶ F x (168 -) x /ton Htg: <u>28.6</u> x, <u>323</u> Btu/ft ² hr'Fx <u>250</u> ft ² x/ <u>5</u> ⁶ F x (168 - <u>45</u>)/(<u>.53 x/3870</u>)			57.9		
Reheat Coil Reset	Clg:. <u>00526</u> x hr/wk x cfm x *F x /ton Htg: 56.16 x hr/wk x cfm x *F/(x x)					
Hot/Cold Deck Reset	Clg:A hr/wk xx *_ *F x/ton Htg: <u>hr/wk xcfm x(23.4x+_28.6x _)/(x</u>)					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	0	0	57.9 0	0	

.

- Activity in the second

; ;

The second s

•

FUNCTIONS BASIC COST 포 0 6423 6423 R) SAVINGS KWH 0 Steam Radiation (13) КW 0 (1801) /ton /ton /ton days/vk /ton Clg:.<u>00195</u>x Btu/ft²hr[•]Fx ft²x [•]F × (168 -) x Htg: <u>28.6</u> ×.<u>625</u>Btu/ft²hr[•]Fx <u>200</u>ft²x <u>10</u>[•]F × (168 - <u>5</u>)/(<u>.6/x</u>) × × days/wk ton × × /ton SAVINGS CALCULATIONS AND COSTS × dy/wk))/(hr)x dy/wk)] -.25)/(× SAVINGS CALCULATIONS + 28 . 6× ۰F ۲ × ,1 SYSTEM TYPE ł × 4 -F/(-(.25x + 204 -(.<u>25x</u> hr x $\frac{232}{15}$ ft²x(168 Btu/ft² hr⁶F x it ... × x(<u>23.4</u>x × × cfm x _cfm x hp x (<u>273</u> (168 ħ cfm x <u>(168 -</u> × X ~ (Computer simulation required.) cfm x cfm x × × I)) × × dq hp × BUILDING NO. 400 SYSTEM NO. cfm x cfm x hp x (168 hr/wk x hr/vk x Å <u>hr/wk x</u> Btu/ft²hr°Fx cfm x hr/wk x Labor: 2 Manhours Labor: 2 Manhours WU V-htg: 5512 X TOTALS FOR SYSTEM V-htg: 679 X WU Aux: .0852 x CD Aux: .11.3 x V-c18: _0301 x × 1.08× h X 265.0 :XNV C18:.00526_ × KW: 0.149 X V-Clg: 0301x V-Htg: 679 X Htg: 56.16X Clg:.00507x Aux: 28.5 x 2115 Hts: 286× Clg: :xny Htg: Safety Alarms Rectrculation Duty Cycling Demand Limit Ventilation/ Reheat Coil Scheduled Start/Stop Economizer Start/Stop Deck Reset Day/Night **OA Limit** Run Time Hot/Cold FUNCTION Setback Opt imum Reset

SECONDARY SYSTEM

10 A. 1. ، بر 14

FUNCTIONS COST BASIC 폋 0 0 SAVINGS 5927 2.5|5927 KWH Electric Radiation (14) 2.5 КW /ton /ton ton/ days/vk 10 × 34/3) /ton × × × days/wk ton × × ž /ton hr)x _dy/wk))/(dy/wk)) × x1.01 -.25)/(× +28.6x •F x (168 -SAVINGS CALCULATIONS ъ Ч × $\frac{hr \times 232}{hr - .75} \times .$ SYSTEM TYPE ft²x(168 - <u>55</u>) x(168 - <u>55</u>) 10 KW X.25 • ¥ -•F/(-(.25x + 204 -(.25x × × Clg:.00507x Btu/ft² hr^eF x ft²x(16 Htg:<u>286x.3/3</u> Btu/ft²hr^eFx <u>2000</u> ft²x(168 cfm x x x x(23.4x × _ft²x ___ × × ft²x ų cfm x hp x (<u>273</u> cfm x x (168 -× (168 -Ĭ ~ (Computer simulation required.) cf**e** x cfa x Btu/ft²hr^eFx Btu/ft²hr[•]Fx⁻ I)) × × dq hp x hp x (168 -BUILDING NO. 100 SYSTEM NO. cfm x Å cfa x hr/vk x hr/wk x hr/wk x × IJ cfm x hr/vk x Labor: 2 Manhours Labor: 2 Manhours Ħ TOTALS FOR SYSTEM WU V-htg: 5512 WU Aux: .0852 x V-clg: 10301 X × 679 × NI: O. LEG X 265-0 :XNV × -00526 × Clg: .00526 X Htg: 56.16X _ V-C18: 0301X V-Htg: 679 X 21.2 Htg: 28.6 x Clg:.00195X Htg: LOBX Aux: 28.5 x V-htg: C1g: Aux: Safety Alarms Recirculation Demand Limit Duty Cycling Ventilation/ Reheat Coil Start/Stop Start/Stop Economizer Deck Reset Scheduled Day/Night Hot/Cold Run Time **DA Limit** FUNCTION Setback Opt Java Reset

115.

SAVINGS CALCULATIONS AND COSTS

SECONDARY SYSTEM

.

. . ÷.,

· · · ·

	COSTS
HEI	AND (
SYSTEM	IONS
SECONDARY	CALCULATIONS A
SECC	CAL
	SAVINGS

.

BUILDING NO. 500 SYSTEM NO. 6 SYSTEM TYPE Hot Water Radiation (15)

			CAUTNO	ų	┝	
FUNCTION	SAVINGS CALCULATIONS	ΚW	HWH	HM 747	T	COST
Scheduled Start/Stop	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$		1610	170.5	<u> </u>	BASIC FUNCTIONS
Duty Cycling	Aux: 5.17 x hp x hr					h
Demand Limit	KW: 0.149 × hp				<u> </u>	
Optimum Start/Stop	WU Aux: $.0852 \times .5$ hp x ((2 hr x 232) - 220 hr)x 5 days/wk CD Aux: <u>11.3 x</u> hp x (<u>hr75) x</u> days/wk		52			
OA Limit	Aux: 0.592 x .5 hp x (x3 + 204)		61			
Run Time	Labor: 2 Manhours					
Ventilation/ Recirculation	WU V-htg: <u>5512</u> x cfm x x (25)/(x) V-c1g: <u>0301</u> x cfm x x((-(.25x dy/wk)) x /ton V-htg: <u>679</u> x cfm x x((-(.25x dy/wk))/(x))					
Economizer	(Computer simulation required.)					
Day/Night Setback	Clg:. <u>D0195</u> x <u>Btu/ft²hr°Fx</u> ft ² x °F x (168 -) x /ton Htg: <u>28.6</u> x <u>Btu/ft²hr°Fx</u> ft ² x <u>°F x (168 -)/(x</u>)					
Reheat Coll Reset	Clg:. <u>00526</u> x hr/wk x cfm x °F x /ton Htg: <u>56.16</u> x hr/wk x cfm x °F/(x)					
Hot/Cold Deck Reset	Clg: .00526 x hr/wk x cfm x x °F x /ton Htg: <u>1.08x</u> hr/wk x cfm x x(<u>23,4x +28,6x)/(x</u>)					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	0	1723	172.1 0		

• • • •

•

FUNCTIONS BASIC COST SYSTEM TYPE Hot Water Radiation (confid) HW See previous sheet 1.6 9**4**2 SAVINGS KWH КW /ton r)x days/wk day<u>s/w</u>k '°F x 2°F 538 hr/yr × 0.01 × 25,000 Btu/hr/(.58 × /38,700 hr)× SAVINGS CALCULATIONS × SYSTEM NO. 6 I 204 $T \times 0.01$ ft²x(168 hr x $\frac{232}{15}$ ft²×(168 -Btu/hr/(т× × + H × hr 273 /ton x /ton x /ton x ч hp × (500 Btu/ft²hr °F x Btu/ft²hr °F x hp x)) × dq hp x (168 -Чd × BUILDING NO. Ч Labor: 2 Manhours 2 Manhours _____hr/yr x 538 hr/yr x 233 hr/yr x 733 hr/yr x TOTALS FOR SYSTEM 5.17 x WU Aux: .0852 x CD Aux: 11.3 x Chiller Demand Kw: 0.0414 x___ Aux: 0.597 x × 0.149 Clg: 00507x Aux: 28.5 x Htg: 286x Labor: Aux: Htg: Htg: clg: Clg: Clg: KW: Safety Alarms Duty Cycling Demand Limit Chiller Opt. Cond. Reset HW OA Reset Boiler Opt. Start/Stop Start/Stop Scheduled CHW Reset **OA Limit** Run Time FUNCTION Opt 1mum

for totals.

117.

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

k

....

FUNCTIONS BASIC COST N 0 HM 1726 1726 5 SYSTEM TYPE Steam Boiler (16, SAVINGS 0 KW KWH 0 days/wk days/wk /ton 2°F hr)× Htg: 538 hr/yr x .0/ x 225.000 Btu/hr/(.68 x /03/ ∕°F х SAVINGS CALCULATIONS 3 1 T × 0.01 204 ft²x(168 hr x $\frac{232}{.75}$) ft²x(168 -Btu/hr/(SYSTEM NO. Т× × + H × hг 273 /ton x /ton x /ton x Btu/ft²hr °F x BUILDING NO. 400) × dy Btu/ft²hr °F x hp x hp x (168 -)) × dy цр × hp Labor: 2 Manhours Labor: 2 Manhours 538 hr/yr x 733 hr/yr x 733 hr/yr x 733 hr/yr x TOTALS FOR SYSTEM × WU Aux: 0852 x CD Aux: 11.3 x 0.0414 x KW: 0.149 X Aux: 0.597 x 5.17 Clg: .00507x Aux: 28.5 x Htg: 286x Htg: clg: Clg: Clg: :xny Chiller Demand Kw: Safety Alarms Duty Cycling Demand Limit Chiller Opt. HW OA Reset Boiler Opt. Cond. Reset Scheduled Start/Stop Optimum Start/Stop **CHW Reset** Run Time FUNCTION **OA Limit**

· .•

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

LALAS A ALASSA

C

FUNCTIONS BASIC COST 0 2 4 Ŧ 53.7 53.7 GAL SYSTEM TYPE. Hot Water Boilers (3 Units total SAVINCS 0 KWH ξ 0 days/wk days/wk /ton /°F x 2°F Htg: _________ x <u>0.02</u> x <u>450,000</u> Btu/hr/(<u>. 65 x /38,700</u>) hr)× SAVINGS CALCULATIONS × I T × 0.01 204 BUILDING NO. 600 SYSTEM NO. .75) × ft²×(168 ft²x(168 -Btu/hr/(Ť× × $hr \times 232$ + H . hr - . × hr 273 /ton x Btu/ft²hr °F x__ /ton x ton x) × dy Btu/ft²hr °F x hp ×)) × dq ф hp x (168 -× Ч 2 Manhours 2 Manhours 538 hr/yr x <u>733</u>hr/yr x 733 hr/yr x 733 hr/yr x TOTALS FOR SYSTEM 5.17 × WU Aux: .0852 x CD Aux: 11.3 x Aux: 0.597 x 0.0414 x 0.149 x Clg: .00507x Aux: 28.5 x Htg: 286x Labor: Labor: Htg: :xnY Clg: Clg: clg: Chiller Demand Kw: KW: Safety Alarms Duty Cycling Demand Limit Chiller Opt. HW OA Reset Boiler Opt. Cond. Reset Start/Stop Start/Stop Scheduled CHW Reset OA Limit Run Time FUNCTION Opt 1mum

SAVINGS CALCULATIONS AND COSTS

FRIMARY SYSTEM

SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS

Lurnace (18) SYSTEM NO. 7 SYSTEM TYPE Direct fired BUILDING NO. 200

-

and a second
			SAVINGS			
FUNCT I ON	SAVINGS CALCULATIONS	KW	KWH	Ŀ	Ŧ	COST
Scheduled	$x ft^{2}x(168 - \frac{1}{2}x(168 - 1$			32,021		BASIC FUNCTIONS
Start/Stop	V-UR: 0.301x CIM x x (100 -) x x (100 V-Htg: 6/9 x 4000 cfm x, 20 x (168 - 55) x 1.0 /(.65 x 1031) Aux: 28.5 x 2.5 hp x (168 - 55) x 1.0		8051	9,593		
Duty Cycling	Aux: 5.12 x 2.5 hp x 45 hr		581			
Demand Limit	KW: 0.149 × 2.5 hp	S.				
Opti aum Start/Stop	WU Aux: <u>0852 x 2.5</u> hp x ((<u>Z</u> hr x <u>232</u>) - Z45 hr)x 5 days/wk CD Aux: 11.3 x hp x (<u>hr75) x</u> days/wk		233			
OA Limit	Aux: 0.597 x hp x (273 + 204) neads ventilation					
Run Time	Labor: 2 Manhours				2	
Ventilation/ Recirculation	WU V-htg: 5512 x 4000 cfm x .20 x (225)/(.65 x /03/) V-clg: 0301 x cfm x x((-(.25x dy/wk)) x /ton V-htg: 679 x cfm x x((-(.25x dy/wk))/(x)			11,515		
Economizer	(Computer simulation required.)					
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ^e Fx ft ² x ^e F x (168 -) x / ton Htg: <u>28.6</u> x Btu/ft ² hr ^e Fx ft ² x ^e F x (168 -)/(x)					
Reheat Coil Reset	Clg:. <u>00526 x hr/wk x cfm x °F x /ton</u> Htg: <u>56.16</u> x hr/wk x cfm x °F/(x)					
Hot/Cold Deck Reset	Clg: <u>00526 x hr/wk x cfm x x °F x /ton</u> Htg: <u>1.08 hr/wk x cfm x x(23.4x +28.6x)/(x</u>)					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	ŵ	8665	8665 135129	2	

.

•••

.

120.

.

a substantia sector a substant a sector a substant a substant a substant a substant a substant a substant a sub • ÷

٠.

والمراجع المراجع المراجع المتحرين والمحرور						
	SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS					
BUI	BUILDING NO. 100 SYSTEM NO. 5 SYSTEM TYPE Direct first builer (19)	r (19				
FINCTION	SAVINCE CALCULATIONS	IVAS VUI	SAVINGS		-00c4	
Scheduled	$ \frac{x ft^{2}x(168 -) \ x}{00 \ ft^{2}x(168 - \frac{55}{5}) \ x, \frac{9}{2}/(\frac{6}{168})} $	╉────	6	8	BASIC	
	$\frac{1}{28.5 \times 5} \frac{1}{5} \frac{1}{100} \frac$	14,492	37,210	0		
Duty Cycling	Aux: 5.17 × 5 hp × 45 hr	1163	3			
Demand Limit	KW: 0.149 × 5 hp	.7				
Opti aua Start/Stop	WU Aux: .0852 x 5 hp x ((2 hr x 232) - 238 hr)x 5 days/wk CD Aux: 11.3 x hp x (hr75) x days/wk	481				
OA Limit	Aux: 0.592 x 5 hp x (2x2 + 204)	609	6			
Run Time	Labor: 2 Manhours			2		
Ventilation/ Recirculation	WU V-htg: 5512 x 7000 cfm x .05 x (225)/(.63 x /03/) V-clg: .0301 x cfm x x((-(.25x dy/wk)) x /ton V-htg: 679 x cfm x x((-(.25x dy/wk))/(x))		5198	80		
Economizer	(Computer simulation required.)					
Day/Night Setback	Clg:. <u>00195</u> x Btu/ft ² hr ⁶ Fx ft ² x ⁶ F x (168 -) x /ton Htg: <u>28.6</u> x Btu/ft ² hr ⁶ Fx ft ² x ⁶ F x (168 -)/(x /ton	 		- 	-	
Reheat Coil Reset	Clg:. <u>00526</u> x hr/wk x cfm x °F x /ton Htg: <u>56.16</u> x hr/wk x cfm x °F/(x)					
Hot/Cold Deck Reset	Clg: <u>00526 x hr/wk x cfm x x °F x /ton</u> Htg: <u>1.08x hr/wk x cfm x x(23.4x +28.6x)/(x</u>)					
Safety Alarms	Labor: 2 Manhours					·. ·. ·
	TOTALS FOR SYSTEM	.7 16,7.	16,745 136,317	17 2		

•••

.

.

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

BUILDING NO. 500 SYSTEM NO. 1 SYSTEM TYPE Steam HW Converter (20)

			SAVINGS	ICS		
FUNCTION	SAVINGS CALCULATIONS	ΚW	КШН	CF MH	Ŧ	соѕт
Scheduled Start/Stop	$\begin{array}{ c c c c c c c c c c c c c c c c c c c$		1449			BASIC
Duty Cycling	Aux: 5.17 x hp x hr					
Demand Limit	KW: 0.149 x hp					
Optimum Start/Stop	WU Aux: <u>.0852</u> x .5 hp x((2 hr x 232) - 220 hr)x 5 days/wk CD Aux: <u>11.3 x hp x (hr75) x days/wk</u>		52			
OA Limit	Aux: 0.597 x .5 hp x (x4 + 204)		61			
Run Time	Labor: 2 Manhours					
HW OA Reset	Htg: 538 hr/yr x 0.0/ x 110,000 Btu/hr/(.55 x 103/)			5401		
Boiler Opt.	Htg: 538 hr/yr x x Btu/hr/(x)					
Chiller Opt.	Clg: 733 hr/yr x /ton x T x 0.01					
CHW Reset	Clg: <u>733</u> hr/yr x/ton xT x/°F x 2°F					
Cond. Reset	Clg: 733 hr/yr x/ton xT x ()					
Chiller Demand	Kw: 0.0414 x hp					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	0	1562	1043	0	
	* Pump dedicated to System #5 Fan coils		-			-

. **-** . '

-

·.••,

۰.

 •••

.

. . . .

<u>}</u>.

.

FUNCTIONS BASIC COST 0 Ŧ 44 4.4 GAL SAVINGS KWH 0 KW 0 /ton r)x days/wk days/wk 2°F 538 hr/yr x 0.01 x 60,000 Btu/hr/(.53 x /38, 700 hr)× /°F × SAVINGS CALCULATIONS × ŧ. T × 0.01 204 ft²x(168 hr x $\frac{232}{75}$) $ft^{2}x(168 -$ Btu/hr/(т× × F × hr 273 °F × /ton x /ton x /ton x hp × (Btu/ft²hr °F x hp x hp x ((hp x (168 -Ч Btu/ft²hr × Чþ 2 Manhours Labor: 2 Manhours 538 hr/yr x 733 hr/yr x 733 hr/yr x 733 hr/yr x TOTALS FOR SYSTEM 5.17 x WU Aux: .0852 x CD Aux: 11.3 x 0.0414 × Aux: 0.597 x 0.149 x Clg: 00507x Aux: 28.5 x Htg: 286x Labor: clg: :xnv Htg: Htg: Clg: clg: KW: Chiller Demand Kw: Safety Alarms Duty Cycling Demand Limit Chiller Opt. Cond. Reset HW OA Reset Scheduled Start/Stop Boiler Opt. Start/Stop **CHW Reset OA Limit** Run Time FUNCTION Opt 1mum

 •

•

123.

PRIMARY SYSTEM SAVINCS CALCULATIONS AND COSTS

P

BUILDING NO. 200 SYSTEM NO. / SYSTEM TYPE HTHW/Steam Converter (21)

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

C

SYSTEM TYPE HTHW/HW CONVERTER (22) _! BUILDING NO. 300 SYSTEM NO.

			SAVINGS	NGS		
FUNCTION	SAVINGS CALCULATIONS	ΚW	КШН	GAL	Ŧ	COST
Scheduled Start/Stop	$\frac{\text{Clg: .00507x Btu/ft}^{2}\text{hr }^{5}\text{hr }^{5}\text{r }_{x}\text{ ft}^{2}\text{x}(168 -) \times \times \frac{x}{1} \times \frac{100}{100}}{\text{Mtg: } \frac{286x}{28.5 \times \text{hp }^{2}\text{hr}(168 -) \times \frac{100}{100}}{\text{hr}(168 -) \times \frac{100}{100}}$			· ·		BASIC
Duty Cycling	Aux: 5.17 x hp x hr office)					
Demand Limit	KW: 0.149 x hp					.
Optimum Start/Stop	WU Aux: <u>.0852 x hp x((hr x 232) - hr)x days/wk</u> CD Aux: <u>11.3 x hp x (hr75) x days/w</u> k					
OA Limit	Aux: 0.597 x hp x (273 + 204)					
Run Time	Labor: 2 Manhours				~	
HW OA Reset	Htg: 538 hr/yr x 0.01 x 350,000 Btu/hr/(.53x/38,700)			256	1	
Boiler Opt.	Htg: 538 hr/yr x x Btu/hr/(x)					
Chiller Opt.	Clg: 733 hr/yr x /ton x T x 0.01					
CHW Reset	Clg: 733 hr/yr x /ton x T x /°F x 2°F					
Cond. Reset	Clg: 733 hr/yr x/ton xT x ()					
Chiller Demand Kw:	Kw: 0.0414 x hp					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	0	0	25.6	2	

.

÷.,

· · · · ·

۰.

1

~

.

•

-

FUNCTIONS BUILDING NO. 100 SYSTEM NO. 4 SYSTEM TYPE Water coved DX Compressor (23) BASIC COST 2 2 Ŧ SAVINGS 2076 21012 4830 106 KWH KW 3.3 3000 /ton days/wk shut down , no summer hr)x day days/wk '°F x 2°F Clg: <u>733</u> hr/yr x <u>1.2 ku/</u>ton x <u>20</u> T x (0.118) ** SAVINGS CALCULATIONS 5 ጙ × × 204 $T \times 0.01$ ft²×(168 - $\frac{hr \times 232}{hr - 75) x}$ Btu/ft²hr°F x tt x... °r v ft²x(168 - $\frac{Btu/it}{Btu/ft^2hr^6F} \times \frac{ft^x}{55} \times \frac{1}{20}$ Btu/hr/(Btu/hr/(Т× ¥ + hr hp x (<u>273</u> /ton x /ton x hp x Aux: <u>28.5 x /5</u> hp x (168 -)) × dq qq 22.5 hp × × ď WU Aux: .0852 x CD Aux: 11.3 x /S Labor: 2 Manhours 2 Manhours 733 hr/yr x Clg: 733 hr/yr x 538 hr/yr x 538 hr/yr x TOTALS FOR SYSTEM 0.0414 x 5.17 × KW: 0.149 x Aux: 0.597 x Clg: .00507x Htg: 286x Labor: Aux: Htg: Htg: Clg: Chiller Demand Ku: Safety Alarms Duty Cycling Demand Limit Chiller Opt. HW OA Reset Cond. Reset Optimum Start/Stop Boller Opt. Start/Stop **CHW Reset** Scheduled **OA Limit** FUNCTION Run Time

SAVINGS CALCULATIONS AND COSTS

PRIMARY SYSTEM

* No credit on fan Since it cycles; caling savings taken on Sgstem # 3 AHU. ** RCWT = 9.4°F, PEI = 14.6 %, AEI = 0.118 . .

FUNCTIONS BASIC COST SYSTEM TYPE Air cooled DX Compressor (24) 0 HW 0 SAVINGS 0 KWH КW 0 days/wk days/wk /ton SAVINGS CALCULATIONS AND COSTS '°F x 2°F hr)x SAVINGS CALCULATIONS SYSTEM NO. 4 × × 1 T × 0.01 204 $ft^{2}x(168 -$ Btu/hr/(hr x $\frac{232}{.75}$) $ft^2x(168 -$ Btu/hr/(× × H + H × ĥ 273 Btu/ft²hr °F x___ /ton x /ton x /ton x BUILDING NO. 200 Btu/ft²hr °F x_) × (hp x)) × dq hp x (168 þ × × ች ٩ Labor: 2 Manhours Labor: 2 Manhours <u>733</u>hr/yr x Htg: 538 hr/yr x Htg: 538 hr/yr x 733 hr/yr x TOTALS FOR SYSTEM 733 hr/yr x × WU Aux: .0852 x CD Aux: 11.3 x 0.0414 x KW: 0.149 X Aux: 0.597 x 5.17 C1g: .00507x Aux: 28.5 x Htg: 286x Clg: :xnV clg: Clg: Chiller Demand Kw: Safety Alarms Duty Cycling Demand Limit Chiller Opt. HW OA Reset Cond. Reset Optimum Start/Stop Boiler Opt. Scheduled Start/Stop **CHW Reset** Run Time FUNCTION OA Limit

PRIMARY SYSTEM

* No savings since it serves a critical area.

-,

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

BUILDING NO. 500 SYSTEM NO. 2 SYSTEM TYPE Air Cooled Chiller (25)

			SAVINGS	CS		
FUNCT ION	SAVINGS CALCULATIONS	КИ	КШН	HM	H	COST
Scheduled *	$\frac{1}{4} Clg: \frac{00507x}{168} Btu/ft^{2}hr^{6}F \times \frac{ft^{2}x(168 - 0) \times x}{168} \times \frac{1}{28} 1$		14,492			BASIC
Duty Cycling	Aux: 5.17 x hp x hr					
Demand Limit	KW: 0.149 x 20 hp (shutting down 1 of 2 compressors)	3.0				
Optimum Start/Stop	WU Aux: $.0852 \times \text{hp x}(($ hr x 232) - hr)x days/wk CD Aux: 11.3×5 hp x $(2$ hr - $.75$) x 5 days/wk		353			
OA Limit	Aux: 0.597 x 5 hp x (273 + 204)		815			
Run Time	Labor: 2 Manhours				2	
HW OA Reset	Htg: 538 hr/yr x x Btu/hr/(x)					
Boiler Opt.	Htg: 538 hr/yr x x Btu/hr/(x)					
Chiller Opt.	Clg: 733 hr/yr x /ton x T x 0.01					
CHW Reset	Clg: 733 hr/yr x L.18 kg/ton x 35 T x .0/2 /°F x 2°F		726			
Cond. Reset	Clg: 733 hr/yr x /ton x T x ()					
Chiller Demand Kw:	Kw: 0.0414 x hp					
Safety Alarms	Labor: 2 Manhours					
	TOTALS FOR SYSTEM	3.0	3.0 16, 386	0	2	
	* Caling and heating savings credited on secondary systems Savings Calculations sheets.	k				

· · ·

•

. .

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

BUILDING NO. 300 SYSTEM NO. 2 SYSTEM TYPE Water Cooled Chiller (26)

			SAVINGS	S	
FUNCTION	SAVINGS CALCULATIONS	КW	Кин	HM	COST
Scheduled Start/Stop	$\frac{\text{Clg: .00507x Btu/ft}^{2}\text{hr }^{\text{F}}\text{ x ft}^{2}\text{ x(168 -) x x} + \frac{1}{x} + \frac$		17,613		BASIC
Duty Cycling	Aux: 5.17 x hp x hr CHW pump will not be duty cucled				1
Demand Limit	KW: 0.149 x hp Centrifugal chillet; see Chiller Demand				 -7
Optimum Start/Stop	WU Aux: .0852 x hp x((hr x 232) - hr)x days/wk CD Aux: <u>11.3 x 6</u> hp x (<u>2</u> hr75) x <u>5</u> days/wk		424		
OA Limit	Aux: 0.597 x hp x (273 + 204)				
Run Time	Labor: 2 Manhours			2	
HW OA Reset	Htg: <u>538</u> hr/yr x x Btu/hr/(<u>x</u>)				
Boiler Opt.	Htg: 538 hr/yr x x Btu/hr/(x)				
Chiller Opt.	Clg: 733 hr/yr x /ton x T x 0.01				
CHW Reset	Clg: <u>733</u> hr/yr x . 44 ku/ton x 50 T x . 0/7 /°F x 2°F		1711		
Cond. Reset	Clg: <u>733</u> hr/yr x. <u>94 kw</u> /ton x <u>50</u> T x (<u>,0/6</u>) *		551		
Chiller Demand Kw:	Kw: 0.0414 x 60 hp	2.4			
Safety Alarms	Labor: 2 Manhours				
	TOTALS FOR SYSTEM	2.4	2.4 19,759	0	

t,

• •

.

	COSTS
ž	AND
PRIMARY SYSTEM	CALCULATIONS
	SAVINGS

BUILDING NO. 300 SYSTEM NO. 6 SYSTEM TYPE DOMESHIC HW - Electric (28)

			SAVINGS	CS		
FUNCTION	SAVINGS CALCULATIONS	КW	КШН		HM	COST
Scheduled * Start/Stop	Clg: <u>00507</u> Btu/ft ² hr °F x ft ² x(168 -) x x /ton Htg: <u>286x</u> Btu/ft ² hr °F x ft ² x(168 -) x /(x) Aux: <u>28.5 x hp</u> x (168 -) x		50/			BASIC
Duty Cycling	Aux: 5.17 x hp x hr					
Demand Limit	KW: 0.749 × hp 2 kw X 0.25	N				
Optimum Start/Stop	WU Aux: .0852 x hp x((hr x 232) - hr)x days/wk CD Aux: <u>11.3 x</u> hp x (hr75) x days/wk					
OA Limit	Aux: 0.597 x hp x (273 + 204)					
Run Time	Labor: 2 Manhours					
HW OA Reset	Htg: 538 hr/yr x xBtu/hr/(x)					
Boiler Opt.	Htg: 538 hr/yr x x Btu/hr/(x)					
Chiller Opt.	Clg: <u>733</u> hr/yr x /ton x T x 0.01					
CHW Reset	Clg: <u>733</u> hr/yr x/ton x T x/°F x 2°F					
Cond. Reset	Clg:hr/yr x/ton xT x ()					
Chiller Demand	Kw: 0.0414 x hp					
Safety Alarms	Labor: 2 Manhours					
, _	TOTALS FOR SYSTEM	5.	105	0	0	
	* See following page for coloulations					

•

* See tollowing page for calculations.

129.

Bldg. 300, System #6 DHW Savings:

0

1.
$$V = 0.785 \times (2^{\circ})^2 \times (6^{\circ}) = 18.84 \text{ ft}^3$$

A = $[1.571 \times (2^{\circ})^2] + (3.14 \times 2^{\circ} \times 6^{\circ}) = 43.9 \text{ ft}^2$
2. Weekday shutdown (1530 to 430)
LSD = 13 hour/night
NSD = (4 nights/wk)(52 wk/yr) - (2x6 holidays) = 196
E = .94
Weekend shutdown (Fri at 1530 to Mon at 330)
LSD = 60 hours/weekend
NSD = 52 weekends/yr
E = .73
Holiday shutdown
LSD = 36 hours
NSD = 6 holidays/yr
E = .83
3. [43.9 x (140-75) x LSD x (.285/2) - 18.84 x 62.4 x (140-75)
x (1-E)] x NSD x 1.0/(.95 x 3413 Btu/Kwh)
= [(406.7 x LSD) - (76,415 x (1-E))] x NSD/3242
Weekday shutdown savings =
[(406.6 x 13) - (76,415 x (1-.94))] x 196/3242 = 42.3
Weekend shutdown savings =
[(406.6 x 60) - (76,415 x (1-.73))] x 52/3242 = 60.3
Holiday shutdown savings =
[(406.6 x 36) - (76,415 x (1-.83))] x 6/3242 = 3.0
total = 105.6 Kwh/yr

••••

FUNCTIONS BASIC COST 0 HM SYSTEM TYPE Domestic HW- Gas (29) 367 367 Ŀ SAVINGS 0 КШН KW 0 days/wk days/wk /ton /°F x 2°F hr)× SAVINGS CALCULATIONS × × 1 SYSTEM NO. 6 204 $T \times 0.01$ ft²x(168 hr x $\frac{232}{.75}$) Btu/hr/(ft²x(168 -Btu/hr/(Т× Т× + × hr 273 /ton x /ton x /ton x 200 Btu/ft²hr °F x Btu/ft²hr °F x_) x dy hp x hp x (168 -)) × dq đ × × BUILDING NO. дų Labor: 2 Manhours Labor: 2 Manhours Htg: 538 hr/yr x Htg: 538 hr/yr x Clg: 733 hr/yr x 733 hr/yr x 733 hr/yr x TOTALS FOR SYSTEM WU Aux: .0852 x CD Aux: 11.3 x 5.17 × 0.0414 x × KW: 0.149 x Clg: 00507x Aux: 0.597 Aux: 28.5 x Htg: 286x :xny clg: Clg: Chiller Demand Kw: Start/Stop 🕊 Safety Alarms Duty Cycling Chiller Opt. Demand Limit HW OA Reset Boiler Opt. Cond. Reset Start/Stop Scheduled **CHW Reset** Run Time FUNCTION OA Limit Opt 1mum

SAVINGS CALCULATIONS AND COSTS

PRIMARY SYSTEM

4

* See following page for calculations.

•

• ; • Bldg. 200, System #6 DHW Savings: $V = 0.785 \times (1.5')^2 \times (4') = 7.065 \text{ ft}^3$ 1. $A = [1.571 \times (1.5')^{2}] + (3.14 \times 1.5' \times 4') = 22.3 \text{ ft}^{2}$ 2. Weekday shutdown (1530 to 630) LSD = 15 hour/night $NSD = (4 \text{ nights/wk})(52 \text{ wk/yr}) - (2 \times 6 \text{ holidays}) = 196$ E = .87 Weekend shutdown (Fri at 1530 to Mon at 530) LSD = 62 hours/weekend NSD = 52 weekends/yr E = .55Holiday shutdown LSD = 38 hours NSD = 6 holidays/yrE = .70 $[22.3 \times (130-70) \times LSD \times (.285/1.5) - 7.065 \times 62.4 \times (130-70)]$ 3. x (1-E)] x NSD x 1.0/(.75 x 1031 Btu/cf) = $[(254.2 \times LSD) - (26,451 \times (1-E))] \times NSD/774$ Weekday shutdown savings = $[(254.2 \times 15) - (26,451 \times (1-.87))] \times 196/774 = 94.8$ Weekend shutdown savings = $[(254.2 \times 62) - (26,451 \times (1-.55))] \times 52/774 = 259.3$ Holiday shutdown savings = $[(254.2 \times 38) - (26,451 \times (1-.70))] \times 6/774 = 13.3$ total = 367.4 cf/yr

C

APPENDIX A.1

·.•.

BLANK FORMS

BUILDING DESCRIPTION DATA

()

BUILDING NUMBER:
BUILDING DESCRIPTION:
GROSS AREA (SQUARE FEET):
NUMBER OF FLOORS:
TYPE CONSTRUCTION:
APPROX. FLOOR TO FLOOR HEIGHT (FT):
GLASS TYPE:
CRITICAL AREAS:
OCCUPANCY SCHEDULE:

SYSTEM DESCRIPTION DATA	BUILDING NUMBER
SYS #	
ТҮРЕ	
MFGR. MOD. #	MFGR. MOD. #
CAPACITY	
HP (TYPE)	HP (TYPE)
HP (TYPE)	
HP (TYPE)	HP (TYPE)
AREA SERVED	AREA SERVED
CONTROLS	CONTROLS
NOTES:	NOTES:
SYS #	SYS #
TYPE	
MFGR. MOD. #	
CAPACITY	
HP (TYPE)	HP (TYPE)
HP (TYPE)	HP (TYPE)
HP (TYPE)	HP (TYPE)
AREA SERVED	AREA SERVED
CONTROLS	CONTROLS
NOTES:	
	135.

.

((

•

CLIMATE - BASED FACTORS

•

LOCATION:

· .

SYMBOL	DESCRIPTION	PAGE REF.	VALUE	UNITS
ACWT	Average Condenser Water Temperature	16		°F
AND	Annual Number of Days for Warmup	18		Days/Yr.
AST*	Average Summer Temperature	19		°F
AWT*	Average Winter Temperature	19		°F
CFLH	Annual Equiv. Full-Load Hrs. For Cooling	20		Hrs/Yr.
HFLH	Annual Equiv. Full-Load Hrs. for Heating	22		Hrs/Yr.
HS	Hrs. of Temp. Limit Shut-off for Summer	23		Ers/Yr
HW	Hrs. of Temp. Limit Shut-off for Winter	23		Ers/Yr
OAH*	Average Outside Air Enthalpy	24		Btu/lb.
PRT*	Percent Run Time for Low Temp. Limit	25		7
WKS*	Weeks of Summer	27		Wks/Yr.
WKW*	Weeks of Winter	27		Wks/Yr.

* Data not necessary if computer methods are used.



	BUILDING	-SPECIFIC FACTORS		
	BUILDING:			
* BTT = Buildin	g Thermal Transmissio	n		
	or X exterior area) +)/Total Floor	r Area
	_Btu/hr°F-ft ² X			
			1.00//	
	n Time of Equipment f			
Heating De	gree Days =	°F-days		
Combined U	-factor, Uo =	Btu/hr°F-ft ²		
From Figur	e 9 or 10 :	ERT =	hr/yr	
Primary Sources	of Cooling Medium			
Sys. No	System Type	Systems Served	CPT	
<u> </u>			. <u></u>	
- <u></u> .			· · · · · · · · · · · · · · · · · · ·	
Primary Sources	of Heating Medium			
Sys. No	System Type	Systems Served	HEFF	HV
- <u></u> .				
·				
- <u></u> .				<u> </u>

* Data not necessary if computer method is used.

PRIMARY SYSTEM SAVINGS CALCULATIONS AND COSTS

T

BUILDING NO. SYSTEM NO. SYSTEM TYPE

		SAVINGS	
FUNCTION	SAVINGS CALCULATIONS	KW KWH MH	COST
Scheduled Start/Stop	Clg: x Btu/ft ² hr °F x ft ² x(168 -) x x /ton Htg: x Btu/ft ² hr °F x ft ² x(168 -) x x /(x / Aux: x hp x (168 -) x x /(x)		BASIC FUNCTIONS
Duty Cycling	Aux: x hp xhr		
Demand Limit	ки: х ћр		
Optimum Start/Stop	WU Aux: x hp x((hr x) - hr)x days/wk CD Aux: x hp x (hr75) x days/wk		[]
OA Limit	Aux: x hp x (+)		
Run Time	Labor: 2 Manhours		
HW OA Reset	Htg: hr/yr x x Btu/hr/(x)		
Boiler Opt.	Htg: hr/yr x x Btu/hr/(x)		
Chiller Opt.	Clg: hr/yr x /ton x T x 0.01		
CHW Reset	Clg:hr/yr x/ton xT x/°F x 2°F		
Cond. Reset	Clg:hr/yr x/ton x T x ()		
Chiller Demand Kw:	Kw: 0.0414 x hp		
Safety Alarms	Labor: 2 Manhours		
	TOTALS FOR SYSTEM		

.

SECONDARY SYSTEM SAVINGS CALCULATIONS AND COSTS

a set of the state of the set of

-

-

-

BUILDING NO. SYSTEM NO.

SYSTEM TYPE

			SAVINGS	┢	ſ
FUNCTION	SAVINGS CALCULATIONS	ΚM	I KWH	HW	COST
Scheduled Start/Stop	Clg: x Btu/ft ² hr ^o F x ft ² x(168 -) x / ton Htg: x Btu/ft ² hr ^o Fx ft ² x(168 -) x / (x / ton V-Clg: x cfm x x (168 -) x / (x / ton V-Htg: x bfm x (168 -) x Aux: x hp x (168 -) x				BASIC FUNCTIONS
Duty Cycling	Aux: x hp x hr	 		 r	
Demand Limit	KW: x hp				
Optimum Start/Stop	WU Aux: x hp x ((hr x) - hr)x days/wk CD Aux: x hp x (hr75) x days/wk				
OA Limit	Aux: x hp x (+)				_
Run Time	Labor: 2 Manhours				
Ventilation/ Recirculation	WU V-htg: x cfm x x (25)/(x) V-clg: x cfm x x((-(.25x dy/wk)) x /ton V-htg: x cfm x x((-(.25x dy/wk))/(x))/(x)				
Economizer	(Computer simulation required.)			 	
Day/Night Setback	Clg: x Btu/ft ² hr°Fx ft ² x °F x (168 -) x / ton Htg: x Btu/ft ² hr°Fx ft ² x °F x (168 -)/(x / ton			 	
Reheat Coil Reset	Clg: x hr/wk x cfm x /ton Htg: x hr/wk cfm °F (x (x)			 	
Hot/Cold Deck Reset	Clg: x hr/wk x cfm x x °F x /ton Htg: x hr/wk x cfm x x(x + x)/(x)			 	
Safety Alarms	Labor: 2 Manhours			 	
	TOTALS FOR SYSTEM			 	

 :

.....

-1

APPENDIX A.2

1990 - P. S.

.

WET BULB (°F)	ENTHALPY (Btu/1b)	WET_BULB (°F)	ENTHALPY (Btu/lb)
40.0	15.20	70.0	34.00
41.0	15.66	71.0	34.86
42.0	16.14	72.0	35.74
43.0	16.62	73.0	36.64
44.0	17.11	74.0	37.56
45.0	17.61	75.0	38.50
46.0	18.12	76.0	39.47
47.0	18.64	77.0	40.46
48.0	19.17	78.0	41.47
49.0	19.71	79.0	42.50
50.0	20.26	80.0	43.57
51.0	20.82	81.0	44.65
52.0	21.39	82.0	45.77
53.0	21.97	83.0	46.91
54.0	22.57	84.0	48.08
55.0	23.17	85.0	49.28
56. 0	23.79	86.0	50.52
57.0	24.42	87.0	51.78
58.0	25.07	88.0	53.07
59.0	25.73	89.0	54.40
60.0	26.40	90.0	55.76
61.0	27.09	91.0	57.16
62.0	27.79	92.0	58.59
63.0	28.51	93.0	60.06
64.0	29.24	94.0	61.57
65.0	29.99	95.0	63.12
66.0	30.76	96.0	64.70
67.0	31.54	97.0	66.33
68.0	32.34	98.0	68.01
69.0	33.16	99 .0	69.73
		100.0	71.49

ENTHALPY OF AIR AT GIVEN WET BULB TEMPERATURES

· - · · ·

• •

APPENDIX A.3

.

.

. . .

-

•

VARIABLE GLOSSARY

A	=	surface area of tank in ft ²
ACWT		average condenser water temperature possible, in °F
		(See page 16)
AEI	=	adjusted efficiency increase of the chiller due to
		condenser water reset
AND	=	annual number of days total that warmup is required
		in days per year (see page 18)
AST	=	average summer temperature in °F (see page 19)
AWT	=	average winter temperature in °F (see page 19)
AZ	=	area of zone being servied in ft ²
BTT	=	building thermal transmission in Btu/hr°F-ft ² (see
		page 28)
CAP	=	maximum capacity of device(s) in Btu/hr
CD	=	fraction of total air passing through the cold
		deck. Assume .50 if no other information is avail-
		able.
CFLH	=	equivalent full-load hours for cooling in hours/
		year (see page 20)
CFM	±	air handling capacity in ft ³ /min
CH	=	present cool-down time before occupancy in hours
		per day. Use either the actual time presently
		scheduled for cool-down by an existing timeclock or
		2 hours to correspond to Scheduled Start/ Stop
		savings calculations
CPT	=	energy consumption per ton of refrigeration in
		kw/ton or lb/ ton-hr (see page 30)
D	=	diameter of tank in ft.
DAY	=	equipment operation in days per week
E	=	parameter determined from Figure 11
EI	=	efficiency increase expressed as a decimal
	-	
ERT	=	equipment run time, total required for warm up in hours per year (see page 30)

F	=	fraction of savings attributable to EMCS (see page
•	-	42)
н	=	hours of operation per week.
HD	=	fraction of total air passing through the hot deck.
		Assume .50 if no other information is available.
HEFF	=	heating efficiency of the system (see page 31)
HFLH	=	annual equivalent full load hours for heating in
		hours/year (see page 22)
HP	=	motor nameplate horsepower
HS	=	hours in summer outside temperature is below summer
		limit in hours per year (see page 23)
HT	=	height of tank in ft.
HV	=	heating value of fuel in Btu/gal, Btu/kwh etc. (see
		page 32)
HW	=	hours in winter outside temperature is above winter
		limit in hours per year (see page 23)
INS	=	thickness of insulation in inches
KW	=	total kw consumption of lights in the zone
L	=	load factor (see page 35)
LSD	=	length of shutdown period in hours
LTL	=	low temperature limit in °F; usually 50°F or 55°F.
		Use the average winter temperature in place of LTL
		if AWT > LTL.
NSD	=	number of shutdown periods per year of a given
		length
OAH	×	average outside air enthalpy in Btu/lb (see page
		24)
PCWT	ź	present condenser water temperature in °F usually
		set at 85°F
PEI	=	percent efficiency increase of the chiller
POA	=	present percent minimum outside air expressed as a
		decimal
PRT	=	percent run time during heating season shutdown
		period required to maintain a low limit temperature
		of 55°F (see page 25). Use PRT = 0 if no low
		temperature limit is planned.

.

.

۰.

.

٠.

-

-

.

- RAH = return air enthalpy. Use 29.91 Btu/lb for 78°F and 50% humidity. For other conditions obtain values from a psychrometric chart.
- RCWT = reduction in condenser water temperature which is achievable, in °F
- REI = rate of efficiency increase per °F increase of chilled water temperature
- RHR = reheat system cooling coil discharge reset in °F. Up to 5° or 6° is possible, dependent on the system. If a better estimate of possible reset is not available use 3°F.
- SCDR = summer cold deck reset in °F (the average reset that will result from this function is dependent on the air handler capacity relative to the loads in the space it serves. If an estimate of the possible reset is not available use 3°F)
- SD = thermostat setdown for unoccupied periods during the heating season in °F
- SHDR = summer hot deck reset in °F (the average reset that will result from this function is dependent on the air handler capacity relative to the loads in the space it serves. If an estimate of the possible reset is not available use 3°F)
- SSP = summer thermostat setpoint in °F
- SU = thermostat setup for unoccupied periods during the cooling season in °F
- T = water temperature at end of shutdown period in °F
- To = hot water temperature setpoint in °F
- **TON** = chiller capacity in tons

- **Ts** = average temperature of surroundings in °F
- UH = unoccupied hours per week
- V = volume of tank in ft³
- WH = present warmup time before occupancy in hours per day

WHDR = winter hot deck reset in °F

WKS	=	length of summer cooling season in weeks per year
		(See page 27)
WKW	=	length of winter heating season in weeks per year
		(see page 27)
WSP	=	winter thermostat setpoint in °F

.

· -

-

È

