

AD-A125 423

ELECTRICAL RESISTANCE TESTING OF ANTISTATIC BENCH AND
FLOOR SURFACE MATERIAL AFTER LAYING(U) MATERIALS
RESEARCH LABS ASCOT VALE (AUSTRALIA)
M G WOLFSON ET AL. AUG 82 ARL-TN-466

1/1

UNCLASSIFIED


F/G 14/2

NL

END

FILMED

DTIC



MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS-1963-A



AD A1 25423

DEPARTMENT OF DEFENCE SUPPORT
DEFENCE SCIENCE AND TECHNOLOGY ORGANISATION
MATERIALS RESEARCH LABORATORIES
MELBOURNE, VICTORIA

TECHNICAL NOTE

MRL-TN-466

ELECTRICAL RESISTANCE TESTING OF ANTISTATIC BENCH
AND FLOOR SURFACE MATERIAL AFTER LAYING

Michael G. Wolfson and Kenneth J. Lee

Approved for Public Release

DTIC FILE COPY



DTIC
SELECTED
MAY 09 1983
E

© COMMONWEALTH OF AUSTRALIA 1982

92 00 00 010

AUGUST 1982

DEPARTMENT OF DEFENCE SUPPORT
MATERIALS RESEARCH LABORATORIES

TECHNICAL NOTE

MRL-TN-466

ELECTRICAL RESISTANCE TESTING OF ANTISTATIC BENCH
AND FLOOR SURFACE MATERIAL AFTER LAYING

Michael G. Wolfson and Kenneth J. Lee

ABSTRACT

Large areas of floors and benchtops in the laboratories of the Explosives and Ammunition Composite at Materials Research Laboratories are covered with an antistatic material. Electrical resistance testing of this material after laying is reported. Testing was carried out in accordance with BS 2050:1961 and BS 3398:1961.

Approved for Public Release

© COMMONWEALTH OF AUSTRALIA 1982

POSTAL ADDRESS: Chief Superintendent, Materials Research Laboratories
P.O. Box 50, Ascot Vale, Victoria 3032, Australia

DOCUMENT CONTROL DATA SHEET

REPORT NO. MRL-TN-466	AR NO. AR-003-047	REPORT SECURITY CLASSIFICATION UNCLASSIFIED
--------------------------	----------------------	--

TITLE
ELECTRICAL RESISTANCE TESTING OF ANTISTATIC BENCH
AND FLOOR SURFACE MATERIAL AFTER LAYING

AUTHOR(S) Wolfson M.G. and Lee K.J.	CORPORATE AUTHOR Materials Research Laboratories P.O. Box 50, Ascot Vale, Victoria 3032
---	--

REPORT DATE August, 1982	TASK NO.	SPONSOR
-----------------------------	----------	---------

CLASSIFICATION/LIMITATION REVIEW DATE	CLASSIFICATION/RELEASE AUTHORITY Superintendent, MRL Physical Chemistry Division
---------------------------------------	--

SECONDARY DISTRIBUTION

Approved for Public Release

ANNOUNCEMENT

Announcement of this report is unlimited

KEYWORDS	Electrical Resistivity Antistatic Techniques Floor Coverings Surface Properties	Surface Finishing Tests Surface Resistance
----------	--	--

COSATI GROUPS	20030	13130
---------------	-------	-------

ABSTRACT

Large areas of floors and benchtops in the laboratories of the Explosives and Ammunition Composite at Materials Research Laboratories are covered with an antistatic material. Electrical resistance testing of this material after laying is reported. Testing was carried out in accordance with BS 2050:1961 and BS 3398:1961.

Accession For

NTIS GRA&I DTIC TAB Unannounced

Justification _____

By _____
Distribution/

Availability Codes

Dist	Avail and/or Special
------	-------------------------

A

C O N T E N T S

	<u>Page No.</u>
1. INTRODUCTION	1
2. LOCATIONS	1
3. TEST SPECIFICATIONS	1
4. TEST METHODS AND CRITERIA	2
4.1 <i>Antistatic Bench and Floor Surface Material After Laying</i>	2
4.2 <i>Equipment Mounted on Antistatic Surfaces</i>	2
5. TEST EQUIPMENT	2
5.1 <i>Insulation Tester</i>	2
5.2 <i>Electrodes and Conducting Solution</i>	2
6. MEASUREMENT PROCEDURE	3
7. RESULTS	3
7.1 <i>Floors and Fixed Benches</i>	3
7.2 <i>Free Standing Benches</i>	3
7.3 <i>Equipment</i>	4
8. CONCLUSIONS AND RECOMMENDATIONS	4
9. REFERENCES	5
APPENDIX A	10
APPENDIX B	11

ELECTRICAL RESISTANCE TESTING OF ANTISTATIC BENCH
AND FLOOR SURFACE MATERIAL AFTER LAYING

1. INTRODUCTION

At MRL, within the Explosives and Ammunition (E&A) Composite, there is a large number of laboratories and workrooms where the floors and benchtops are covered with "Tarkett" PVC/carbon sheet antistatic material. It was noted in May 1979 by the E&A Composite Explosives Safety Committee during a routine inspection "that some of the benches with antistatic covering were not apparently earthed".

Upon further investigation it became apparent that testing of many floors and benchtops with antistatic covering had either never been performed or the results of any testing were not available. It was therefore decided that the earth resistance for all antistatic floors and benchtops in the E&A Composite be measured. It was also decided to include the measurement of earth resistance between some "explosive process" equipment mounted on antistatic floors or benchtops and the existing earth strap.

2. LOCATIONS

A list of buildings, bays and rooms, having benchtops and/or floors surfaced with antistatic material, was compiled in July 1979 (Appendix A). A photograph of a typical workroom is shown in Fig. 1.

3. TEST SPECIFICATIONS

Specifications for tests based on BS 2050:1961 [1], BS 3398:1961 [2] and AS 1020:1970 [3]. AS 1020:1970 refers to BS 2050:1961 for methods of determining the electrical resistance of conductive and antistatic articles.

4. TEST METHODS AND CRITERIA

4.1 Antistatic Bench and Floor Surface Material After Laying

- (a) Tested between dry electrodes spaced 610 mm \pm 13 mm apart on the antistatic surface.
Requirements: Average resistance not greater than $2 \times 10^6 \Omega$, no single result greater than $5 \times 10^6 \Omega$.
- (b) Tested between a wet electrode on the antistatic surface and the existing earth strap.
Requirements: Average resistance not less than $5 \times 10^4 \Omega$, no single result less than $2 \times 10^4 \Omega$.
- (c) Tested between a dry electrode on the antistatic surface and the existing earth strap.
Requirements: No specific requirements as this test is not required by British Standard Specifications. However it was considered that this test would best represent actual conditions.

4.2 Equipment Mounted on Antistatic Surfaces

Tested between the existing earth strap and the "explosive process" equipment. Measurement points used on equipment were typically handles or surfaces which would come into contact with explosives or personnel.

5. TEST EQUIPMENT

5.1 Insulation Tester

The insulation tester used was a Record Minor (Ref. No. 5G/203). This instrument generates 500 to 1000 V AC into a $15 \times 10^4 \Omega$ load.

5.2 Electrodes and Conducting Solution

Electrodes were manufactured and a conducting solution prepared in accordance with BS 2050 and BS 3398:1961 [1,2].

6. MEASUREMENT PROCEDURE

Each bay or room was measured and a floor plan drawn, then resistance measuring points determined in accordance with BS 3398:1961 [2]. Two electrodes were placed 610 mm apart on the antistatic surface being tested and a resistance reading taken using the insulation tester.

Resistance measurements were also taken between the antistatic surface and the earth strap in the bay. In this case one electrode was placed on the antistatic surface while the other side of the insulation tester was connected through an alligator clip to the earth strap. Separate measurements were taken using both wet and dry electrodes. For the wet electrode the measurement point on the antistatic surface was wetted with a conducting solution (Ref. 5.2).

Results from all measuring points were tabulated and the average values of resistance for the floor and benchtops in each bay determined.

7. RESULTS

A visual check showed all floors and benchtops to be in apparently good condition except in Bldg. 670, Bay 6. Here, a weld on the east benchtop was faulty and the floor covering under the west bench was lifting.

The results of the resistance measurements are summarised in Tables 1 and 2. For details of floor plans, measuring points and resistance measurements see Appendix B.

7.1 Floors and Fixed Benches

All floors and benches covered with antistatic material were within the specification [2] except Bldg. 670, Bay 6, Explosives Casting Bay, where floors and benchtops had apparently been waxed. Preliminary measurements here gave values of resistance in excess of $10^7 \Omega$.

The floors and benchtops in Bldg. 670, Bay 6 were subsequently machine scrubbed using "Ajax" and "Bon Ami". Further resistance testing gave improved results but they still failed to meet the specifications. Further hand cleaning of the measuring points using "Ajax" was required before satisfactory test results were obtained.

7.2 Free Standing Benches

The locations of free standing benches, covered with antistatic material, which were not earthed are listed below:

Bldg. 670/5
Bldg. 675/3 and 4
Bldg. 697/12

These bench tops gave readings of infinity when tested between the antistatic surface material and the earth strap.

7.3 Equipment

Several bays contained equipment, used in explosive processes, which had no direct connection to an earth point, but instead relied on conduction through the antistatic floor or benchtop material on which the particular equipment was standing. Table 3 lists this equipment along with locations and test results.

8. CONCLUSIONS AND RECOMMENDATIONS

1. Most antistatic floors and benchtops tested were well within the specification except those in Bldg. 670/6. In this bay further cleaning of the antistatic surfaces will be required before compliance with BS 3398:1961 [2] is achieved. Clearly, any special surface treatment such as waxing should be avoided. If any such treatment is contemplated then tests to determine the suitability of the treatment should be performed.

2. Results from floors and benchtops laid *circa* 1972 (eg. Bldgs. 613, 666 and 670) are comparable with results from those laid *circa* 1978 (eg. Bldgs. 675 and 697). This suggests that there has been negligible deterioration of the older antistatic material or in the bonding between it and the earthing straps.

3. Those free standing benches covered with antistatic material but not earthed should be connected to an earth strap and re-tested before they are used for explosives work.

4. If equipment standing on antistatic floors or benchtops is required to be earthed then a proper connection to the earth strap should be provided.

5. Although it is obviously desirable for periodic testing of all antistatic floors and benchtops to be performed it should be realised that testing in accordance with BS 3398:1961 [2] is very time consuming. The testing reported here is estimated to have taken two (2) man months, and since that time, with Bldgs. 505, 671 and 1078 having been completed, the area of antistatic surfaces in the E&A Composite has probably doubled. Therefore a system of spot checking may be more appropriate.

9. REFERENCES

1. British Standards Institution (1961). BS 2050:1961 "Specification for Electrical Resistance of Conductive and Anti-Static Products made from Flexible Polymeric Material".
2. British Standards Institution (1961). BS 3398:1961 "Specification for Anti-Static Rubber Flooring".
3. The Standards Association of Australia (1970). AS 1020:1970 "The Control of Undesirable Static Electricity" known as the SAA Static Electricity Code.

TABLE 1

SUMMARY OF SURFACE MEASUREMENTS

Location (Bldg/Bay)	Average Resistance (k Ω)	
	Floor	Bench Top
613	608	837
671/10	517	475
670/5	561	783
670/6 *	892	900
675/2	545	1088
675/3	594	313
675/4	670	860
675/5	575	790
675/6	550	500
675/7	579	590
675/9	660	575
697/1	500	-
697/2	644	688
697/4	537	783
697/6	469	750
697/8	410	660
697/12	430	733
666/15	587	425
914	683	775

* Results obtained after hand cleaning measuring points with "Ajax"

TABLE 2

SUMMARY OF SURFACE TO EARTH STRAP MEASUREMENTS

Location (Bldg/Bay)	Average Resistance (k Ω)			
	Dry		Wet	
	Floor	Benchtop	Floor	Benchtop
613	224	300	90	188
671/10	223	250	133	185
670/5	225	983	103	880
670/6 *	305	294	149	400
675/2	259	467	132	300
675/3	193	375	112	300
675/4	220	565	100	194
675/5	283	380	132	170
675/6	231	285	144	180
675/7	238	270	131	153
675/9	250	275	134	150
697/1	309	-	94	-
697/2	306	294	138	189
697/4	231	383	112	175
697/6	169	417	85	183
697/8	167	315	103	195
697/12	190	325	90	200
666/15	220	210	107	182
914	303	368	143	206

* Results obtained after hand cleaning measuring points with "Ajax"

TABLE 3

EQUIPMENT NOT DIRECTLY EARTHED

Location	Equipment Description	Earth Resistance (Ω)
Bld 675/6	Air operated lathe	10^5
Bld 675/7	Explosive magazine	4×10^4
Bld 675/4	Press against east wall	4×10^4
Bld 675/4	Press against north wall	7×10^4
Bld 675/4	Press against west wall	175×10^4
Bld 675/3	Cabinet against west wall on free standing bench	Infinity
Bld 675/2	Cabinet against west wall	35×10^3
Bld 675/2	Mixing and Pouring device	60×10^3
Bld 697/2B	Propellant grinder against north wall; earth strap provided but not connected	15×10^4
Bld 697/4	Rotter Impact Tester	10^4
Bld 697/4	Ignition Bath	Infinity




Fig. 1. Photograph of explosive charge preparation room showing antistatic floor and benchtop, with earthing straps on wall.

APPENDIX A

List of Buildings and Bays where resistance testing of floors and bench tops covered with antistatic material was carried out.

Bld 613 Charge Preparation Room

Bld 666/15 Gap Test Firing Area

Bld 670/5 and 6

Bld 671/10

Bld 675/2, 3, 4, 5, 6, 7 and 9

Bld 697/1, 2, 4, 6, 8, 12

Bld 914

APPENDIX B

Details of floor plans, measuring points and tables of all resistance measurements.

ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)		BENCHTOP
	FLOOR	BENCHTOP	
1			
2		800	
3	440		
4			
5	400		
6	W		
7		750	
8			
9	500		
10			
11	800		
12	W		
13	900		
14			
15		800	
16			
17		1000	
18			
MEAN:	608		837


SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2		340	190
4	160		80
6	250		100
8		320	170
10	150		70
12	400		130
14	160		70
16		240	140
18		300	250
MEAN:	224	300	90
			188

BLDG. 613

BAY/ Charge Prep.

TESTER K. Lee

DATE 16/4/80





ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (k Ω)	
	FLOOR	BENCHTOP
1		
2		350
3	500	
4	460	
5	400	
6	700	
7		
8		
9		
10		
11		500
12		
13	1000	
14 W	450	
15 W	600	
16 W		
17		
18 W		
MEAN:	587	425

BLDG. 666 BAY/15 Gap Test Area

SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (k Ω)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2		200		175
4	200		100	
6	160		100	
8	190		75	
10	170		100	
12		220	130	190
14	400		130	
16	120		70	
18	300		150	
MEAN:	220	210	107	182

TESTER K. Lee DATE 18/1/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)		BENCHTOP
	FLOOR	BENCHTOP	
1	W	500	
2	W	500	
3	W	500	
4	W	500	
5	TROUGH	500	
6	TROUGH	500	
7	W	600	
8	W	600	
9	W	600	
10	W	600	
11	W	600	850
12	W	600	850
13	W	600	
14	W	600	
15	TROUGH	600	
16	TROUGH	600	
17	TROUGH	600	
18	TROUGH	600	700
19	W	500	
20	W	500	
21	W	800	
22	W	800	
23	W	700	
24	W	700	
25	W	350	
26	W	350	
27	W	350	
28	W	350	
MEAN:		561	783


SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2	200		100	
4	200		120	
8	200		120	
10	150		90	
12		2500		2500
14	250		100	
18		200		60
20	200		80	
22	300		120	
24		250		80
26	400		100	
28	400		100	
MEAN:	255	983	103	880

BLDG. 670

BAY/5

TESTER Lee/Stewart/Irvine

Date 1/4/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1	2 W	350	
3	4 W		700
5	6 W	850	
7	8 FAULTY WELD		1000
9	10 W		1000
11	12 W	500	
13	14 W	650	
17	18 W	2000	
19	20	1000	
15 & 16	BENCH OBSTRUCTION		
MEAN:		892	900


SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2	150		100
4		300	250
6	500		150
8		350	300
10		600	650
12	175		125
14		200	70
18	500		300
20	200		
MEAN:	305	294	149
			400

BLDG. 670

BAY/6

TESTER K. Lee

DATE 1/4/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)		BENCHTOP
	FLOOR	BENCHTOP	
1	2 W	800	500
3	4		
5	6 W x 2	400	
7	8 W	350	
9	10		450
MEAN:		517	475



SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		BENCHTOP
	DRY		
	FLOOR	BENCHTOP	
2	300	150	
4		300	200
6	170	100	
8	200	150	
10		200	170
MEAN:		223	133
		250	185

BLDG. 671

BAY/10

TESTER K. Lee

DATE 1/4/80




ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1			
2	Metal Sink		600
3			1000
4			1000
5			
6			
7	W	350	
8	W	350	
9	W x 2	700	
10	W	500	
11	W	350	
12	W	500	
13	W	500	
14	W	500	
15	W	700	
16	W	500	
17	W	500	
18	W	500	
19	W	500	
20	W	1000	
21	W	500	
22	W	500	
23	W	1750	
24	W		
25	W		
26	W		
27	NO READING		
28	TAKEN DUE TO BENCH		
29	OBSTRUCTION		
30			
MEAN:		545	1088

SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2		600	
4		600	
6		200	
8	250		300
10	250		250
12	175		100
14	200		75
16	100		70
18	200		80
20	200		100
22	175		75
24	300		100
26	800		450
30	200		150
MEAN:	259	467	132
			300

BLDG. 675 BAY/2 TESTER K. Lee DATE 3/3/80





ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS	
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)
	FLOOR BENCHTOP
1	
2 W	275
3	350
4	
5	700
6 W	
7	500
8 W	
9	500
10 W	
11	400
12 W	
13	500
14 W	
15	450
16 W	
17	700
18 W	
19	800
20 W	
21	800
22 W	
MEAN:	594
	313

BLDG. 675 BAY/3

SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2		275	
4		475	
6	150		100
8	150		90
10	155		100
12	100		100
14	130		90
16	150		100
18	275		125
20	250		150
22	375		150
MEAN:	193	375	112
			300

TESTER K. Lee DATE 3/3/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1	2 W	1000	
3	4		800
5	6		900
7	8 W	600	
9	10		500
11	12 W	450	
13	14	500	
15	16		900
17	18		1200
19	20 W	800	
MEAN:		670	860


BLDG. 675

BAY/4

SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		BENCHTOP
	DRY		
	FLOOR	BENCHTOP	
2	175		100
4		400	200
6		375	175
8	200		100
10		900	220
12	225		100
14	300		100
16		450	250
18		700	220
20	200		100
MEAN:		220	194
		565	100

TESTER K. Lee

DATE 3/3/80





ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1 2			800
3 4 W	550		
5 6 W	550		
7 8		350	
9 10 W	500		
11 12		1000	
13 14 W	450		
15 16 W	500		
17 18 Cup. in way			
19 20			900
21 22 W	900		
23 24			900
MEAN:	575		790

SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2		350	
4	300		175
6	200		125
8		150	125
10	150		90
12		500	175
14	300		150
16	200		100
20		450	175
22	550		150
24		450	150
MEAN:	283	380	132

BLDG. 675 BAY/5 TESTER K. Lee DATE 3/3/80

BLDG. 675 BAY 5



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1 2 W	500		
3 4 W	600		
5 6		500	
7 8 W	600		
9 10 W	500		
11 12 Lathe in way			
13 14		650	
15 16		350	
17 18		750	
19 20		250	
MEAN:	550		500



SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2	200		150	
4	175		150	
6		250		150
8	350		175	
10	200		100	
14		350		200
16		300		200
18		350		200
20		175		150
MEAN:	231	285	144	180

BLDG. 675

BAY/6

TESTER K. Lee

DATE 3/3/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)		BENCHTOP
	FLOOR	BENCHTOP	
1	2	W x 2	
3	4	W	600
5	6		600
7	8		650
9	10	W	800
11	12	W	400
13	14		600
15	16	W	600
17	18		600
19	20		500
21	22	W x 2	475
MEAN:			579
MEAN:			590


BLDG. 675

BAY/7

SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2	275		160	
4	225		100	
6		250		150
8		250		140
10	400		200	
12	175		115	
14		300		180
16	150		100	
18		300		150
20		250		145
22	200		110	
MEAN:			238	131
MEAN:			270	153

TESTER K. Lee

DATE 3/3/80





ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1 2 W	600		
3 4 W	1000		
5 & 6 NON ANTI STATIC BENCH			
7 8	600		
9 10		600	
11 12		550	
13 14	600		
15 16	500		
MEAN:	660		575

BLDG. 675 BAY/9

SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		BENCHTOP
	DRY		
	FLOOR	BENCHTOP	
2	250		
4	350		
8	250		
10		250	150
12		300	150
14	200		110
16	200		150
MEAN:	250	275	134

TESTER K. Lee DATE 3/3/80



ANTISTATIC FLOOPS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			
	FLOOR	BENCHTOP	
1	2 W	450	
3	4 W	600	
5	6 W	500	
7	8 W	400	
9	10 W	500	
11	12 W	500	
13	14 W	450	
15	16 W	600	
MEAN:		500	


SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2	275		100
4	375		100
6	120		80
8	150		60
10	175		80
12	150		70
14	175		70
16	250		90
Bench Top 17			200
MEAN:	209		94

BLDG. 697

BAY/1

TESTER K. Lee

DATE 3/3/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1 2	850		
3 4, 5 6, 7 8, 9 10			
NO ANTI-STATIC FLOOR			
11 12		700	
13 14 W	750		
15 16 W	400		
17 18		650	
19 20	800		
21 22 W	700		
23 24 W	750		
25 26		650	
27 28		750	
29 30	500		
31 32 W	700		
33 34 W	350		
MEAN:	644		688

SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2	175		125	
12		275		170
14	450		175	
16	150		80	
18		300		200
20	400		125	
22	425		150	
24	325		185	
26		300		185
28		300		200
30	300		100	
32	275		180	
34	250		125	
MEAN:	306	294	138	189



BLDG. 697

BAY/2

TESTER K. Lee

DATE 4/3/80

BLDG. 697 BAY 2



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)		BENCHTOP
	FLOOR	BENCHTOP	
1			
2	W		
3	4	325	
4	W	400	
5	6	450	
7	8		
8	Wall		
9	10		750
11	12	800	
13	14	500	
15	16		850
17	18	800	
19	20	700	
21	22	500	
23	24		600
25	26		800
27	28	450	
29	30	300	
31	32	450	
33	34		800
35	36	700	
37	38	600	
39	40		900
MEAN:		537	783

SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
2	200		125
4	125		70
6	150		80
10		400	150
12	450		175
14	150		70
16		550	200
18	350		175
20	250		150
22	200		80
24		300	200
26		350	200
28	200		100
30	125		60
32	150		70
34		350	150
36	350		150
38	300		150
40		350	150
MEAN:	231	383	112
			175


BLDG. 697

BAY/4

TESTER K. Lee

DATE 3/3/80

BLDG. 697 BAY 4



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)	
	FLOOR	BENCHTOP
1		
2	W	
3	W	
4	W	
5		1000
6		
7	W	
8	W	
9	W	
10	W	
11		550
12		
13		700
14		
MEAN:	469	750


SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2	125		70	
4	125		85	
6		500		150
8	125		60	
10	300		125	
12		350		150
14		400		250
MEAN:	169	417	85	183

BLDG. 697

BAY/6

TESTER K. Lee

DATE 4/3/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
15	16		650
17	18	W	300
19	20		800
21	22	W	500
23	24	W	350
25	26		500
27	28	W	500
29	30		700
31	32	W	400
33	34		700
MEAN:		410	660


SURFACE TO EARTH STRAP MEASUREMENTS			
SURFACE POINTS	RESISTANCE (kΩ)		
	DRY		WET
	FLOOR	BENCHTOP	FLOOR
16		275	200
18	150		90
22	200		125
20		300	175
24	110		75
26		250	175
28	177		125
30		375	225
32	200		100
34		375	200
MEAN:		167	315
		103	195

BLDG. 697

BAY/8

TESTER K. Lee

DATE 4/3/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		RESISTANCE (kΩ)	
MEASUREMENT POINTS (W = ACROSS WELD)			BENCHTOP
	FLOOR		
1			
2			600
3			1000
5	W	500	
7	W	400	
9	W	500	
11	TABLE		600
13	W	400	
15	W	350	
MEAN:		430	733


SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2		300		225
4		350		175
6	200		100	
8	175		100	
10	225		80	
12	TABLE NOT EARTHED			
14	150		90	
16	200		80	
MEAN:	190	325	90	200

BLDG. 697

BAY/12

TESTER K. Lee

DATE 4/3/80



ANTISTATIC FLOORS AND BENCHTOPS - RESISTANCE TESTS

SURFACE MEASUREMENTS		
MEASUREMENT POINTS (W = ACROSS WELD)	RESISTANCE (kΩ)	
	FLOOR	BENCHTOP
1		
2	250	
3		
4	W x 2	
5	600	
7	900	
9	700	
11	800	
13		700
15		1200
17		350
19		850
21		700
23		850
MEAN:	683	775


SURFACE TO EARTH STRAP MEASUREMENTS				
SURFACE POINTS	RESISTANCE (kΩ)			
	DRY		WET	
	FLOOR	BENCHTOP	FLOOR	BENCHTOP
2	120		80	
4	450		200	
6	300		140	
8	400		160	
10	300		150	
12	250		130	
14		400		250
16		500		180
18		260		200
20		350		170
22		350		250
24		350		190
MEAN:	303	368	143	206

BLDG. 914



BAY/ROOM

TESTER K. Lee

DATE 15/4/80



TOP BENCH



FLOOR & BOTTOM BENCH



DISTRIBUTION LIST

MATERIALS RESEARCH LABORATORIES

Director, Materials Research Laboratories
Superintendent, Physical Chemistry
Head, E&A Composite
Dr B.W. Thorpe
Dr G.J. Jenks
Mr J. Howe
Mr J. Bentley
Mr P. Ramsay
Mr R. Bird
Mr D.J. Pinson
Mr F.G.J. May
Library
Mr M.G. Wolfson
Mr K.J. Lee
Safety Officer
Secretary, E&A Explosives Safety Committee
Engineer, Building and Services (Attn. Mr J. Hilton)

DEPARTMENT OF DEFENCE/DEFENCE SUPPORT

Chief Defence Scientist/Deputy Chief Defence Scientist/
Controller, Projects and Analytical Studies 1 copy
Superintendent, Science and Technology Programme
Controller Services Laboratories and Trials
Army Scientific Adviser
Air Force Scientific Adviser
Navy Scientific Adviser
Librarian, (Through Officer-in-Charge), Materials Testing
Laboratories, ALEXANDRIA, N.S.W.
Senior Librarian, Aeronautical Research Laboratories
Senior Librarian, Defence Research Centre Salisbury, S.A.
Officer-in-Charge, Document Exchange Centre (17 copies)
Technical Reports Centre, Defence Central Library
Central Office, Directorate of Quality Assurance - Air Force
Deputy Director Scientific and Technical Intelligence, Joint
Intelligence Organisation.
Librarian, Bridges Library
Defence Scientific & Technical Representative, (Summary Sheets Only)
Australia High Commission, London
Counsellor Defence Science (Summary Sheets Only)
(Attention: Dr J. Stals)
Head of Staff, British Defence Research & Supply Staff (Aust.)

OTHER FEDERAL AND STATE DEPARTMENTS AND INSTRUMENTALITIES

The Chief Librarian, Central Library, C.S.I.R.O.
Library, Australian Atomic Energy Commission Research Establishment

MISCELLANEOUS - OVERSEAS

Reports Centre, Directorate of Materials Aviation, England
Library - Exchange Desk, National Bureau of Standards, U.S.A.
UK/USA/CAN/NZ ABCA Armies Standardisation Representative (4 copies)
The Director, Defence Scientific Information & Documentation
Centre, India
Military, Naval and Air Adviser, High Commission of India,
Canberra
Director, Defence Research Centre, Kuala Lumpur, Malaysia
Exchange Section, British Library, U.K.
Periodicals Recording Section, Science Reference Library,
British Library, U.K.
Library, Chemical Abstracts Service
INSPEC: Acquisition Section, Institution of Electrical
Engineers, U.K.
Engineering Societies Library, U.S.A.

ADDITIONAL DISTRIBUTION

DRCS, Safety Officer
Secretary, Operational Safety Committee