

AD-A142 314

DENSIFIED REFUSE-DERIVED FUELS-OVERVIEW OF PRODUCTION  
PROCESSES AND COMBUSTION CHARACTERISTICS(U) NAVAL CIVIL  
ENGINEERING LAB PORT HUENEME CA B E SWAIDAN MAY 84  
NCEL-TN-1695

1/1


UNCLASSIFIED

F/G 13/2

NL

END

8-84



MICROCOPY RESOLUTION TEST CHART  
NATIONAL BUREAU OF STANDARDS-1963-A

DTIC FILE COPY

AD-A142 314  
JAVINHS  
TELL

TN NO: N-1695

TITLE: DENSIFIED REFUSE-DERIVED FUELS -  
OVERVIEW OF PRODUCTION PROCESSES  
AND COMBUSTION CHARACTERISTICS

AUTHOR: Brian E. Swaidan

DATE: May 1984

SPONSOR: Chief of Naval Material

PROGRAM NO: S0371-01-421E

# NOTE

NAVAL CIVIL ENGINEERING LABORATORY  
PORT HUENEME, CALIFORNIA 93043

Approved for public release; distribution unlimited.

DTIC  
ELECTE  
JUN 21 1984

84 06 19 122

# METRIC CONVERSION FACTORS


## Approximate Conversions to Metric Measures

Symbol	When You Know	Multiply by	To Find	Symbol
<b>LENGTH</b>				
m	inches	2.5	centimeters	cm
ft	feet	30	centimeters	cm
yd	yards	0.9	meters	m
mi	miles	1.6	kilometers	km
<b>AREA</b>				
m <sup>2</sup>	square inches	6.5	square centimeters	cm <sup>2</sup>
ft <sup>2</sup>	square feet	0.09	square meters	m <sup>2</sup>
yd <sup>2</sup>	square yards	0.8	square meters	m <sup>2</sup>
mi <sup>2</sup>	square miles	2.6	square kilometers	km <sup>2</sup>
acres	acres	0.4	hectares	ha
<b>MASS (weight)</b>				
oz	ounces	28	grams	g
lb	pounds	0.45	kilograms	kg
	short tons (2,000 lb)	0.9	tonnes	t
<b>VOLUME</b>				
tdp	teaspoons	5	milliliters	ml
tblsp	tablespoons	15	milliliters	ml
fl oz	fluid ounces	30	milliliters	ml
c	cups	0.24	liters	l
pt	pints	0.47	liters	l
qt	quarts	0.95	liters	l
gal	gallons	3.8	liters	l
ft <sup>3</sup>	cubic feet	0.03	cubic meters	m <sup>3</sup>
yd <sup>3</sup>	cubic yards	0.76	cubic meters	m <sup>3</sup>
<b>TEMPERATURE (exact)</b>				
°F	Fahrenheit temperature	5/9 (after subtracting 32)	Celsius temperature	°C



## Approximate Conversions from Metric Measures

Symbol	When You Know	Multiply by	To Find	Symbol
<b>LENGTH</b>				
mm	millimeters	0.04	inches	in
cm	centimeters	0.4	inches	in
m	meters	3.3	feet	ft
km	kilometers	1.1	yards	yd
		0.6	miles	mi
<b>AREA</b>				
cm <sup>2</sup>	square centimeters	0.16	square inches	in <sup>2</sup>
m <sup>2</sup>	square meters	1.2	square yards	yd <sup>2</sup>
km <sup>2</sup>	square kilometers	0.4	square miles	mi <sup>2</sup>
ha	hectares (10,000 m <sup>2</sup> )	2.5	acres	acres
<b>MASS (weight)</b>				
g	grams	0.035	ounces	oz
kg	kilograms	2.2	pounds	lb
t	tonnes (1,000 kg)	1.1	short tons	
<b>VOLUME</b>				
ml	milliliters	0.03	fluid ounces	fl oz
l	liters	2.1	pints	pt
		1.06	quarts	qt
m <sup>3</sup>	cubic meters	0.26	gallons	gal
		36	cubic feet	ft <sup>3</sup>
		1.3	cubic yards	yd <sup>3</sup>
<b>TEMPERATURE (exact)</b>				
°C	Celsius temperature	9/5 (then add 32)	Fahrenheit temperature	°F



\* 1 in. = 2.54 (exactly). For other exact conversions and more detailed tables, see NBS Mon. Publ. 280, Units of Weights and Measures, Price \$2.25, SD Catalog No. C13.10.286.

# AD-A142314

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1 REPORT NUMBER TN-1695	2 GOVT ACCESSION NO DN887053	3 RECIPIENT'S CATALOG NUMBER
4 TITLE (and Subtitle)  DENSIFIED REFUSE-DERIVED FUELS - OVERVIEW OF PRODUCTION PROCESSES AND COMBUSTION CHARACTERISTICS		5 TYPE OF REPORT & PERIOD COVERED  Final; Oct 1981 - Sep 1982
		6 PERFORMING ORG. REPORT NUMBER
7 AUTHOR(s)  Brian E. Swaidan		8 CONTRACT OR GRANT NUMBER(s)
9 PERFORMING ORGANIZATION NAME AND ADDRESS  NAVAL CIVIL ENGINEERING LABORATORY Port Hueneme, CA 93043		10 PROGRAM ELEMENT PROJECT TASK AREA & WORK UNIT NUMBERS  64710N; S0371-01-421E
11 CONTROLLING OFFICE NAME AND ADDRESS  Chief of Naval Material Washington, DC 20360		12 REPORT DATE May 1984
		13 NUMBER OF PAGES 25
14 MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		15 SECURITY CLASS (of this report)  Unclassified
		15a DECLASSIFICATION DOWNGRADING SCHEDULE
16 DISTRIBUTION STATEMENT (of this Report)  Approved for public release; distribution unlimited.		
17 DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18 SUPPLEMENTARY NOTES		
19 KEY WORDS (Continue on reverse side if necessary and identify by block number)  Waste, densified, refuse, combustion, fuel		
20 ABSTRACT (Continue on reverse side if necessary and identify by block number)  A literature search was conducted to assess the feasibility of utilizing densified refuse-derived fuel (d-RDF) for the production of hot water and steam in Navy boilers. This report also includes the Air Force efforts in adapting d-RDF technology such as manufacturing processes, storage, shipping, and burning characteristics. Based on experiences in utilizing d-RDF to this date, the technology is available, the burning characteristics are very encouraging, and the economic feasibility would be enhanced		

DD FORM 1 JAN 73 1473 EDITION OF 1 NOV 65 IS OBSOLETE

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

(continued)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

20. Continued

with local production sites. Further developments in multi-fuel boiler design specifications, modifications, and performance testing will promote the utilization of d-RDF.

Library Card

Naval Civil Engineering Laboratory  
DENSIFIED REFUSE-DERIVED FUELS -  
OVERVIEW OF PRODUCTION PROCESSES  
AND COMBUSTION CHARACTERISTICS  
(Final), by Brian E. Swaidan  
TN-1695 25 pp illus May 1984 Unclassified

1. Waste

2. Densified

I. S0371-01-421E

A literature search was conducted to assess the feasibility of utilizing densified refuse-derived fuel (d-RDF) for the production of hot water and steam in Navy boilers. This report also includes the Air Force efforts in adapting d-RDF technology such as manufacturing processes, storage, shipping, and burning characteristics. Based on experiences in utilizing d-RDF to this date, the technology is available, the burning characteristics are very encouraging, and the economic feasibility would be enhanced with local production sites. Further developments in multi-fuel boiler design specifications, modifications, and performance testing will promote the utilization of d-RDF.

Unclassified


SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

# CONTENTS

	Page
INTRODUCTION . . . . .	1
d-RDF PRODUCTION TECHNIQUES . . . . .	1
Air Force Research . . . . .	1
NCEL Study . . . . .	3
Energy to Produce d-RDF . . . . .	5
d-RDF CHARACTERISTICS . . . . .	5
Structural Integrity . . . . .	5
Storage . . . . .	6
Heat Content . . . . .	6
Ash Content . . . . .	6
Combustion Characteristics . . . . .	6
RESULTS . . . . .	7
CONCLUSIONS AND RECOMMENDATIONS . . . . .	7
REFERENCES . . . . .	8
APPENDIX - Excerpts From Reference 5 on Boiler Emission Tests Using d-RDF and Coal at WPAFB . . . . .	12

Accession For	
NTIS GRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution/	
Availability Codes	
Avail and/or	
Dist	Special
A-1	







## INTRODUCTION

The ever increasing demand for energy dictates a judicious use of all available resources. A renewable source of energy is inherent in the large quantities of organic wastes generated daily. These organic wastes, unlike fossil fuels, contain lower concentrations of sulphur and their availability is guaranteed. These wastes, however, are generated in varying ways and compositions, and have high moisture content. In addition, means for shipping, storage, and handling are severely restricted. Proper processing enhances the above properties and renders the product adaptable for burning in Navy coal fired boilers. Densified refuse-derived fuel (d-RDF) is the product of this processing and the subject of this report.

Densified refuse-derived fuel is produced by extracting and densifying into small pellets that fraction of solid waste which possesses the bulk of the fuel value. These dense pellets are then substituted or mixed with coal to produce steam in spreader stoker boilers. The d-RDF manufacturing technology is feasible, but long-term reliability and maintainability of equipment and the consistency of product properties is lacking. While a number of firms have engaged in the production of d-RDF pellets both in this country and abroad, d-RDF pellets are not generally available today. However, a number of firms may be willing to produce pellets if a stable market for the product exists.

The U.S. Air Force is conducting a multi-year evaluation of the merits and problems associated with the use of d-RDF. Their experiences with the handling and firing characteristics of d-RDF at Wright-Patterson Air Force Base (WPAFB), Ohio, are presented. In addition, NCEL has conducted studies aimed at identification and development of fuel specifications, equipment modifications, and operational procedures for the procurement and utilization of d-RDF at Naval shore facilities.

The scope of this report is to survey the various processes that have been under consideration and experimentation and to report on the Air Force experiences in co-burning d-RDF with coal at Wright-Patterson Air Force Base.

## d-RDF PRODUCTION TECHNIQUES

### Air Force Research

Common to all manufacturing processes for producing d-RDF are those shown in Figure 1. Dumping of incoming waste and cooling the product are also used in certain processes. An Air Force study (Ref 1 and 2) classified d-RDF production processes into two categories. In the first category were existing plants capable of providing fuel suitable for the

boiler facilities at WPAFB, where the fuel was to be used. The second category consisted of processes considered developmental in nature with unknown technical and economic risk.

The development processes classified in the second category are totally unexplored and can be considered as primarily research concept schemes. Their potential impact on d-RDF production in the near future are extremely slight. These were cited in the appendix of the Air Force study (Ref 1) and referred to as research briefs.

Under the first classification, seven systems are cited and are summarized here.

The Maryland Environmental Service Plant operated by Teledyne National. This plant has been supplying d-RDF to WPAFB for testing purposes. Figure 2 shows the basic plant material flow patterns (the aluminum recovery system is not being operated at all). The most significant fact concerning this facility is that it has been on-line more or less continuously for a number of years. The economic feasibility of this facility is not known because of local, state, and government subsidies. Other facts about the d-RDF product are also shown in Figure 2.

Plant capacity for incoming refuse is rated at 1200 tons/day, and the overwhelming majority of this is landfilled. Only a small percentage is processed into d-RDF (approximately 6000 tons from 1975 to the present), and due to the relatively low yield, additional development is warranted. Furthermore, the d-RDF quality produced is marginal when compared to Air Force specifications, and fuel delivery rates have been lower than originally required (8000 tons/yr).

National Center for Resource Recovery Plant. This system included a full scale facility (no pelletizing) in New Orleans (now terminated) and a pilot plant in Washington, D.C. (also terminated). In general, this system includes a Trommel screening process as a pre-shredding separation step. The same types of problems existed here as in the Teledyne-operated plant; i.e., d-RDF fuel quality was inconsistent and delivery was far behind schedule. The National Center ceased operation at its Washington, D.C., plant and the organization disbanded.

Raytheon Service Corporation (RSC). This plant was built in Monroe County, N.Y., and follows the steps shown in Figure 1 for the production of d-RDF, which has recently been added as an extension of refuse-derived fuel production. Therefore, no production history is available.

Combustion Equipment Associates (CEA). This type of facility utilizes a proprietary technology for embrittling the cellulosic fraction of refuse followed by various steps to prepare the combustible fraction. The pilot plant has operated satisfactorily after much development, but CEA discontinued operations and the full-scale facility scheduled was cancelled.

Black Clawson (BC). This system is totally different; it employs a wet pulverization and separation process. A pilot plant is operating and producing pellets, but problems have been encountered with slagging in the furnaces. Though a major facility (1,500 to 2,000 tons/day) has

been constructed on Long Island, operation has ceased due to concerns about toxic emissions from the stack. Therefore, no long-term data are available on the product fuel of this system.

SPM Group, Inc. At this plant oversized materials are reduced by a coarse low horsepower shredder. A separation process on a proprietary type conveyor follows, and the product fuel is extruded into cubettes or briquettes. The Air Force at WPAFB conducted a satisfactory burn test on a 20-ton load, but the SPM pilot plant has a limited operating history.

Ames, Iowa Plant. The process used at this plant is considered a possible preliminary step to the densification step for d-RDF production in that no pelletizing is done. After instituting significant improvements and modifications performed by Midwest Research Institute, the Environmental Protection Agency (EPA), and the Department of Energy (DOE), a combination of disc screens, shredders, and air classifiers has produced a high quality combustible product ready for densification. The Ames plant produced an average of 35,000 tons of RDF per shift year. The Air Force study recommends further consideration of this process for possible incorporation into a local d-RDF plant in the greater Dayton area.

#### NCEL Study

NCEL sponsored a study (Ref 3 and 4) which included the identification of commercial systems (100 to 300 tons/day of d-RDF production) and product characteristics. The following summarizes the findings.

Bio-Solar R&D Corporation (Woodex). The Bio-Solar R&D Corporation has licensed Woodex, Inc., to produce a densified fuel, commonly known as Woodex, which is manufactured from organic fibrous materials through a patented process. Apparently, the first step in the system includes a compression step whereby the moisture content of the fuel is reduced to about 25%. The material is then pulverized and the moisture content is further reduced. Moisture removal is followed by densification under "extreme pressure."

Woodex, Inc., operates a plant in Brownsville, Ore., and is capable of producing between 250 and 300 tons of fuel per day. The cost for purchasing the feedstock and producing the pellets was purported to be about \$15/ton in 1979.

<u>Product Characteristics</u>	<u>Description or Value</u>
Cylindrical shape	1/4 in. diam x 3/4 in. long
Specific gravity	1.3 g/cc
Bulk density	35 lb/ft <sup>3</sup>
Net heating value	8,340 Btu/lb

Guaranty Fuels, Inc. (ROEMCC). The main steps in this type of fuel production are drying, size reduction, densification, and cooling. A portion of the feedstock is used to fuel the processing plant.

One ROEMCC plant operates in Stillwater, Minn. The plant is capable of producing approximately 40,000 tons of densified fuel per year. The fuel is sold at about \$26/ton.

<u>Product Characteristics</u>	<u>Description or Value</u>
Cylindrical shape	3/8 in. diam
Pellet density	1.14 g/cc
Bulk density	43 lb/ft <sup>3</sup>
Moisture content	15% (maximum)
Heating value	8,000 Btu/lb (as received)
Ash content	less than 5%

LeHigh Forming Co. (The Palmer Process). This process has been designed to process municipal solid waste. The unit processes include (1) magnetic separation, (2) air classification, (3) size reduction, and (4) densification.

Estimated cost for a plant capable of processing 52,000 tons of waste per year is about \$3.5 million. Operating and maintenance costs can range from \$12 to \$60/ton, depending upon the quantity of material processed.

A pilot plant capable of processing 10 tons of refuse per hour has been operated in Easton, Pa., for the last 5 years.

<u>Product Characteristics</u>	<u>Description or Value</u>
Cylindrical shape variable diameter typical	5/8 in. diam
Pellet density	1.3 g/cc
Bulk density	35 lb/ft <sup>3</sup>
Heating value	7,000 to 11,500 Btu/lb
Ash content	10 to 20%

Koppers (Sprout-Waldron Division). The main components of this process are two shredders, a dryer, pellet mills, and a cooler.

The production cost is estimated as about \$22/ton at 15 to 18 tons/hr and about \$26/ton at 6 TPH.

<u>Product Characteristics</u>	<u>Description or Value</u>
Cylindrical shape	1/4 in. diam x 1 in. long
Pellet density	1.1 g/cc
Bulk density	32 lb/ft <sup>3</sup>
Heating value	7,300 Btu/lb
Moisture content	12%

PAPACUBE (Energy Cube Densifying System). PAPAC" is a process originally designed to compress shredded newsprint. pilot plant of the PAPACUBE process is located in San Diego, Calif. he overall system is divided into five unit processes: sorting, size 'uction, magnetic separation, conditioning and metering, and densifica n.

<u>Product Characteristics</u>	<u>Description or Value</u>
Production rate	8 to 10 tons/hr
Shape	1-1/4 in. <sup>2</sup> , 1 to 2-1/2 in. in length
Ash content	15%
Heating value (day)	7,100 Btu/lb

#### Energy to Produce d-RDF

Energy input requirements for the production of d-RDF are of consideration. Table 1 shows approximate energy consumption for the three prevalent processes.

#### d-RDF CHARACTERISTICS

Closely associated with the production of d-RDF are the resulting properties and characteristics of the fuel which must be considered for the utilization of d-RDF.

#### Structural Integrity

This property allows the fuel to be shipped and handled without disintegrating into smaller particles and dust. Experiments at WPAFB have shown that dust was a persistent problem during rail car unloading and in the fuel bunker serving the boiler. Health hazard potential, spontaneous combustion, and equipment maintenance are reasons enough to minimize and contain this problem. Solution approaches include:

1. Providing powered ventilation to remove the dust from the bunker area and into the boiler overfire air system or a bag house.

2. Providing mist oiling of the d-RDF as it is removed from the storage silo. This solution, however, may cause fuel jamming in the bunker because of resulting sticky surfaces.

3. Providing water or steam spray for the d-RDF with a resulting penalty in boiler performance due to the higher moisture content.

#### Storage

At WPAFB, two storage techniques were used. First, a coal silo was set aside for d-RDF storage. It was found, however, that the bearing capacity of d-RDF prior to deformation was only 285 psf. Therefore, only 20 feet of the silo's 70-foot height can be used without bridging and jamming the chute. Second, outdoor storage was also explored, but deterioration of the fuel quality resulted in a recommendation that a shed be constructed over the storage area to prevent the adverse effects of inclement weather.

#### Heat Content

In the discussion concerning d-RDF production, the heat content ranged between 6,000 and 11,500 Btu/lb. The more time and effort that is put into the beneficiation process so that the higher grade combustibles are selected, the better the quality of the d-RDF produced is. However, economics dictate that such a product would be relatively costly. It should be noted that coal has an approximate heating value of 13,500 Btu/lb and that spreader stoker boilers are designed to accommodate this type of fuel. Therefore d-RDF, with an average heating value of 7000 Btu/lb, would be blended with coal under less than full capacity conditions.

#### Ash Content

The ash content is an important consideration because the higher the ash content, the lower the number of Btu's delivered per unit weight of fuel and the greater the expense of removing and discarding the ash. It should be noted here that the ash content of d-RDF approaches twice as much as that of coal. Therefore, since the heat content of d-RDF averages half that of coal, the ash content of d-RDF would be quadruple that of coal.

#### Combustion Characteristics

In February 1982, boiler efficiency and emissions testing using d-RDF (Teledyne National product) and coal were carried out at WPAFB (Ref 5). The purpose of the testing was to quantify the differences in the boiler pollutant emissions, precipitator efficiency, and boiler thermal efficiency.

The boiler is a Keeler Rotograte overfire unit with a rated capacity of 150,000 lb/hr of steam. Design steam is 600 psi; but, during testing, steam pressure was 385 psi. The electrostatic precipitator (ESP) is a dual chamber unit designed by Precipitair.

## RESULTS

The Appendix is an excerpt of Reference 5 and describes the sampling and analytical procedures used, summarizes the results, and offers conclusions and recommendations. For the purpose of this discussion, however, Table [2] (found in the Appendix) gives a summary of the tabulated results while Figures [3] through [6] (also found in the Appendix) show the flow path and sampling points of the tests.

The contractual specifications for d-RDF are summarized below:

Energy content	6500 Btu/lb (minimum) dry
Ash content	15% (maximum) dry
Moisture content	20% (maximum) as received
Bulk density	35 lb/ft <sup>3</sup> (minimum) as received
Fines	5% (maximum) as received
Pellet size	1/2 in. x 1 in.

## CONCLUSIONS AND RECOMMENDATIONS

1. The limited co-firing tests at WPAFB has demonstrated that 100% d-RDF can be combusted in an existing spreader stoker, and with proper grate control, clinkering and ash burnout is improved with no adverse impact on the environment.
2. Per unit weight, d-RDF contains half the Btu content of coal and twice the ash content. Therefore, for 100% d-RDF firing two points must be addressed. First, the existing fuel handling equipment must be capable of delivering twice the amount of fuel; otherwise, the boiler must be de-rated. (The fuel handling equipment at WPAFB could not deliver the required fuel during the 100% d-RDF test.) Second, the existing ash removal equipment must be capable of handling quadruple the amount. This could lead to major retrofit plans if the expected utilization of d-RDF is to be 100%. Therefore, storage and handling of twice the quantity by weight of d-RDF as coal to sustain the same Btu loading and a drop of 3.5% of thermal efficiency are disadvantages.
3. The generation and accumulation of dust, especially in the storage bunkers above the boilers, is another major problem encountered with the handling of d-RDF. At WPAFB, dusting was extreme. Potential fire and explosion hazard must be considered.

4. It should be noted that the contractor (Entropy Environmentalists, Inc.) experienced difficulties in obtaining the fuel quality specified earlier. This indicates that either the specifications are too stringent or that the production method requires further refinement.

5. Storage of d-RDF in an open area is not recommended because of deterioration of fuel quality.

6. Local production of d-RDF is most desirable because long distance transportation costs can run as high as twice the cost of d-RDF production on a per ton basis.

7. The establishment of an integrated d-RDF facility to develop fuel specifications and boiler performance test programs at WPAFB or other such activity is also recommended.

#### REFERENCES

1. Air Force Engineering and Services Laboratory. Contract Report ESL-TR-81-59: Performance analysis of co-firing densified refuse derived fuel in a military boiler. Cincinnati, Ohio, Rycon Inc., Dec 1981.

2. Air Force Engineering and Services Laboratory. Contract Report ESL-TR-81-57: A field test using d-RDF in a spreader stoker hot water generator, by Ned J. Kleinhenc and Paul F. Carpenter. Xenia, Ohio, Systems Technology Inc., Aug 1981.

3. Civil Engineering Laboratory. Purchase Order Report PO No. N62583-79-MR-543: Conversion of Navy waste to densified refuse-derived fuel by the PAPACUBE process and identification of commercial sources. Richmond, Calif., Cal Recovery Systems, Inc., Richmond, Calif., Jul 1979.

4. Civil Engineering Laboratory. Contract Report, Final Report: Technology evaluation for densified refuse-derived fuel specifications and acquisition. Richmond, Calif., Cal Recovery Systems, Inc., Mar 1981. (Contract No.: N68305-80-C-0033)

5. USAF Occupational and Environmental Health Laboratory. Contract Report No. 82-017EA206HEF: Boiler efficiency and emission testing using refuse-derived fuel (RDF) and coal. Research Triangle Park, N.C., Entropy Environmentalists, Inc., Aug 1982.



Table 1. Approximate Energy Requirements  
for the Production of d-RDF

Process	Energy Required (kWh/ton) <sup>a</sup>
Size reduction	17.0
Air Classification	4.0
Densification	6.3
Miscellaneous	2.7
TOTAL	30.0

<sup>a</sup>Of incoming waste.




Figure 1. Typical d-RDF manufacturing process.




Figure 2. Process flow - Baltimore County resource recovery facility.

## Appendix

### EXCERPTS FROM REFERENCE 5 ON BOILER EMISSION TESTS USING d-RDF AND COAL AT WPAFB

#### SUMMARY OF RESULTS

The average pollutant emission results, average precipitator efficiency results, and average boiler operating efficiency results for each of the three fuel conditions, as well as the particle sizing, flow angle and resistivity tests results, are presented in Table [2].

Due to the difference in the fuel types being burned, the maximum steam loading obtainable for each fuel mix was not the same; since the boiler emissions and efficiency are affected by the loading, care must be used in comparing the results.

The "Boiler Emissions and Precipitator Efficiencies" and "Boiler Efficiency" subsections present the individual run-by-run summaries for each of the two main test objectives at each of the three fuel type test conditions. A third subsection, "Conclusions and Observations," presents a discussion and interpretation of the results. The first subsection, "Boiler Emissions and Precipitator Efficiencies," also presents the F-factor values, the results from the flyash resistivity measurements, and the flue gas flow angle data summaries.

The 40% RDF-60% coal ratio in Table [2] was calculated using the average ultimate heating values for coal and RDF in conjunction with the heating value obtained for the RDF/coal mixtures. Using this method, the estimated percent of coal making up the RDF/coal mixtures averaged 60.2% dry, by weight. Samples 1, 2, and 3 were 64.0%, 49.9%, and 66.7% coal, respectively.

#### Conclusions and Observations

Conclusions and observations can be grouped into two general categories: (1) the effect of the different fuel mixtures on precipitator efficiency and pollutant emissions, and (2) the effect of the different fuel mixtures on material handling systems (including boiler firing chamber maintenance) and boiler efficiency.

(1) From Table [2] it is apparent that the type of fuel mixture fired has little or no effect on the particulate collection efficiency of the precipitator. This conclusion is reinforced by the fact that the flyash resistivity remained essentially constant for the ash from all three fuel mixtures. However, the steam flow rate for the 100% RDF tests was only 66% of the steam rate for the 100% coal tests while steam load for the RDF/coal tests was 77% of that of the 100% coal tests. The collection efficiencies may or may not be similar if the steam flow rate is

held constant for all fuel mixtures. In any case, the particulate emissions are well below the limits set by the Ohio EPA (0.10 lb/MBtu), and any differences may be of little consequence. No U.S. EPA emission standards apply to this boiler since it generates less than 250 MBtu/hr. It is recommended that a constant steam flow rate be among the objectives of any further test programs.

Sulfur dioxide emissions were considerably lower using 100% RDF as opposed to 100% coal. The RDF/coal mixture showed some reduction of sulfur dioxide emissions but not as dramatic a reduction as seen with 100% RDF. This is understandable in that the RDF is shown by ultimate fuel analysis to contain a lower percentage of sulfur and sulfur compounds than the coal.

The nitrogen oxides emissions for the 100% coal tests were considerably higher than those of the 100% RDF and RDF/coal mixture tests. Since higher temperature (among other factors) increases nitrogen oxide production, this suggests that the combustion temperatures were indeed higher while firing 100% coal. This could not be verified due to the lack of necessary instrumentation.

The differences in nonmethane organic emissions between the three fuel conditions are more difficult to interpret. The 100% coal tests showed the lowest emissions while the 100% RDF tests showed an increase in emissions of approximately 70%. The RDF/coal mixture tests, which presumably would show an intermediate level of emissions, in fact revealed emissions 50% higher than the 100% RDF tests. The implication is that unknown thermodynamic conditions and/or stoichiometric relationships in the boiler were affecting the nonmethane organic emissions.

Particle size analysis results showed essentially what would be expected. The mass median principle diameter at the precipitator inlet during the 100% RDF tests was 3.0 microns which is lower than expected. However, since the excess air in the boiler was much higher with this fuel than during the tests with the other two fuels, the higher excess air would have led to more complete combustion and, thereby, to smaller particles exiting the firing chamber.

(2) Using 100% RDF led to one problem associated with its low density and heat content, and another which was probably a result of its metal content.

The first problem was the inability of the material handling system to convey a large enough amount of fuel to the boiler to maintain a normal (approximately 120 to 140 thousand pounds per hour) steam flow rate. The sheer bulk of the RDF overtaxed the fuel feed conveyers and, incidentally, the counter mechanism for quantifying the amount of fuel fed. The RDF also created a large volume of fibrous dust which led to an increase in housekeeping efforts.

The second major problem is that the RDF (from visual inspection and conversations with boiler maintenance personnel) caused greater than normal slag buildup on boiler tubes and walls. This would probably lead, in the long term, to a drop in boiler efficiency and an increase in downtime for firing chamber maintenance.

It appears from the data that boiler efficiency increased when the RDF/coal mixture was fired. Again, it must be taken into consideration that the steam flow rate varied between the three fuel conditions.

Additionally, boiler instrumentation was inadequate to evaluate steam quality. These parameters could be expected to change under different steam flow rates and fuel conditions. Due to the lack of steam data, steam quality had to be assumed to be constant even though it most likely was not. The data seem to show that there are both advantages and disadvantages to the use of RDF as boiler fuel. It is recommended that these data be used in conjunction with other past or future data to determine if the fuel can be used to improve the economic and environmental performance of medium sized boilers.

#### SAMPLING AND ANALYTICAL PROCEDURES

All sampling and analytical procedures used were those generally recommended by the United States Environmental Protection Agency (U.S. EPA), the Ohio Environmental Protection Agency, and the American Society of Mechanical Engineers (ASME). Details of the equipment and procedures used are described in the Federal Register, August 18, 1977.

The number and locations of the sampling points were determined using EPA Method 1 [Figure 3]. The inlet and outlet ducts cross sections were each divided into 48 equal areas, i.e., 12 points on each of the four traverse axes, as shown in Figures [4] and [6] for the inlet duct and Figures [5] and [6] for the outlet duct. The centroid of each equal area was sampled for two minutes for a net run time of 96.

Velocity measurements were made according to EPA Method 2. The flue gas composition and molecular weight were determined using EPA Method 3 criteria. Particulate emissions at the inlet were determined using EPA Method 5 procedures. Outlet particulate and sulfur dioxide emissions determinations followed the procedures outlined in combined EPA Methods 5 and 8. Nitrogen oxides emissions determinations used EPA Method 7 criteria. EPA Method 25 was used in determining total gaseous nonmethane organic emissions. Particle sizing was performed using a cascade impactor sampling head attached to an EPA Method 5 probe end.

Boiler efficiency tests were performed at each condition according to ASME Power Test Code 4.1, section 4, which is the input-output method.

Flyash resistivity tests were performed according to paragraph 4.05 of ASME Power Test Code 28-1965. The flyash samples for resistivity measurements were collected at the precipitator inlet following EPA Method 5 procedures. For each condition, the filter catches for the three runs performed were combined to make one sample. In the laboratory, the test cell was filled with flyash and heated to 500 degrees F to simulate inlet duct conditions. Two readings were taken for each sample.

The F-factor value used in the calculations was determined using the ultimate analyses of the fuel samples.

All sampling equipment used was manufactured by Nutech Corporation, Andersen Samplers, Inc., or Entropy Environmentalists, Inc.

Table [2]. Average Results Per Fuel Condition

	40% RDF/ 60% Coal	100% RDF	100% Coal
Boiler Data			
Steam Load, lb/hr	115,000	97,000	146,000
Efficiency, %	82.7	75.5	75.5
Precipitator Data	grains per dscf		
Particulate Concentration			
Precipitator Inlet	0.361	0.337	0.472
Precipitator Outlet	0.011	0.009	0.014
Collection Efficiency, %	97.0	97.4	97.0
Emissions to Atmosphere	pounds per Million Btu		
Particulate	0.026	0.024	0.029
Sulfur Dioxide	0.847	0.372	0.926
Nitrogen Oxides as NO <sub>2</sub>	0.506	0.584	0.680
Total Nonmethane Organics as Carbon	0.261	0.177	0.103
	ppm dry by volume		
Sulfur Dioxide	315	116	392
Nitrogen Oxides as NO <sub>2</sub>	261	248	397
Total Nonmethane Organics as Carbon	519	295	231
Flyash Resistivity, ohm-cm	$4.7 \times 10^7$	$4.9 \times 10^7$	$4.6 \times 10^7$
Yaw Angle of Flue Gas, degrees			
Precipitator Inlet	7.4	14	---
Precipitator Outlet	7.0	5.6	---
Particle Size, mass median diam.*			
Precipitator Inlet, microns	25	3.0	17
Precipitator Outlet, microns	1.1	2.1	3.6

\*Taken from log-probability plot.




Figure [3]. Air flow schematic, showing sampling locations during testing.



FOR SECTION S-S  
SEE FIGURE 6




Figure [4]. Inlet duct dimensions and sampling port locations.




Figure [5]. Outlet duct configuration showing sampling port locations.




Figure [6]. Inlet duct cross section showing equal area divisions and sampling point locations.

## DISTRIBUTION LIST

ARMY Fd Engr, Letterkenny Army Depot, Chambersburg, PA  
 AF HQ LEEH (J Stanton) Washington, DC  
 AFB (AFITIDE), Wright Patterson OH; S2ABG-DEMC, Williams AZ; ABG-DEF (E. Nethers), Goodfellow  
 AFB TX; AF Tech Office (Mgt & Ops), Tyndall, FL; AFESC-1SL, Tyndall FL; AUT-1SL 63-465, Maxwell  
 AL; CESCH, Wright-Patterson; HQ MAC-DEFEE, Scott, IL; HQ Tactical Air Cnd DEEM (Schmidt)  
 Langley, VA; SAMSOMNND, Norton AFB CA; Samso Dec (Sauer) Vandenburg, CA; Stinto Library,  
 Offutt NE  
 AFESC-DEB, Tyndall, FL  
 NATL ACADEMY OF ENG, Alexandria, VA  
 ARMY ARRADCOM, Dover, NJ; BMDSC-RE (H. McClellan) Huntsville AL; Contracts - Facs Engr  
 Directorate, Fort Ord, CA; DAEN-CWE-M, Washington DC; DAEN-MPI-D Washington DC;  
 DAEN-MPU, Washington DC; ERADCOM Tech Supp Dir. (DFLSD-L) Ft Monmouth, NJ; Engr District  
 (Memphis) Library, Memphis TN; Natick R&D Command (Kwoh Hu) Natick MA; Tech. Ref. Div., Fort  
 Huachuca, AZ  
 ARMY - CERL Library, Champaign IL  
 ARMY AMMUNITION PLANT Sarhw - FEM Hawthorne, NY  
 ARMY CORPS OF ENGINEERS MRD-Eng. Div., Omaha NE; Seattle Dist. Library, Seattle WA  
 ARMY CRREL G. Phetteplace Hanover, NH  
 ARMY ENG DIV HNDED-CS, Huntsville AL; HNDED-FD, Huntsville, AL  
 ARMY ENG WATERWAYS EXP STA Library, Vicksburg MS  
 ARMY ENGR DIST. Library, Portland OR  
 ARMY ENVIRON. HYGIENE AGCY Dir Env Qual Aberdeen Proving Ground MD; HSE-EW Water Qual  
 Eng Div Aberdeen Prov Grnd MD; HSE-RP-HG Pest Coord. Aberdeen Proving Ground, MD; Librarian,  
 Aberdeen Proving Ground MD  
 ARMY MATERIALS & MECHANICS RESEARCH CENTER Dr. Lenoe, Watertown MA  
 ARMY MISSILE R&D CMD SCI Info Cen (DOC) Redstone Arsenal, AL  
 ARMY-DEPOT SYS COMMAND DRSDS-AI Chambersburg, PA  
 ASO PWD (ENS M W Davis), Philadelphia, PA  
 BUMED Security Offr, Washington DC  
 BUREAU OF RECLAMATION Code 1512 (C. Selander) Denver CO  
 CINCLANT CIV ENGR SUPP PLANS OFFR NORFOLK, VA  
 CINCPAC Fac Engrng Div (J44) Makalapa, HI  
 CNAVRES Code 13 (Dir. Facilities) New Orleans, LA  
 CNM Code MAT-04, Washington, DC; Code MAT-08E, Washington, DC; NMAT - 044, Washington DC  
 CNO Code NOP-964, Washington DC; Code OP 987 Washington DC; Code OP-413 Wash, DC; Code OPNAV  
 09B24 (H); OP-098, Washington, DC; OP-411F, Wash DC; OP-987J, Washington, DC  
 COMFAIRWESTPAC Security Offr, Misawa Japan  
 COMFLEACT, OKINAWA PWO, Kadena, Okinawa  
 COMNAVMARIANAS Code N4, Guam  
 COMOCEANSYSLANT PW-FAC MGMNT Off Norfolk, VA  
 COMOCEANSYSPAC SCE, Pearl Harbor HI  
 COMSUBDEVGRUONE Operations Offr, San Diego, CA  
 DEFENSE CIVIL PREPAREDNESS AGENCY Washington, DC  
 DEFFUELSUPPCEN DFSC-OWE (Term Engrng) Alexandria, VA; DFSC-OWE, Alexandria VA  
 DOD Staff Spec. Chem. Tech. Washington DC  
 DOE Div Ocean Energy Sys Cons-Solar Energy Wash DC; INEL Tech. Lib. (Reports Section), Idaho Falls, ID  
 DTIC Defense Technical Info Ctr Alexandria, VA  
 DTNSRDC Code 284 (A. Rufolo), Annapolis MD  
 DTNSRDC Code 4111 (R. Gierich), Bethesda MD; Code 42, Bethesda MD  
 DTNSRDC Code 522 (Library), Annapolis MD  
 ENVIRONMENTAL PROTECTION AGENCY Reg. III Library, Philadelphia PA; Reg. VIII, 8M-ASL,  
 Denver CO  
 FAA Civil Aeromedical Institute, Oklahoma City, OK  
 FLTCOMBATTRACENLANT PWO, Virginia Bch VA  
 GIDEP OIC, Corona, CA  
 GSA Assist Comm Des & Cnst (FAIA) D R Dibner Washington, DC ; Off of Des & Const-PCDP (D Eakin)  
 Washington, DC  
 KWAJALEIN MISRAN BMDSC-RKL-C  
 LIBRARY OF CONGRESS Washington, DC (Sciences & Tech Div)  
 MARINE CORPS BASE Code 406, Camp Lejeune, NC; M & R Division, Camp Lejeune NC; Maint Off Camp  
 Pendleton, CA; PWD - Maint. Control Div, Camp Butler, Kawasaki, Japan; PWO Camp Lejeune NC;  
 PWO, Camp Pendleton CA; PWO, Camp S. D. Butler, Kawasaki Japan  
 MARINE CORPS HQS Code LFF-2, Washington DC

MCAS Facil. Engr. Div. Cherry Point NC; CO. Kaneohe Bay HI; Code S4, Quantico VA; Facs Maint Dept - Operations Div. Cherry Point; PWD - Utilities Div. Iwakuni, Japan; PWO, Iwakuni, Japan; PWO, Yuma AZ

MCDEC M&I Div Quantico VA; NSAP REP, Quantico VA

MCLB B520, Barstow CA; Maintenance Officer, Barstow, CA; PWO, Barstow CA

MCRD SCE, San Diego CA

MILITARY SEALIFT COMMAND Washington DC

NAF PWD - Engr Div, Atsugi, Japan; PWO, Atsugi Japan

NALF OINC, San Diego, CA

NARF Code 100, Cherry Point, NC; Code 612, Jax, FL; Code 640, Pensacola FL; SCE Norfolk, VA

NAS CO, Guantanamo Bay Cuba; Code 114, Alameda CA; Code 183 (Fac. Plan BR MGR); Code 187, Jacksonville FL; Code 18700, Brunswick ME; Code 18U (ENS P.J. Hickey), Corpus Christi TX; Code 70, Atlanta, Marietta GA; Code SE, Patuxent Riv., MD; Dir of Engrng, PWD, Corpus Christi, TX; Grover, PWD, Patuxent River, MD; Lakehurst, NJ; Lead, Chief, Petty Offr, PW Self Help Div, Beeville TX; PW (I Maguire), Corpus Christi TX; PWD - Engr Div Dir, Millington, TN; PWD - Engr Div, Gtmo, Cuba; PWD - Engr Div, Oak Harbor, WA; PWD - Maint. Control Dir, Millington, TN; PWD Maint. Cont. Dir., Fallon NV; PWD Maint. Div., New Orleans, Belle Chasse LA; PWD, Code 1821H (Ptankuch) Miramar, SD CA; PWD, Maintenance Control Dir., Bermuda; PWD, Willow Grove PA; PWO Belle Chasse, LA; PWO Chase Field Beeville, TX; PWO Key West FL; PWO Lakehurst, NJ; PWO Sigonella Sicily; PWO Whiting Hld, Milton FL; PWO, Dallas TX; PWO, Glenview IL; PWO, Kingsville TX; PWO, Millington TN; PWO, Miramar, San Diego CA; PWO., Moffett Field CA; SCE Norfolk, VA; SCE, Barbers Point HI; Weapons Offr, North Island

NATL RESEARCH COUNCIL Naval Studies Board, Washington DC

NAVACT PWO, London UK

NAVACTDET PWO, Holy Lock UK

NAVAEROSPREGMEDCEN SCE, Pensacola FL

NAVAIRDEVCEEN PWD, Engr Div Mgr, Warminster, PA

NAVAIRPROTESTCEN CO, Trenton, NJ

NAVAIRTESTCEN PATUXENT RIVER PWD (F. McGrath), Patuxent Riv., MD

NAVAVIONICFAC PW Div Indianapolis, IN; PWD Deputy Dir, D 701, Indianapolis, IN

NAVAVNWPNSFAC Wpns Offr, St. Mawgan, England

NAVCOASTSYSCEEN CO, Panama City FL; Code 423 Panama City, FL; Code 715 (J Quirk) Panama City, FL; Library Panama City, FL; PWO Panama City, FL

NAVCOMMAREAMSTRSTA Maint Control Div., Wahiawa, HI; PWO, Norfolk VA; SCE Unit 1 Naples Italy; SCE, Wahiawa HI

NAVCOMMSTA Code 401 Nea Makri, Greece; PWD - Maint Control Div, Diego Garcia Is.; PWO, Exmouth, Australia; SCE, Balboa, CZ

NAVCONSTRACEN Code 00U15, Port Hueneme CA

NAVEDTRAPRODEVCEEN Technical Library, Pensacola, FL

NAVEDUTRACEN Engr Dept (Code 42) Newport, RI

NAVENVIRHLTHCEN CO, NAVSTA Norfolk, VA

NAVEODTECHCEN Code 605, Indian Head MD

NAVFAC PWO, Brawdy Wales UK; PWO, Centerville Beh, Ferndale CA; PWO, Point Sur, Big Sur CA

NAVFACENGCOM Alexandria, VA; Code 03 Alexandria, VA; Code 031 (Essoglou) Alexandria, VA; Code 0454B Alexandria, VA; Code 04A1 Alexandria, VA; Code 04B3 Alexandria, VA; Code 051A Alexandria, VA; Code 09M54, Tech Lib, Alexandria, VA; Code 100 Alexandria, VA; Code 1113, Alexandria, VA; Code 111B Alexandria, VA; code 08T Alexandria, VA

NAVFACENGCOM - CHES DIV, Code 101 Wash, DC; Code 403 Washington DC; Code 405 Wash, DC; FPO-1 Washington, DC; Library, Washington, D.C.

NAVFACENGCOM - LANT DIV, Code 111, Norfolk, VA; Code 403, Norfolk, VA; Code 405 Civil Engr BR Norfolk VA; Eur. BR Deputy Dir, Naples Italy; Library, Norfolk, VA; Code 1112, Norfolk, VA

NAVFACENGCOM - NORTH DIV, (Boretsky) Philadelphia, PA; CO; Code 04 Philadelphia, PA; Code 09P Philadelphia PA

NAVCOMMUNIT CO, Cutler, East Machias, ME

NAVFACENGCOM - NORTH DIV, Code 111 Philadelphia, PA; Code 114 (A. Rhoads); Code 04AL, Philadelphia PA; ROICC, Contracts, Crane IN

NAVFACENGCOM - PAC DIV, (Kyi) Code 101, Pearl Harbor, HI; CODE 09P PEARL HARBOR HI; Code 402, RDT&E, Pearl Harbor HI; Commander, Pearl Harbor, HI; Library, Pearl Harbor, HI

NAVFACENGCOM - SOUTH DIV, Code 403, Gaddy, Charleston, SC; Code 1112, Charleston, SC; Library, Charleston, SC

NAVFACENGCOM - WEST DIV, AROICC, Contracts, Twentynine Palms CA; Code 04B San Bruno, CA; Code 101.6 San Bruno, CA; Code 114C, San Diego CA; Library, San Bruno, CA; 09P 20 San Bruno, CA, RDT&ELO San Bruno, CA

NAVFACENGCOM CONTRACTS AROICC, NAVSTA Brooklyn, NY; AROICC, Quantico, VA; Contracts AROICC, Lemoore CA; Dir, Eng. Div., Exmouth, Australia; Eng Div dir, Southwest Pac, Manila, PI; OICC, Southwest Pac, Manila, PI; OICC-ROICC, NAS Oceana, Virginia Beach, VA; OICC-ROICC,


Balboa Panama Canal; ROICC AF Guam; ROICC Code 495 Portsmouth VA; ROICC Key West FL;  
 ROICC, Keflavik, Iceland; ROICC, NAS, Corpus Christi, TX; ROICC, Pacific, San Bruno CA; ROICC,  
 Point Mugu, CA; ROICC, Yap; ROICC-OICC-SPA, Norfolk, VA  
 NAVFORCARIB Commander (N42), Puerto Rico  
 NAVMAG PWD - Engr Div, Guam; SCE, Subic Bay, R.P.  
 NAVOCEANO Library Bay St. Louis, MS  
 NAVOCEANSYSCEN Code 09 (Talkington), San Diego, CA; Code 4473B (Tech Lib) San Diego, CA; Code  
 523 (Hurley), San Diego, CA; Code 6700, San Diego, CA; Code 811 San Diego, CA  
 NAVORDSTA PWO, Louisville KY  
 NAVPETOFF Code 30, Alexandria VA  
 NAVPETRES Director, Washington DC  
 NAVPGSCOL E. Thornton, Monterey CA  
 NAVPHIBASE CO, ACB 2 Norfolk, VA; Code S3T, Norfolk VA; SCE, Coronado, SD, CA  
 NAVRADRECFAC PWO, Kami Seya Japan  
 NAVREGMEDCEN Code 29, Env. Health Serv. (Al Bryson) San Diego, CA  
 NAVHOSP CO, Millington, TN  
 NAVREGMEDCEN PWD - Engr Div, Camp Lejeune, NC; PWO, Camp Lejeune, NC  
 NAVREGMEDCEN PWO, Okinawa, Japan  
 NAVREGMEDCEN SCE; SCE San Diego, CA; SCE, Camp Pendleton CA; SCE, Guam; SCE, Newport, RI;  
 SCE, Oakland CA  
 NAVREGMEDCEN SCE, Yokosuka, Japan  
 NAVREGMEDCLINIC A. Watanabe, Pearl Harbor, HI  
 NAVSCOLCECOFF C35 Port Hueneme, CA; CO, Code C44A Port Hueneme CA  
 NAVSCSOL PWO, Athens GA  
 NAVSEASYSOM Code 0325, Program Mgr, Washington, DC; Code SEA OOC Washington, DC; SEA 04E (L  
 Kess) Washington, DC  
 NAVSECGRUACT PWO, Adak AK; PWO, Edzell Scotland; PWO, Puerto Rico; PWO, Torri Sta, Okinawa  
 NAVSECSTA PWD - Engr Div, Wash., DC  
 NAVSHIPYD Bremerton, WA (Carr Inlet Acoustic Range); Code 202.4, Long Beach CA; Code 202.5  
 (Library) Puget Sound, Bremerton WA; Code 380, Portsmouth, VA; Code 382.3, Pearl Harbor, HI; Code  
 400, Puget Sound; Code 410, Mare Is., Vallejo CA; Code 440 Portsmouth NH; Code 440, Norfolk; Code  
 440, Puget Sound, Bremerton WA; Code 453 (Util. Supr), Vallejo CA; L.D. Vivian; Library, Portsmouth  
 NH; PW Dept, Long Beach, CA; PWD (Code 420) Dir Portsmouth, VA; PWD (Code 450-HD) Portsmouth,  
 VA; PWD (Code 453-HD) SHPO 03, Portsmouth, VA; PWO, Bremerton, WA; PWO, Mare Is.; PWO,  
 Puget Sound; SCE, Pearl Harbor HI; Tech Library, Vallejo, CA  
 NAVSTA Adak, AK; CO Roosevelt Roads P.R. Puerto Rico; CO, Brooklyn NY; Code 4, 12 Marine Corps  
 Dist, Treasure Is., San Francisco CA; Dir Engr Div, PWD, Mayport FL; Dir Mech Engr 37WC93 Norfolk,  
 VA; Engr. Dir., Rota Spain; Long Beach, CA; PWD (LTJG.P.M. Motolenich), Puerto Rico; PWD - Engr  
 Dept, Adak, AK; PWD - Engr Div, Midway Is.; PWO, Keflavik Iceland; PWO, Mayport FL; SCE, Guam,  
 Marianas; SCE, Pearl Harbor HI; SCE, San Diego CA; SCE, Subic Bay, R.P.; Security Offr, San Francisco,  
 CA; Utilities Engr Off, Rota Spain  
 NAVSUBASE SCE, Pearl Harbor HI  
 NAVSUPPACT PWO Naples Italy  
 NAVSUPPFAC PWD - Maint. Control Div, Thurmont, MD  
 NAVSURFWPCEN PWO, White Oak, Silver Spring, MD  
 NAVTECHTRACEN SCE, Pensacola FL  
 NAVTELCOMMCOM Code 53, Washington, DC  
 NAVWPNCEN Code 24 (Dir Safe & Sec) China Lake, CA; Code 2636 China Lake; PWO (Code 266) China  
 Lake, CA; ROICC (Code 702), China Lake CA  
 NAVWPNSTA (Clebak) Colts Neck, NJ; Code 092, Colts Neck NJ; Code 092, Concord CA; Code 092A, Seal  
 Beach, CA; Maint. Control Dir., Yorktown VA  
 NAVWPNSTA PW Office Yorktown, VA  
 NAVWPNSTA PWD - Maint Control Div, Charleston, SC; PWD - Maint. Control Div., Concord, CA; PWD -  
 Supr Gen Engr, Seal Beach, CA; PWO, Charleston, SC; PWO, Seal Beach CA  
 NAVWPNSUPPCEN Code 09 Crane IN  
 NCTC Const. Elec. School, Port Hueneme, CA  
 NCBC Code 10 Davisville, RI; Code 15, Port Hueneme CA; Code 155, Port Hueneme CA; Code 156, Port  
 Hueneme, CA; Code 25111 Port Hueneme, CA; Code 400, Gulfport MS; Code 430 (PW Engrng) Gulfport,  
 MS; Code 470.2, Gulfport, MS; NEESA Code 252 (P Winters) Port Hueneme, CA; PWO (Code 80) Port  
 Hueneme, CA; PWO, Davisville RI; PWO, Gulfport, MS  
 NCR 20, Code R70; 20, Commander  
 NMCB FIVE, Operations Dept; THREE, Operations Off.  
 NOAA Library Rockville, MD  
 NORDA Code 410 Bay St. Louis, MS  
 NRL Code 5800 Washington, DC

NSC CO, Biomedical Rsch Lab, Oakland CA; Code 44 (Security Officer) Oakland, CA; Code 541 Norfolk, VA; Security Offr, Hawaii  
 NSD SCE, Subic Bay, R.P.  
 NSWSES Code 0150 Port Hueneme, CA  
 NTC OICC, CBU-401, Great Lakes IL  
 NUCLEAR REGULATORY COMMISSION T.C. Johnson, Washington, DC  
 NUSC DET Code 131 New London, CT; Code 5202 (S. Schady) New London, CT; Code EA123 (R.S. Munn), New London CT; Code SB 331 (Brown), Newport RI  
 OFFICE SECRETARY OF DEFENSE OASD (MRA&L) Dir. of Energy, Pentagon, Washington, DC  
 ONR Code 221, Arlington VA; Code 481, Bay St. Louis, MS; Code 700F Arlington VA  
 PACMISANFAC HI Area Bkg Sands, PWO Kekaha, Kauai, HI  
 PHIBCB 1 P&E, San Diego, CA  
 PWC ACE Office Norfolk, VA; CO Norfolk, VA; CO, (Code 10), Oakland, CA; CO, Great Lakes IL; CO, Pearl Harbor HI; Code 10, Great Lakes, IL; Code 105 Oakland, CA; Code 110, Great Lakes, IL; Code 110, Oakland, CA; Code 120, Oakland CA; Code 128, Guam; Code 154 (Library), Great Lakes, IL; Code 200, Great Lakes IL; Code 200, Guam; Code 30V, Norfolk, VA; Code 400, Great Lakes, IL; Code 400, Pearl Harbor, HI; Code 400, San Diego, CA; Code 420, Great Lakes, IL; Code 420, Oakland, CA; Code 424, Norfolk, VA; Code 500 Norfolk, VA; Code 505A Oakland, CA; Code 600, Great Lakes, IL; Code 610, San Diego Ca; Code 700, Great Lakes, IL; Code 700, San Diego, CA; Library, Code 120C, San Diego, CA; Library, Guam; Library, Norfolk, VA; Library, Pearl Harbor, HI; Library, Pensacola, FL; Library, Subic Bay, R.P.; Library, Yokosuka JA; Util Dept (R Pascua) Pearl Harbor, HI; Utilities Officer, Guam  
 SPCC PWO (Code 120) Mechanicsburg PA  
 SUPANX PWO, Williamsburg VA  
 TVA Smelser, Knoxville, Tenn.; Solar Group, Arnold, Knoxville, TN  
 U.S. MERCHANT MARINE ACADEMY Kings Point, NY (Reprint Custodian)  
 US DEPT OF COMMERCE NOAA, Pacific Marine Center, Seattle WA  
 US DEPT OF HEALTH, ED., & WELFARE Food & Drug Admin. (A. Story), Dauphin Is. AL  
 US GEOLOGICAL SURVEY Off. Marine Geology, Piteleki, Reston VA  
 US NATIONAL MARINE FISHERIES SERVICE Highlands NY (Sandy Hook Lab-Library)  
 USAF REGIONAL HOSPITAL Fairchild AFB, WA  
 US GEOLOGICAL SURVEY (Chas E. Smith) Minerals Mgmt Serv, Reston, VA  
 USCG G-EOE-4 (T Dowd), Washington, DC; G-MMT-4/82 (J Spencer)  
 USCG R&D CENTER CO Groton, CT; D. Motherway, Groton CT  
 USDA Forest Products Lab, Madison WI; Forest Service Reg 3 (R. Brown) Albuquerque, NM; Forest Service, Bowers, Atlanta, GA; Forest Service, San Dimas, CA  
 USNA Ch. Mech. Engr. Dept Annapolis MD; ENGRNG Div, PWD, Annapolis MD; Energy-Environ Study Grp, Annapolis, MD; Environ. Prot. R&D Prog. (J. Williams), Annapolis MD; Mech. Engr. De-., (C. Wu), Annapolis MD; PWO Annapolis MD; USNA-SYS ENG DEPT ANNAPOLIS MD  
 USS FULTON WPNS Rep. Offr (W-3) New York, NY  
 USS JASON Repair Officer, San Francisco, CA  
 ARIZONA State Energy Programs Off., Phoenix AZ  
 AUBURN UNIV. Bldg Sci Dept, Lechner, Auburn, AL  
 BERKELEY PW Engr Div, Harrison, Berkeley, CA  
 BONNEVILLE POWER ADMIN Portland OR (Energy Consvr. Off., D. Davey)  
 BROOKHAVEN NATL LAB M. Steinberg, Upton NY  
 CALIF. DEPT OF FISH & GAME Long Beach CA (Marine Tech Info Ctr)  
 CALIF. DEPT OF NAVIGATION & OCEAN DEV. Sacramento, CA (G. Armstrong)  
 CALIFORNIA INSTITUTE OF TECHNOLOGY Pasadena CA (Keck Ref. Rm)  
 CALIFORNIA STATE UNIVERSITY LONG BEACH, CA (CHELAPATI)  
 COLORADO STATE UNIV., FOOTHILL CAMPUS Fort Collins (Nelson)  
 CONNECTICUT Office of Policy & Mgt. Energy, Div. Hartford, CT  
 CORNELL UNIVERSITY Ithaca NY (Serials Dept, Engr Lib.)  
 DAMES & MOORE LIBRARY LOS ANGELES, CA  
 DRURY COLLEGE Physics Dept, Springfield, MO  
 FLORIDA ATLANTIC UNIVERSITY Boca Raton, FL (McAllister)  
 FOREST INST. FOR OCEAN & MOUNTAIN Carson City NV (Studies - Library)  
 GEORGIA INSTITUTE OF TECHNOLOGY (LT R. Johnson) Atlanta, GA; Col. Arch. Benton, Atlanta, GA  
 HARVARD UNIV. Dept. of Architecture, Dr. Kim, Cambridge, MA  
 HAWAII STATE DEPT OF PLAN. & ECON DEV. Honolulu HI (Tech Info Ctr)  
 ILLINOIS STATE GEO. SURVEY Urbana IL  
 WOODS HOLE OCEANOGRAPHIC INST. Woods Hole MA (Winget)  
 KEENE STATE COLLEGE Keene NH (Cunningham)  
 LEHIGH UNIVERSITY Bethlehem PA (Fritz Engr. Lab No. 13, Beedle); Bethlehem PA (Lunderman Lib. No 30, Flecksteiner)  
 LOUISIANA DIV NATURAL RESOURCES & ENERGY Div Of R&D, Baton Rouge, LA  
 MAINE OFFICE OF ENERGY RESOURCES Augusta, ME

MISSOURI ENERGY AGENCY Jefferson City MO  
 MIT Cambridge MA; Cambridge MA (Rm 10-500, Tech. Reports, Engr. Lib.); Cambridge, MA (Harleman)  
 MONTANA ENERGY OFFICE Anderson, Helena, MT  
 NATL ACADEMY OF ENG. ALEXANDRIA, VA (SEARIE, JR.)  
 NATURAL ENERGY LAB Library, Honolulu, HI  
 NEW HAMPSHIRE Concord NH (Governor's Council on Energy)  
 NEW MEXICO SOLAR ENERGY INST. Dr. Zwibel Las Cruces NM  
 NY CITY COMMUNITY COLLEGE BROOKLYN, NY (LIBRARY)  
 NYS ENERGY OFFICE Library, Albany NY  
 PURDUE UNIVERSITY Lafayette, IN (CE Engr. Lib)  
 SCRIPPS INSTITUTE OF OCEANOGRAPHY LA JOLLA, CA (ADAMS)  
 SEATTLE U Prof Schwaegler Seattle WA  
 SRI INTL Phillips, Chem Engr Lab, Menlo Park, CA  
 STATE UNIV. OF NEW YORK Buffalo, NY; Fort Schuyler, NY (Longobardi)  
 TEXAS A&M UNIVERSITY College Station TX (CE Dept. Herbich); W B Ledbetter College Station, TX  
 UNIVERSITY OF CALIFORNIA BERKELEY, CA (CE DEPT. MITCHELL); Berkeley CA (E. Pearson),  
 Energy Engineer, Davis CA; LIVERMORE, CA (LAWRENCE LIVERMORE LAB, TOKARZ); La Jolla  
 CA (Acq. Dept. Lib. C-075A); UCSE, Physical Plant, San Francisco, CA  
 UNIVERSITY OF DELAWARE Newark, DE (Dept of Civil Engineering, Chesson)  
 UNIVERSITY OF HAWAII HONOLULU, HI (SCIENCE AND TECH. DIV.)  
 UNIVERSITY OF ILLINOIS (Hall) Urbana, IL; Metz Ref Rm, Urbana IL; URBANA, IL (LIBRARY)  
 UNIVERSITY OF MASSACHUSETTS (Heronemus), ME Dept. Amherst, MA  
 UNIVERSITY OF NEBRASKA-LINCOLN Lincoln, NE (Ross Ice Shelf Proj.)  
 UNIVERSITY OF TEXAS Inst. Marine Sci (Library), Port Arkansas TX  
 UNIVERSITY OF TEXAS AT AUSTIN AUSTIN, TX (THOMPSON)  
 UNIVERSITY OF WASHINGTON (FH-10, D. Carlson) Seattle, WA; SEATTLE, WA (OCEAN ENG RSCH  
 LAB, GRAY); Seattle WA (E. Linger)  
 UNIVERSITY OF WISCONSIN Milwaukee WI (Ctr of Great Lakes Studies)  
 VENTURA COUNTY PWA (Brownie) Ventura, CA  
 VIRGINIA INST. OF MARINE SCI. Gloucester Point VA (Library)  
 WESTERN ARCHEOLOGICAL CENTER Library, Tucson AZ  
 ARCAIR CO. D. Young, Lancaster OH  
 ARVID GRANT OLYMPIA, WA  
 ATLANTIC RICHFIELD CO. DALLAS, TX (SMITH)  
 BECHTEL CORP. SAN FRANCISCO, CA (PHELPS)  
 BRITISH EMBASSY M A Wilkins (Sci & Tech Dept) Washington, DC  
 BROWN & ROOT Houston TX (D. Ward)  
 CHEMED CORP Lake Zurich IL (Dearborn Chem. Div.Lib.)  
 COLUMBIA GULF TRANSMISSION CO. HOUSTON, TX (ENG. LIB.)  
 CROWLEY ENVIRON. SERV. CORP Anchorage, AK  
 DESIGN SERVICES Beck, Ventura, CA  
 DIXIE DIVING CENTER Decatur, GA  
 DURLACH, O'NEAL, JENKINS & ASSOC. Columbia SC  
 EVALUATION ASSOC. INC KING OF PRUSSIA, PA (FEDELE)  
 FURGO INC. Library, Houston, TX  
 GARD INC. Dr. L. Holmes, Niles, IL  
 GEOTECHNICAL ENGINEERS INC. Winchester, MA (Paulding)  
 GRUMMAN AEROSPACE CORP. Bethpage NY (Tech. Info. Ctr)  
 HALEY & ALDRICH, INC. Cambridge MA (Aldrich, Jr.)  
 LITHONIA LIGHTING Application eng. Dept. (B. Helton), Conyers, GA 30207  
 MATRECON Oakland, CA (Haxo)  
 MCDONNELL AIRCRAFT CO. (Fayman) Engrng Dept., St. Louis, MO  
 MEDERMOTT & CO. Diving Division, Harvey, LA  
 MIDLAND-ROSS CORP. TOLEDO, OH (RINKER)  
 MOFFATT & NICHOL ENGINEERS (R. Palmer) Long Beach, CA  
 NEWPORT NEWS SHIPBLDG & DRYDOCK CO. Newport News VA (Tech. Lib.)  
 PACIFIC MARINE TECHNOLOGY (M. Wagner) Duvall, WA  
 PG&E Library, San Francisco, CA  
 PORTLAND CEMENT ASSOC. SKOKIE, IL (CORLEY; SKOKIE, IL (KIEGER); Skokie IL (Rsch & Dev  
 Lab, Lib.)  
 RAYMOND INTERNATIONAL INC. E Colle Soil Tech Dept, Pennsauken, NJ; J. Welsh Soiltech Dept,  
 Pennsauken, NJ  
 SANDIA LABORATORIES Albuquerque, NM (Vortman); Library Div., Livermore CA  
 SCHUPACK ASSOC SO. NORWALK, CT (SCHUPACK)  
 SEAFOOD LABORATORY MOREHEAD CITY, NC (LIBRARY)  
 SHANNON & WILLSON INC. Librarian Seattle, WA



SHELL DEVELOPMENT CO. Houston, TX (C. Sellars Jr.)  
TEXTRON INC BUFFALO, NY (RESEARCH CENTER LIB.)  
THE AM. WATERWAYS OPERATIONS, INC. Arlington, VA (Schuster)  
TRW SYSTEMS REDONDO BEACH, CA (DAI)  
UNITED TECHNOLOGIES Windsor Locks CT (Hamilton Std Div., Library)  
WARD, WOLSTENHOLD ARCHITECTS Sacramento, CA  
WESTINGHOUSE ELECTRIC CORP. Annapolis MD (Oceanic Div. Lib., Bryant Library, Pittsburgh PA)  
WM CLAPP LABS - BATTELLE DUXBURY, MA (LIBRARY)  
WOODWARD-CLYDE CONSULTANTS PLYMOUTH MEETING PA (CROSS, III)  
BRAHTZ La Jolla, CA  
BULLOCK La Canada  
ERVIN, DOUG Belmont, CA  
KETRON, BOB Ft Worth, TX  
KRIZIC, T.P. Silver Spring, MD  
CAPT MURPHY Sunnyvale, CA  
PAULI Silver Spring, MD  
BROWN & CALDWELL Saunders, E.M. Oakland, CA  
T.W. MERMEL Washington DC  
WALTZ Livermore, CA



## INSTRUCTIONS

The Naval Civil Engineering Laboratory has revised its primary distribution lists. The bottom of the mailing label has several numbers listed. These numbers correspond to numbers assigned to the list of Subject Categories. Numbers on the label corresponding to those on the list indicate the subject category and type of documents you are presently receiving. If you are satisfied, throw this card away (or file it for later reference).

If you want to change what you are presently receiving:

- Delete — mark off number on bottom of label
- Add — circle number on list
- Remove my name from all your lists — check box on list
- Change my address — line out incorrect line and write in correction (ATTACH MAILING LABEL).
- Number of copies should be entered — after the title of the subject categories you select

Fold on line below and drop in the mail.

Note: Numbers on label but not listed on questionnaire are for NCEL use only, please ignore them.

Fold on line and staple

### DEPARTMENT OF THE NAVY

NAVAL CIVIL ENGINEERING LABORATORY  
PORT HUENEME, CALIFORNIA 93043

#### OFFICIAL BUSINESS

PENALTY FOR PRIVATE USE, \$300

1 IND-NCEL-2700/4 (REV. 12-73)

0930-LL-L70-0044

POSTAGE AND FEES PAID  
DEPARTMENT OF THE NAVY  
DOD-318



Commanding Officer  
Code L14  
Naval Civil Engineering Laboratory  
Port Hueneme, California 93043

## DISTRIBUTION QUESTIONNAIRE

The Naval Civil Engineering Laboratory is revising its primary distribution lists.

### SUBJECT CATEGORIES

- 1 SHORE FACILITIES
- 2 Construction methods and materials (including corrosion control, coatings)
- 3 Waterfront structures (maintenance/deterioration control)
- 4 Utilities (including power conditioning)
- 5 Explosives safety
- 6 Construction equipment and machinery
- 7 Fire prevention and control
- 8 Antenna technology
- 9 Structural analysis and design (including numerical and computer techniques)
- 10 Protective construction (including hardened shelters, shock and vibration studies)
- 11 Soil/rock mechanics
- 13 BEQ
- 14 Airfields and pavements
- 15 ADVANCED BASE AND AMPHIBIOUS FACILITIES
- 16 Base facilities (including shelters, power generation, water supplies)
- 17 Expedient roads/airfields/bridges
- 18 Amphibious operations (including breakwaters, wave forces)
- 19 Over-the-Beach operations (including containerization, materiel transfer, lighterage and cranes)
- 20 POL storage, transfer and distribution
- 24 POLAR ENGINEERING
- 24 Same as Advanced Base and Amphibious Facilities, except limited to cold-region environments

### 28 ENERGY/POWER GENERATION

- 29 Thermal conservation (thermal engineering of buildings, HVAC systems, energy loss measurement, power generation)
- 30 Controls and electrical conservation (electrical systems, energy monitoring and control systems)
- 31 Fuel flexibility (liquid fuels, coal utilization, energy from solid waste)
- 32 Alternate energy source (geothermal power, photovoltaic power systems, solar systems, wind systems, energy storage systems)
- 33 Site data and systems integration (energy resource data, energy consumption data, integrating energy systems)
- 34 ENVIRONMENTAL PROTECTION
- 35 Solid waste management
- 36 Hazardous/toxic materials management
- 37 Wastewater management and sanitary engineering
- 38 Oil pollution removal and recovery
- 39 Air pollution
- 40 Noise abatement
- 44 OCEAN ENGINEERING
- 45 Seafloor soils and foundations
- 46 Seafloor construction systems and operations (including diver and manipulator tools)
- 47 Undersea structures and materials
- 48 Anchors and moorings
- 49 Undersea power systems, electromechanical cables, and connectors
- 50 Pressure vessel facilities
- 51 Physical environment (including site surveying)
- 52 Ocean-based concrete structures
- 53 Hyperbaric chambers
- 54 Undersea cable dynamics

### TYPES OF DOCUMENTS

- 85 Techdata Sheets                      86 Technical Reports and Technical Notes  
83 Table of Contents & Index to TDS

82 NCEL Guide & Updates

91 Physical Security

☐ None—  
remove my name