

AD-A142 987


THE QUANTIFICATION OF DAYLIGHTING(U) AIR FORCE INST OF  
TECH WRIGHT-PATTERSON AFB OH SCHOOL OF SYSTEMS AND  
LOGISTICS T J INGRAM 02 DEC 83 AFIT-LSSR-52-83


1/1

UNCLASSIFIED

F/G 13/1

NL





MICROCOPY RESOLUTION TEST CHART  
NATIONAL BUREAU OF STANDARDS-1963-A

DTIC FILE COPY

AD-A142 987



(2)

THE QUANTIFICATION  
OF DAYLIGHTING

Thomas J. Ingram  
2nd Lt USAF

LSSR 52-83

DISTRIBUTION STATEMENT A

Approved for public release;  
Distribution Unlimited

DEPARTMENT OF THE AIR FORCE  
AIR UNIVERSITY

**AIR FORCE INSTITUTE OF TECHNOLOGY**

DTIC  
ELECTED  
S JUL 13 1984 D  
H

Wright-Patterson Air Force Base, Ohio

84 07 10 007



Accession For  
NTIS GRA&I  
DTIC TAB  
Unannounced  
Justification

By	Distribution/ Availability Codes
Dist	Avail and/or Special
A-1	

THE QUANTIFICATION  
OF DAYLIGHTING

Thomas J. Ingram  
2nd Lt USAF

LSSR 52-83

The contents of the document are technically accurate, and no sensitive items, detrimental ideas, or deleterious information are contained therein. Furthermore, the views expressed in the document are those of the author(s) and do not necessarily reflect the views of the School of Systems and Logistics, the Air University, the United States Air Force, or the Department of Defense.

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE			READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER <b>LSSR 52-83</b>	2. GOVT ACCESSION NO. <b>AD-A1429 87</b>	3. RECIPIENT'S CATALOG NUMBER	
4. TITLE (and Subtitle) <b>THE QUANTIFICATION OF DAYLIGHTING</b>	5. TYPE OF REPORT & PERIOD COVERED <b>Master's Thesis</b>		
7. AUTHOR(s) <b>Thomas J. Ingram, IV, 2nd Lieutenant, USAF</b>	6. PERFORMING ORG. REPORT NUMBER		
9. PERFORMING ORGANIZATION NAME AND ADDRESS <b>School of Systems and Logistics Air Force Institute of Technology, Wright-Patterson AFB, OH</b>	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS		
11. CONTROLLING OFFICE NAME AND ADDRESS <b>Department of Communication AFIT/LSH, WPAFB, OH 45433</b>	12. REPORT DATE <b>2 December 1983</b>		
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)	13. NUMBER OF PAGES <b>70</b>		
15. SECURITY CLASSIFICATION OF THIS REPORT <b>UNCLASSIFIED</b>			
16. DECLASSIFICATION/DOWNGRADING SCHEDULE			
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)			
Approved for public release; distribution unlimited			
18. SUPPLEMENTARY NOTES <i>Tyler Wolan</i> <i>24 February 1984</i>			
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) <b>Daylighting; Solar Energy; Interior Lighting; Computer-Aided Analysis; Building Design; Lighting Design</b>			
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) <b>Thesis Chairman: Timothy L. Skvarenina, Major, USAF</b>			

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

It is the policy of the Air Force to consider solar design applications in its new construction where there is a potential for significant savings of fossil fuel-derived energy. The required analysis, however, is often either not performed properly, or not performed at all. There is a requirement for a simplified preliminary analysis of solar applications so that such analyses may be more reliably accomplished. One aspect of passive solar design is daylighting, used to supplement electric light when conditions are appropriate. A computer program is developed to aid in preliminary daylighting analysis by automating two accepted design procedures: the Zonal Cavity Method for interior lighting design; and the Libby-Owens-Ford method for predicting interior daylighting. After a trial run, it is shown that the appropriate use of passive daylighting can save approximately 23% to 33% of kilowatt-hour lighting costs for a design light level of 70 footcandles. The author concludes that daylighting can offer significant potential savings in lighting costs.

UNCLASSIFIED

LSSR 52-83

THE QUANTIFICATION OF DAYLIGHTING

A Thesis

Presented to the Faculty of the School of Systems and Logistics  
of the Air Force Institute of Technology

Air University

In Partial Fulfillment of the Requirements for the  
Degree of Master of Science in Engineering Management

By

Thomas J. Ingram, BS  
Second Lieutenant, USAF

December 1983

Approved for public release;  
distribution unlimited


This thesis, written by

2LT Thomas J. Ingram

has been accepted by the undersigned on behalf of the faculty of the School of Systems and Logistics in partial fulfillment of the requirements for the degree of

MASTER OF SCIENCE IN ENGINEERING MANAGEMENT

DATE: 2 December 1983



COMMITTEE CHAIRMAN

#### **ACKNOWLEDGEMENTS**

The author would like to acknowledge the help and support of his thesis advisor, Major Timothy Skvarenina; the Graduate Engineering Management program manager, Major Alan E. E. Tucker; Captain Michael Kaminskas, of the AFIT School of Civil Engineering; and his classmates in the GEM 83-S program.

## TABLE OF CONTENTS

	Page
ACKNOWLEDGMENTS. . . . .	iii
LIST OF FIGURES. . . . .	vi
CHAPTER	
1. INTRODUCTION . . . . .	1
Background . . . . .	1
Definitions. . . . .	2
Problem Statement. . . . .	3
Research Question. . . . .	3
Procedure. . . . .	3
Scope and Limitations. . . . .	4
2. LITERATURE REVIEW. . . . .	5
Viability of Daylighting . . . . .	5
LOF Publications . . . . .	6
CEL-1. . . . .	7
AFIT Material. . . . .	7
Air Force Guidance . . . . .	8
3. METHODOLOGY. . . . .	10
Choice of Methods. . . . .	10
Automating the Procedure . . . . .	10
Equipment. . . . .	11
The Program. . . . .	12
4. ANALYSIS . . . . .	16
Location . . . . .	16

Prototype Room . . . . .	17
Running the Program. . . . .	17
Choosing Electric Lighting . . . . .	20
Daylight Analysis. . . . .	21
Results. . . . .	22
Recommendations for Further Research . . . . .	25
APPENDICES	
A. Variable List. . . . .	27
B. Program Listings . . . . .	30
C. Complete Output: Example Run . . . . .	51
D. Output: 30 And 49 Degrees North Latitude . . . . .	64
SELECTED BIBLIOGRAPHY. . . . .	68
A. REFERENCES CITED	
B. RELATED SOURCES	

## LIST OF FIGURES

Figure	Page
1      Program Relationships . . . . .	14
2      Prototype Room . . . . .	18
3      Output for Example Run . . . . .	23

## CHAPTER 1

### INTRODUCTION

The purpose of this project has been to develop a procedure by which the contribution of daylighting to the illumination of a room may be predicted, and to describe that contribution in terms of the electric lighting that is not required when daylight is sufficient to provide a given level of illumination. This procedure could be used by the Air Force to determine the cost effectiveness of unique passive solar daylighting applications. Such applications could potentially reduce the cost of meeting the energy demands of the Air Force.

#### Background

In 1979, the Congress of the United States passed legislation (Section 2688 (a) to Title 10 of the United States Code, November 1979) requiring that all new military construction include solar energy applications, where such applications are found to be cost effective. Among the solar applications to be considered is unique passive daylighting, which is defined as using window areas greater than 15% of the affected wall area to provide workplace illumination. Where increasing the window size is

appropriate, savings would result as the level of daylighting permits electric lights to be turned off.

The experience within the Air Force, however, indicates that the preliminary analysis to determine the cost effectiveness of passive daylighting is not being performed adequately. Specifically, many of the individuals responsible for doing the required analysis are either not aware of accepted methods, or they consider those procedures too time consuming. The task of simplifying the analysis procedure was offered as a topic for graduate research at the Air Force Institute of Technology by Headquarters Air Force/LEEEU. This thesis is the result of that research.

#### Definitions

Unique passive solar daylighting is defined as an application in which in which glazing is more than 15% of the affected wall area. Using up to 15% of the wall area for windows is generally considered to be normal (7:1). A unique solar application can be expected to add to the initial cost of a structure, and must therefore be analyzed and proved cost effective in accordance with Congressional guidelines (6:1).

The amount of light at a given location is usually described in terms of footcandles. For the purposes of this

report, one footcandle may be considered to be the amount of light that falls on a one-square-foot surface from a candle one foot away (5:7).

Problem Statement

It is the policy of the Air Force to consider passive solar applications in construction where there is a potential for significant savings of fossil fuel-derived energy. What is lacking, however, is a simple and direct approach to analyzing daylighting and quantifying the savings that may be possible at a given location. Research into the specific criteria involved in the evaluation of passive solar daylighting applications is needed.

Research Question

How may the designers of Air Force construction projects, in accomplishing the required preliminary analysis of unique solar daylighting applications, quickly and reliably estimate the value of daylighting at a given location?

Procedure

Current procedures for predicting interior daylight illumination is investigated, and a simple computerized method of estimating potential savings in electric lighting

costs is developed.

#### Scope and Limitations

This project is limited to consideration of passive solar daylighting applications, as distinct from passive solar heating and cooling applications. A thorough cost analysis must consider both types of applications, because increasing glass area is a technique for increasing direct heat gain as well as daylight availability. Predicting the cost effectiveness of solar heating and cooling, however, is by itself a significant topic and is left for other research.

The computer program developed during the course of this project has been written with conventional rectangular structures in mind. Such daylighting techniques as skylights and clerestories are not considered.

Only the quantity of available daylight is taken into account. Such aspects of light quality as contrast and glare are ignored.

Calculations may only be performed for locations between 24 and 52 degrees latitude, which includes all of the continental United States. The rooms considered in this program must face south.

## CHAPTER 2

### LITERATURE REVIEW

Literature in the field of interior lighting and daylighting will be briefly discussed in this chapter. Specifically, previous work that is relevant to developing simplified estimating procedures is reviewed. Also included is recent Air Force guidance details approved methods for the analysis of passive solar applications.

#### Viability of Daylighting

As Evans (3:142) observes, "daylighting is part of the total building cost-benefit picture...and must be considered in conjunction with other lighting costs and benefits" in order to make a reliable estimate of cost effectiveness. Evans takes particular care to establish that windows are not necessarily the "energy losers" that many people believe them to be. Solar gains during the air-conditioning season and conduction losses during the heating season are the obvious disadvantages associated with windows, but these must be balanced against solar heat gain in the winter and the reduced heat load that results from not turning lights on in the summer. Multipane windows offer greatly decreased thermal transmittance as compared

to monolithic glass windows. According to a booklet published by the Libby-Owens-Ford Company (5:3), "the proper use of daylighting for interiors can reduce the electrical consumption of a building by three times the kilowatt cost of heat gain and loss through the windows.

The American Institute of Architects Level 3A Seminar on Daylighting reinforces Evans's observations concerning the broader cost-benefit picture (1:5.1), and includes several simplified methods for estimating the various energy requirements of a building. The seminar package includes a worksheet for calculating the electric energy savings that would result if appropriate lights were turned off around the perimeter of a building. The method makes use of the "Sun Angle Calculator," a design aid available from the Libby-Owens-Ford Company, and local weather information to determine average annual savings.

#### LOF Publications

In addition to the above-mentioned "Sun Angle Calculator," the Libby-Owens-Ford Company has also published a booklet called How to Predict Interior Daylight Illumination. Both of these items are easy to use, and the fact of their incorporation into the AIA methods suggests that they have been well received by design professionals. Air Force Engineering Technical Letter 82-5 specifically

identifies these LOF publications as acceptable for Air Force purposes (6:5). How to Predict Interior Daylight Illumination provides graphs and tables, from which values may be obtained for illumination, coefficients of utilization, surface reflectance, and glass transmittance.

#### CEL-1

An extensive computer program, the Conservation of Electric Lighting Program Version 1.0 (CEL-1), is presently available for aiding the illumination engineer in designing energy efficient rooms. In particular, CEL-1 calculates the most efficient luminaire locations given the user's design criteria. The user may provide such details as the placement of furniture, walls and partitions, and the use of dimmers. The level of detail possible with CEL-1 suggests that its most profitable use might be somewhat later in the design process than the procedure developed for this project.

#### AFIT Material

The Air Force Institute of Technology School of Civil Engineering distributes a guide called the "Introduction to Lighting Design" in conjunction with its electrical engineering classes. The guide contains a procedure, the Zonal Cavity Method, for calculating the number of lighting

fixtures required to provide a given footcandle level in a rectangular room (2:2). This procedure forms the basis for determining what electric lighting is required in the preliminary analysis design room considered in this project. The Method is one way of determining a room's Coefficient of Utilization (CU), that coefficient being the percentage of generated light that actually reaches the workplane. The Zonal Cavity Method considers aspects of room geometry, such as fixture-to-workplane distance and fixture-to ceiling distance, from which guide numbers are calculated. The guide numbers are used to locate the appropriate CU on a chart, such as the Photometric Data Chart in the Illuminating Engineering Society's IES Lighting Handbook.

#### Air Force Guidance

Engineering Technical Letter (ETL) 82-5, entitled "Solar Applications," and dated 10 November 1982 has been distributed to the Air Force Major Commands by Headquarters Air Force. This document outlines current initiatives in the implementation of passive solar technology. For purposes of calculating daylight illumination, ETL 82-5 states that 20 feet is the maximum room depth to be considered (6:6).

ETL 82-6, entitled "Normal Passive Solar

Applications," and dated 30 December 1982, provides details of solar design considerations that must be considered in all Air Force building design. Of specific interest is the guidance on orientation: maximum solar exposure is achieved by situating a rectangular building with the long dimension along the east-west axis, and all buildings should be sited within 45 degrees of this orientation unless significant factors indicate otherwise (8:2). Rooms with southern exposure may get much of their heat and light from the sun. Spaces that are less temperature- and light-sensitive, such as corridors, closets, and mechanical rooms, should be placed along the northern side to act as a "buffer between the heated spaces and the colder north face" (8:3).

There must be available daylight for at least 6 hours per day at all times of the year, and ETL 82-6 specifies that those hours should be between 0900 and 1500 for analysis purposes.

## CHAPTER 3

### METHODOLOGY

The methodology employed in this project has been to identify the variables and equations used in existing lighting and daylighting prediction procedures, and to then develop a computerized routine for the quantification of electricity savings possible with the use of daylighting. Such a routine would be useful as part of an economic analysis of the cost effectiveness of daylighting applications.

#### Choice of Methods

Because of their simplicity and the ease with which they could be adapted to a computer program, the Libby-Owens-Ford methods and the AFIT School of Civil Engineering methods were chosen to form the basis of the daylighting quantification procedure. Further, both methods have been identified as acceptable for Air Force use in making daylighting and electric lighting calculations.

#### Automating the Procedure

While the LOF and AFIT methods are relatively simple to use, they can also become tedious as the number of

iterations increases. For example, the LOF procedure for estimating daylight at a particular location involves finding the angle of the sun at the specific hour, reading direct and reflected light values from a series of charts, and performing several mathematical calculations using coefficients corresponding to the design conditions. In order to estimate yearly savings, these calculations would have to be repeated for each daylight hour on a representative selection of days. Further, the calculations would have to be done for both cloudy and clear conditions. As the number calculations increases, the desirability of using the LOF method to manually figure yearly savings decreases.

By storing the required tables and equations in a computer, what are essentially the same calculations can be performed for each hour, season, and sky condition. The principal effort of this project has been directed at automating the LOF procedure, and calculating the possible savings when the electric lighting system chosen by the AFIT procedure can be turned off.

#### Equipment

The computer equipment used to develop this project is the Tandy Corporation TRS-80 Color Computer and disk system. A microcomputer was chosen because such systems are

increasingly available to private individuals and to professionals at their places of work. Many of these systems use a version of the BASIC computer language licensed from the Microsoft Corporation, as does the TRS-80. In that no version of BASIC is likely to be very different from any other, the potential user of this program should have no difficulty in finding a microcomputer on which the routines may be run. The principal changes that one might expect would be in the input/output statements, as each manufacturer is likely to address storage and printing devices in a different way.

It is necessary to have data available concerning light fixtures and lamps, such as may be found in the IES Lighting Handbook.

#### The Program

The program for quantifying potential daylighting savings is divided into five parts, as follows: calculating required solar altitudes and azimuths for a given latitude; setting illumination data into arrays for later use; calculating available light for winter, spring, and autumn skies; calculating available light for summer and cloudy skies; and determining energy savings based on calculations using the previously stored available light and room data. Each part is a separate program, the separations being made

on the basis of the logical grouping of procedures and the limitations of available computer memory. Their interrelationship is depicted in Figure 1.

The first program, PART1, calculates solar angles and azimuths for a given latitude. The required latitude having been entered, the program searches through data statements until that value has been bracketed by latitudes for which solar altitude angles and azimuths are available. The altitude and azimuth data was obtained from the LOF "Sun Angle Calculator." For input latitudes not equal to one of the index latitudes, altitudes and azimuths are obtained by linear interpolation. The altitude and azimuth calculations are then written to a file for later use.

The second program, PART2, is designed to set information into arrays and to write it to files for later use. This information has been read from the charts in the LOF booklet, How to Predict Interior Daylight Illumunation, and consists of data for sky illuminations, direct illuminations, and coefficients of utilization.

PART3 is the third program, which calculates the available illumination under summer and cloudy skies. The solar altitude angles and azimuths found in PART1 are compared to the indexes of the available light tables stored in PART2. The resulting values for available light are saved in a file.




Figure 1  
Program Relationships

PART4 performs the same function as PART3, but finds and saves the available light for winter and spring/fall skies. Because sun positions are symmetric with respect to the summer and winter solstices, it is sufficient to use the one chart for both seasons.

PART5 is the program in which the electric lighting and daylighting calculations are made. The program consists of two routines: finding a prototype electric lighting system using the Zonal Cavity Method; and finding the amount of time during the course of a year that daylight is sufficient to allow turning off the electric lights.

Output of interest to the user is printed during the course of the run to record the user's inputs and the program's assumptions. The user may elect to have more information printed, specifically the footcandle levels for daylight under both clear and cloudy skies at three reference points in the prototype room. As this information is printed for each hour for seven months (the fall and spring months being symmetrical about the solstices, as previously noted) and for three glass areas, the user might wish to stop the extended printout as soon as he was satisfied that the values obtained were realistic.

## CHAPTER 4

### ANALYSIS

This chapter describes a test case of the program developed for this thesis. The progress of the program during the test run is followed and the results are discussed. Recommendations are made with respect to further research.

#### Location

The program user describes the geographic location he wishes to analyze in two ways: by choosing the location latitude; and by using actual or assumed weather data to indicate the occurrence of clear, partly cloudy, and cloudy skies. For the purposes of this example, a latitude of 39 degrees north is assumed. Sky conditions are taken to be clear 20% of the time over the course of a year, partly cloudy 50%, and cloudy 30%.

Also included in Appendix D are the outputs for two assumed locations near the northern and southern borders of the continental United States. The northern location was chosen at 49 degrees north latitude, and the southern location at 30 degrees north latitude.

### Prototype Room

The prototype room used in this test run is depicted in Figure 2. Clear thermopane glass is used to maximize light transmission, and also to minimize heat transfer even though heating and cooling considerations are not a part of this analysis.

The lights are placed in three rows parallel to the plane of the window. The lights are directly over the three desktop-level points in the room (MAX, MID, and MIN) at which the illumination levels are predicted. Thus, if daylight provides the required amount of light at a certain distance into the room, all the lights at that distance may be turned off.

The design light level is 70 footcandles, which is suitable for such office tasks as reading manuscripts, typing, and filing.

On clear days, direct sunlight falls on the surface of the window. It is assumed that there is a macadam street or parking lot outside the window, and that 18% of the daylight that falls on it is reflected to the window (5:11).

### Running the Program

Upon giving the command to run PART1, the user is asked to enter the latitude of the location to be analyzed.




Figure 2  
Prototype Room

In this example, the value 39 is entered. The program proceeds to read data statements containing the solar altitude angles and azimuths for each latitude until the input latitude is bracketed by the stored latitudes (in this case, 36 and 40). Solar altitudes and azimuths are then estimated for the input latitude by linear interpolation between the bracket latitudes. These interpolated values are stored for later use in a file called "ANGLES/DAT".

Executing program PART2 causes several tables, stored as matrices, to be saved in files on disk. The tables include sky illumination data for clear summer, winter, and spring-fall skies; direct sunlight illumination values; overcast sky illuminations; and coefficients of utilization.

PART3 and PART4 accomplish similar functions. Both use the solar altitude angles and azimuths found in PART1, and compare those angles to the indexes of the tables stored in PART2. PART3 finds and saves available light information for summer and cloudy skies; PART4 finds and saves available light information for winter and spring/fall skies. Spring and fall values are obtained from the same chart because the sun positions in the two seasons are symmetrical with respect to the summer and winter solstices.

The program PART5 consists of two sections. The first section involves choosing an artificial lighting system. The second part analyzes daylight in the same room, and calculates the kilowatt-hour savings possible based on the electric lighting system characteristics.

#### Choosing Electric Lighting

The first user inputs required in PART5 are room dimensions. The user may choose from three room lengths: 20, 30, or 40 feet. The ceiling height may be chosen at 8, 10, or 12 feet. In this example, a 20 foot length and an 8 foot ceiling height were entered. The room depth is set at 20 feet, the upper limit imposed by Air Force guidance on daylight analysis.

The next user inputs involve the choice of a particular electric lighting system. This example assumes fluorescent light fixtures mounted in a suspended ceiling, and thus the fixture-to-ceiling height is 0. Given these room characteristics, the program is able to proceed with the Zonal Cavity Method for interior light design. The Room Cavity Ratio (RCR) is calculated and printed so that the user may find the coefficient of utilization (CU) for his choice of fixture in the IES Handbook. For the example, given an RCR of 2.75, a two lamp unit with a flat prismatic lens was chosen and the CU was found to be .64 (2:C76).

Also chosen from the IES Handbook tables is the lamp to be installed in the fixture. A 36-inch, 32.4 watt (including ballast) Cool White lamp was chosen for the example. A Lamp Lumen Depreciation factor (LLD) of .81 was noted for the lamp (2:D83). The Luminaire Dirt Depreciation factor (LDD) of .9 was obtained from the IES Handbook tables, for clean conditions (2:B59). Multiplying the LLD by the LDD gives the Maintenance Factor (.73 in this case), which is entered into the program.

Given the required footcandle level, the program calculates the number of fixtures required to provide that level. The user is given the opportunity to choose a whole number of fixtures that could be symmetrically installed. For the example, 13 fixtures were required and 15 were chosen for the final design. The user is also given the opportunity to go back and change either room dimensions or fixture and lamp characteristics.

#### Daylight Analysis

The electric light design having been accomplished, the daylighting analysis begins. The program reads in the files containing the total available light that were previously obtained, and calculates glass areas as percentages (15%, 30%, and 60%) of the wall area. The user supplies the program with the percentage of light that is

reflected to the window from the ground (obtained from IES Handbook tables), and the percentage of light that passes through the chosen window (obtained from manufacturer's data). The reflectance entered for the example was 18%, and the glass transmittance was 77%.

The user may choose to have all the footcandle levels calculated for the room printed out, or may choose to save time by printing only the final results. The example was run twice: the short output is included as Figure 3; the complete run, including the individual light levels, is included as Appendix C.

### Results

Figure 3 shows the output from the example run. The most significant observation to be made about this example is that daylight seems to be able to provide a substantial saving in terms of kilowatt-hours: a window that is 60% of the wall area could be expected to save 591 kilowatt-hours out of a total of 1769 kilowatt-hours per year, or better than 33% of electric lighting costs per year given the assumed weather. Whether daylighting would in fact be cost effective under the circumstances analyzed in this example would depend on the cost of installing the larger window, and on the cost of electricity. The cost-benefit analysis would have to be carried out for the projected life of the

LATITUDE = 39

LENGTH OF ROOM: 20

WIDTH OF ROOM ASSUMED TO BE 20 FEET

CEILING HEIGHT= 8

FLOOR TO WORKPLANE HEIGHT ASSUMED TO BE 2.5 FEET

Fixture to ceiling height= 0

Room cavity ratio= 2.75

Ceiling cavity ratio= 0

Floor cavity ratio= 1.25

Coefficient of utilization: .64

Maintenance factor: .73

Lamps per luminaire: 2

Lumens per lamp: 2300

Watts per lamp: 32.4

Design footcandle level: 70

The actual footcandle level for 15 fixtures is: 80.592

Ground reflectance: .18

Glass transmittance: .77

Electric use without daylighting: 1769.04 KW-HRS/YR

The following are luminaire row-hours when lights are off--

GLASS AREA HRS OFF(SUN) HRS OFF(CLD)

15%	2808	108
30%	2952	864
60%	3024	1944

GLASS AREA KW-HRS OFF(SUN) KW-HRS OFF(CLD)

15%	909.792001	34.992
30%	956.448	279.936
60%	979.776001	629.856

Figure 3

Output for Example Run

CLEAR= 20 %, PTLY CLDY= 50 %, CLDY= 30 %

TOTAL EXPECTED KW-HRS SAVINGS: 246.6936  
FOR GLASS = 15 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 393.8768  
FOR GLASS = 30 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 591.364801  
FOR GLASS = 60 % OF WALL AREA

Figure 3 (cont'd)

Output for Example Run

building.

The results for test runs at other latitudes (Appendix D) support the observation that daylighting has a significant impact on kilowatt-hour usage at a 70 footcandle design light level, at each latitude providing a possible 23% and 33% savings in kilowatt-hour lighting use for 30%- and 60%- of-wall-area windows, respectively. Of course, even greater savings could be realized if the design footcandle level was lower.

#### Recommendations for Further Research

The quantity of light at a given location is not the only consideration of the lighting designer. Also important are aspects of the quality of the light being provided, such as contrast, glare, and veiling reflections. The proper use of daylighting to address light quality can result in greater task visibility, while footcandle requirements can be reduced by 50% or more (4:6). Further research might find ways of incorporating quality aspects into the routine, so that without affecting task visibility, the threshold at which daylight becomes sufficient to replace electric light could be safely lowered.

Further research might also develop a program that

combines solar lighting and heating applications, and which would consider installation and energy costs in determining if an integrated solar energy system is cost effective for a given situation.

**APPENDIX A  
VARIABLE LIST**

## VARIABLES USED

L	LATITUDE, LENGTH OF ROOM
LA(2)	INDEX LATITUDES
SA(2,7,7)	SOLAR ALTITUDE(ITERATION,MONTH,HOUR)
AA(7,7)	CALCULATED SOLAR ALTITUDE(MONTH,HOUR)
SZ(2,7,7)	AZIMUTH (ITERATION,MONTH,HOUR)
AZ(7,7)	CALCULATED AZIMUTH(MONTH,HOUR)
AT(11)	SOLAR ANGLE INDEX
AW(11)	SOLAR ANGLE INDEX
AF(14)	SOLAR ANGLE INDEX
CS(11,5)	ILLUMINATION ARRAY(ALT.,AZ.)
CW(11,5)	ILLUMINATION ARRAY
CA(14,5)	ILLUMINATION ARRAY
BA(5)	AZIMUTH INDEX
DS(19,4)	ILLUMINATION ARRAY(ALT.,AZ.)
DA(19)	ALTITUDE INDEX
OS(19,2)	OVERCAST ILLUMINATION ARRAY(ALT.,SURFACE)
CU(4,3,3)	COEFFICIENTS OF UTILIZATION
TL(7,2,7,2)	TOTAL LIGHT(MONTH,SKY,HR,SURF.)
EL-E4	LIGHT VALUE READ FROM TABLE
TC	ELECTRIC USE WITHOUT DAYLIGHT, KW-HRS
II-I7	FOOTCANDLE VALUES, CLR SKIES
J1-J7	FOOTCANDLE VALUES, CLDY SKIES
WB	WATT-HRS PER BANK
S1-S3	WEATHER %'S

S4	HRS OFF, CLEAR
S5	HRS OFF, CLDY
S6,S7	HRS OFF, PTLY CLDY
S8	HRS OFF, TOTAL
S10	KW-HRS SAVINGS, TOTAL

**APPENDIX B  
PROGRAM LISTINGS**

## THE QUANTIFICATION OF DAYLIGHTING

```
100 ' PROGRAM: PART1
110 '
120 ' PROGRAM STORES HOURLY SOLAR ANGLES AND AZIMUTHS FOR
130 ' LATITUDES 24 TO 52 (BY 4) AND INTERPOLATES TO FIND
VALUES
140 ' FOR ANY GIVEN LATITUDE BETWEEN 24 AND 52.
150 '
160 DIM LA(2),SA(2,7,7),AA(7,7),SZ(2,7,7),AZ(7,7)
170 INPUT "LATITUDE";L
180 PRINT #2,"LATITUDE =";L
190 PRINT#2
200 '
210 ' READ IN STORED ANGLE DATA
220 READ LA(1)
230 FOR M=1 TO 7
240 FOR H=1 TO 7
250 READ SA(1,M,H):NEXT H
260 FOR J=1 TO 7
270 READ SZ(1,M,J):NEXT J
280 NEXT M
290 FOR I=1TO7
300 LA(2)=LA(1)
310 READ LA(1)
320 FOR M=1TO7
330 FOR H=1TO7
340 SA(2,M,H)=SA(1,M,H)
350 READ SA(1,M,H)
360 ' BRACKET GIVEN LATITUDE BETWEEN AVAILABLE LATITUDES-
370 IF LA(1)>=L AND LA(2)<L THEN 420
380 GOTO 460
390 '
400 '
410 ' INTERPOLATION STEPS-SOLAR ANGLES
420 AA(M,H)=((LA(1)-L)/4)*(SA(1,M,H)-SA(2,M,H))-SA(1,M,H)
430 AA(M,H)=AA(M,H)*-1
440 ' ROUND RESULT TO NEAREST 5 DEGREES
450 AA(M,H)=INT(AA(M,H)/5+.5)*5
460 NEXT H
470 '
480 FOR J=1TO7
490 SZ(2,M,J)=SZ(1,M,J)
500 READ SZ(1,M,J)
510 IF LA(1)>=L AND LA(2)<L THEN 540
520 GOTO 570
```

```

530 ' INTERPOLATION TO FIND AZIMUTHS FOR GIVEN LAT.
540 AZ(M,J)=((LA(1)-L)/4)*(SZ(1,M,J)-SZ(2,M,J))-SZ(1,M,J)
550 AZ(M,J)=AZ(M,J)*-1
560 '
570 NEXT J
580 NEXT M
590 NEXT I
600 '
610 ' WRITE CALCULATED ANGLES AND AZIMUTHS TO FILE:
ANGLES/DAT
620 OPEN "O",#1,"ANGLES/DAT"
630 FOR A=1TO7
640
WRITE#1,AA(A,1),AA(A,2),AA(A,3),AA(A,4),AA(A,5),AA(A,6),AA(A
,7)
650 NEXT A
660 FOR B=1TO7
670
WRITE#1,AZ(B,1),AZ(B,2),AZ(B,3),AZ(B,4),AZ(B,5),AZ(B,6),AZ(B
,7)
680 NEXT B
690 CLOSE #1
700 '
710 ' DATA-
720 DATA 24,26,34,40,43,40,34,26
730 DATA 46,33,18,0,18,33,46
740 DATA 28,37,44,46,44,37,28
750 DATA 48,35,20,0,20,35,48
760 DATA 34,45,53,56,53,45,34
770 DATA 56,42,24,0,24,42,56
780 DATA 40,53,62,67,62,53,40
790 DATA 68,55,33,0,33,55,68
800 DATA 46,59,72,78,72,59,46
810 DATA 82,71,51,0,51,71,82
820 DATA 48,62,76,86,76,62,48
830 DATA 90,87,76,0,76,87,90
840 DATA 49,63,77,87,77,63,49
850 DATA 90,90,89,0,89,90,90
860 DATA 28,22,31,37,39,37,31,22
870 DATA 45,32,17,0,17,32,45
880 DATA 25,34,40,42,40,34,25
890 DATA 47,34,18,0,18,34,47
900 DATA 32,42,48,52,48,42,32
910 DATA 55,40,22,0,22,40,55
920 DATA 39,50,59,62,59,50,39
930 DATA 65,51,29,0,29,51,65
940 DATA 45,58,69,74,69,58,45
950 DATA 78,66,42,0,42,66,78
960 DATA 49,62,75,82,75,62,49
970 DATA 89,80,62,0,62,80,89
980 DATA 50,63,76,85,76,63,50
990 DATA 90,87,73,0,73,87,90

```

```
1000 DATA 32,20,27,33,35,33,27,20
1010 DATA 43,31,16,0,16,31,43
1020 DATA 22,31,36,38,36,31,22
1030 DATA 46,33,17,0,17,33,46
1040 DATA 30,38,45,47,45,38,30
1050 DATA 52,38,21,0,21,38,52
1060 DATA 37,48,55,58,55,48,37
1070 DATA 62,47,27,0,27,47,62
1080 DATA 45,56,66,70,66,56,45
1090 DATA 74,60,37,0,37,60,74
1100 DATA 48,61,72,78,72,61,48
1110 DATA 85,73,51,0,51,73,85
1120 DATA 50,62,74,82,74,62,50
1130 DATA 89,79,59,0,59,79,89
1140 DATA 36,17,24,29,31,29,24,17
1150 DATA 42,30,16,0,16,30,42
1160 DATA 20,27,33,34,33,27,20
1170 DATA 44,31,16,0,16,31,44
1180 DATA 27,36,42,44,42,36,27
1190 DATA 51,37,19,0,19,37,51
1200 DATA 35,45,52,54,52,45,35
1210 DATA 59,44,24,0,24,44,59
1220 DATA 43,54,63,66,63,54,43
1230 DATA 70,55,32,0,32,55,70
1240 DATA 48,60,70,74,70,60,48
1250 DATA 80,66,42,0,42,66,80
1260 DATA 50,62,72,77,72,62,50
1270 DATA 84,71,48,0,48,71,84
1280 DATA 40,15,21,25,27,25,21,15
1290 DATA 42,30,15,0,15,30,42
1300 DATA 17,24,29,31,29,24,17
1310 DATA 44,31,16,0,16,31,44
1320 DATA 25,33,38,40,38,33,25
1330 DATA 50,35,19,0,19,35,50
1340 DATA 33,42,48,51,48,42,33
1350 DATA 57,42,23,0,23,42,57
1360 DATA 42,52,59,62,59,52,42
1370 DATA 68,52,29,0,29,52,68
1380 DATA 47,58,67,71,67,58,47
1390 DATA 76,61,37,0,37,61,76
1400 DATA 49,60,70,74,70,60,49
1410 DATA 80,66,42,0,42,66,80
1420 DATA 44,11,17,21,23,21,17,11
1430 DATA 41,29,15,0,15,29,41
1440 DATA 14,20,25,26,25,20,14
1450 DATA 43,30,15,0,15,30,43
1460 DATA 22,29,34,36,34,29,22
1470 DATA 48,34,18,0,18,34,48
1480 DATA 31,39,44,47,44,39,31
1490 DATA 55,39,21,0,21,39,55
1500 DATA 40,49,55,58,55,49,40
1510 DATA 64,47,26,0,26,47,64
```

1520 DATA	46,56,63,67,63,56,46
1530 DATA	72,55,32,0,32,55,72
1540 DATA	48,58,66,70,66,58,48
1550 DATA	75,59,35,0,35,59,75
1560 DATA	48,8,14,17,18,17,14,8
1570 DATA	41,28,14,0,14,28,41
1580 DATA	12,17,21,22,21,17,12
1590 DATA	43,29,15,0,15,29,43
1600 DATA	20,26,30,32,30,26,20
1610 DATA	47,33,17,0,17,33,47
1620 DATA	28,36,41,43,41,36,28
1630 DATA	53,38,20,0,20,38,53
1640 DATA	37,46,52,54,52,46,37
1650 DATA	61,45,24,0,24,45,61
1660 DATA	45,53,60,63,60,53,45
1670 DATA	68,51,28,0,28,51,68
1680 DATA	47,56,63,66,63,56,47
1690 DATA	71,54,31,0,31,54,71
1700 DATA	52,5,10,13,14,13,10,5
1710 DATA	41,28,14,0,14,28,41
1720 DATA	8,13,17,18,17,13,8
1730 DATA	42,29,15,0,15,29,42
1740 DATA	16,23,26,27,26,23,16
1750 DATA	46,32,16,0,16,32,46
1760 DATA	26,33,37,38,37,33,26
1770 DATA	52,36,19,0,19,36,52
1780 DATA	36,43,48,50,48,43,36
1790 DATA	59,42,22,0,22,42,59
1800 DATA	43,51,57,58,57,51,43
1810 DATA	65,47,26,0,26,47,65
1820 DATA	46,54,59,62,59,54,46
1830 DATA	67,50,27,0,27,50,67

```

100 ' PROGRAM: PART2
110 '
120 ' PROGRAM READS IN DATA FOR SEASONAL AND OVERCAST SKY
130 ' ILLUMINATIONS, AND COEFFICIENTS OF UTILIZATION.
140 ' DATA IS SAVED IN FILES FOR REFERENCE BY LATER
PROGRAMS.
150 DIM
AT(11),AW(11),AF(14),CS(11,5),CW(11,5),CA(14,5),BA(5)
160 '
170 ' READS IN CLEAR SUMMER SKY ILLUMINATIONS.
180 ' AT(A) IS THE SOLAR ANGLE INDEX; BA(C) IS THE AZIMUTH
INDEX
190 ' CS(A,B) IS THE ILLUMINATION ARRAY.
200 '
210 I=35
220 FOR A=1TO11
230 AT(A)=I+5
240 I=I+5
250 FOR B=1TO5
260 READ CS(A,B)
270 NEXT B:NEXT A
280 FOR C=1TO5
290 READ BA(C):NEXT C
300 DATA 1480,1330,950,700,1350
310 DATA 1490,1320,950,710,1450
320 DATA 1480,1300,950,730,1500
330 DATA 1450,1270,940,750,1580
340 DATA 1420,1210,930,750,1600
350 DATA 1380,1080,920,750,1600
360 DATA 1300,1050,900,750,1600
370 DATA 1250,1020,900,750,1600
380 DATA 1200,990,900,750,1600
390 DATA 1150,960,900,750,1600
400 DATA 1100,930,900,750,1600
410 DATA 0,45,70,90,100
420 '
430 '
440 ' READS IN CLEAR WINTER SKY ILLUMINATIONS.
450 ' AW(A) IS THE SOLAR ANGLE INDEX; CW(A,B) IS ILLUM.
ARRAY
460 '
470 Y=0
480 FOR A=1TO11
490 AW(A)=Y
500 Y=Y+5
510 FOR B=1TO5
520 READ CW(A,B)
530 NEXT B:NEXT A
540 DATA 0,0,0,0,0
550 DATA 600,400,200,150,280
560 DATA 830,670,380,250,440

```

```

570 DATA 970,800,490,330,580
580 DATA 1040,880,570,390,670
590 DATA 1100,910,620,430,770
600 DATA 1120,940,660,470,850
610 DATA 1130,950,680,500,920
620 DATA 1130,940,690,520,980
630 DATA 1120,930,700,530,1030
640 DATA 1120,920,700,530,1050
650 '
660 '
670 ' READS IN CLEAR FALL/SPRING SKY ILLUMINATIONS.
680 ' AF(A) IS THE SOLAR ANGLE INDEX; CA(A,B) IS ILLUM.
ARRAY
690 '
700 V=10
710 FOR A=1TO14
720 AF(A)=V+5
730 FOR B=1TO5
740 READ CA(A,B)
750 NEXTB:NEXTA
760 DATA 1040,830,590,380,630
770 DATA 1140,960,670,460,760
780 DATA 1200,1040,740,510,880
790 DATA 1250,1090,780,560,1000
800 DATA 1280,1120,810,590,1100
810 DATA 1300,1130,830,610,1180
820 DATA 1300,1130,830,620,1250
830 DATA 1290,1110,820,610,1310
840 DATA 1270,1080,800,600,1360
850 DATA 1250,1050,780,590,1400
860 DATA 1230,1020,760,580,1440
870 DATA 1210,990,730,560,1470
880 DATA 1180,960,700,540,1500
890 DATA 1150,920,670,510,1500
900 '
910 '
920 ' READS IN ILLUMINATIONS FROM DIRECT SUNSHINE.
930 ' DA(A) IS THE SOLAR ANGLE INDEX; DS(A,B) IS ILLUM.
ARRAY
940 '
950 DIM DS(19,4),DA(19),OS(19,2),CU(4,3,3)
960 U=0
970 FOR A=1TO19
980 DA(A)=U
990 U=U+5
1000 FOR B=1TO4
1010 READ DS(A,B)
1020 NEXT B:NEXT A
1030 DATA 0,0,0,0
1040 DATA 1750,1250,300,175
1050 DATA 3000,2250,700,500
1060 DATA 4200,2900,1000,1000

```

```
1070 DATA 5000,3500,1250,750
1080 DATA 5500,3750,1400,2600
1090 DATA 5700,4000,1500,3500
1100 DATA 5800,4100,1600,4100
1110 DATA 5700,4100,1600,5000
1120 DATA 5500,3900,1500,5500
1130 DATA 5200,3600,1400,6000
1140 DATA 4700,3300,1250,6500
1150 DATA 4200,2900,1000,7000
1160 DATA 3500,2500,800,7500
1170 DATA 3000,2000,600,7750
1180 DATA 2300,1500,500,8250
1190 DATA 1500,1000,250,8400
1200 DATA 800,500,100,8600
1210 DATA 0,0,0,8800
1220 '
1230 '
1240 ' READS IN O'CAST ILLUMINATIONS
1250 ' INDEX SAME AS DIRECT ILLUM, NOT READ IN AGAIN;
OS(A,B) IS
1260 ' THE OVERCAST ILLUMINATION ARRAY
1270 FOR A=1TO19
1280 FOR B=1TO2
1290 READ OS(A,B)
1300 NEXT B:NEXTA
1310 DATA 0,0,50,180,150,350
1320 DATA 200,540,280,700,350,850
1330 DATA 400,1050,480,1200,550,1300
1340 DATA 650,1580,700,1750,800,1950
1350 DATA 900,2150,1000,2350,1100,2700
1360 DATA 1200,3200,1300,3300
1370 DATA 1400,3400,1500,3400
1380 '
1390 ' READS IN COEFFICIENTS OF UTILIZATION
1400 ' STORED IN ARRAY CU(A,B,C)
1410 FOR A=1TO4
1420 FOR B=1TO3
1430 FOR C=1TO3
1440 READ CU(A,B,C)
1450 NEXT C:NEXTB:NEXTA
1460 DATA .0276,.0159,.0087
1470 DATA .0191,.0101,.0063
1480 DATA .0143,.0081,.005
1490 DATA .125,.0908,.0908
1500 DATA .121,.107,.0951
1510 DATA .111,.111,.111
1520 DATA .0206,.0153,.0106
1530 DATA .0143,.01,.0079
1540 DATA .011,.0083,.0067
1550 DATA .145,.110,.105
1560 DATA .129,.116,.112
1570 DATA .111,.111,.111 .
```

```
1580 '
1590 '
1600 ' SAVE DATA TO FILES-
1610 '
1620 OPEN "O",#1,"WINTER/DAT"
1630 FOR A=1TO11
1640 PRINT#1,AW(A)
1650 FOR B=1TO5:WRITE#1,CW(A,B):NEXT B
1660 NEXT A
1670 FOR C=1TO5:WRITE#1,BA(C):NEXT C
1680 FOR A=1TO19
1690 PRINT#1,DA(A)
1700 FOR B=1TO4:WRITE#1,DS(A,B):NEXT B
1710 NEXT A
1720 CLOSE #1
1730 '
1740 OPEN"O",#1,"FALLSPR/DAT"
1750 FOR A=1TO14
1760 WRITE#1,AF(A)
1770 FOR B=1TO5:WRITE#1,CA(A,B):NEXT B
1780 NEXT A
1790 CLOSE#1
1800 '
1810 OPEN"O",#1,"SUMMER/DAT"
1820 FOR A=1TO11
1830 WRITE#1,AT(A)
1840 FOR B=1TO5:WRITE#1,CS(A,B):NEXT B
1850 NEXT A
1860 FOR C=1TO5:WRITE#1,BA(C):NEXT C
1870 FOR A=1TO19
1880 WRITE#1,DA(A)
1890 FOR B=1TO4:WRITE#1,DS(A,B):NEXT B
1900 NEXT A
1910 CLOSE#1
1920 '
1930 OPEN"O",#1,"OCAST/DAT"
1940 FOR A=1TO19
1950 WRITE#1,DA(A)
1960 FOR B=1TO2:WRITE#1,OS(A,B):NEXT B
1970 NEXT A
1980 CLOSE#1
1990 '
2000 OPEN"O",#1,"CUTBLS/DAT"
2010 FOR A=1TO4:FOR B=1TO3
2020 FOR C=1TO3:WRITE#1,CU(A,B,C):NEXT C
2030 NEXT B:NEXT A
2040 CLOSE#1
```

```

100 'PROGRAM:PART3- SUMMER AND CLDY SKIES
110 ' THIS PROGRAM CALCULATES THE AVAILABLE ILLUMINATION
USING
120 ' THE STORED ANGLES FROM PART1 AND THE STORED TABLES
FROM
130 ' PART2. STORES RESULTS FOR CLEAR SUMMER AND O'CAST
SKIES.
140 '
150 DIM AA(7,7),AZ(7,7)
160 DIM
TL(7,2,7,2),AT(11),CS(11,5),BA(5),DA(19),DS(19,4),OS(19,2)
170 '
180 OPEN"I",#1,"ANGLES/DAT"
190 FOR A=1TO7:FOR B=1TO7
200 INPUT#1,AA(A,B)
210 NEXT B:NEXT A
220 FOR A=1TO7:FOR B=1TO7
230 INPUT#1,AZ(A,B)
240 NEXT B:NEXT A
250 CLOSE#1
260 '
270 '
280 ' INPUT AVAIL. LIGHT FILES FOR SUMMER AND O'CAST SKIES
290 '
300 OPEN"I",#1,"SUMMER/DAT"
310 FOR A=1TO11
320 INPUT#1,AT(A)
330 FOR B=1TO5:INPUT#1,CS(A,B):NEXT B
340 NEXT A
350 FOR C=1TO5:INPUT#1,BA(C):NEXT C
360 FOR A=1TO19
370 INPUT#1,DA(A)
380 FOR B=1TO4:INPUT#1,DS(A,B):NEXT B
390 NEXT A
400 CLOSE#1
410 '
420 '
430 OPEN"I",#1,"OCAST/DAT"
440 FOR A=1TO19
450 INPUT#1,DA(A)
460 FOR B=1TO2
470 INPUT#1,OS(A,B):NEXT B
480 NEXT A
490 CLOSE#1
500 '
510 '
520 ' FIND AND SAVE AVAILABLE LIGHT, CLEAR SUMMER SKY
530 FOR M=6TO7
540 FOR H=1TO7
550 FOR B=1 TO 11
560 IF AA(M,H)=AT(B)THEN K=B

```

```

570 NEXT B
580 FOR C=1TO4
590 IF AZ(M,H)>BA(C)AND AZ(M,H)<BA(C+1)THEN 610
600 GOTO640
610 E1=(AZ(M,H)-BA(C+1))*(CS(K,C)-CS(K,C+1))
620 E1=E1/(BA(C)-BA(C+1))+CS(K,C+1)
630 E2=CS(K,5)
640 NEXT C
650 '
660 FOR A=1TO19:E3=0
670 IF AA(M,H)<>DA(A)THEN 700
680 E4=DS(A,4)
690 Q=A
700 NEXT A
710 IF AZ(M,H)>75 THEN 780
720 IF AZ(M,H)<=75 AND AZ(M,H)>45 THEN 760
730 E3=(AZ(M,H)-45)*(DS(Q,1)-DS(Q,2))
740 E3=E3/-45 +DS(Q,2)
750 GOTO 780
760 E3=(AZ(M,H)-75)*(DS(Q,2)-DS(Q,3))
770 E3=E3/-30+DS(Q,3)
780 '
790 '
800 TL(M,1,H,1)=E1+E3
810 TL(M,1,H,2)=E2+E4
820 NEXT H
830 NEXT M
840 '
850 '
860 OPEN"O",#1,"TLSMR/DAT"
870 FOR M=6TO7:FOR H=1TO7
880 FOR W=1TO2:WRITE#1,TL(M,1,H,W):NEXT W
890 NEXT H:NEXT M
900 CLOSE#1
910 '
920 '
930 ' FIND AND SAVE AVAILABLE LIGHT, O'CAST SKY
940 '
950 FOR M=1TO7
960 FOR H=1TO7
970 K=0
980 FOR B=1TO19
990 IF AA(M,H)=DA(B)THEN K=B
1000 NEXT B
1010 TL(M,2,H,1)=OS(K,1)
1020 TL(M,2,H,2)=OS(K,2)
1030 NEXT H
1040 NEXT M
1050 '
1060 '
1070 OPEN"O",#1,"TLCMD/DAT"
1080 FOR M=1TO7

```

```
1090 FOR H=1TO7
1100 FOR W=1TO2
1110 WRITE#1,TL(M,2,H,W)
1120 NEXT W
1130 NEXT H
1140 NEXT M
1150 CLOSE#1
```

```

100 'PROGRAM: PART4-WINTER AND SPRING/FALL
110 DIM TL(7,2,7,2)
120 DIM AF(14),CA(14,5)
130 DIM
AA(7,7),AZ(7,7),BA(5),DS(20,5),DA(19),AW(11),CW(11,5)
140 '
150 '
160 'READ FILES
170 '
180 OPEN "I",#1,"ANGLES/DAT"
190 FOR A=1TO7:FOR B=1TO7
200 INPUT#1,AA(A,B)
210 NEXT B:NEXT A
220 FOR A=1TO7:FOR B=1TO7
230 INPUT#1,AZ(A,B)
240 NEXT B:NEXT A
250 CLOSE#1
260 OPEN "I",#1,"WINTER/DAT"
270 FOR A=1TO11
280 INPUT#1,AW(A)
290 FOR B=1TO5:INPUT#1,CW(A,B):NEXT B
300 NEXT A
310 FOR C=1TO5:INPUT#1,BA(C):NEXT C
320 FOR A=1TO19
330 INPUT#1,DA(A)
340 FOR B=1TO4:INPUT#1,DS(A,B):NEXT B
350 NEXT A
360 CLOSE#1
370 OPEN "I",#1,"FALLSPR"
380 FOR A=1TO14
390 INPUT#1,AF(A)
400 FOR B=1TO5:INPUT#1,CA(A,B):NEXT B
410 NEXT A
420 CLOSE#1
430 '
440 '
450 'FIND ILLUMINATIONS-WINTER
460 '
470 FOR M=1TO2
480 FOR H=1TO7
490 FOR B=1TO11
500 IF AA(M,H)=AW(B)THEN K=B:NEXT B
510 FOR C=1TO4
520 IF AZ(M,H)>BA(C) AND AZ(M,H)<BA(C+1) THEN540
530 GOTO 570
540 E1=(AZ(M,H)-BA(C+1))*(CW(K,C)-CW(K,C+1))
550 E1=E1/(BA(C)-BA(C+1))+CW(K,C+1)
560 E2=CW(K,5)
570 NEXT C:NEXT B

```

```

580 '
590 FOR A=1TO19
600 IF AA(M,H)<>DA(A) THEN 670
610 E4=DS(A,4)
620 IF AZ(M,H)>75THEN670
630 IF AZ(M,H)<=75 AND AZ(M,H)>45THEN660
640 E3=(AZ(M,H)-45)*(DS(A,1)- DS(A,2))/(-45)+DS(A,2)
650 GOTO670
660 E3=(AZ(M,H)-75)*(DS(A,2)- DS(A,3))/(-30)+DS(A,3)
670 NEXT A
680 '
690 TL(M,1,H,1)=E1+E3
700 TL(M,1,H,2)=E2+E4
710 NEXT H
720 NEXT M
730 '
740 'SAVE TOTAL WINTER ILLUMS.
750 OPEN "O",#1,"TLWTR/DAT"
760 FOR M=1TO2:FOR H=1TO7
770 FOR W=1TO2:WRITE#1,TL(M,1,H,W):NEXT W
780 NEXT H:NEXT M
790 CLOSE#1
800 '
810 '
820 '
830 'FIND SPRING/FALL ILLUMS.-'
840 '
850 FOR M=3TO5
860 FOR H=1TO7
870 FOR B=1TO14
880 IF AA(M,H)=AF(B)THEN K=B:NEXT B
890 FOR C=1TO4
900 IF AZ(M,H)>BA(C) AND AZ(M,H)<BA(C+1) THEN 950
910 GOTO950
920 E1=(AZ(M,H)-BA(C+1))*(CA(K,C)-CA(K,C+1))
930 E1=E1/(BA(C)-BA(C+1))+CA(K,C+1)
940 E2=CA(K,5)
950 NEXT C
960 '
970 FOR A=1 TO 19
980 IF AA(M,H)<>DA(A) THEN 1050
990 E4=DS(A,4)
1000 IF AZ(M,H)>75THEN1050
1010 IF AZ(M,H)<=75 AND AZ(M,H)>45THEN1040
1020 E3=(AZ(M,H)-45)*(DS(A,1)- DS(A,2))/(-45)+DS(A,2)
1030 GOTO1050
1040 E3=(AZ(M,H)-75)*(DS(A,2)- DS(A,3))/(-30)+DS(A,3)
1050 NEXT A
1060 '
1070 TL(M,1,H,1)=E1+E3
1080 TL(M,1,H,2)=E2+E4
1090 NEXT H:NEXT M

```

```
1100 '
1110 'SAVE SPRING/FALL ILLUMS.
1120 OPEN"O",#1,"TLSF/DAT"
1130 FOR M=3TO5:FOR H=1TO7
1140 FOR W=1TO2:WRITE#1,TL(M,l,H,W):NEXT W
1150 NEXT H:NEXT M
1160 CLOSE#1
```

```

100 ' THE QUANTIFICATION OF DAYLIGHTING
110 '
120 ' PROGRAM TO CALCULATE A TENTATIVE ARTIFICIAL LIGHT
SYSTEM;
130 ' CALCULATE THE AMOUNT OF INTERIOR ILLUMINATION
POSSIBLE BY
140 ' USING PASSIVE DAYLIGHTING TECHNIQUES; AND CALCULATE
THE
150 ' NUMBER OF HOURS DURING WHICH DAYLIGHT IS SUFFICIENT
TO TURN
160 ' OFF SOME OR ALL OF THE ELECTRIC LIGHTING.
170 '
180 '
190 '
200 ' ARTIFICIAL LIGHT ANALYSIS
210 '
220 ' ROOM DIMENSIONS-
230 PRINT "CHOOSE LENGTH OF ROOM: 20, 30, OR 40 FEET"
240 INPUT L
250 PRINT #-2, "LENGTH OF ROOM:", L
260 PRINT #-2
270 PRINT #-2, "WIDTH OF ROOM ASSUMED TO BE 20 FEET"
280 PRINT #-2
290 W=20
300 PRINT
310 PRINT "CHOOSE CEILING HEIGHT: 8, 10, OR 12 FEET"
320 INPUT "CEILING HEIGHT"; H1
330 PRINT #-2, "CEILING HEIGHT="; H1
340 PRINT #-2
350 PRINT
360 PRINT
370 PRINT #-2, "FLOOR TO WORKPLANE HEIGHT ASSUMED TO BE 2.5
FEET"
380 PRINT #-2
390 H2=2.5
400 PRINT
410 PRINT
420 INPUT "FIXTURE TO CEILING HEIGHT"; H3
430 PRINT #-2, "FIXTURE TO CEILING HEIGHT="; H3
440 '
450 '
460 ' OTHER ROOM CHARACTERISTICS-
470 '
480 H4=H1-H2-H3
490 R1=(5*H4*(L+W))/(L*W)
500 PRINT #-2, "ROOM CAVITY RATIO="; R1
510 C1=(5*H3*(L+W))/(L*W)
520 PRINT
530 PRINT
540 PRINT #-2, "CEILING CAVITY RATIO="; C1

```

```

550 F1=(5*H2*(L+W))/(L*W)
560 PRINT
570 PRINT
580 PRINT#-2,"FLOOR CAVITY RATIO=";F1
590 PRINT#-2
600 PRINT"FROM IES HANDBOOK, FIND THE FOLLOWING:"
610 INPUT"CU FOR ROOM SPECIFIED";U1
620 PRINT#-2,"COEFFICIENT OF UTILIZATION:";U1
630 '
640 '
650 ' LUMINAIRE CHARACTERISTICS-
660 '
670 INPUT"INPUT THE LLD X LDD OR MAINTENANCE FACTOR";M1
680 PRINT#-2,"MAINTENANCE FACTOR:";M1
690 INPUT"INPUT LAMPS PER LUMINAIRE";F2
700 PRINT#-2,"LAMPS PER LUMINAIRE:";F2
710 INPUT"HOW MANY LUMENS PER LAMP";B1
720 PRINT#-2,"LUMENS PER LAMP:";B1
730 INPUT"WATTS PER LAMP(INCL BALLAST)";WL
740 PRINT#-2,"WATTS PER LAMP:";WL
750 PRINT#-2
760 '
770 '
780 INPUT"WHAT IS DESIRED FOOTCANDLE LEVEL";F3
790 PRINT#-2,"DESIGN FOOTCANDLE LEVEL:";F3
800 PRINT#-2
810 F5=(F3*(L*W))/(U1*B1*M1*F2)
820 PRINT
830 PRINT
840 PRINT"NO. OF FIXTURES REQ'D TO PROVIDE"
850 PRINT"DESIRED FOOTCANDLE LEVEL FOR ROOM IS:";F5
860 PRINT
870 PRINT
880 INPUT"HOW MANY FIXTURES DO YOU INTEND TO USE";A1
890 A2=(A1/F5)*F3
900 PRINT
910 PRINT
920 PRINT"THE ACTUAL FOOTCANDLE LEVEL FOR YOUR NO. OF
FIXTURES IS ";A2
930 PRINT#-2,"THE ACTUAL FOOTCANDLE LEVEL FOR";A1;"FIXTURES
IS:";A2
940 PRINT
950 PRINT
960 INPUT"DO YOU WISH TO TRY ANOTHER CU (1=YES, 0=NO)";Z
970 IF Z=1 THEN 610
980 PRINT
990 INPUT"DO YOU WISH TO TRY ANOTHER ROOM";Z2
1000 IF Z2=1 THEN 240
1010 TC=WL*A1*F2*7*260
1020 '
1030 '
1040 ' DAYLIGHTING ANALYSIS

```

```

1050 '
1060 '
1070 DIM TL(7,2,7,2),CU(4,3,3),AG(3),SO(3,2),C(3),K(3)
1080 DIM D(3,3),E(3,3)
1090 '
1100 OPEN "I",#1,"CUTBLS/DAT"
1110 FOR A=1 TO 4:FOR B=1 TO 3
1120 FOR C=1 TO 3:INPUT #1,CU(A,B,C):NEXT C
1130 NEXT B:NEXT A
1140 CLOSE #1
1150 '
1160 OPEN "I",#1,"TLSMR/DAT"
1170 FOR M=6 TO 7:FOR H=1 TO 7
1180 FOR W=1 TO 2:INPUT #1,TL(M,1,H,W):NEXT W
1190 NEXT H:NEXT M
1200 CLOSE #1
1210 '
1220 OPEN "I",#1,"TLCLD/DAT"
1230 FOR M=1 TO 7
1240 FOR H=1 TO 7
1250 FOR W=1 TO 2
1260 INPUT #1,TL(M,2,H,W)
1270 NEXT W
1280 NEXT H
1290 NEXT M
1300 CLOSE #1
1310 '
1320 OPEN "I",#1,"TLWTR/DAT"
1330 FOR M=1 TO 2:FOR H=1 TO 7
1340 FOR W=1 TO 2:INPUT #1,TL(M,1,H,W):NEXT W
1350 NEXT H:NEXT M
1360 '
1370 CLOSE #1
1380 OPEN "I",#1,"TLSF/DAT"
1390 FOR M=3 TO 5:FOR H=1 TO 7
1400 FOR W=1 TO 2:INPUT #1,TL(M,1,H,W)
1410 NEXT H:NEXT M
1420 '
1430 CLOSE #1
1440 '
1450 ' GLASS AREAS-
1460 AG(1)=.15*L*H1
1470 AG(2)=.3*L*H1
1480 AG(3)=.6*L*H1
1490 '
1500 ' SITE CHARACTERISTICS-
1510 INPUT "GROUND REFLECTANCE RATIO";R
1520 INPUT "TRANSMITTANCE OF GLASS";T
1530 '
1540 PRINT #-2,"GROUND REFLECTANCE:";R
1550 PRINT #-2,"GLASS TRANSMITTANCE:";T
1560 '

```

```

1570 PRINT"DO YOU WISH TEST OUTPUT GIVING ALL LIGHT VALUES
? (1=YES,0=NO)"
1580 INPUT OP
1590 '
1600 L10=20:H10=8
1610 FOR A=1TO3
1620 IF L= L10 THEN X=A
1630 IF H1=H10 THEN Y=A
1640 L10=L10+10
1650 H10=H10+2
1660 NEXT A
1670 '
1680 IF OP<>1THEN 1710
1690 PRINT#-2," ","MAX","MID","MIN"
1700 '
1710 FOR M=1TO7
1720 IF OP<>1THEN 1740
1730 PRINT#-2,"MONTH:";M
1740 FOR H=1TO7
1750 IF OP<>1THEN 1780
1760 PRINT#-2
1770 PRINT#-2," HOUR:";H
1780 I1=TL(M,1,H,1)
1790 I2=TL(M,1,H,2)
1800 I3=I2*.5*R
1810 IF OP<>1THEN 1830
1820 ' FOR EACH INTERIOR LOCATION
1830 FOR A=1TO3
1840 '
1850 ' COEFFICIENTS OF UTILIZATION CHOSEN
1860 C(A)=CU(3,X,A)
1870 K(A)=CU(4,Y,A)
1880 IF OP<>1THEN 1900
1890 ' FOR EACH GLASS AREA
1900 FOR B=1TO3
1910 I5=I1*AG(B)*T*C(A)*K(A)
1920 I6=I3*AG(B)*T*C(A)*K(A)
1930 I7=I5+I6
1940 D(A,B)=I7
1950 IF OP<>1THEN 1960
1960 IF I7>=F3 THEN SO(B,1)=SO(B,1)+1
1970 IF M>1 AND M<7 AND I7>=F3 THEN SO(B,1)=SO(B,1)+1
1980 NEXT B:NEXT A
1990 IF OP<>1THEN 2080
2000 PRINT#-2
2010 FOR B=1TO3
2020 PRINT#-2," ",D(1,B),D(2,B),D(3,B)
2030 NEXT B
2040 PRINT # -2
2050 '
2060 ' CLOUDY SKIES
2070 '

```

```

2080 J1=TL(M,2,H,1)
2090 J2=TL(M,2,H,2)
2100 J3=J2*.5*R
2110 '
2120 IF OP<>1 THEN 2130
2130 FOR A=1 TO 3
2140 C(A)=CU(1,X,A)
2150 K(A)=CU(2,Y,A)
2160 IF OP<>1 THEN 2170
2170 FOR B=1 TO 3
2180 J5=J1*AG(B)*T*C(A)*K(A)
2190 J6=J3*AG(B)*T*C(A)*K(A)
2200 J7=J5+J6
2210 E(A,B)=J7
2220 IF OP<>1 THEN 2230
2230 IF J7>=F3 THEN SO(B,2)=SO(B,2)+1
2240 IF M>1 AND M<7 AND J7>=F3 THEN SO(B,2)=SO(B,2)+1
2250 NEXT B:NEXT A
2260 IF OP<>1 THEN 2300
2270 FOR B=1 TO 3
2280 PRINT#-2," ",E(1,B),E(2,B),E(3,B)
2290 NEXT B
2300 NEXT H:NEXT M
2310 '
2320 ' *OUTPUT*
2330 PRINT #2:PRINT#2
2340 WD=WL*F2*A1*1820/1000
2350 PRINT #2,"ELECTRIC USE WITHOUT DAYLIGHTING:";WD;"KW-
HRS/YR"
2360 '
2370 ' FOR EACH GLASS AREA; FOR CLEAR AND CLOUDY SKIES
2380 PRINT#2:PRINT#2
2390 PRINT#2,"THE FOLLOWING ARE LUMINAIRE ROW-HOURS WHEN
LIGHTS ARE OFF--"
2400 PRINT#2,"GLASS AREA","HRS OFF(SUN)","HRS OFF(CLD)"
2410 PRINT#2
2420 PRINT#2," 15%",SO(1,1)*12,SO(1,2)*12
2430 PRINT#2," 30%",SO(2,1)*12,SO(2,2)*12
2440 PRINT#2," 60%",SO(3,1)*12,SO(3,2)*12
2450 PRINT#2:PRINT#2
2460 WB=WL*F2*A1/3:' WATTS PER BANK
2470 PRINT#2,"GLASS AREA","KW-HRS OFF(SUN)","KW-HRS
OFF(CLD)"
2480 PRINT#2
2490 PRINT#2," 15%",SO(1,1)*WB*12/1000,SO(1,2)*WB*12/1000
2500 PRINT#2," 30%",SO(2,1)*WB*12/1000,SO(2,2)*WB*12/1000
2510 PRINT#2," 60%",SO(3,1)*WB*12/1000,SO(3,2)*WB*12/1000
2520 PRINT#2:PRINT#2
2530 '
2540 PRINT"ASSUME THREE POSSIBLE SKY CONDITIONS- CLEAR,
PARTLY CLOUDY, CLOUDY"
2550 INPUT"% CLEAR";S1

```

```
2560 INPUT "% CLOUDY";S3
2570 S2=100-S1-S3
2580 PRINT#-2,"CLEAR=";S1;"%", PTLY CLDY=";S2;"%",
CLDY=";S3;"%
2590 Y=15
2600 FOR X=1TO3
2610 S4=(S1*18.20)*(S0(X,1)/1820)
2620 S5=(S3*18.20)*(S0(X,2)/1820)
2630 S6=(S2/2)*18.20*(S0(X,1)/1820)
2640 S7=(S2/2)*18.20*(S0(X,2)/1820)
2650 S8=S4+S5+S6+S7
2660 S9=S8*WB*12
2670 PRINT#-2
2680 PRINT#-2,"TOTAL EXPECTED KW-HRS SAVINGS:";S9/1000
2690 PRINT#-2,"FOR GLASS =";Y;"% OF WALL AREA"
2700 Y=Y*2
2710 PRINT#-2
2720 NEXT X
```

**APPENDIX C**  
**COMPLETE OUTPUT: EXAMPLE RUN**

LATITUDE = 39

LATITUDE = 39

LENGTH OF ROOM: 20

WIDTH OF ROOM ASSUMED TO BE 20 FEET

CEILING HEIGHT= 8

FLOOR TO WORKPLANE HEIGHT ASSUMED TO BE 2.5 FEET

Fixture to ceiling height= 0

Room cavity ratio= 2.75

Ceiling cavity ratio= 0

Floor cavity ratio= 1.25

COEFFICIENT OF UTILIZATION: .64

MAINTENANCE FACTOR: .73

LAMPS PER LUMINAIRE: 2

LUMENS PER LAMP: 2300

WATTS PER LAMP: 32.4

DESIGN FOOTCANDLE LEVEL: 70

THE ACTUAL FOOTCANDLE LEVEL FOR 15 FIXTURES IS: 80.592

GROUND REFLECTANCE: .18

GLASS TRANSMITTANCE: .77

MONTH: 1	MAX	MID	MIN
HOUR: 1			
	166.498541	123.661538	85.6740067
	332.997083	247.323976	171.348013
	665.994165	494.646152	342.696027
	14.0745706	8.10817651	4.43654941
	28.1491411	16.816353	8.87369883
	56.2982822	32.4327061	17.7461977
HOUR: 2			
	213.865113	158.841565	110.047097
	427.730226	317.683129	220.094194
	855.460453	635.366259	440.188388
	19.4190575	11.1870557	6.12122466
	38.8381151	22.3741315	12.2424493
	77.6762301	44.748263	24.4845986
HOUR: 3			
	263.927171	196.023573	135.897185
	527.854343	392.047157	271.61437
	1055.70869	734.094315	543.228741
	24.1464374	13.9104476	7.61137761
	48.2928748	27.8208953	15.222754
	96.5857496	55.6417906	30.4455081
HOUR: 4			
	300.861584	223.455449	154.812272
	601.723169	446.910897	309.624543
	1203.44634	893.821794	619.249086
	27.9962797	16.1282916	8.82431426
	55.9925595	32.2565832	17.6438285
	111.985119	64.5131663	35.2996571

## HOUR: 5

263.927171	196.023579	135.807183
327.854343	392.047157	271.61437
1055.70869	764.094315	543.228741
24.1464374	13.9104476	7.61137791
48.2928748	27.8208953	15.222754
96.5857496	55.6417906	38.4455081

## HOUR: 6

213.865113	158.841565	110.047097
427.730226	317.683129	220.094194
855.460453	635.366259	440.188388
19.4190575	11.1870657	6.12122466
38.8381151	22.3741315	12.2424433
77.6762301	44.748263	24.4848986

## HOUR: 7

166.498541	123.661536	85.6748667
332.997083	247.323876	171.046013
665.994165	494.646152	342.696627
14.0745706	8.10817651	4.43654941
28.1491411	16.216353	8.87009383
56.2982822	32.4327961	17.7461977

## MONTH: 2

## HOUR: 1

192.042046	142.63317	98.817752
384.084093	285.266341	197.635504
768.168185	570.532682	395.271008
19.4190575	11.1870657	6.12122466
38.8381151	22.3741315	12.2424433
77.6762301	44.748263	24.4848986

## HOUR: 2

235.235097	174.713446	121.043389
470.470195	349.426892	242.086665
940.94039	698.853785	484.17321
24.1464374	13.9104476	7.61137791
48.2928748	27.8208953	15.222754
96.5857496	55.6417906	38.4455081

## HOUR: 3

276.485764	205.351077	142.269374
552.971528	410.702154	284.538747
1105.94306	821.404309	569.077495
27.9962797	16.1282916	8.82491426
55.9925595	32.2565832	17.6498285
111.985119	64.5131663	35.2996571

## HOUR: 4

302.027391	224.321314	155.412153
604.054781	448.642629	310.824305
1208.10956	897.285258	621.64861
27.9962797	16.1282916	8.82491426
55.9925595	32.2565832	17.6498285
111.985119	64.5131663	35.2996571

## HOUR: 5

276.485764	205.351077	142.269374
552.971528	410.702154	284.538747
1105.94306	821.404309	569.077495
27.9962797	16.1282916	8.82491426
55.9925595	32.2565832	17.6498285
111.985119	64.5131663	35.2996571

## HOUR: 6

235.235097	174.713446	121.043303
470.470195	349.426892	242.086685
940.94039	698.853785	484.17321
24.1464374	18.9104476	7.61137701
48.2928748	27.8208953	15.222754
96.5857496	55.6417906	30.4455681

## HOUR: 7

192.042046	142.63317	98.817752
384.084093	285.266341	197.635584
768.168185	570.532682	395.271003
19.4190575	11.1870657	6.12122466
38.8381151	22.3741315	12.2424493
77.6762301	44.748263	24.4848986

MONTH: 3

HOUR: 1

178.419298	132.515384	91.9879881
356.838596	265.036687	188.615976
713.677191	539.061215	367.231953
24.1464374	18.9104476	7.61137701
48.2928748	27.8208953	15.222754
96.5857496	55.6417986	38.4455881

HOUR: 2

138.178324	102.62759	71.1814674
276.356647	205.25518	142.202935
552.713294	410.510359	284.49587
38.2898129	19.177827	10.493528
66.5796258	38.355654	28.987656
133.159252	76.711388	41.9741119

HOUR: 3

225.752298	167.670397	116.163894
451.504597	335.340793	232.327688
903.009194	670.681586	464.655216
37.7624238	21.7544398	11.9833727
75.5248476	43.5088796	23.8867454
151.049695	87.0177592	47.6134969

HOUR: 4

201.562376	149.704466	103.71682
403.125751	299.406932	207.433639
806.251503	598.817863	414.867273
37.7624238	21.7544398	11.9833727
75.5248476	43.5088796	23.8867454
151.049695	87.0177592	47.6134969

HOUR: 5

249.650623	185.420123	128.461
499.301245	370.640245	256.922
998.60249	741.68049	513.844
37.7624238	21.7544398	11.9833727
75.5248476	43.5088796	23.8867454
151.049695	87.0177592	47.6134969

HOUR: 6

239.593607	177.950592	123.286031
479.187214	355.901183	246.572061
958.374428	711.802366	493.144123
33.2898129	19.177827	10.493528
66.5796258	38.355654	20.987056
133.159252	76.711308	41.9741119

HOUR: 7

278.197147	206.622153	143.149988
556.394294	413.244306	286.299976
1112.78859	826.488611	572.539953
24.1464374	13.9104476	7.61137761
48.2928748	27.8208953	15.222754
96.5857496	55.6417906	30.4455081

MONTH: 4

HOUR: 1

239.593607	177.950592	123.286031
479.187214	355.901183	246.572061
958.374428	711.802366	493.144123
33.2898129	19.177827	10.493528
66.5796258	38.355654	20.987056
133.159252	76.711308	41.9741119

HOUR: 2

249.650623	185.420123	126.461
499.301245	370.840245	256.922
998.60249	741.68049	513.844
44.8506629	25.9378819	14.137769
89.7013258	51.6757637	28.2754179
179.402652	103.351527	56.5506358

HOUR: 3

239.593607	177.950592	123.286031
479.187214	355.901183	246.572061
958.374428	711.802366	493.144123
48.5476438	27.9676644	15.3030616
97.0952876	55.9353287	30.6061233
194.190575	111.870657	61.2122466

## HOUR: 4

225.752298	167.670397	116.163684
451.504597	335.340793	232.327688
903.009194	670.681586	464.655216
48.5476438	27.9676644	15.3000616
97.0952876	55.9353287	30.6001233
194.190575	111.870657	61.2122466

## HOUR: 5

201.562876	149.704466	103.71682
403.125751	299.408932	207.403639
806.251503	598.817883	414.867278
48.5476438	27.9676644	15.3000616
97.0952876	55.9353287	30.6001233
194.190575	111.870657	61.2122466

## HOUR: 6

178.419298	132.515384	91.0079881
356.838596	265.030607	183.615976
713.677191	530.061215	367.231953
44.8506629	25.8378819	14.137789
89.7013258	51.6757637	28.2754179
179.402652	108.351527	56.5500358

## HOUR: 7

138.178924	102.62759	71.1014674
276.356647	205.25518	142.202935
552.713294	410.510359	284.40587
33.2898129	19.177827	10.493528
66.5796258	38.355654	20.987056
133.159252	76.711308	41.9741119

## MONTH: 5

## HOUR: 1

166.569908	123.714543	85.7107293
333.139816	247.429086	171.421458
666.279631	494.858173	342.842917
37.7624238	21.7544398	11.9403727
75.5248476	43.5088796	23.8067454
151.049695	87.0177592	47.6134369

## HOUR: 2

201.562876	149.704466	103.71682
463.125751	299.406932	207.433639
806.251503	598.817863	414.867278
55.2282525	31.8162759	17.4089057
110.456505	63.6325519	34.8178114
220.91301	127.265104	69.6356227

## HOUR: 3

205.891806	152.919642	105.944327
411.783612	305.839285	211.888655
823.567224	611.678569	423.777309
61.9088612	35.6648874	19.5147497
123.817722	71.3297749	39.8294995
247.635445	142.65955	78.058999

## HOUR: 4

260.721791	193.642884	134.157815
521.443582	387.285767	268.315629
1042.88716	774.571534	536.631259
68.58947	39.513499	21.6245938
137.17894	79.026998	43.2411876
274.35788	158.053996	86.4823751

## HOUR: 5

222.137032	164.985271	114.388521
444.274063	329.970542	228.607042
888.548127	659.941085	457.214085
61.9088612	35.6648874	19.5147497
123.817722	71.3297749	39.8294995
247.635445	142.65955	78.058999

## HOUR: 6

281.849975	209.335176	145.029599
563.69995	418.670351	290.059197
1127.3999	837.340702	580.118395
55.2282525	31.8162759	17.4089057
110.456505	63.6325519	34.8178114
220.91301	127.265104	69.6356227

HOUR: 7

257.068963	190.929861	132.278204
514.137926	381.659721	264.556468
1028.27585	763.719443	529.112816
37.7624238	21.7544398	11.9033727
75.5248476	43.5088796	23.8867454
151.049695	87.0177592	47.6134969

MONTH: 6

HOUR: 1

63.025373	46.8101071	32.4305317
126.050746	93.6202142	64.8610634
252.101492	187.240428	129.722127
44.8506629	25.8378819	14.137709
89.7013258	51.6757637	28.2754179
179.402652	103.351527	56.5508358

HOUR: 2

152.051089	112.931149	79.2398888
304.102178	225.862298	156.479762
608.204357	451.724595	312.959523
61.9088612	35.6648874	19.5147437
123.817722	71.3297749	39.0294955
247.635445	142.65955	78.058999

HOUR: 3

172.363725	128.017718	88.692014
344.727451	256.035437	177.384928
689.454901	512.070873	354.768856
76.0343856	43.8024178	23.9673687
152.068771	87.6048355	47.9347213
304.137542	175.209671	95.8694426

HOUR: 4

208.281638	154.694615	107.174447
416.563276	309.38923	214.348894
833.126553	618.778459	428.696187
76.0343856	43.8024178	23.9673687
152.068771	87.6048355	47.9347213
304.137542	175.209671	95.8694426

## HOUR: 5

172.363725	128.817718	88.692014
344.727451	256.035437	177.384028
689.454901	512.070873	354.768056
76.6343856	43.8824178	23.9673607
152.068771	87.6948355	47.9347213
304.137542	175.209671	95.8694426

## HOUR: 6

152.051089	112.931149	78.2398808
304.102178	225.862298	156.479762
608.204357	451.724595	912.959523
61.9088612	35.6648874	19.5147497
123.817722	71.3297749	39.0294995
247.635445	142.65955	78.058999

## HOUR: 7

63.025373	46.8101071	32.4305317
126.050746	93.6202142	64.8610634
252.101492	187.240428	129.722127
44.8506629	25.8378819	14.137709
89.7013258	51.6757637	28.2754179
179.402652	103.351527	56.5508358

## MONTH: 7

## HOUR: 1

63.5535775	47.2024144	32.7023263
127.107155	94.4048289	65.4046526
254.21431	188.809658	130.809305
48.5476438	27.9676644	15.3030616
97.0952876	55.9353287	30.6061233
194.190575	111.870657	61.2122466

## HOUR: 2

136.303549	101.23516	70.1387777
272.607098	202.470321	140.273555
545.214197	404.940641	280.547111
61.9088612	35.6648874	19.5147497
123.817722	71.3297749	39.0294995
247.635445	142.65955	78.058999

## HOUR: 3

166.201338	123.4408	85.521077
332.402677	246.8816	171.042154
664.805353	493.763199	342.084308
76.0343856	43.8024178	23.9673607
152.068771	87.6048355	47.9347213
304.137542	175.209671	95.8694426

## HOUR: 4

179.37124	133.222329	92.2978225
358.74248	266.444658	184.595645
717.48436	532.889315	369.19123
84.2436081	48.5316438	26.5550564
168.487216	97.0632876	53.1101008
336.974433	194.126575	106.420202

## HOUR: 5

166.201338	123.4408	85.521077
332.402677	246.8816	171.042154
664.805353	493.763199	342.084308
76.0343856	43.8024178	23.9673607
152.068771	87.6048355	47.9347213
304.137542	175.209671	95.8694426

## HOUR: 6

136.303549	101.23516	70.1367777
272.607098	202.470321	140.270555
545.214197	404.940641	280.547111
61.9088612	35.6648874	19.5147497
123.817722	71.3297749	39.0294995
247.635445	142.65955	78.058999

## HOUR: 7

63.5535775	47.2024144	32.7023263
127.107155	94.4048289	65.4046526
254.21431	188.809658	130.809305
46.5476438	27.9676644	15.8038616
97.0952876	55.9353287	38.6061233
194.196575	111.870657	61.2122466

ELECTRIC USE WITHOUT DAYLIGHTING: 1769.84 KW-HRS/YR

THE FOLLOWING ARE LUMINAIRE ROW-HOURS WHEN LIGHTS ARE OFF--  
GLASS AREA HRS OFF(SUN) HRS OFF(CLD)

15%	2808	168
30%	2952	864
60%	3024	1944

GLASS AREA KW-HRS OFF(SUN) KW-HRS OFF(CLD)

15%	969.792001	34.992
30%	956.448	279.936
60%	979.776001	629.856

CLEAR= 20 %, PTLY CLDY= 50 %, CLDY= 30 %

TOTAL EXPECTED KW-HRS SAVINGS: 246.6936  
FOR GLASS = 15 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 393.0768  
FOR GLASS = 30 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 591.364801  
FOR GLASS = 60 % OF WALL AREA

**APPENDIX D**

**OUTPUT: 30 AND 49 DEGREES NORTH LATITUDE**

LATITUDE = 30

LENGTH OF ROOM: 30

WIDTH OF ROOM ASSUMED TO BE 20 FEET

CEILING HEIGHT= 10

FLOOR TO WORKPLANE HEIGHT ASSUMED TO BE 2.5 FEET

Fixture to ceiling height= 0

Room cavity ratio= 3.125

Ceiling cavity ratio= 0

Floor cavity ratio= 1.04166667

Coefficient of utilization: .55

Maintenace factor: .72

Lamps per luminaire: 2

Lumens per lamp: 3200

Watts per lamp: 40.7

Design footcandle level: 70

The actual footcandle level for 18 fixtures is: 76.032

Ground reflectance: .06

Glass transmittance: .77

Electric use without daylighting: 2666.664 kw-hrs/yr

The following are luminaire run-hours when lights are off--

GLASS AREA HRS OFF(SUN) HRS OFF(CLD)

15%	2556	276
30%	2880	1152
60%	3024	2388

GLASS AREA KW-HRS OFF(SUN) KW-HRS OFF(CLD)

15%	1248.3504	134.7984
30%	1406.592	562.6368
60%	1476.9216	1166.2992

CLEAR= 30 %, PTLY CLDY= 50 %, CLDY= 20 %

TOTAL EXPECTED KW-HRS SAVINGS: 372.74688  
FOR GLASS = 15 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 684.83456  
FOR GLASS = 30 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 894.065041  
FOR GLASS = 60 % OF WALL AREA

LATITUDE = 49

LENGTH OF ROOM: 30

WIDTH OF ROOM ASSUMED TO BE 20 FEET

CEILING HEIGHT= 10

FLOOR TO WORKPLANE HEIGHT ASSUMED TO BE 2.5 FEET

FIXTURE TO CEILING HEIGHT= 0

ROOM CAVITY RATIO= 3.125

CEILING CAVITY RATIO= 0

FLOOR CAVITY RATIO= 1.04166667

COEFFICIENT OF UTILIZATION: .55

MAINTENANCE FACTOR: .72

LAMPS PER LUMINAIRE: 2

LUMENS PER LAMP: 3200

WATTS PER LAMP: 40.7

DESIGN FOOTCANDLE LEVEL: 70

THE ACTUAL FOOTCANDLE LEVEL FOR 18 FIXTURES IS: 76.032

GROUND REFLECTANCE: .3

GLASS TRANSMITTANCE: .77

ELECTRIC USE WITHOUT DAYLIGHTING: 2666.664 KW-HRS/YR

THE FOLLOWING ARE LUMINAIRE ROW-HOURS WHEN LIGHTS ARE OFF--  
GLASS AREA            HRS OFF(SUN)            HRS OFF(CLD)

15%	2832	252
30%	3024	960
60%	3024	2088

GLASS AREA            KW-HRS OFF(SUN)            KW-HRS OFF(CLD)

15%	1383.1488	123.0768
30%	1476.9216	468.864
60%	1476.9216	1019.7792

CLEAR= 20 %, PTLY CLDY= 45 %, CLDY= 35 %

TOTAL EXPECTED KW-HRS SAVINGS: 381.97764  
FOR GLASS = 15 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 601.98416  
FOR GLASS = 30 % OF WALL AREA

TOTAL EXPECTED KW-HRS SAVINGS: 918.6804  
FOR GLASS = 60 % OF WALL AREA

**SELECTED BIBLIOGRAPHY**

#### A. REFERENCES CITED

1. American Institute of Architects. Energy in Design: Applications Level 3 Workshop of the AIA Energy Professional Development Program, Washington DC, 1981.
2. Department of Technical Applications, School of Civil Engineering, Air Force Institute of Technology (AU). Introduction to Lighting Design. Wright-Patterson AFB OH.
3. Evans, Benjamin H. Daylighting in Architecture. New York: McGraw-Hill Book Company, 1981.
4. Kaufman, J., ed. IES Lighting Handbook Fifth Edition, Illuminating Engineering Society, New York, 1981.
5. Libby-Owens-Ford Company. How to Predict Interior Daylight Illumination. Toledo OH, 1976.
6. U.S. Department of the Air Force. Engineering Technical Letter 82-5: Solar Applications. Washington: HQ USAF/LEEEU, 10 November 1982.
7. U.S. Department of the Air Force. Engineering Technical Letter 82-7: Unique Passive Solar Applications. Washington: HQ USAF/LEEEU, 30 November 1982.
8. U.S. Department of the Air Force. Engineering Technical Letter 82-6: Normal Passive Solar Applications. Washington: HQ USAF/LEEEU, 30 December 1982.

#### B. RELATED SOURCES

Illuminating Engineering Society. Recommended Practice of Daylighting. New York: IES, August 1962.

Naval Civil Engineering Laboratory, Department of the  
Navy. CEL-1 Lighting Computer Program- User's Guide  
Port Hueneme CA, September 1981.

Pierpoint, William. "A Simple Sky Model for Daylighting  
Calculations." Unpublished Technical Report, Naval Civil  
Engineering Laboratory, Port Hueneme CA, 1982.

"Sun Angle Calculator," Libby-Owens-Ford Company,  
Toledo OH, 1974.

END

FILMED

8

100

PRINTED