

10

TN NO: N-1696

TITLE: FUEL CELL POWER SYSTEMS FOR NAVY APPLICATIONS

20000803085

AUTHOR: W. R. Major and C. R. Miles

DATE: May 1984

SPONSOR: Naval Material Command

PROGRAM NO: Z0829-01-533A

# NOTE

NAVAL CIVIL ENGINEERING LABORATORY  
PORT HUENEME, CALIFORNIA 93043

Approved for public release; distribution unlimited.

DTIC  
ELECTE

JUL 24 1984

S  
E

84 07 23 008

Reproduced From  
Best Available Copy

DTIC FILE COPY

AD-A143 402  
FINAL


METRIC CONVERSION FACTORS

Approximate Conversions to Metric Measures


Symbol	When You Know	Multiply by	To Find	Symbol
in	inches	2.5	centimeters	cm
ft	feet	30	centimeters	cm
yd	yards	0.9	meters	m
mi	miles	1.6	kilometers	km
in <sup>2</sup>	square inches	6.5	square centimeters	cm <sup>2</sup>
ft <sup>2</sup>	square feet	0.09	square meters	m <sup>2</sup>
yd <sup>2</sup>	square yards	0.8	square meters	m <sup>2</sup>
mi <sup>2</sup>	square miles	2.6	square kilometers	km <sup>2</sup>
	acres	0.4	hectares	ha
oz	ounces	28	grams	g
lb	pounds	0.45	kilograms	kg
	short tons (2,000 lb)	0.9	tonnes	t
tp	teaspoons	5	milliliters	ml
Tbsp	tablespoons	15	milliliters	ml
fl oz	fluid ounces	30	milliliters	ml
c	cup	0.24	liters	l
pt	pint	0.47	liters	l
qt	quart	0.96	liters	l
gal	gallon	3.8	liters	l
ft <sup>3</sup>	cubic feet	0.03	cubic meters	m <sup>3</sup>
yd <sup>3</sup>	cubic yards	0.76	cubic meters	m <sup>3</sup>
°F	Fahrenheit temperature	5/9 (after subtracting 32)	Celsius temperature	°C

Approximate Conversions from Metric Measures

When You Know	Multiply by	To Find	Symbol
millimeters	0.04	inches	in
centimeters	0.4	inches	in
meters	3.3	feet	ft
meters	1.1	yards	yd
kilometers	0.6	miles	mi
square centimeters	0.16	square inches	in <sup>2</sup>
square meters	1.2	square yards	yd <sup>2</sup>
square kilometers	0.4	square miles	mi <sup>2</sup>
hectares (10,000 m <sup>2</sup> )	2.5	acres	
grams	0.036	ounces	oz
kilograms	2.2	pounds	lb
tonnes (1,000 kg)	1.1	short tons	
milliliters	0.03	fluid ounces	fl oz
liters	2.1	pints	pt
liters	1.06	quarts	qt
liters	0.26	gallons	gal
cubic meters	36	cubic feet	ft <sup>3</sup>
cubic meters	1.3	cubic yards	yd <sup>3</sup>
Celsius temperature	9/5 (then add 32)	Fahrenheit temperature	°F



\*1 in = 2.54 (exactly). For other exact conversions and more detailed tables, see NBS Misc. Publ. 286, Units of Weights and Measures, Price \$2.25, SD Catalog No. C13.10-286.



Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER TN-1696	2. GOVT ACCESSION NO. DN387293	3. RECIPIENT'S CATALOG NUMBER AN 143 402
4. TITLE (and Subtitle) FUEL CELL POWER SYSTEMS FOR NAVY APPLICATIONS	5. TYPE OF REPORT & PERIOD COVERED Final; Oct 1981 - Nov 1982	6. PERFORMING ORG. REPORT NUMBER
	7. AUTHOR(s) W. R. Major and C. R. Miles	8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS NAVAL CIVIL ENGINEERING LABORATORY Port Hueneme, California 93043	10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS 63724N; Z0829-01-533A	12. REPORT DATE May 1984
11. CONTROLLING OFFICE NAME AND ADDRESS Naval Material Command Washington, DC 20360	13. NUMBER OF PAGES 68	15. SECURITY CLASS. (of this report) Unclassified
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)	15a. DECLASSIFICATION DOWNGRADING SCHEDULE	
16. DISTRIBUTION STATEMENT (of this Report)  Approved for public release; distribution unlimited.		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Fuel cell, co-generation, computer simulation, thermal storage, operational mode		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) A fuel cell power plant can supply both thermal and electrical energy to a site load. The technical and economic attractiveness of using a fuel cell system for a given application depends on many factors such as: satisfying load requirements, reliability, local energy costs, and capital costs. Satisfying site load requirements cost effectively requires a properly sized fuel cell system operating in its optimum mode. A computer program was continued		

DD FORM 1473 1 JAN 73 EDITION OF 1 NOV 65 IS OBSOLETE

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

over

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

2J. Continued

developed to simulate the dynamic input/outputs of the fuel cell system (fuel cell, auxiliary boiler, thermal storage, electrical grid) and evaluate the separate system operational costs. Using the computer simulation in an iterative method, the optimum operational mode and size of the fuel cell and thermal storage can be estimated. A life-cycle-cost analysis for a given application can be performed using current manufacturer hardware costs and energy input/output data generated from the computer simulation. ←

Library Card

Naval Civil Engineering Laboratory  
FUEL CELL POWER SYSTEMS FOR NAVY APPLICATIONS  
(Final), by W. R. Major and C. R. Miles  
TN-1696 68 pp illus May 1984 Unclassified

1. Fuel cell                      2. Computer simulation                      I. Z0829-01-533A


A fuel cell power plant can supply both thermal and electrical energy to a site load. The technical and economic attractiveness of using a fuel cell system for a given application depends on many factors such as: satisfying load requirements, reliability, local energy costs, and capital costs. Satisfying site load requirements cost effectively requires a properly sized fuel cell system operating in its optimum mode. A computer program was developed to simulate the dynamic input/outputs of the fuel cell system (fuel cell, auxiliary boiler, thermal storage, electrical grid) and evaluate the separate system operational costs. Using the computer simulation in an iterative method, the optimum operational mode and size of the fuel cell and thermal storage can be estimated. A life-cycle-cost analysis for a given application can be performed using current manufacturer hardware costs and energy input/output data generated from the computer simulation.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

CONTENTS

	Page
INTRODUCTION . . . . .	1
APPROACH . . . . .	1
DISCUSSION . . . . .	2
United Technology 40-kW Fuel Cell Power Plant . . . . .	2
Development Of 40-kW Phosphoric Acid Fuel Cell Computer Model . . . . .	3
Extended 40-kW Fuel Cell Power Plant Computer Simulation . . . . .	4
APPLICATION . . . . .	5
Simulation At Naval Air Station (NAS) Sewell's Point . . . . .	5
Phosphoric Acid Fuel Cell Economics . . . . .	8
SUMMARY . . . . .	8
REFERENCES . . . . .	8
 APPENDIXES	
A - Program Listing For Extended 40-kW Fuel Cell Computer Simulation . . . . .	A-1
B - Program Printouts Of Extended 40-kW Fuel Cell Computer Simulation . . . . .	E-1

<b>Accession For</b>	
ETYS GRA&I	<input checked="" type="checkbox"/>
DTIC IAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A-1	



## INTRODUCTION

An analysis of the technical and economic feasibility of using fuel cells for Navy shore activity applications was performed. The primary advantage of fuel cell power plants is their ability to generate electrical energy efficiently (approximately 40%) regardless of their size. This feature, in addition to the inherent operating quietness, allows siting of fuel cell plants next to loads where the fuel cell thermal by-product (domestic hot water) can be utilized. Fuel efficiencies as high as 80% can be realized when operating in the co-generation mode.

This report documents a computer program for simulating the operation of a fuel cell power plant at a Navy site. The computer program was initially developed to simulate a 40-kW phosphoric acid fuel cell operating with or without an electrical grid and auxiliary boiler. The program was later extended to include thermal storage and phosphoric acid fuel cells of any size.

## APPROACH

In this investigation of fuel cell power systems, a model was developed to simulate the operation of an existing fuel cell system. The United Technology 40-kW phosphoric acid fuel cell was chosen to model because it is currently the most commercially developed fuel cell power plant system available.

As a first step in the analysis, data were collected for the 40-kW fuel cell. Available data consisted of performance curves and subsystem operational "thermodynamic state points" for the power plant operating at 20- and 40-kW. From these data and the objectives of the investigation, output requirements for the computer simulation were established.

In the development of the computer program, a mathematical model of the fuel cell power plant subsystems was employed. A mathematical model was developed through a thermodynamic analysis of each power plant subsystem, using the thermodynamic state point data collected. Most subsystems could be modeled accurately, but it was found that the data was insufficient for an accurate model of the entire system. Therefore, the mathematical model was modified to include manufacturer performance test curves in lieu of state points. Subsystem models from the thermodynamic analysis, such as the effect of ambient air temperature on the fuel cell performance, were kept for thermal effects not well-represented in performance curves.

A computer flow chart was then prepared, based on the modified mathematical model and computer program input/output requirements. From this flow chart, a computer simulation program was developed for this particular fuel cell operating at a Navy site. After achieving a working

computer simulation model for the 40-kW fuel cell, the program was extended to include phosphoric acid fuel cells of any size. This enhanced the computer program capability while requiring relatively minor alterations to the program itself. Because fuel cell electrical efficiencies are consistent over a wide range of sizes, the same performance curves could be used for the extended program. Thermal storage sizing capability was also added.

With the modified program used in an iteration scheme, the optimum operational size of a fuel cell and thermal storage can be determined for a given Navy site application. From current fuel cell capital costs, site-specific energy load and rates, and energy consumption/displacement data generated from the computer simulation, a life cycle cost analysis can be performed for a given application.

## DISCUSSION

### United Technology 40-kW Fuel Cell Power Plant

The 40-kW fuel cell power plant is an on-site energy system which simultaneously generates AC electrical power and recoverable thermal energy. It uses pipeline gas or peak-shaved gas for fuel (Table 1).

Figure 1 illustrates the 40-kW fuel cell power plant. The plant features include: high efficiency; quiet, nonpolluting, automatic, unattended operation; and instantaneous load response. The power plant consists of the following major subsystems:

1. Fuel processor
2. Power section
3. Thermal management subsystem
4. Power conditioner

Figure 2 is a simplified block diagram of the fuel cell power plant. The fuel processor delivers a hydrogen-rich gas to the anode side of the power section. The power section electrochemically consumes this gas and oxygen, which has been delivered to the cathode side of the power section, to produce direct electric current. This direct current goes to an inverter to produce AC electrical power with characteristics shown in Table 2. The thermal management system controls the power section reaction temperature (approximately 370°F) and supplies thermal energy for fuel preprocessing/processing, high and low grade heat exchangers, and condensate preheating. The high grade heat exchanger is connected in the cooling loop of the power section, and the low grade heat exchanger is connected to the power section cathode exhaust. Both heat exchangers supply domestic hot water between 110 and 180°F.

At the time of this investigation, the most detailed operational data available for the United Technology 40-kW fuel cell system were the "thermodynamic state point" data for the power plant operating at 20 and

40 kW. This operational data were generated by United Technologies and supplied to the NASA-Lewis Research Center under contract. Figure 3 illustrates the operational schematic of the 40-kW fuel cell power plant, and Table 3 is a list of the accompanying thermodynamic state point data for the fuel cell operating at 20- and 40-kW. System performance curves also generated by United Technologies (Figures 4 through 7) exist for system electrical efficiencies, low and high grade heat availability, and power plant percent fuel utilization.

#### Development Of 40-kW Phosphoric Acid Fuel Cell Computer Model

As a first step in developing this computer model, computer input and output requirements were established. Data inputs that are available or can be approximated for a given site include: daily electrical and thermal load data, ambient air temperature, electrical costs (buying and selling), and auxiliary boiler and fuel cell fuel costs. Using these input data, computer output requirements were determined as follows:

- A. Energy Printouts (every 1/2 hour)
  - 1. Fuel cell electrical output
  - 2. Fuel cell thermal output
  - 3. Fuel cell thermal energy dumped
  - 4. Grid output
  - 5. Grid input (from fuel cell)
  - 6. Auxiliary boiler output
- B. Total Daily Cost Printouts
  - 1. Fuel cell fuel consumption
  - 2. Electricity purchased
  - 3. Electricity sold
  - 4. Auxiliary boiler fuel consumed

The printout requirements listed are available for four different load following schemes: the fuel cell running at rated output; electrical load following; thermal load following; and the fuel cell at zero output. The computer program simulates fuel cell operation for a maximum of 24 hours per total data set entry.

Development of the computer model to meet these output requirements proceeded with a thermodynamic analysis of the fuel cell power plant subsystems, using the thermodynamic state point data. These data were found insufficient for a complete and accurate mathematical model of the system. Equations derived from manufacturer performance test curves



were then combined with specific subsystem thermodynamic models (ambient air temperature effects, thermal management system) to provide a more accurate model of the fuel cell system.\*

Four of the performance curves used in the mathematical model of the 40-kW power plant are shown in Figures 4 through 7. Equations generated from these curves represent the fuel cell plant's low- and high-grade thermal and electrical outputs and the ambient air temperature enthalpy effect on the power section cathode exhaust. These equations are all interrelated and are solved in the mathematical model by equating the appropriate equation variables to either the electrical or the thermal load requirement and sequentially (rated output; electrical load following) or simultaneously (thermal load following) solving for the remaining variables. By using the mathematical model and program input/output requirements, a computer flow chart was developed. The flow chart is divided into six major sections as follows:

1. Data input and load following scheme selection
2. Fuel cell power plant running at rated output
3. Plant electrical output set equal to the electrical load requirement
4. The combined thermal output of the fuel cell (low- and high-grade heat) set equal to the total thermal load requirement
5. Fuel cell output set equal to zero
6. Printout of desired energy and operational cost data

The computer program developed from this flow chart reads in one electrical and thermal load data set for every 1/2 hour of simulated operation. Each data set is run through the separate load following schemes and all output requirements are computed before the next data set is read. After computations are completed for the last data set entry, the user may select a variety of printouts pertaining to the program load following schemes, energy input/outputs, and cost analysis. This computer simulation of the United Technologies 40-kW fuel cell power plant is available, but a program listing is not included in this report as it is not the final product of this investigation.

#### Extended 40-kW Fuel Cell Power Plant Computer Simulation

The extended computer simulation is similar to the 40-kW computer program but also allows the user to select the size fuel cell and thermal storage capacity desired. A simplified operational schematic of the integrated fuel cell, utility grid, thermal storage, and auxiliary heater

\*Forty-eight United Technology fuel cell power plants are currently being manufactured and tested in a variety of locations. Verification of manufacturer performance curves will accompany the associated field test data.

system used for this simulation is shown in Figure 8. Figure 9 shows the flow chart of the extended fuel cell computer program with fuel cell and thermal storage size selection capability.

The extended 40-kW fuel cell computer program optimizes the fuel cell and thermal storage size with respect to energy inputs/outputs and operational costs through an iteration method. Initial fuel cell size and thermal storage capacity is selected by the user based on electrical and thermal load data and desired operational mode. Table 4 lists all input requirements for the extended computer program. With these inputs, an initial computer simulation is run. From this simulation the user would observe energy input/output data printouts to determine if all energy requirements are satisfied for the size of fuel cell and storage capacity selected. The total system energy operating costs would also be noted for comparison with subsequent simulations having the same load requirement data sets. This method can be repeated until the lowest operating cost is obtained and all energy requirements of a particular application are satisfied.

Appendix A lists the extended computer simulation for the phosphoric acid fuel cell power plant. Operating options and use of this simulation are presented in Table 5.

## APPLICATION

### Simulation At Naval Air Station (NAS) Sewell's Point

To provide an example for using the extended computer program, a computer simulation was done for NAS Sewell's Point, Va. This example simulated a fuel cell operating with grid and auxiliary boiler with operating options and use outlined in Table 5. Bachelor's Enlisted Quarters (BEQ) (Building U-16) at Sewell's Point was chosen for simulation for its comparable hot water and electrical load profiles. Detailed electrical consumption data for this activity were obtained from Reference 1. Hot water consumption data were generated on a per man basis in accordance with Reference 2. The electrical, fuel, and thermal energy unit cost data for Sewell's Point and the Navy-wide averages obtained from FY82 DEIS II reports (Ref 3 and 4) are listed in Table 6. For this computer simulation example, electrical energy was "sold back" to the grid for \$0.01/kW less than its purchase cost. Actual sell back rates vary greatly, depending on utility company policy and local laws governing those rates. Printouts of this simulation are shown in Appendix B.

A 150-kW fuel cell size, between the minimum (115-kW) and maximum (195-kW) electrical load, was selected for the initial simulation. Thermal storage size was initially selected at 10% of the total daily consumption (Ref 2). User inputs for the initial simulation are listed in Appendix B. Tables B-1, B-2, and B-3 list the 24-hour total energy inputs/outputs every 1/2 hour for a grid, auxiliary heater (boiler), thermal storage, and fuel cell operating under three separate load following schemes: rated output (Table B-1); electrical load following (Table B-2); thermal load following (Table B-3). The columns on each page show how all components of the fuel cell energy system react to the electrical and thermal load for the selected load following scheme.

Each table has eight columns defined as follows:

1. TIME - actual time of simulation in increments of 1/2 hour up to 24 hours
2. ELEC - the BEQ electrical load
3. THERM - the BEQ thermal load
4. F/C - the fuel cell electrical output
5. GRID - electrical energy delivered from (+) or to (-) the grid
6. F/C - the fuel cell thermal output
7. BOILER - the auxiliary boiler/heater thermal output
8. STORAGE - the hot water storage thermal output

Note that columns 4 and 5 together equal column 2 (electrical load) and that columns 7 and 8 together equal column 3 (thermal load) for a given simulation time. Column 6, the fuel cell thermal output, contributes to the thermal load and hot water storage, and in some instances must be dumped by means of cooling fans in the fuel cell power unit.

To aid in the interpretation of the fuel cell thermal outputs, the computer program incorporates a separate printout sheet titled "Thermal System Input/Output." Table B-4 lists the thermal system inputs/outputs for a 150-kW fuel cell and 3,000-gallon thermal storage. Each of these pages has six columns defined as follows:

1. TIME - actual time of simulation in increments of 1/2 hour up to 24 hours
2. LOAD - the BEQ thermal load
3. AVAIL - thermal energy available from the fuel cell
4. DUMPED - thermal energy dumped by the fuel cell (cooling fans)
5. OUTPUT - hot water storage contribution to the thermal load
6. LEVEL - actual storage in 1,000 Btu's of hot water storage at a given time.

The change in storage level for any 1/2-hour period (any two adjacent figures in column 6) equals 1/2(column 3 - column 4 - column 5). For example, in Table B-4, from 0 to 30,

$$\Delta 6 = 1/2(358.94 - 0 - 64.34) = 147.30 \text{ Btu}$$

These printouts are used primarily for sizing thermal storage to handle system thermal level fluctuations created by (1) high fuel cell thermal output at low thermal load and (2) low fuel cell thermal output at high thermal load. Optimizing thermal storage size is accomplished by minimizing the auxiliary boiler output and fuel cell thermal dumping and maximizing the thermal storage contribution to the thermal load. For comparison, the thermal storage size was changed to 500 gallons and the simulation was run with identical load data. Table B-5 lists the thermal inputs/outputs for this simulation.

Operational cost printouts for a 150-kW fuel cell operating with grid and auxiliary boiler are shown in Table B-6. Sewell's Point energy unit cost data (Ref 4) were used for these printouts. Similar cost printouts were also generated for a 100-, 150-, and 200-kW fuel cell with 3,000 gallon thermal storage, using both Navy-wide average and Sewell's Point energy unit cost data. A summary of these printouts and an operational cost total for a 150-kW fuel cell with 500-gallon storage are presented in Table 7, which can be used in combination with energy input/output printouts to determine the lowest operating costs for given application requirements and to explain the varied costs.

The following are observations and comments for Table 7.

1. Observation: For the rated and electrical load following schemes, daily operational costs for the 150-kW fuel cell with 3,000-gallon thermal storage are approximately \$5/day lower than the 150-kW fuel cell with 500-gallon thermal storage.

Comments: The 500-gallon storage thermal system input/output printouts (Table B-5, column 4) show that a high percentage of the fuel cell thermal energy is dumped and that the storage thermal output (column 5) is considerably lower than the thermal demand (column 2), resulting in higher auxiliary boiler costs. The 3,000-gallon thermal storage (Table B-4, column 4) minimizes the thermal load fluctuations, thereby utilizing the fuel cell thermal energy more efficiently.

2. Observation: Using Sewell's Point energy unit costs, the lowest system operating cost is obtained with fuel cell electrical load following. When Navy-wide energy unit costs are used, the lowest operating cost is obtained by running the fuel cell at rated output.

Comments: Table 6 shows that Navy-wide average purchased electrical unit costs are considerably higher than Sewell's Point electrical unit costs but that Navy-wide natural gas unit costs are lower than at Sewell's Point. Operational costs are lower using Navy-wide energy unit costs since the fuel cell can cost effectively produce excess electrical energy to sell back to the grid. These operational costs will decrease for larger fuel cells until the fuel cell thermal by-product cannot be utilized efficiently because they exceed the thermal load. When using Sewell's Point energy unit costs, it is not cost-effective to produce excess electrical energy; consequently, the electrical load following scheme has lower operating costs.

3. Observation: The fuel cell thermal load following scheme operational costs are higher than the electrical load following costs.

Comments: The thermal load following energy input/output printouts (Table B-3, column 5) show that a considerable amount of electrical energy had to be purchased from the grid. This is due to the low fuel cell electrical output when the fuel cell is following a minimal thermal load. Although each application must be considered separately, this investigation found that thermal load following was not advantageous when extreme fluctuations in the thermal load existed.

4. Observation: Daily cost "savings" (operational cost without fuel cell minus operational cost with fuel cell) using Navy-wide energy unit costs are over \$100/day more than when using Sewell's Point energy unit costs.

Comments: This large operational cost savings difference is due directly to the differences in the Navy-wide average and the Sewell's Point energy unit costs. The effects of such cost differences on the economics of a given application are discussed briefly in the following section.

#### Phosphoric Acid Fuel Cell Economics

A total life-cycle-cost product analysis for a 150-kW fuel cell operating with grid, auxiliary boiler, and 3,000-gallon thermal storage is shown in Table 8. The analysis was done in accordance with Reference 5 using a 25-year projected life, a 9.524 cumulative uniform series discount factor, and Navy-wide levelized fuel prices shown in Table 9. Energy consumption and displacement data used in lines 9 and 11 in Table 8 was taken directly from the 150-kW fuel cell electrical load following computer simulation printouts of Appendix B and extrapolated to represent one year's energy consumption/displacement. Since fuel cells are an emerging technology, projected commercial capital costs were used for this analysis. A unit fuel cell capital cost of \$1,500/kW-energy was selected from a range of \$400 to \$1,600/kW-energy (Ref 6). Applying Navy-wide levelized unit energy costs to the Sewell's Point example, line 12 of Table 8 shows a life-cycle-cost of \$10.51/MBtu. When compared to Table 9's purchased electricity levelized price (\$10.66/MBtu), this application is seen as marginally cost effective. Using Sewell's Point levelized energy unit costs would make this application not cost effective for the fuel cell unit capital cost selected. However, the majority of fuel cell capital cost projections are lower than used in this example, and more desirable energy unit costs can be obtained by selecting a different Navy site.

#### SUMMARY

Since phosphoric acid fuel cells produce electricity with high efficiency, have instantaneous load response, are nonpolluting, and can be sited next to loads (quiet operation) for thermal by-product use, the technical feasibility of fuel cells for Navy applications becomes a

question of operational reliability and life cycle costs. Although high reliability is a design feature of phosphoric acid fuel cells, actual operating data is needed to verify this reliability. The economics of each fuel cell system (grid, auxiliary heater, thermal storage) application are determined primarily by capital costs, local energy unit costs, and fuel cell system operational mode and handling of electrical and thermal loads. An example was given of a Navy application at NAS Sewell's Point. This example had a marginal economic return due to a high fuel cell unit capital cost of \$1,500/kW-energy. Industry's projected lower capital costs could greatly increase the cost-effectiveness and number of potential Navy fuel cell applications.

The computer program developed in this investigation simulates the fuel cell system (grid, auxiliary heater, thermal storage) daily operation and generates energy consumption and displacement data required for an economic analysis. Since a variety of phosphoric acid fuel cell sizes are not currently available, this computer program is best utilized for projecting Navy fuel cell applications and evaluating phosphoric acid fuel cells as they become commercially available. Fuel cell sizing applications using computer methods will increase with fuel cell commercialization. The phosphoric acid fuel cell is currently the most commercially developed but other types of fuel cells (molten carbonate, solid electrolyte) having greater technical and economic potential are emerging. The enclosed computer program (Appendix A) is structured such that it can be modified to simulate the operation of these different fuel cells without excessive alterations to the existing program.

#### REFERENCES

1. R.E. Bergman and R.J. Tinsley. Measurements of winter electrical consumption at Sewell's Point Naval complex, Naval Civil Engineering Laboratory, Technical Memorandum M-53-81-03. Port Hueneme, Calif., Aug 1981.
2. Navy Bureau of Yards and Docks. Mechanical engineering, NAVFAC DM-3. Washington, D.C., Sep 1972, pp 3-1-13 and 3-1-14.
3. Naval Energy and Environmental Support Activity (NEESA). Defense energy information system, Navy-wide shore utilities (DEIS II) FY82. Port Hueneme, Calif., Oct 82.
4. \_\_\_\_\_. Defense energy information system, Energy unit cost, shore utilities (DEIS II) FY82. Port Hueneme, Calif., Oct 82.
5. National Bureau of Standards. Life cycle cost manual for the Federal Energy Management Program, NBS Handbook 135. Washington, D.C., Dec 1980.
6. Institute of Gas Technology. Symposium papers: Fuel cell technology status and applications. Chicago, Ill., May 82.
7. United Technologies Power Systems Division. On site 40-kilowatt fuel cell power plant model specification, Contract Report No. OE-AC-0377 ET11302. South Windsor, Conn., Sep 79.

Table 1. Pipeline and Peak-Shaved Gas Specifications

Component	Specification	Maximum Allowable Volume
<b>Peak-Shaved Gas</b>		
Natural Gas	Minimum, 45% by Volume Total Gas Mix	
Peak-Shaved Gas Mix	Maximum, 55% by Volume Total Gas Mix	
Liquified Petroleum (L.P.) Gas	Maximum, 36% by Volume, in Total Gas Mix	
Air	Maximum, 23.5% by Volume, in Total Gas Mix	
Propylene	Maximum, 10% by Volume, in L.P. Gas (Equal to 3.6% in Total Gas Mix)	
Total Sulfur	Maximum, 30 ppm <sub>V</sub>	
Thiophane Sulfur	Maximum, 10 ppm <sub>V</sub>	
Maximum NH <sub>3</sub>	Maximum, 1.0 ppm <sub>V</sub>	
Chlorine	0.05 ppm <sub>W</sub>	
<b>Pipeline Gas</b>		
Methane		100.0%
Ethane		10.0%
Propane		5.0%
Butanes		1.25%
Pentanes, Hexanes C <sub>6</sub> <sup>+</sup>		0.5%
CO <sub>2</sub>		3.0%
O <sub>2</sub>		2.5%
N <sub>2</sub> (Continuous)		15.0%
Total Sulfur	Maximum, 30 ppm <sub>V</sub>	
Thiophane Sulfur	Maximum, 10 ppm <sub>V</sub>	
Maximum NH <sub>3</sub>	Maximum, 1.0 ppm <sub>V</sub>	
Chlorine	0.05 ppm <sub>W</sub>	

Table 2. Electrical Characteristics

Characteristic	Description
Output Power Form	4-wire, 3-phase
Frequency	60 Hertz
Frequency Stability	±0.0002%/yr
Voltage	120/208 VAC
Voltage Regulation	±5% with up to 30% load unbalance under steady state conditions
Voltage Recovery	Within 2 cycles
Phase Separation	120 ±5 degrees electrical
Current Limit	Up to 300 amperes RMS for line-to-line short circuits and 450 amperes RMS for line to neutral short circuits
Maximum Duration of Current Limit	5 seconds
Total Harmonic Distortion	≤15%
Electromagnetic Noise	Shall not degrade performance of conventional electrical equipment located farther than 10 feet from the power plant



Table 3. Thermodynamics State Point Data

Station No.	Temperature (°F)	Pressure (psia)	Hydrogen (pph)	Carbon Dioxide (pph)	Carbon Monoxide (pph)	Nitrogen <sup>a</sup> (pph)	Oxygen (pph)	Water (pph)	Methane (pph)	Total (pph)
A. 20-kW AC Net, 70°F Ambient, 500 hr performance										
1	70	14.8							8.0	8.0
2	407	13.1	0.403	2.162	0.032			1.48	8.07	12.1
3	366	13.0	0.403	2.162	0.032			1.48	8.07	12.1
4	474	13.0	0.403	2.162	0.032			1.48	8.07	12.1
5	448	11.7	0.403	2.162	0.032			1.48	8.07	12.1
6	505	15.4	0.403	2.162	0.032			30.75	8.07	41.6
7	656	14.9	3.555	11.128	7.020			19.11	0.80	41.6
8	602	14.9	3.555	11.128	7.020			19.11	0.80	41.6
9	378	14.9	3.555	11.128	7.020			19.11	0.80	41.6
10	363	14.8	3.555	11.128	7.020			19.11	0.80	41.6
11	443	14.8	4.037	21.648	0.325			14.81	0.80	41.6
12	438	14.8	0.403	2.162	0.032			1.48	0.08	4.2
13	362	14.7	3.634	19.486	0.292			13.33	0.72	37.5
14	355	14.7	3.634	19.486	0.292			13.33	0.72	37.5
15	374	14.7	0.715	19.488	0.292			4.43	0.72	25.6
16	677	14.7		21.947		37.679	2.63	12.44		74.7

Continued

Table 3. Continued

Station No.	Temperature (°F)	Pressure (psia)	Hydrogen (pph)	Carbon Dioxide (pph)	Carbon Monoxide (pph)	Nitrogen <sup>a</sup> (pph)	Oxygen (pph)	Water (pph)	Methane (ppt.)	Total (pph)
17	242	14.7		22.045		203.64	29.48	63.54		318.7
18	111	14.7		22.045		203.64	29.48	15.21		270.4
19	114	14.7		2.629		4,430.0	1,334.82			5,767.4
20	70	14.7		0.121		203.64	61.36			265.1
21	70	14.7		0.022		37.679	11.35			49.1
22	70	14.7		0.004		7.674	2.116			10.0
23	475	14.7		0.018		30.005	9.234			39.1
24	70	14.7		0.098		165.961	50.01			216.1
25	374	14.7		0.098		165.961	26.84	34.97		227.9
26	185	14.7		0.098		165.961	26.84	34.97		227.9
27	111	14.7						48.33		48.33
28	212	14.7						44.20		44.20
29	71	14.2						44.20		44.20
30	203	164.5						44.20		44.20
31	358	164.5						1,800.0		1,800.0
32	366	165.2						1,800.0		1,800.0

Continued

Table 3. Continued

Station No.	Temperature (°F)	Pressure (psia)	Hydrogen (pph)	Carbon Dioxide (pph)	Carbon Monoxide (pph)	Nitrogen <sup>2</sup> (pph)	Oxygen (pph)	Water (pph)	Methane (pph)	Total (pph)
33	366	165.2						1,800.0		1,800.0
34	366	165.0						1,800.0		1,800.0
35	366	164.8						1,800.0		1,800.0
36	366	164.7						1,800.0		1,800.0
37	366	164.5						1,800.0		1,800.0
38	365	164.5						1,755.8		1,755.8
39	362	164.5						1,755.8		1,755.8
B. 40-kW net, 70°F Ambient, 500 hr performance										
1	70	14.8							16.1	16.1
2	443	13.2	0.854	4.546	0.097			3.10	16.24	24.8
3	351	13.1	0.854	4.546	0.097			3.10	16.24	24.8
4	476	13.0	0.854	4.546	0.097			3.10	16.24	24.8
5	467	10.3	0.854	4.546	0.097			3.10	16.24	24.8
6	594	16.5	0.854	4.546	0.097			61.89	16.24	83.6
7	795	15.3	7.086	20.150	15.718			39.07	1.60	83.6
8	746	15.2	7.086	20.150	15.718			39.07	1.60	83.6

Table 3. Continued

Station No.	Temperature (°F)	Pressure (psia)	Hydrogen (pph)	Carbon Dioxide (pph)	Carbon Monoxide (pph)	Nitrogen <sup>a</sup> (pph)	Oxygen (pph)	Water (pph)	Methane (pph)	Total (pph)
9	483	15.2	7.086	20.150	15.718			39.07	1.60	83.6
10	352	15.0	7.086	20.150	15.718			39.07	1.60	83.6
11	483	15.0	8.150	43.393	0.922			29.56	1.61	83.6
12	481	15.0	0.854	4.546	0.097			3.10	0.17	8.8
13	403	14.7	7.296	38.846	0.826			26.46	1.44	74.9
14	345	14.7	7.296	38.846	0.826			26.46	1.44	74.9
15	372	14.7	1.501	38.845	0.826			9.21	1.44	51.8
16	825	14.7		44.132		74.026	4.18	25.85		148.2
17	301	14.7		44.324		397.395	55.62	113.25		610.6
18	105	14.7		44.324		397.395	55.62	25.07		522.4
19	135	14.7		3.647		6,144.897	1,851.55			8,000.1
20	70	14.7		0.236		397.395	119.74			517.4
21	70	14.7		0.044		74.026	22.31			96.4
22	70	14.7		0.004		7.674	2.116			10.0
23	608	14.7		0.040		66.352	20.194			86.4
24	70	14.7		0.192		323.359	97.43			421.0

Table 3. Continued

Station No.	Temperature (°F)	Pressure (psia)	Hydrogen (pph)	Carbon Dioxide (pph)	Carbon Monoxide (pph)	Nitrogen <sup>a</sup> (pph)	Oxygen (pph)	Water (pph)	Methane (pph)	Total (pph)
25	372	14.7		0.192		323.359	51.44	69.06		444.1
26	230	14.7		0.192		323.359	51.44	69.06		444.1
27	105	14.7						88.2		88.2
28	212	14.7						88.2		88.2
29	72	13.8						88.2		88.2
30	203	131.9						88.2		88.2
31	338	131.9						88.2		88.2
32	350	134.3						1,800.0		1,800.0
33	350	134.1						1,800.0		1,800.0
34	349	133.6						1,800.0		1,800.0
35	349	133.1						1,800.0		1,800.0
36	349	132.5						1,800.0		1,800.0
37	348	132.0						1,800.0		1,800.0
38	348	131.9						1,711.8		1,711.8
39	345	131.9						1,711.8		1,711.8

<sup>a</sup>Includes argon in air.

Table 4. User Inputs for Extended 40-kW Computer Program

Input	Units
Fuel cell size	kW
Date/location/total hours of simulation	
Electrical load data	kW
Thermal load data	kBtu/hr
Ambient air temperature	°F
Thermal storage volume	gal
Thermal storage initial temperature	°F
Required hot water temperature	°F
System feed water temperature	°F
Natural gas unit cost	\$/MBtu
Thermal energy unit cost	\$/MBtu
Purchased electricity unit cost	\$/kW
Sell electricity unit cost	\$/kW

Table 5. Extended Fuel Cell Computer Simulation Operating Options and Use

Option	Load Following Schemes	Fuel Cell Size Selection	Storage Size Selection	Auxiliary Heater Size
Can Buy and Sell Electricity				
I. Operating With Grid and Auxiliary Heater	(a) Rated output (b) Electrical load following (c) Thermal load following (program determines lowest operating cost)	Vary size to obtain lowest operating cost for the three load-following schemes	Vary size to minimize: (a) Fuel cell thermal energy dumping (b) Auxiliary heater thermal output	(a) With existing heater: do not exceed maximum size (b) With new heater: size to maximum heater load
II. Operating With Grid and No Auxiliary Heater	(a) Rated output (b) Electrical load following (if combination of thermal storage and fuel cell output is sufficient) (c) Thermal load following	Must have enough output to meet maximum thermal load	Size to handle thermal demand fluctuations	Not applicable
Can Buy Electricity Only				
I. Operating With Grid and Auxiliary Heater	Electrical load following only	Vary size to obtain lowest operating cost for electrical load following	Vary size to minimize: (a) Fuel cell thermal energy dumping (b) Auxiliary heater thermal output	(a) With existing heater: do not exceed maximum size (b) With new heater: size to maximum heater load
II. Operating With Grid and No Auxiliary Heater	Electrical load following only	Must have enough output to meet maximum thermal load	Size to handle thermal demand fluctuations	
No Grid Connection				
III. No Grid Connection and Auxiliary Heater Available	Electrical load following only	Fuel cell sized to maximum electrical demand	Sized to minimize fuel cell thermal dumping and auxiliary heater output	Sized to meet thermal demand not handled by fuel cell and thermal storage
IV. Remote Operation	Electrical load following only	Size to maximum electrical or thermal demand (whichever is higher)	Size to handle all thermal demand fluctuations	
V. Dual Use of Fuel Cells (Reliability)	Run one fuel cell at rated power	Subtract thermal and electrical output from load requirement data	Simulate other fuel cells operating with modified load requirement data	

Table 6. Navy-wide and Sewell's Point FY82 Energy Prices

Energy Type	NAS Sewell's Point	Navy-wide Average
Natural Gas	\$4.95/MBtu	\$4.24/MBtu
Thermal Energy <sup>a</sup>	\$7.80/MBtu	\$9.33/MBtu
Purchased Electricity	\$37.43/MWh	\$57.54/MWh

<sup>a</sup>Based on average fuel oil price and 0.75 boiler conversion efficiency.



Table 7. Operational Cost Summary for 24-Hour Simulation of Building U-16 at Sewell's Point

Fuel Cell Output/Size	3,000-Gallon Thermal Storage							500-Gallon Thermal Storage
	Navy-wide Energy Unit Costs (\$) for--			Sewell's Point Energy Unit Costs (\$) for--			Navy-wide Energy Costs (\$) for--	
	100 kW	150 kW	200 kW	100 kW	150 kW	200 kW		
Rated	254.49	218.05	191.37	230.77	231.77	240.90	223.80	
Electrical load following	254.49	218.84	216.33	230.77	224.67	224.21	223.93	
Thermal load following	275.06	240.29	218.19	238.07	229.83	229.95	240.29	
Fuel Cell Output = 0 <sup>a</sup>		369.26			265.20		369.26	

<sup>a</sup>All electricity is supplied by utility grid, and all thermal energy is supplied by auxiliary heater/boiler.

Table 8. Total Life-Cycle-Cost Analysis

Product: 150-kW Phosphoric Acid Fuel Cell operating with utility grid and auxiliary boiler

Location: Building U-16, NAS Sewell's Point

Item	Cost
1. Acquisition cost of (typical) single application	\$225K
2. Present worth, terminal value of single application	\$0K
3. Net adjusted capital investment of single application [1 - 2]	\$225K
4. Economic life of application	25 years
5. CUS factor for economic life of single application	9.524
6. Capital investment, annualized [3 ÷ 5]	\$23.62K/yr
7. Annual non-energy O&M costs	\$2K/yr
8. Annual energy use	
a. Energy Type <u>Natural Gas</u>	
(1) Annual energy consumption	11,640 MBtu/yr
(2) Unit cost	\$9.07/MBtu
(3) Annual energy cost	\$106K/yr
b. Energy Type <u>Fuel Oil</u>	
(1) Annual energy consumption	3,595 MBtu/yr
(2) Unit cost	\$13.29/MBtu
(3) Annual energy cost	\$47.78K/yr
c. Energy type <u>Electricity</u>	
(1) Annual energy consumption	614 MBtu/yr
(2) Unit cost	\$10.66/MBtu
(3) Annual energy cost	\$6.54K/yr
d. Total annual cost for energy [8a (2) + 8b (2) + 8c (2)]	\$160.32K/yr
9. Total annual recurring costs [(8d) + (7)]	\$162.32K/yr
10. Annual energy generated/displaced	17,688 MBtu/yr
11. Life-cycle-costs [(6 + 9)/10]	\$10.51/MBtu

Table 9. Levelized Fuel Prices by Fuel Type<sup>a</sup>  
 [1985-2010 time period]

Fuel Type	Cost (\$/MBtu)
Purchased Electricity	10.66 <sup>b</sup>
Fuel Oil	13.29
Natural Gas	9.07
Coal	4.17
Propane	29.30
Purchased Steam/Hot Water	24.42

<sup>a</sup>Steps developed by NCEL to project levelized fuel prices in 1982 dollars:

1. 1980 prices are derived from least-squares analysis of historical DEIS and UCAR data (1970 - Second Quarter 1980).
2. 1985 prices are projected from 1980 prices using short-term escalation rates, but ignoring inflation.
3. Prices are levelized over 1985-2010 time period using long-term differential escalation rates.

<sup>b</sup>The \$/MBtu number given for electricity includes the power plant conversion efficiency of 11,600 Btu/kWh.




Figure 1a. Outer configuration.




Figure 1b. Major component locations.

Figure 1. 40-kW power plant (from Ref 7).




Figure 2. Simplified block diagram (from Ref 7).




Figure 3. Power plant schematic (from Ref 7).




Figure 4. Electrical efficiency bandwidth (from Ref 7).




Figure 5. Power plant fuel flow (from Ref 7).




Figure 6. Low grade heat availability (from Ref 7).




Figure 7. High grade heat availability (from Ref 7).






Figure 8. Fuel cell operating with utility grid, thermal storage, and auxiliary heater.






Figure 9. Steps for extended fuel cell

I  
P-29

U  
 sec  
 ions  
 and  
 ata  
 fuel  
 cell  
 le-  
 scheme  
 nes  
 J = 1  
 J = 2  
 J = 3  
 output  
 tput  
 option,  
 enthalpy



ided fuel cell computer program.



II

**Appendix A**

**PROGRAM LISTING FOR EXTENDED 40-kW FUEL CELL COMPUTER SIMULATION**

---

```

LIST
2 GO TO 10
4 GO TO 1950
10 INIT
11 SET KEY
88 PRINT "L***** FUEL CELL POWER SYSTEM *****"
89 D5=0
90 PRINT "JTHIS PROGRAM EVALUATES OPTIMUM RUNNING CONDITIONS OF AN"
91 PRINT "ENERGY SYSTEM (FUEL CELL PLANT, AUX BOILER, ELEC GRID)"
92 PRINT "SUPPLYING ELECTRICAL AND THERMAL ENERGY."
100 PRINT "JJJENTER INITIAL,FINAL TIME FOR ELEC/THERM LOAD REQUIREMENT"
110 PRINT "DATA."
120 PRINT "JEXAMPLE: 600,1700"
130 INPUT T4,T5
140 T6=(T5-T4)/100
150 IF T6<0 THEN 180
160 T6=25
170 GO TO 210
180 IF T6>0 THEN 200
190 T6=24+T6
200 T6=2*T6+1
210 DIM R1(T6),R2(T6),E(3,T6),F(3,T6),A(3,T6),Q(3,T6),T1(3,T6),T2(2,T6)
220 DIM G(3,T6),D(3,T6),S8(3,T6),B(3,T6),S(3,T6),X1(6),X2(6),X3(6)
230 DIM X4(6),X5(6),X6(6),U3(4),U4(4),U5(4),U6(4),U7(4),U8(4)
240 DIM F9(4),D1(4),D2(4),D3(4),D4(4),D9(4),T(3,T6),X(6),T7(T6)
250 DIM H2(3,T6),H3(3,T6),H4(T6),H5(3,T6),A5(3,T6),X9(6),U9(4),T3(3,T6)
260 DIM L5(4)
270 PRINT "ENTER SIZE OF FUEL CELL TO BE EVALUATED (UNITS: KW)"
280 INPUT F5
290 IF D5=0 THEN 990
300 PRINT "JJENTER LOCATION OF FUEL CELL PLANT THEN PRESS RETURN"
310 INPUT A5
320 PRINT "JJENTER DATE OF LOAD REQUIREMENT DATA"
330 INPUT D5
340 PRINT "JJENTER AVERAGE AMBIENT TEMPERATURE (DEG-F)"

```

```

350 INPUT T8
360 GO TO 380
370 PRINT "L"
380 PRINT "J" JENTER VOLUME OF THERMAL STORAGE (UNITS: GALLONS)"
390 INPUT U9
400 IF DS=7 THEN 850
410 PRINT "J" JENTER INITIAL TEMP OF THERMAL STORAGE (UNITS: DEG F)"
420 INPUT A3
430 T9=T8-70
440 PRINT "L" ENTER REQUIRED HOT WATER TEMPERATURE (UNITS: DEG F)"
450 INPUT A2
460 PRINT "J" JENTER SYSTEM FEEDWATER TEMPERATURE (UNITS: DEG F)"
470 INPUT A1
540 GO TO 560
550 T6=T6+1
560 PRINT "L" ENTER THERMAL LOAD REQUIREMENT DATA (NOTE: DATA ENTRIES"
570 PRINT " MUST BE FOR EVERY 1/2 HOUR)."
580 PRINT "J" JTIME HOT WATER REQ. I (GALLONS/HR)."
590 L=T4-70
600 K5=2
610 FOR K=1 TO T6
620 IF K5=2 THEN 660
630 L=L+30
640 K5=2
650 GO TO 700
660 L=L+70
670 K5=1
680 IF K=T6 THEN 720
700 PRINT L;"I";
710 INPUT R2(K)
720 T7(K)=L
730 NEXT K
740 R2(K-1)=R2(K-2)
750 GO TO 780
760 T6=T6-1

```

```

770 GO TO 850
780 PRINT "LENER ELECTRICAL LOAD REQUIREMENT DATA (NOTE:DATA ENTRIES"
790 PRINT "MUST BE FOR EVERY 1/2 HOUR)."
800 PRINT "JJTIMEKIELEC REQ_I (KW)_"
810 FOR K=1 TO T6
820 IF K=T6 THEN 850
830 PRINT T7(K);"I"
840 INPUT R1(K)
850 NEXT K
860 R1(K-1)=R1(K-2)
870 T6=T6-1
880 PRINT "JJPROGRAM IN PROGRESS"
890 H9=8.33*V9*(A2-A1)/1000
900 R9=F5/40
910 H1=8.33*V9*(A3-A1)/1000
920 J=1
930 FOR K=1 TO T6+1
940 REM ***** POWER PLANT @ RATED POWER (J=1) *****
950 E(J,K)=F5
960 F(J,K)=4.07*R9*EXP(0.0354*E(J,K)/R9)
970 A(J,K)=26.5*F(J,K)
980 Q(J,K)=0.24*A(J,K)*T9/1000
990 T1(J,K)=26.75*R9*EXP(0.029*E(J,K)/R9)
1000 T2(J,K)=0.5398*R9*(E(J,K)/R9-0.5*F5/R9)+1.493+0(J,K)
1010 T(J,K)=T1(J,K)+T2(J,K)
1015 C9=1(1,1)
1020 G(J,K)=R1(K)-E(J,K)
1030 REM FOLLOWING DETERMINES THERMAL STORAGE AND AUX HEATER
1040 REM INPUT/OUTPUTS
1050 IF K<>1 THEN 1090
1060 REM H2(J,K) IS A STORAGE TANK LEVEL WITH UNITS (KBTU)
1070 H2(J,K)=1/(1+0.5*R2(K)/V9)*(H1+T(J,K)/2)
1080 GO TO 1100
1090 H2(J,K)=1/(1+0.5*R2(K)/V9)*(H2(J,K-1)+T(J,K)/2)
1100 IF H2(J,K)<=H9 THEN 1200

```

```

1110 REM DETERMINE AMOUNT OF T(J,K) THAT ENTERS STORAGE - T3(J,K)
1120 H2(J,K)=H9
1130 IF K<>1 THEN 1160
1140 T3(J,K)=2*(H2(J,K)*(1+0.5*R2(K)/V9)-H1)
1150 GO TO 1170
1160 T3(J,K)=2*(H2(J,K)*(1+0.5*R2(K)/V9)-H2(J,K-1))
1170 D(J,K)=T(J,K)-T3(J,K)
1180 H3(J,K)=R2(K)*H2(J,K)/V9
1190 GO TO 1220
1200 H3(J,K)=R2(K)*H2(J,K)/V9
1210 D(J,K)=0
1220 H4(K)=8.33*R2(K)*(A2-A1)/1000
1230 H5(J,K)=H4(K)-H3(J,K)
1240 A5(J,K)=H2(J,K)*1000/(8.33*V9)+A1
1260 NEXT K
1270 IF J=2 THEN 1310
1280 REM ***** FUEL CELL PLANT ELECTRIC LOAD FOLLOWING (J=2) *****
1290 J=2
1300 FOR K=1 TO T6+1
1310 IF R1(K)>F5 THEN 1360
1320 REM OBTAIN ELECTRIC POWER FROM FUEL CELL OUTPUT ONLY
1330 E(J,K)=R1(K)
1340 G(J,K)=0
1350 GO TO 1390
1360 REM OBTAIN ELECTRIC POWER FROM FUEL CELL AND GRID
1370 E(J,K)=F5
1380 G(J,K)=R1(K)-F5
1390 REM DETERMINE FUEL CELL PLANT THERMAL OUTPUT
1400 F(J,K)=4.07*R9*EXP(0.0354*E(J,K)/R9)
1410 A(J,K)=26.5*F(J,K)
1420 Q(J,K)=0.24*A(J,K)*T9/1000
1430 T1(J,K)=26.75*R9*EXP(0.029*E(J,K)/R9)
1440 IF E(J,K)<0.5*F5 THEN 1470
1450 T2(J,K)=0.5398*R9*(E(J,K)/R9-0.5*F5/R9)+1.493+Q(J,K)
1460 GO TO 1480

```



```

1470 T2(J,K)=0
1480 T(J,K)=T1(J,K)+T2(J,K)
1490 REM DETERMINING THERMAL STORAGE AND AUXILIARY HEATER INPUT/OUTPUTS
1500 GO TO 1030
1510 REM ***** FOLLOW CUSTOMER THERMAL LOAD *****
1520 J=3
1530 FOR K=1 TO T6
1540 D(J,K)=0
1550 REM C9 IS MAXIMUM THERMAL OUTPUT OF FUEL CELL
1560 IF H4(K)>C9 THEN 1010
1570 T(J,K)=H4(K)
1580 H5(J,K)=0
1590 N=0
1600 REM PROGRAM USES NEWTON-RAPHSON ITERATION METHOD TO SOLVE
1610 REM FOR E(J,K) AT EACH VALUE OF T(J,K).
1620 N=N+1
1630 X(1)=0.5*F5+5
1640 X9(N)=0.5398*R9*(X(N)/R9-0.5*F5/R9)+1.493
1650 X3(N)=26.75*R9*EXP(0.029*X(N)/R9)+X9(N)
1660 X4(N)=0.026*T9*R9*EXP(0.0354*X(N)/R9)-T(J,K)
1670 REM X1(N)=T1(J,K)+T2(J,K)-T(J,K)=0
1680 X1(N)=X3(N)+X4(N)
1690 X5(N)=0.776*EXP(0.029*X(N)/R9)+0.806*(X(N)/R9-0.5*F5/R9)+0.493
1700 X6(N)=9.0E-4*T9*EXP(0.0354*X(N)/R9)
1710 REM X2(N)=THE DERIVATIVE OF T1(J,K)+T2(J,K)-T(J,K)=0
1720 X2(N)=X3(N)+X6(N)
1730 X(N+1)=X(N)-X1(N)/X2(N)
1750 IF X(2)<0.5*F5 THEN 1850
1760 IF X(N+1)>X(N)+0.05 THEN 1620
1770 IF X(N+1)<X(N)-0.05 THEN 1620
1790 E(J,K)=X(N+1)
1800 GO TO 1920
1810 E(J,K)=F5
1820 T(J,K)=C9
1830 H5(J,K)=H4(K)-T(J,K)

```

```

1840 GO TO 1920
1850 REM E<J,K> IS LESS THEN HALF FUEL CELL RATED OUTPUT
1860 REM THEREFORE T<J,K>=T1<J,K> AND TERMS T2<J,K> & Q<J,K> DROP OUT
1870 IF T<J,K>>26.85*R9 THEN 1910
1880 T<J,K>=26.85*R9
1890 E<J,K>=0
1900 GO TO 1920
1910 E<J,K>=R9*(LOG(T<J,K>)-LOG(R9))-3.29)/0.029
1920 G<J,K>=R1<K>-E<J,K>
1930 F<J,K>=4.07*R9*EXP(0.0354*E<J,K>/R9)
1940 NEXT K
1950 PRINT "L***** MENU *****"
1960 PRI "JJLIST FUEL CELL ENERGY SYSTEM INPUT/OUTPUT (SELECT 1,2,OR3)"
1970 PRINT "J1-RATED POWER"
1980 PRINT "J2-ELECTRICAL LOAD FOLLOWING"
1990 PRINT "J3-THERMAL LOAD FOLLOWING"
2000 PRINT "J4-ECONOMIC EVALUATION"
2010 PRINT "J5-LIST CURRENT USER INPUTS"
2020 PRINT "J6-ENTER NEW LOAD REQUIREMENT DATA SET"
2030 PRINT "J7-CHANGE VOLUME OF THERMAL STORAGE"
2040 PRINT "J8-CHANGE SIZE OF FUEL CELL"
2050 PRINT "J9-RUN NEW PROGRAM"
2060 PRINT "JJJSELECT NUMBER THEN PRESS RETURN."
2070 INPUT T$
2080 D5=VAL(T$)
2090 IF D5=4 THEN 2620
2100 IF D5=5 THEN 2230
2110 IF D5=6 THEN 550
2120 IF D5=7 THEN 370
2130 IF D5=8 THEN 270
2140 IF D5=9 THEN 2
2150 GOSUB D5 OF 2170,2190,2210
2160 GO TO 2330
2170 F$="RATED POWER"
2180 RETURN

```

```

2190 F$="ELECTRICAL LOAD FOLLOWING"
2200 RETURN
2210 F$="THERMAL LOAD FOLLOWING"
2220 RETURN
2230 PRINT "LFUEL CELL SIZE ="
2240 PRINT "JAMBIENT TEMPERATURE ="
2250 PRINT "JTHERMAL STORAGE VOLUME ="
2260 PRINT "JSTORAGE INITIAL TEMP ="
2270 PRINT "JREQUIRED HOT WATER TEMP ="
2280 PRINT "JSYSTEM FEEDWATER TEMP ="
2290 PRINT "JJJJJJJJJJPRESS RETURN FOR MENU"
2300 INPUT P$
2310 GO TO 1950
2320 F5=120
2330 PRINT "L
2340 PRINT "JDATE:
2350 PRINT "JLOCATION:
2360 PRINT "F/C LOAD:
2370 PRINT "AVG TEMP:
2380 PRINT "J
2390 IMAGE L,9X,10A,10X,10A,12X,14A
2400 IMAGE "TIME",4X,16A,6X,11A,14X,9A
2410 IMA L,8X,"ELEC",4X,"THERM",7X,"F/C",6X,"GRID",7X,"F/C",5X,6A,3X,7A
2420 G$="ENERGY REQ"
2430 H$="ELECTRICAL"
2440 I$="THERMAL OUTPUT"
2450 P$="STORAGE"
2460 J$="(KW) (KBTU/HR)"
2470 K$="OUTPUT (KW)"
2480 L$="(KBTU/HR)"
2490 M$="BOILER"
2500 N$="LEVEL"
2510 PRINT USING 2390:G$,H$,I$
2520 PRINT USING 2400:J$,K$,L$
2530 PRINT USING 2410:M$,P$

```

```

"IF5!" "KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT"
"IB$"
"IA$"
"IF$"
"IT9!" (DEG-F)"

```

```

"IF5!" (KW)"
"IT9!" (DEG F)"
"IV9!" (GALLONS)"
"IA3!" (DEG F)"
"IA2!" (DEG F)"
"IA1!" (DEG F)"

```

```

2540 PRINT " "
2550 IMAGE 4D, 6D, 2D, 6D, 2D, 8D, 2D, 6D, 2D, 8D, 2D, 6D, 2D, 6D, 2D, 6D, 2D
2560 IMAGE 4D, 6D, 2D, 6D, 2D, 8D, 2D, 6D, 2D, 8D, 2D, 6D, 2D, 6X, "-"
2570 IMAGE "TOTAL", 5D, 2D, 6D, 2D, 8D, 2D, 6D, 2D, 8D, 2D, 6D, 2D, 6D, 2D, 6D, 2D
2580 X$="(KBTU)"
2590 IMAGE 6X, "(KH-HR)", 2X, 9A, 7X, "(KH-HR)", 18X, 9A
2600 REM INITIALIZE TOTAL ENERGY INPUT/OUTPUT VARIABLES
2610 IF D5<>5 THEN 2640
2620 FOR J=1 TO 3
2630 GO TO 2650
2640 J=D5
2650 U1=0
2660 U2=0
2670 U3<J>=0
2680 U4<J>=0
2690 U5<J>=0
2700 U6<J>=0
2710 U7<J>=0
2720 U8<J>=0
2730 U9<J>=0
2740 FOR K=1 TO T6
2750 IF D5=4 THEN 2810
2760 IF D5<>3 THEN 2800
2770 PRINT USING 2560: T7<K>, R1<K>, H4<K>, E<J, K>, G<J, K>, T<J, K>, H5<J, K>
2780 H3<J, K>=0
2790 GO TO 2810
2800 PRI USI 2550: T7<K>, R1<K>, H4<K>, E<J, K>, G<J, K>, T<J, K>, H5<J, K>, H3<J, K>
2810 U1=U1+R1<K>/2
2820 U2=U2+H4<K>/2
2830 U3<J>=U3<J>+E<J, K>/2
2840 IF G<J, K><0 THEN 2870
2850 U4<J>=U4<J>+G<J, K>/2
2860 GO TO 2880
2870 U5<J>=U5<J>-G<J, K>/2
2880 U6<J>=U6<J>+T<J, K>/2

```

```

2890 U7<J>=U7<J>+H5<J,K>/2
2900 U8<J>=U8<J>+D<J,K>/2
2910 IF J=3 THEN 2930
2920 U9<J>=U9<J>+H3<J,K>/2
2930 NEXT K
2940 IF D5=4 THEN 3000
2950 PRINT USING "J1T6/21"-HR"
2960 PRINT USING 2570:U1,U2,U3<J>,U4<J>-U5<J>,U6<J>,U7<J>,U9<J>
2970 PRINT USING 2590:X$,X$
2980 PRINT "JJJJJJJJJJJJJJJJJJJJJJJJJJJJJJ"
2990 PRINT USING 3040:U4<J>
3000 PRINT USING 3050:U5<J>
3010 PRINT "JJTHERMAL ENERGY"
3020 PRINT USING 3060:U8<J>
3030 IMAGE "FINAL =",11X,3D.2D," (KBTU)"
3040 IMAGE P,"ENERGY PURCHASED",,"FROM GRID =",7X,4D.2D," (KW-HR)"
3050 IMAGE L,"ENERGY SOLD",,"TO GRID =",8X,4D.2D," (KW-HR)"
3060 IMAGE "DUMPED =",8X,4D.2D," (KBTU)"
3070 IMAGE 2L,"TOTAL FUEL USED =",1X,3D.2D," (#'S METHANE)"
3080 F9<J>=F<J,1>/2
3090 FOR K=2 TO T6
3100 F9<J>=F9<J>+F<J,K>/2
3110 NEXT K
3120 IF D5<>4 THEN 3150
3130 NEXT J
3140 GO TO 3580
3150 PRINT USING 3070:F9<J>
3160 PRINT "JJJJJPRESS RETURN FOR MENU."
3170 INPUT P$
3180 IF D5=3 THEN 1950
3190 PRINT "WOULD YOU LIKE PRINT OUT OF THERMAL STORAGE SIZING"
3200 PRINT "ROUTINE (Y OR N?)"
3210 INPUT P$
3220 IF P$="N" THEN 1950
3230 REM START THERMAL STORAGE SIZING PRINTOUT ROUTINE

```

```

3240 PRINT "L
3250 PRINT "JF$
3260 IMAGE 3L,8X,"THERMAL",5X,"FUEL CELL THERMAL",9X,"THERMAL STORAGE"
3270 IMAGE L,8X,"LOAD",9X,"AVAIL",5X,"DUMPED",8X,"OUTPUT",6X,"LEVEL"
3280 G$="(KBTU/HR)"
3290 H$="(KBTU)"
3300 IMAGE 6X,9A,9X,9A,10X,9A,4X,6A
3310 IMAGE 4D,6D,2D,10D,2D,7D,2D,13D,2D,8D,2D
3320 IMAGE 4D,6X,"-",12X,"-",9X,"-",15X,"-",10D,2D
3330 IMAGE "TOTAL",5D,2D,10D,2D,7D,2D,13D,2D,8D,2D
3340 PRINT USING 3260:
3350 PRINT USING 3270:
3360 PRINT "KTIME"
3370 PRINT USING 3300:G$,G$,G$,H$
3380 PRINT
3390 FOR K=1 TO T6
3400 IF K<>1 THEN 3430
3410 PRINT USING 3310:T7(K),H4(K),T(J,K),D(J,K),H3(J,K),H1
3420 GO TO 3440
3430 PRINT USING 3310:T7(K),H4(K),T(J,K),H3(J,K),H2(J,K-1)
3440 NEXT K
3450 PRINT USING 3320:T7(K),H2(J,K-1)
3460 PRINT "J";T6/2;"-HR"
3470 L5(J)=H2(J,K)-H1
3480 PRINT USING 3330:U2,U6(J),U8(J),U9(J),L5(J)
3490 IMAGE 7X,"(KBTU)",7X,"(KBTU)",4X,"(KBTU)",10X,"(KBTU)",6X,"(KBTU)"
3500 PRINT USING 3490:
3510 IMAGE 57X,"(CHANGE)"
3520 PRINT USING 3510:
3530 PRINT "JJJ THERMAL STORAGE MAX CAP = "JH9;"(KBTU)"
3540 PRINT "JJJ FINAL STORAGE TEMP = "JA1+120#H2(J,K-1)/V9;"(DEG-F)"
3550 PRINT "JJJJJ PRESS RETURN FOR MENU"
3560 INPUT P$
3570 GO TO 1950
3580 REM ***** ECONOMICS *****

```

3590 PRINT "LIS ENERGY/FUEL COST INFORMATION ENTERED PREVIOUSLY CORRECT"  
 3600 PRINT "FOR CURRENT LOAD REQUIREMENT DATA SET? (Y OR N)?"  
 3610 INPUT P\$  
 3620 IF P\$="Y" THEN 3730  
 3630 REM METHANE LHV=1031 (BTU/SCF)  
 3640 PRINT "ENTER DOLLAR VALUES FOR ENERGY/FUEL COSTS IN"  
 3650 PRINT "FOLLOWING ORDER:"  
 3660 PRINT ""  
 3670 PRI "J1). FUEL CELL FUEL (\$/MBTU-CH4)I(METHANE LHV=1031 (BTU/SCF))"  
 3680 PRINT "2). BOILER THERM ENERGY (\$/MBTU)"  
 3690 PRINT "3). ELEC PURCHASED (\$/KW-HR)"  
 3700 PRINT "4). ELEC SOLD (\$/KW-HR)"  
 3710 PRINT "EXAMPLE: 4.25,8.26,.054,.045"  
 3720 INPUT F4,B4,G4,G5  
 3730 REM DETERMINE ENERGY CONSUMPTION COSTS  
 3740 FOR J=1 TO 3  
 3750 REM TOTAL COST OF FUEL CELL FUEL "D1(J)" FOR SELECTED TIME PERIOD  
 3760 D1(J)=F4#F9(J)#0.023  
 3770 REM TOTAL COST OF BOILER HEAT "D2(J)"  
 3780 D2(J)=B4#U7(J)#1.0E-3  
 3790 REM TOTAL COST OF ELEC PURCHASED FROM GRID "D3(J)"  
 3800 D3(J)=G4#U4(J)  
 3810 D4(J)=G5#U5(J)  
 3820 REM TOTAL COST "D9(J) OF SPECIFIC LOAD FOLLOWING SCHEME "J"  
 3830 D9(J)=D1(J)+D2(J)+D3(J)-D4(J)  
 3840 NEXT J  
 3850 REM FUEL CELL OUTPUT = 0  
 3860 D1(4)=0  
 3870 D2(4)=B4#U2#1.0E-3  
 3880 D3(4)=G4#U1  
 3890 D4(4)=0  
 3900 D9(4)=D2(4)+D3(4)  
 3910 IMAGE 2L,"FUEL CELL",16X,"ELEC",8X,"ELEC"  
 3920 U\$="BOILER"  
 3930 H\$="TOTAL COST"

```

3940 IMAGE" OUTPUT      ",3X,"F/C",8X,"PURCHASED",3X,"SOLD",8X,6A,6X,10A
3950 IMAGE 14X,"($)",9X,"($)",9X,"($)",9X,"($)",11X,"($)"
3960 IMAGE L,"RATED",10D.2D,9D.2D,9D.2D,9D.2D,11D.2D
3970 IMAGE L,"ELEC LOAD",6D.2D,9D.2D,9D.2D,9D.2D,11D.2D
3980 IMAGE L,"THERM LOAD",5D.2D,9D.2D,9D.2D,9D.2D,11D.2D
3990 IMAGE L,"F/C=0",10D.2D,9D.2D,9D.2D,9D.2D,11D.2D
4000 PRINT "LDATE:      ";18$
4010 PRINT "TIME:       ";14;"--"1T5
4020 PRINT "LOCATION:    ";1A$
4030 PRINT "AVG TEMP:   ";1T8;" (DEG-F)"
4040 PRINT "JJ        ";1F5;"KW FUEL CELL SYSTEM ENERGY CONSUMPTION COSTS"
4050 PRINT USING 3910:
4060 PRINT USING 3940:V$,M$
4070 PRINT USING 3950:
4080 PRINT USING 3960:D1(1),D3(1),D4(1),D2(1),D9(1)
4090 PRINT USING 3970:D1(2),D3(2),D4(2),D2(2),D9(2)
4100 PRINT USING 3980:D1(3),D3(3),D4(3),D2(3),D9(3)
4110 PRINT USING 3990:D1(4),D3(4),D4(4),D2(4),D9(4)
4120 PRINT "JJJJPRESS RETURN FOR MENU."
4130 INPUT P$
4140 GO TO 1950

```



Appendix B

PROGRAM PRINTOUTS OF EXTENDED 40-kW FUEL CELL COMPUTER SIMULATION

PREVIOUS PAGE  
IS BLANK

The following are the conditions for the computer printouts Tables B-1 through B-4.

FUEL CELL SIZE = 150 (KW)  
AMBIENT TEMPERATURE = 65 (DEG F)  
THERMAL STORAGE VOLUME = 3000 (GALLONS)  
STORAGE INITIAL TEMP = 80 (DEG F)  
REQUIRED HOT WATER TEMP = 130 (DEG F)  
SYSTEM FEEDWATER TEMP = 55 (DEG F)

Tables B-5 through B-8.

PRESS RETURN FOR MENU

Table B-1. Printout based on fuel cell load: rated power.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: RATED POWER  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KWH)		ELECTRICAL OUTPUT (KW)		THERMAL OUTPUT (KBTU/HR)		
	ELEC	THERM	F/C	GRID	F/C	BUILER STORAGE	
0	125.00	156.19	150.00	-25.00	495.29	86.40	69.79
30	125.00	140.57	150.00	-25.00	495.29	62.12	78.44
100	115.00	124.95	150.00	-35.00	495.29	41.49	83.46
130	115.00	93.71	150.00	-35.00	495.29	20.57	73.15
200	110.00	62.47	150.00	-40.00	495.29	6.39	56.08
230	110.00	62.47	150.00	-40.00	495.29	0.00	62.47
300	120.00	31.24	150.00	-30.00	495.29	0.00	31.24
330	115.00	31.24	150.00	-35.00	495.29	0.00	31.24
400	115.00	93.71	150.00	-35.00	495.29	0.00	93.71
430	138.00	124.95	150.00	-12.00	495.29	0.00	124.95
500	135.00	499.80	150.00	-15.00	495.29	0.53	499.27
530	150.00	937.12	150.00	0.00	495.29	89.16	847.96
600	150.00	1062.08	150.00	0.00	495.29	203.88	858.20
630	160.00	1436.93	150.00	10.00	495.29	460.33	976.59
700	150.00	1749.30	150.00	0.00	495.29	781.10	968.20
730	150.00	1999.20	150.00	0.00	495.29	1105.29	893.91
8-HR TOTAL	1041.50 (KW-HR)	4302.97 (KBTU)	1200.00	-158.50 (KW-HR)	3962.30	1428.63 (KBTU)	2874.33

Table B-1. Continued.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: RATED POWER  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KW)		THERM (KBTU/HR)	ELECTRICAL OUTPUT (KW)		F/C	THERMAL OUTPUT (KBTU/HR)		
	ELEC			F/C	GRID		BOILER	STORAGE	
800	165.00		1874.25	150.00	15.00	495.29		1159.37	714.88
830	160.00		1749.30	150.00	10.00	495.29		1136.79	612.51
900	155.00		1436.93	150.00	5.00	495.29		935.96	500.96
930	160.00		1062.08	150.00	10.00	495.29		664.20	397.88
1000	145.00		749.70	150.00	-5.00	495.29		433.11	316.59
1030	150.00		624.75	150.00	0.00	495.29		327.86	296.89
1100	195.00		624.75	150.00	45.00	495.29		299.52	325.23
1130	180.00		812.17	150.00	30.00	495.29		376.46	435.71
1200	170.00		1662.08	150.00	20.00	495.29		508.74	553.33
1230	150.00		874.65	150.00	0.00	495.29		411.47	463.18
1300	150.00		687.22	150.00	0.00	495.29		302.95	384.28
1330	150.00		624.75	150.00	0.00	495.29		254.56	370.19
1400	150.00		562.27	150.00	0.00	495.29		207.96	354.32
1430	160.00		499.80	150.00	10.00	495.29		163.63	336.17
1500	160.00		468.56	150.00	10.00	495.29		133.39	335.17
1530	150.00		468.56	150.00	0.00	495.29		115.60	352.96
8-HR TOTAL	1275.00 (KH-HR)		7090.91 (KBTU)	1200.00 (KH-HR)	75.00	3962.30		3715.79 (KBTU)	3375.13

Table B-1. Continued.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEHELL'S POINT NAS  
 F/C LOAD: RATED POWER  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KBTU/HR)		ELECTRICAL OUTPUT (KW)		F/C	THERMAL OUTPUT (KBTU/HR)		
	ELEC (KW)	THERM	F/C	GRID		F/C	BOILER	STORAGE
1600	185.00	812.17	150.00	35.00	495.29	225.54	586.63	
1630	180.00	999.60	150.00	30.00	495.29	325.32	674.28	
1700	170.00	1374.45	150.00	20.00	495.29	563.18	811.27	
1730	170.00	1749.30	150.00	20.00	495.29	887.71	861.59	
1800	160.00	1499.40	150.00	10.00	495.29	830.39	669.91	
1830	155.00	1249.50	150.00	5.00	495.29	707.54	541.96	
1900	155.00	874.65	150.00	5.00	495.29	473.35	401.30	
1930	150.00	749.70	150.00	0.00	495.29	380.51	369.19	
2000	150.00	687.22	150.00	0.00	495.29	324.50	362.73	
2030	150.00	499.80	150.00	0.00	495.29	208.76	291.04	
2100	135.00	312.38	150.00	-15.00	495.29	106.37	206.00	
2130	130.00	249.90	150.00	-20.00	495.29	64.44	185.46	
2200	130.00	249.90	150.00	-20.00	495.29	45.08	204.82	
2230	125.00	218.66	150.00	-25.00	495.29	22.02	196.64	
2300	120.00	218.66	150.00	-30.00	495.29	5.56	213.10	
2330	118.00	187.43	150.00	-32.00	495.29	0.00	187.43	
8-HR TOTAL	1191.50 (KW-HR)	5966.36 (KBTU)	1200.00 (KW-HR)	-9.50 (KW-HR)	3962.30	2585.14 (KBTU)	3381.22	

Table B-2. Printout based on fuel cell load: electrical load following.

**150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT**

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: ELECTRICAL LOAD FOLLOWING  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KW)		ELECTRICAL OUTPUT (KW)		THERMAL OUTPUT (KBTU/HR)		
	ELEC	THERM	F/C	GRID	F/C	BOILER	STORAGE
0	125.00	156.19	125.00	0.00	358.94	91.85	64.34
30	125.00	140.57	125.00	0.00	358.94	71.78	68.78
100	115.00	124.95	115.00	0.00	312.03	55.71	69.24
130	115.00	93.71	115.00	0.00	312.03	35.44	58.27
200	110.00	62.47	110.00	0.00	290.31	19.51	42.97
230	110.00	62.47	110.00	0.00	290.31	15.45	47.02
300	120.00	31.24	120.00	0.00	334.92	5.15	26.09
330	115.00	31.24	115.00	0.00	312.03	2.79	28.45
400	115.00	93.71	115.00	0.00	312.03	2.84	90.88
430	138.00	124.95	138.00	0.00	426.51	0.00	124.95
500	135.00	499.80	135.00	0.00	410.27	10.53	489.27
530	150.00	937.12	150.00	0.00	495.29	104.17	832.96
600	150.60	1062.00	150.00	0.00	495.29	217.13	844.95
630	160.00	1436.93	150.00	10.00	495.29	473.29	963.63
700	150.00	1749.30	150.00	0.00	495.29	791.86	957.44
730	150.00	1999.20	150.00	0.00	495.29	1113.30	885.90
8-HR TOTAL	1041.50 (KW-HR)	4302.97 (KBTU)	1036.50 (KW-HR)	5.00	3097.30	1505.40 (KBTU)	2797.57

Table B-2. Continued.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: ELECTRICAL LOAD FOLLOWING  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KBTU/HR)		ELECTRICAL OUTPUT (KW)		THERMAL OUTPUT (KBTU/HR)		
	ELEC (KW)	THERM	F/C	GRID	F/C	BOILER	STORAGE
800	165.00	1874.25	150.00	15.00	495.29	1159.37	714.88
830	160.00	1749.30	150.00	10.00	495.29	1136.79	612.51
900	155.00	1436.93	150.00	5.00	495.29	935.96	500.96
930	160.00	1062.08	150.00	10.00	495.29	664.20	397.88
1000	145.00	749.70	145.00	0.00	465.89	438.01	311.69
1030	150.00	624.75	150.00	0.00	495.29	331.36	293.39
1100	195.00	624.75	150.00	45.00	495.29	302.52	322.23
1130	180.00	812.17	150.00	30.00	495.29	379.67	432.51
1200	170.00	1062.08	150.00	20.00	495.29	512.01	550.07
1230	150.00	874.65	150.00	0.00	495.29	413.65	461.00
1300	150.00	607.22	150.00	0.00	495.29	304.40	382.83
1330	150.00	624.75	150.00	0.00	495.29	255.69	369.06
1400	150.00	562.27	150.00	0.00	495.29	208.84	353.44
1430	160.00	499.80	150.00	10.00	495.29	164.33	335.47
1500	160.00	468.56	150.00	10.00	495.29	133.97	334.59
1530	150.00	468.56	150.00	0.00	495.29	116.11	352.45
8-HR TOTAL	1275.00 (KW-HR)	7090.91 (KBTU)	1197.50 (KW-HR)	77.50 (KW-HR)	3947.60	3728.43 (KBTU)	3362.48

Table B-2. Continued.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: ELECTRICAL LOAD FOLLOWING  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ		ELECTRICAL		THERMAL OUTPUT		
	ELEC (KW)	THERM (KBTU/HR)	F/C OUTPUT (KW)	GRID	F/C	BOILER (KBTU/HR)	STORAGE
1600	185.00	812.17	150.00	35.00	495.29	225.54	586.63
1630	180.00	999.60	150.00	30.00	495.29	325.32	674.28
1700	170.00	1374.45	150.00	20.00	495.29	563.18	811.27
1730	170.00	1749.30	150.00	20.00	495.29	887.71	861.59
1800	160.00	1499.40	150.00	10.00	495.29	830.39	669.01
1830	155.00	1249.50	150.00	5.00	495.29	707.54	541.96
1900	155.00	874.65	150.00	5.00	495.29	473.35	401.30
1930	150.00	749.70	150.00	0.00	495.29	380.51	369.19
2000	150.00	687.22	150.00	0.00	495.29	324.50	362.73
2030	150.00	499.80	150.00	0.00	495.29	208.76	291.04
2100	135.00	312.38	135.00	0.00	410.27	112.91	199.46
2130	130.00	249.90	130.00	0.00	384.06	176.30	173.60
2200	130.00	249.90	130.00	0.00	384.06	63.14	186.76
2230	125.00	218.66	125.00	0.00	358.94	44.47	174.19
2300	120.00	218.66	120.00	0.00	334.92	35.61	183.05
2330	118.00	187.43	118.00	0.00	325.63	22.49	164.93
8-HR TOTAL	1191.50 (KW-HR)	5966.36 (KBTU)	1129.00 (KW-HR)	62.50	3575.38	2640.87 (KBTU)	3325.49



Table B-3. Printout based on fuel cell load: thermal load following.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: THERMAL LOAD FOLLOWING  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KW)		ELECTRICAL OUTPUT (KW)		THERMAL OUTPUT (KBTU/HR)		
	ELEC	THERM	F/C	GRID	F/C	BOILER STORAGE	
0	125.00	156.19	56.81	68.19	156.19	0.00	
30	125.00	148.57	43.18	81.82	140.57	0.00	
100	115.00	124.95	27.95	87.95	124.95	0.00	
130	115.00	93.71	0.00	115.00	100.69	0.00	
200	110.00	62.47	0.00	110.00	100.69	0.00	
230	110.00	62.47	0.00	110.00	100.69	0.00	
300	120.00	31.24	0.00	120.00	100.69	0.00	
330	115.00	31.24	0.00	115.00	100.69	0.00	
400	115.00	93.71	0.00	115.00	100.69	0.00	
430	138.00	124.95	27.95	110.05	124.95	0.00	
500	135.00	499.80	150.00	-15.00	495.29	0.00	
530	150.00	937.12	150.00	0.00	495.29	4.51	
600	150.00	1062.88	150.00	0.00	495.29	441.84	
630	160.00	1436.93	150.00	10.00	495.29	566.79	
700	150.00	1749.30	150.00	0.00	495.29	941.64	
730	150.00	1999.20	150.00	0.00	495.29	1254.01	
8-HR TOTAL	1041.50 (KW-HR)	4302.97 (KBTU)	527.95 (KW-HR)	513.55 (KW-HR)	2061.25	2356.35 (KBTU)	0.00

Table B-3. Continued.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: THERMAL LOAD FOLLOWING  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KBTU/HR)		ELECTRICAL OUTPUT (KW)		THERMAL OUTPUT (KBTU/HR)		
	ELEC (KW)	THERM	F/C	GRID	F/C	BOILER	STORAGE
800	165.00	1874.25	150.00	15.00	495.29	1378.96	-
830	160.00	1749.30	150.00	10.00	495.29	1254.01	-
900	155.00	1436.93	150.00	5.00	495.29	941.64	-
930	160.00	1062.08	150.00	10.00	495.29	566.79	-
1000	145.00	749.70	150.00	-5.00	495.29	254.41	-
1030	150.00	624.75	150.00	0.00	495.29	129.46	-
1100	195.00	624.75	150.00	45.00	495.29	129.46	-
1130	180.00	812.17	150.00	30.00	495.29	316.89	-
1200	170.00	1062.08	150.00	20.00	495.29	566.79	-
1230	150.00	874.65	150.00	0.00	495.29	379.36	-
1300	150.00	687.22	150.00	0.00	495.29	191.94	-
1330	150.00	624.75	150.00	0.00	495.29	129.46	-
1400	150.00	562.27	150.00	0.00	495.29	66.99	-
1430	160.00	499.80	150.00	10.00	495.29	4.51	-
1500	160.00	468.56	145.46	14.54	468.56	0.00	-
1530	150.00	468.56	145.46	4.54	468.56	0.00	-
8-HR TOTAL	1275.00 (KW-HR)	7090.91 (KBTU)	1195.46 (KW-HR)	79.54 (KW-HR)	3935.57	3155.34 (KBTU)	0.00

Table B-3. Continued.

150KW FUEL CELL ENERGY SYSTEM INPUT/OUTPUT

DATE: 27MAR80  
 LOCATION: SEWELL'S POINT NAS  
 F/C LOAD: THERMAL LOAD FOLLOWING  
 AVG TEMP: 65 (DEG-F)

TIME	ENERGY REQ (KW)		THERM (KBTU/HR)	ELECTRICAL OUTPUT (KW)		THERMAL OUTPUT (KBTU/HR)		
	ELEC	F/C		F/C	GRID	F/C	BOILER	STORAGE
1600	185.00	150.00	812.17	150.00	35.00	495.29	316.89	-
1630	180.00	150.00	999.60	150.00	30.00	495.29	504.31	-
1700	170.00	150.00	1374.45	150.00	20.00	495.29	879.16	-
1730	170.00	150.00	1749.30	150.00	20.00	495.29	1254.01	-
1800	160.00	150.00	1499.40	150.00	10.00	495.29	1004.11	-
1830	155.00	150.00	1249.50	150.00	5.00	495.29	754.21	-
1900	155.00	150.00	874.65	150.00	5.00	495.29	379.36	-
1930	150.00	150.00	749.70	150.00	0.00	495.29	254.41	-
2000	150.00	150.00	687.22	150.00	0.00	495.29	191.94	-
2030	150.00	150.00	499.80	150.00	0.00	495.29	4.51	-
2100	135.00	115.00	312.38	115.00	19.92	312.38	0.00	-
2130	130.00	99.84	249.90	99.84	30.16	249.90	0.00	-
2200	130.00	99.84	249.90	99.84	30.16	249.90	0.00	-
2230	125.00	90.81	218.66	90.81	34.19	218.66	0.00	-
2300	120.00	90.81	218.66	90.81	29.19	218.66	0.00	-
2330	118.00	79.63	187.43	79.63	38.37	187.43	0.00	-
8-HR TOTAL	1191.50 (KW-HR)	1038.00 (KW-HR)	5966.36 (KBTU)	1038.00 (KW-HR)	153.50 (KW-HR)	3194.90	2771.46 (KBTU)	0.00

Table B-6. Intout for Navy-wide 3,000-gallon thermal storage.

**THERMAL SYSTEM INPUT/OUTPUT  
ELECTRICAL LOAD FOLLOWING**

TIME	THERMAL LOAD (KBTU/HR)	FUEL CELL THERMAL AVAIL (KBTU/HR)	THERMAL DUMPED (KBTU/HR)	THERMAL STORAGE OUTPUT (KBTU/HR)	THERMAL STORAGE LEVEL (KBTU)
0	156.19	358.94	0.00	64.34	624.75
30	140.57	358.94	0.00	68.78	772.05
100	124.95	312.03	0.00	69.24	917.13
130	93.71	312.03	0.00	58.27	1038.53
200	62.47	290.31	0.00	42.97	1165.41
230	62.47	290.31	0.00	47.02	1289.08
300	31.24	334.92	0.00	26.09	1410.72
330	31.24	312.03	0.00	28.45	1565.14
400	93.71	312.03	0.00	90.88	1786.93
430	124.95	426.51	188.08	124.95	1817.51
500	499.80	410.27	0.00	489.27	1874.25
530	937.12	495.29	0.00	832.96	1834.75
600	1062.08	495.29	0.00	844.95	1665.92
630	1436.93	495.29	0.00	963.63	1491.09
700	1749.30	495.29	0.00	957.44	1256.91
730	1999.20	495.29	0.00	885.90	1025.83
800	-	-	-	-	830.53
8-HR TOTAL	4302.97 (KBTU)	3097.38 (KBTU)	94.04 (KBTU)	2797.57 (KBTU)	78.41 (KBTU) (CHANGE)

Table B-4. Continued.

THERMAL SYSTEM INPUT/OUTPUT  
ELECTRICAL LOAD FOLLOWING

TIME	THERMAL LOAD (KBTU/HR)	FUEL CELL THERMAL AVAIL (KBTU/HR)	DUMPED (KBTU/HR)	THERMAL STORAGE OUTPUT (KBTU/HR)	LEVEL (KBTU)
800	1874.25	495.29	0.00	714.88	824.67
830	1749.30	495.29	0.00	612.51	714.88
900	1436.93	495.29	0.00	500.96	656.26
930	1062.08	495.29	0.00	397.88	653.43
1000	749.79	465.89	0.00	311.69	702.13
1030	624.75	495.29	0.00	293.39	779.23
1100	624.75	495.29	0.00	322.23	800.18
1130	812.17	495.29	0.00	432.51	966.70
1200	1062.08	495.29	0.00	550.07	998.09
1230	874.65	495.29	0.00	461.00	970.71
1300	687.22	495.29	0.00	382.83	987.85
1330	624.75	495.29	0.00	369.66	1044.08
1400	562.27	495.29	0.00	353.44	1107.19
1430	499.80	495.29	0.00	335.47	1178.12
1500	468.56	495.29	0.00	334.59	1258.02
1530	468.56	495.29	0.00	352.45	1338.37
1600	-	-	-	-	1409.79
8-HR TOTAL	7090.91 (KBTU)	3947.60 (KBTU)	0.00 (KBTU)	3362.48 (KBTU)	648.61 (KBTU) (CHANGE)

Table B-4. Continued.

THERMAL SYSTEM INPUT/OUTPUT		ELECTRICAL LOAD FOLLOWING		THERMAL STORAGE	
TIME	THERMAL LOAD (KBTU/HR)	FUEL CELL THERMAL AVAIL (KBTU/HR)	THERMAL DUMPED (KBTU/HR)	THERMAL OUTPUT (KBTU/HR)	THERMAL STORAGE LEVEL (KBTU)
1600	812.17	495.29	0.00	586.63	1399.44
1630	999.60	495.29	0.00	674.28	1353.77
1700	1374.45	495.29	0.00	811.27	1264.27
1730	1749.30	495.29	0.00	861.59	1106.28
1800	1499.40	495.29	0.00	669.01	923.13
1830	1249.50	495.29	0.00	541.96	836.27
1900	874.65	495.29	0.00	401.30	812.93
1930	749.70	495.29	0.00	369.19	859.93
2000	687.22	495.29	0.00	362.73	922.98
2030	499.80	495.29	0.00	291.04	989.26
2100	312.38	410.27	0.00	199.46	1091.38
2130	249.90	384.06	0.00	173.60	1196.78
2200	249.90	384.06	0.00	186.76	1302.01
2230	218.66	358.94	0.00	174.19	1400.67
2300	218.66	334.92	0.00	183.05	1493.04
2330	187.43	325.63	0.00	164.93	1568.98
2400	-	-	-	-	1649.33
8-HR TOTAL	5966.36 (KBTU)	3575.38 (KBTU)	0.00 (KBTU)	3325.49 (KBTU)	326.41 (KBTU) (CHANGE)

Table B-5. P-intout for Navy-wide 500-gallon thermal storage.

THERMAL SYSTEM INPUT/OUTPUT						
ELECTRICAL LOAD FOLLOWING						
TIME	THERMAL LOAD (KBTU/HR)	FUEL CELL THERMAL AVAIL (KBTU/HR)	THERMAL DUMPED (KBTU/HR)	THERMAL OUTPUT (KBTU/HR)	THERMAL STORAGE LEVEL (KBTU)	
0	156.19	358.94	0.00	113.44	104.13	
30	140.57	358.94	47.38	140.57	226.08	
100	124.95	312.03	187.68	124.95	312.38	
130	93.71	312.03	218.32	93.71	312.38	
200	62.47	290.31	227.83	62.47	312.38	
230	62.47	290.31	227.83	62.47	312.38	
300	31.24	334.92	303.69	31.24	312.38	
330	31.24	312.03	280.80	31.24	312.38	
400	93.71	312.03	218.32	93.71	312.38	
430	124.95	426.51	301.56	124.95	312.38	
500	499.80	410.27	0.00	460.01	312.38	
530	537.12	495.29	0.00	642.18	287.51	
600	1062.08	495.29	0.00	581.40	214.06	
630	1436.93	495.29	0.00	583.57	171.00	
700	1749.30	495.29	0.00	551.90	126.86	
730	1999.20	495.29	0.00	527.54	98.55	
800	-	-	-	-	82.43	
8-HR TOTAL	4302.97 (KBTU)	3097.38 (KBTU)	1006.40 (KBTU)	2112.68 (KBTU)	-25.54 (KBTU)	(CHANGE)

Table B-5. Continued.

THERMAL SYSTEM INPUT/OUTPUT						
ELECTRICAL LOAD FOLLOWING						
TIME	THERMAL LOAD (KBTU/HR)	FUEL CELL THERMAL AVAIL (KBTU/HR)	DUMPED (KBTU/HR)	THERMAL STORAGE OUTPUT (KBTU/HR)	LEVEL (KBTU)	
800	1874.25	495.29	0.00	577.63	137.45	
830	1749.30	495.29	0.00	506.02	96.27	
900	1436.93	495.29	0.00	471.36	90.50	
930	1062.08	495.29	0.00	440.88	102.47	
1000	749.70	465.89	0.00	395.58	129.67	
1030	624.75	495.29	0.00	412.47	164.83	
1100	624.75	495.29	0.00	453.88	206.23	
1130	812.17	495.29	0.00	536.49	226.94	
1200	1062.08	495.29	0.00	571.68	206.34	
1230	874.65	495.29	0.00	485.08	168.14	
1300	687.22	495.29	0.00	440.93	173.24	
1330	624.75	495.29	0.00	448.07	200.42	
1400	562.27	495.29	0.00	446.85	224.03	
1430	499.80	495.29	0.00	440.80	248.25	
1500	468.56	495.29	0.00	448.41	275.50	
1530	468.56	495.29	0.00	468.50	298.94	
1600	-	-	-	-	312.33	
8-HR TOTAL	7090.91 (KBTU)	3947.60 (KBTU)	0.00 (KBTU)	3772.71 (KBTU)	174.93 (KBTU)	<CHANGE>



Table B-5. Continued.

THERMAL SYSTEM INPUT/OUTPUT  
ELECTRICAL LOAD FOLLOWING

TIME	THERMAL LOAD (KBTU/HR)	FUEL CELL THERMAL AVAIL (KBTU/HR)	THERMAL DUMPED (KBTU/HR)	THERMAL OUTPUT (KBTU/HR)	THERMAL STORAGE LEVEL (KBTU)
1600	812.17	495.29	0.00	543.61	233.24
1630	999.60	495.29	0.00	562.12	209.00
1700	1374.45	495.29	0.00	582.05	175.66
1730	1749.30	495.29	0.00	559.89	132.28
1800	1499.40	495.29	0.00	490.76	99.98
1830	1249.50	495.29	0.00	466.52	102.24
1900	874.65	495.29	0.00	424.98	116.63
1930	749.70	495.29	0.00	435.74	151.78
2000	687.22	495.29	0.00	449.64	181.56
2030	499.80	495.29	0.00	401.80	204.38
2100	312.38	410.27	0.00	304.17	251.12
2130	249.90	384.06	117.76	249.90	304.17
2200	249.90	384.06	134.16	249.90	312.38
2230	218.66	358.94	140.28	218.66	312.38
2300	218.66	334.92	116.26	218.66	312.38
2330	187.43	325.63	138.21	187.43	312.38
2400	-	-	-	-	-
8-HR TOTAL	5966.36 (KBTU)	3575.38 (KBTU)	323.33 (KBTU)	3172.91 (KBTU)	79.13 (KBTU) (CHANGE)

Table B-6. Energy consumption costs first eight hours.

DATE: 27MAR80  
 TIME: 0-800  
 LOCATION: SEHELL'S POINT NAS  
 AVG TEMP: 65 (DEG-F)

150KW FUEL CELL SYSTEM ENERGY CONSUMPTION COSTS

FUEL CELL OUTPUT	F/C (\$)	ELEC PURCHASED (\$)	ELEC SOLD (\$)	BOILER (\$)	TOTAL COST (\$)
RATED	57.28	0.19	4.41	11.14	64.19
ELEC LOAD	47.76	0.19	0.00	11.74	59.68
THERM LOAD	31.75	19.28	0.20	18.38	69.20
F/C=0	0.00	30.54	0.00	33.56	72.10

PRESS RETURN FOR MENU.

Table B-7. Energy consumption costs second eight hours.

DATE: 27MAR88  
 TIME: 800-1600  
 LOCATION: SEHELL'S POINT NAS  
 AVG TEMP: 65 (DEG-F)

150KW FUEL CELL SYSTEM ENERGY CONSUMPTION COSTS

FUEL CELL OUTPUT	F/C (\$)	ELEC PURCHASED (\$)	ELEC SOLD (\$)	BOILER (\$)	TOTAL COST (\$)
RATED	57.28	2.87	0.07	28.98	89.06
ELEC LOAD	57.12	2.87	0.00	29.08	89.07
THERM LOAD	56.98	3.04	0.07	24.61	84.56
F/C=0	0.00	47.18	0.00	55.31	102.48

PRESS RETURN FOR MENU.

Table B-8. Energy consumption costs third eight hours.

DATE: 27MAR80  
 TIME: 1600-2400  
 LOCATION: SEHELL'S POINT NAS  
 AVG TEMP: 65 (DEG-F)

150KW FUEL CELL SYSTEM ENERGY CONSUMPTION COSTS

FUEL CELL OUTPUT	F/C (\$)	ELEC PURCHASED (\$)	ELEC SOLD (\$)	BOILER (\$)	TOTAL COST (\$)
RATED	57.28	2.31	1.92	20.16	77.84
ELEC LOAD	53.01	2.31	0.00	20.60	75.92
THERM LOAD	48.77	5.68	0.00	21.62	76.07
F/C=0	0.00	44.09	0.00	46.54	90.62

PRESS RETURN FOR MENU.

## DISTRIBUTION LIST

ARMY Fil Engr. Letterkenny Army Depot, Chambersburg, PA  
AF SM/ALC/DEE (J. Pestillo) McClellan AFB, CA  
AF ENERGY LIAISON OFF-SERI OFESC/OL-N (Capt B Tolbert) Golden CO  
AFB (AFIT/LDE), Wright Patterson OH; 82ABG/DEMC, Williams AZ; ABG/DEE (F. Nethers), Goodfellow  
AFB TX; AF Tech Office (Mgt & Ops), Tyndall, FL; AFESC/TST, Tyndall FL; CESCH, Wright-Patterson;  
HO MAC/DEEE, Scott, IL; SAMSO/MNND, Norton AFB CA; Samsco/Dec (Sauer) Vandenburg, CA; Stinfo  
Library, Offutt NE; Wright-Patterson, Energy Conversion, Dayton, OH  
AFESC DEB, Tyndall, FL; HQ, RDVA & RDVCW  
ARMY ARRADCOM, Dover, NJ; BMDSC-RE (H. McClellan) Huntsville AL; Contracts - Facs Engr  
Directorate, Fort Ord, CA; DAEN-CWE-M, Washington DC; DAEN-MPE-D Washington DC;  
DAEN-MPR, Chief of Engrs Sol Therm/Sol Htg & Cool Washington; DAEN-MPU, Washington DC;  
ERADCOM Tech Supp Dir. (DELS-D) Ft. Monmouth, NJ; Natick R&D Command (Kwoh Hu) Natick  
MA; Tech. Ref. Div., Fort Huachuca, AZ  
ARMY - CERL Energy Systems, Champaign, IL; Library, Champaign IL  
ARMY CORPS OF ENGINEERS MRD-Eng. Div., Omaha NE; Seattle Dist. Library, Seattle WA  
ARMY CRREL G. Phetteplace Hanover, NH  
ARMY ENGR DIST, Library, Portland OR  
ARMY ENVIRON. HYGIENE AGCY HSE-EW Water Qual Eng Div Aberdeen Prov Grnd MD; Librarian,  
Aberdeen Proving Ground MD  
ARMY MATERIALS & MECHANICS RESEARCH CENTER Dr. Lenox, Watertown MA  
ARMY MISSILE R&D CMD SCI Info Ccn (DOC) Redstone Arsenal, AL  
ARMY MTMC Trans Engr Agency MTT-CE, Newport News, VA  
ASO PWD (ENS M W Davis), Philadelphia, PA  
BUREAU OF RECLAMATION Code 1512 (C. Selander) Denver CO  
CINCLANT CIV ENGR SUPP PLANS OFFR NORFOLK, VA  
CNAVRES Code 13 (Dir. Facilities) New Orleans, LA  
CNM Code MAT-4M, Washington, DC; Code MAT-08E, Washington, DC; NMAT - 044, Washington DC  
CNO Code NOP-964, Washington DC; Code OP 987 Washington DC; Code OP-413 Wash, DC; Code OPNAV  
09B24 (H); OP-098, Washington, DC; OP987J, Washington, DC  
COMFLEACT, OKINAWA PWD - Engr Div, Sasebo, Japan; PWO, Kadena, Okinawa; PWO, Sasebo, Japan  
COMNAVMIANAS Code N4, Guam  
COMOCEANSYSLANT PW-FAC MGMNT Off Norfolk, VA  
COMOCEANSYSPAC SCE, Pearl Harbor HI  
COMSUBDEVRUONE Operations Offr, San Diego, CA  
DEFUELSUPPCEN DFSC-OWE (Term Engrng) Alexandria, VA; DFSC-OWF, Alexandria VA  
DOE Div Ocean Energy Sys Cons/Solar Energy Wash DC; INEL Tech. Lib. (Reports Section), Idaho Falls, ID;  
OPS OFF (Capt WJ Barrattino) Albuquerque NM  
DTIC Defense Technical Info Ctr/Alexandria, VA  
DTNSRDC Code 4111 (R. Gierich), Bethesda MD  
DTNSRDC Code 522 (Library), Annapolis MD  
ENVIRONMENTAL PROTECTION AGENCY Reg. III Library, Philadelphia PA; Reg. VIII, 8M-ASL,  
Denver CO  
FLTCOMBATTRACENLANT PWO, Virginia Bch VA  
GIDEP OIC, Corona, CA  
GSA Assist Comm Des & Cnst (FAIA) D R Dibner Washington, DC ; Off of Des & Const-PCDP (D Eakin)  
Washington, DC  
HC & RS Tech Pres. Service, Meden, Washington, DC  
KWAJALEIN MISRAN BMDSC-RKL-C  
LIBRARY OF CONGRESS Washington, DC (Sciences & Tech Div)  
MARINE CORPS BASE Code 406, Camp Lejeune, NC; Maint Off Camp Pendleton, CA; PWD - Maint,  
Control Div, Camp Butler, Kawasaki, Japan; PWO Camp Lejeune NC; PWO, Camp Pendleton CA; PWO,  
Camp S. D. Butler, Kawasaki Japan  
MARINE CORPS HQS Code LFF-2, Washington DC  
MCAS Facil. Engr. Div. Cherry Point NC; CO, Kaneohe Bay HI; Code S4, Quantico VA; Facs Maint Dept -  
Operations Div, Cherry Point; PWD - Utilities Div, Iwakuni, Japan; PWO, Iwakuni, Japan; PWO, Yuma  
AZ; SCE, Futema Japan  
MCDEC NSAP REP, Quantico VA  
JCLB B520, Barstow CA; Maintenance Officer, Barstow, CA; PWO, Barstow CA  
MCRD SCE, San Diego CA  
NAF PWD - Engr Div, Atsugi, Japan; PWO, Atsugi Japan  
NALF OINC, San Diego, CA  
NARF Code 100, Cherry Point, NC; Code 612, Jax, FL; Code 640, Pensacola FL; SCE Norfolk, VA

NAS CO, Guantanamo Bay Cuba; Code 114, Alameda CA; Code 183 (Fac. Plan BR MGR); Code 18700,  
 Brunswick ME; Code 18U (ENS P.J. Hickey), Corpus Christi TX; Code 70, Atlanta, Marietta GA; Code  
 8E, Patuxent Riv., MD; Dir of Engrng. PWD, Corpus Christi, TX; Grover, PWD, Patuxent River, MD;  
 Lakehurst, NJ; Lead, Chief, Petty Offr. PW/Self Help Div, Beeville TX; PW (J. Maguire), Corpus Christi  
 TX; PWD - Engr Div Dir, Millington, TN; PWD - Engr Div, Gitmo, Cuba; PWD - Engr Div, Oak Harbor,  
 WA; PWD Maint. Cont. Dir., Fallon NV; PWD Maint. Div., New Orleans, Belle Chasse LA; PWD, Code  
 1821H (Pfankuch) Miramar, SD CA; PWD, Maintenance Control Dir., Bermuda; PWO Belle Chasse, LA;  
 PWO Chase Field Beeville, TX; PWO Key West FL; PWO Lakehurst, NJ; PWO Sigonella Sicily; PWO  
 Whiting Fid, Milton FL; PWO, Dallas TX; PWO, Glenview IL; PWO, Millington TN; PWO, Miramar, San  
 Diego CA; PWO., Moffett Field CA; SCE Norfolk, VA; SCE, Barbers Point HI; SCE, Cubi Point, R.P;  
 Weapons Offr, Alameda, CA  
 NATL RESEARCH COUNCIL Naval Studies Board, Washington DC  
 NAVACT PWO, London UK  
 NAVAEROSPREGMEDCEN SCE, Pensacola FL  
 NAVAIRDEVCCEN Chmielewski, Warminster, PA; PWD, Engr Div Mgr, Warminster, PA  
 NAVAIRPROPTSTCEN CO, Trenton, NJ  
 NAVCOASTSYSCEN CO, Panama City FL; Code 715 (J Quirk) Panama City, FL; Library Panama City, FL;  
 PWO Panama City, FL  
 NAVCOMMAREAMSTRSTA PWO, Norfolk VA; SCE Unit 1 Naples Italy; SCE, Wahiawa HI  
 NAVCOMMSTA CO, San Miguel, R.P.; Code 401 Nea Makri, Greece; PWD - Maint Control Div, Diego  
 Garcia Is.; PWO, Exmouth, Australia; SCE, Balboa, CZ  
 NAVCONSTRACEN Curriculum/Instr. Stds Offr, Gulfport MS  
 NAVEDTRAPRODEVCCEN Technical Library, Pensacola, FL  
 NAVEDUTRACEN Engr Dept (Code 42) Newport, RI  
 NAVENENVSA Code 11 Port Hueneme, CA; Code 111A (Winters) Port Hueneme CA  
 NAVEODTECHCEN Code 605, Indian Head MD  
 NAVFAC PWO, Brawdy Wales UK; PWO, Centerville Bch, Ferndale CA; PWO, Point Sur, Big Sur CA  
 NAVFACENGCOM Alexandria, VA; Code 03 Alexandria, VA; Code 03T (Essoglou) Alexandria, VA; Code  
 04B3 Alexandria, VA; Code 051A Alexandria, VA; Code 09M54, Tech Lib, Alexandria, VA; Code 100  
 Alexandria, VA; Code 1113, Alexandria, VA; Code 111B Alexandria, VA; code 08T Alexandria, VA  
 NAVFACENGCOM - CHES DIV, Code 10/11 Washington, DC; Code 403 Washington DC; FPO-1 Washington,  
 DC; Library, Washington, D.C.  
 NAVFACENGCOM - LANT DIV, Code 04 Norfolk VA Norfolk VA; Code 111, Norfolk, VA; Code 403,  
 Norfolk, VA; Eur. BR Deputy Dir, Naples Italy; Library, Norfolk, VA; Code 1112, Norfolk, VA  
 NAVFACENGCOM - NORTH DIV, Code 04 Philadelphia, PA; Code 04AL, Philadelphia PA; Code 09P  
 Philadelphia PA; Code 111 Philadelphia, PA; ROICC, Contracts, Crane IN  
 NAVFACENGCOM - PAC DIV, (Kyi) Code 101, Pearl Harbor, HI; CODE 09P PEARL HARBOR HI; Code  
 04 Pearl Harbor HI; Code 11 Pearl Harbor HI; Code 402, RDT&E, Pearl Harbor HI; Library, Pearl  
 Harbor, HI  
 NAVFACENGCOM - SOUTH DIV, Code 04, Charleston, SC; Code 11, Charleston, SC; Code 403, Gaddy,  
 Charleston, SC; Code 1112, Charleston, SC; Library, Charleston, SC  
 NAVFACENGCOM - WEST DIV, AROICC, Contracts, Twentynine Palms CA; Code 04, San Bruno, CA;  
 Code 04B San Bruno, CA; Library, San Bruno, CA; 09P/20 San Bruno, CA; RDT&ELO San Bruno, CA  
 NAVFACENGCOM CONTRACTS AROICC, NAVSTA Brooklyn, NY; AROICC, Quantico, VA; Contracts,  
 AROICC, Lemoore CA; Dir, Eng, Div., Exmouth, Australia; Eng Div dir, Southwest Pac, Manila, PI;  
 OICC, Southwest Pac, Manila, PI; OICC-ROICC, NAS Oceana, Virginia Beach, VA; OICC/ROICC,  
 Balboa Panama Canal; ROICC AF Guam; ROICC Code 495 Portsmouth VA; ROICC Key West FL;  
 ROICC MCAS El Toro; ROICC, Keflavik, Iceland; ROICC, NAS, Corpus Christi, TX; ROICC, Pacific, San  
 Bruno CA; ROICC, Yap; ROICC-OICC-SPA, Norfolk, VA  
 NAVHOSP PWD - Engr Div, Beaufort, SC  
 NAVMAG IWD - Engr Div, Guam; SCE, Sibic Bay, R.P.  
 NAVOCEANSYSCEN Code 4473 Bayside Library, San Diego, CA; Code 4473B (Tech Lib) San Diego, CA;  
 Code 523 (Hurley), San Diego, CA; Code 6700, San Diego, CA; Code 811 San Diego, CA  
 NAVORDMISTESTFAC PWD - Engr Dir, White Sands, NM  
 NAVORDSTA PWD - Dir, Engr Div, Indian Head, MD; PWO, Louisville KY  
 NAVPETOFF Code 30, Alexandria VA  
 NAVPETRES Director, Washington DC  
 NAVPHIBASE CO, ACB 2 Norfolk, VA; Code S3T, Norfolk VA; SCE Coronado, SD,CA  
 NAVHOSP CO, Millington, TN  
 NAVREGMEDCEN PWD - Engr Div, Camp Lejeune, NC; PWO, Camp Lejeune, NC  
 NAVREGMEDCEN PWO, Okinawa, Japan  
 NAVREGMEDCEN SCE; SCE San Diego, CA; SCE, Camp Pendleton CA; SCE, Guam; SCE, Newport, RI;  
 SCE, Oakland CA  
 NAVREGMEDCEN SCE, Yokosuka, Japan  
 NAVSCOLCECOFF C35 Port Hueneme, CA  
 NAVSCOL PWO, Athens GA

NAVSEASCOM Code 0325, Program Mgr. Washington, DC; Code PMS 395 A 3, Washington, DC; SEA  
04E (L Kess) Washington, DC  
NAVSECGRUACT PWO, Adak AK; PWO, Edzell Scotland; PWO, Puerto Rico; PWO, Torri Sta. Okinawa  
NAVSECSTA PWD - Engr Div. Wash., DC  
NAVSHIPYD Code 202.4, Long Beach CA; Code 202.5 (Library) Puget Sound, Bremerton WA; Code 380,  
Portsmouth, VA; Code 382.3, Pearl Harbor, HI; Code 400, Puget Sound; Code 410, Mare Is., Vallejo CA;  
Code 440 Portsmouth NH; Code 440, Norfolk; Code 440, Puget Sound, Bremerton WA; Code 453 (Util.  
Supr), Vallejo CA; Library, Portsmouth NH; PW Dept, Long Beach, CA; PWD (Code 420) Dir Portsmouth,  
VA; PWD (Code 450-HD) Portsmouth, VA; PWD (Code 453-HD) SHPO 03, Portsmouth, VA; PWO,  
Bremerton, WA; PWO, Mare Is.; PWO, Puget Sound; SCE, Pearl Harbor HI; Tech Library, Vallejo, CA  
NAVSTA Adak, AK; CO, Brooklyn NY; Code 4, 12 Marine Corps Dist, Treasure Is., San Francisco CA; Dir  
Engr Div, PWD, Mayport FL; Dir Mech Engr 37WC93 Norfolk, VA; Engr. Dir., Rota Spain; Long Beach,  
CA; Maint. Cont. Div., Guantanamo Bay Cuba; PWD - Engr Dept, Adak, AK; PWD - Engr Div, Midway  
Is.; PWO, Keflavik Iceland; PWO, Mayport FL; SCE, Guam, Marianas; SCE, Pearl Harbor HI; SCE, San  
Diego CA; SCE, Subic Bay, R.P.; Utilities Engr Off, Rota Spain  
NAVSUPPACT CO, Naples, Italy; PWO Naples Italy  
NAVSUPPFAC PWD - Maint. Control Div, Thurmont, MD  
NAVSUPPO PWO, La Maddalena, Italy  
NAVSURFWPCEN PWO, White Oak, Silver Spring, MD  
NAVTECHTRACEN SCE, Pensacola FL  
NAVTELCOMMCOM Code 53, Washington, DC  
NAVWPNCEN Code 24 (Dir Safe & Sec) China Lake, CA; Code 2636 China Lake; Cmdr, China Lake, CA;  
Code 26605 China Lake CA; Code 623 China Lake CA; PWO (Code 266) China Lake, CA; ROICC (Code  
702), China Lake CA  
NAVWPNEVALFAC Technical Library, Albuquerque NM  
NAVWPNSTA (Clebak) Colts Neck, NJ; Code 092, Concord CA; Code 092A, Seal Beach, CA  
NAVWPNSTA PW Office Yorktown, VA  
NAVWPNSTA PWD - Maint. Control Div., Concord, CA; PWD - Supr Gen Engr, Seal Beach, CA; PWO,  
Charleston, SC; PWO, Seal Beach CA  
NAVWPNSUPPCEN Code 09 Crane IN  
NCTC Const. Elec. School, Port Hueneme, CA  
NCBC Code 10 Davisville, RI; Code 15, Port Hueneme CA; Code 155, Port Hueneme CA; Code 156, Port  
Hueneme, CA; Code 25111 Port Hueneme, CA; Code 430 (PW Engrng) Gulfport, MS; Code 470.2,  
Gulfport, MS; Library, Davisville, RI; NEESA Code 252 (P Winters) Port Hueneme, CA; PWO (Code 80)  
Port Hueneme, CA; PWO, Davisville RI; PWO, Gulfport, MS; Technical Library, Gulfport, MS  
NCR 20, Code R70  
NMCB FIVE, Operations Dept: THREE, Operations Off.  
NOAA (Mr. Joseph Vadus) Rockville, MD; Library Rockville, MD  
NRL Code 5800 Washington, DC  
NROTC J.W. Stephenson, UC, Berkeley, CA  
NSC Code 54.1 Norfolk, VA  
NSD SCE, Subic Bay, R.P.  
NSWSES Code 0150 Port Hueneme, CA  
NUSC DET Code 131 New London, CT; Code 4111 (R B MacDonald) New London CT; Code 5202 (S. Schady)  
New London, CT; Code EA123 (R.S. Munn), New London CT; Code SB 331 (Brown), Newport RI  
OFFICE SECRETARY OF DEFENSE OASD (MRA&L) Dir. of Energy, Pentagon, Washington, DC  
ONR Code 221, Arlington VA; Code 700F Arlington VA  
PACMISRANFAC HI Area Bkg Sands, PWO Kekaha, Kauai, HI  
PERRY OCEAN ENG R. Pellen, Riviera Beach, FL  
PHIBCB I P&E, San Diego, CA  
PMTC Code 3331 (S. Opatowsky) Point Mugu, CA  
PWC ACE Office Norfolk, VA; CO, (Code 10), Oakland, CA; Code 10, Great Lakes, IL; Code 105 Oakland,  
CA; Code 110, Great Lakes, IL; Code 110, Oakland, CA; Code 120, Oakland CA; Code 154 (Library),  
Great Lakes, IL; Code 200, Great Lakes IL; Code 400, Great Lakes, IL; Code 400, Pearl Harbor, HI; Code  
400, San Diego, CA; Code 420, Great Lakes, IL; Code 420, Oakland, CA; Code 424, Norfolk, VA; Code  
500 Norfolk, VA; Code 505A Oakland, CA; Code 600, Great Lakes, IL; Code 610, San Diego Ca; Code  
700, Great Lakes, IL; Library, Code 120C, San Diego, CA; Library, Guam; Library, Norfolk, VA; Library,  
Pearl Harbor, HI; Library, Pensacola, FL; Library, Subic Bay, R.P.; Library, Yokosuka JA; Util Dept (R  
Pascua) Pearl Harbor, HI; Utilities Officer, Guam  
SPCC PWO (Code 120) Mechanicsburg PA  
SUPANX PWO, Williamsburg VA  
TVA Smelser, Knoxville, Tenn.; Solar Group, Arnold, Knoxville, TN  
U.S. MERCHANT MARINE ACADEMY Kings Point, NY (Reprint Custodian)  
USAF REGIONAL HOSPITAL Fairchild AFB, WA  
US GEOLOGICAL SURVEY (Chas E. Smith) Minerals Mgmt Serv, Reston, VA  
USCG G-DMT-3/54 (D Scribner) Washington DC; G-MMT-4/82 (J Spencer); Library Hqs Washington, DC

USCG R&D CENTER D. Motherway, Groton CT; Library New London, CT  
USDA Forest Service Reg 3 (R. Brown) Albuquerque, NM; Forest Service, San Dimas, CA  
USNA Ch. Mech. Engr. Dept Annapolis MD; ENGRNG Div. PWD, Annapolis MD; Energy-Environ Study  
Grp. Annapolis, MD; Environ. Prot. R&D Prog. (J. Williams), Annapolis MD; Mech. Engr. Dept. (C.  
Wu), Annapolis MD; USNA/SYS ENG DEPT ANNAPOLIS MD  
USS FULTON WPNS Rep. Offr (W-3) New York, NY  
ARIZONA Kroelinger Tempe, AZ; State Energy Programs Off., Phoenix AZ  
AUBURN UNIV. Bldg Sci Dept, Lechner, Auburn, AL  
BATTELLE PNW Labs (R Barchet) Richland WA  
BERKELEY PW Engr Div, Harrison, Berkeley, CA  
BONNEVILLE POWER ADMIN Portland OR (Energy Conserv. Off., D. Davey)  
BROOKHAVEN NATL LAB M. Steinberg, Upton NY  
CALIFORNIA STATE UNIVERSITY LONG BEACH, CA (CHELAPATI)  
CLEMSON UNIV. Col. Arch., Egan, Clemson, SC  
CONNECTICUT Office of Policy & Mgt. Energy, Div. Hartford, CT  
CORNELL UNIVERSITY Ithaca NY (Serials Dept. Engr Lib.)  
DAMES & MOORE LIBRARY LOS ANGELES, CA  
DRURY COLLEGE Physics Dept, Springfield, MO  
FLORIDA ATLANTIC UNIVERSITY Boca Raton, FL (McAllister)  
FOREST INST. FOR OCEAN & MOUNTAIN Carson City NV (Studies - Library)  
GEORGIA INSTITUTE OF TECHNOLOGY (LT R. Johnson) Atlanta, GA; Col. Arch. Benton, Atlanta, GA  
HARVARD UNIV. Dept. of Architecture, Dr. Kim, Cambridge, MA  
HAWAII STATE DEPT OF PLAN. & ECON DEV. Honolulu HI (Tech Info Ctr)  
IOWA STATE UNIVERSITY Dept. Arch. McKrown, Ames, IA  
WOODS HOLE OCEANOGRAPHIC INST. Woods Hole MA (Winget)  
KEENE STATE COLLEGE Keene NH (Cunningham)  
LEHIGH UNIVERSITY BETHLEHEM, PA (MARINE GEOTECHNICAL LAB., RICHARDS); Bethlehem  
PA (Linderman Lib. No.30, Flecksteiner)  
LOUISIANA DIV NATURAL RESOURCES & ENERGY Div Of R&D, Baton Rouge, LA  
MAINE OFFICE OF ENERGY RESOURCES Augusta, ME  
MISSOURI ENERGY AGENCY Jefferson City MO  
MIT Cambridge MA (Rm 10-500, Tech. Reports, Engr. Lib.); Cambridge, MA (Harleman)  
MONTANA ENERGY OFFICE Anderson, Helena, MT  
NATURAL ENERGY LAB Library, Honolulu, HI  
NEW HAMPSHIRE Concord NH (Governor's Council on Energy)  
NEW MEXICO SOLAR ENERGY INST. Dr. Zwibel Las Cruces NM  
NY CITY COMMUNITY COLLEGE BROOKLYN, NY (LIBRARY)  
NYS ENERGY OFFICE Library, Albany NY  
OAK RIDGE NATL LA 3 T. Lundy, Oak Ridge, TN  
PENNSYLVANIA STATE UNIVERSITY STATE COLLEGE, PA (SNYDER)  
PURDUE UNIVERSITY Lafayette, IN (CE Engr. Lib)  
SCRIPPS INSTITUTE OF OCEANOGRAPHY LA JOLLA, CA (ADAMS)  
SEATTLE U Prof Schwaegler Seattle WA  
SOUTHWEST RSCH INST King, San Antonio, TX  
SRI INTL Phillips, Chem Engr Lab, Menlo Park, CA  
STATE UNIV. OF NEW YORK Fort Schuyler, NY (Longobardi)  
STATE UNIV. OF NY AT BUFFALO School of Medicine, Buffalo, NY  
TEXAS A&M UNIVERSITY W.B. Ledbetter College Station, TX  
UNIVERSITY OF ALASKA Doc Collections Fairbanks, AK  
UNIVERSITY OF CALIFORNIA Berkeley CA (Dept of Naval Arch.); Energy Engineer, Davis CA;  
LIVERMORE, CA (LAWRENCE LIVERMORE LAB. TOKARZ); UCSF, Physical Plant, San Francisco,  
CA  
UNIVERSITY OF DELAWARE Newark, DE (Dept of Civil Engineering, Chesson)  
UNIVERSITY OF FLORIDA Dept Arch., Morgan, Gainesville, FL  
UNIVERSITY OF HAWAII (Colin Ramage) Dept of Meteorology Honolulu HI; HONOLULU, HI (SCIENCE  
AND TECH. DIV.); Natl Energy Inst (DR Neill) Honolulu HI  
UNIVERSITY OF ILLINOIS (Hall) Urbana, IL; URBANA, IL (LIBRARY)  
UNIVERSITY OF MASSACHUSETTS (Heronemus), ME Dept. Amherst, MA  
UNIVERSITY OF NEBRASKA-LINCOLN Lincoln, NE (Ross Ice Shelf Proj.)  
UNIVERSITY OF NEW HAMPSHIRE Elec. Engr. Depot, Dr. Murdoch, Durham, N.H.  
UNIVERSITY OF TEXAS Inst. Marine Sci (Library), Port Arkansas TX  
UNIVERSITY OF TEXAS AT AUSTIN AUSTIN, TX (THOMPSON)  
UNIVERSITY OF WASHINGTON Seattle WA (E. Linger)  
UNIVERSITY OF WISCONSIN Milwaukee WI (Ctr of Great Lakes Studies)  
ARVID GRANT OLYMPIA, WA  
ATLANTIC RICHFIELD CO. DALLAS, TX (SMITH)



BECHTEL CORP. SAN FRANCISCO. CA (PHELPS)  
BROWN & ROOT Houston TX (D. Ward)  
CHEMED CORP Lake Zurich IL (Dearborn Chem. Div.Lib.)  
CHEVRON OIL FIELD RESEARCH CO. LA HABRA. CA (BROOKS)  
COLUMBIA GULF TRANSMISSION CO. HOUSTON, TX (ENG. LIB.)  
DESIGN SERVICES Beck. Ventura, CA  
DILLINGHAM PRECAST F. McHale. Honolulu HI  
DIXIE DIVING CENTER Decatur, GA  
DURLACH. O'NEAL. JENKINS & ASSOC. Columbia SC  
EXXON PRODUCTION RESEARCH CO Houston, TX (Chao)  
GARD INC. Dr. L. Holmes. Niles, IL  
KLEIN ASSOCIATES Vincent. Salem NH  
LITHONIA LIGHTING Application eng. Dept. (B. Helton), Conyers, GA 30207  
LOCKHEED MISSILES & SPACE CO. INC. L. Trimble. Sunnyvale CA  
MCDONNELL AIRCRAFT CO. (Fayman) Engrng Dept., St. Louis, MO  
MEDERMOTT & CO. Diving Division, Harvey, LA  
NEWPORT NEWS SHIPBLDG & DRYDOCK CO. Newport News VA (Tech. Lib.)  
PACIFIC MARINE TECHNOLOGY (M. Wagner) Duvall, WA  
PG&E Library, San Francisco, CA  
PORTLAND CEMENT ASSOC. Skokie IL (Rsch & Dev Lab. Lib.)  
RAYMOND INTERNATIONAL INC. E Colle Soil Tech Dept. Pennsauken, NJ  
ROCKWELL INTL Energy Sys Group (R.A. Williams) Golden CO  
SANDIA LABORATORIES Albuquerque, NM (Vortman); Library Div., Livermore CA  
SCHUPACK ASSOC SO. NORWALK, CT (SCHUPACK)  
SEATECH CORP. MIAMI, FL (PERONI)  
SHANNON & WILLSON INC. Librarian Seattle, WA  
SHELL DEVELOPMENT CO. Houston TX (C. Sellars Jr.)  
TEXTRON INC BUFFALO, NY (RESEARCH CENTER LIB.)  
TRW SYSTEMS REDONDO BEACH, CA (DAI)  
UNITED TECHNOLOGIES Windsor Locks CT (Hamilton Std Div., Library)  
WARD, WOLSTENHOLD ARCHITECTS Sacramento, CA  
WESTINGHOUSE ELECTRIC CORP. Annapolis MD (Oceanic Div Lib. Bryan); Library, Pittsburgh PA  
WM CLAPP LABS - BATTELLE DUXBURY, MA (LIBRARY)  
WOODWARD-CLYDE CONSULTANTS PLYMOUTH MEETING PA (CROSS, III)  
BRAHTZ La Jolla, CA  
ERVIN, DOUG Belmont, CA  
FISHER San Diego, Ca  
KETRON, BOB Ft Worth, TX  
KRUZIC, T.P. Silver Spring, MD  
BROWN & CALDWELL Saunders, E.M./Oakland, CA  
T.W. MERMEL Washington DC  
WALTZ Livermore, CA

## INSTRUCTIONS

The Naval Civil Engineering Laboratory has revised its primary distribution lists. The bottom of the mailing label has several numbers listed. These numbers correspond to numbers assigned to the list of Subject Categories. Numbers on the label corresponding to those on the list indicate the subject category and type of documents you are presently receiving. If you are satisfied, throw this card away (or file it for later reference).

If you want to change what you are presently receiving:

- Delete – mark off number on bottom of label.
- Add – circle number on list.
- Remove my name from all your lists – check box on list.
- Change my address – line out incorrect line and write in correction (ATTACH MAILING LABEL).
- Number of copies should be entered after the title of the subject categories you select.

Fold on line below and drop in the mail.

Note: Numbers on label but not listed on questionnaire are for NCEL use only, please ignore them.

Fold on line and staple.

### DEPARTMENT OF THE NAVY

NAVAL CIVIL ENGINEERING LABORATORY  
PORT HUENEME, CALIFORNIA 93043

#### OFFICIAL BUSINESS

PENALTY FOR PRIVATE USE, \$300  
1 IND-NCEL-2700/4 (REV. 12-78)  
0930-LL-L70-0044

POSTAGE AND FEES PAID  
DEPARTMENT OF THE NAVY  
DOD-316



Commanding Officer  
Code L14  
Naval Civil Engineering Laboratory  
Port Huene, California 93043

## DISTRIBUTION QUESTIONNAIRE

The Naval Civil Engineering Laboratory is revising its primary distribution lists.

### SUBJECT CATEGORIES

- 1 SHORE FACILITIES
- 2 Construction methods and materials (including corrosion control, coatings)
- 3 Waterfront structures (maintenance/deterioration control)
- 4 Utilities (including power conditioning)
- 5 Explosives safety
- 6 Construction equipment and machinery
- 7 Fire prevention and control
- 8 Antenna technology
- 9 Structural analysis and design (including numerical and computer techniques)
- 10 Protective construction (including hardened shelters, shock and vibration studies)
- 11 Soil/rock mechanics
- 13 BEQ
- 14 Airfields and pavements
- 15 ADVANCED BASE AND AMPHIBIOUS FACILITIES
- 16 Base facilities (including shelters, power generation, water supplies)
- 17 Expedient roads/airfields/bridges
- 18 Amphibious operations (including breakwaters, wave forces)
- 19 Over-the-Beach operations (including containerization, materiel transfer, lighterage and cranes)
- 20 POL storage, transfer and distribution
- 24 POLAR ENGINEERING
- 24 Same as Advanced Base and Amphibious Facilities, except limited to cold-region environments

- 28 ENERGY/POWER GENERATION
- 29 Thermal conservation (thermal engineering of buildings, HVAC systems, energy loss measurement, power generation)
- 30 Controls and electrical conservation (electrical systems, energy monitoring and control systems)
- 31 Fuel flexibility (liquid fuels, coal utilization, energy from solid waste)
- 32 Alternate energy source (geothermal power, photovoltaic power systems, solar systems, wind systems, energy storage systems)
- 33 Site data and systems integration (energy resource data, energy consumption data, integrating energy systems)
- 34 ENVIRONMENTAL PROTECTION
- 35 Solid waste management
- 36 Hazardous/toxic materials management
- 37 Wastewater management and sanitary engineering
- 38 Oil pollution removal and recovery
- 39 Air pollution
- 40 Noise abatement
- 44 OCEAN ENGINEERING
- 45 Seafloor soils and foundations
- 46 Seafloor construction systems and operations (including diver and manipulator tools)
- 47 Undersea structures and materials
- 48 Anchors and moorings
- 49 Undersea power systems, electromechanical cables, and connectors
- 50 Pressure vessel facilities
- 51 Physical environment (including site surveying)
- 52 Ocean-based concrete structures
- 53 Hyperbaric chambers
- 54 Undersea cable dynamics

### TYPES OF DOCUMENTS

- |                                     |  |                         |   |
|-------------------------------------|--|-------------------------|---|
| 85 Techdata Sheets                  | 86 Technical Reports and Technical Notes | 82 NCEL Guide & Updates | <input type="checkbox"/> None--<br>remove my name |
| 83 Table of Contents & Index to TDS |  | 91 Physical Security    |   |