

AD-A198 185

DTIC FILE COPY

2

— USAFOEHL REPORT —

88-078EQ0025FEF



**COMPLIANCE TESTING of GRISSOM AFB
CENTRAL HEATING PLANT COAL-FIRED
BOILERS 3 and 5, GRISSOM AFB IN**

JAMES A. GARRISON, Maj, USAF, BSC

June 1988

Final Report

DTIC
ELECTE
AUG 29 1988
S D
H

Distribution is unlimited; approved for public release

**USAF Occupational and Environmental Health Laboratory
Human Systems Division (AFSC)
Brooks Air Force Base, Texas 78235-5501**

88 8 29 02 81

NOTICES

When Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government thereby incurs no responsibility nor any obligation whatsoever. The fact that the Government may have formulated, or in any way supplied the said drawing, specifications, or other data, is not to be regarded by implication, or otherwise, as in any manner licensing the holder or any other person or corporation; or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

The mention of trade names or commercial products in this publication is for illustration purposes and does not constitute endorsement or recommendation for use by the United States Air Force.

Do not return this copy. Retain or destroy.


Air Force installations may direct requests for copies of this report to: USAF Occupational and Environmental Health Laboratory (USAFOEHL) Library, Brooks AFB TX 78235-5501.

Other Government agencies and their contractors registered with the DTIC should direct requests for copies of this report to: Defense Technical Information Center (DTIC), Cameron Station, Alexandria VA 22314.

Non-Government agencies may purchase copies of this report from: National Technical Information Service (NTIS), 5285 Port Royal Road, Springfield VA 22161

The Public Affairs Office has reviewed this report, and it is releasable to the National Technical Information Service, where it will be available to the general public, including foreign nations.


This report has been reviewed and is approved for publication.


JOHN J. COUGHLIN, Colonel, USAF, BSC
Commander

Prepared By:


JAMES A. GARRISON, Maj, USAF, BSC
Chief, Air Quality Section

Reviewed By:


MARTIN L. SWEIGART, Lt Col, USAF, BSC
Chief, Environmental Quality Branch


SHELTON R. BIRCH, Col, USAF, BSC
Chief, Consultant Services Division

UNCLASSIFIED


SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE				
1a REPORT SECURITY CLASSIFICATION UNCLASSIFIED		1b RESTRICTIVE MARKINGS NA		
2a SECURITY CLASSIFICATION AUTHORITY NA		3 DISTRIBUTION / AVAILABILITY OF REPORT Distribution is unlimited; approved for public release.		
2b DECLASSIFICATION / DOWNGRADING SCHEDULE NA				
4 PERFORMING ORGANIZATION REPORT NUMBER(S) USAFOEHL REPORT 88-078EQ0025FEF		5 MONITORING ORGANIZATION REPORT NUMBER(S)		
6a. NAME OF PERFORMING ORGANIZATION USAF Occupational and Environmental Health Laboratory		6b OFFICE SYMBOL (If applicable) ECO	7a NAME OF MONITORING ORGANIZATION	
6c. ADDRESS (City, State, and ZIP Code) Brooks AFB TX 78235-5501		7b ADDRESS (City, State, and ZIP Code)		
8a. NAME OF FUNDING / SPONSORING ORGANIZATION Same as 6a		8b OFFICE SYMBOL (If applicable)	9 PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER	
8c. ADDRESS (City, State, and ZIP Code)		10 SOURCE OF FUNDING NUMBERS	PROGRAM ELEMENT NO	PROJECT NO
			TASK NO	WORK UNIT ACCESSION NO
11 TITLE (Include Security Classification) Compliance Testing of Grissom AFB Central Heating Plant Coal-Fired Boilers 3 and 5, Grissom AFB IN				
12 PERSONAL AUTHOR(S) Maj James A. Garrison				
13a. TYPE OF REPORT Final		13b. TIME COVERED FROM 4 TO 14 Mar	14 DATE OF REPORT (Year, Month, Day) June 1988	15 PAGE COUNT 105
16 SUPPLEMENTARY NOTATION				
17 COSATI CODES		18 SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP		
			<input checked="" type="checkbox"/> Compliance Testing Grissom Source Emission Testing <input checked="" type="checkbox"/> Stack Sampling Particulates Boiler <input checked="" type="checkbox"/> Stack Emission(s) Garrison Air Pollution	
19 ABSTRACT (Continue on reverse if necessary and identify by block number)				
<p><input checked="" type="checkbox"/> At the request of HQ SAC/SGPB, compliance testing (particulate Emissions) of coal-fired boilers 3 and 5 in the Grissom AFB Central Heating Plant was performed on 4-14 Mar 1988. The survey was conducted to determine compliance with Indiana Administrative Code, Title 325--Air Pollution Control Board, Articles 5 and 6. Results indicate that boilers 3 and 5 met particulate standards while exhausting through scrubber A. However, boiler 5 failed to meet particulate standards while exhausting through the bypass stack.</p>				
20. DISTRIBUTION / AVAILABILITY OF ABSTRACT <input checked="" type="checkbox"/> UNCLASSIFIED/UNLIMITED <input type="checkbox"/> SAME AS RPT <input type="checkbox"/> DTIC USERS		21 ABSTRACT SECURITY CLASSIFICATION Unclassified		
22a. NAME OF RESPONSIBLE INDIVIDUAL Maj James A. Garrison		22b TELEPHONE (Include Area Code) (512) 536-2891	22c OFFICE SYMBOL ECO	

CONTENTS

	Page
DD FORM 1473	i
Illustrations	iv
I. INTRODUCTION	1
II. DISCUSSION	1
A. Background	1
B. Site Description	1
C. Applicable Standards	2
D. Sampling Methods and Procedures	7
III. CONCLUSIONS	11
IV. RECOMMENDATIONS	12
References	14
Appendix	
A Personnel Information	15
B State Regulations	19
C Plant Operating Data	33
D Coal Analysis	41
E Boiler 3, Scrubber Stack Field Data	53
F Boiler 5, Bypass Stack Field Data	63
G Boiler 5, Scrubber Stack Field Data	75
H EPA Computer Program Emissions Calculations	87
I Calibration Data	93
Distribution List	101

Accession For	
NIE GRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	<input type="checkbox"/>
By _____	
Distribution/ _____	
Availability Codes	
Dist _____	Special _____



Illustrations

Figure	Title	Page
1	View of Scrubber and Bypass Stacks	3
2	Scrubber Stacks	4
3	Bypass Stack	5
4	Flue Gas Flow Diagram	6
5	ORSAT Sampling Train	9
6	ORSAT Apparatus	9
7	Particulate Sampling Train	10

Table

1	Particulate Emission Survey Results	13
---	-------------------------------------	----

I. INTRODUCTION

On 4-14 Mar 1988, a stationary source sampling survey for particulate emissions was conducted on coal-fired boilers 3 and 5 at the Grissom AFB Central Heating Plant, by the Air Quality Function of the USAF Occupational and Environmental Health Laboratory (USAFOEHL). This survey was requested by HQ SAC/SGPB to determine particulate emission compliance status with regards to Indiana Administrative Code, Title 325 - Air Pollution Control Board, Article 5, Opacity Regulations (325 IAC 5), and Article 6, Particulate Regulations (325 IAC 6). Personnel involved with on-site testing are listed in Appendix A.

II. DISCUSSION

A. Background

On 7 Nov 1986, the Director, Air and Radiation Division, U.S. Environmental Protection Agency (EPA), Region V, issued a notice of violation (NOV) to Grissom AFB for violation of 325 IAC 5, Opacity Regulations. The NOV was based on information submitted by the State of Indiana Department of Environmental Management and by the EPA. Observations indicated that oil-fired boiler 1 and coal-fired boilers 3 and 4 (boiler 5 was out of service during the State observations) were out of compliance with respect to visible emissions.

To demonstrate and maintain compliance with 325 IAC 5 and other rules set forth by the Indiana Air Pollution Control Board, EPA, Region V required Grissom AFB to: (1) conduct stack particulate emission testing on boilers 3, 4 and 5 (when operational) as specified in Title 40, Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A, Reference Method 5; (2) determine visible emissions from boilers 1-4 and 5 (when operational) as specified in 40 CFR 60, Appendix A, Reference Method 9; and (3) request stack testing following future major modifications to the central heating plant.

B. Site Description

The Central Heating Plant operates a total of five boilers for steam production:

<u>Boiler No / Manufacturer</u>	<u>Steam Capacity (lb/hr)</u>	<u>Year Installed</u>	<u>Fuel</u>
1/Springfield Boiler Co.	40,000	1955	oil
2/Springfield Boiler Co.	40,000	1955	oil
3/Springfield Boiler Co.	40,000	1955	coal
4/E. Keeler Co.	40,000	1960	coal

Boilers 3 and 5 are spreader-stoker fired units with each having forced-draft and induced-draft fans and mechanical fly-ash collection systems. The purpose of the forced-draft fan is to supply air for combustion and that of the induced-draft fan is to maintain a negative draft condition in the furnace part of the boiler for combustion and removal of gases and to provide a positive static pressure at flue gas exhaust discharge points. The ash system pneumatically removes ash from bottom-ash hoppers, sifting hoppers and mechanical collector hoppers. Each unit is fitted with a steam-operated soot blower to remove fly-ash and soot from heat exchanger tubing. Boiler 5 is also fitted with an economizer to further increase operating efficiency by preheating the feed water using exhaust gas heat.

Air pollution control consists of individual multiclone dust collectors on each boiler and an optional wet scrubber common to the three coal-fired boilers. The multiclone dust collectors fitted on boilers 3 and 5 were manufactured by Western Precipitation Division - Joy Manufacturing Co. The collector on boiler 3 is a Model 9VM-10 and consists of 36 nine-inch diameter cyclonic collectors operating in parallel. The collector on boiler 5 is a Model 9VMU-10 and consists of 48 nine-inch diameter cyclonic collectors operating in parallel. Each unit is located in the boiler exhaust duct upstream of the induced-draft fan. Ash collected by the multiclones is carried by gravity to a hopper.

The exhaust effluent from each boiler is ducted to a common breeching and can be routed to the wet-scrubber or to a bypass stack. The scrubber is a double-alkali flue-gas desulfurization system using soda ash (sodium carbonate) in the scrubbing fluid and lime (calcium hydroxide) slurry for regeneration of the scrubbing liquid. The primary purpose of the unit is to remove sulfur from the flue gases; a secondary purpose is to remove particulates from the flue gases. The system has two identical scrubber units (A & B), each designed to handle 50% of the flue gases from the three coal-fired boilers. Each unit has a 5 ft diameter stack and terminates about 70 feet above the ground. There is no requirement at this time to use the scrubber system because of the low-sulfur coal being used by the plant. The bypass stack has a 5.5 ft diameter and terminates approximately 70 ft above ground level. The scrubber stacks and the bypass stack can be seen in Figures 1, 2 and 3. A flue gas flow diagram is shown in Figure 4.

C. Applicable Standards

The monitoring requirements, opacity regulations and particulate regulations are defined under 325 IAC 3, 5 and 6 respectively. Article 5 states that visible emissions shall not exceed an average of 40% opacity in 24 consecutive readings or 60% opacity for more than a cumulative total of 15 minutes (60 readings) in a 6-hour period.

Under 325 IAC 6, the maximum allowable particulate emission rate from the combustion of fuel for indirect heating facilities (which were existing and in operation or which received permits to construct prior to the effective date of 325 IAC 6, 26 Sept 1980) is determined by the following equation:




Figure 1. View of Scrubber and Bypass Stacks




Figure 2. Scrubber A and B Stacks






Figure 4. Flue Gas Flow Diagram

$$Pt = \frac{C \times a \times h}{76.5 \times Q \times N \times 0.75 \times 0.25}$$

Where:

Pt = Pounds of particulate matter emitted per million Btu heat input (lb/mmBtu).

C = Maximum ground level concentration with respect to distance from the point source at the "critical" wind speed for level terrain (50 micrograms per cubic meter-provided in standard).

Q = Total source maximum operating capacity rating in million Btu per hour (mmBtu/hr) heat input (50.0 mmBtu/hr - boiler 3, 82.4 mmBtu/hr - boiler 5: determined from plant operation).

N = Number of stacks (1) in fuel burning operation

a = Plume rise factor (0.67 used for Q less than or equal to 1.000 mmBtu/hr heat input).

h = Stack height in feet (70 ft).

The limits on particulate emissions determined by the above equation and values of the variables applicable to this facility are 1.6 lb/mmBtu for boiler 3 and 1.1 lb/mmBtu for boiler 5. However, particulate emissions from facilities used for indirect heating purposes shall in no case exceed the following emission limitations: (1) 0.8 lb/mmBtu heat input for facilities existing and in operation on or before 8 June 1972 or (2) 0.6 lb/mmBtu heat input for any facility which has 250 mmBtu/hr heat input or less and which began operation after 8 June 1972. Item (1) applies to boiler 3 and item (2) applies to boiler 5. State regulations are presented in Appendix B.

D. Sampling Methods and Procedures

Boiler 3 was tested through scrubber A. Boiler 5 was tested through both scrubber A and the bypass stack. Emission testing was conducted only on scrubber A since scrubber B was not operational at the time of the survey. Boiler 4 was not tested due to a stoker malfunction. Coordination was made with plant personnel to operate each boiler at 95% capacity or greater during testing. One of the three runs which comprised a complete test included a soot blow; this is indicated on the field data sheets. Boiler operating logs for the test periods are provided in Appendix C. These logs indicate hourly steam output and coal usage. Laboratory results for the coal analysis are provided in Appendix D. Each coal sample represents an integrated sample collected over a particular one hour test run as noted on the analysis sheet.

325 IAC 3 requires that all emissions tests be conducted in accordance with the procedures and analysis methods specified in 40 CFR 60, Appendix A, Methods 1-5. Therefore, test methods, equipment, sample train preparations, sampling and recovery, calibration requirements and quality assurance were done in accordance with the methods and procedures outlined in 40 CFR 60, Appendix A.

Sampling ports were in place on the scrubber stack and located 1.4 stack diameters upstream from the stack exit and 5.6 stack diameters downstream from any disturbance (cyclonic separator). Based on a 5 ft inside stack diameter, port location and type of sample (particulate), a total of twenty traverse points were determined for emission evaluation. Sampling ports were also in place on the bypass stack and were located 2 stack diameters upstream from the stack exit and 7 stack diameters downstream from the nearest disturbance (common breeching inlet). Based on a 5.5 ft inside stack diameter, port location and type of sample (particulate), a total of twelve traverse points were determined for emission evaluation. The sampling time for each sampling run was 60 minutes; therefore, the sampling time per traverse point in the scrubber stack was 3 minutes and 5 minutes per point in the bypass stack. Illustrations showing port locations and sampling points are provided in Appendixes E, F and G.

Prior to every sample run on each stack, a preliminary velocity pressure traverse was accomplished and cyclonic flow was determined. For acceptable flow conditions to exist in a stack, the average of the absolute value of the flow angle taken at each traverse point must be less than or equal to 20 degrees. The flow angle in the bypass stack averaged 11 degrees which indicated an acceptable flow condition. Straightening vanes were installed directly above the cyclonic separator in scrubber A to prevent cyclonic flow out of the separator into the stack. The resultant flow angle in the scrubber stack averaged 9 degrees.

During each sample run, a flue gas sample for orsat analysis (measures oxygen, and carbon dioxide for stack gas molecular weight determination and emissions correction) was taken. Orsat sampling and analysis equipment are shown in Figures 5 and 6. Flue gas moisture content, also needed for determination of gas molecular weight, was obtained during particulate sampling.

Particulate samples were collected using the sampling train shown in Figure 7. The train consisted of a button-hook probe nozzle, heated inconel probe, heated glass filter, impingers and pumping and metering device. The nozzle was sized prior to each sample run so that the gas stream could be sampled isokinetically; in other words, the velocity at the nozzle tip was the same as the stack gas velocity at each point sampled. Flue gas velocity pressure was measured at the nozzle tip using a Type-S pitot tube connected to a ten-inch inclined-verticle manometer. Type K thermocouples were used to measure flue gas as well as sampling train temperatures. The probe was heated to minimize moisture condensation. The heated filter was used to collect particulate materials. The impinger train (first, third and fourth impingers: modified Greenburg-Smith type, second impinger: standard Greenburg-Smith design) was used as a condenser to collect stack gas moisture. The pumping and metering system was used to control and monitor the sample gas flow rate.




Figure 5. ORSAT Sampling Train




Figure 6. ORSAT Apparatus




Figure 7. Particulate Sampling Train

Emission calculations were done using "Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators" (EPA-340/1-85-018) developed by the EPA's Office of Air Quality Planning and Standards, Research Triangle Park NC. This is our standard method for calculating emissions data. Calculations from the EPA programs are found in Appendix H. Calibration data is presented in Appendix I.

Method 9 determinations for opacity during this project was not accomplished since neither EPA Region V nor State observers were present. Region V had been notified in advance that a requirement existed for qualified observers since no one on our team was presently qualified to perform opacity determinations. Reply was that observers would be on hand if possible, but the Method 5 evaluations were of more importance.

III. CONCLUSIONS

The following table provides operating parameters for boilers 3 and 5 during testing and the resultant particulate emission rates determined from these tests. Results indicate that boiler 3 emissions through scrubber A were well below the emission standard of 0.8 lb/mmBtu with an emission rate of 0.35 lb/mmBtu. Boiler 5 emissions through scrubber A were well below the emission standard of 0.60 lb/mmBtu with a particulate emission rate of 0.09 lb/mmBtu. However, boiler 5 emissions through the bypass stack were above the 0.60 lb/mmBtu standard with a rate of 0.98 lb/mmBtu.

In our previous survey during November 1987, we noted that boiler 3 didn't meet the emission standard through scrubber B which was surprising since it met the standard through the bypass stack. If anything, the particulate emissions should have been less through the scrubber. At the time, we believed that two factors other than boiler operation may have contributed to the results: (1) a very low percentage of carbon dioxide (CO₂) was found in the exhaust gas from scrubber B (3%) as opposed to what was seen in the bypass stack exhaust (10%), and (2) material collected on the filter may have contained soda ash carry-over from the scrubber. It was thought that the low CO₂ value was caused by either the scrubber liquid absorbing the CO₂ or outside air being drawn into the system prior to the scrubber and diluting the exhaust gases.

To try and eliminate these two possible causes, we intended to evaluate gas stream CO₂ and Na content prior to and after scrubber B. The proposed evaluation of scrubber B during this survey was not possible since it was not operational, however, scrubber A was evaluated. Results indicated that there was little change in CO₂ percentage between the scrubber inlet and outlet with the inlet values averaging 8.9% and the outlet values averaging 9.4%. Evaluation of two of the Method 5 one-hour runs for boiler 5 through the bypass stack and scrubber indicate that the contribution of sodium to total filter mass averaged 0.085% and 0.74% respectively - an insignificant contribution.

At this time, boilers 3 and 4 meet applicable emission standards when exhausted through the bypass stack. Boilers 3 and 5 meet emission standards when exhausted through scrubber A and boiler 4 meets the standard when exhausted through scrubber B.

IV. RECOMMENDATIONS

It is our recommendation that boiler 5 be retested; however, all aspects of the system (boiler, particular control devices, etc.) should be evaluated for proper operation prior to testing.

It is our recommendation that EPA, Region V, should make the final determination as to whether it is necessary at this point to evaluate boiler 4 through scrubber A and conduct a retest of boiler 3 through scrubber B.

Table 1

STACK EMISSION TESTING RESULTS

DATE	TIME (MILITARY)	BOILER NO.	STACK NO.	ROW NO.	BOILER OPERATING CAPACITY (%)	SOOT BLOW	COAL HEAT VALUE (Btu/lb)	COAL USE (lb/hr)	HEAT INPUT (mbtu/hr)	SPH EMISSIONS (lb/hr)	PM EMISSIONS (lb/mbtu)
8 MAR 88	1100	5	00BP	1	93.0		11906	6344	77.9	37.1	6.73
9 MAR 88	1330	5	BP	2	96.0		11799	6710	79.2	74.6	6.94
9 MAR 88	1535	5	BP	3	96.0	X	11883	6933	82.4	105.3	1.28
					AVG = 96.0					AVG = 79.0	AVG = 6.98
10 MAR 88	1000	5	000BC	1	98.0		11896	7111	84.6	9.9	0.11
11 MAR 88	0750	5	BC	2	99.0		11743	7778	91.3	7.5	0.08
11 MAR 88	0915	5	BC	3	101.0	X	11888	7378	86.5	7.0	0.08
					AVG = 99.0					AVG = 8.1	AVG = 0.09
13 MAR 88	0930	3	8C	1	95.0	X	11785	4222	49.0	19.6	0.39
13 MAR 88	1205	3	8C	2	95.0		11749	4222	49.6	9.2	0.19
13 MAR 88	1443	3	8C	3	95.0		11905	4197	50.0	23.8	0.48
					AVG = 95.0					AVG = 17.5	AVG = 0.35

0 PARTICULATE EMISSIONS
 00 BYPASS STACK
 000 SCRUBBER STACK

REFERENCES

1. "Standards of Performance for New Stationary Sources", Title 40, Part 60, Code of Federal Regulations, July 1, 1987.
2. Quality Assurance Handbook for Air Pollution Measurement Systems - Volume III, Stationary Source Specific Methods, U.S. Environmental Protection Agency, EPA-600/4-77-027-b, Research Triangle Park, North Carolina, December 1984.
3. Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators. U.S. Environmental Protection Agency, EPA-340/1-85-018, Research Triangle Park, North Carolina. May 1987.

APPENDIX A
Personnel Information

(This page left blank)

1. USAFOEHL Test Team

Maj James Garrison, Chief, Air Quality Function

Capt Tim Fagin, Consultant, Air Quality Engineer

Capt Mary Daly, Consultant, Air Quality Engineer

1Lt Mark Dibben, Chemist

SGT Robert Davis, Environmental Engineering Technician

USAFOEHL/ECQ
Brooks AFB TX 78235-5501

Phone: AUTOVON 240-2891
Commercial (512) 536-2891

2. Grissom AFB on-site representatives

SSGT Paul Franco	USAF Clinic Grissom/SGPB AUTOVON 928-3017 Commercial (317) 689-3017
------------------	---

Ruel Burns	305TH CSG/DEEV AUTOVON 928-2225 Commercial (317) 689-2225
------------	---

Smedley Graham Jim Williams Michael Esca Michael Ryan	305TH CES/DEMMHZ AUTOVON 928-3253 Commercial (317) 689-3253
--	---

(This page left blank) _____

APPENDIX B
State Regulations



(B) When the owner or operator elects under Section 8(a) [325 IAC 3-2-8(1)] of this Rule to measure carbon dioxide in the flue gases, the measurement of the pollutant concentration and the carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure used;

$$E = CF_c \frac{(100)}{(\% \text{ CO}_2)}$$

(C) When the owner or operator elects under Section 8(a) [325 IAC 3-1-8(1)] of this Rule to measure sulfur dioxide or nitrogen oxides in the flue gases, the measurement of the pollutant concentration and the sulfur dioxide and/or the nitrogen oxides concentration(s) shall each be on a wet basis and the following conversion procedure used except where wet scrubbers are employed or where moisture is otherwise added to the stack gases;

$$E = C_w F_w \frac{(20.9)}{(20.9(1-B_{w,v}) - \%O_{2,w})}$$

(D) When the owner or operator elects under Section 8(a) [325 IAC 3-1-8(1)] of this Rule to measure sulfur dioxide or nitrogen oxides in the flue gases, the measurement of the pollutant concentration and the sulfur dioxide and/or the nitrogen oxides concentration(s) shall each be on a wet basis and the following conversion procedure used where wet scrubbers or moisture is otherwise present in the stack gases provided water vapor content of the stack gas is measured at least once every fifteen minutes at the same point as the pollutant and oxygen measurements are made;

$$E = C_w F \frac{(20.9)}{(20.9(1-B_{w,v}) - \%O_{2,w})}$$

(F) The values used in the equations under this Section are derived as follows: C_w = pollutant concentration at stack conditions, g/wscm (grams/wet standard cubic meter), lb/wscm (pounds/wet standard cubic meter), determined by multiplying the average concentration (ppm) for each one hour period by $4.15 \times 10^5 \text{ M} \text{ wscm per ppm}$ ($2.59 \times 10^5 \text{ M lb/wscm per ppm}$) where M is pollutant molecular weight, g/g-mole (lb/lb-mole).

M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.

C = as above but measured in terms of pounds/dry standard cubic meter (lb/dscm) or grams/dry standard cubic meter (g/dscm).

F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given in Section 60.45(f) of 40 CFR Part 60, as applicable.

F_w = a factor representing a ratio of the volume of wet flue gases generated to the calorific value of the fuel combusted. Values of F_w are:

(i) For anthracite coal as classified according to A.S.T.M. D388-66, $F_w = 1.188 \text{ wscm/million calories}$ (10580 wscf/million BTU).

(ii) For sub-bituminous and bituminous coal as classified according to A.S.T.M. D388-66, $F_w = 1.200 \text{ wscm/million calories}$ (10680 wscf/million BTU).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, $F_w = 1.164 \text{ wscm/million calories}$ (10360 wscf/million BTU).

(iv) For gaseous fossil fuels: for natural gas, $F_w = 1.196 \text{ wscm/million calories}$ (10650 wscf/million BTU); for propane, $F_w = 1.150 \text{ wscm/million calories}$ (10240 wscf/million BTU); for butane $F_w = 1.172 \text{ wscm/million calories}$ (10430 wscf/million BTU).

$B_{w,v}$ = proportion by volume of water vapor in the ambient air.

$B_{w,v}$ = proportion by volume of water vapor in the stack gas.

$\%O_2$, $\%CO_2$ = Oxygen or carbon dioxide volume (expressed as percent) determined with equipment specified under Section 8 [325 IAC 3-1-8] of this Rule.

E = pollutant emission, lb/million BTU.

(2) For sulfuric acid plants the owner or operator shall:

(A) Establish a conversion factor three times daily according to the procedures of Section 60.84(b) of 40 CFR Part 60;

(B) Multiply the conversion factor by the average sulfur dioxide concentration in the flue gases to obtain average sulfur dioxide emissions in lb/ton; and

(C) Report the average sulfur dioxide emission for each 3-hour period in excess of the emission standard set forth in 325 IAC 7-1 (formerly known as APC-13), in the quarterly summary.

(3) For nitric acid plants the owner or operator shall:

(A) Establish a conversion factor according to the procedures of Section 60.73(b) of 40 CFR Part 60;

(B) Multiply the conversion factor by the average nitrogen oxides concentration in the flue gases to obtain nitrogen oxides emissions in lb/ton;

(C) Report the average nitrogen oxides for each averaging period in excess of the emission standard set forth in 325 IAC 10-1 (formerly known as APC-17), in the quarterly summary.

(4) Alternate Data Reporting and Reduction Procedures.

(A) Alternate procedures for computing emission averages that do not require integration of data may be approved by the APCB if the owner or operator shows that his procedures are at least as accurate as those in this Rule [325 IAC 3-1].

(B) Alternative methods of converting pollutant concentration measurements to units of the emission standard may be approved by the APCB if the owner or operator shows that his procedures are at least as accurate as those in this Rule [325 IAC 3-1].

Rule 2. Source Sampling Procedures

Sec. 1. Applicability. This rule applies to any emissions testing performed in the State to determine compliance with applicable emission limits contained in this Title (Air Pollution Control Board Rules), or for any other purpose requiring review and approval by the APCB.

Sec. 2. Adoption of Federal Test Procedures. Emissions tests subject to this Rule shall be conducted in accordance with the procedures and analysis methods specified in Title 40, Code of Federal Regulations Part 60, Appendix A and Part 61, Appendix B, as in effect on December 2, 1981. Such test methods, equipment, calibration requirements, and analysis must be strictly followed unless otherwise approved by the Board or the Technical Secretary. If any test method is

revised as contained in the Code of Federal Regulations, this Rule is subject to change pursuant to IC 4-22-2.

Sec. 3. Requirements Prior to Conducting Tests. (a) When a test is to be performed by any person other than staff, a test protocol form shall be completed and received by the Board no later than 35 days prior to the intended test date. Such test protocol shall be on a form approved by the Board. Any special or unique information relative to the scheduled test shall be included with the form.

(b) After evaluating the completed test protocol form, the Board or the Technical Secretary.

(1) Inspect the test site.

(2) Require additional conditions, including, but not limited to the following:

(A) Reasonable modifications to the stack or duct to obtain acceptable test conditions.

(B) A pretest meeting to resolve an acceptable test protocol.

(C) Additional tests to allow for adverse conditions such as interferences, non-steady or cyclic processes.

(D) The keeping of process operating parameter records, operating logs or charts during the test.

(E) Conditions on control equipment operation to make it representative of future normal operation, or

(F) The recording of specified control equipment operating parameters during the test.

(c) If the Board or the Technical Secretary requires modifications to the test methods, analytical methods, operational parameters or other matters included in the test protocol, or if a pretest meeting is required, the source operator and the testing firm shall be notified by letter or telephone at least 25 days prior to the proposed test date. The source operator will receive notice of the acceptability of the test protocol from the Board or the Technical Secretary within 10 days of its receipt. If the source operator or test firm desires to change any previously submitted procedures or conditions, the Board must be notified of such change at least 25 days prior to the intended test date, and such changes cannot be made unless approved by the Board or the Technical Secretary prior to the test. Changes in the test protocol that result from emergency conditions

must be approved by an authorized on-site staff member.

(d) The Board or the Technical Secretary reserves the right to conduct any portion of the reference method tests. In such case, a 25-day notice of proper test procedures will be given to the company and their testing representative.

(e) The source operator must notify the Board of the actual test date at least two weeks prior to the date.

Sec. 4. Performance of Test. (a) Staff may observe the field test procedures and plant operation during the test.

(b) All tests shall be conducted while the source is operating at between 95% to 100% of its maximum operating capacity, or under other capacities or conditions specified and approved by the Board or the Technical Secretary. For the purpose of this rule, maximum operating capacity means the maximum design capacity of the source or other maximum operating capacities agreed to by the source and the Board or the Technical Secretary.

(c) Sources subject to Article 12 of this Title (New Source Performance Standards) shall be tested under conditions as specified in the applicable Rule.

(d) Calibration results of the various sampling components must be available for examination at the test site. The information must include dates, methods used, data and results. All components requiring calibration must be calibrated within 60 days prior to the actual test date. Post test calibrations must be performed on the components within 45 days after the actual test date or before the equipments' next field use whichever comes first. Components requiring calibration are listed in the Federal test methods specified in Section 2 above. Calibration need not be done between tests when several facilities at one location are tested in series, as long as the units are calibrated prior to the first test and after the last test in the series which is conducted at that site.

Sec. 5. Test Results and Reports. (a) All tests shall be reported to the Board or the Technical Secretary in the form of a test report containing the following information (which can be kept confidential upon request):

(1) Certification by team leader and reviewer.

(2) Introduction, containing:

(A) Date and type of tests,
(B) Type of process and control equipment.

(C) Plant name and location,

(D) Purpose of test, and

(E) Test participants and titles.

(3) Results summary, containing:

(A) Tabulated data and results of each test run, process weight rate or heat input rate, the stack gas flow rate, the measured emissions given in units consistent with the applicable emission limits, and the visible emissions or average opacity readings, and

(B) Allowable emission rate.

(4) Process information, including:

(A) Description of process and control device,

(B) Process flow diagram,

(C) Maximum design capacities,

(D) Fuel analysis and heat value for heat input rate determination,

(E) Process and control equipment operating conditions during tests,

(F) Discussion of variations from normal plant operations, and

(G) Stack height, exit diameter, volumetric flow rate (acfm), exit temperature, and exit velocity.

(5) Sampling information, including

(A) Description of sampling methods used,

(B) Brief discussion of the analytical procedures with justification for any variance from standard procedures.

(C) Specification of the number of sampling points, time per point, and total sampling time per run.

(D) Cross sectional diagram showing sampling points, diagram showing stack dimensions, sampling location and distance from the nearest flow disturbance upstream and downstream of the sampling points, and

(E) Sampling train diagram.

(6) Appendix, containing:

(A) Sampling and analytical procedures

(B) Results and calculations — One complete calculation using actual data for each type of test performed must be shown. Results must be stated to units consistent with the applicable emission limitation

(C) Raw production data signed by plant official

(D) Photocopies of all actual field data or original raw field data.

(E) Laboratory report with chain of custody shown.

(F) Copies of all calibration data.

(G) Applicable regulations showing emission limitation, and

(H) Copies of visible emissions observations or opacity monitor readings (for TSP tests).

(b) Unless previously agreed to in writing by the Board or the Technical Secretary, all test reports must be received by the Board within forty-five (45) days of the completion of the testing.

Sec. 6. Special Requirements for Testing Certain Pollutants. (a) Particulate matter tests shall be conducted in accordance with the following procedures:

(1) Method 5, Title 40 Code of Federal Regulations, Part 60, Appendix A, as in effect on December 2, 1981, or other procedures approved by the Board or the Technical Secretary shall be used.

(2) Visible emissions (VE) evaluation shall be performed in conjunction with a particulate emissions test by a qualified observer in accordance with the procedures contained in 325 IAC 5-1-4. VE readings shall be continuously recorded for at least 30 minutes per hour of sampling time for each sampling repetition. A variance from this requirement may be granted by the on-site staff person for one repetition only and provided that adverse conditions exist which would invalidate the VE readings. Sources equipped with continuous opacity monitors may submit the monitor's instantaneous or six-minute integrated readings during the sampling period, in lieu of performing VE observations, provided:

(A) The monitoring system meets the Performance Specifications Tests I as specified in 40 CFR 60, Appendix B as in effect on December 2, 1981, and

(B) The monitor readings submitted with the test include a zero and span calibration check at the start and end of each test.

(3) At least three (3) repetitions of the test must be performed under identical source operating conditions unless otherwise allowed by the Board or the Technical Secretary.

(4) During each of the repetitions, each sampling point shall be sampled for a minimum of two (2) minutes.

(5) The total test time per repetition shall be no less than sixty (60) minutes.

(6) The total sample volume per repetition shall be no less than thirty (30) dry standard cubic feet (dscf).

(7) The total particulate weight collected from the sampling nozzle, probe, cyclone (if used), filter holder (front half), filter and connecting glassware shall be reported. Particulate analysis of the impinger catch is not required unless specified by staff.

(b) Sulfur dioxide (SO₂) tests shall be conducted in accordance with the following procedures:

(1) Method 6 or Method 8, Title 40 Code of Federal Regulations, Part 60, Appendix A, as in effect on December 2, 1981, or other procedures approved by the Board or the Technical Secretary shall be used.

(2) At least three (3) repetitions of two (2) samples, each of Method 6 or three (3) repetitions of Method 8 performed under identical source operating conditions, shall constitute a test.

(3) During each of the repetitions for Method 8, each sampling point shall be sampled for a minimum of two (2) minutes.

(4) The total test time per repetition shall be as follows:

(A) Method 6 — a minimum of 20 minutes per run with a 30 minute interval between each run, or

(B) Method 8 — a minimum of 60 minutes per run.

(5) The total sample volume per repetition under Method 8 shall be no less than 40 dry standard cubic feet (dscf).

(c) Nitrogen oxide tests shall be conducted in accordance with the following procedures:

(1) Method 7, Title 40, Code of Federal Regulations, Part 60, Appendix A as in effect on December 2, 1981, or other procedures approved by the Board or the Technical Secretary shall be used.

(2) At least three (3) repetitions of four (4) samples each shall constitute a test.

(d) Volatile Organic Compounds (VOC) emissions tests shall be conducted in accordance with the following procedures:

(1) Method 25, Title 40 Code of the Federal Regulations, Part 60, Appendix A as in effect on December 2, 1981, or other procedures approved by the Board or duly authorized staff member shall be used for

the total non-methane organic (TNMO) emissions.

(2) At least three (3) duplicate samples must be collected and analyzed.

(3) The total test time per repetition shall be a minimum of sixty (60) minutes.

Sec. 7. Invalid Tests. Any tests not meeting the requirements of this Rule may be treated by staff and the Board as invalid for any and all purposes.

Sec. 8. Board Resolves Disputes. A source operator or testing firm may appeal to the Board any decision made by staff under the discretionary terms of this Rule. Any person desiring to make such an appeal shall notify staff of the matters to be appealed, and, if agreement cannot be reached, the matter shall be presented to the Board for a final determination. The Board may appoint one of its members to hear the matter and make recommendations for a final decision by the full Board.

ARTICLE 4. BURNING REGULATIONS

Rule 1. Open Burning

Sec. 1. Applicability—This Rule [325 IAC 4-1-] establishes standards for the open burning of material which would result in emissions of regulated pollutants and applies everywhere in the State. However, this Rule [325 IAC 4-1-] shall not apply in areas where acts permitted by Section 3 [325 IAC 4-1-3] or authorized by variance pursuant to Section 4 [325 IAC 4-1-4] are prohibited by other State and/or local laws, regulations, or ordinances such as IC 13-7-4-1(g).

Sec. 2. Prohibition—No persons shall open burn any material except as provided in Section 3 [325 IAC 4-1-3] or Section 4 [325 IAC 4-1-4].

Sec. 3. Exemptions. (a) The following types of fires are permitted:

(1) Fires celebrating Twelfth Night Ceremonies.

(2) Fires celebrating school pep rallies.

(3) Fires celebrating scouting activities.

(4) Camp fires.

(5) Residential burning—where residence contains four or fewer units. Burning shall be in a noncombustible container with enclosed sides a bottom, and a mesh covering with openings no larger than 1/4" square. Burning is prohibited in apartment complexes and mobile home parks.

(6) Farm burning—wood products derived from farming operations. Clearing operations (Section 4(a)(4) [325 IAC 4-1-4(a)(4)]) are not considered farm burning.

(7) Waste oil burning—where the waste oil has been collected in a properly constructed and located pit as prescribed in 310 IAC 7-1-37(A) (Rule 37A of the Division of Oil and Gas, Department of Natural Resources) at an oil well. Each oil pit may be burned once every two (2) months and all the oil must be completely burned within thirty (30) minutes after ignition.

(b) All exemptions shall be subject to the following:

(1) Only wood products shall be burned unless otherwise stated above.

(2) Fires shall be attended at all times until completely extinguished.

(3) If fires create an air pollution problem, a nuisance, or a fire hazard, they shall be extinguished.

(4) All residential, farm operation, and waste oil burning shall occur during daylight hours during which the fires may be replenished, but only in such a manner that nearly all of the burning material is consumed by sunset.

(5) No burning shall be conducted during unfavorable meteorological conditions such as temperature inversions, high winds, air stagnation, etc.

Sec. 4. Variances. (a) Burning with prior approval of the board or its designated agent may be authorized for the following:

(1) Emergency burning of petroleum products.

(2) Burning of refuse consisting of material resulting from a natural disaster.

(3) Burning for the purpose of fire training.

(4) Burning of natural growth derived from a clearing operation, i.e., removal of natural growth for change in use of the land.

(5) Burning of highly explosive or other dangerous materials.

(b) Burning not exempted by Section 3 [325 IAC 4-1-3] may be permitted with prior receipt of a variance application and approval of the Board. (*Air Pollution Control Board*)

Sec. 5. Liability—Any person who allows the accumulation or existence of

combustible material which constitutes or contributes to a fire causing air pollution shall not be excused from responsibility therefore on the basis that said fire was accidental or an act of God.

Rule 2. Incinerator

Sec. 1. Applicability—This Rule [325 IAC 4-2] establishes standards for the use of incinerators which emit regulated pollutants. This rule [325 IAC 4-2] does not apply to incinerators in residential units consisting of four or fewer families. All other incinerators are subject to this rule. [325 IAC 4-2].

Sec. 2. Stationary Incinerators—All stationary incinerators shall:

(1) Consist of primary and secondary chambers or the equivalent.

(2) Be equipped with a primary burner unless burning wood products.

(3) Comply with 325 IAC 5-1 (formerly known as APC 3) and 325 IAC Article 2 (formerly known as APC 19).

(4) Be maintained properly as specified by the manufacturer and approved by the Board or its designated agent.

(5) Be operated according to the manufacturer's recommendations and only burn waste approved by the Board or its designated agent.

(6) Comply with other state and/or local regulations or ordinances regarding installation and operation.

(7) Be operated so emissions of hazardous material including, but not limited to, viable pathogenic bacteria, dangerous chemicals or gases, or noxious odors are prevented

(8) Not emit particulate matter in excess of the following:

(A) Incinerators with a maximum refuse-burning capacity of 200 or more pounds per hour: 0.3 pounds of particulate matter per 1,000 pounds of dry exhaust gas at standard conditions as corrected to 50% excess air.

(B) All other incinerators: 0.5 pounds of particulate matter per 1,000 pounds of dry exhaust gas at standard conditions corrected to 50% excess air.

(9) Not create an air pollution problem, a nuisance or a fire hazard. If any of the above result, the burning shall be terminated immediately

Sec. 3. Portable Incinerators—All portable incinerators shall be subject to the following conditions:

(1) Approval of the Board or its designated agent must be obtained prior to operation at a new project site.

(2) Only wood products shall be burned.

(3) Merchantable material shall be salvaged where practicable.

(4) The local health department shall be notified prior to any burning.

(5) All burning shall be conducted under favorable meteorological conditions.

(6) Burning shall occur during daylight hours and all material shall be consumed by sunset.

(7) If burning creates an air pollution problem, a nuisance or a fire hazard, the burning shall be terminated immediately.

(8) The incinerator shall be maintained and operated according to the manufacturer's recommendations and in a manner approved by the Board or its designated agent.

(9) The installation and operation of such an apparatus shall comply with all other state and/or local regulations or ordinances.

(10) A portable incinerator shall comply with both 325 IAC 5-1 (formerly known as APC 3) and 325 IAC, Article 2 (formerly known as APC 19).

ARTICLE 5. OPACITY REGULATIONS

Rule 1. Opacity Limitations

Sec. 1. Applicability. (a) This rule [325 IAC 5-1] shall apply to all visible emissions (not including condensed water vapor) emitted by or from any facility or source except those sources or facilities for which specific visible emission limitations are established by 325 IAC, Article 11, 325 IAC, Article 12, or 325 IAC, Article 6.

(1) The requirements of Section 2(a)(1) [325 IAC 5-1-2(a)] shall apply to sources or facilities located in attainment areas for particulate matter, designated in 325 IAC 1.1-3 (formerly known as APC 22).

(2) The requirements of Section 2(a)(2) [325 IAC 5-1-2(a)(2)] shall apply to sources or facilities located in nonattainment areas for particulate matter as designated in 325 IAC 1.1-3 (formerly known as APC 22).

(b) Sources or facilities located in areas

designated as unclassifiable or attainment areas in 325 IAC 1.1-3 (formerly Regulation APC 22) which became subject to more stringent limitations as a result of said area being redesignated as a nonattainment area by the Board, shall comply with such limitations as expeditiously as practicable, but no later than December 31, 1982. No later than 60 days after the promulgation of the nonattainment designation in 325 IAC 1.1-3, all sources or facilities subjected to more stringent visible emission limitations by their redesignation shall submit to the Board for approval a schedule for attaining compliance with this Rule [325 IAC 5-1].

Sec. 2. Emission Limitations. (a) Visible emissions from any source or facility shall not exceed any of the following limitations. Unless otherwise stated, all visible emissions shall be observed in accordance with the procedures set forth in Section 4 [325 IAC 5-1-4] of this rule:

(1) Sources or facilities of visible emissions located in attainment areas for particulate matter shall meet the following limitations:

(A) Visible emissions shall not exceed, an average of 40% opacity in 24 consecutive readings.

(B) Visible emissions shall not exceed 60% opacity for more than a cumulative total of 15 minutes (60 readings) in a 6-hour period.

(2) Sources or facilities of visible emissions located in nonattainment areas shall meet the following limitations:

(A) Visible emissions shall not exceed, an average of 30% opacity in 24 readings.

(B) Visible emissions shall not exceed 60% opacity for more than a cumulative total of 15 minutes (60 readings) in a 6-hour period.

(3) Sources and facilities of visible emissions located in both attainment or nonattainment areas, for which an alternate visible emission limitation has been established pursuant to Section 5(b) [325 IAC 5-1-5(b)] herein, shall comply with said limitations in lieu of the limitations set forth in subsection 2(a)(1) and 2(a)(2) [subsections (a)(1) and (a)(2) of this section] preceding.

Sec. 3. Temporary Exemptions. (a) Boiler Startup and Shutdown—When building a new fire in a boiler, or shutting down a boiler, visible emissions may ex-

ceed the applicable opacity limit established in Section 2(a) [325 IAC 5-1-2(a)]; however, visible emissions shall not exceed an average of 60% opacity and emissions in excess of the applicable opacity limit shall not continue for more than 10 continuous minutes on one occasion in any 24-hour period.

(b) Cleaning Boilers—When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, visible emissions may exceed the applicable opacity limit established in Section 2(a) [325 IAC 5-1-2(a)]; however, visible emissions shall not exceed 60% opacity and visible emissions in excess of the applicable opacity limit shall not continue for more than five continuous minutes on one occasion in any 60-minute period. Such emissions shall not be permitted on more than three occasions in any 12-hour period.

(c) Facilities not temporarily exempted by Subsections (a) and (b) above may be granted special temporary exemptions by the Board of the same duration and type authorized therein provided that the facility proves to the satisfaction of the Board that said exemptions are needed and that during periods of startup and shutdown, owners and operators shall, to the extent practicable, maintain and operate any affected facility including air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Board, which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures and inspection of the source.

(d) Sources or facilities not exempted through subsections (a), (b), or (c) above may also be granted special exemptions by the Board, provided that the source or facility owner or operator proves to the satisfaction of the Board that said exemption is justifiable. Said exemption(s) may be of longer duration and may apply to other types of facilities not provided for in subsections (a) and (b) above.

Sec. 4. Procedure to Determine Compliance. (a) Determination of visible emissions from sources or facilities to which this Rule [325 IAC 5-1] applies may be

made in accordance with subsections (1) and (2) below.

(1) Determination of visible emissions by means of a qualified observer shall be made according to the following provisions (A) through (H).

(A) Position—The qualified observer shall stand at a distance sufficient to provide a clear view of the emissions with the sun, if visible, oriented in the 140° sector to his back. Consistent with maintaining the above requirement, the observer shall, as much as possible, make his observations from the position such that his line of vision is approximately perpendicular to the direction of the visible emissions (plume where applicable), and when observing opacity of emissions from rectangular outlets (e.g., monitors open baghouses, noncircular stacks), approximately perpendicular to the longer axis of the outlet. The observer's line of sight should not include more than one plume at a time when multiple stacks are involved, and in any case the observer should make his observations with his line of sight perpendicular to the longer axis of such a set of multiple stacks (e.g., stub stacks on baghouses).

(B) Field Records—The observer shall record the name of the plant, emission location, type of facility, observer's name and affiliation, and the date on a field data sheet. Time, estimated distance to the emission location, approximate wind direction, estimated wind speed, description of the sky conditions (presence and color of clouds), and visible emissions (plume where applicable) background are recorded on a field data sheet at the time opacity readings are initiated and completed.

(C) Observations—Opacity observations shall be made at the point of greatest opacity in that portion of the visible emissions, (plume where applicable) where condensed water vapor is not present. The observer shall not look continuously at the visible emissions, (plume where applicable) but instead shall observe the visible emissions, (plume where applicable) momentarily at 15-second intervals.

(D) Recording Observations—Opacity observations shall be recorded to the nearest 5% at 15-second intervals on an observational record sheet. A minimum of 24 observations shall be recorded. Each

momentary observation shall be deemed to represent the average opacity of emissions for a 15-second period.

(E) Determination of Opacity As An Average of 24 Consecutive Observations—Opacity shall be determined as an average of 24 consecutive observations recorded at 15-second intervals. Divide the observations recorded on the record sheet into sets of 24 consecutive observations. A set is composed of any 24 consecutive observations. Sets need not be consecutive in time and in no case shall two sets overlap. For each set of 24 observations, calculate the average by summing the opacity of the 24 observations and dividing this sum by 24. Record the average opacity on a record sheet. For the purpose of determining an alternate visible emission limit in accordance with Section 5(b) [325 IAC 5-5-5(h)] following, an average of 24 consecutive readings or more may be used to calculate the alternate visible emissions limit.

(F) Determination of Opacity As A Cumulative Total of 15 Minutes—For emissions from intermittent sources, opacity shall be determined in accordance with subsections (1), (2), (3), and the first sentence of (4). Each momentary observation shall be deemed to represent the average opacity of emissions for a 15 second period. All readings greater than the specified limit in Section 2 [325 IAC 5-1-2] shall be accumulated as 15 second segments for comparison with the limit.

(G) Attached Steam Plumes—When condensed water vapor is present within the plume as it emerges from the emission outlet, opacity observations shall be made beyond the point in the plume at which condensed water vapor is no longer visible. The observer shall record the approximate distance from the emission outlet to the point in the plume at which the observations are made.

(H) Detached Steam Plumes—When water vapor in the plume condenses and becomes visible at a distinct distance from the emission outlet, the opacity of emissions should be evaluated at the emission outlet prior to the condensation of water vapor and the formation of the steam plume.

(2) Determination of compliance with visible emission limitations established in this Rule [325 IAC 5-1] may also be made

in accordance with a source's or facility's continuous monitoring equipment, for any source or facility in compliance with the requirements of 325 IAC 3-1.

(b) If the compliance determination procedures set forth in subsection (1) and (2) preceding results in any conflict in visible emission readings, the determination made in accordance with subsection (2) above shall prevail for the purpose of compliance, provided that it can be shown that the continuous monitor has met the performance specifications as set forth in the U.S. EPA Federal Reference 40 CFR, Part 60, specifically Performance Specification 1.

Sec. 5. Special Considerations. (a) A violation of this Rule [325 IAC 5-1] shall constitute prima facie evidence of a violation of other applicable particulate emission control regulations. A violation of any such regulation can be refuted by a performance test conducted in accordance with paragraph (b), below. Such test shall refute the mass emission violation only if the source is shown to be in compliance with the allowable mass emission limit. An exceedance of the allowable opacity emission limit will not be treated as a violation if, during the test described in (b) below, the source demonstrates compliance with the allowable mass emission limit while simultaneously having visible emissions more than or equal to the reading at which the exceedance was originally observed.

(b) Establishment of Alternate Visible Emission Limits—The owner or operator of a source or facility which believes it can operate in compliance with the applicable mass emission limitation, but exceeds the limits specified in Section 2 [325 IAC 5-1-2] of this Rule, may submit a written petition to the Technical Secretary requesting that an alternate opacity limitation be established pursuant to the following provisions. Additionally, if the Board has issued a Notice of Violation to an owner or operator of a source or facility for violation of the applicable opacity limitation, such owner or operator may, propose in Notice of Violation resolution, to disprove said violation by establishing an alternate opacity limit pursuant to the following provisions. This alternate limit shall be based upon a mass emission performance test conducted according to a

method designated by the Board, and a visible emission test conducted simultaneously, according to Section 4 [325 IC 5-1-4] of this Rule. Where the Board determines there is no acceptable test method available, a request for an alternate visible emission limit shall be denied.

(1) The alternate emission limit shall be equal to that level of opacity at which the source or facility will be able, as indicated by the performance and opacity tests, to meet the opacity standard at all times during which the source or facility is meeting the mass emission limitation. However, the Board shall also reserve the right to determine the alternate visible emissions limit in the following manner:

(A) If a performance test of a source or facility demonstrates (i) that said source or facility is in compliance with the allowable mass emissions limit (as defined in 325 IAC 1.1.-1) at the time that the test is done, and; (ii) simultaneously, said source's or facility's test demonstrates that the allowable opacity emission limit is being exceeded, then, the enforceable opacity limitation shall be equal to that level of opacity at which the source or facility will be able as indicated by the performance and opacity tests to meet the opacity standard at all times during which the source or facility is meeting the mass emission limitation.

(B) If a performance test of a source or facility demonstrates (i) that said source or facility is in compliance with the allowable mass emission limit, and the test mass emission rate is within 10% of the allowable emissions limit for that source or facility, and; (ii) simultaneously, said source's or facility's test demonstrates that the opacity observed is below the allowable opacity emission limit, the enforceable opacity limitation shall be equal to that level of opacity at which the source or facility will be able as indicated by the performance and opacity tests, to meet the opacity standard at all times during which the source or facility is meeting the mass emission limitation.

(C) If a performance test of a source or facility demonstrates (i) that said source or facility is in compliance with the allowable mass emission limit, and the test mass emission rate is less than 90% of the allowable emissions limit and; (ii)

simultaneously, said source's or facility's test demonstrates that the opacity observed is below the allowable opacity emission limit, the enforceable opacity limitation shall remain the existing allowable opacity emission limitation for that source or facility.

(2) Compliance with 325 IAC 6-2 (formerly known as APC 4R), 325 IAC 6-3 (formerly known as APC 5), 325 IAC 11-1 (formerly known as APC 6), and 325 IAC 6-1 (formerly known as APC 23), and other applicable regulations must be demonstrated by the performance test.

(3) The Board may require a performance test in any case where it is necessary to determine the compliance status for a facility. However, the Board will not request a performance test for any facility which is known to be in compliance with the allowable opacity limitation.

(4) All alternate visible emission limits shall be established on a source or facility-specific basis. No limitation for any facility or source shall be established by reference to a similar or identical facility or source.

(5) The owner or operator of the source or facility shall notify the Board at least fifteen days prior to conducting a test for the purposes of demonstrating an alternate visible emission limit.

(6) A staff member who is a qualified observer, approved by the Board or other consultant approved by the Board shall be present during any performance tests.

(7) The cost of the performance test shall be at the expense of the owner or operator.

(8) Any alternate visible emission limit established for any source or facility shall not become effective until said limitation is established in the applicable operating permit. Said limitation will be incorporated, by amendment, into the operating permit for said source or facility and submitted to the U.S. EPA as a SIP revision.

(9) Where a visible emission limitation is based upon a New Source Performance Standard, any new limitation must comply with the provisions of said standard.

Sec. 6. Compliance Timetables—Sources newly subject to more stringent limitations at the promulgation date of this Rule [325 IAC 5 //] by Section 2 [325 IAC 5-2-1] shall comply with the compliance schedule of 325 IAC 6-1 (formerly known as APC 23).

Sec. 7. SIP Revision—Any exemptions given or provisions granted to this rule [325 IAC 5-1] by the Board in Sections 3 (c) [325 IAC 5-3-2(c)] or 5(b) [325 IAC 5-1-5(b)] shall be submitted to the U.S. EPA as revisions to the State Implementation Plan.

ARTICLE 6. PARTICULATE REGULATIONS

Rule 1. Nonattainment Area Limitations

Sec. 1. Applicability. Sources or facilities specifically listed in Appendix A [325 IAC 6-1-7] of this Rule shall comply with the limitations contained therein. Sources or facilities that are (1) located in the nonattainment counties listed in Appendix A [325 IAC 6-1-7], (2) but which sources or facilities are not specifically listed in Appendix A [325 IAC 6-1-7], and (3) have the potential to emit 100 tons or more of particulate matter per year or have actual emissions of 10 tons or more of particulate matter per year, shall comply with the limitations of Section 2 [325 IAC 6-1-2], hereof.

Sec. 2. Emission Limitations. (a) **General Sources**—Facilities not limited by paragraphs (b) through (g) below shall not allow or permit discharge to the atmosphere any gases which contain particulate matter in excess of 0.07 gram per dry standard cubic meter (g/dscm) (0.03 grain per dry standard cubic foot (dscf)). Where this limitation is more stringent than the applicable limitations of paragraphs (b) through (g) of this section, for facilities in existence prior to the applicability dates, or of a size not applicable to said paragraphs, emission limitations for those facilities shall be determined by the Board and will be established in accordance with the procedures set forth in paragraph (h) of this section.

(b) **Fuel Combustion Steam Generators**—No person shall operate a fossil fuel combustion steam generator (any furnace or boiler used in the process of burning solid, liquid, or gaseous fuel or any combination thereof for the purpose of producing steam by heat transfer) so as to discharge or cause to be discharged any gases unless such gases are limited to:

(1) A particulate matter content of no greater than 0.18 grams per million calo-

ries (0.10 pounds per million Btu) for solid fuel fired generators of greater than 63 million kilocalories (kcal) per hour heat input (250 million Btu);

(2) A particulate matter content of no greater than 0.63 grams per million calories (0.35 pounds per million Btu) for solid fuel fired generators of equal to or greater than 6.3 but less than or equal to 63 million kcal per hour heat input (25 but less than or equal to 250 million Btu);

(3) A particulate matter content of no greater than 1.08 grams per million calories (0.6 pounds per million Btu) for solid fuel fired generators of less than 6.3 million kcal per hour heat input (25 million Btu);

(4) A particulate matter content of no greater than 0.27 grams per million kcal (0.15 pounds per million Btu) for all liquid fuel fired steam generators.

(5) A particulate matter content of no greater than .01 grains per dry standard cubic foot for all gaseous fuel-fired steam generators.

(c) **Asphalt Concrete Plants**—The requirements of this provision shall apply to any asphalt concrete plant (any facility used to manufacture asphalt concrete by heating and drying aggregate and mixing with asphalt cement). An asphalt concrete plant is deemed to consist only of the following: driers, systems for screening, handling, storing, and weighing hot aggregate; systems for loading, transferring, and storing mineral filler; systems for mixing asphalt concrete; and the loading, transfer, and storage systems associated with emission control systems.

(1) No person shall operate the affected facilities of an asphalt concrete plant which existed on or prior to June 11, 1973, so as to discharge or cause to be discharged into the atmosphere any gases unless such gases are limited to:

(A) A particulate matter content of no greater than 230 mg per dscm (0.10 grain per dscf).

(d) **Grain Elevators**—No person shall operate a grain elevator (a grain elevator is defined as any plant or installation at which grain is unloaded, handled, cleaned, dried, stored or loaded) without meeting the provisions of this Section. Paragraph (1) below shall apply to any grain storage elevator located at any grain processing source which has a permanent

* **Rule 2. [Repealed]****Rule 2.1. Particulate Emission Limitations for Sources of Indirect Heating**

Sec. 1. Applicability. This rule establishes limitations for sources of indirect heating. (a) Particulate emissions from the combustion of fuel for indirect heating from all facilities located in Lake, Porter, Marion, Boone, Hamilton, Hendricks, Johnson, Morgan, Shelby, and Hancock Counties which were existing and in operation or which received permit to construct prior to the effective date of this rule (325 IAC 6-2.1) shall be limited by section 2 below.

(b) Particulate emissions from the combustion of fuel for indirect heating from all facilities not specified in (a) which were existing and in operation or which received permits to construct prior to the effective date of this rule (325 IAC 6-2.1) shall be limited by section 3 below.

(c) Particulate emissions from the combustion of fuel for indirect heating from all facilities receiving permits to construct on or after the effective date of this rule (325 IAC 6-2.1) shall be limited by section 4 below.

(d) If any limitation established by this rule (325 IAC 6-2.1) is inconsistent with applicable limitations contained in 325 IAC 6-1, then the limitations contained in 325 IAC 6-1 prevail.

(e) If any limitation established by this rule (325 IAC 6-2.1) is inconsistent with applicable limitations contained in 325 IAC article 12.1 (New Source Performance Standards) then the limitations contained in 325 IAC article 12.1 prevail.

(f) If any limitation established by this rule (325 IAC 6-2.1) is inconsistent with a limitation contained in a facility's construction or operation permit as issued pursuant to 325 IAC article 2 (Permit Review Regulations), then the limitations contained in the source's current permits prevail.

(g) If any limitation established by this rule (325 IAC 6-2.1) is inconsistent with a limitation required by 325 IAC article 2 (Permit Review Regulations) to prevent a violation of the Ambient Air Quality Standards set forth in 325 IAC 1.1-3, then the limitations required by 325 IAC article 2 prevail.

(h) The addition of a new facility at a

source does not affect the limitations of the existing facilities unless such changes in the limitations are required by the provisions of 325 IAC article 2 or 325 IAC 6-1.

Sec. 2. Emission limitations for facilities specified in 325 IAC 6-2.1-1(a). (a) Particulate emissions from existing indirect heating facilities located in the specified counties shall be limited by the following equation:

$$Pt = \frac{0.87}{Q^{0.16}}$$

Where:

Pt = Pounds of particulate matter emitted per million Btu (lb/mmBtu) heat input.

Q = Total source maximum operating capacity rating in million Btu per hour (mmBtu/hr) heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's operation permit application, except when some lower capacity is contained in the facility's operation permit, in which case, the capacity specified in the operation permit shall be used.

For Q less than 10 mmBtu/hr, Pt shall not exceed 0.6.

For Q greater than or equal to 10,000 mmBtu/hr, Pt shall not exceed 0.2. Figure 1 may be used to estimate allowable emissions.

(b) The emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall be calculated using the equation contained in subsection 2(a) where: Q shall reflect the total source capacity on June 8, 1972. The resulting Pt is the emission limitation for each facility existing on that date and will not be affected by the addition of any subsequent facility. The particulate emissions from all of the facilities which were in existence on June 8, 1972, may be allocated in any way among these facilities provided that they will not result in a significantly greater air quality impact level at any receptor than that which would result if the particulate emissions from each of these facilities were limited to Pt; and provided that the emission limitations for each facility are

specified in its operation permit. Significant impact levels are defined in 325 IAC 2-3, section 2(d).

(c) The emission limitations for those indirect heating facilities which began operation after June 8, 1972, and before the effective date of this rule (325 IAC 6-2.1), and those facilities which receive permits to construct prior to the effective date of this rule (325 IAC 6-2.1) shall be calculated using the equation contained in subsection 2(a) where: Q includes the capacity for the facility in question and the capacities for those facilities which were previously constructed or received prior permits to construct. The limitations for all previously permitted facilities do not change. The Q and Pt for each facility at a source which begins operation or receives a construction permit during this time period will be different.

Sec. 3. (a) Particulate emissions from indirect heating facilities existing and in operation before the effective date of this rule shall be limited by the following equation:

$$Pt = \frac{C X a X h}{76.5 X Q^{0.75} X N^{0.25}}$$

Where:

C = Maximum ground level concentration with respect to distance from the point source at the "critical" wind speed for level terrain. This shall equal 50 micrograms per cubic meter (ug/m³) for a period not to exceed a 60-minute time period.

Pt = Pounds of particulate matter emitted per million Btu heat input (lb/mmBtu).

Q = Total source maximum operating capacity rating in million Btu per hour (mmBTU/hr) heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's operation permit application, except when some lower capacity is contained in the facility's operation permit; in which case, the capacity specified in the operation permit shall be used.

N = Number of stacks in fuel burning operation.

a = Plume rise factor which is used to make allowance for less than theoretical

plume rise. The value 0.67 shall be used for Q less than or equal to 1,000 mmBtu/hr heat input. The value 0.8 shall be used for Q greater than 1,000 mmBtu/hr heat input.

h = Stack height in feet. If a number of stacks of different heights exist, the average stack height to represent "N" stacks shall be calculated by weighing each stack height with its particulate matter emission rate as follows:

$$h = \frac{\sum_{i=1}^N H_i \times p_a \times Q_i}{\sum_{i=1}^N p_a \times Q_i}$$

Where:

p_a = the actual controlled emission rate in lb/mmBtu using the emission factor from AP-42 or stack test data. Stacks constructed after January 1, 1971, shall be credited with GEP stack height only. GEP stack height shall be calculated as specified in rule 325 IAC 1.1-6.1

(b) The emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall be calculated using the equation contained in subsection 3(a) where: Q, N, and h shall include the parameters for all facilities in operation on June 8, 1972. The resulting Pt is the emission limitation for each facility existing on that date and will not be affected by the addition of any subsequent facility. The particulate emissions from all of the facilities which were in existence on June 8, 1972, may be allocated in any way among these facilities provided that they will not result in a significantly greater air quality impact level at any receptor than that which would result if the particulate emissions from each of these facilities were limited to Pt; and provided that the emission limitations for each facility are

specified in its operation permit. Significant impact levels are defined in 325 IAC 2-3 section 2(d).

(c) The emission limitations for those indirect heating facilities which began operation after June 8, 1972, and before the effective date of this rule (325 IAC 6-2.1), and those facilities which receive permits to construct prior to the effective date of this rule (325 IAC 6-2.1) shall be calculated using the equation contained in subsection 3(a) where: Q, N, and h shall include the parameters for the facility in question and for those facilities which were previously constructed or received prior permits to construct. The limitations for all previously permitted facilities do not change. The Q, N, h, and Pt for each facility at a source which begins operation or receives a construction permit during this time period will be different.

(d) Particulate emissions from all facilities used for indirect heating purposes which were existing and in operation on or before June 8, 1972, shall in no case exceed 0.8 lb/mmBtu heat input.

(e) Particulate emissions from any facility used for indirect heating purposes which has 250 mmBtu/hr heat input or less and which began operation after June 8, 1972, shall in no case exceed 0.6 lb/mmBtu heat input.

Sec. 4. Emission limitations for facilities specified in 325 IAC 6-2.1-1(c) (a) Particulate emissions from indirect heating facilities constructed after the effective date of this rule (325 IAC 6-2.1) shall be limited by the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where:

Pt = Pounds of particulate matter emitted per million Btu (lb/mmBtu) heat input.

Q = Total source maximum operating capacity rating in million Btu per hour (mmBtu/hr) heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is

operated or the nameplate capacity, whichever is specified in the facility's permit application, except when some lower capacity is contained in the facility's operation permit; in which case, the capacity specified in the operation permit shall be used.

For Q less than 10 mmBtu/hr, Pt shall not exceed 0.6.

For Q greater than or equal to 10,000 mmBtu/hr, Pt shall not exceed 0.1. Figure 2 may be used to estimate allowable emissions.

(b) As each new indirect heating facility is added to a plant Q will increase. As a result, the emission limitation for each progressively newer facility will be more stringent until the total plant capacity reaches 10,000 mmBtu/hr after which the emission limit for each newer facility will be 0.1 lb/mmBtu heat input. The rated capacities for facilities regulated by article 12.1, New Source Performance Standards, shall be included when calculating Q for subsequent facilities.

Rule 3. Process Operations

Sec. 1. Applicability—This Rule [325 IAC 6-3] establishes emission limitations for particulate emissions from process operations located anywhere in the State. The following processes and their attendant emissions are exempt from this Rule [325 IAC 6-3]:

- (1) Combustion for indirect heating
- (2) Incinerators
- (3) Open burning
- (4) Existing Foundry Cupolas

If any limitation established by this Rule [325 IAC 6-3] is inconsistent with applicable limitations contained in 325 IAC 6-1 (formerly known as APC 23), or contained in 325 IAC, Article 12 (New Source Performance Standards), then the limitation contained herein shall not apply; but the limit in such sections shall apply.

Sec. 2. Emission Limitations. (a) Cement Kilns—No owner or operator of a cement manufacturing operation commencing operation prior to December 6, 1968, equipped with electrostatic

precipitators, bag filters or equivalent gas-cleaning devices shall cause, allow or permit any discharge to the atmosphere any gases containing particulate matter in excess of:

(1) $E = 8.6 P^{0.67}$, below 30 tons per hour of process weight;

(2) $E = 15.0 P^{0.50}$, over 30 tons of process weight.

Where E = emission rate in pounds/hour and P = process weight in tons/hour.

(b) Catalytic Cracking Units—The owner or operator of a catalytic cracking unit commencing operation prior to December 6, 1968, and which is equipped with cyclone separators, electrostatic precipitators, or other gas-cleaning systems shall recover 99.97% or more of the circulating catalyst or total gas-borne particulate.

(c) Process Operations—No person shall operate any process so as to produce, cause, suffer or allow particulate matter to be emitted in excess of the amount shown in the following table.

Allowable Rate of Emission Based on Process Weight Rate¹

Process Weight Rate		Rate of Emission		Process Weight Rate		Rate of Emission	
Lbs./Hr	Tons/Hr	Lbs./Hr	Tons/Hr	Lbs./Hr	Tons/Hr	Lbs./Hr	Tons/Hr
100	0.05	0.551		16,000	8.00	16.5	
200	0.10	0.877		18,000	9.00	17.9	
400	0.20	1.40		20,000	10.00	19.2	
600	0.30	1.83		30,000	15.00	25.2	
800	0.40	2.22		40,000	20.00	30.5	
1,000	0.50	2.58		50,000	25.00	35.4	
1,500	0.75	3.38		60,000	30.00	40.0	
2,000	1.00	4.10		70,000	35.00	41.3	
2,500	1.25	4.76		80,000	40.00	42.5	
3,000	1.50	5.38		90,000	45.00	43.6	
3,500	1.75	5.96		100,000	50.00	44.6	
4,000	2.00	6.52		120,000	60.00	46.3	
5,000	2.50	7.58		140,000	70.00	47.8	
6,000	3.00	8.56		160,000	80.00	49.0	
7,000	3.50	9.49		200,000	100.00	51.2	
8,000	4.00	10.40		1,000,000	500.00	69.0	
9,000	4.50	11.20		2,000,000	1,000.00	77.6	
10,000	5.00	12.00		6,000,000	3,000.00	92.7	
12,000	6.00	13.60					

¹Interpolation of the data in this table for process weight rates up to 60,000 lbs/hr shall be accomplished by use of the equation:

$$E = 4.10 P^{0.6}$$

and interpolation and extrapolation of the data for process weight rates in excess of 60,000 lbs/hr shall be accomplished by use of the equation:

$$E = 55.0 P^{0.1140}$$

where E = rate of emission in lbs/hr and P = process weight in tons/hr


When the process weight exceeds 200 tons/hour, the maximum allowable emission may exceed that shown in the table, provided the concentration of particulate matter in the discharge gases to the atmosphere is less than 0.10 pounds per 1,000 pounds of gases at standard conditions.

Rule 4. Fugitive Dust Emissions

Sec. 1. Applicability—This Rule [325 IAC 6-4] shall apply to all sources of fugitive dust. For the purposes of this Rule [325 IAC 6-4], "fugitive dust" means the generation of particulate matter to the extent that some portion of the material escapes beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located.

Sec. 2. Allowable Emissions—A source or sources generating fugitive dust shall be

P₁ ALLOWABLE POUNDS DUST/MILLION BTU INPUT



PARTICULATE EMISSION LIMITS

FIGURE 1




Figure 2
ASME STANDARD - GUIDE FOR CONTROL OF DUST EMISSION

(This page left blank)

APPENDIX C
Plant Operating Logs



STEAM BOILER PLANT OPERATING LOG

I. COMMAND SAC

II. BASE APPLICATION 200-100-116 1 4491

III. BUILDING NO. AND NAME 217 1011

IV. DATE 8/10/68

V. CONDENSATE TEMPERATURE J

VI. FEEDWATER PUMP PRESSURES (PSIG) K

VII. FEEDWATER TEMPERATURE L

VIII. MAKEUP WATER FLOW (GPH) M

BOILER NO.	FLUE GAS O ₂ (%)	FLUE GAS CO ₂ (%)	TEMP (DEGREE F)	FUEL OIL PRESS (PSIG)	FUEL OIL TEMP (°F)	FEDWATER HEATER PRESS (PSIG)	FEDWATER HEATER TEMP (°F)	FEEDWATER FLOW (GPH)	START	STOP	GALS
1	11.3	16.5	470	4	218	4	218	4740	450	293	205
2	11.3	16.5	470	4	218	4	218	4740	450	293	205
3	11.3	16.5	470	4	218	4	218	4740	450	293	205
4	11.3	16.5	470	4	218	4	218	4740	450	293	205
5	11.3	16.5	470	4	218	4	218	4740	450	293	205
6	11.3	16.5	470	4	218	4	218	4740	450	293	205
7	11.3	16.5	470	4	218	4	218	4740	450	293	205
8	11.3	16.5	470	4	218	4	218	4740	450	293	205
9	11.3	16.5	470	4	218	4	218	4740	450	293	205
10	11.3	16.5	470	4	218	4	218	4740	450	293	205

IX. PLANT ECONOMIZER EFFICIENCY (PERCENT) 79.5%

X. MAKEUP WATER (GALLONS) 4.0%

XI. TOTAL FUEL USED 72.7 TONS

XII. COAL - LBS. 45450

XIII. OIL - GALS. —

XIV. GAS - MCF. —

XV. PEAK DEMAND FACTOR (PERCENT) 95.9%

OPERATING DATA

SHIFT	START	STOP	BOILER NO.	TEMP (DEGREE F)	OPERATOR
FIRST SHIFT	5:01:15	14:05	1	470	W.C. G. DA
SECOND SHIFT	14:05	22:15	1	470	W.C. G. DA
THIRD SHIFT	22:15	5:00	1	470	W.C. G. DA

SIGNATURE OF CHIEF OPERATING ENGINEER W.C. G. DA

STEAM BOILER PLANT OPERATING LOG

BASE APPLICATION: 200-100-116 1 4491

BUILDING NO. AND NAME: 217 1011

DATE: 8/10/68

CONDENSATE TEMPERATURE: J

FEEDWATER PUMP PRESSURES (PSIG): K

FEEDWATER TEMPERATURE: L

MAKEUP WATER FLOW (GPH): M

PLANT ECONOMIZER EFFICIENCY (PERCENT): 79.5%

MAKEUP WATER (GALLONS): 4.0%

TOTAL FUEL USED: 72.7 TONS

COAL - LBS.: 45450

OIL - GALS.: —

GAS - MCF.: —

PEAK DEMAND FACTOR (PERCENT): 95.9%

OPERATING DATA:

SHIFT	START	STOP	BOILER NO.	TEMP (DEGREE F)	OPERATOR
FIRST SHIFT	5:01:15	14:05	1	470	W.C. G. DA
SECOND SHIFT	14:05	22:15	1	470	W.C. G. DA
THIRD SHIFT	22:15	5:00	1	470	W.C. G. DA

SIGNATURE OF CHIEF OPERATING ENGINEER: W.C. G. DA

DATE 9 MAR 53

DAILY STEAM BOILER PLANT OPERATING LOG

1. COMMAND SAC
2. BUILDING NO. AND NAME 225 BOP
3. BASE AND LOCATION CHINA K971

TIME HOUR	STEAM PRODUCED (1000 POUNDS)		FUELED D		FLUE GAS		FUEL OIL		FEEDWATER HEATER		FEEDWATER FLOW (GPM)		MAKEUP WATER FLOW (GPM)		COMBUSTION EFFICIENCY (%)	PLANT COMBUSTION EFFICIENCY (%)	TOTAL FUEL USED
	COAL - BTU/GAL	GAS - BTU/GAL	COAL - BTU/GAL	GAS - BTU/GAL	O ₂ OR CO ₂ (AM %)	TEMP (DEGREE F)	TEMP (DEGREE F)	TEMP (DEGREE F)	TEMP (DEGREE F)	START	STOP	START	STOP	START			
06:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
07:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
07:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
08:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
08:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
09:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
09:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
10:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
10:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
11:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
11:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
12:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
12:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
13:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
13:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
14:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
14:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
15:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
15:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
16:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
16:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
17:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
17:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
18:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
18:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
19:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
19:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
20:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
20:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
21:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
21:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
22:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
22:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
23:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
23:30	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500
24:00	5120	3305	540	540	540	212	212	418	565	500	500	500	500	500	500	500	500

OPERATING DATA	SECOND SHIFT	THIRD SHIFT	TOTAL
1. STEAM FLOW FINAL (DEGREE F)	501.25	51.778	553.028
2. STEAM FLOW START	496.46	51.778	548.238
3. TOTAL STEAM PRODUCED	411.162	51.778	462.94
4. STEAM FLOW PER UNIT OF FUEL	1318	2025	1543
5. SLOPE DOWN	1555.0453	1400	2955.0453
6. SLOPE UP	1555.0453	1400	2955.0453
7. SLOPE DAY	1555.0453	1400	2955.0453
8. FIREMAN	SCHEGLO, BERRY, WILSON	BOGARD	BOGARD, DEGRAND
9. TOTAL MAKEUP WATER DESIRED	38	38	76
10. MAKEUP WATER (PERCENT)	116.50220	116.50220	233.00440
11. YEAR DEMAND FACTOR (PERCENT)	73.50	73.50	73.50
12. YEAR DEMAND FACTOR (PERCENT)	103.40	103.40	103.40

1. TOTAL MAKEUP WATER DESIRED 38
 2. MAKEUP WATER (PERCENT) 116.50220
 3. YEAR DEMAND FACTOR (PERCENT) 73.50
 4. YEAR DEMAND FACTOR (PERCENT) 103.40
 5. SIGNATURE OF CHIEF OPERATING ENGINEER
 6. DATE
 7. AF FORM 1458 PREV. EDITION WILL BE USED
 8. COMMENTS: WTC O.C. 1625
 9. COMMENTS: ASHES 0800-1600
 10. COMMENTS: 116.50220
 11. COMMENTS: 73.50
 12. COMMENTS: 103.40
 13. COMMENTS: 1417.23788
 14. COMMENTS: 1907650.000
 15. COMMENTS: 73.50
 16. COMMENTS: 103.40

DAILY STEAM BOILER PLANT OPERATING LOG

TIME	STEAM PRODUCED (1000 LBS/H)			FUEL USED			FLUE GAS			FEEDWATER HEATER			FEEDWATER FLOW (G/H)			MAKE UP WATER FLOW (G/H)			FEEDWATER PUMP PRESSURES (PSIG)		
	A	B	C	COAL	OIL	GAS	CO ₂	O ₂	N ₂	TEMP (°F)	PRESS (PSIG)	START	STOP	START	STOP	START	STOP	START	STOP	START	STOP
0-10	105	5900	120	120	120	120	120	120	210	4	7:13	7:13	6:50	5:00	235	31	180	180	180	180	180
10-20	105	5700	115	115	115	115	115	115	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
20-30	105	6000	115	115	115	115	115	115	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
30-40	105	6200	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
40-50	105	6000	115	115	115	115	115	115	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
50-60	105	6500	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
60-70	105	6500	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
70-80	105	6200	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
80-90	105	6200	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
90-100	105	6200	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180
Avg	105	6200	120	120	120	120	120	120	210	4	7:13	7:13	5:00	5:00	205	31	180	180	180	180	180

STEAM FLOW		TOTAL	
FINAL (INTERIOR)	START	FINAL (INTERIOR)	START
510175	532412	532412	532412
518948	528446	528446	528446
436000	445600	445600	445600
TOTAL		1414558	

OPERATING DATA		SECOND SHIFT		THIRD SHIFT	
TIME	VALVE	TIME	VALVE	TIME	VALVE
12:37	1A00	12:37	1A00	12:37	1A00
12:37	1A00	12:37	1A00	12:37	1A00
12:37	1A00	12:37	1A00	12:37	1A00

TOTAL	
PLANT COMBUSTION EFFICIENCY (PERCENT)	PLANT BTU OUTPUT (Million)
83.5	147176224
4.7%	79 lbs

1. BUILDING NO. AND NAME: SAC
 2. DATE: 10/10/51
 3. OPERATOR: [Signature]
 4. SIGNATURE OF CHIEF OPERATING ENGINEER: [Signature]
 5. PREVIOUS EDITION WILL BE USED.

DAILY STEAM BOILER PLANT OPERATING LOG

DATE: 11 Mar 51

BUILDING NO. AND NAME: 233 RCHP

BASE AND LOCATION: GPER Tol 4:071

COMMAND: SAL

A	B		C		D		E		F		G		H		I		J				
	STEAM PRODUCED (1000 POUNDS)	COAL - BTU/LB	STEAM PRODUCED (1000 POUNDS)	COAL - BTU/LB	FLUE GAS O ₂ OR CO ₂ (AUG %)	BOILER NO.	TEMP (DIPPER)	FLUE GAS O ₂ OR CO ₂ (AUG %)	BOILER NO.	TEMP (DIPPER)	FUEL OIL PRESS (PSIG)	FUEL OIL TEMP (F)	FUEL OIL PRESS (PSIG)	FUEL OIL TEMP (F)	FEEDWATER FLOW (GPM)	FEEDWATER HEATER PRESS (PSIG)	FEEDWATER HEATER TEMP (F)	FEEDWATER FLOW (GPM)	MAKE UP WATER FLOW (GPM)	MAKE UP WATER FLOW (GPM)	
105	6337	105	6337	105	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	771	250	
106	6300	106	6300	106	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
107	6337	107	6337	107	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
108	6337	108	6337	108	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
109	6337	109	6337	109	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
110	6337	110	6337	110	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
111	6337	111	6337	111	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
112	6337	112	6337	112	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
113	6337	113	6337	113	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
114	6337	114	6337	114	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
115	6337	115	6337	115	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
116	6337	116	6337	116	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
117	6337	117	6337	117	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
118	6337	118	6337	118	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
119	6337	119	6337	119	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
120	6337	120	6337	120	12.0	1	12.0	1	214	6	214	6	214	771	6	214	6	214	250	250	
AVG	6337	AVG	6337	AVG	12.0	AVG	12.0	AVG	214	AVG	214	AVG	214	AVG	6	AVG	6	AVG	250	AVG	250

OPERATING DATA		SECOND SHIFT		THIRD SHIFT		TOTAL	
STEAM FLOW START	5:45:14	5:45:14	5:45:14	5:45:14	5:45:14	5:45:14	5:45:14
TOTAL STEAM PRODUCED	53247	53247	53247	53247	53247	53247	53247
COAL STEAM PER UNIT OF FUEL	53247	53247	53247	53247	53247	53247	53247
COOL DOWN	9:20	9:20	9:20	9:20	9:20	9:20	9:20
BLDG DOWN	9:20	9:20	9:20	9:20	9:20	9:20	9:20
OPERATION	WATER - WILEY - LINDSAY	WATER - WILEY - LINDSAY	WATER - WILEY - LINDSAY	WATER - WILEY - LINDSAY	WATER - WILEY - LINDSAY	WATER - WILEY - LINDSAY	WATER - WILEY - LINDSAY
PLANTMAN	W.C. + G.G. + DA	W.C. + G.G. + DA	W.C. + G.G. + DA	W.C. + G.G. + DA	W.C. + G.G. + DA	W.C. + G.G. + DA	W.C. + G.G. + DA
TOTAL HOURS OPERATION	11:40	11:40	11:40	11:40	11:40	11:40	11:40
ESTIMATES (CONTINUED ON REVERSE)	ASHES 845-1530	ASHES 845-1530	ASHES 845-1530	ASHES 845-1530	ASHES 845-1530	ASHES 845-1530	ASHES 845-1530
PLANT EFFICIENCY (%)	80%	80%	80%	80%	80%	80%	80%
PLANT OUTPUT (TONS)	506 TONS	506 TONS	506 TONS	506 TONS	506 TONS	506 TONS	506 TONS
PLANT DEMAND FACTOR (%)	107.6%	107.6%	107.6%	107.6%	107.6%	107.6%	107.6%

FORM 1450 PREVIOUS EDITION WILL BE USED.

SIGNATURE OF CHIEF OPERATING ENGINEER: [Signature]

DATE: 11 Mar 51

10/1/72

DAILY STEAM BOILER PLANT OPERATING LOG

A. BEAM PRODUCTION (1000 THRU)			B. FULL USE			C. COAL - STEAM			D. OIL - STEAM			E. GAS - STEAM			F. FLUE GAS			G. FUEL OIL			H. FEEDWATER			I. MAKE UP WATER			J. CONDENSATE			K. FEEDWATER PUMP DISCH			L. TREATMENT								
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36						
105	105	105	5000	5000	5000	4.83	181.0	5	110	110	110	3.0	3.0	3.0	110	110	110	2.8	2.8	2.8	1000	1000	1000	500	500	500	200	200	200	100	100	100	100	100	100	100	100	100			
105	105	105	5000	5000	5000	4.83	181.0	5	110	110	110	3.0	3.0	3.0	110	110	110	2.8	2.8	2.8	1000	1000	1000	500	500	500	200	200	200	100	100	100	100	100	100	100	100	100	100	100	100
105	105	105	5000	5000	5000	4.83	181.0	5	110	110	110	3.0	3.0	3.0	110	110	110	2.8	2.8	2.8	1000	1000	1000	500	500	500	200	200	200	100	100	100	100	100	100	100	100	100	100	100	100
105	105	105	5000	5000	5000	4.83	181.0	5	110	110	110	3.0	3.0	3.0	110	110	110	2.8	2.8	2.8	1000	1000	1000	500	500	500	200	200	200	100	100	100	100	100	100	100	100	100	100	100	100

M. PLANT CONSUMPTION			N. PLANT EFFICIENCY			O. TOTAL FUEL USED			P. TOTAL OUTPUT			Q. COAL - LBS.			R. OIL - GALS.			S. GAS - MCF		
37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57
874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874
874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874
874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874	874

DATE: 10/1/72

SIGNATURE OF CHIEF OPERATING ENGINEER: [Signature]

OPERATOR: [Name]

REMARKS (COLUMN OR OTHER):

1. REMARKS (COLUMN OR OTHER):

2. REMARKS (COLUMN OR OTHER):

3. REMARKS (COLUMN OR OTHER):

APPENDIX D
Coal Analysis

(This page left blank)



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0001
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION

CAN #5004
 BOILER # 5
 R041
 BYPASS

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	12.78	5.82	---
% ASH	5.90	6.37	6.76
% VOLATILE	32.79	35.40	37.59
% FIXED CARBON	48.53	52.41	55.65
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.74	0.80	0.85
BTU/LB.	11,906	12,857	13,651
MAF BTU/LB.	---	---	14,641
LBS SULFUR/MM BTU	0.62		
LBS WATER/MM BTU	10.73		
LBS ASH/MM BTU	4.96		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil
 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2709

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0002
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION
 CAN # 5005
 BOILER #5
 RUN 2
 BYPASS

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	13.93	6.39	---
% ASH	5.37	5.84	6.24
% VOLATILE	32.04	34.85	37.23
% FIXED CARBON	48.66	52.92	56.53
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.71	0.77	0.82
BTU/LB.	11,799	12,833	13,709
MAF BTU/LB.	---	---	14,621
LBS SULFUR/MM BTU	0.60		
LBS WATER/MM BTU	11.81		
LBS ASH/MM BTU	4.55		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil

 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0003
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION
 CAN # 5007
 BOILER # 5
 RUN 3
 BYPASS

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	12.58	6.02	---
% ASH	6.17	6.63	7.06
% VOLATILE	32.94	35.41	37.68
% FIXED CARBON	48.31	51.93	55.26
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.79	0.85	0.90
BTU/LB.	11,883	12,775	13,593
MAF BTU/LB.	---	---	14,625
LBS SULFUR/MM BTU	0.66		
LBS WATER/MM BTU	10.59		
LBS ASH/MM BTU	5.19		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil
 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0004
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION
 CAN # 5009
 BOILER # 5
 RUN 1
 SCRUBBER

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	12.42	5.32	---
% ASH	6.46	6.99	7.38
% VOLATILE	33.04	35.71	3.72
% FIXED CARBON	48.08	51.98	54.90
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.83	0.90	0.95
BTU/LB.	11,896	12,860	13,583
MAF BTU/LB.	---	---	14,664
LBS SULFUR/MM BTU	0.70		
LBS WATER/MM BTU	10.44		
LBS ASH/MM BTU	5.43		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED.

Kevin J. Weil
 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0005
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION
 CAN # 5011
 BOILER #5
 RUN 2
 SCRUBBER

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	14.37	5.25	---
% ASH	5.67	6.27	6.62
% VOLATILE	33.67	37.26	39.32
% FIXED CARBON	46.29	51.22	54.06
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.72	0.80	0.84
BTU/LB.	11,713	12,994	13,714
MAF BTU/LB.	---	---	14,685
LBS SULFUR/MM BTU	0.61		
LBS WATER/MM BTU	12.24		
LBS ASH/MM BTU	4.83		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil
 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0006
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION
 CAN # 5012
 BOILER # 5
 RUN 3
 SCRUBBER

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	12.97	5.46	---
% ASH	5.76	6.26	6.62
% VOLATILE	32.89	35.73	37.79
% FIXED CARBON	48.38	52.55	55.59
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.75	0.81	0.86
BTU/LB.	11,888	12,914	13,660
MAF BTU/LB.	---	---	14,627
LBS SULFUR/MM BTU	0.63		
LBS WATER/MM BTU	10.91		
LBS ASH/MM BTU	4.84		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED

Kevin J. Weil

 KEVIN J. WEIL



CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0007
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION

CAN # 5013
 BOILER #3
 RUN 1
 SCRUBBER

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	13.53	5.51	---
% ASH	6.04	6.60	6.98
% VOLATILE	33.01	36.07	38.17
% FIXED CARBON	47.42	51.83	54.85
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.73	0.79	0.84
BTU/LB.	11,785	12,878	13,629
MAF BTU/LB.	---	---	14,651
LBS SULFUR/MM BTU	0.62		
LBS WATER/MM BTU	11.48		
LBS ASH/MM BTU	5.12		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil
 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0008
 INVOICE JOB #: CB8434
 LOCATION #: 63120

IDENTIFICATION

CAN # 5014
 BOILER #3
 RUN 2
 SCRUBBER

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	14.14	6.07	---
% ASH	5.57	6.10	6.49
% VOLATILE	32.18	35.20	37.48
% FIXED CARBON	48.11	52.63	56.03
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.72	0.79	0.84
BTU/LB.	11,749	12,853	13,684
MAF BTU/LB.	---	---	14,634
LBS SULFUR/MM BTU	0.61		
LBS WATER/MM BTU	12.03		
LBS ASH/MM BTU	4.74		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil
 KEVIN J. WEIL



CORE LABORATORIES
CORE LABORATORIES, INC.
ANALYTICAL REPORT

2315 GLENVIEW AVE.
 EVANSVILLE, IN 47712
 (812) 424-2909

13-APR-88

DEPT. OF THE AIR FORCE
 305 CSG/DE
 GRISSOM A.F.B., IN 46971-500

FILE NUMBER: GA041188
 SAMPLE NO. : 0009
 INVOICE JOB #: C88434
 LOCATION #: 63120

IDENTIFICATION

CAN # 5017
 BOILER # 3
 RUN 3
 SCRUBBER

	AS RECEIVED BASIS	AIR DRIED BASIS	DRY BASIS
% MOISTURE	12.69	5.46	---
% ASH	6.26	6.78	7.17
% VOLATILE	33.35	36.11	38.20
% FIXED CARBON	47.70	51.65	54.63
TOTAL PERCENTAGE	100.00	100.00	100.00
% SULFUR	0.78	0.84	0.89
BTU/LB.	11,905	12,891	13,635
MAF BTU/LB.	---	---	14,688
LBS SULFUR/MM BTU	0.66		
LBS WATER/MM BTU	10.66		
LBS ASH/MM BTU	5.26		

REDUCING ASH FUSION: 2700+ DEGREES F

RESPECTFULLY SUBMITTED,

Kevin J. Weil
 KEVIN J. WEIL

The analysis, opinions or interpretations contained in this report are based upon observations and material supplied by the client for whose exclusive and confidential use this report has been made. The calculations or opinions expressed herein represent the best judgment of Core Laboratories. Core Laboratories assumes no responsibility and makes no warranty or representation, expressed or implied, for the accuracy or operations or profitability of any oil, gas, coal or other mineral property, well or service in connection with which such report is prepared.

(This page left blank)

APPENDIX E
Boiler 3, Scrubber Stack Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: SCRUBBER A
STACK Stack diameter at ports: 5.0 (ft)



Distance A (ft) 7.0 (duct diameters) 1.4

Recommended number of traverse points as determined by
distance A: 20

Distance B (ft) 28 (duct diameters) 5.6

Recommended number of traverse points as determined by
distance B: 20

Number of traverse points used: 20



PARTICULATE SAMPLING DATA SHEET

TOTAL WT = 0.1140 g

RUN NUMBER	DATE	PLANT	BASE	SAMPLE BOX NUMBER	METER BOX NUMBER	Qw/Qm	Co	SCHEMATIC OF STACK CROSS SECTION		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		IMPINGER OUTLET TEMP (°F)
								STATIC PRESSURE (in H ₂ O)	STACK TEMP (°F)				IN (°F)	OUT (°F)	
B3 R1 Sewer	13 Mar 88	Heating	6/1550R	RAC	Nuclech			3 min / pt 20 pt	0.165	1.24	245.375	26	220		
								Blow set 48 min	0.175	1.32		27			
								leak check @ 9:45 = zero	0.18	1.36		29			
								PTS = 9.5564	0.19	1.36		26	235		
								Ts = 109	0.195	1.33		27			
								Tm = 30.17	0.17	1.31		28		20	
								AH = 1.23	0.13	1.15		27			
								TOT VOL = 30.922	0.13	1.00		29			
									0.11	0.85		33			
									0.155	1.19	261.265	34	240		
									0.16	1.23		30			
									0.17	1.31		30	237		
									0.175	1.35		30			
									0.17	1.31		31			
									0.165	1.24		30			
									0.155	1.20		31			
									0.14	1.16		32			
										1.09					

EQUATIONS

$$OR = OF + 460$$

$$H = \left[\frac{5130 \cdot F \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Tm \cdot Vp}{Tr}$$

End 276.817
start 245.295

PROBE LENGTH 6' glass
NOZZLE AREA (A) .300
Cp .84
DRY GAS FRACTION (FG) .28 (est)

TOTAL WT = 0.0525

PARTICULATE SAMPLING DATA SHEET

STATION PRESS 28.933	AMBIENT TEMP
HEATER BOX TEMP	OF
PROBE HEATER SETTING	In Hg
PROBE LENGTH	OF
NOZZLE AREA (A)	sq ft
Cp	
DRY GAS FRACTION (FD)	

EQUATIONS

$OR = OF + 460$

$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$

leak check: (25.5" Hg) new

end 308.515

SCHEMATIC OF STACK CROSS SECTION

3 min/pt 20 pt
 6-meter bit
 PSFS = 9.5161
 Ts = 105.3
 Tm = 37.0
 At = 1.26
 DT VOL = 31.41

RUN NUMBER B3K2 Sealed
DATE 13 Mar 88
PLANT heating
BASE Grissom
SAMPLE BOX NUMBER RAC
METER BOX NUMBER Nileed
Qw/Qm
Co

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T _s) (°R)				IN (°F)	AVG (T _m) (°R)		
10	1205	1.1	5	110	0.16	1.26	277.104	29	29	236	18
9		5	5	110	0.175	1.34		30	30	238	25
8		3	5	108	0.18	1.38		31	31	240	
7		5	5	103	0.185	1.44		32	32	243	
6		5	5	105	0.185	1.44		33	33	236	28
5		5	5	107	0.17	1.33		34	34	232	27
4		5	5	105	0.17	1.09		40	40	238	28
3		5	5	106	0.17	1.01		41	41	238	28
2		4.5	4	108	0.11	0.86		41	41	238	28
1		4	4	108	0.13	1.01	292.766	39	36	232	29
10	124030	4.5	5	108	0.175	1.17		40	36	232	29
9		5	5	104	0.175	1.38		42	37	249	23
8		5	5	104	0.18	1.42		43	37	250	29
7		5	5	103	0.18	1.42		43	36	259	29
6		5	5	103	0.16	1.27		44	37	267	30
5		5	5	103	0.16	1.27		44	38	273	30
4		5	5	102	0.145	1.27		44	38	268	34
3		5	5	101	0.145	1.15		44	38	268	34
2		5	5	101	0.14	1.11		44	38	270	35
1		5	5	101	0.14	1.11		44	38	270	35

PARTICULATE SAMPLING DATA SHEET

TOTPL WT = 0.1278 gm

RUN NUMBER B3R3 scrub	STATION PRESS 28.933	OP
DATE 13 Mar 88	HEATER BOX TEMP	in Hg
PLANT heating	PROBE HEATER SETTING	OP
BASE Frascan	PROBE LENGTH 6' glass	in
SAMPLE BOX NUMBER RAC	NOZZLE AREA (A) 0.302	sq ft
METER BOX NUMBER Newtech	Cp	
Qw/Qm	DRY GAS FRACTION (FD) 0.91	
Co	end 340,882	

SCHEMATIC OF STACK CROSS SECTION

3-mo-1-pt 20 pt

$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{Co} \right]^2 \cdot \frac{T_m \cdot V_p}{T_b}$
 $Q = 5 \text{ Hg} = 2.6 \text{ in Hg}$
 $P_{SB} = 10.3480$
 $T_b = 105$
 $T_m = 38.6$
 $\Delta H = 1.29$
 $TOT VOL = 31.828$

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		IMPINGER OUTLET TEMP (°F)
			(°F)	(T _b) (°F)				IN (°F)	OUT (°F)	
1	2443	0.1	110	113	1.00	309.054	33	33	27	
2	3	0.1	110	165	1.27		33	33	29	
3	6	0.1	109	117	1.32		37	33	29	
4	9	0.1	107	175	1.36		39	34	30	
5	12	0.1	107	180	1.40		41	34	28	
6	15	0.1	106	185	1.41		42	35	28	
7	18	0.1	106	165	1.29		42	35	28	
8	21	0.1	105	116	1.26		43	36	28	
9	24	0.1	105	114	1.10		43	36	30	
10	27	0.1	105	116	1.25	324.881	41	36	30	
11	30	0.1	104	117	1.34		41	37	29	
12	3	0.1	101	185	1.42		42	36	28	
13	6	0.1	101	185	1.47		44	37	29	
14	9	0.1	101	185	1.47		44	37	29	
15	12	0.1	101	119	1.51		45	38	31	
16	15	0.1	102	117	1.35		45	38	30	
17	18	0.1	104	145	1.74		45	37	30	
18	21	0.1	106	113	1.02		46	38	30	
19	24	0.1	106	172	1.94		45	38	32	
20	27	0.1	106	172	1.94		45	38	32	

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverse)

BASE <i>05690110</i>	DATE <i>13 May 48</i>
BOILER NUMBER	
INSIDE STACK DIAMETER <i>60</i>	
Inches	
STATION PRESSURE <i>18.933</i>	
In Hg	
STACK STATIC PRESSURE <i>0.09</i>	
In H ₂ O	

SAMPLING TEAM

TRAVERSE POINT NUMBER	VELOCITY HEAD, V_p IN H ₂ O	$\sqrt{V_p}$ CYCLONE	STACK TEMPERATURE (°F)
10	0.17 <i>0.17</i>	15	112
9	.17	15	112
8	.18	2	111
7	.17	2	111
6	.19	0	110
5	.19	0	110
4	.18	10	111
3	.17	10	110
2	.15	20	110
1	.15	25	110
		<i>avg = 9.9</i>	
AVERAGE			

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE	DATE	RUN NUMBER
	13 mtr 88	B3R3 B3R1
BUILDING NUMBER	SOURCE NUMBER	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	12	0.3805	0.2867
ACETONE WASHINGS (Probe, Front Half Filter)			
BEAKER # 55	100.0700	100.0498	0.0202
BACK HALF (if needed)			
Total Weight of Particulates Collected			0.1140 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	152	100	52
IMPINGER 2 (H2O)	112	100	12
IMPINGER 3 (Dry)	1	0	1
IMPINGER 4 (Silica Gel)	208.70	203.25	5.5
Total Weight of Water Collected			70.5 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	6.0	6.2	6.2		6.1
VOL % O ₂	13.6	13.5	13.5		13.5
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE	DATE 13 MAR 84	RUN NUMBER B3R2
BUILDING NUMBER	SOURCE NUMBER	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER 13	0.3236	0.2867	0.0369
ACETONE WASHINGS (Probe, Front Half Filter) BEAKER # 6F	102.3552	102.3396	0.0156
BACK HALF (if needed)			
Total Weight of Particulates Collected			0.0525 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	151	100	51
IMPINGER 2 (H2O)	118	100	18
IMPINGER 3 (Dn)	3	0	3
IMPINGER 4 (Silica Gel)	238.32	203.25	35.1
Total Weight of Water Collected			107.1 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	6.0	6.0	6.0		6.0
VOL % O ₂	14.0	14.0	14.0		14.0
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100 - % CO₂ - % O₂ - % CO)

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE	DATE 13 MAR 55	RUN NUMBER B3R3
BUILDING NUMBER	SOURCE NUMBER	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER 14	0.3210	0.2902	0.0308
ACETONE WASHINGS (Probe, Front Half Filter) BEAKER # 1	98.8548	98.7578	0.0970
BACK HALF (if needed)			
Total Weight of Particulates Collected			0.1275 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	140	100	40
IMPINGER 2 (H2O)	120	100	20
IMPINGER 3 (Dry)	5	0	5
IMPINGER 4 (Silica Gel)	239.35	204.06	35.3
Total Weight of Water Collected			100.3 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	60	60	6.2		6.1
VOL % O ₂	14.2	14.4	14.2		14.3
VOL % CO					
VOL % N ₂					

APPENDIX F
Boiler 5, Bypass Stack Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: By Pass Stack diameter at ports: 5.5 (ft)



Distance A (ft) 11.5 (duct diameters) 2.1

Recommended number of traverse points as determined by distance A: 12

Distance B (ft) 39.5 (duct diameters) 7.2

Recommended number of traverse points as determined by distance B: 12

Number of traverse points used: 12



PARTICULATE SAMPLING DATA SHEET

DRY GAS FRACTION (FD) = 0.7042 g/d

TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	AVG (T _m) (°R)	OUT (°F)	
6	1100	0.09	2	332	0.09	1.21	905.344	55	55	55	236
5	2.5			321	0.070.1	1.42		55	55.5	56	248
	5			325	1.12	1.69		57	56.5	56	255
	10		2	330	1.13	1.85		58	57.5	57	269
	10		2	329	1.12	1.69		60	58.5	57	271
	15		2	331	1.12	1.69		60	58.5	57	271
	15		2	332	1.12	1.41		61	59	57	160
	20		2	331	0.09	1.27		60	59	57	271
	20		2	322	0.09	1.28		60	59	57	256
	25			321	1.14	1.43		61	59.5	58	41
	30			320	0.08	1.14		61	59.5	58	41
	30			320	1.14	1.43		60	59	57	230
6	1140		3	320	1.07	1.00	924.239	58	58	58	237
5	2.5			318	0.065	0.93		59	58.5	58	51
	5			318	0.07	1.00		59	58.5	58	51
	10			322	0.08	1.14		60	59	58	52
	10		3	323	0.08	1.14		60	58.5	59	52
	15			327	0.085	1.21		61	60	59	53
	15			329	0.105	1.49		63	61.5	60	53
	20			332	1.12	1.69		62	61	60	256
	20			334	1.12	1.69		64	62.5	62	240
	25			332	1.12	1.70		65	63.5	62	53
	25			330	1.12	1.70		65	63.5	62	53
OEHL	FORM 18			323	1.11	1.58		65	63.5	62	234
	MAY 78			323							51

SCHEMATIC OF STACK CROSS SECTION

5 m in / ft x 12 ft
 leak check @ 3" Hg = zero
 Heating Plant B5 Bypass

ASIS = 8.7994
 TS = 326
 Tm = 59.3
 ΔH = 1.41

$R = 9F + 460$

$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$

$T_m = 54.40$

$A_{(90)} = 1.41$

$R_{(55)} = 8.80$

$T_s = 326.21$

$V_m = 53.196$

$V_{(1)} = 47.05$

$C_o = 10.81$

TOTAL VOL = 33.196

end 938,540

STATION PRESS	29.188
HEATER BOX TEMP	
PROBE HEATER SETTING	
PROBE LENGTH	
NOZZLE AREA (M/D/A)	0.378"
Cp	1.84
DRY GAS FRACTION (FD)	~ 8.9%

PARTICULATE SAMPLING DATA SHEET

TOTAL WT = 0.8785 gr

AMBIENT TEMP _____ OF _____
 STATION PRESS 28.927 in Hg
 HEATER BOX TEMP _____ OF _____
 PROBE HEATER SETTING _____
 PROBE LENGTH _____ in
 NOZZLE AREA $\pi D^2/4$
 Cp _____
 DRY GAS FRACTION (FG) _____

$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_a}$
 $^{\circ}R = ^{\circ}F + 460$
 PSTS = 9.5871
 $T_m = 49.4$
 $T_a = 32.5$
 $\Delta H = 1.64$
 TOTAL VOL = 351.659
 end 992.324

SCHEMATIC OF STACK CROSS SECTION

5 mpppt 12 pt
 500t blow @ 7.5 min
 3.1 pitot line duct
 3.1 " " "
 leak @ 8" Hg = 3rd

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGING OUTLET TEMP (°F)
			(in H ₂ O)	(°F)				IN (°F)	OUT (°F)		
6	1330	0.09	3	323	0.09	1.23	956.665	41	40.5	257	37
	25		3	318	0.09	1.25		43	42		
5	5		4	320	0.105	1.45		45	42	260	40
	10		5	326	0.11	1.52		47	43	268	40
			5	326	0.11	1.52		50	43		
3	15		5.5	330	0.13	1.56		53	44	277	45
	20		6	331	0.135	1.80		53	44		
			6	332	0.14	1.93		55	45		47
1	25		6	329	0.14	1.95		56	46	237	
			6.5	320	0.14	1.95		57	46	257	48
6	1410	30	5	326	0.11	1.97		57	47		
	25		5	318	0.11	1.40		50	48	256	38
5	5		6	316	0.115	1.62		53	48	258	38
	10		6	324	0.12	1.68		54	48		
			7	324	0.12	1.68		53	49		
3	15		7	328	0.13	1.81		56	49		
	20		7	330	0.12	1.67		57	49		
			7	328	0.12	1.68		57	49	259	40
1	25		7	325	0.105	1.68		57	50		
			7	326	0.11	1.47		57	50	257	39
				326	0.11	1.54		57	50		

67

-0

TOTAL WTS 1.1613

PARTICULATE SAMPLING DATA SHEET

AMBIENT TEMP	OP
STATION PRESS	In Hg
HEATER BOX TEMP	OP
PROBE HEATER SETTING	
PROBE LENGTH	In
NOZZLE AREA (sq in)	
Cp	
DRY GAS FRACTION (FG)	

$OR = OP + 460$

$H = \left[\frac{5130 \cdot FG \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Tm}{Ts} \cdot Vp$

PSYS = 9.1249

Tm = 51.6

Ts = 322

AH = 1.50

TOT VOL = 33.943

end 26.458

SCHEMATIC OF STACK CROSS SECTION

Smin / ft 12 ft
 Leak check @ 7" = zero

TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP (°F)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP (°F)	SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
-----------------------	---------------------	--------------------------	-----------------	--------------------	---------------------------	---------------------------	---------------------	----------------------	---------------------------

6	1535	1.07	2	320	0.09	992.515	46	46	43
5	2.5		3	315	0.08		47	46	
4	5		3	319	0.10		48	46	
3	10		3	320	0.11		50	46	
3	15		3	322	0.12		52	47	
2	20		3	322	0.10		53	47	
1	25		3	323	0.10		54	47	
6	1615		4	326	0.09		55	47	
5	5		4	320	0.10		55	48	
4	10		3	320	0.085		56	48	
3	15		3	320	0.085		56	48	
2	20		4.5	319	0.10		52.5	49	
1	25		6	324	0.09		50.5	49	
6	1615		5.5	326	0.095		52	50	
5	5		6	324	0.10		57	50	
4	10		5.5	327	0.125		57	50	
3	15		6	327	0.13		58	51	
2	20		6	327	0.14		58	51	
1	25		6.5	327	0.13		59	51	
OEHL	FORM MAY 78		6.5	324	0.14		60	52	

4.48

2.11

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverses)

BASE <i>Grissom</i>	DATE <i>8 Mar 88</i>
BOILER NUMBER <i>B5 Bypass</i>	
INSIDE STACK DIAMETER <i>66"</i> Inches	
STATION PRESSURE <i>29.31 29.188</i> In Hg	
STACK STATIC PRESSURE <i>+ 0.09</i> 8% moist In H2O	
SAMPLING TEAM	

TRAVERSE POINT NUMBER	VELOCITY HEAD, V_p IN H2O	<i>cyclonic flow</i>	STACK TEMPERATURE (°F)
<i>Port A</i> 1	<i>0.09</i> ₂₁	<i>4</i>	<i>331</i>
2	<i>0.11</i> ₂₃	<i>1</i>	<i>331</i>
3	<i>0.11</i> ₂₃	<i>11</i>	↓
4	<i>0.13</i> ₂₅	<i>15</i>	
5	<i>0.135</i> ₂₆	<i>15</i>	
6	<i>0.11</i> ₂₃	<i>20</i>	<i>331</i>
<i>Port B</i> 1		<i>24 SB</i>	
2			
3			
4			
5			
6			
<i>actual d = 0.3982</i>			
<i>.375, .374, .374</i>			
<i>leak</i>			
<i>⊕ 2.7" leak check pitot lines</i>			
<i>⊖ 5.7" " " " "</i>			
AVERAGE			

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverse)

BASE GRASSOM	DATE 9/17/78
BOILER NUMBER B5 BYPASS	
INSIDE STACK DIAMETER 66" Inches	
STATION PRESSURE 28.927 In Hg	
STACK STATIC PRESSURE 0.09 In H2O	

SAMPLING TEAM

TRAVERSE POINT NUMBER	VELOCITY HEAD, v_p IN H ₂ O	$\sqrt{v_p}$ CYCLONES	STACK TEMPERATURE (°F)
6	0.08	19	316
5	0.09	15	320
4	0.07	16	318
3	0.11	10	316
2	0.13	0	322
1	0.14	6	323
4		AVG = 11	
AVERAGE			

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>GT/SSOM</i>	DATE <i>8 Mar 88</i>	RUN NUMBER <i>1</i>
-------------------------------	--------------------------------	-------------------------------

BUILDING NUMBER <i>Bypass #5</i>	SOURCE NUMBER
--	----------------------

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER <i>1</i>	<i>0.5558</i>	<i>0.2842</i>	<i>0.2716</i>
ACETONE WASHINGS (Probe, Front Half Filter) <i>BEAKER # 7</i>	<i>97.9631</i>	<i>97.5305</i>	<i>0.4326</i>
BACK HALF (if needed)			<i>0.7042</i>
Total Weight of Particulates Collected			<i>0.7042 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H ₂ O)	<i>102.2</i>	<i>100</i>	<i>2.2</i>
IMPINGER 2 (H ₂ O)	<i>138</i>	<i>100</i>	<i>38</i>
IMPINGER 3 (D ₂ O)	<i>5</i>	<i>0</i>	<i>5</i>
IMPINGER 4 (Silica Gel)	<i>202.30</i>	<i>200.45</i>	<i>1.85</i>
Total Weight of Water Collected			<i>47.05 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>10.3</i>	<i>10.4</i>	<i>10.4</i>		<i>10.4</i>
VOL % O ₂	<i>8.9</i>	<i>8.8</i>	<i>9.0</i>		<i>8.9</i>
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>Grissom</i>	DATE <i>9 Mar 88</i>	RUN NUMBER <i>Run # 2 B</i>	<i>163</i>
BUILDING NUMBER <i>Bypass # 5</i>		SOURCE NUMBER	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER <i>3</i>	<i>0.6766</i>	<i>0.2872</i>	<i>0.3894</i>
ACETONE WASHINGS (Probe, Front Half Filter) <i>BEAKER # 53</i>	<i>105.5764</i>	<i>105.0873</i>	<i>0.4891</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>0.8785 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>128</i>	<i>100</i>	<i>28.0</i>
IMPINGER 2 (H2O)	<i>112</i>	<i>100</i>	<i>12.0</i>
IMPINGER 3 (Dry)	<i>1.5</i>	<i>0</i>	<i>1.5</i>
IMPINGER 4 (Silica Gel)	<i>216.65</i>	<i>202.43</i>	<i>14.2</i>
Total Weight of Water Collected			<i>55.7 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>9.8</i>	<i>10.0</i>	<i>9.8</i>		<i>9.9</i>
VOL % O ₂	<i>9.6</i>	<i>9.5</i>	<i>9.6</i>		<i>9.6</i>
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>Grissom</i>	DATE <i>9 Mar 88</i>	RUN NUMBER <i>Run 3</i>	<i>#4</i>
-------------------------------	--------------------------------	-----------------------------------	-----------

BUILDING NUMBER <i>Baker 5 Bypass</i>	SOURCE NUMBER
---	----------------------

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER <i>#4</i>	<i>0.7671</i>	<i>0.2868</i>	<i>0.4803</i>
ACETONE WASHINGS (Probe, Front Half Filter) <i>BRIMMER # 60</i>	<i>99.7884</i>	<i>99.1084</i>	<i>0.6810</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>1.1613 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H ₂ O)	<i>113</i>	<i>100</i>	<i>13</i>
IMPINGER 2 (H ₂ O)	<i>118.5</i>	<i>100</i>	<i>18.5</i>
IMPINGER 3 (Dry)	<i>5</i>	<i>0</i>	<i>5</i>
IMPINGER 4 (Silica Gel)	<i>211.85</i>	<i>200.00</i>	<i>11.85</i>
Total Weight of Water Collected			<i>48.35 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>9.4</i>	<i>9.4</i>	<i>9.4</i>		<i>9.4</i>
VOL % O ₂	<i>10.2</i>	<i>10.2</i>	<i>10.1</i>		<i>10.2</i>
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

(This page left blank)

APPENDIX G
Boiler 5, Scrubber Stack Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: SCRUBBER A
STACK Stack diameter at ports: 5.0 (ft)



Distance A (ft) 7.0 (duct diameters) 1.4

Recommended number of traverse points as determined by
distance A: 20

Distance B (ft) 28 (duct diameters) 5.6

Recommended number of traverse points as determined by
distance B: 20

Number of traverse points used: 20



PARTICULATE SAMPLING DATA SHEET

TOTAL WT = 0.0695 gm

TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	AVG (1m) (°R)	OUT (°F)		
10	1000	1.23	5	105	0.28	2.20	261.836	40		40	249	16
2	5		5	105	0.30	2.36		41		40	259	11
3	6		5	105	0.31	2.44		43		40	269	0
4	12		5	105	0.30	2.37		44		41		0
5	15		5	107	0.30	2.31		45		41		0
4	18		5	107	0.26	2.05		47		42	263	4
3	21		5	107	0.23	1.82		47		42	262	4
2	24		4	107	0.22	1.65		48		42		8
10	1033		5	107	0.23	1.87	47.6	45		43		8
9	3		5	107	0.27	2.13		46		43		1
8	6		5	107	0.29	2.29		48		43	263	1
7	9		5	107	0.295	2.34		49		44		30
6	12		5	107	0.30	2.38		52		44	266	30
5	15		5	107	0.29	2.31		52		45		38
4	18		5	107	0.263	2.11		52		45	262	38
3	21		5	107	0.25	1.99		52		45		38
2	24		5	107	0.24	1.91		53		46	267	38
1	27		5	107	0.19	1.51		53		46	244	
	30	V										

OR = °F + 460

$$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$

PSIS = 12.29

T_s = 106.5

T_m = 45.0

ΔH = 2.12

TOT VOL = 40.455

and 67.291

SCHEMATIC OF STACK CROSS SECTION

3 min/ft 20 ft

6" dia

lead @ 6" Hg zero

RUN NUMBER: 65A1
 DATE: 10 Mar 83
 PLANT: Heating S (1) Weber
 BASE: FASSCOM
 SAMPLE BOX NUMBER: RAC
 METER BOX NUMBER: Nuted
 Qw/Qm

Co

DRY GAS FRACTION (FD) 28% (est)

1545 147.5 105

RUN NUMBER		AGAIN		PARTICULATE SAMPLING DATA SHEET		EQUATIONS		SCHEMATIC OF STACK CROSS SECTION		COIL 170.901		DRY GAS FRACTION (P _D)	
TRAVEL POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP (°F)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP IN (°F)	GAS METER TEMP OUT (°F)	IMPINGER OUTLET TEMP (°F)	AMBIENT TEMP	STATION PRESS	HEATER BOX TEMP	PROBE HEATER SETTING
10	0250	0.18	115	1.17	1.32	153.706	47	35.5	27	31	29.120		
9	3		113	1.17	1.60		48	36.5	27				
8	6		115	1.15	1.76		50	38	28				
7	12		115	1.23	1.80		51	40	29				
6	15		115	1.23	1.83		53	40	30				
5	14		115	1.18	1.83		53	41.5	32				
4	21		115	1.17	1.67		54	41.5	32				
3	24		115	1.19	1.51		54	41.5	31				
2	27		115	1.17	1.35		53	49.5	32				
1	30		109	1.145	1.15		54	50.5	32				

$OR = OF + 460$
 $H = \left[\frac{5130 \cdot P \cdot C_p \cdot A}{Co} \right] \cdot \frac{T_m \cdot V_p}{T_s}$
 6' Probe
 nozzle area (A)
 .300
 Cp
 .84
 Probe length
 6' Probe
 nozzle area (A)
 .300
 Cp
 .84
 Probe heater setting
 in Hg
 of
 of
 in
 sq ft

3 min / pt 20 pts
 pitch line 4.7
 3.3
 Ts = 113.2
 P = 10.45
 A = 1.49
 T_m = 44.3
 V_p = 32.67
 V₁₀ = 104

Main flow slow - note their
 36 mm - info inc fan slightly
 170.901

PARTICULATE SAMPLING DATA SHEET

TOTAL WTE 0.0664 g

RUN NUMBER	ASAIN
DATE	B5R3 scrub
PLANT	11 Mar 88
BASE	Heat Exchanger
SAMPLE BOX NUMBER	Grison
METER BOX NUMBER	RAC
Qw/Qm	Nitert
Co	

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	AVG (Tm) (°R)	OUT (°F)	
10	0915	1.18	110		1.75	171.055	45	45	45	36	
9	1.18		115		2.07		47	45	45	23	
8	6	5	112		2.06		48	46	46	24	
7	5	5	109		1.21		50	46	46	24	
6	14	5	107		1.23		50	46	47	24	
5	15	5	101		1.23		52	47	47	24	
4	18	5	100		1.45		52	47	47	24	
3	21	5	100		1.21		52	47	47	24	
2	24	5	115		1.25		52	47	47	24	
1	27	5	106		1.18		53	48	48	24	
10	0950	5	115		1.22	189.0	52	49	49	35	
9	3	5	106		1.25		53	49	49	35	
8	6	5	111		1.24		54	50	50	35	
7	9	5	115		1.23		54	50	50	35	
6	12	5.5	118		1.24		56	51	51	35	
5	15	6	117		1.23		56	50	50	35	
4	18	5.5	114		1.22		56	50	50	35	
3	21	5	110		1.20		56	51	51	35	
2	24	5	105		1.19		57	51	51	35	
1	27	4.5	103		1.16		56	52	52	35	

$R = °F + 460$
 $H = \left[\frac{5130 \cdot P \cdot C \cdot A}{C_c} \right]^2 \cdot \frac{T_m \cdot V_p}{T_a}$
 PSTS = 10.9207
 TS = 109.6
 Tm = 50.5
 ΔH = 1.67
 TOT VOL = 36.106

end 207.161

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverse)

BASE <i>Grasson</i>	DATE <i>10 Mar 88</i>
BOILER NUMBER <i>B5 Scrubber</i>	
INSIDE STACK DIAMETER <i>60"</i> Inches	
STATION PRESSURE <i>29.046</i> In Hg	
STACK STATIC PRESSURE <i>0.23</i> In H ₂ O	
SAMPLING TEAM	

TRAVERSE POINT NUMBER	VELOCITY HEAD, V _p IN H ₂ O	cyclonic flow (deg)	STACK TEMPERATURE (°F)
<i>10</i>	<i>0.26 0.25</i>	<i>25</i>	<i>30 105</i>
<i>9</i>	<i>0.31 0.285</i>	<i>10</i>	<i>32</i>
<i>8</i>	<i>0.32 0.285</i>	<i>5</i>	<i>32</i>
<i>7</i>	<i>0.32 0.295</i>	<i>0</i>	<i>32</i>
<i>6</i>	<i>0.295</i>	<i>10</i>	<i>32</i>
<i>5</i>	<i>0.30</i>	<i>0</i>	<i>33</i> ↓
<i>4</i>	<i>0.275</i>	<i>10</i>	<i>31 105</i>
<i>3</i>	<i>0.20</i>	<i>8</i>	<i>27</i>
<i>2</i>	<i>0.185</i>	<i>5</i>	<i>26</i>
<i>1</i>	<i>0.17</i>	<i>2</i>	<i>25</i> ↓
		<i>AVG = 7.5</i>	<i>AVG = 30</i>
<i>⊕ pilot</i>	<i>5.5</i> ✓		
<i>⊖ "</i>	<i>2.1</i> ✓		
<i>act d = 0.3015</i>			
<i>.300</i>			
<i>.299</i>			
<i>.300</i>			
AVERAGE			

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverses)

BASE <i>75504</i>	DATE <i>11/11/78</i>
BOILER NUMBER <i>B5 SCRUBBER</i>	
INSIDE STACK DIAMETER <i>60"</i> Inches	
STATION PRESSURE <i>29.120</i> In Hg	
STACK STATIC PRESSURE <i>0.18</i> In H ₂ O	
SAMPLING TEAM	

TRAVERSE POINT NUMBER	VELOCITY HEAD, V_p IN H ₂ O	F_p CYCLES PER MIN	STACK TEMPERATURE (°F)
<i>1</i>	<i>0.13</i>	<i>4</i>	<i>115</i> ↓
<i>2</i>	<i>0.16</i>	<i>6</i>	
<i>3</i>	<i>0.18</i>	<i>7</i>	
<i>4</i>	<i>0.185</i>	<i>9</i>	
<i>5</i>	<i>0.2195</i>	<i>0</i>	
<i>6</i>	<i>0.21</i>	<i>0</i>	
<i>7</i>	<i>0.205</i>	<i>5</i>	
<i>8</i>	<i>0.195</i>	<i>10</i>	
<i>9</i>	<i>0.195</i>	<i>10</i>	
<i>10</i>	<i>0.17</i>	<i>24</i>	
		<i>Avg = 7.5</i>	
AVERAGE			

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>Grisson</i>		DATE <i>10 Mar</i>		RUN NUMBER <i>BERI Jarubizer #5</i>	
BUILDING NUMBER <i>Boiler 5</i>			SOURCE NUMBER		
I. PARTICULATES					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER <i>#5</i>	<i>0.3154</i>	<i>0.2864</i>	<i>0.0290</i>		
ACETONE WASHINGS (Probe, Front Half Filter) <i>BEHLER # 16</i>	<i>98.7738</i>	<i>98.7333</i>	<i>0.0405</i>		
BACK HALF (If needed)					
			Total Weight of Particulates Collected		<i>0.0695 gm</i>
II. WATER					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H ₂ O)	<i>150</i>	<i>100</i>	<i>50</i>		
IMPINGER 2 (H ₂ O)	<i>120</i>	<i>100</i>	<i>20</i>		
IMPINGER 3 (Dry)	<i>3.5</i>	<i>0</i>	<i>3.5</i>		
IMPINGER 4 (Silica Gel)	<i>212.70</i>	<i>201.91</i>	<i>10.8</i>		
			Total Weight of Water Collected		<i>84.3 gm</i>
III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>7.4</i>	<i>7.4</i>	<i>7.6</i>		<i>7.5</i>
VOL % O ₂	<i>12.4</i>	<i>12.4</i>	<i>12.4</i>		<i>12.4</i>
VOL % CO					
VOL % N ₂					
Vol % N ₂ = (100% - % CO ₂ - % O ₂ - % CO)					

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>GT1550M</i>	DATE <i>11 Mar 88</i>	RUN NUMBER <i>AGAIN B5R2 scrub</i>
BUILDING NUMBER		SOURCE NUMBER

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER <i>8</i>	<i>0.3248</i>	<i>0.2886</i>	<i>0.0362</i>
ACETONE WASHINGS (Probe, Front Half Filter) <i>BRAKER # 2F</i>	<i>100.3628</i>	<i>100.3376</i>	<i>0.0252</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>0.0614 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>176</i>	<i>100</i>	<i>76</i>
IMPINGER 2 (H2O)	<i>118</i>	<i>100</i>	<i>18</i>
IMPINGER 3 (Dry)	<i>1.6</i>	<i>0</i>	<i>1.6</i>
IMPINGER 4 (Silica Gel) <i>238.9 tare 27.6</i>	<i>211.3</i>	<i>202.80</i>	<i>8.50</i>
Total Weight of Water Collected			<i>104.10 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>8.8</i>	<i>8.9</i>	<i>8.9</i>		<i>8.9</i>
VOL % O ₂	<i>10.6</i>	<i>10.5</i>	<i>10.5</i>		<i>10.5</i>
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100 - % CO₂ - % O₂ - % CO)

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>Grissom</i>	DATE <i>11 Mar 88</i>	RUN NUMBER <i>again B5R3 Scrubber</i>
BUILDING NUMBER	SOURCE NUMBER	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER <i>9</i>	<i>0.3332</i>	<i>0.2907</i>	<i>0.0425</i>
ACETONE WASHINGS (Probe, Front Half Filter) <i>BEAKER # 4F</i>	<i>98.4383</i>	<i>98.4144</i>	<i>0.0239</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>0.0664 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>174</i>	<i>100</i>	<i>74</i>
IMPINGER 2 (H2O)	<i>119</i>	<i>100</i>	<i>19</i>
IMPINGER 3 (Dry)	<i>2.2</i>	<i>0</i>	<i>2.2</i>
IMPINGER 4 (Silica Gel) <i>240.8 + air 27.6</i>	<i>213.2</i>	<i>203.28</i>	<i>9.9</i>
Total Weight of Water Collected			<i>105.1 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>10.0</i>	<i>10.0</i>	<i>10.0</i>		<i>10.0</i>
VOL % O ₂	<i>9.6</i>	<i>9.7</i>	<i>9.8</i>		<i>9.7</i>
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

(This page left blank)

APPENDIX H
EPA Computer Program Emissions Calculations

(This page left blank)

XROM "METH 5"

RUN NUMBER
BS R1 BP

METER BOX Y? RUN
1.0820 RUN

DELTA H? RUN
1.4100 RUN

BAR PRESS ? RUN
29.1800 RUN

METER VOL ? RUN
33.1960 RUN

NTR TEMP F? RUN
59.3000 RUN

% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN

STATIC HOH IN ? RUN
.0900 RUN

STACK TEMP.
326.0000 RUN

ML. WATER ? RUN
47.0500 RUN

IMP. % HOH = 5.8

% HOH=5.8

% CO2? RUN
10.4000 RUN

% OXYGEN? RUN
8.9000 RUN

% CO ? RUN

MOL WT OTHER? RUN

MWD =30.02
MW MET=29.32

SQRT PSTS ? RUN
8.7994 RUN

TIME MIN ? RUN
60.0000 RUN

NOZZLE DIA ? RUN
.3740 RUN

STK DIA INCH ? RUN
66.0000 RUN

- VOL NTR STD = 35.753
- STK PRES ABS = 29.19
- VOL HOH GAS = 2.21
- % MOISTURE = 5.87
- MOL DRY GAS = 0.942
- % NITROGEN = 80.70
- MOL WT DRY = 30.02
- MOL WT MET = 29.32
- VELOCITY FPS = 21.60
- STACK AREA = 23.76
- STACK ACFM = 30.789
- STACK BSCFM = 19.004
- % ISOXINETIC = 97.71

XROM "METH 5"

RUN NUMBER
BS R2 BP

METER BOX Y? RUN
1.0820 RUN

DELTA H? RUN
1.6400 RUN

BAR PRESS ? RUN
28.9270 RUN

METER VOL ? RUN
35.6590 RUN

NTR TEMP F? RUN
49.4000 RUN

% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN

STATIC HOH IN ? RUN
.0900 RUN

STACK TEMP.
325.0000 RUN

ML. WATER ? RUN
55.7000 RUN

IMP. % HOH = 6.3

% HOH=6.3

% CO2? RUN
9.9000 RUN

% OXYGEN? RUN
9.6000 RUN

% CO ? RUN

MOL WT OTHER? RUN

MWD =29.97
MW MET=29.21

SQRT PSTS ? RUN
9.5071 RUN

TIME MIN ? RUN
60.0000 RUN

NOZZLE DIA ? RUN
.3740 RUN

STK DIA INCH ? RUN
66.0000 RUN

- VOL NTR STD = 30.826
- STK PRES ABS = 28.93
- VOL HOH GAS = 2.62
- % MOISTURE = 6.33
- MOL DRY GAS = 0.937
- % NITROGEN = 80.50
- MOL WT DRY = 29.97
- MOL WT MET = 29.21
- VELOCITY FPS = 23.60
- STACK AREA = 23.76
- STACK ACFM = 33.758
- STACK BSCFM = 20.568
- % ISOXINETIC = 98.03

XROM "METH 5"

RUN NUMBER
BS R3 BP

METER BOX Y? RUN
1.0820 RUN

DELTA H? RUN
1.5000 RUN

BAR PRESS ? RUN
28.9270 RUN

METER VOL ? RUN
33.9430 RUN

NTR TEMP F? RUN
51.6000 RUN

% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN

STATIC HOH IN ? RUN
.0900 RUN

STACK TEMP.
322.0000 RUN

ML. WATER ? RUN
48.3500 RUN

IMP. % HOH = 5.8

% HOH=5.8

% CO2? RUN
9.4000 RUN

% OXYGEN? CLX RUN
2.0000 RUN

% CO ? RUN

MOL WT OTHER? RUN

MWD =29.91
MW MET=29.22

SQRT PSTS ? RUN
9.1249 RUN

TIME MIN ? RUN
60.0000 RUN

NOZZLE DIA ? RUN
.3740 RUN

STK DIA INCH ? RUN
66.0000 RUN

- VOL NTR STD = 36.785
- STK PRES ABS = 28.93
- VOL HOH GAS = 2.20
- % MOISTURE = 5.83
- MOL DRY GAS = 0.942
- % NITROGEN = 80.40
- MOL WT DRY = 29.91
- MOL WT MET = 29.22
- VELOCITY FPS = 22.54
- STACK AREA = 23.76
- STACK ACFM = 32.126
- STACK BSCFM = 19.754
- % ISOXINETIC = 96.71

XROM "MASSFLO"

RUN NUMBER
BS R1 BP

VOL NTR STD ? RUN
35.753 RUN

STACK BSCFM ? RUN
19.004.00 RUN

FRONT 1/2 MG ? RUN
704.20 RUN

BACK 1/2 MG ? RUN

F GR/BSCF = 0.30
F MG/MM = 695.55
F LB/HR = 49.51
F KG/HR = 22.46

→ 57.134 $\frac{4}{hr}$ @ 12% CO₂

XROM "MASSFLO"

RUN NUMBER
BS R2 BP

VOL NTR STD ? RUN
30.826 RUN

STACK BSCFM ? RUN
20.568.00 RUN

FRONT 1/2 MG ? RUN
878.50 RUN

BACK 1/2 MG ? RUN

F GR/BSCF = 0.35
F MG/MM = 799.04
F LB/HR = 61.56
F KG/HR = 27.92

→ 74.62 $\frac{4}{hr}$ @ 12% CO₂

XROM "MASSFLO"

RUN NUMBER
BS R3 BP

VOL NTR STD ? RUN
36.785 RUN

STACK BSCFM ? RUN
19.754.00 RUN

FRONT 1/2 MG ? RUN
1.161.30 RUN

BACK 1/2 MG ? RUN
0.00 RUN

F GR/BSCF = 0.49
F MG/MM = 1.114.86
F LB/HR = 82.49
F KG/HR = 37.42

→ 105.34 $\frac{4}{hr}$ @ 12% CO₂

XROM "METH 5"
 RUN NUMBER
 B5 R1 SC
 METER BOX Y? 1.0820 RUN
 DELTA H? 2.1200 RUN
 BAR PRESS ? 29.0460 RUN
 METER VOL ? 48.4550 RUN
 NTR TEMP F? 45.0000 RUN
 STATIC HOH IN ? .2300 RUN
 STACK TEMP. 106.5000 RUN
 ML. WATER ? 84.3000 RUN

XROM "METH 5"
 RUN NUMBER
 B5 R2 SC
 METER BOX Y? 1.0820 RUN
 DELTA H? 1.4900 RUN
 BAR PRESS ? 29.1200 RUN
 METER VOL ? 32.6900 RUN
 NTR TEMP F? 44.3000 RUN
 STATIC HOH IN ? .1800 RUN
 STACK TEMP. 113.2000 RUN
 ML. WATER ? 104.1000 RUN

XROM "METH 5"
 RUN NUMBER
 B5 R3 SC
 METER BOX Y? 1.0820 RUN
 DELTA H? 1.6700 RUN
 BAR PRESS ? 29.0000 RUN
 METER VOL ? 36.1060 RUN
 NTR TEMP F? 58.5000 RUN
 STATIC HOH IN ? .1800 RUN
 STACK TEMP. 109.6000 RUN
 ML. WATER ? 105.1000 RUN

XROM "MASSFLO"
 RUN NUMBER
 B5 R1 SC
 VOL NTR STD ? 44.667 RUN
 STACK BSCFM ? 29,941.00 RUN
 FRONT 1/2 MG ? 69.50 RUN
 BACK 1/2 MG ? RUN
 F GR/DSCF = 0.02
 F MG/MMM = 54.95
 F LB/HR = 6.16 = 7.9 @ 12302
 F KG/HR = 2.80

SAT % = 8.1

IMP. % HOH = 8.2

% HOH=8.1

% CO2?

7.5000 RUN

% OXYGEN?

12.4000 RUN

% CO ?

MWD =29.78

MW MET=28.75

SOFT PSTS ?

12.2900 RUN

TIME MIN ?

60.0000 RUN

NOZZLE DIA ?

.3000 RUN

STK DIA IMCH ?

60.0000 RUN

• VOL NTR STD = 44.667
 STK PRES ABS = 29.06
 VOL HOH GAS = 3.97
 % MOISTURE = 8.05
 MOL DRY GAS = 0.919
 % NITROGEN = 88.10
 MOL WT DRY = 29.78
 MOL WT MET = 28.75
 VELOCITY FPS = 38.53
 STACK AREA = 19.63
 STACK ACFM = 35.967.
 • STACK BSCFM = 29,941.
 % ISOKINETIC = 99.51

SAT % = 9.7

IMP. % HOH = 11.9

% HOH=9.7

% CO2?

8.9000 RUN

% OXYGEN?

10.5000 RUN

% CO ?

MWD =29.84

MW MET=28.69

SOFT PSTS ?

10.4500 RUN

TIME MIN ?

60.0000 RUN

NOZZLE DIA ?

.3000 RUN

STK DIA IMCH ?

60.0000 RUN

• VOL NTR STD = 36.178
 STK PRES ABS = 29.13
 VOL HOH GAS = 4.90
 % MOISTURE = 9.75
 MOL DRY GAS = 0.903
 % NITROGEN = 88.60
 MOL WT DRY = 29.84
 MOL WT MET = 28.69
 VELOCITY FPS = 25.96
 STACK AREA = 19.63
 STACK ACFM = 30.580.
 • STACK BSCFM = 24,755.
 % ISOKINETIC = 97.49

SAT % = 8.8

IMP. % HOH = 11.2

% HOH=8.8

% CO2?

10.0000 RUN

% OXYGEN?

9.7000 RUN

% CO ?

MWD =29.99

MW MET=28.93

SOFT PSTS ?

10.9207 RUN

TIME MIN ?

60.0000 RUN

NOZZLE DIA ?

.3000 RUN

STK DIA IMCH ?

60.0000 RUN

• VOL NTR STD = 39.329
 STK PRES ABS = 29.01
 VOL HOH GAS = 4.95
 % MOISTURE = 8.03
 MOL DRY GAS = 0.912
 % NITROGEN = 88.30
 MOL WT DRY = 29.99
 MOL WT MET = 28.93
 VELOCITY FPS = 27.07
 STACK AREA = 19.63
 STACK ACFM = 31.800.
 • STACK BSCFM = 26,135.
 % ISOKINETIC = 100.35

XROM "MASSFLO"

RUN NUMBER
 B5 R2 SC

VOL NTR STD ?

36.178 RUN

STACK BSCFM ?

24,755.00 RUN

FRONT 1/2 MG ?

61.40 RUN

BACK 1/2 MG ?

RUN

F GR/DSCF = 0.03

F MG/MMM = 59.93

F LB/HR = 5.56 = 7.5 @ 12302

F KG/HR = 2.52

XROM "MASSFLO"

RUN NUMBER

B5 R3 SC

VOL NTR STD ?

39.329 RUN

STACK BSCFM ?

26,135.00 RUN

FRONT 1/2 MG ?

66.40 RUN

BACK 1/2 MG ?

RUN

F GR/DSCF = 0.03

F MG/MMM = 59.62

F LB/HR = 5.84 = 7.0 @ 12302

F KG/HR = 2.65

XROM "METH 5"
 RUN NUMBER
 B3 R1 SC
 METER BOX Y? RUN
 1.0820 RUN
 DELTA H? RUN
 1.2300 RUN
 BAR PRESS ? RUN
 28.9330 RUN
 METER VOL ? RUN
 30.9220 RUN
 MTR TEMP F? RUN
 30.7000 RUN
 STATIC HOH IN ? RUN
 .0900 RUN
 STACK TEMP. RUN
 109.0000 RUN
 ML. WATER ? RUN
 70.5000 RUN

SAT z = 8.7

IMP. z HOH = 8.7

z HOH=8.7

z CO2? RUN
 6.1000 RUN
 z OXYGEN? RUN
 13.5000 RUN
 z CO ? RUN

MWD =29.52
 MW WET=28.52

SQRT PSTS ? RUN
 9.5564 RUN
 TIME MIN ? RUN
 60.0000 RUN
 NOZZLE DIA ? RUN
 .3000 RUN
 STK DIA INCH ? RUN
 60.0000 RUN

• VOL MTR STD = 34.922
 STK PRES ABS = 28.94
 VOL HOH GAS = 3.32
 z MOISTURE = 8.68
 MOL DRY GAS = 0.917
 z NITROGEN = 80.49
 MOL WT DRY = 29.52
 MOL WT WET = 28.52
 VELOCITY FPS = 23.09
 STACK AREA = 19.67
 STACK ACFM = 20.147
 • STACK BSCFM = 23.068
 z ISOKINETIC = 109.00

XROM "METH 5"
 RUN NUMBER
 B3 R2 SC
 METER BOX Y? RUN
 1.0820 RUN
 DELTA H? RUN
 1.2600 RUN
 BAR PRESS ? RUN
 28.9330 RUN
 METER VOL ? RUN
 31.4100 RUN
 MTR TEMP F? RUN
 37.0000 RUN
 STATIC HOH IN ? RUN
 .0900 RUN
 STACK TEMP. RUN
 105.3000 RUN
 ML. WATER ? RUN
 107.1000 RUN

SAT z = 7.8

IMP. z HOH = 12.6

z HOH=7.8

z CO2? RUN
 6.0000 RUN
 z OXYGEN? RUN
 14.0000 RUN
 z CO ? RUN

MWD =29.52
 MW WET=28.62

SQRT PSTS ? RUN
 9.5161 RUN
 TIME MIN ? RUN
 60.0000 RUN
 NOZZLE DIA ? RUN
 .3000 RUN
 STK DIA INCH ? RUN
 60.0000 RUN

• VOL MTR STD = 35.026
 STK PRES ABS = 28.94
 VOL HOH GAS = 5.04
 z MOISTURE = 7.01
 MOL DRY GAS = 0.922
 z NITROGEN = 80.00
 MOL WT DRY = 29.52
 MOL WT WET = 28.62
 VELOCITY FPS = 23.74
 STACK AREA = 19.63
 STACK ACFM = 27.974
 • STACK BSCFM = 23.299
 z ISOKINETIC = 109.28

XROM "METH 5"
 RUN NUMBER
 B3 R3 SC
 METER BOX Y? RUN
 1.0820 RUN
 DELTA H? RUN
 1.2900 RUN
 BAR PRESS ? RUN
 28.9330 RUN
 METER VOL ? RUN
 31.8200 RUN
 MTR TEMP F? RUN
 38.6000 RUN
 STATIC HOH IN ? RUN
 .0900 RUN
 STACK TEMP. RUN
 105.0000 RUN
 ML. WATER ? RUN
 100.3000 RUN

SAT z = 7.7

IMP. z HOH = 11.8

z HOH=7.7

z CO2? RUN
 6.1000 RUN
 z OXYGEN? RUN
 14.3000 RUN
 z CO ? RUN

MWD =29.55
 MW WET=28.65

SQRT PSTS ? RUN
 10.3480 RUN
 TIME MIN ? RUN
 60.0000 RUN
 NOZZLE DIA ? RUN
 .3000 RUN
 STK DIA INCH ? RUN
 60.0000 RUN

• VOL MTR STD = 35.381
 STK PRES ABS = 28.94
 VOL HOH GAS = 4.72
 z MOISTURE = 7.74
 MOL DRY GAS = 0.923
 z NITROGEN = 79.68
 MOL WT DRY = 29.55
 MOL WT WET = 28.65
 VELOCITY FPS = 25.81
 STACK AREA = 19.63
 STACK ACFM = 30.491
 • STACK BSCFM = 25.353
 z ISOKINETIC = 97.09

XROM "MASSFLOW"

RUN NUMBER
 B3 R1 SC
 VOL MTR STD ? RUN
 34.922 RUN
 STACK BSCFM ? RUN
 23.068.00 RUN
 FRONT 1/2 MG ? RUN
 114.00 RUN
 BACK 1/2 MG ? RUN

F CR/BSCF = 0.85
 F MG/MM = 115.28
 F LB/HR = 9.96
 F KG/HR = 4.52

→ 19.54 m @ 12% CO2

XROM "MASSFLOW"

RUN NUMBER
 B3 R2 SC
 VOL MTR STD ? RUN
 35.026 RUN
 STACK BSCFM ? RUN
 23.299.00 RUN
 FRONT 1/2 MG ? RUN
 52.50 RUN
 BACK 1/2 MG ? RUN

F CR/BSCF = 0.82
 F MG/MM = 52.93
 F LB/HR = 4.62
 F KG/HR = 2.10

→ 9.24 m @ 12% CO2

XROM "MASSFLOW"

RUN NUMBER
 B3 R3 SC
 VOL MTR STD ? RUN
 35.381 RUN
 STACK BSCFM ? RUN
 25.353.00 RUN
 FRONT 1/2 MG ? RUN
 127.00 RUN
 BACK 1/2 MG ? RUN

F CR/BSCF = 0.86
 F MG/MM = 127.56
 F LB/HR = 12.11
 F KG/HR = 5.49

→ 23.84 m @ 12% CO2

(This page left blank)

APPENDIX I
Calibration Data

(This page left blank)

METER BOX CALIBRATION DATA AND CALCULATION FORM

(English units)

Date 28 Oct 87

Meter box number Intest

Barometric pressure, $P_b = 29.575$ in. Hg Calibrated by Daly

Orifice manometer setting (ΔH), in. H ₂ O	Gas volume		Temperature				Time (θ), min	Y_i	$\Delta H C_i$, in. H ₂ O	
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F/R	Dry gas meter						
				Inlet (t_{d_i}), °F	Outlet (t_{d_o}), °F	Avg ^a (t_d), °F				
VAC 6 0.5	5	4.672	74 74	534 534	79 75	79 75	535.5	13 ²⁵ / ₆₀	1.072	2.056
6 1.0	5	4.684	73 74	533.5 533.5	85 81	75 81	540	9 ³² / ₆₀	1.078	2.096
6 1.5	10	9.376	73 74	533.5 533.5	90 86	90 86	543.75	15 ⁴⁰ / ₆₀	1.083	2.067
6 2.0	10	9.400	73 73	533 533	93 91	93 91	547	13 ⁴⁹ / ₆₀	1.086	2.126
6 3.0	10	9.441	73 73	533 533	97 95	97 95	550.5	11 ¹⁷ / ₆₀	1.086	2.126
6 4.0	10	9.433	74 73	533.5 533.5	99 97	98 87	553	9 ⁵⁵ / ₆₀	1.089	2.171
								Avg	1.082	2.11

$\frac{\Delta H, \text{in. H}_2\text{O}}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t + 460)}$	$\Delta H C_i = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	
1.0	0.0737	
1.5	0.110	
2.0	0.147	
3.0	0.221	
4.0	0.294	

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d .

POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number POST Date 12 APR 88 Meter box number NUTECH Plant Mc CLELLAN AFB
 Barometric pressure, $P_b = 21.74$ in. Hg Dry gas meter number 6840593 Pretest Y 1.082

Orifice manometer setting, (ΔH), in. H ₂ O	Gas volume		Temperature		Time (Θ), min	Vacuum setting, in. Hg	Y_i	Y_i
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F/ °K	Dry gas meter Average (t_d), °F/ °K				
7.5	10	9.725	76.765 / 24.593	84.88.5 / 29.52.5	22 57/60	7.5	1.094	$V_w P_b (t_d + 460)$ $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$
7.5	10	9.310	75.775 / 23.95	86.88 / 26.88	17 57/60	7.5	1.088	
7.5	10	9.350	76.771 / 23.9	87.91 / 27.91	16 53/60	7.5	1.093	
							$Y = 1.095$	OK

VAC
: Hg

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d

where

- V_w = Gas volume passing through the wet test meter, ft³.
- V_d = Gas volume passing through the dry gas meter, ft³.
- t_w = Temperature of the gas in the wet test meter, °F.
- t_{d_i} = Temperature of the inlet gas of the dry gas meter, °F.
- t_{d_o} = Temperature of the outlet gas of the dry gas meter, °F.

t_d = Average temperature of the gas in the dry gas meter, obtained by the average of t_{d_i} and t_{d_o} , °F.
 ΔH = Pressure differential across orifice, in. H₂O.

Y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.
 Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs;
 tolerance = pretest $Y \pm 0.05Y$.

P_b = Barometric pressure, in. Hg.
 Θ = Time of calibration run, min.

\bar{Y} TOLERANCE = PRETEST $Y \pm 0.05Y$
 = 1.095 \rightarrow 1.136

NOZZLE CALIBRATION DATA FORM

Wright Patterson

Date Dec 85 S MARS Calibrated by GARRISON

Nozzle identification number	Nozzle Diameter ^a			ΔD , ^b mm (in.)	D_{avg} ^c
	D_1 , mm (in.)	D_2 , mm (in.)	D_3 , mm (in.)		
0.375	0.375	0.374	0.374	0.001	0.374

where:

^a $D_{1,2,3}$ = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

^b ΔD = maximum difference between any two diameters, mm (in.), $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

^c D_{avg} = average of D_1 , D_2 , and D_3 .

NOZZLE CALIBRATION DATA FORM

Wright Patterson

Date ~~Dec 85~~ 10 MAR 88 Calibrated by GARRISON

Nozzle identification number	Nozzle Diameter ^a			ΔD , ^b mm (in.)	D_{avg} ^c
	D_1 , mm (in.)	D_2 , mm (in.)	D_3 , mm (in.)		
0.3	0.300	0.299	0.300	0.001	0.300

where:

^a $D_{1,2,3}$ = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

^b ΔD = maximum difference between any two diameters, mm (in.), $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

^c D_{avg} = average of D_1 , D_2 , and D_3 .

ANALYTICAL BALANCE CALIBRATION FORM

Balance name _____ Number _____

Classification of standard weights

Date	0.500 g	1.0000 g	10.0000 g	50.0000 g	100.0000 g	Analyst
Sartorius ID# FH4314/ F7821	0.51	1.01	9.97	50.00	99.63 99.58 99.82	MD 4 Mar 88
Mettler AE163	0.4999	1.0000	9.9996	49.9979	99.9963	MD 4 Mar 88
Mettler AE163		1.000				MD 5 Mar 88
Ohaus Triple Beam	0.50	0.95	10.00	50.00 50.10	100.05	8 Mar 88 MD
Ohaus	0.50					9 Mar MD
Ohaus	0.30					13 Mar MD
Ohaus	0.50					17 Mar MD
METTLER 163	0.4999	1.000	9.9997	49.9980	99.9965	21 MAR 88

Quality Assurance Handbook M5-5.2

ANALYTICAL BALANCE CALIBRATION FORM

Balance name _____ Number _____

Classification of standard weights

Date	0.500 g	1.0000 g	10.0000 g	50.0000 g	100.0000 g	Analyst
Sartorius 1702MP8	0.4999	0.9999	10.0001	50.0008	100.0022	MD 17 Mar 88
ID# FH 3029	0.4999	1.0000	10.0000	50.0001	100.0009	MD

Quality Assurance Handbook M5-5.2

DISTRIBUTION LIST

	Copies
HQ AFSC/SGPB Andrews AFB DC 20334-5000	1
HQ USAF/SGPA Bolling AFB DC 20332-6188	1
HQ SAC/SGPB Offutt AFB NE 68113-5001	1
USAF Regional Medical Center Wiesbaden/SGB APO New York 09220-5300	1
OL AD, USAFOEHL APO San Francisco 96274-5000	1
USAFSAM/TSK Brooks AFB TX 78235-5301	1
USAFSAM/EDH Brooks AFB TX 78235-5301	1
Defense Technical Information Center (DTIC) Cameron Station Alexandria VA 22319	2
HSD/EV Brooks AFB TX 78235-5501	1
HQ USAF/LEEV Bolling AFB DC 20330-5000	1
HQ AFESC/RDV Tyndall AFB FL 32403-6001	1
HQ SAC/DE Offutt AFB OH 68113-5001	1
USAF Hospital Grissom/SGPB Grissom AFB IN 46971-5300	5