

2

**DTIC FILE COPY**

USAFOEHL REPORT

88-149EQ0686MEF



AD-A204 505

**COMPLIANCE TESTING OF EIELSON AFB  
CENTRAL HEATING AND POWER PLANT,  
COAL FIRED BOILER NO. 3, EIELSON AFB AK**

JAMES A. GARRISON, Major, USAF, BSC

December 1988

Final Report

**DTIC**  
**ELECTE**  
15 FEB 1989  
**S D**  
**& E**

Distribution is unlimited; approved for public release

**USAF Occupational and Environmental Health Laboratory  
Human Systems Division (AFSC)  
Brooks Air Force Base, Texas 78235-5501**


## NOTICES

When Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government incurs no responsibility or any obligation whatsoever. The fact that the Government may have formulated, or in any way supplied the drawing, specifications, or other data, is not to be regarded by implication, or otherwise, as in any manner licensing the holder or any other person or corporation; or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

The mention of trade names or commercial products in this publication is for illustration purposes and does not constitute endorsement or recommendation for use by the United States Air Force.

The Public Affairs Office has reviewed this report, and it is releasable to the National Technical Information Service, where it will be available to the general public, including foreign nations.

This report has been reviewed and is approved for publication.


  
JAMES A. GARRISON, Maj, USAF, BSC  
Chief, Air Quality Function

  
SHELTON R. BIRCH, Colonel, USAF, BSC  
Chief, Consultant Services Division

Air Force installations may direct requests for copies of this report to: USAF Occupational and Environmental Health Laboratory (USAFOEHL) Library, Brooks AFB TX 78235-5501.

Other Government agencies and their contractors registered with the DTIC should direct requests for copies of this report to: Defense Technical Information Center (DTIC), Cameron Station, Alexandria VA 22304-6145.

Non-Government agencies may purchase copies of this report from: National Technical Information Service (NTIS), 5285 Port Royal Road, Springfield VA 22161

  
JAMES C. ROCK, Colonel, USAF, BSC  
Commander

## **DISCLAIMER NOTICE**

**THIS DOCUMENT IS BEST QUALITY PRACTICABLE. THE COPY FURNISHED TO DTIC CONTAINED A SIGNIFICANT NUMBER OF PAGES WHICH DO NOT REPRODUCE LEGIBLY.**

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE

ADA204505

REPORT DOCUMENTATION PAGE				Form Approved OMB No 0704-0188	
1a REPORT SECURITY CLASSIFICATION UNCLASSIFIED		1b RESTRICTIVE MARKINGS			
2a SECURITY CLASSIFICATION AUTHORITY NA		3 DISTRIBUTION/AVAILABILITY OF REPORT Distribution is unlimited; Approved for public release			
2b DECLASSIFICATION/DOWNGRADING SCHEDULE NA					
4 PERFORMING ORGANIZATION REPORT NUMBER(S) USAF O EHL REPORT 88- EQ0686MEF			5 MONITORING ORGANIZATION REPORT NUMBER(S)		
6a NAME OF PERFORMING ORGANIZATION USAF OCCUPATIONAL AND ENVIRONMENTAL HEALTH LABORATORY		6b OFFICE SYMBOL (if applicable) ECQ	7a NAME OF MONITORING ORGANIZATION		
6c ADDRESS (City, State, and ZIP Code) BROOKS AFB TX 78235-5501			7b ADDRESS (City, State, and ZIP Code)		
8a NAME OF FUNDING/SPONSORING ORGANIZATION Same as 6a		8b OFFICE SYMBOL (if applicable)	9 PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER		
8c ADDRESS (City, State, and ZIP Code)			10 SOURCE OF FUNDING NUMBERS		
			PROGRAM ELEMENT NO	PROJECT NO	TASK NO
					WORK UNIT ACCESSION NO
11 TITLE (Include Security Classification) Compliance Testing of Eielson AFB Central Heating and Power Plant, Coal Fired No. 3, Eielson AFB AK					
12 PERSONAL AUTHOR(S) Maj James A. Garrison					
13a TYPE OF REPORT Final		13b TIME COVERED FROM 12 TO 22 Jul		14 DATE OF REPORT (Year, Month, Day) Dec 1988	15 PAGE COUNT 139
16 SUPPLEMENTARY NOTATION					
17 COSATI CODES			18 SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP			
			Compliance Testing Eielson Source Emission Testing		
			Stack Sampling Particulates Boiler		
			Stack Emission(s) Garrison Air Pollution		
19 ABSTRACT (Continue on reverse if necessary and identify by block number) At the request of HQ AAC/SGPB, compliance testing for particulate and visible emissions was conducted on coal-fired boiler No. 3 in the Eielson AFB Central Heat and Power Plant on 12-22 July 88. The survey was conducted as a requirement for renewal of Alaska Department of Environmental conservation Air Quality Control permit to operate #8331-AA001. Boiler No. 3 was tested at capacities of 100,000 lbs steam/hr and 90,000 lbs steam/hr. Results indicate that boiler No. 3 passed the visible emissions standard, but failed the particulate emission standard. <i>Handwritten notes: Garrison, Alaska, Source Emission Testing (S-E-T)</i>					
20 DISTRIBUTION/AVAILABILITY OF ABSTRACT <input checked="" type="checkbox"/> UNCLASSIFIED/UNLIMITED <input type="checkbox"/> SAME AS RPT <input type="checkbox"/> OTIC USERS			21 ABSTRACT SECURITY CLASSIFICATION UNCLASSIFIED		
22a NAME OF RESPONSIBLE INDIVIDUAL James A. Garrison, Maj, USAF, BSC			22b TELEPHONE (Include Area Code) (512) 536-2891	22c OFFICE SYMBOL ECQ	

# CONTENTS

	Page
DD FORM 1473	i
Illustrations	iv
I. INTRODUCTION	1
II. DISCUSSION	1
A. Background	1
B. Site Description	2
C. Aplicable Standards	3
D. Sampling Methods and Procedures	4
III. CONCLUSIONS	10
IV. RECOMMENDATIONS	10
References	12
Appendix	
A Personnel Information	13
B Permit No. 8831-AA001	17
C State Regulations	29
D Plant Operating Data	39
E Boiler 2 Field Data, 120,000 lbs/hr, 14 July	43
F Boiler 3 Field Data, 100,000 lbs/hr, 17 July	53
G Boiler 3 Field Data, 100,000 lbs/hr, 18 July	69
H Boiler 3 Field Data, 90,000 lbs/hr, 19 July	85
I Boiler 3 Field Data, 90,000 lbs/hr, 20 July	101
J Acetone Blank Results and Emissions Calculations	117
K Calibration Data	127
L EPA Method 9 Certification Documentation	133
Distribution List	137



<b>Accession For</b>	
NTIS GRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
<b>Availability Codes</b>	
Dist	Avail and/or Special
<b>A-1</b>	

## Illustrations

Figure	Title	Page
1	Eielson AFB Central Heat and Power Plant	1
2	Steam Turbine Generator	2
3	Multiclone Dust Collector	3
4	Boiler 2 Stack During Testing	4
5	Exhaust Duct Transition	5
6	Exhaust Stack Duct System	6
7	Particulate Sampling Train	8
8	ORSAT Sampling Train	9
9	ORSAT Apparatus	9

## Table

1	Stack Emission Test Results	11
---	-----------------------------	----

## I. INTRODUCTION

On 12-22 Jul 1988, compliance emission testing for particulate and opacity of visible emissions was conducted on coal fired boilers 2 and 3 at the Eielson AFB Central Heating and Power Plant (CH&PP), by the Air Quality Function of the USAF Occupational and Environmental Health Laboratory (USAFOEHL). This survey was requested by HQ AAC/SGPB to determine visible and particulate emission compliance status with regards to the renewal of Alaska Dept. of Environmental Conservation (ADEC) Air Quality Control Permit to Operate No. 8331-AA001. Personnel involved with on-site testing are listed in Appendix A.

## II. DISCUSSION

### A. Background

On 7 January 1988 Eielson AFB requested that ADEC renew Air Quality Control Permit to Operate No. 8331-AA001 for the CH&PP shown in Figure 1. As a condition of the permit renewal process and prior to issue of the new Air Quality Control Permit to Operate No.




FIGURE 1: EIELSON AFB CENTRAL HEATING AND POWER PLANT

1-AA001 (Appendix B), ADEC required source testing of a representative boiler in accordance with Title 40 Code of Federal Regulations Part 60 (40 CFR 60) Appendix A, Methods 1 through 5 (determination of particulate emissions) and 9 (visual determination of the opacity of emissions) to determine the maximum steam load at which the boilers will meet the applicable emission standards. Permit No. 8831-AA001 limits the operation of the boilers to the maximum steam load at which the associated visible and particulate emissions meet the applicable standards.

To demonstrate and maintain compliance with Alaska Administrative Code, Title 18, Environmental Conservation, Chapter 50 - Air Quality Control (18 AAC 50) and other rules set forth by ADEC, Eielson AFB requested USAFOEHL assistance to: (1) determine particulate emissions from a representative boiler as specified in 40 CFR 60, Appendix A, Reference Methods 1-5, and (2) determine the opacity of visible emissions from the same boiler during Method 5 testing as specified in 40 CFR 60, Appendix A, Reference Method 9.


#### B. Site Description

The CH&PP operates a total of six boilers for electrical power and steam production:

<u>Boiler No./ Manufacturer</u>	<u>Steam Capacity (lb/hr)</u>	<u>Year Installed</u>	<u>Fuel</u>
1/Springfield Boiler Co.	120,000	1950	coal
2/Springfield Boiler Co.	120,000	1950	coal
3/Springfield Boiler Co.	120,000	1950	coal
4/Springfield Boiler Co.	120,000	1950	coal
5/Garrette and Schafer	120,000	1954	coal
6/Garrette and Schafer	120,000	1954	coal

The CH&PP also operates five steam turbine generators for electrical power production. The turbines range in size from 2500 KW to 10,000 KW. A typical turbine is shown in Figure 2.






**FIGURE 2: STEAM TURBINE GENERATOR**

All boilers are spreader-stoker fired units with each having forced-draft and induced-draft fans and mechanical fly-ash collection systems. The purpose of the forced-draft fan is to supply air for combustion and that of the induced-draft fan is to maintain a negative draft condition in the furnace part of the boiler for combustion, removal of gases, and to provide a positive static pressure at flue gas exhaust discharge points. Each unit is fitted with a steam-operated soot blower to remove fly-ash and soot from heat exchanger tubing.

Air pollution control consists of individual multiclone dust collectors on each boiler (Fig. 3). The multiclone dust collectors were manufactured by Western Precipitation Division - Joy Manufacturing Co. and consist of a number of cyclonic collectors operating in parallel. Each unit is located in the boiler exhaust duct upstream of the induced-draft fan.




**FIGURE 3: MULTICLONE DUST COLLECTOR**

The exhaust effluent from each boiler is ducted to a separate exhaust stack located on the roof of the CH&PP. Figure 4 shows the exhaust stack for boiler 1 during testing. All boiler exhaust stacks are similar to the one pictured in Figure 4.

#### C. Applicable Standards

The opacity, particulate and source testing regulations are defined under 18 AAC 50.050(a), 50.050(b) and 50.500 respectively (Appendix C). Paragraph 50.050(a) states that visible emissions, excluding condensed water vapor from an industrial process or fuel burning equipment, may not reduce visibility through the exhaust effluent by greater than 20% for a total of more than three minutes in any one hour.



**FIGURE 4: BOILER STACK DURING TESTING**

Under 18 AAC 50.050(b), particulate matter emitted from industrial processes or fuel burning equipment may not exceed, per cubic foot of exhaust gas corrected to standard conditions, 0.1 grains per dry standard cubic foot (gr/dscf) for steam generating plants burning as fuel: (1) coal, and in operation before July 1, 1972 or (2) coal, and rated less than 250 million Btu per hour heat input.


Permit to Operate No. 8831-AA001, Exhibit B, reiterates the visible and particulate emissions standards imposed by 18 ACC 50.050(a) and (b).

#### D. Sampling Methods and Procedures

The permit to operate for the CH&PP limits the operation of the boilers to the maximum steam load at which the associated visible and particulate emissions meet standards. We analyzed particulate emission data on site to determine the operating capacity which would meet emission standards.

18 AAC 500 and Permit No. 8831-AA001 require that all emissions tests be conducted in accordance with the procedures and analysis methods specified in 40 CFR 60, Appendix A, Methods 1-5 and 9. Therefore, test methods, equipment, sample train preparation, sampling and recovery, calibration requirements and quality assurance were done in accordance with the methods and procedures outlined in 40 CFR 60, Appendix A.

The boiler exhaust stacks are tapered and diverge from a 52 inch (in) outside diameter (OD) at the roof line to a 72 in OD at the top. The included divergent angle of the stack is approximately 7 degrees. The stack height is 14.2 feet (ft). Based on the relative small divergent angle, we considered the stacks to be straight ducts. Sampling ports were already in place and located 38 in above the roof. Prior to the stack, exhaust gases pass through the induced draft fan, rectangular ducting and a transition to the stack located just below the roof (Figure 5). Even though the sampling port location did not meet Method 1 criteria, the ADEC on-scene observer and the test team evaluated the duct system and made the decision to use the existing sample ports. Figure 6 provides a schematic of the exhaust stack and associated duct work. Based on the port location, stack diameter at the sample port location and type of sample (particulate), a maximum number of 24 traverse points were used for emission evaluation.



**FIGURE 5: EXHAUST DUCT TRANSITION**




FIGURE 6: EXHAUST STACK DUCT SYSTEM

Particulate samples were collected using the sampling train shown in Figure 7. The train consisted of a button-hook probe nozzle, heated inconel probe, heated glass filter, impingers and pumping and metering device. The nozzle was sized prior to each sample run so that the gas stream could be sampled isokinetically; in other words, the velocity at the nozzle tip was the same as the stack gas velocity at each point sampled. Flue gas velocity pressure was measured at the nozzle tip, using a Type-S pitot tube connected to a ten inch inclined-verticle manometer. Type K thermocouples were used to measure flue gas, as well as, sampling train temperatures. The probe was heated to minimize moisture condensation. The heated filter was used to collect particulate material. The impinger train (first, third and fourth impingers, modified Greenburg-Smith type; second impinger, standard Greenburg-Smith design) was used as a condenser to collect stack gas moisture. The pumping and metering system was used to control and monitor the sample gas flow rate.

The time for each sampling run was 60 minutes; therefore, the sampling time per traverse point was 2.5 minutes. These sample times were applicable for all runs except runs 2 and 3 on boiler 3 during testing at 100,000 lbs steam/hr on 17 July. A smaller nozzle size was used to reduce the total sample volume; however, this resulted in the isokinetic sampling rate being 115.5% and 110.9% for runs 2 and 3 respectively, values greater than the required 100 + 10% range for isokinetic sampling. Even though this would tend to bias the particulate sample low, the emission rates were not affected with regards to compliance. All subsequent runs, including the retest of boiler 3 at 90,000 lbs/hr were within the required isokinetic rate.

Prior to each sample run on a stack, a preliminary velocity pressure traverse was accomplished and cyclonic flow was determined. For acceptable flow conditions to exist in a stack, the average of the absolute value of the flow angle taken at each traverse point must be less than or equal to 20 degrees. The flow angle for the boiler 2 stack averaged 1.3 degrees and that for the boiler 3 stack averaged approximately 1.5 degrees.

During each sample run, a flue gas grab sample for orsat analysis (measures oxygen, and carbon dioxide for stack gas molecular weight determination and emissions correction) was taken. Orsat sampling and analysis equipment are shown in Figures 8 and 9. Flue gas moisture content, also needed for determination of gas molecular weight, was obtained during particulate sampling.

Testing was initially started on boiler 2 at the maximum rated steam output of 120,000 lbs/hr. However, the refractory in the boiler furnace fractured during the second test run of the Method 5 evaluation and testing of this unit was terminated. At the request of the ADEC on-scene observer, the data for the first test run is included in the test report at Appendix E.

Subsequent testing was accomplished on boiler 3 at steam output capacities of 100,000 lbs/hr and 90,000 lbs/hr. Typical boiler operating logs for the 100,000 lbs/hr (17 July) and 90,000 lbs/hr (20 July) test capacities are provided in Appendix D. These logs indicate hourly steam output and other operating parameters. We accomplished two complete Method 5 and Method 9 evaluations of this boiler at each of these operating capacities. One of the three runs which comprised a complete test included a soot blow. This is indicated on the field data sheets provided in Appendixes F-I.




FIGURE 7: PARTICULATE SAMPLING TRAIN




FIGURE 8: ORSAT SAMPLING TRAIN




FIGURE 9: ORSAT APPRATUS



Emission calculations were done using "Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators" (EPA-340/1-85-018) developed by the EPA's Office of Air Quality Planning and Standards, Research Triangle Park NC. This is our standard method for calculating emissions data. Emissions calculations are found in Appendix J. Calibration data are presented in Appendix K.

Method 9 determinations for opacity during this project were accomplished during each test run by a certified test team member. EPA Method 9 certification documentation is provided in Appendix L.

### **III. CONCLUSIONS**

Visible emissions averaged less than 10% for all runs except for time periods where soot blows occurred. Soot blows did cause opacity to exceed 20% but not for more than three-minute period. Visible emission observation forms are provided in Appendices E-I.

Table 1 provides operating parameters for boilers 2 and 3 during testing and the resultant particulate emission rates determined from these tests. Results indicate that the one test run conducted on boiler 2 showed the emissions rate was above the standard of 0.1 gr/dscf. However, this is inconclusive since Method 5 uses the average of the emission rates determined from three test runs as the reportable emission rate. Boiler 3 emissions were above the emission standard for each of the four Method 5 evaluations. Emission rates determined for each test run were above the standard except for run 2 on 20 July when boiler 3 was operating at 90,000 lbs/hr.

We believe that a primary factor in boiler 3 not meeting the emission standard was the physical quality of the coal entering the boiler. The coal should have had an aggregate size of about 3/4 inch; however, the largest aggregate size seen during testing was more on the order 1/4 - 1/2 inch along with a large quantity of very fine material. Coal which most closely matched the desired aggregate size was burned during run 2 of the boiler 3 evaluation on 20 July. As can be seen in Table 1, run 2 was the only test to show an emission rate below the standard.

### **IV. RECOMMENDATIONS**

It is our recommendation that boiler 3 be retested with emphasis on testing with a coal that meets the desirable physical requirements as closely as possible. All aspects of the system (boiler, particulate control devices, etc.) should also be evaluated for proper operation prior to testing.

TABLE 1

## STACK EMISSION TEST RESULTS

DATE	BOILER NO.	RUN NO.	BOILER OPERATING CAPACITY (1000 lbs steam/hr)	SOOT BLOW	PARTICULATE EMISSIONS (gr/dscf)*
14 JULY	2	1	120		0.15
17 JULY	3	1	100	X	0.21
17 JULY	3	2	100		0.15
17 JULY	3	3	100		0.14
					----- AVG = 0.17
18 JULY	3	1	100		0.16
18 JULY	3	2	100		0.14
18 JULY	3	3	100	X	0.29
					----- AVG = 0.20
19 JULY	3	1	90		0.10
19 JULY	3	2	90	X	0.23
19 JULY	3	3	90		0.11
					----- AVG = 0.15
20 JULY	3	1	90	X	0.11
20 JULY	3	2	90		0.09
20 JULY	3	3	90		0.13
					----- AVG = 0.11

\* gr/dscf = grains per dry standard cubic foot

## REFERENCES

1. "Standards of Performance for New Stationary Sources". Title 40, Part 60, Code of Federal Regulations, July 1, 1987.
2. Quality Assurance Handbook for Air Pollution Measurement Systems - Volume III, Stationary Source Specific Methods, U.S. Environmental Protection Agency, EPA-600/4-77-027-b, Research Triangle Park, North Carolina, December 1984.
3. Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators. U.S. Environmental Protection Agency, EPA-340/1-85-018, Research Triangle Park, North Carolina, May 1987.

(This page left blank)

APPENDIX A  
Personnel Information

(This page left blank)

1. USAFOEHL Test Team

Maj James Garrison, Chief, Air Quality Function  
Capt Tim Fagin, Consultant, Air Quality Engineer  
Capt Paul Scott, Consultant, Air Resources Meteorologist  
SSGT Dan Schillings, Industrial Hygiene Technician  
SGT Robert Davis, Environmental Engineering Technician

----

USAFOEHL/ECQ  
Brooks AFB TX 78235-5501

Phone: AUTOVON 240-2891  
Commercial (512) 536-2891

2. Eielson AFB on-site representatives

Col Dennis W. Franks	USAF Clinic Eielson/SG
MSGT L.S. Satterfield	USAF Clinic Eielson/SGPB
SRA Jay L. Dulik	USAF Clinic Eielson/SGPB
Ted W. Tisdale	343 CES/DEMP Utilities Operations General Foreman, Central Heat and Power Plant
George Pousche	343 CES/DEMP Assistant, Utilities Operations General Foreman, Central Heat and Power Plant
Larry Bright	343 CES/DEEV
Jack Coutts	Regional Air Coordinator/Dept of Environmental Conservation, State of Alaska

(This page left blank)



APPENDIX B

Permit No. 8831-AA001

(This page left blank)

# STATE OF ALASKA

DEPT. OF ENVIRONMENTAL CONSERVATION

January 21, 1988

STEVE COWPER, GOVERNOR

(907) 452-1714

Northern Regional Office  
1001 Noble Street  
Suite 350  
Fairbanks, Alaska 99701

CERTIFIED MAIL  
RETURN RECEIPT  
REQUESTED

Captain George A. Heiner  
Chief, Environmental/Contract Planning  
U.S. Department of the Air Force  
343D Civil Engineer Squad (AAC)  
Eielson AFB, Alaska 99702

Dear Capt. Heiner:

Re: Air Quality Control Permit to Operate 8831-AA001

We have received your letter dated January 7, 1988, requesting renewal of Air Quality Control Permit to Operate 8331-AA001. In our review of the permit file, we find a letter dated March 11, 1986 from Capt. Blackshear in which he states "a source test will be conducted after repair. . ." Your letter indicated that the repairs were completed last summer. Since the source test has not been completed, we are requiring it as condition 4 of the new Air Quality Control Permit to Operate # 8831-AA001. Please note that the source test report must be submitted to the department by December 31, 1989. The source test will determine at which maximum load the boiler can be fired.

The new permit expires on January 30, 1993, and you must have it renewed if you intend to continue to operate the facility beyond that date. Please note that there are 11 conditions to be met on this permit. Failure to comply with any of these conditions will result in the suspension or revocation of your permit in accordance with 18 AAC 50.310.

Captain Heiner

-2-

January 21, 1988

Any person who disagrees with this decision may appeal the decision by requesting an adjudicatory hearing, using the procedures contained in 18 AAC 15.200-310. Hearing requests must be delivered to the Commissioner of the Department of Environmental Conservation, 3220 Hospital Drive, P.O. Box 0, Juneau, Alaska 99811-1800, within 30 days of receipt of this letter. If a hearing is not requested within 30 days, the right to appeal is waived and the decision becomes final.

Sincerely,



William D. McGee  
Regional Environmental Supervisor

jc/wdm/tss

Enclosure

cc: A. Ewing, EPA/Anchorage  
R. Joy, FNSB/Fairbanks  
L. Verrelli, ADEC/Juneau

100.16.002

ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION  
NORTHERN REGION OFFICE  
1001 NOBLE STREET, SUITE 350  
FAIRBANKS, ALASKA 99701

AIR QUALITY CONTROL PERMIT TO OPERATE

Permit No. 8831-AA001  
Renews Permit No. 8331-AA001,

Date of Issue January 21, 1988

The Department of Environmental Conservation, under the authority of AS 46.03 and 18 AAC 50.400, issues an Air Quality Control Permit to Operate to:

U.S. Department of the Air Force  
343D Civil Engineering Squadron (AAC)  
Eielson A.F.B., Alaska 99702

FOR THE OPERATION OF the Eielson Air Force Base power and heating plant, consisting of six coal-fired boilers, as described in Exhibit A in accordance with the conditions of this permit and Exhibits A and B and as described in permit application documents listed in Exhibit C.

LOCATED near Fairbanks, Alaska on Eielson Air Force Base.

THE FOLLOWING CONDITIONS SHALL APPLY TO THIS PERMIT:

01. The permittee shall comply with the State Ambient Air Quality Standards established in Section 020 and the applicable emission limitation specified in Section 040 of the State Air Quality Control Regulations 18 AAC 50 and Exhibit B.
02. An Air Contaminant Emission Source Operating Report as described in Exhibit A shall be submitted semiannually to the department's Northern Regional Office, 1001 Noble Street, Suite 350, Fairbanks, Alaska 99701, by the 30th of January and July of each year.
03. The permittee shall maintain and operate all fuel burning equipment, emission control devices, testing equipment, and monitoring equipment to provide optimum fuel burning efficiency during all operating periods. The permittee shall establish and have in the control room written standard operating procedures for use by the operators of the boilers.
04. The permittee shall conduct a source test of one representative boiler in accordance with Title 40 Code of Federal Regulation Part 60 Appendix A, Methods 1 through 5 to determine the maximum steam load at which the boilers will meet the emission standards in Exhibit B. The source

test report must be in the format specified by Appendix IV-3 of the State Air Quality Control Plan and be submitted to the Department's Northern Regional Office by December 31, 1989.

05. Until the source test in Condition 4 is conducted, permittee shall operate the coal fired boilers at a firing rate, which at no time shall exceed 100,000 lbs/hr steam, (5/6) rated capacity, based on one-hour average steam production. The source test shall thereafter determine the maximum load.
06. Additional testing or monitoring, as deemed necessary, shall be conducted, installed, maintained, and operated in accordance with 18 AAC 50.500 and 50.520 to measure air contaminant emission concentrations. If any continuous monitor is malfunctioning or non-operable for three or more consecutive days, permittee shall notify the Northern Regional Office of the department on the fourth day indicating the cause of failure and anticipated time required to repair the instrument.
07. The permittee shall maintain test results, monitoring instrument recording charts, and other applicable data in an active file for not less than one year, and have them accessible, upon request, to the department for not less than three years.
08. Permittee shall notify the department's Northern Regional Office by telephone (452-1714) when equipment failures or operation conditions occur which increase air contaminant emissions. Opacity violations totaling less than one-half hour per day do not need to be reported. The permittee shall report the expected duration, nature of occurrence, amount and type of material burned, and steps taken to minimize emissions and avoid recurrence.
09. Permittee shall submit a written report by the 15th day of each month to the department's Northern Regional Office which summarizes the date, time, and other information requested in Condition 8 for each incident reported in accordance with that permit condition and in violation of performance limitations listed in Exhibit B.
10. The department's representative is allowed access to permittee's facilities to conduct inspections or tests to determine compliance with this permit and state environmental laws and regulations.

11. A copy of this permit shall be clearly displayed, and the State Air Quality Control Regulations 18 AAC 50 kept on file, at the permitted facility location.

This permit expires 30 January 1993 and may be suspended or revoked in accordance with 18 AAC 50.310.



William D. McGee

Regional Environmental Supervisor

EXHIBIT A  
AIR QUALITY CONTROL PERMIT TO OPERATE 8831-AA001  
AIR EMISSION SOURCE OPERATING REPORT

An Air Source Operating Emission Report shall be submitted to the Alaska Department of Environmental Conservation, Northern Regional Office, 1001 Noble Street, Suite 350, Fairbanks, Alaska 99701 semiannually by January 30 and July 30 each year. The report shall include, but not be limited to, the following information:

1. Facility identification and reporting period. Include the firm name, facility name and location, permit number and the period of time covered by the report.
2. Operating time and fuel consumption logged on permitted equipment tabulated by quarter. Include the number of days or hours of operation and quantity of fuel consumed by each boiler.
3. Report a change in type of fuel and tests or analyses performed.
4. A brief discussion of any change in monitoring equipment or failure which may affect reported results or yield incomplete data for any given day.
5. Signature of authorized agent preceded by the statement, "I am familiar with the information contained in this report and that to the best of my knowledge and belief such information is true, complete, and accurate."



EXHIBIT B  
AIR QUALITY CONTROL PERMIT TO OPERATE 8831-AA001  
AIR CONTAMINANT EMISSION LIMITATIONS

Exhaust conditions shall be in accordance with the information submitted.

<u>Pollutant</u>	<u>Performance Limitation</u>	<u>Annual Limit TPY</u>
Particulate matter	0.1 grains per dry standard cubic foot, 100,000 lbs steam/hour for each of the 134 MMBTU/HR boilers  20 percent opacity not to be exceeded for more than 3 minutes in any one hour, except during upsets, startups, and shutdowns	150 per each of the six boilers

EXHIBIT C  
AIR QUALITY CONTROL PERMIT TO OPERATE 8831-AA001  
PERMITTEE'S DOCUMENTATION

1. Department of the Air Force Air Quality Control Permit to Operate application dated December 19, 1977, and emissions information report OMB 158-R75, dated February 2, 1976.
2. The Alaska Department of Environmental Conservation (ADEC) report of "Particulate Matter and Sulfur Dioxide Emissions Source Test" for Eielson Air Force Base's power plant May 14 and 15, 1981.
3. ADEC letter to U.S. Air Force Director, Engineering Energy and Environmental Planning Elmendorf Air Force Base, dated March 19, 1985, requesting a source test at the Eielson power plant.
4. U.S. Air Force letter dated March 11, 1986, to ADEC stating "a source test will be conducted. . ."
5. U.S. Air Force letter dated January 7, 1988, to ADEC requesting renewal of Eielson's Air Quality Control Permit to Operate.

APPENDIX C  
State Regulations

(This page left blank)

## ALASKA AIR QUALITY CONTROL REGULATIONS

(Alaska Administrative Code, Title 18, Environmental Conservation, Chapter 50 — Air Quality Control; Effective May 26, 1972; Amended November 9, 1972; May 8, 1974; May 4, 1980; November 1, 1982; October 30, 1983; June 7, 1987)

ARTICLE I.  
PROGRAM STANDARDS  
AND LIMITATIONS

**50.010. APPLICABILITY OF LOCAL GOVERNMENT REGULATIONS.** A local air quality control agency may establish the same or more stringent regulations, but not less stringent regulations, as the applicable regulations specified in this chapter.

**50.020. AMBIENT AIR QUALITY STANDARDS.** (a) The concentration of contaminants in the ambient air, corrected to standard conditions, may not exceed the following.

- (1) suspended particulate matter —
  - (A) annual geometric mean of 60 micrograms per cubic meter; or
  - (B) 24-hour average of 150 micrograms per cubic meter more than once each year;
- (2) sulfur oxides, measured as sulfur dioxide —
  - (A) annual arithmetic mean of 80 micrograms per cubic meter;
  - (B) 24-hour average of 365 micrograms per cubic meter more than once each year; or
  - (C) three-hour average of 1300 micrograms per cubic meter more than once each year;
- (3) carbon monoxide —
  - (A) eight-hour average of 10 milligrams per cubic meter more than once each year; or
  - (B) one-hour average of 40 milligrams per cubic meter more than once each year;
- (4) ozone — one-hour average of 235 micrograms per cubic meter expected more than once per year;

(5) nitrogen dioxide — annual arithmetic mean of 100 micrograms per cubic meter;

(6) reduced sulfur compounds, expressed as sulfur dioxide — 30-minute average of 50 micrograms per cubic meter more than once each year; and

(7) lead — quarterly arithmetic mean of 1.5 micrograms per cubic meter.

(b) In areas where concentrations of contaminants in the ambient air are less than the standards set out in (a) of this section, the concentrations must be kept below those standards, and no increase above the baseline concentration may exceed

- (1) for a Class I area
  - (A) suspended particulate matter —
    - (i) annual geometric mean of five micrograms per cubic meter; or
    - (ii) 24-hour average of 10 micrograms per cubic meter more than once each year; and
  - (B) sulfur dioxide —
    - (i) annual arithmetic mean of two micrograms per cubic meter;
    - (ii) 24-hour average of five micrograms per cubic meter more than once each year; or
    - (iii) three-hour maximum of 25 micrograms per cubic meter more than once each year;
- (2) for a Class II area
  - (A) particulate matter —
    - (i) annual geometric mean of 19 micrograms per cubic meter, or
    - (ii) 24-hour average of 37 micrograms per cubic meter more than once each year; and
  - (B) sulfur dioxide —
    - (i) annual arithmetic mean of 20 micro-

grams per cubic meter;

(ii) 24-hour average of 91 micrograms per cubic meter more than once each year; or

(iii) three-hour average of 512 micrograms per cubic meter more than once each year;

(3) for a Class III area

(A) particulate matter

(i) annual geometric mean of 37 micrograms per cubic meter; or

(ii) 24-hour average of 75 micrograms per cubic meter more than once each year, and

(B) sulfur dioxide

(i) annual arithmetic mean of 40 micrograms per cubic meter;

(ii) 24-hour average of 182 micrograms per cubic meter more than once each year; or

(iii) three-hour average of 700 micrograms per cubic meter more than once each year.

**50.021. STATE AIR QUALITY CLASSIFICATIONS.** (a) For purposes of classifying areas according to air quality, those areas in nonattainment with the ambient air quality standards of this chapter are

(1) Anchorage urban area for carbon monoxide; and

(2) Fairbanks and North Pole urban areas for carbon monoxide.

(b) For purposes of the ambient air quality standards specified in 18 AAC 50.020(b)

(1) Class I areas in the state are

(A) Denali (Mt. McKinley) National Park,

(B) that portion of Bering Sea National Wildlife Refuge designated as a National Wilderness Area;

(C) that portion of Simeonof National Wildlife Refuge designated as a National Wilderness Area; and

(D) that portion of Tuxedni National Wildlife Refuge designated as a National Wilderness Area.

(2) those areas of the state not classified in (a) of this section, or (1) or (3) of this subsection are classified as Class II; and

(3) no areas in the state have been classified as Class III.

(c) For purposes of preventing impairment of visibility, the designated areas are

(1) Mt. Deberah and the Alaska Range East, as viewed from approximately the Savage River Campground area;

(2) Mt. McKinley, Alaska Range, and the Interior Lowlands, as viewed from the vicinity of Wonder Lake; and

(3) the Class I areas listed in (b)(1) of this section.

(d) For purposes of maintaining the ambient air quality standards set out in 18 AAC 50.020(a), the Mendenhall Valley of Juneau is a wood smoke control area.

**50.030. OPEN BURNING.** (a) Open burning must achieve maximum combustion efficiency throughout the burning period, and is subject to the exception in (e) of this section, the limitations in (b), (c), (d), and (f) of this section, and 18 AAC 50.110.

(b) Open burning of asphalts, rubber products, plastics, tars, oils, oily wastes, contaminated oil cleanup materials, or other materials in a way that gives off black smoke is prohibited without written approval from the department. Approved open burning is subject to the following limitations:

(1) controlled fires for training fire fighters must be advertised through news media in the general area of the activity at least three days before the activity, informing the public of the time, place, and purpose of the fire, unless waived by the department;

(2) open burning of liquid hydrocarbons produced during oil or gas well flow tests will be approved only if there are no practical means available to recycle, reuse, or dispose of the fluids in a more environmentally acceptable way; and

(3) reasonable procedures and requirements must be established by the person doing the burning to minimize adverse environment effects and limit the amount of smoke generated.

(c) Open burning or incineration of pesticides, halogenated organic compounds, cyanic compounds, or polyurethane products in a way that gives off toxic or acidic gases or particulate matter is prohibited.

(d) Open burning of putrescible garbage, animal carcasses, or petroleum-based materials is prohibited if it causes odor or black smoke which has an adverse effect on nearby persons or residences.

(e) Controlled burning for the management of forest land, vegetative cover, fisheries, or wildlife habitat, other than burning to combat a natural wildfire, requires written approval from the department.

(f) Open burning is prohibited in an area if an air quality advisory by the department is broadcast on radio or television stating that burning is not permitted in that area for that day. This advisory will be based on a determination that there is or is likely to be inadequate air ventilation to maintain the standards set by 18 AAC 50.020.

(g) Open burning is prohibited in wood smoke control areas identified in 18 AAC 50.021(d) between November 1 and March 31.

**50.040. INCINERATORS.** (a) Visible emissions, excluding condensed water vapor, from an incinerator may not reduce visibility through the exhaust effluent by:

(1) greater than 20 percent for a total of more than three minutes in any one hour, except as provided in (2) of this subsection; or

(2) 20 percent or greater for municipal wastewater treatment plant sludge incinerators.

(b) Emissions of particulate matter from incinerators may not exceed, per cubic foot of exhaust gas corrected to 12 percent CO<sub>2</sub> and standard conditions, and except as specified in (c) of this section:

(1) 0.15 grains for incinerators less than 2,000 pounds, but greater than or equal to 1,000 pounds per hour rated capacity; or

(2) 0.08 grains from incinerators of 2,000 pounds per hour rated capacity or larger.

(c) Emissions of particulate matter from municipal wastewater treatment plant sludge incinerators which serve 10,000 or more persons and burn waste containing more than 10 percent wastewater treatment plant sludge by dry weight, may not exceed 0.65 grams per kilogram of dry sludge input.

**50.050 INDUSTRIAL PROCESSES AND FUEL BURNING EQUIPMENT.**

(a) Visible emissions, excluding condensed water vapor, from an industrial process or fuel burning equipment may not reduce visibility through the exhaust effluent by:

(1) greater than 20 percent for a total of more than three minutes in any one hour, except as noted in (2) — (8) of this subsection;

(2) greater than 30 percent for more than three minutes in any one hour for fuel burning equipment in operation before November 1, 1982 and using more than 20 percent woodwaste as fuel;

(3) greater than 30 percent for urea prilling towers in operation before July 1, 1972, for a total of more than three minutes in any one hour;

(4) 20 percent or greater for asphalt plants installed or modified after November 1, 1982;

(5) 20 percent or greater for process emissions, other than from pneumatic cleaners, at coal preparation facilities installed or modified after November 1, 1982;

(6) 10 percent or greater for pneumatic cleaners at coal preparation facilities installed or modified after November 1, 1982;

(7) 10 percent or greater for process emissions, other than from kilns, at portland cement plants installed or modified after November 1, 1982; and

(8) 20 percent or greater for kilns at portland cement plants installed or modified after November 1, 1982.

(b) Particulate matter emitted from industrial processes or fuel burning equipment may not exceed, per cubic foot of exhaust gas corrected to standard conditions:

(1) 0.05 grains except as provided in (2) — (4) of this subsection, (d) of this section, and 18 AAC 50.060.

(2) 0.1 grains for steam generating plants burning as fuel.

(A) coal, and in operation before July 1, 1972;

(B) coal, and rated less than 250 million Btu per hour heat input; or

(C) municipal wastes;

(3) 0.1 grains for an industrial process in operation before July 1, 1972; or

(4) 0.15 grains from fuel burning equipment in operation before November 1, 1982, and using more than 20 percent woodwastes as fuel.

(c) Sulfur compound emissions, expressed as sulfur dioxide, from an industrial process or from fuel burning equipment may not exceed 500 ppm averaged over a period of three hours, except as provided in (d) of this section, and 18 AAC 50.060.

(d) Emissions from a source installed or modified after November 1, 1982 may not exceed

(1) at asphalt plants, 90 milligrams of particulate matter per cubic meter of exhaust gas at standard conditions;

(2) at petroleum refineries

(A) catalytic cracking unit catalyst regenerator

(i) 1.0 kilogram of particulate matter per 1,000 kilograms of coke burnoff;

(ii) 43.0 additional grams of particulate matter per million joules supplemental heat attributable to fuels burned in a catalytic regenerator waste heat boiler; and

(iii) 500 ppm carbon monoxide by volume of exhaust gas;

(B) sulfur recovery plant rated at more than 20 long tons per day

(i) 250 ppm sulfur dioxide at zero percent oxygen on a dry basis; or

(ii) 10 ppm hydrogen sulfide and a total of 300 ppm reduced sulfur compounds, expressed as sulfur dioxide, at zero percent oxygen on a dry basis, if the air contaminants are not oxidized before release to the atmosphere; and

(C) fuel burning equipment, sulfur dioxide averaged over three hours

(i) equal to the concentration of uncontrolled emissions which would result from burning fuel gas containing 230 milligrams hydrogen sulfide per dry standard cubic meter from equipment burning fuel gas;

(ii) a calculated concentration based on the allowable emissions in (i) and (iii) of this subparagraph and the proportion of

fuel gas and other fuels to the total fuel burned in fuel burning equipment; or

(iii) 500 ppm from all other fuel burning equipment;

(3) at coal preparation facilities

(A) thermal drying unit, 70 milligrams of particulate matter per cubic meter of exhaust gas at standard conditions; and

(B) pneumatic coal cleaning unit, 40 milligrams of particulate matter per cubic meter of exhaust gas at standard conditions; and

(4) at portland cement plants

(A) clinker cooler, 0.050 kilograms of particulate matter per 1,000 kilograms of feed on a dry basis to the kiln; and

(B) kiln, 0.15 kilograms of particulate matter per 1,000 kilograms of feed on a dry basis

(e) Release of materials other than process emissions, products of combustion, or materials introduced to control pollutant emissions from a stack at a source built or modified after November 1, 1982 is prohibited unless approved in writing by the department.

(f) No person may cause or permit bulk materials to be handled, transported, or stored, or engage in an industrial activity or construction project without taking reasonable precautions to prevent particulate matter from becoming airborne

**50.060. PULP MILLS.** Average emissions per ton of pulp produced from a sulfite pulp mill may not exceed in any 24-hour period

(1) 20 pounds of sulfur oxides (expressed as sulfur dioxide) from blow pits, washer vents, storage tanks, digester relief systems, and recovery systems; and

(2) two pounds of particulate matter from blow pits, washer vents, storage tanks, digester relief systems, and recovery systems.

**50.070. MOTOR VEHICLE EMISSIONS.** (a) Emissions from gasoline-powered motor vehicles, excluding condensed water vapor, may not be visible for more than any five consecutive seconds.

(b) Visible emissions from diesel-powered motor vehicles, excluding condensed water vapor, may not result in a reduction of visibility of greater than 40 percent through the exhaust effluent for more than any five consecutive seconds.

**50.080 [Repealed]**

**50.085. WOOD-FIRED HEATING DEVICES.** For wood-fired heating devices,

(1) when an air quality alert is issued under 18 AAC 50.610(a)(1)(B) for particulate matter within a specific area, except areas set out in (3) of this section, visible emissions at the point of release to the atmosphere may not reduce visibility through the exhaust effluent by 50 percent or greater for more than 15 minutes in any one hour;

(2) burning in a way that creates black smoke is prohibited; and

(3) for wood smoke control areas identified in 18 AAC 50.021(d)

(A) visible emissions at the point of release to the atmosphere may not reduce visibility through the exhaust effluent by 50 percent or greater for more than 15 minutes in any one hour; and

(B) when an air emergency has been issued under 18 AAC 50.610 (a)(3)(D), no person may operate, permit, or allow the operation of a wood-fired heating device which results in the emission of smoke

**50.090. ICE FOG LIMITATIONS.** The department will, in its discretion, require any person proposing to build or operate an industrial process, fuel burning equipment or incinerator in areas of potential ice fog, to obtain a permit to operate and to reduce water emissions

**50.100. MARINE VESSELS.** Within three miles of the coastline of Alaska, visible emissions from any marine vessel, excluding condensed water vapor, may not result in a reduction of visibility through the exhaust effluent of greater than

(1) 40 percent for a period or periods aggregating more than three minutes in any one hour, except as provided in (2) of this section; and

(2) 40 percent for a period or periods aggregating more than six minutes in any one hour during initial startup of diesel-driven vessels

**50.110. AIR POLLUTION PROHIBITED.** No person may permit any emission which is injurious to human health or welfare, animal or plant life, or property, or which would unreasonably interfere with the enjoyment of life or property

## 50.120 — 50.190. [Repealed]

## ARTICLE 2.

## PERMIT REQUIREMENTS

## 50.300. PERMIT TO OPERATE. (a)

No person may construct, modify, reconstruct, operate, or cause the operation of the following without a permit from the department:

(1) a facility containing a source which requires an air contaminant emission control unit or system to comply with emission standards set by 18 AAC 50.040—18 AAC 50.060, and which is

(A) an industrial process with a total design rate, capacity, or throughput greater than five tons per hour and which physically or chemically treats the material, or

(B) fuel-burning equipment with a rating of 50 million Btu per hour or greater;

(2) fuel-burning equipment with a rating of 100 million Btu per hour or more;

(3) an incinerator with a rated capacity of 1,000 pounds per hour or more;

(4) a facility subject to the standards set by 18 AAC 50.040(c), 18 AAC 50.050(d)(5), 18 AAC 50.050(a)(7), or 18 AAC 50.050(d).

(5) a facility

(A) which has allowable emissions of 100 tons per year or more of an air contaminant regulated under the Clean Air Act (P.L. 91-604) as amended August 7, 1977 (P.L. 95-95), is installed after November 1, 1982, and is a

(i) fossil fuel fired steam electric plant of more than 250 million Btu's per hour heat input;

(ii) coal cleaning plant (with thermal dryers);

(iii) kraft pulp mill;

(iv) portland cement plant;

(v) primary zinc smelter;

(vi) iron and steel mill plant;

(vii) primary aluminum ore reduction plant;

(viii) primary copper smelter;

(ix) municipal incinerator capable of charging more than 250 tons of refuse per day;

(x) hydrofluoric, sulfuric, or nitric acid plant;

(xi) petroleum refinery;

(xii) lime plant;

(xiii) phosphate rock processing plant;

(xiv) coke oven battery;

(xv) sulfur recovery plant;

(xvi) carbon black plant (furnace process);

(xvii) primary lead smelter;

(xviii) fuel conversion plant;

(xix) sintering plant;

(xx) secondary metal production plant;

(xxi) chemical process plant;

(xxii) fossil fuel boiler or a combination of boilers totaling more than 250 million Btu's per hour heat input;

(xxiii) petroleum storage and transfer unit with a total storage capacity exceeding 300,000 barrels;

(xxiv) taconite ore processing plant;

(xxv) glass fiber processing plant; or

(xxvi) charcoal production plant;

(B) which is listed in (A) of this paragraph with allowable emissions of less than 100 tons per year of a regulated air contaminant and is modified after August 7, 1977, causing an increase in allowable emissions of 100 tons per year or more; or

(C) which is listed in (A) of this paragraph with allowable emissions of greater than 100 tons per year of a regulated air contaminant and is modified after August 7, 1980, or after the date of the most recent permit issued for the affected area under 18 AAC 50.400(c)(3), causing an increase in actual emissions equal to or exceeding the emissions listed in (6)(C)(i) — (xvii) of this subsection;

(6) a facility not listed in (5) of this subsection

(A) which has allowable emissions of 250 tons per year or more of an air contaminant regulated under the Clean Air Act (P.L. 91-604) as amended August 7, 1977 (P.L. 95-95), and is installed after November 1, 1982;

(B) which has allowable emissions of less than 250 tons per year of a regulated air contaminant and is modified after August 7, 1977, causing an increase in allowable emissions of 250 tons per year or more; or

(C) which has allowable emissions of more than 250 tons per year of a regulated air contaminant and is modified after August 7, 1980, or after the date of the most recent permit issued for the affected area under 18 AAC 50.400(c)(3), causing an increase in actual emissions equal to exceeding any of the following:

(i) carbon monoxide — 100 tpy;

(ii) nitrogen oxides — 40 tpy;

(iii) sulfur dioxide — 40 tpy;

(iv) particulate matter — 25 tpy;

(v) ozone — 40 tpy of volatile organic compounds as an ozone indicator;

(vi) lead — 0.6 tpy;

(vii) asbestos — 0.007 tpy;

(viii) beryllium — 0.0004 tpy;

(ix) mercury — 0.1 tpy;

(x) vinyl chloride — 1 tpy;

(xi) fluorides — 3 tpy;

(xii) sulfuric acid mist — 7 tpy;

(xiii) hydrogen sulfide (H<sub>2</sub>S) — 10 tpy;

(xiv) total reduced sulfur including H<sub>2</sub>S — 10 tpy;

(xv) reduced sulfur compounds including H<sub>2</sub>S — 10 tpy;

(xvi) increased emissions of a pollutant regulated by the Clean Air Act (P.L. 91-604) as amended August 7, 1977 (P.L. 95-95) and not listed in (6)(C)(i)-(xv) of this subsection, or

(xvii) notwithstanding (i) through (xvi), if located within 10 kilometers of an area listed in 18 AAC 50.021(b)(1) with increased emissions that impact the area by 1 ug/m<sup>3</sup> or more for a 24-hour average;

(7) a source or facility installed, reconstructed, or modified after July 1, 1979 or after the date of the most recent permit issued since November 1, 1982, under 18 AAC 50.400(c)(4), located within an area identified in 18 AAC 50.021(a), and causing an increase in actual or allowable carbon monoxide emissions, whichever is greater, from the source or facility of 100 tons per year or more; or

(8) a facility or modification to a facility for which the owner or operator has requested that the department approve limitations of emission rates or operations to reduce emissions to levels below those specified in this chapter.

(b) An application for a permit required by (a) of this section must include

(1) one set of plans and specifications clearly showing the layout of the proposed facility, location of individual equipment and points of discharge, building dimensions, and stack heights;

(2) a map or aerial photograph, on a scale at least one inch to one mile indicating the location of the proposed facility, homes, buildings, roads, and other adjacent facilities, and the general topography within 15 kilometers of the facility;

(3) an engineering report outlining the proposed methods of operation, the



amount of material to be processed, the proposed use and distribution of the processed material, and a process flow diagram with description showing points of emission and estimated amounts and types of air contaminants to be emitted;

(4) a description of air quality control devices, including efficiency and other design criteria, and assurances that this equipment is capable of complying with applicable emission requirements specified in this chapter;

(5) if requested by the department, an evaluation of the effect of the facility's expected maximum emissions on the ambient air, including ambient air quality and meteorological data;

(6) if requested by the department, plans for emission reduction procedures to be used during an air episode; and

(7) a detailed schedule for construction or modification of the facility.

(c) A permit application for a facility subject to (a)(5) or (a)(6) of this section must include the following information in addition to that required under (b) of this section:

(1) ambient air and meteorological data to fully describe the air quality in the vicinity of the proposed facility and any changes in air quality due to general growth which has occurred after the establishment of the baseline date in the area the facility or modification would affect; department approval of the air monitoring network is required before starting data collection;

(2) a detailed demonstration that the expected maximum emissions from the construction and operation of the facility, including emissions from associated growth, will not cause a violation, or contribute to an existing violation, of the ambient air quality standards in 18 AAC 50.020(a) or allowable increments in 18 AAC 50.020(b);

(3) an adequate demonstration that the proposed emission control system represents the best available control technology for each air contaminant and for each new or modified source; and

(4) an analysis of the impact of expected maximum emissions from the facility,

including emissions from associated growth, on visibility, vegetation, and soils.

(d) A permit application for a facility subject to (a)(7) of this section must include the following information in addition to that required under (b) of this section:

(1) proof that emissions of a pollutant for which the area is declared in nonattainment will not exceed the applicable emission allowance, and will be controlled to a rate which represents the lowest achievable emission rate; and

(2) proof that other sources owned or operated by the applicant within the state are in compliance with the requirements of this chapter and the Clean Air Act (P.L. 91-604) as amended August 7, 1977 (P.L. 95-95).

(e) A permit application submitted under (a)(8) of this section need not include the information required under (b) and (c) of this section, but must specify the limitations on emission rates or operations necessary to exempt the facility from 18 AAC 50.300(a)(5) — (7) or any other requirement of this chapter.

(f) If a permit application is deficient, the department will notify the applicant by certified mail within 30 days after receipt of the application, identifying the deficiencies and the information to be submitted. When the deficiencies are corrected, the department will continue processing the application.

**50.310. REVOCATION OR SUSPENSION OF PERMIT.** A permit to operate will, in the department's discretion, be revoked or suspended if the conditions of the permit or applicable laws or regulations are violated.

### ARTICLE 3. PERMIT REVIEW CRITERIA

**50.400. APPLICATION REVIEW AND ISSUANCE OF PERMIT TO OPERATE.** (a) Before review under (b) of this section for a facility described in 18 AAC 50.300(a)(5), (6), or (7); for a facility with a stack described in 18 AAC 50.900(23)(C); or for any other facility for which the department finds that additional public review and comment is desirable, an opportunity for public comment and

hearing will be provided using the following procedures:

(1) at least 30 days before beginning review under (b) of this section a summary of the department's preliminary review and analysis of the application will be published in a newspaper of general circulation within the area where the new or modified facility is to be located. The analysis will be sent to the Environmental Protection Agency, and any federal land manager, Indian governing body on a reservation, or unit of local government which may be affected by emissions from the proposed activity; materials submitted by the applicant and a copy of the proposed permit will be available in at least one location within the area of the new or modified facility;

(2) the department, upon its own motion, or upon request, will hold a public hearing on the application following the procedures set out in 18 AAC 15.060(d) — (g); 60 days notice of a hearing will be sent to any affected federal land manager under 18 AAC 50.021(c); and

(3) public comments and testimony received on the application will be evaluated as part of the information needed to complete evaluation of the permit application, and will be made available to the public.

(b) The department will review a permit application and will, in its discretion, issue the permit within 30 days after receipt of all information needed to complete evaluation of the application, including testimony at a public hearing held under (a) of this section. For applications subject to (a) of this section, a copy of the final determination will be published and distributed as described in (a)(1) of this section.

(c) The department will issue a permit only if the applicant shows that:

(1) allowable emissions from the facility and from associated growth will not prevent or interfere with the attainment or maintenance of ambient air quality standards set by 18 AAC 50.020(a);

(2) air contaminant emissions from a source in the facility will not exceed the requirements of 18 AAC 50.040 — 18 AAC 50.060 and 18 AAC 50.110 and are approvable by the Environmental Protec-

tion Agency under the federal new source performance standards or emission standards for hazardous air pollutants:

(3) for a facility subject to 18 AAC 50.040(a)(5) or (6),

(A) the best available control technology for controlling emissions of each pollutant will be installed and used for each new or modified source;

(B) in an area designated in 18 AAC 50.021(b) as in attainment with ambient air quality standards set by 18 AAC 50.020(a), allowable emissions from the facility and from associated growth will not

(i) cause or contribute to an increase in air contaminants greater than specified in 18 AAC 50.020(b), or

(ii) cause an increase of carbon monoxide more than 500  $\mu\text{g}/\text{m}^3$  eight-hour average or 2000  $\mu\text{g}/\text{m}^3$  one-hour average within any area specified in 18 AAC 50.021(a), and

(C) allowable emissions from the facility and from associated growth will not adversely affect air quality related values, including noise, odor, visibility, vegetation, and soils of any area within the state; and

(4) for a facility subject to 18 AAC 50.300(a)(7),

(A) emissions will not exceed the emission allowance in the applicable nonattainment area;

(B) the lowest achievable emission rate will be achieved for each new or modified source; and

(C) other sources owned or operated by the applicant within the state are in compliance with requirements of this chapter and the Clean Air Act (P.L. 91-604) as amended August 7, 1977 (P.L. 95-95).

(d) A permit to operate

(1) will be granted for no more than five years, after which the permit must be renewed for continued operation of the facility;

(2) will include a compliance schedule if the facility is emitting air contaminants in excess of applicable limitations contained in this chapter, based on the minimum time necessary to install the required control equipment; a permit which includes a compliance schedule must be renewed every year of its duration;

(3) will, in the department's discretion, require the permittee to install, use, and

maintain monitoring equipment, to sample emissions according to methods prescribed by the department, at locations and intervals and by procedures specified by the department, to provide source test reports, to provide monitoring data, emission data, and information from analyses of any test samples, and to make periodic reports on process operations and emissions;

(4) will, for an application submitted under 18 AAC 50.300(a)(8), include specific limitations on emissions or operations as necessary to exempt the facility from 18 AAC 50.300(a)(5) — (7) or any other requirement of this chapter;

(5) will, in the department's discretion, require that specific emission reduction procedures be taken during an air episode; and

(6) may not be transferred without the written consent of the regional supervisor.

(e) If an application for a permit is denied, the department will notify the applicant by certified mail, stating the reasons for denial. The notification will include a statement that a person aggrieved by the department's decision may request in adjudicatory hearing within 30 days after service of the denial under 18 AAC 15.200 — 18 AAC 15.310. For applications subject to (a) of this section, a copy of the final determination will be published and distributed as described in (a)(1) of this section

50.410. [Repealed]

#### ARTICLE 4. REGULATION COMPLIANCE CRITERIA

50.500. SOURCE TESTING. (a) Except as provided in (d) of this section, the department will, in its discretion, conduct or have conducted air contaminant emission tests to determine compliance with this chapter

(b) Testing to determine compliance with this chapter must be by methods approved by the department and done at a point or points which characterize the actual discharge into the ambient air

(c) Except as provided in (d) of this section, air contaminant emission tests must be done at maximum rate burning or operating capacity of the unit, or other

rate determined by the department to characterize the actual discharge into the ambient air

(d) Demonstration by source testing of compliance with the requirements of 18 AAC 50.040(a)(2) and (b)(2) for incinerators greater than 4,100 pounds per hour, 18 AAC 50.050(a)(1) for catalyst cracking unit catalyst regenerators, 18 AAC 50.040(c), 18 AAC 50.050(a)(4) — (8) and (d) must be done at maximum operating or production rates within 180 days after startup of a new or modified source. Source test methods specified in 40 C.F.R. 60, Appendix A, as amended through November 1, 1982 or their equivalent are to be used as follows:

(1) for emissions of particulate matter, procedures specified in reference methods 1, 2, 3, 4, and 5;

(2) for emission of carbon monoxide, procedures specified in reference method 10;

(3) for emissions of sulfur dioxide, procedures specified in reference methods 1, 2, and 6;

(4) for emissions of reduced sulfur compounds, procedures specified in reference method 15;

(5) for hydrogen sulfide content of process fuel gas streams, procedures specified in reference method 11; and

(6) for visible emissions, procedures specified in reference method 9.

(e) If the provisions in (d) of this section do not apply, then compliance with emission standards must be measured by the following

(1) for emissions of particulate matter, procedures specified in reference methods 1, 2, 3, 4, and 5 of Appendix A to 40 C.F.R. sec. 60 as amended through November 1, 1983;

(2) for emissions of sulfur dioxide, procedures specified in reference methods 1, 2, and 6 of Appendix A to 40 C.F.R. sec. 60 as amended through November 1, 1983, and

(3) to determine the reduction of visibility and opacity of exhaust gases, the procedures specified in the department document entitled "Alaska Air Quality Visible Emissions Evaluation Procedures" (dated August 1983).

(f) To determine compliance with this chapter, standard exhaust gas volumes

must include only the gases formed from theoretical combustion of the fuel, plus the excess gas volume normal for the specific source type, corrected to standard conditions.

**50.510. AMBIENT ANALYSIS METHODS.** (a) Air quality data and analyses submitted in support of a permit application under 18 AAC 50.300(a)(5) or (6) must comply with procedures set out in the department document entitled "ADEC Ambient Analysis Procedures" (dated July 1982).

(b) Continuous ambient air monitoring is required in support of a permit application submitted under 18 AAC 50.300(a)(5) or (6) for each pollutant which exceeds the limitations described in 18 AAC 50.300(a)(6)(C)(i) — (xvii) unless the existing concentrations or the predicted ambient air quality impacts are less than

(1) carbon monoxide — 575 ug/m<sup>3</sup>, 8-hour average;

(2) nitrogen dioxide — 14 ug/m<sup>3</sup>, annual average;

(3) total suspended particulates — 10 ug/m<sup>3</sup>, 24-hour average;

(4) sulfur dioxide — 13 ug/m<sup>3</sup>, 24-hour average;

(5) ozone — any increase in allowable or actual volatile organic compounds emissions of 100 tons per year or more;

(6) lead — 0.1 ug/m<sup>3</sup>, quarterly average;

(7) mercury — 0.25 ug/m<sup>3</sup>, 24-hour average;

(8) beryllium — 0.001 ug/m<sup>3</sup>, 24-hour average;

(9) fluorides — 0.25 ug/m<sup>3</sup>, 24-hour average;

(10) vinyl chloride — 15 ug/m<sup>3</sup>, 24-hour average; and

(11) hydrogen sulfide — 0.2 ug/m<sup>3</sup>, 1-hour average.

**50.520. EMISSION AND AMBIENT MONITORING.** (a) Operators of facilities requiring a permit under 18 AAC 50.300 shall install, maintain, and operate continuous ambient air quality, meteorological, process, or emission monitoring and recording devices specified by the department and in accordance with 40 CFR sec. 58, Appendix B, as amended through November 1, 1983.

(b) Operators of facilities subject to 18

AAC 50.040(b)(2), 18 AAC 50.040(c), or 18 AAC 50.050(d) shall install, maintain, and operate continuous emission and process monitoring devices, keep records, and report excess emissions in accordance with procedures established in 40 CFR sec. 60 as amended through November 1, 1983.

(c) The department will, in its discretion, require the owner or operator of an air contaminant source to keep records and periodically report on the nature and amount of emissions as necessary to determine compliance with this chapter.

**50.530. CIRCUMVENTION.** (a) Use of air for dilution of emission contaminants without causing a total decrease in the contaminants is not permitted as a method of compliance with this chapter, except that dilution air may be used at sulfur recovery plants with a maximum production rate of 20 long tons per day or less to achieve compliance with the 500 ppm sulfur dioxide requirement in 18 AAC 50.050(c).

(b) A person owning or operating a facility emitting air contaminants subject to the limitations and provisions of this chapter shall ensure that the facility is in compliance with this chapter and any other applicable local, state, or federal law.

(c) Stack heights which exceed good engineering practice, or dispersion techniques, may not be used to affect the degree of emission limitation required for control of air contaminants.

(d) No person may construct, operate, or modify an air contaminant emission source which will result in a violation of the applicable emission standards or will interfere with the attainment or maintenance of the ambient air standards of this chapter.

## ARTICLE 5. PROCEDURAL AND ADMINISTRATIVE

**50.600. RECLASSIFICATION PROCEDURES AND CRITERIA.** (a) The department will, in its discretion, periodically review and revise the air quality classifications within the state after notice and public hearing, except that

(1) the areas identified in 18 AAC

50.021(b)(1) of this chapter will not be reclassified; and

(2) the following areas may be reclassified only to Class I or II:

(A) an area which exceeds 10,000 acres in size and is a national monument, national primitive area, national preserve, national recreation area, national wild and scenic river, national wildlife refuge or range, or national lakeshore or seashore; and

(B) a national park or national wilderness area established after August 7, 1977 which exceeds 10,000 acres; and

(3) land within the exterior boundaries of reservations of federally recognized Indian tribes may be redesignated only by the appropriate Indian governing body.

(b) Reclassification will be initiated by the department on its own motion, or upon receipt of a petition for reclassification containing

(1) detailed reasons why reclassification is requested and is in the best interests of the public;

(2) an accurate description of the proposed boundaries of the area and the air quality within it;

(3) a detailed evaluation of emission and ambient air quality effects of any proposed new or modified facility;

(4) an evaluation of the effects of any proposed new or modified facility on air quality within other areas classified under 18 AAC 50.021;

(5) a detailed analysis of the health, environmental, economic, social, and energy effects of the proposed reclassification; and

(6) if an area proposed for reclassification includes or is part of a local government jurisdiction

(A) a resolution recommending reclassification and adopted by each affected unit of local government; and


(B) evidence that the resolution required under (A) of this paragraph was adopted after public hearing with at least 15 days' prior notice published in a newspaper of general circulation.

(c) The department will review the petition for reclassification within 30 days after receipt and will accept it for consideration if it satisfactorily describes the circumstances behind the proposed reclassification and meets the requirements of

(This page left blank)


APPENDIX D  
Plant Operating Data

(This page left blank)



FI-283	BLR 3
FEEDWATER	135.00
97.00 KLB/HR	0.00
SMP	
LI-144	BLR 3
STEAM DRUM	100.00
55.13 "	0.00
SMP	
FI-103	BLR 3
STEAM FLOW	135.00
103.50 KLB/HR	0.00
SMP	

TIME = 15:05:00




AI-846	BLR 3
OXYGEN PERCENT	85.00
8.92 %	0.00
SMP	
FI-154	BLR 3
AIR	100.00
56.82 KLB/HR	0.00
SMP	
TI-571	BLR 3
FLUE GAS OUTLET	1500.0
390.85 DEG F	0.00
SMP	

30 JUL 83 WEDNESDAY 02


BLR NO. 3 TRENDS

AS12345678

09:47:37



FI-303	BLR 3
SPEEDWATER	
125.00	
80.00 KLB/HR	
0.00	
SMP	
FI-144	BLR 2
WATERM DRUM	
100.00	
0.00	
SMP	
FI-103	BLR 3
STEAM FLOW	
100.00	
80.00 KLB/HR	
0.00	
SMP	



FI-845	BLR 2
OXYGEN PERCENT	
20.00	
0.00 %	
0.00	
SMP	
FI-154	BLR 3
NO2 COMB. AIR	
100.00	
60.00 KLB/HR	
0.00	
SMP	
FI-554	BLR 3
VALVE GAS OUTLET	
1000.0	
300.00 DEG F	
0.00	
SMP	

TIME = 11:05:00



APPENDIX E

Boiler 2, Field Data, 120,000 lbs/hr, 14 July 88

(This page left blank)

PARTICULATE SAMPLING DATA SHEET

TRAVEL POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	AVG (T <sub>m</sub> ) (°R)		
A 1	0	-6	411		1.80	2.3	53.952	95	96	240	71
2	2.5	-6	411		1.5	4.31		94	94	241	69
3	5.0	-7	409		1.6	4.63		95	96	246	74
4	7.5	-7	414		1.6	4.64		94	95	250	85
5	10.0	-7	415		1.5	4.32		99	95	252	97
6	12.5	-7.5	415		1.3	4.35		101	95	253	99
7	15.0	-8.0	415		1.4	4.05		103	96	254	96
8	17.5	-8.0	413		1.3	3.77		103	96	257	91
9	20.0	-8.2	413		1.3	3.77		107	97	258	87
10	22.5	-8.5	412		1.3	3.78		104	97	264	85
11	25.0	-9.0	412		1.2	3.49		105	98	268	83
12	27.5	-8.5	412		1.0	2.91	81.338	105	98	262	81

SCHEMATIC OF STACK CROSS SECTION  
 2.2 checker-18 in by  
 Mult. cone probe set up for H<sub>2</sub>O  
 MAIL ROOM  
 208  
 BASE  
 Eielson AFB

RUN NUMBER #1 BOILER HEAD  
 DATE 14 July 88  
 PLANT CHIPP  
 BASE Eielson AFB  
 SAMPLE BOX NUMBER  
 METER BOX NUMBER  
 Q<sub>w</sub>/Q<sub>m</sub>  
 Co

EQUATIONS  
 $\theta R = \theta F + 460$   
 $H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$   
 $T_s = 412^\circ F$   
 $T_m = 98^\circ F$   
 $\Delta H = 3.7$   
 $P_{SIS} = 32.86$   
 $53.952$

AMBIENT TEMP  
 STATION PRESS 29.235  
 HEATER BOX TEMP  
 PROBE HEATER SETTING  
 PROBE LENGTH 6'  
 NOZZLE AREA 1/4 DIA  
 Cp 0.84  
 DRY GAS FRACTION (F<sub>d</sub>) 5  
 3  
 4

14 July 88

### PARTICULATE SAMPLING DATA SHEET

SCHEMATIC OF STACK CROSS SECTION			EQUATIONS			AMBIENT TEMP						
			$\text{OR} = \text{OR} + 160$ $\text{H} = \left[ \frac{5130 \cdot \text{Fd} \cdot \text{C}_p \cdot \text{A}}{\text{C}_o} \right]^2 \cdot \frac{\text{T}_{\text{im}} \cdot \text{V}_p}{\text{T}_s}$			STATION PRESS <span style="float: right;">°F</span> HEATER BOX TEMP <span style="float: right;">in Hg</span> PROBE HEATER SETTING <span style="float: right;">°F</span> PROBE LENGTH <span style="float: right;">in</span> NOZZLE AREA (A) <span style="float: right;">sq ft</span> Cp <span style="float: right;"></span> DRY GAS FRACTION (F'd) <span style="float: right;"></span>						
TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)	
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	OUT (°F)			
B 1	30	-3.0	400		0.06	2.17	81.338	102	97	246	76	
2	32.5	-10.0	400		1.4	4.07	101	101	98	245	70	
3	35.0	-12.0	404		1.6	4.65	101	101	97	243	70	
4	37.5	-12.0	414		1.5	4.34	102	102	97	245	75	
5	40.0	-12.0	415		1.4	4.06	104	104	98	244	80	
6	42.5	-12.0	414		1.35	3.92	105	105	98	246	81	
7	45.0	-12.1	413		1.3	3.78	105	105	98	245	82	
8	47.5	-12.0	413		1.3	3.78	106	106	98	244	83	
9	50.0	-13.0	413		1.25	3.64	106	106	99	239	82	
10	52.5	-13.5	412		1.30	3.77	106	106	98	251	80	
11	55.0	-14.0	413		1.25	3.61	105	105	99	252	82	
12	57.5	-13.0	413		0.97	2.82	107.229	106	99	256	83	
			<del>DATA</del>			<del>DATA</del>	TOT VOL = 53.277					
						0.515	31.657					

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <b>EIELSON AFB</b>	DATE <b>14 JULY 88</b>	RUN NUMBER <b>1</b>
BUILDING NUMBER	SOURCE NUMBER <b>BOILER #2</b>	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<b>0.4919</b>	<b>0.2903</b>	<b>.2016</b>
ACETONE WASHINGS (Probe, Front Half Filter)	<b>105.7112</b>	<b>105.3781</b>	<b>.3331</b>
BACK HALF (If needed)			-
Total Weight of Particulates Collected			<b>.5347 gm</b>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H <sub>2</sub> O)	<b>152 ml</b>	<b>100 ml</b>	<b>52.0 g</b>
IMPINGER 2 (H <sub>2</sub> O)	<b>152 ml</b>	<b>100 ml</b>	<b>52.0 g</b>
IMPINGER 3 (Dry)	<b>14 ml</b>	-	<b>14.0 g</b>
IMPINGER 4 (Silica Gel)	<b>337.3 g</b>	<b>2.00 g</b>	<b>137.3 g</b>
Total Weight of Water Collected			<b>255.3 gm</b>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<b>13.6</b>	<b>13.6</b>	<b>13.6</b>		<b>13.6</b>
VOL % O <sub>2</sub>	<b>6.0</b>	<b>5.8</b>	<b>5.8</b>		<b>5.9</b>
VOL % CO					
VOL % N <sub>2</sub>					

47  
Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)

**PRELIMINARY SURVEY DATA SHEET NO. 1**  
(Stack Geometry)

<small>BASE</small> Eielson AFB	<small>PLANT</small> CH & PP
<small>DATE</small> July 20	<small>SAMPLING TEAM</small> ECQ
<small>SOURCE TYPE AND MAKE</small>	

<small>SURVEY NUMBER</small> Boilers #2, #3	<small>INSIDE STACK DIAMETER</small> 52.5 Inches
<small>RELATED CAPACITY</small> 10	<small>TYPE FUEL</small> Coal
<small>DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER</small>	
<small>NUMBER OF TRAVERSES</small> 2	<small>NUMBER OF POINTS/TRAVERSE</small> 12 Inches

**LOCATION OF SAMPLING POINTS ALONG TRAVERSE**

POINT	PERCENT OF DIAMETER	DISTANCE FROM INSIDE WALL (Inches)	TOTAL DISTANCE FROM OUTSIDE OF NIPPLE TO SAMPLING POINT (Inches)
1			2.6
2			5.0
3			7.7
4			10.8
5			14.6
6			20.2
7			35.3
8			40.9
9			44.7
10			47.8
11			50.5
12			52.9

**PRELIMINARY SURVEY DATA SHEET NO. 2**  
(Velocity and Temperature Traverse)

BASE <b>Eielson</b>	DATE <b>July 88</b>	+ <b>2.8 in Diff</b> - <b>5.4 in Diff</b>
BOILER NUMBER <b>#2</b>		
INSIDE STACK DIAMETER <b>52.5</b> Inches		
STATION PRESSURE <b>29.235</b> In Hg		
STACK STATIC PRESSURE <b>- 1.45</b> In H2O		
SAMPLING TEAM <b>UEHL/ECQ</b>		

5  
411

TRAVERSE POINT NUMBER	VELOCITY HEAD, V <sub>p</sub> IN H2O	CYCLONIC $\frac{V_p}{\alpha}$	STACK TEMPERATURE (°F)
1	1.1	4°	402
2	1.5	0	402
3	1.6	0	411
4	1.6	0	414
5	1.5	1	414
6	1.4	0	414
7	1.3	0	414
8	1.3	0	413
9	1.3	0	412
10	1.3	10	412
11	1.1	0	412
12	0.84	0	410
		<u>1.25°</u>	
	MW <sub>3</sub> 28.17		
	$\overline{V_p}$ <del>5.30</del> 5.11	$\alpha = 0.218$	
	$\overline{V_p}$ 1.32		
	2934		
	$\overline{T}_{stack}$ 411		
	76.83		
	DSCFM 43,889		
	AVERAGE		

NOZZLE CALIBRATION DATA FORM

Date 14 JUL 58

Calibrated by GARRISON

Nozzle identification number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> mm (in.)	$D_{avg}$ <sup>c</sup>
	$D_1$ , mm (in.)	$D_2$ , mm (in.)	$D_3$ , mm (in.)		
0.25	0.251	0.252	0.252	0.001	0.252

where:

<sup>a</sup> $D_{1,2,3}$  = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of  $D_1$ ,  $D_2$ , and  $D_3$ .



VISIBLE EMISSION OBSERVATION FORM

Run #1  
No. 1 of 2

COMPANY NAME  
**EIELSON AFB**

STREET ADDRESS

---

CITY STATE ZIP

PHONE (KEY CONTACT) SOURCE ID NUMBER  
**CHAPP**

PROCESS EQUIPMENT OPERATING MODE  
**COAL-FIRED BOILER #2**

CONTROL EQUIPMENT OPERATING MODE  
**MULTICLONES**

DESCRIBE EMISSION POINT  
**TAPERED STACK SE CORNER OF BLDG.**  
**(LEAK BOILER HAS DEDICATED STACK)**

HEIGHT ABOVE GROUND LEVEL HEIGHT RELATIVE TO OBSERVER  
**14' INSIDE ROOF** Start **14"** End

DISTANCE FROM OBSERVER DIRECTION FROM OBSERVER  
Start **90'** End Start **SSW** End

DESCRIBE EMISSIONS **CONTINUOUS PLUME**

Start **CONTINUOUS** End

EMISSION COLOR IF WATER DROPLET PLUME  
Start **LT BROWN** End Attached  **N/A** Detached

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
Start **2-4" ABOVE STACK** End


DESCRIBE PLUME BACKGROUND

Start **SLIGHTLY HAZY** End

BACKGROUND COLOR SKY CONDITIONS  
Start **GREEN-WHITE** End **SAME** Start **SCATTERED** End **SAME**

WIND SPEED WIND DIRECTION  
Start **CALM** End **SAME** Start **CALM** End **SAME**

AMBIENT TEMP WET BULB TEMP RH. percent  
Start **75°F** End **78°F**



ADDITIONAL INFORMATION

OBSERVATION DATE		START TIME		END TIME	COMMENTS
SEC	MIN	0	15	30	
1	5	5	5	5	
2	5	5	5	5	ALL RUNS
3	5	5	5	5	EXHIBITED SOME
4	5	5	5	5	OPACITY
5	5	5	5	5	
6	5	5	5	5	
7	5	5	5	5	
8	5	5	5	5	
9	5	5	5	5	
10	5	5	5	5	
11	5	5	5	5	
12	5	5	5	5	
13	5	5	5	5	
14	5	5	5	5	
15	5	5	5	5	
16	5	5	5	5	
17	5	5	5	5	
18	5	5	5	5	
19	5	5	10	5	
20	10	10	5	5	
21	5	5	10	10	SLIGHT UPSET - GREATEST
22	15	10	10	10	OPACITY OCCURRED BETWEEN
23	10	10	10	5	21:15 + 21:30.
24	5	5	5	5	
25	5	5	5	5	
26	5	5	5	5	
27	5	5	10	10	
28	10	10	10	5	
29	5	5	5	5	
30	5	5	5	5	WENT - OVER TO PART B

OBSERVER'S NAME (PRINT)  
**M/3 JAMES A. GARRISON**

OBSERVER'S SIGNATURE DATE  
**James A. Garrison** **14 JULY 88**

ORGANIZATION  
**CSAF/CEHL/CCG**

CERTIFIED BY EASTERN TECHNICAL ASSOCIATE (STATE CERTIFIED DER) DATE  
**1 JUNE 88**

CONTINUED ON VEG FORM NUMBER

VISIBLE EMISSION OBSERVATION FORM

RUN #1  
No. 2 of 2

COMPANY NAME		
STREET ADDRESS		
CITY	STATE	ZIP
PHONE (KEY CONTACT)	SOURCE ID NUMBER BOILER # 2	

PROCESS EQUIPMENT	OPERATING MODE
CONTROL EQUIPMENT	OPERATING MODE

DESCRIBE EMISSION POINT


HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER Start          End	
DISTANCE FROM OBSERVER Start          End	DIRECTION FROM OBSERVER Start          End	

DESCRIBE EMISSIONS

Start	End	IF WATER DROPLET PLUME Attached <input type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start          End		

DESCRIBE PLUME BACKGROUND

Start	End	SKY CONDITIONS Start          End
BACKGROUND COLOR Start          End		WIND DIRECTION Start          End
WIND SPEED Start          End		WET BULB TEMP          RH, percent
AMBIENT TEMP Start          End		



ADDITIONAL INFORMATION

OBSERVATION DATE		START TIME			END TIME	COMMENTS
SEC	MIN	0	15	30	45	
1	5	5	5	5		
2	5	5	5	5		
3	10	10	10	10		
4	10	10	10	10		
5	10	10	10	5		
6	5	5	5	5		
7	5	5	5	10		
8	10	5	5	5		
9	5	5	5	5		
10	5	5	5	5		
11	5	5	5	5		
12	5	5	5	5		
13	5	10	10	10		
14	10	10	5	5		
15	5	5	5	5		
16	5	5	5	5		
17	5	5	5	5		
18	5	5	5	10		
19	10	10	10	5		
20	5	10	10	5		
21	5	5	5	10		
22	5	5	5	5		
23	5	5	5	5		
24	5	5	10	10		
25	10	10	10	5		
26	10	10	10	10		
27	10	10				
28						
29						
30						

OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE          DATE

ORGANIZATION

CERTIFIED BY          DATE

CONTINUED ON VEO FORM NUMBER

--	--	--	--	--	--

APPENDIX F

Boiler 3, Field Data, 100,000 lbs/hr, 17 July 88

(This page left blank)

1 of 2

1.736

Butler #3 PARTICULATE SAMPLING DATA SHEET

RUN NUMBER #1  
 DATE 17 July  
 PLANT CILEDD  
 BASE Eielson  
 SAMPLE BOX NUMBER RAC  
 METER BOX NUMBER  
 Qm: Qm  
 Co

AMBIENT TEMP 74  
 STATION PRESS 29.624  
 HEATER BOX TEMP  
 PROBE HEATER SETTING  
 PROBE LENGTH 72  
 NOZZLE AREA 254  
 Cp  
 DRY GAS CORRECTION (F) MW 28.17

EQUATIONS  
 $OR = OF + 460$   
 $H = \left[ \frac{5130 \cdot F \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Tm}{Ts} \cdot Vp$

SCHEMATIC OF STACK CROSS SECTION  
 N  
 W (5) (3) A (1) E  
 R  
 Pie leak check - good @ 15 in Hg  
 DP accuracy - within 4

100,000 lb/hr  
Scrub Blow

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (OF)	IMPINGER OUTLET TEMP (OF)
			(OF)	(TS) (OR)				IN (OF)	AVG (Tm) (OR)	OUT (OF)		
A 1	0	4.5	358		1.1	2.79	701.929	86		75	266	
2	25	2.5	365		1.5	3.82		80		76	275	
3	50	5.0	366		1.8	4.65		107		78	273	
4	75	6.0	365		2.0	5.22		115		79	261	
5	100	6.5	365		1.95	5.12		119		81	264	
6	125	7.0	365		1.95	5.13		122		82	241	
7	150	7.0	365		1.85	4.85		124		82	264	
8	175	7.5	365		1.9	5.02		124		85	242	
9	200	7.0	365		1.85	4.88		121		82	265	
10	225	6.2	364		1.70	3.11		123		85	240	
11	250	6.0	364		0.70	1.84		119		86	260	
12	275	0.5	360		0.01	0.03		115		86	243	

Conf. number 747

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER #1  
 DATE 17 July 88  
 PLANT CLEPP  
 BASE Erlson  
 SAMPLE BOX NUMBER RALC  
 METER BOX NUMBER  
 Qw: Qm  
 Co

SCHEMATIC OF STACK CROSS SECTION  
 Post leak check, general? On top?

EQUATIONS  

$$H = \left[ \frac{5130 \cdot F_d \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$

100,000 lb/hr  
 25 mm diameter

AMBIENT TEMP 75  
 STATION PRESS 29.628  
 HEATER BOX TEMP  
 PROBE HEATER SETTING  
 PROBE LENGTH  
 NOZZLE AREA (A) 1.254  
 Cp 1.84  
 DRY GAS FRACTION (Fd)

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	AVG (Tm) (°R)	OUT (°F)		
1	0	3.5	353		0.67	1.64	789.800	82	82	82	248	
2	2.5	6.0	355		0.74	1.64		102	85	85	248	
3	5.0	13.5	356		1.75	4.54		103	84	84	239	
4	7.5	13.5	358		1.65	4.33		108	84	84	262	
5	10.0	16.0	358		1.85	4.88		113	85	85	270	
6	12.5	16.5	360		1.85	4.88		116	85	85	258	
7	15.0	19.5	362		1.80	4.74		116	85	85	266	
8	17.5	20.0	355		1.80	4.81		117	86	86	243	
9	20.0	20.0	358		1.80	4.81		110	85	85	243	
10	22.5	24.0	358		1.80	4.74		109	85	85	254	
11	25.0	13.5	357		1.80	3.16	818.752	106	84	84	260	
12	27.5	14.0	357		1.80	2.14			97			
			361			3.84						
						7.95	33.8455					

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <b>EIELSON AFB</b>	DATE <b>17 JUL 88</b>	RUN NUMBER <b>1</b>
----------------------------	--------------------------	------------------------

BUILDING NUMBER	SOURCE NUMBER <b>Boiler # 3</b>
-----------------	------------------------------------

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<b>0.6714</b>	<b>0.2854</b>	<b>0.3860</b>
ACETONE WASHINGS (Probe, Front Half Filter)	<b>107.8106</b>	<b>107.4366</b>	<b>0.3740</b>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<b>0.7600 gm</b>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<b>177</b>	<b>100</b>	<b>77</b>
IMPINGER 2 (H2O)	<b>140</b>	<b>100</b>	<b>40</b>
IMPINGER 3 (Dry)	<b>8.6</b>	<b>0.0</b>	<b>8.6</b>
IMPINGER 4 (Silica Gel)	<b>336.4</b>	<b>300</b>	<b>36.4</b>
Total Weight of Water Collected			<b>gm</b>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<b>10.6</b>	<b>10.6</b>	<b>10.6</b>	<b>10.6</b>	<b>10.6</b>
VOL % O <sub>2</sub>	<b>8.8</b>	<b>8.8</b>	<b>8.8</b>	<b>8.8</b>	<b>8.8</b>
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)

copy 2

$\Delta H_a = 1.736$

PARTICULATE SAMPLING DATA SHEET

Boiler #3


AMBIENT TEMP	77	°F
STATION PRESS	29.630	in Hg
HEATER BOX TEMP		°F
PROBE HEATER SETTING		
PROBE LENGTH	72	in
NOZZLE AREA	1.55	sq ft
Cp	1.84	
DRY GAS PRODUCTION (FGD)	2817	

EQUATIONS

$$^{\circ}R = ^{\circ}F + 460$$

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$$

100% (or 100%)



RUN NUMBER	#2
DATE	17 July 88
PLANT	CHS PUD
BASE	Erickson
SAMPLE BOX NUMBER	RAC
METER BOX NUMBER	
Q <sub>ST</sub> /Q <sub>m</sub>	

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (psi)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	OUT (°F)		
1	10.5	0.41	354		4.6	0.16	818.512	82	81	252	
2	10.5	0.41	354		7.3	0.26		84	81	263	
3	10.5	0.41	354		1.4	0.54		87	82	275	
4	10.5	0.41	354		1.5	0.54		91	82	274	
5	10.5	0.41	354		1.8	0.64		93	83	268	
6	10.5	0.41	354		1.8	0.64		94	83	268	
7	10.5	0.41	354		1.8	0.64		94	83	268	
8	10.5	0.41	354		1.8	0.64		94	83	268	
9	20.0	0.41	354		1.8	0.64		95	84	263	
10	20.0	0.41	354		1.85	0.66		97	82	266	
11	27.5	0.41	354		1.75	0.62		97	83	268	
12	27.5	0.41	354		1.74	0.43		96	83	246	
	27.5	0.41	354		0.55	0.20		91	83	254	
3 min sampling time											



## PARTICULATE SAMPLING DATA SHEET

RUN NUMBER <div style="font-size: 24pt; font-weight: bold; text-align: center;"># 2</div>	AMBIENT TEMP <div style="font-size: 24pt; font-weight: bold; text-align: center;">78</div>	OF
DATE 17 Jun 88	STATION PRESS 29.620	In Hg
PLANT CHEPP	HEATER BOX TEMP	OF
BASE E. I. du Pont	PROBE HEATER SETTING 72	
SAMPLE BOX NUMBER RAC	PROBE LENGTH 155	in
METER BOX NUMBER	NOZZLE AREA (A) Cp	sq ft
Q <sub>1</sub> /Q <sub>m</sub> Cs	DRY GAS FRACTION (Fd)	

### EQUATIONS

$^{\circ}R = ^{\circ}F + 460$

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$$

100,000 lb/hr

### SCHEMATIC OF STACK CROSS SECTION

Post Leaks Check good ok 20

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (In H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (Cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	AVG (T <sub>m</sub> ) (°R)	OUT (°F)		
1	10	1.5	355		1.25	0.45	843.621	83		81	253	
2	4.5	1.5	358		1.53	0.55		84		82	251	
3	5.0	1.8	364		1.77	0.62		85		81	274	
4	7.5	1.0	366		1.90	0.67		84		81	271	
5	10.0	1.0	368		1.90	0.67		88		82	253	
6	12.5	1.0	368		1.90	0.67		89		87	245	
7	15.0	2.0	368		1.85	0.65		90		87	263	
8	17.5	2.0	368		1.85	0.65		93		81	234	
9	20.0	2.5	368		1.85	0.65		94		81	261	
10	22.5	3.0	368		1.18	0.43		94		82	260	
11	24.0	4.0	366		.58	0.21		94		82	234	
12	27.5	1.0	366		.56	0.20	848.551	92		83		
$\bar{H} = .52$							$\bar{H} = 30.039$					
$\bar{H} = 363$												
$UBS = 33.905$												
$Cu F = 840.551 - 818.512 = 30.039$												

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <b>EIFELSON</b>		DATE <b>17 JULY 88</b>		RUN NUMBER <b>#2</b>	
BUILDING NUMBER <b>CH + PP</b>			SOURCE NUMBER <b>BOILER #3</b>		
<b>I. PARTICULATES</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	<b>0.4415</b>	<b>0.2850</b>	<b>0.1565</b>		
ACETONE WASHINGS (Probe, Front Half Filter)	<b>99.7674</b>	<b>99.6269</b>	<b>0.1405</b>		
BACK HALF (if needed)					
			Total Weight of Particulates Collected		<b>0.2970 gm</b>
<b>II. WATER</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H <sub>2</sub> O)	<b>143</b>	<b>100</b>	<b>43</b>		
IMPINGER 2 (H <sub>2</sub> O)	<b>114</b>	<b>100</b>	<b>14</b>		
IMPINGER 3 (Dry)	<b>4</b>	<b>0</b>	<b>4</b>		
IMPINGER 4 (Silica Gel)	<b>310.7</b>	<b>300</b>	<b>10.7</b>		
			Total Weight of Water Collected		<b>71.7 gm</b>
<b>III. GASES (Dry)</b>					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<b>10.6</b>	<b>10.6</b>	<b>10.6</b>		<b>10.6</b>
VOL % O <sub>2</sub>	<b>8.4</b>	<b>8.4</b>	<b>8.4</b>		<b>8.4</b>
VOL % CO					
VOL % N <sub>2</sub>					
Vol % N <sub>2</sub> = (100% - % CO <sub>2</sub> - % O <sub>2</sub> - % CO)					

602

Sta 1736


PARTICULATE SAMPLING DATA SHEET

Boiler #3

RUN NUMBER	#3	AMBIENT TEMP	78 °F
DATE	17 July 88	STATION PRESS	29.62 in Hg
PLANT	EHEDP	HEATER BOX TEMP	°F
BASE	Erglson	PROBE HEATER SETTING	°F
SAMPLE BOX NUMBER	RAC	PROBE LENGTH	72 in
METER BOX NUMBER		NOZZLE AREA (A)	.153 sq ft
Q <sub>w</sub> /Q <sub>m</sub>		Cp	.84
Co		DRY GAS FRACTION (F <sub>d</sub> )	

SCHEMATIC OF STACK CROSS SECTION

WSE



Pre-check at 15 in. by good

°R = °F + 460

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$

100,000 lbf/hr

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (°F)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	AVG (T <sub>m</sub> ) (°R)	OUT (°F)		
1	0	1.01	350		0.55	0.20	848.727	87		81	240	
2	3.5	1.5	365		0.50	0.28		86		82	254	
3	7.0	1.06	378		1.20	0.42		88		87	261	
4	10.5	2.11	380		1.60	0.56		91		87	271	
5	14.0	2.4	384		1.80	0.63		94		87	258	
6	17.5	2.5	381		1.84	0.63		92		85	247	
7	21.0	2.7	381		1.87	0.65		94		84	233	
8	24.5	2.7	381		1.80	0.63		97		84	221	
9	28.0	2.8	379		1.85	0.65		96		84	240	
10	31.5	2.6	379		1.65	0.50		94		83	225	
11	35.0	2.3	379		1.20	0.42		95		83	253	
12	38.5	2.0	380		0.79	0.28		95		83	272	
	42.0											

(Cont) 2 of 2-

PARTICULATE SAMPLING DATA SHEET										
SCHEMATIC OF STACK CROSS SECTION										
TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP (°F) (T <sub>s</sub> )	VELOCITY HEAD (V <sub>p</sub> )	ORIFICE GIFF. PRESS. (Fi)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		IMPINGER OUTLET TEMP (°F)	
			(°F)				IN (°F)	OUT (°F)		
1	6	2.1	361	1.1	0.39	865.074	40	83	257	
2	3.5	2.5	376	1.4	0.59		42	87	257	
3	7.0	3.1	381	1.75	0.61		45	85	253	
4	10.5	3.5	380	1.90	0.67		44	87	263	
5	14.5	3.5	383	1.95	0.68		46	84	267	
6	17.5	3.5	383	1.90	0.66		44	85	225	
7	21.5	3.5	383	1.8	0.63		45	84	279	
8	24.5	3.5	378	1.8	0.63		49	87	239	
9	28.0	3.4	378	1.7	0.59		46	83	276	
10	31.2	2.6	378	0.89	0.31		46	82	225	
11	35.2	1.6	379	0.31	0.11		46	83	254	
12	38.5	1.4	377	0.11	0.04	881.041	81	84	213	
42 stop			377		ΔH = 0.49			88		
Total Time 84 min										
100,000 cu ft										
7 PSTs = 33.2152										
Cubic ft 881.041 - 848.727 = 32.314										

Plant #3

PIN NUMBER #3

DATE 17 July

PLANT CITE PD

SAVE Explor

SAMPLE BOX NUMBER RHC

METER BOX NUMBER

Post looks check at 5:14

EQUATIONS

$$\rho R = \rho F + 460$$

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_0} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$$

AMBIENT TEMP	78	OF
STATION PRESS	29.626	in Hg
HEATER BOX TEMP		OF
PROBE HEATER SETTING		OF
PROBE LENGTH	12	in
NOZZLE AREA (sq in)	1.55	sq in
CP	.84	
DRY GAS FRACTION (Fd)		

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>Evelson</i>	DATE <i>17<del>th</del> July 58</i>	RUN NUMBER <i>#3</i>
BUILDING NUMBER <i>CH&amp;DD</i>	SOURCE NUMBER <i>Boiler #3</i>	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.4352</i>	<i>.2877</i>	<i>.1475</i>
ACETONE WASHINGS (Probe, Front Half Filter)	<i>98.8771</i>	<i>98.7231</i>	<i>.1540</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>.3015 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H <sub>2</sub> O)	<i>194 ml</i>	<i>100</i>	<i>94</i>
IMPINGER 2 (H <sub>2</sub> O)	<i>70 ml</i>	<i>100</i>	<i>-30</i>
IMPINGER 3 (D <sub>2</sub> O)	<i>1 ml</i>	<i>0</i>	<i>1</i>
IMPINGER 4 (Silica Gel)	<i>318.6</i>	<i>300</i>	<i>18.6</i>
Total Weight of Water Collected			<i>83.6 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<i>10.6</i>	<i>5.6</i>	<i>5.6</i>		<i>10.4</i>
VOL % O <sub>2</sub>	<i>0.4</i>	<i>0.4</i>	<i>0.4</i>		<i>0.4</i>
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = 100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO

**PRELIMINARY SURVEY DATA SHEET NO. 1**  
(Stack Geometry)

BASE <i>Edison AFB</i>	PLANT <i>CH &amp; DP</i>
DATE <i>7-20 July</i>	SAMPLING TEAM <i>ECQ</i>
SOURCE TYPE AND MAKE	
SOURCE NUMBER <i>Boilers #2, #3</i>	INSIDE STACK DIAMETER <i>52.5</i> Inches
RELATED CAPACITY <i>10</i>	TYPE FUEL <i>Coal</i>
DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER <i>1.5</i> Inches	
NUMBER OF TRAVERSES <i>2</i>	NUMBER OF POINTS/TRAVERSE <i>12</i>

LOCATION OF SAMPLING POINTS ALONG TRAVERSE

POINT	PERCENT OF DIAMETER	DISTANCE FROM INSIDE WALL (Inches)	TOTAL DISTANCE FROM OUTSIDE OF NIPPLE TO SAMPLING POINT (Inches)
<i>1</i>			<i>2.6</i>
<i>2</i>			<i>5.0</i>
<i>3</i>			<i>7.7</i>
<i>4</i>			<i>10.8</i>
<i>5</i>			<i>14.6</i>
<i>6</i>			<i>20.2</i>
<i>7</i>			<i>35.3</i>
<i>8</i>			<i>40.9</i>
<i>9</i>			<i>44.7</i>
<i>10</i>			<i>47.8</i>
<i>11</i>			<i>50.5</i>
<i>12</i>			<i>52.9</i>

**PRELIMINARY SURVEY DATA SHEET NO. 2**  
(Velocity and Temperature Traverse)

BASE <b>Eielson</b>	DATE <b>17 July 88</b>
BOILER NUMBER <b>#3</b>	
INSIDE STACK DIAMETER <b>52.5</b>	Inches <b>P.H. -37 +53</b>
STACK AREA <b>29.624</b>	In. Hg
STACK STATIC PRESSURE <b>-1.9</b>	In H <sub>2</sub> O
SAMPLING TEAM <b>EPG</b>	

TRAVERSE POINT NUMBER	VELOCITY HEAD, Vp IN H <sub>2</sub> O	CYCLONE $\frac{V_p}{V} \alpha$	STACK TEMPERATURE (OF)
1	0.74	1 <sup>0</sup>	355
2	0.91	3	356
3	1.3	1	358
4	1.6	1	360
5	1.9	2	360
6	1.9	2	360
7	1.9	0	360
8	<del>1.9</del> 1.9	1	361
9	<del>1.85</del> 1.85	0	360
10	<del>1.8</del> 1.8	0	360
11	<del>1.30</del> 1.30	3	359
12	0.53	4	357

M.W. = 28.17    PV. = 1.5°

F.S. = 5

AVERAGE

NOZZLE CALIBRATION DATA FORM

Date 17 July 88 Calibrated by Fogin

Nozzle identification number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> mm (in.)	$D_{avg}$ <sup>c</sup>
	$D_1$ mm (in.)	$D_2$ mm (in.)	$D_3$ mm (in.)		
stack #3 run 1 .25	.254	.254	.253	.001	.254
run 2 & 3 .15	.155	.155	.154	.001	.155
18 July	.25 $\phi$	.25 $\phi$	.251	.001	.25 $\phi$

where:

- <sup>a</sup> $D_{1,2,3}$  = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.
- <sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$
- <sup>c</sup>  $D_{avg}$  = average of  $D_1$ ,  $D_2$ , and  $D_3$ .



VISIBLE EMISSION OBSERVATION FORM

No.

COMPANY NAME  
**EIELSON AFB**

STREET ADDRESS

CITY STATE ZIP

PHONE (KEY CONTACT) SOURCE ID NUMBER  
**BOILER # 3**

OBSERVATION DATE		START TIME		END TIME	COMMENTS
SEC	MIN	0	15	30	
1	5	5	5	5	ALL RUNS
2	5	10	5	5	EXHIBITED SMOKE
3	5	5	5	5	OPACITY
4	5	5	10	5	
5	5	10	10	10	
6	10	10	10	5	
7	5	5	5	5	
8	5	5	5	5	
9	5	5	5	5	
10	5	5	5	10	
11	5	5	5	5	
12	5	5	5	10	
13					
14					
15					
16					
17					
18					
19					
20	50	75	75	50	
21	30	20	60	5	
22	20	40	50	10	
23					
24					
25					
26					
27					
28					
29					
30					

PROCESS EQUIPMENT  
**COAL-FIRED BOILER**

OPERATING MODE  
**100.000 4/hr**

CONTROL EQUIPMENT  
**MULTICLINE**

OPERATING MODE

DESCRIBE EMISSION POINT  
**TAPERED STEEL STACK**

HEIGHT ABOVE GROUND LEVEL  
**108'**

HEIGHT RELATIVE TO OBSERVER  
Start **108'** End **SAME**

DISTANCE FROM OBSERVER  
Start **350'** End **SAME**

DIRECTION FROM OBSERVER  
Start End

DESCRIBE EMISSIONS  
Start **CONING** End **SAME**

EMISSION COLOR  
Start **LT BROWN** End **SAME**

IF WATER DROPLET PLUME  
Attached **N/A** Detached

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
Start **1-5' ABOVE STACK** End **SAME**

DESCRIBE PLUME BACKGROUND  
Start **BLUE SKY** End **SAME**


BACKGROUND COLOR  
Start **SKY** End **SAME**

WIND SPEED  
Start **6 KTS** End **SAME**

WIND DIRECTION  
Start **SE** End **SAME**

AMBIENT TEMP  
Start **75 F** End

WET BULB TEMP RH percent



OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE

ORGANIZATION

DATE

DATE

CONTINUED ON VEG FORM NUMBER

(This page left blank)

APPENDIX G

Boiler 3, Field Data, 100,000 lbs/hr, 18 July 88

(This page left blank)

Sta 207

Run #3

PARTICULATE SAMPLING DATA SHEET

10fz  
 AMBIENT TEMP 77  
 STATION PRESS 29.789 in Hg  
 HEATER BOX TEMP  
 PROBE-METER SETTING FPS = 80  
 PROBE LENGTH F 72 in  
 NOZZLE AREA (A) 2.50 sq ft  
 Cp .84  
 DRY GAS FRACTION (F<sub>D</sub>)

SCHEMATIC OF STACK CROSS SECTION  

$$H = \left[ \frac{5130 \cdot F_D \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$
  
 WIND 13005  
 100,000 lb/h  
 Cool Sample 3792

(5) - 300 (1) w/s  
 Tie leak check at 19 in Hg  
 DP across multichine 4  
 MW = 30.0  
 H<sub>2</sub>O = 10.5  
 static P = -1.1

Run #1  
 DATE 18 July 88  
 P-PLANT 2149 TDP  
 BASE 1145 DM  
 SAMPLE BOX NUMBER 2410 ALTRCH  
 METER BOX NUMBER  
 Q<sub>w</sub>/Q<sub>m</sub>  
 Co

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	VACUUM STARTING PRESSURE (mm-Hg)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (ft)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	OUT (°F)		
1	0	-3.0	380		0.62	1.64	209.427	97	98	233	54
2	2.5	-3.0	380		0.81	2.13		97	98	243	56
3	5.0	-4.0	380		1.1	4.10		98	98	243	57
4	7.5	-5.0	380		1.55	4.63		101	98	249	53
5	10.0	-6.0	390		1.75	4.63		103	98	249	58
6	12.5	-6.2	390		1.75	4.63		105	99	251	58
7	15.0	-7.0	380		1.65	4.63		106	99	248	60
8	17.5	-8.0	380		1.80	4.74		107	100	252	72
9	20.0	-8.0	380		1.75	4.66		107	100	246	72
10	22.5	-8.0	380		1.65	4.41		108	100	235	71
11	25.0	-7.0	380		1.25	3.34		109	100	252	73
12	27.5	-6.2	380		0.98	2.62		107	100	257	75

T<sub>s</sub> = 380.2 ΔP 1.40  
 ΔH = 3.73  
 IN/out T = 103

TPTS = 34.0274  
 CUBIC FT = 54.251

PARTICULATE SAMPLING DATA SHEET

2 of 2  
78

RUN NUMBER	18	AMBIENT TEMP (°F)	78
DATE	18 July 88	STATION PRESS	29.789
PLANT	CH DTD	HEATER BOX TEMP	
BASE	1100	PROBE HEATER SETTING	
SAMPLE BOX NUMBER	2416	PROBE LENGTH	72
METER BOX NUMBER		NOZZLE AREA (A)	258
Flow Qm		Cp	84
Co		DRY GAS FRACTION (Fg)	

EQUATIONS

$OR = OF + 460$

$H = \left[ \frac{5130 \cdot Fg \cdot Co \cdot A}{Co} \right]^2 \cdot \frac{Im}{Is} \cdot Vp$

100,000.66/67

Mix local load  
from 230.531  
to 230.620  
0.087

Schematic of Stack Cross Section

Disk located at -11 ft

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(Ts) (°F)				IN (°F)	OUT (°F)		
1	0	-6.4	382		1.6	2.5	230.620	102	100	258	67
2	2.5	-6.5	387		1.5	3.05		102	100	261	67
3	3.0	-8.5	388		1.64	4.25		104	100	253	65
4	3.0	-7.5	387		1.75	4.66		105	100	262	73
5	10.6	-10.0	387		1.80	4.78		106	100	263	78
6	13.2	-10.2	384		1.80	4.79		107	100	260	76
7	15.0	-10.3	387		1.74	4.65		108	101	262	78
8	17.5	-10.7	386		1.75	4.68		108	102	262	78
9	20.0	-10.8	387		1.65	4.3		108	102	262	78
10	22.5	-1.0	385		1.15	3.08		108	102	262	80
11	25.0	-8.4	385		0.82	2.24		108	102	265	78
12	27.5	-6.5	386		0.62	1.66	257.767	108	102	262	76

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <b>FEILSON AF13</b>		DATE <b>18 JULY 88</b>		RUN NUMBER <b>BOILER 3 R1</b>	
BUILDING NUMBER <b>CHAPP</b>			SOURCE NUMBER <b>BOILER 3</b>		
<b>I. PARTICULATES</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	<b>0.5428</b>	<b>0.2857</b>	<b>0.3072</b>		
ACETONE WASHINGS (Probe, Front Hall Filter)	<b>107.7100</b>	<b>107.4346</b>	<b>0.2734</b>		
BACK HALF (if needed)					
			Total Weight of Particulates Collected		<b>0.5805 gm</b>
<b>II. WATER</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	<b>141</b>	<b>100</b>	<b>41</b>		
IMPINGER 2 (H2O)	<b>138</b>	<b>100</b>	<b>38</b>		
IMPINGER 3 (Dry)	<b>11.9</b>	<b>0</b>	<b>11.9</b>		
IMPINGER 4 (Silica Gel)	<b>327.1</b>	<b>300</b>	<b>27.3</b>		
			Total Weight of Water Collected		<b>118.2 gm</b>
<b>III. GASES (Dry)</b>					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<b>9.0</b>	<b>9.0</b>	<b>9.0</b>		<b>9.0</b>
VOL % O <sub>2</sub>	<b>9.6</b>	<b>9.6</b>	<b>9.6</b>		<b>9.6</b>
VOL % CO					
VOL % N <sub>2</sub>					
Vol % N <sub>2</sub> = (100% - % CO <sub>2</sub> - % O <sub>2</sub> - % CO)					

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER # 2	AMBIENT TEMP 79
DATE 18 July 88	STATION PRESS 29.789
PLANT ELECTRA	HEATER BOX TEMP
BASE CH PD	PROBE HEATER SETTING
SAMPLE BOX NUMBER 2610	PROBE LENGTH 72
METER BOX NUMBER	NOZZLE AREA 25
Q <sub>w</sub> /Q <sub>m</sub>	CP
Co	DRY GAS FRACTION (F <sub>D</sub> ) .87

SCHEMATIC OF STACK CROSS SECTION



Pre existing (existing)

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$

100000 W/hr

Coal Sample 5798

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STACK PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	OUT (°F)		
1	2.0	-6.2	383	383	0.72	2.45	2579.65	100	101	250	58
2	2.5	-8.5	384	384	1.10	2.73		102	101	248	57
3	5.0	-11.5	388	388	1.40	3.72		104	101	250	56
4	2.5	-10.5	388	388	1.75	4.66		106	101	255	60
5	10.0	-18.5	388	388	1.80	4.73		105	101	250	61
6	12.5	-18.5	387	387	1.8	4.80		106	102	252	64
7	15.0	-18.5	387	387	1.75	4.67		106	102	255	64
8	11.5	-17.8	387	387	1.8	4.80		106	101	258	64
<del>9</del>	<del>10.0</del>	<del>-18.0</del>	<del>387</del>	<del>387</del>	<del>1.8</del>	<del>4.80</del>	<del></del>	<del>105</del>	<del>101</del>	<del>250</del>	<del>64</del>
9	10.0	-18.9	387	387	1.5	4.10		105	101	263	66
10	12.5	-8.5	387	387	0.69	1.81		105	107	264	65
11	15.0	-3.4	386	386	0.15	0.44		105	102	264	65
12	21.5	-3.4	386	386	0.19	0.37	282.754	105	102	264	66
		T <sub>m</sub> = 104	T <sub>s</sub> = 386								
		AT =									
		AH = 342									
		PSB = 31.8630									



2 of 2

PARTICULATE SAMPLING DATA SHEET

Filter #3

Run Number: A2

TRaverse Point Number	Sampling Time (min)	Stack Pressure (in H <sub>2</sub> O)	Stack Temp		Velocity Head (Vp)	Orifice Diff. Press. (in)	Gas Sample Volume (cu ft)	Gas Meter Temp			Sample Box Temp (°F)	Impinger Outlet Temp (°F)
			(°F)	(°R)				In (°F)	Avg (T <sub>m</sub> ) (°R)	Out (°F)		
B1	0	-6.0	385		0.51	1.36	282.873	102		102	259	64
B2	2.5	-8.0	385		0.72	1.92		102		102	258	54
3	5.0	-11.5	386		1.10	2.93		104		102	259	54
4	7.5	-14.0	386		1.50	4.01		105		102	260	52
5	10.0	-16.0	387		1.70	4.54		107		102	258	61
6	12.5	-17.5	388		1.70	4.54		107		102	256	60
7	15.0	-19.5	388		1.75	4.67		108		102	260	62
8	17.5	-19.8	387		1.75	4.68		108		102	261	64
9	20.0	-20.0	386		1.7	4.51		106		102	260	63
10	22.5	-20.0	387		1.65	4.40		106		102	260	62
11	25.0	-18.0	388		1.15	3.09		106		104	264	72
12	27.5	-12.0	383		0.74	1.99	307.732	106		108	265	73

WAC

OR = °F + 460

$$H = \left[ \frac{5130 \cdot F_d \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$

1st Intermediate taken at 10.0 in. spot  
 to 282.873  
 from 282.254  
 2nd Intermediate -11.9  
 to 282.971  
 from 282.873

116.5 cc @ 60/61

CUMULATIVE = 49.554

Schematic of Stack Cross Section

AMBIENT TEMP

STATION PRESS

HEATER BOX TEMP

PROBE HEATER SETTING

PROBE LENGTH

NOZZLE AREA (A)

Cp

DRY GAS FRACTION (F<sub>D</sub>)

in Hg

sq ft

°F

°F

in

sq ft

°F

in

sq ft

°F

in Hg

°F

in Hg

°F

in Hg

°F

in Hg

°F

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>Eielson</i>	DATE <i>18 July</i>	RUN NUMBER <i>2</i>
BUILDING NUMBER <i>CHDP</i>	SOURCE NUMBER <i>Boiler # 3</i>	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.5698</i>	<i>.2876</i>	<i>.2822</i>
ACETONE WASHINGS (Probe, Front Half Filter)	<i>99.8124</i>	<i>99.6269</i>	<i>.1851</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>.4673 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H <sub>2</sub> O)	<i>168</i>	<i>100</i>	<i>68</i>
IMPINGER 2 (H <sub>2</sub> O)	<i>111</i>	<i>100</i>	<i>11</i>
IMPINGER 3 (Dry)	<i>5.4</i>	<i>—</i>	<i>5.4</i>
IMPINGER 4 (Silica Gel)	<i>333</i>	<i>300</i>	<i>33</i>
Total Weight of Water Collected			<i>117.4 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<i>10.0</i>	<i>10.0</i>	<i>10.0</i>		<i>10.0</i>
VOL % O <sub>2</sub>	<i>9.4</i>	<i>9.4</i>	<i>9.4</i>		<i>9.4</i>
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)

Sta 207

Run #13

PARTICULATE SAMPLING DATA SHEET

1 of 2

RUN NUMBER	DATE	PLANT	BASE	SAMPLE BOX NUMBER	METER BOX NUMBER	V <sub>1</sub> STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS AFTER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
							(°F)	(°R)				IN (°F)	OUT (°F)		
#3	18 July	Mill #1	2015m	7010		-2.4	384	0.60	1.66	307.713	102	101	267	73	
						-2.4	384	0.74	2.93		102	101	267	73	
						-5.0	380	1.14	2.93		104	102	270	74	
						-5.0	380	1.45	3.87		106	102	272	67	
						-6.4	384	1.10	4.54		109	103	272	70	
						-6.4	384	1.13	4.54		109	103	266	83	
						-7.5	384	1.75	4.71		111	103	259	88	
						-7.5	384	1.75	4.71		111	107	273	88	
						-8.4	380	1.23	4.57		111	107	272	89	
						-5.0	384	1.05	2.82		111	104	266	79	
						-5.6	384	0.78	2.10	335.917	110	105	258	75	

SCHEMATIC OF STACK CROSS SECTION

SOOT BLOW at 1930

stopped at 1932



each check as soon as good

100,000 WPM

P<sub>3</sub> = 1.1

Coal sample 3786

AMBIENT TEMP	79 °F
STATION PRESS	21.789 in Hg
HEATER BOX TEMP	
PROBE HEATER SETTING	
PROBE LENGTH	72 in
NOZZLE AREA (A)	.25 sq ft
Cp	.84
DRY GAS FRACTION (Fd)	N <sub>2</sub> = 30.0

77  
1805

PARTICULATE SAMPLING DATA SHEET

2072

PLANT NUMBER: # 3  
 DATE: 16 July  
 PLANT: 2175  
 BASE: 10/10  
 SAMPLE BOX NUMBER:  
 METER BOX NUMBER:  
 NO. OF:   
 AMBIENT TEMP: 72  
 STATION PRESS:   
 HEATER BOX TEMP:   
 PROBE HEATER SETTING:   
 PROBE LENGTH: 72  
 NOZZLE AREA (A):   
 Cp: .81  
 DRY GAS FRACTION (Fd):   
 OF:   
 in Hg:   
 OF:   
 in:   
 sq ft:

SCHMATIC OF STACK CROSS SECTION

EQUATIONS

$OR = OF + 460$

$H = \left[ \frac{5120 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$

Part load, clean, at 15 m/hg  
good

33000 cfm

33000

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (Pi)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (OF)	IMPINGER OUTLET TEMP (OF)
			(OF)	(Ts) (OR)				IN (OF)	AVG (Tm) (OR)	OUT (OF)		
1	2.0	-6.5	385	9.0	2.91	325.717	107	104	104	267	67	
2	2.5	-7.0	384	7.5	3.09		107	104	104	260	65	
3	3.0	-8.5	381	7.5	4.02		108	107	107	266	65	
4	2.5	-10.0	387	7.0	4.95		108	105	105	267	71	
5	1.0	-11.0	385	8.0	4.83		107	107	107	269	75	
6	2.5	-11.5	382	8.0	4.82		107	104	104	266	78	
7	2.0	-12.0	384	7.5	4.72		107	107	107	268	74	
8	2.0	-12.0	377	7.0	4.64		108	107	107	268	75	
9	2.0	-13.0	380	6.5	4.19		108	107	107	269	75	
10	2.5	-14.0	381	6.5	2.59		108	104	104	262	69	
11	2.5	-8.0	380	6.8	1.87	365.475	108	105	105	263	68	
							T = 1006					
							ΔH = 3.74					
							T <sub>2515</sub> = 33.896					
							C <sub>w</sub> F = 53.712					

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <b>EIKELSON</b>		DATE <b>18 July 88</b>		RUN NUMBER <b>3</b>	
BUILDING NUMBER <b>CH &amp; PP</b>			SOURCE NUMBER <b>BEILER 3</b>		
<b>I. PARTICULATES</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	<b>0.7544</b>	<b>0.2851</b>	<b>0.4693</b>		
ACETONE WASHINGS (Probe, Front Half Filter)	<b>49.2870</b> <del>0.7</del>	<b>98.7231</b>	<b>0.5039</b>		
BACK HALF (if needed)					
			Total Weight of Particulates Collected		<b>1.0332 gm</b>
<b>II. WATER</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	<b>140</b>	<b>100</b>	<b>40</b>		
IMPINGER 2 (H2O)	<b>144</b>	<b>100</b>	<b>44</b>		
IMPINGER 3 (Dry)	<b>12</b>	<b>0</b>	<b>12</b>		
IMPINGER 4 (Silica Gel)	<b>333.4</b>	<b>300</b>	<b>33.4</b>		
			Total Weight of Water Collected		<b>129.4 gm</b>
<b>III. GASES (Dry)</b>					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<b>10.6</b>	<b>10.6</b>	<b>10.2</b>		<b>10.1</b>
VOL % O <sub>2</sub>	<b>9.4</b>	<b>9.4</b>	<b>9.6</b>		<b>9.5</b>
VOL % CO					
VOL % N <sub>2</sub>					
Vol % N <sub>2</sub> = (100% - % CO <sub>2</sub> - % O <sub>2</sub> - % CO)					

**PRELIMINARY SURVEY DATA SHEET NO. 1**  
(Stack Geometry)

BASE <i>Eielson AFB</i>		PLANT <i>CH &amp; PD</i>	
DATE <i>14-20 July</i>		SAMPLING TEAM <i>ECC</i>	
SOURCE TYPE AND MAKE			
SOURCE NUMBER <i>Boilers #2, #3</i>		INSIDE STACK DIAMETER <i>52.5</i> Inches	
RELATED CAPACITY <i>10</i>		TYPE FUEL <i>Coal</i>	
DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER <i>1.5</i> Inches			
NUMBER OF TRAVERSES <i>2</i>		NUMBER OF POINTS/TRAVERSE <i>12</i>	
<b>LOCATION OF SAMPLING POINTS ALONG TRAVERSE</b>			
POINT	PERCENT OF DIAMETER	DISTANCE FROM INSIDE WALL (Inches)	TOTAL DISTANCE FROM OUTSIDE OF NIPPLE TO SAMPLING POINT (Inches)
1			<i>2.6</i>
2			<i>5.0</i>
3			<i>7.7</i>
4			<i>10.8</i>
5			<i>14.6</i>
6			<i>20.2</i>
7			<i>35.3</i>
8			<i>40.9</i>
9			<i>44.7</i>
10			<i>47.8</i>
11			<i>50.5</i>
12			<i>52.9</i>



NOZZLE CALIBRATION DATA FORM

Date 18 JULY

Calibrated by GARRISON

Nozzle identification number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> mm (in.)	$D_{avg}$ <sup>c</sup>
	$D_1$ , mm (in.)	$D_2$ , mm (in.)	$D_3$ , mm (in.)		
.25	0.250	0.250	0.251	0.001	0.250

where:

<sup>a</sup> $D_{1,2,3}$  = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  
 $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of  $D_1$ ,  $D_2$ , and  $D_3$ .

Quality Assurance Handbook MS-2.6



VISIBLE EMISSION OBSERVATION FORM

No.

COMPANY NAME  
**FIELSON AFB**

STREET ADDRESS

CITY STATE ZIP  
STATE **AK**

PHONE (KEY CONTACT) SOURCE ID NUMBER  
**BOILER #3**

OBSERVATION DATE **18 July 88** START TIME **1303** END TIME **1313**

PROCESS EQUIPMENT **COAL-FIRED BOILER** OPERATING MODE **100,000 lb/hr**

CONTROL EQUIPMENT **MULTICLONES** OPERATING MODE

DESCRIBE EMISSION POINT  
**TAPERED STEEL STACK**

HEIGHT ABOVE GROUND LEVEL **14** HEIGHT RELATIVE TO OBSERVER  
Start **14** End **SAME**

DISTANCE FROM OBSERVER **90'** DIRECTION FROM OBSERVER  
Start **NW** End **SAME**

DESCRIBE EMISSIONS **VERTICAL PLUME - ALMOST INVIS.**

EMISSION COLOR **LT BROWN** IF WATER DROPLET PLUME  
Start **SAME** Attached  **N/A** Detached


POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
Start **2-5' ABOVE STACK** End **SAME**

DESCRIBE PLUME BACKGROUND  
Start **HAZY** End

BACKGROUND COLOR **SKY BLUE** SKY CONDITIONS  
Start **W/STR** End **SAME** Start **SCATTERED** End **SAME**

WIND SPEED **CALM** WIND DIRECTION  
Start **SAME** Start **SE** End **SAME**

AMBIENT TEMP **78** WET BULB TEMP RH percent  
End **SAME**



ADDITIONAL INFORMATION

SEC	0	15	30	45	COMMENTS
1	5	5	5	5	PLUME ALMOST
2	5	5	5	5	N/E LOST ABOUT
3	5	5	5	5	30' ABOVE STACK
4	5	5	5	5	
5	5	5	5	5	RUNS 2+3
6	5	5	5	5	REMAINED THE
7	5	5	5	5	SAME
8	5	5	5	5	
9	5	5	5	5	
10	5	5	5	5	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE DATE

ORGANIZATION

CERTIFIED BY DATE

CONTINUED ON VEG FORM NUMBER

VISIBLE EMISSION OBSERVATION FORM

No.


COMPANY NAME  
STREET ADDRESS  
CITY STATE ZIP  
PHONE (KEY CONTACT) SOURCE ID NUMBER  
BILDER NUMBER 3

PROCESS EQUIPMENT OPERATING MODE  
COAL FIRED BILDER 100,000 lbs/hr  
CONTROL EQUIPMENT OPERATING MODE  
MULTIPLUME 4" H<sub>2</sub>O

DESCRIBE EMISSION POINT  
THREE INCH STEEL STACK  
HEIGHT ABOVE GROUND LEVEL 14  
DISTANCE FROM OBSERVER  
HEIGHT RELATIVE TO OBSERVER  
DIRECTION FROM OBSERVER

DESCRIBE EMISSIONS  
EMISION COLOR  
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED

DESCRIBE PLUME BACKGROUND  
BACKGROUND COLOR  
WIND SPEED  
AMBIENT TEMP  
WET BULB TEMP



OBSERVATION DATE		START TIME				END TIME
15 JULY 80		1923				1936
SEC	0	15	30	45	COMMENTS	
MIN						
1	5	5	5	5	SOOT BLOW	
2	5	5	5	5	RUN # 3	
3	5	5	5	5		
4	5	5	5	5	STACK CAPACITY	
5	5	5	5	5	READ MOCM RECF	
6	5	5	5	5		
7	5	25	45	60		
8	70	100	80	75		
9	80	10	15	5		
10	5	5	5	10		
11	15	15	15	20		
12	50	10	15	15		
13	5	5	5	5		
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

OBSERVER'S NAME (PRINT)  
OBSERVER'S SIGNATURE  
ORGANIZATION  
CERTIFIED BY  
DATE  
CONTINUED ON NEO FORM NUMBER

APPENDIX H

Boiler 3, Field Data, 100,000 lbs/hr, 19 July 88

(This page left blank)

$\Delta H_Q = 2.07$

1 of 2

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER	ONE A	AMBIENT TEMP	82
DATE	19 July 88	STATION PRESS	29.628
PLANT	CHIPP Bulk #1	HEATER BOX TEMP	
BASE	Eielson	PROBE HEATER SETTING	
SAMPLE BOX NUMBER	2010 NUTECH	PROBE LENGTH	72
METER BOX NUMBER		NOZZLE AREA (in <sup>2</sup> )	0.250
Qw/Qm		Cp	0.84
Co		DRY GAS FRACTION (F <sub>d</sub> )	

SCHEMATIC OF STACK CROSS SECTION

$\Delta P_{static} = -1.05$   
 $90,000 \text{ cfm}$

EQUATIONS

$\Delta P = \rho F + 460$   
 $H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{I_m}{T_s} \cdot V_p$   
 WIND: CALM at 09  
 MW 34.0 CO<sub>2</sub> 210.0  
 DP static -1.05 O<sub>2</sub> 9.0  
 %H<sub>2</sub>O 9.0  
 FPS = 72.0

start time 1307

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in. Hg)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in. Hg)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	AVG (IM) (°R)	OUT (°F)		
A 1	0	-3.0	374		0.95	2.64	362.343	103		103	247	62
2	25	-3.5	376		1.10	3.03		103		103	247	59
3	50	-5.0	378		1.45	4.02		104		103	250	60
4	75	-5.5	381		1.60	4.43		105		104	253	61
5	100	-6.0	382		1.60	4.43		107		104	256	62
6	125	-6.5	382		1.60	4.43		108		104	256	62
7	150	-6.5	382		1.55	4.29		110		104	256	62
8	175	-7.0	382		1.60	4.45		111		105	256	62
9	200	-7.0	382		1.55	4.31		112		106	253	61
10	225	-6.0	383		0.80	2.45		115		107	254	65
11	250	-3.0	379		0.22	0.62		112		107	253	61
12	275	-3.0	379		0.25	0.70	388.714	112		107	254	61

continued 2 of 2

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER 041E B  
 DATE 19 July 58  
 PLANT CHEMCO Bulk 423  
 BASE EICKSON  
 SAMPLE BOX NUMBER 2010  
 METER BOX NUMBER  
 Qw/Qm  
 Co

SCHEMATIC OF STACK CROSS SECTION  
 Post Lock ck good at 12 in Hg  
 90,000 cfm  
 stop time 1410

AMBIENT TEMP OF  
 STATION PRESS 29.628 In Hg  
 HEATER BOX TEMP OF  
 PROBE HEATER SETTING in  
 PROBE LENGTH 72  
 NOZZLE AREA 84  
 Cp  
 DRY GAS FRACTION (Fd)

$$\text{OR} = 9^{\circ}\text{F} + 460$$

$$H = \left[ \frac{5130 \cdot \text{Ft} \cdot \text{Cp} \cdot A}{\text{Co}} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$$

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (100 H <sub>2</sub> O) <sup>1/2</sup>	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (Rt)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	Avg (°R)		
B 1	0	-4.5	376		0.59	1.69	388.714	110	108	254	71
2	25	-5.2	378		0.74	2.07		110	108	253	71
3	50	-6.6	380		0.90	2.68		111	108	254	70
4	25	-8.4	380		1.35	3.77		112	108	254	70
5	10.0	-8.6	380		1.60	4.46		113	108	254	71
6	12.2	-9.0	381		1.60	4.48		114	109	254	72
7	15.0	-10.0	382		1.55	4.33		114	109.7	254	74
8	17.5	-10.0	380		1.52	4.34		114	107	250	78
9	20.0	-10.0	380		1.50	4.70		114	109	251	85
10	22.5	-10.0	381		1.45	5.06		114	109	251	86
11	25.0	-10.7	387		1.05	2.94		116	110	254	81
12	27.5	-7.0	381		0.77	2.11	<u>915.085</u>	116	110	254	82
	$T_m = 109$										
	$T_s = 380$										
	SH = 3.57										
	VP = 3.83										
	CAFE = 52.57										

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>Eickson AFB</i>		DATE <i>19 July 99</i>		RUN NUMBER <i>#1</i>	
BUILDING NUMBER <i>6203</i>			SOURCE NUMBER <i>Boiler #3</i>		
<b>I. PARTICULATES</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	<i>Ø.48ØØ</i>	<i>.2878</i> <del><i>0.28569</i></del>	<i>0.1922</i>		
ACETONE WASHINGS (Probe, Front Half Filter)	<i>107.5895</i>	<i>107.4366</i>	<i>0.1529</i>		
BACK HALF (if needed)					
Total Weight of Particulates Collected			<i>0.3451 gm</i>		
<b>II. WATER</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	<i>138</i>	<i>100mls</i>	<i>38</i>		
IMPINGER 2 (H2O)	<i>132mls</i>	<i>100mls</i>	<i>32</i>		
IMPINGER 3 (Dry)	<i>8.4</i>	<i>0</i>	<i>8.4</i>		
IMPINGER 4 (Silica Gel)	<i>323.9</i>	<i>300g</i>	<i>23.9</i>		
Total Weight of Water Collected			<i>102.3 gm</i>		
<b>III. GASES (Dry)</b>					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<i>8.6</i>	<i>8.4</i>	<i>8.6</i>		<i>8.5</i>
VOL % O <sub>2</sub>	<i>11</i>	<i>11</i>	<i>10.6</i>		<i>10.9</i>
VOL % CO					
VOL % N <sub>2</sub>					
Vol % N <sub>2</sub> = (100% - % CO <sub>2</sub> - % O <sub>2</sub> - % CO)					

$\Delta H @ = 2.07$

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER	DATE	PLANT	BASE	SAMPLE BOX NUMBER	METER BOX NUMBER	Q <sub>m</sub> /Q <sub>m</sub>	Co	SCHEMATIC OF STACK CROSS SECTION		EQUATIONS		AMBIENT TEMP		STATION PRESS	In Hg	OF
								(3) (0) (1)	Pre heateck good at 13 in Hg	90,000 lb/hr	OR = °F + 460	H = $\left[ \frac{5120 \cdot F \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Im}{Ts} \cdot Vp$	STATION PRESS			
TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP (°F)	STACK TEMP (°R)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP IN (°F)	GAS METER TEMP OUT (°F)	IMPINGER OUTLET TEMP (°F)	SAMPLE BOX TEMP (°F)	DRY GAS FRACTION (Fd)				
A 1	0	-4.5	374	374	0.50	1.41	415.07	111	111	81	235					
2	2.5	-6.0	378	378	0.69	1.99		112	111	75	240					
3	5.0	-8.0	380	380	0.95	2.67		114	112	75	243					
4	7.5	-10.0	379	379	1.35	3.80		115	112	66	245					
5	10.0	-12.5	382	382	1.60	4.50		117	112	70	246					
6	12.5	-14.0	384	384	1.55	4.35		118	113	75	246					
7	15.0	-14.0	383	383	1.55	4.35		119	114	73	245					
8	17.5	-14.0	383	383	1.55	4.35		118	114	80	247					
9	20.0	-14.0	382	382	1.55	4.35		117	113	80	245					
10	22.5	-14.0	381	381	1.45	4.05		116	113	80	245					
11	25.0	-12.5	381	381	1.05	2.95		115	113	81	246					
12	27.5	-9.0	380	380	0.80	2.11		112	112	82	246					

Start time 1430



(cont) 2 of 2

PARTICULATE SAMPLING DATA SHEET

AMBIENT TEMP	OF
STATION PRESS	In Hg
HEATER BOX TEMP	OF
PROBE HEATER SETTING	
PROBE LENGTH	in
NOZZLE AREA	sq ft
CP	
DRY GAS FRACTION (F <sub>d</sub> )	

EQUATIONS

$$^{\circ}R = ^{\circ}F + 460$$

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_a} \cdot V_p$$

Schematic of Stack Cross Section

Q<sub>1</sub> Q<sub>2</sub> Q<sub>3</sub> Q<sub>4</sub> Q<sub>5</sub> Q<sub>6</sub> Q<sub>7</sub> Q<sub>8</sub> Q<sub>9</sub> Q<sub>10</sub> Q<sub>11</sub> Q<sub>12</sub>

Post leak check good @ 20" Hg

96,000 Wt/hr

Send blow at 1512 (point 5)

Run Number	TWC B
Date	19 July 88
Plant	CHPP Boiler #3
Base	Elasur AFB
Sample Box Number	2010
Meter Box Number	
Q <sub>w</sub> /Q <sub>m</sub>	
C <sub>o</sub>	

step time 1533

Traverse Point Number	Sampling Time (min)	Static Pressure (in H <sub>2</sub> O)	Stack Temp		Velocity Head (Vp)	Orifice Diff. Press. (ft)	Gas Sample Volume (cu ft)	Gas Meter Temp		Sample Box Temp (°F)	Impinger Outlet Temp (°F)
			(°F)	(T <sub>s</sub> ) (°R)				In (°F)	Out (°F)		
B1	0	9.0	378	1.00	2.81	441.00	113	112	246	73	
2	2.5	-10.8	380	1.20	3.27		113	112	246	75	
3	5.0	-19.8	383	1.40	3.97		114	112	246	76	
4	7.5	-19.5	382	1.60	4.49		115	113	246	73	
5	10.0	-20.4	379	1.52	4.35		113	111	246	69	
6	12.5	-20.0	376	1.53	4.35		112	110	246	68	
7	15.0	-20.4	377	1.55	4.35		110	110	246	68	
8	17.5	-19.6	378	1.50	4.20		111	109	245	67	
9	20.0	-19.6	376	1.40	3.97		109	108	246	70	
10	22.5	-19.8	372	0.91	2.55		107	108	246	67	
11	25.0	-19.8	375	0.79	2.21	467.36	108	108	246	67	
12	27.5	-19.8	375								
T <sub>m</sub>	112										
T <sub>s</sub>	329										
ΔH	3.60										
10513	32.470A										
Mixture	ML-52.2 59										

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>Edgem AFB</i>	DATE <i>19 July 85</i>	RUN NUMBER <i>#2</i>
BUILDING NUMBER <i>6203</i>	SOURCE NUMBER <i>Boiler #3</i>	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>φ. 637φ</i>	<i>0.2839g</i>	<i>0.3531</i>
ACETONE WASHINGS (Probe, Front Half Filter)	<i>100. φ 338</i>	<i>99.6269</i>	<i>0.4669</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>.7600 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>200</i>	<i>100 ml/s</i>	<i>100</i>
IMPINGER 2 (H2O)	<i>60</i>	<i>100 ml/s</i>	<i>-40</i>
IMPINGER 3 (Dry)	<i>5.4</i>	<i>0</i>	<i>5.4</i>
IMPINGER 4 (Silica Gel)	<i>322.5</i>	<i>300</i>	<i>22.5</i>
Total Weight of Water Collected			<i>83.9 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<i>9.1</i>	<i>9.5</i>	<i>9.6</i>		<i>9.5</i>
VOL % O <sub>2</sub>	<i>10</i>	<i>10</i>	<i>10</i>		<i>9.9</i>
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)


PARTICULATE SAMPLING DATA SHEET

RUN NUMBER: THREE  
 DATE: 19 July 88  
 PLANT: CHPP Boiler #3  
 BASE: Eielson AFB  
 SAMPLE BOX NUMBER: 2410  
 METER BOX NUMBER:   
 Q<sub>W</sub>/Q<sub>m</sub>:   
 Co:   
 AMBIENT TEMP: 79 °F  
 STATION PRESS: 29.628 in Hg  
 HEATER BOX TEMP:   
 PROBE HEATER SETTING:   
 PROBE LENGTH: 72 in  
 NOZZLE AREA (A):   
 Cp: 0.84  
 DRY GAS FRACTION (F<sub>D</sub>):   
 EQUATIONS:  

$$OR = OF + 460$$

$$H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{Co} \right]^2 \cdot \frac{T_m \cdot V_p}{T_b}$$
 MW = 30.0  
 ΔP<sub>s</sub> = 7105  
 %H<sub>2</sub>O = 9.0  
 FPS = 72  
 CO<sub>2</sub> = 10.0  
 O<sub>2</sub> = 9.0  
 start time 3:57

SCHEMATIC OF STACK CROSS SECTION



TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (ft)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	OUT (°F)		
1	4	4	375	375	1.1	3.07	107.570	105	106	250	85
2	2.5	4	375	375	1.2	3.35		107	106	251	75
3	5.0	5	372	372	1.5	4.21		107	106	257	72
4	7.5	5	378	378	1.65	4.61		110	106	252	74
5	10.0	6	380	380	1.7	4.77		111	106	252	78
6	12.5	6	381	381	1.6	4.46		112	107	252	83
7	15.0	6	381	381	1.55	4.33		113	107	252	82
8	17.5	6.5	381	381	1.55	4.33		114	108	250	82
9	20.0	6.5	381	381	1.55	4.33		114	108	253	81
10	22.5	6	382	382	1.0	2.80		115	109	256	78
11	25.0	5	380	380	1.0	2.80		115	109	250	71
12	27.5	5	378	378	1.00	1.80	494.143	113	108	237	67

(cont) 2 of 2

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER		DATE		PLANT		BASE		SAMPLE BOX NUMBER		METER BOX NUMBER		Qw/Qm		Co	
THREE B		19 July 88		CHOPP Bldg #3		Kielson		2010							
SCHEMATIC OF STACK CROSS SECTION EQUATIONS $OR = °F + 460$ $H = \left[ \frac{5130 \cdot F \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{T_m \cdot Vp}{T_a}$															
AMBIENT TEMP: 79 STATION PRESS: 29.628 HEATER BOX TEMP: [blank] PROBE HEATER SETTING: [blank] PROBE LENGTH: 72 NOZZLE AREA (A): [blank] Cp: 0.84 DRY GAS FRACTION (Fg): [blank]															
TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	IN (°F)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)			
			(°F)	(T <sub>s</sub> ) (OR) %					AVG (T <sub>m</sub> ) (OR) %	OUT (°F)					
1	0	3.5	375		.42	1.78	498.693	110	107	251	69				
2	2.5	4.5	375		.62	1.79		109	107	250	67				
3	5.0	6.8	375		.96	2.89		109	106	251	68				
4	7.5	8.8	376		1.4	3.91		109	106	249	65				
5	10.0	8.8	380		1.55	4.32		110	106	242	66				
6	12.5	8.5	379		1.55	4.32		110	106	249	67				
7	15.0	9	380		1.55	4.32		109	106	240	69				
8	17.5	9	380		1.55	4.31		109	105	249	71				
9	20.0	9.5	380		1.95	4.03		109	105	247	67				
10	22.5	9.5	378		1.4	3.90		108	105	248	66				
11	25.0	7.5	379		.85	2.36		110	104	246	66				
12	27.5	6	378		.58	1.06	520.066	107	104	248	68				
TME = 108															
TS = 378															
OH = 3.41															
VPSIS = 31.4201															
CU FT = 52.496															

step time 4.59

Post leak check at 6:11"

90,000 lb/hr

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>Eglin AFB</i>		DATE <i>19 July 65</i>		RUN NUMBER <i>43</i>	
BUILDING NUMBER <i>6203</i>			SOURCE NUMBER		
<b>I. PARTICULATES</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	<i>.4823</i>	<i>0.2853</i>	<i>0.1970</i>		
ACETONE WASHINGS (Probe, Front Half Filter)	<i>98.9072</i>	<i>98.7231</i>	<i>0.1841</i>		
BACK HALF (if needed)					
Total Weight of Particulates Collected			<i>0.3811 gm</i>		
<b>II. WATER</b>					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	<i>146</i> <del>23.6</del>	<i>100 ml</i>	<i>46.0</i>		
IMPINGER 2 (H2O)	<i>131</i> <del>7.0</del>	<i>100 ml</i>	<i>31.0</i>		
IMPINGER 3 (Dry)	<del>23.6</del> <i>7.0</i>	<i>0</i>	<i>7.0</i>		
IMPINGER 4 (Silica Gel)	<del>7.0</del> <i>23.6</i>	<i>300g</i>	<i>23.6</i>		
Total Weight of Water Collected			<i>107.6 gm</i>		
<b>III. GASES (Dry)</b>					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<i>7.2</i>	<i>7.2</i>	<i>7.4</i>		<i>7.3</i>
VOL % O <sub>2</sub>	<i>12</i>	<i>12.2</i>	<i>12.2</i>		<i>12.3</i>
VOL % CO					
VOL % N <sub>2</sub>					
Vol % N <sub>2</sub> = (100% - % CO <sub>2</sub> - % O <sub>2</sub> - % CO)					

**PRELIMINARY SURVEY DATA SHEET NO. 1**  
(Stack Geometry)

<small>BASE</small> <b>Eielson AFB</b>	<small>PLANT</small> <b>CH &amp; PP</b>
<small>DATE</small> <b>14-20 July</b>	<small>SAMPLING TEAM</small> <b>ECC</b>
<small>SOURCE TYPE AND MAKE</small>	

<small>SOURCE NUMBER</small> <b>Boilers #2, #3</b>	<small>INSIDE STACK DIAMETER</small> <b>52.5</b> Inches
<small>RELATED CAPACITY</small> <b>10</b>	<small>TYPE FUEL</small> <b>Coal</b>
<small>DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER</small> <b>1.5</b> Inches	
<small>NUMBER OF TRAVERSES</small> <b>2</b>	<small>NUMBER OF POINTS/TRAVERSE</small> <b>12</b>

**LOCATION OF SAMPLING POINTS ALONG TRAVERSE**

POINT	PERCENT OF DIAMETER	DISTANCE FROM INSIDE WALL (Inches)	TOTAL DISTANCE FROM OUTSIDE OF NIPPLE TO SAMPLING POINT (Inches)
1			2.6
2			5.0
3			7.7
4			10.8
5			14.6
6			20.2
7			35.3
8			40.9
9			44.7
10			47.8
11			50.5
12			52.9

**PRELIMINARY SURVEY DATA SHEET NO. 2**  
(Velocity and Temperature Traverse)

BASE <b>Eielson AFB</b>	DATE <b>19 July 88</b>
BOILER NUMBER <b>#3</b>	
INSIDE STACK DIAMETER <b>52.5</b> Inches	
STATION PRESSURE <b>29.628</b> In Hg	
STACK STATIC PRESSURE <b>-1.05</b> In H2O	
SAMPLING TEAM <b>OEHL/ECG Garrison Scott, Fergin, Schilling, Davis</b>	

TRAVERSE POINT NUMBER	VELOCITY HEAD, $V_p$ IN H2O	$\bar{V}_p$	STACK TEMPERATURE (°F)
one	0.78		374
two	0.88		375
three	1.10		376
four	1.15		378
five	1.20		382
six	1.20		382
seven	1.20		382
eight	1.20		382
nine	1.20		382
ten	1.05		381
eleven	0.84		380
twelve	0.71		380
OPERATING at 90,000			
+21 - 33			
+ 1.2			
FPS = 72.0			
$\Delta P = 1.04$			
$\bar{T}_s = 380$			
noz dia = 0.2364			
AVERAGE			

NOZZLE CALIBRATION DATA FORM

Date 19 ~~20~~ JULY Calibrated by GARRISON

Nozzle identification number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> mm (in.)	$D_{avg}$ <sup>c</sup>
	$D_1$ , mm (in.)	$D_2$ , mm (in.)	$D_3$ , mm (in.)		
0.25	0.251	0.250	0.250	0.001	0.250

where:

<sup>a</sup> $D_{1,2,3}$  = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.)  
 $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of  $D_1$ ,  $D_2$ , and  $D_3$ .



VISIBLE EMISSION OBSERVATION FORM

No

COMPANY NAME  
**EIELSON AFB**

STREET ADDRESS

CITY STATE ZIP  
STATE **AK**

PHONE (KEY CONTACT) SOURCE ID NUMBER  
**BOILER # 3**

PROCESS EQUIPMENT OPERATING MODE  
**COAL-FIRED BOILER** **90,000 lb/hr**

CONTROL EQUIPMENT OPERATING MODE  
**MULTIPLUME**

DESCRIBE EMISSION POINT  
**TAPERED STEEL STACK**

HEIGHT ABOVE GROUND LEVEL HEIGHT RELATIVE TO OBSERVER  
**14** Start **14** End

DISTANCE FROM OBSERVER DIRECTION FROM OBSERVER  
Start **90'** End **SAME** Start **NW** End **SAME**

DESCRIBE EMISSIONS **VERTICAL PLUME ILLUMINABLE STACK**

Start **CUNNING** End **SAME**

EMISSION COLOR IF WATER DROPLET PLUME  
Start **LT. BROWN** End **SAME** Attached  **N/A** Detached

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
Start **2-5' ABOVE STACK** End **SAME**


DESCRIBE PLUME BACKGROUND

Start **HAZY** End

BACKGROUND COLOR SKY CONDITIONS  
Start **SKY BLUE** End **SAME** Start **SCATTERED** End

WIND SPEED WIND DIRECTION  
Start **BLM** End Start **VAR** End

AMBIENT TEMP WET BULB TEMP RH percent  
Start **82** End



ADDITIONAL INFORMATION

OBSERVATION DATE		START TIME		END TIME	COMMENTS
19 JUL 88					
MIN	SEC	0	15	30	45
1	5	5	5	5	OPACITY READ
2	5	5	5	5	FROM RECF.
3	5	5	5	5	
4	5	5	5	5	PLUME ALMOST
5	5	5	5	5	INVISIBLE.
6	5	5	5	5	
7	5	5	5	5	ALL PLUMES EXISTING
8	5	5	5	5	SHOW OPACITY
9	5	5	5	5	
10	5	5	5	5	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE DATE

ORGANIZATION

CHECKED BY DATE

CONTINUED ON VEO FORM NUMBER

VISIBLE EMISSION OBSERVATION FORM

No.

COMPANY NAME  
**EIELSON AFB**

STREET ADDRESS

---

CITY STATE ZIP

PHONE (KEY CONTACT) SOURCE ID NUMBER  
**BOILER #3**

PROCESS EQUIPMENT  
**COAL-FIRED BOILER**

OPERATING MODE  
**90,000 lb/hr**

CONTROL EQUIPMENT  
**MULTICONE**

OPERATING MODE

DESCRIBE EMISSION POINT

HEIGHT ABOVE GROUND LEVEL  
**14'**

HEIGHT RELATIVE TO OBSERVER  
Start **14'** End **SAME**

START FROM OBSERVER  
Start **90'** End **SAME**

START FROM OBSERVER  
Start **14'** End **SAME**

DESCRIBE EMISSIONS **VERTICAL PLUME 5' ABOVE STACK**

Start **CONVING** End

EMISSION COLOR  
Start **LT BROWN** End **SAME**

IF WATER DROPLET PLUME  
Attached **N/A** Detached

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
Start **2-5' ABOVE STACK** End **SAME**

DESCRIBE PLUME BACKGROUND

Start **HAZY** End


BACKGROUND COLOR SKY CONDITIONS

WIND SPEED Start End WIND DIRECTION Start End

Start **CALM** End Start **VAR.** End

AMBIENT TEMP WET BULB TEMP RH percent

Start End



ADDITIONAL INFORMATION

OBSERVATION DATE		START TIME				END TIME
19 JULY 88						
SEC	0	15	30	45	COMMENTS	
MIN						
1	5	5	5	5	SOOT BLOW	
2	10	5	5	5	RUN #2	
3	5	5	5	5		
4	5	5	5	5		
5	10	15	25	45		
6	40	30	5	5		
7	5	5	40	40		
8	70	75	60	15		
9	10	5	5	5		
10	5	5	5	5		
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE DATE

ORGANIZATION

CERTIFIED BY DATE

CONTINUED ON VEO FORM NUMBER

--	--	--	--	--	--

APPENDIX I

Boiler 3, Field Data, 100,000, 20 July 88

(This page left blank)

PARTICULATE SAMPLING DATA SHEET

Run # 3  
 RUN NUMBER #1 A  
 DATE 20 July 88  
 PLANT  
 BASE  
 SAMPLE BOX NUMBER  
 METER BOX NUMBER  
 CO

Schematic of Stack Cross Section: 1 (S) (3) (B) (1) (A)

Pre-located 15 m. off  
 90,000 cfm  
 Stack above at 125 ft (p. 15)

Equations:  
 $OR = OF + 460$   
 $H = \left[ \frac{5130 \cdot F \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Im}{Is} \cdot \frac{Vp}{Vs}$

AMBIENT TEMP 70 OF  
 STATION PRESS 29.245 in Hg  
 HEATER BOX TEMP  
 PROBE HEATER SETTING OF  
 PROBE LENGTH 72 in  
 NOZZLE AREA (A) 2.500 sq ft  
 Cp .84  
 DRY GAS FRACTION (FG)

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (F)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°R)				IN (°F)	OUT (°F)		
A 1	0	-3.4	371	371	0.52	1.47	520.285	91	91	242	72
2	2.5	3.2	374	374	0.64	1.75		92	92	240	70
3	5.0	4.1	374	374	0.90	2.95		92	92	245	66
4	7.5	-5.5	374	374	1.3	3.57		94	94	246	67
5	10.0	-6.2	374	374	1.9	3.87		95	95	247	69
6	12.5	-6.7	374	374	1.4	3.87		97	97	245	69
7	15.0	-6.5	374	374	1.4	3.87		98	98	243	71
8	17.5	-6.2	374	374	1.3	3.63		96	96	245	70
9	20.0	-6.2	374	374	1.25	3.48		99	99	247	69
10	22.5	-6.5	374	374	0.95	2.66		95	95	249	70
11	25.0	-5.5	374	374	0.72	2.61		101	101	249	70

PARTICULATE SAMPLING DATA SHEET

SCHEMATIC OF STACK CROSS SECTION

AMBIENT TEMP	71
STATION PRESS	29.245
HEATER BOX TEMP	
PROBE HEATER SETTING	
PROBE LENGTH	72
NOZZLE AREA (A)	0.5
Cp	0.84
DRY GAS FRACTION (Fd)	

°R = °F + 460
$H = \left[ \frac{5130 \cdot Fd \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Tm \cdot Vp}{Ts}$
step size 125 L



RUN NUMBER	A1 B
DATE	2/1/64
PLANT	Ch. 1
BASE	100.00 (6%)
SAMPLE BOX NUMBER	
METER BOX NUMBER	
Q <sub>dry</sub> (scfm)	
C <sub>d</sub>	

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (ft)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(Ts) (°R)				IN (°F)	AVG (Tm) (°R)		
1	3.5	-5.8	370		0.17	2.70	545.095	107	107	250	69
2	3.5	-7.4	371		1.10	3.04		107	107	250	65
3	5.4	-8.5	371		1.40	3.73		107	107	250	67
4	2.5	-9.0	371		1.58	4.21		104	104	251	68
5	1.5	-9.5	375		1.5	4.21		105	105	254	64
6	1.5	-10.8	376		1.5	4.20		105	105	252	64
7	1.5	-11.3	372		1.9	3.49		103	103	250	64
8	1.5	-11.8	371		1.9	3.43		103	103	251	65
9	2.5	-14.8	370		1.45	4.67		103	103	250	66
10	2.5	-14.8	374		1.66	3.84		105	105	250	67
11	2.5	-14.8	373		0.61	1.72		106	106	254	69
12	2.5	-14.8	371		0.36	1.02	570.499	106	106	254	64

T <sub>m</sub> = 164
T <sub>s</sub> = 373
AH = 3.19
PPSTs = 30.4430
VOL = 49.809

AIR POLLUTION PARTICULATE ANALYTICAL DATA					
BASE Eielson		DATE 20 July 88		RUN NUMBER one	
BUILDING NUMBER CHAPP.			SOURCE NUMBER Boiler #3		
I. PARTICULATES					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	0.4496	0.2871	0.1625		
ACETONE WASHINGS (Probe, Front Hall Filter)	107.6335	107.4366	0.1969		
BACK HALF (if needed)					
			Total Weight of Particulates Collected		35.94 gm
II. WATER					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	174	100	74.0		
IMPINGER 2 (H2O)	129	100	29.0		
IMPINGER 3 (Dry)	3.8		3.2		
IMPINGER 4 (Silica Gel)	311.7	300	11.7		
			Total Weight of Water Collected		117.9 gm
III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	9.6	9.6	9.8		9.7
VOL % O <sub>2</sub>	9.4	9.2	9.2		9.3
VOL % CO					
VOL % N <sub>2</sub>					
Vol % N <sub>2</sub> = (100 - % CO <sub>2</sub> - % O <sub>2</sub> - % CO)					

### PARTICULATE SAMPLING DATA SHEET

RUN NUMBER # 2	DATE 20 July 88	PLANT C4 DP	BASE Lindson	SAMPLE BOX NUMBER 2010	METER BOX NUMBER	Q <sub>w</sub> /Q <sub>m</sub>	Co
<p>SCHEMATIC OF STACK CROSS SECTION</p>  <p style="text-align: center;">(5) </p> <p style="text-align: center;">North Arrow</p> <p style="text-align: center;">Probe located at 15m height</p> <p style="text-align: center;">Pressure within</p>							
<p>EQUATIONS</p> $OR = °F + 460$ $H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{Co} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$							
<p>AMBIENT TEMP</p> <p>STATION PRESS 27.238</p> <p>HEATER BOX TEMP</p> <p>PROBE HEATER SETTING</p> <p>PROBE LENGTH</p> <p>NOZZLE AREA (A) .25</p> <p>Cp .84</p> <p>DRY GAS FRACTION (Fd)</p>							
<p>GAS METER TEMP</p> <p>IN (°F) 106</p> <p>AVG (T<sub>m</sub>) (°F) 104</p> <p>OUT (°F) 104</p>							
<p>GAS METER TEMP</p> <p>IN (°F) 106</p> <p>AVG (T<sub>m</sub>) (°F) 104</p> <p>OUT (°F) 104</p>							
<p>ORIFICE DIFF. PRESS. (H)</p> <p>2.44</p> <p>3.68</p> <p>3.78</p> <p>3.91</p> <p>4.64</p> <p>3.72</p> <p>3.25</p> <p>3.43</p> <p>3.94</p> <p>3.35</p> <p>2.95</p> <p>1.73</p>							
<p>VELOCITY HEAD (Vp)</p> <p>0.87</p> <p>1.16</p> <p>1.35</p> <p>1.41</p> <p>1.45</p> <p>1.48</p> <p>1.35</p> <p>1.4</p> <p>1.4</p> <p>1.2</p> <p>0.76</p> <p>0.62</p>							
<p>STACK TEMP (°F) (T<sub>s</sub>) (°F)</p> <p>374 372</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p> <p>374 374</p>							
<p>STATIC PRESSURE (in H<sub>2</sub>O)</p> <p>-7.8</p> <p>-9.4</p> <p>-13.0</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p>							
<p>SAMPLING TIME (min)</p> <p>0</p> <p>2.5</p> <p>5.6</p> <p>7.5</p> <p>10.0</p> <p>12.5</p> <p>15.0</p> <p>17.5</p> <p>20.0</p> <p>22.5</p> <p>25.0</p> <p>27.5</p> <p>30.0</p>							
<p>STATIC PRESSURE (in H<sub>2</sub>O)</p> <p>-7.8</p> <p>-9.4</p> <p>-13.0</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p> <p>-17.4</p>							
<p>TRaverse Point Number</p> <p>1</p> <p>2</p> <p>3</p> <p>4</p> <p>5</p> <p>6</p> <p>7</p> <p>8</p> <p>9</p> <p>10</p> <p>11</p> <p>12</p>							
<p>GAS SAMPLE VOLUME (cu ft)</p> <p>511.240</p>							
<p>START TIME 1237</p>							
<p>IMPINGER OUTLET TEMP (°F)</p> <p>74</p> <p>76</p> <p>69</p> <p>78</p> <p>81</p> <p>83</p> <p>79</p> <p>83</p> <p>85</p> <p>87</p> <p>87</p>							
<p>SAMPLE BOX TEMP (°F)</p> <p>242</p> <p>246</p> <p>248</p> <p>251</p> <p>252</p> <p>252</p> <p>254</p> <p>254</p> <p>254</p> <p>254</p> <p>254</p> <p>254</p>							



PARTICULATE SAMPLING DATA SHEET

AMBIENT TEMP	70	°F
STATION PRESS	29.238	in Hg
HEATER BOX TEMP		°F
PROBE HEATER SETTING		
PROBE LENGTH	72	in
NOZZLE AREA (A)	1.25	sq ft
Cp	.84	
DRY GAS FRACTION (Fd)		

EQUATIONS

$OR = 9F + 460$

$H = \left[ \frac{5130 \cdot Fd \cdot Cp \cdot A}{Co} \right]^2 \cdot \frac{Tm}{Tb} \cdot Vp$

SCHEMATIC OF STACK CROSS SECTION

Post work done at 22 July  
see also

STEP TIME 1338

RUN NUMBER	#2 B
DATE	20 July 88
PLANT	LEPP
BASE	Electric
SAMPLE BOX NUMBER	2016
METER BOX NUMBER	
Qw, Qm	
Co	

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(T <sub>s</sub> ) (°R)				IN (°F)	AVG (T <sub>m</sub> ) (°R)	OUT (°F)		
1	0	-6.5	370		0.48	1.55	577.407	106		104	250	74
2	2.5	-8.4	371		0.69	1.93		106		104	250	71
3	5.0	-10.0	373		0.91	2.57		107		104	251	72
4	7.5	-11.4	374		1.15	3.27		108		105	246	70
5	10.0	-12.8	376		1.35	3.78		110		106	244	73
6	12.5	-14.2	377		1.34	3.67		111		105	244	73
7	15.0	-15.5	375		1.50	3.62		111		107	247	74
8	17.5	-16.5	375		1.2	3.65		111		108	247	74
9	20.0	-17.5	374		0.84	3.37		111		108	249	75
10	22.5	-17.5	374		0.69	2.36		111		108	249	75
11	25.0					1.94	622.015	111		108	249	76
12	27.5											
T <sub>m</sub>	107											
T <sub>s</sub>	373											
ΔH	3.13											
V <sub>PSI</sub>	30.1997											
V <sub>OC</sub>	50.775											

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>Eielson AFB</i>	DATE <i>20 July 88</i>	RUN NUMBER <i>Two</i>
BUILDING NUMBER <i>CH&amp;PP</i>	SOURCE NUMBER <i>Boiler # 3</i>	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.4456</i>	<i>.3851</i>	<i>.1605</i>
ACETONE WASHINGS (Probe, Front Half Filter)	<i>99.7448</i>	<i>99.6269</i>	<i>.1229</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>.2834 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>152</i>	<i>100</i>	<i>52.0</i>
IMPINGER 2 (H2O)	<i>120</i>	<i>100</i>	<i>20.0</i>
IMPINGER 3 (Dry)	<i>7.5</i>	<i>0</i>	<i>7.5</i>
IMPINGER 4 (Silica Gel)	<i>336.1</i>	<i>300</i>	<i>36.1</i>
Total Weight of Water Collected			<i>115.6 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	<i>10.2</i>	<i>10.2</i>	<i>10.2</i>		<i>10.3</i>
VOL % O <sub>2</sub>	<i>9.0</i>	<i>9.0</i>	<i>9.0</i>		<i>9.0</i>
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER #3 A	SCHEMATIC OF STACK CROSS SECTION ③ ② ① N ↑		EQUATIONS °R = °F + 460 $H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_b}$		AMBIENT TEMP 72		STATION PRESS 29.30		°F		
DATE 20 July 88	Pre heat check @ 19 in				HEATER BOX TEMP		PROBE HEATER SETTING		in Hg		
PLANT Kiel sock	90,000 bbl/hr				PROBE LENGTH 72		NOZZLE AREA (A) .25		of		
BASE CMTD					NOZZLE AREA (A) .25		CP .84		of		
SAMPLE BOX NUMBER 2014					NOZZLE AREA (A) .25		DRY GAS FRACTION (F <sub>D</sub> )				
METER BOX NUMBER					NOZZLE AREA (A) .25						
Q <sub>air</sub> /Q <sub>m</sub>					NOZZLE AREA (A) .25						
Co					NOZZLE AREA (A) .25						
TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP (°F) (°R)		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (ft)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP (°F) (°R)		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
A	4.5	-3.4	370	370	0.52	1.46	622.254	106	232	66	66
B	4.5	-3.0	371	371	0.68	1.47		106	234	67	67
C	5.0	-3.6	372	372	0.78	2.18		106	239	59	59
D	2.5	-4.4	373	373	1.24	3.36		106	240	60	60
E	10.0	-5.5	374	374	1.40	3.91		107	241	57	57
F	12.0	-6.2	375	375	1.46	3.91		108	242	60	60
G	12.0	-6.4	377	377	1.34	3.62		107	241	61	61
H	17.5	-6.7	377	377	1.54	3.67		108	242	59	59
I	20.0	-6.4	376	376	1.20	3.40		108	242	60	60
J	22.5	-6.0	376	376	0.86	2.43		108	242	59	59
K	22.5	-5.6	371	371	0.86	2.43		108	245	62	62
L	22.5	-3.8	372	372	0.67	1.89		108	245	62	62

START TIME 1400

PARTICULATE SAMPLING DATA SHEET

SCHEMATIC OF STACK CROSS SECTION			EQUATIONS			AMBIENT TEMP			
TRaverse POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H <sub>2</sub> O)	STACK TEMP (°F)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP (°F)	SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(Vp)	(in)	(cu ft)	IN (°F)	OUT (°F)	
			(°F)				AVG (°F)		
1	10	-5.5	372	6.95	2.68	656.728	117	117	68
2	7.5	-6.4	372	6.85	2.61		117	117	68
3	5.0	-7.4	375	6.25	2.40		117	117	68
4	7.5	-8.4	373	7.45	4.00		117	117	68
5	10.0	-8.4	373	7.45	4.00		117	117	68
6	12.5	-8.4	372	7.45	4.00		117	117	68
7	12.5	-8.4	371	7.35	3.81		117	117	68
8	12.5	-8.5	371	7.35	3.81		117	117	68
9	10.0	-9.4	371	6.75	3.53		117	117	68
10	12.5	-9.4	374	6.75	3.53		117	117	68
11	12.5	-7.5	371	6.75	3.53		117	117	68
12	12.5	-7.4	371	6.75	3.53		117	117	68
$Q_R = \text{°F} + 460$ $H = \left[ \frac{5130 \cdot F \cdot C_p \cdot A}{C_g} \right]^2 \cdot \frac{T_m \cdot V_p}{T_b}$			96,000 cfm 1501						
RUN NUMBER DATE PLANT BASE SAMPLE BOX NUMBER METER BOX NUMBER Q <sub>w</sub> /Q <sub>m</sub> C <sub>g</sub>	AMBIENT TEMP STATION PRESS HEATER BOX TEMP PROBE HEATER SETTING PROBE LENGTH NOZZLE AREA (A) C <sub>p</sub> DRY GAS FRACTION (F <sub>d</sub> )								

$T_m = 110$   
 $T_b = 372$   
 $\Delta H = 3.19$   
 $Q_{PDS} = 30,412.3$   
 $VOL = 512.5$

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

<b>BASE</b> Eielson	<b>DATE</b> 20 July 88	<b>RUN NUMBER</b> THREE
<b>BUILDING NUMBER</b> CHSPD.	<b>SOURCE NUMBER</b> Boiler #3	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	0.4883	.2858	.2025
ACETONE WASHINGS (Probe, Front Half Filter)	98.9511	98.7231	.2280
BACK HALF (if needed)			<del>0.0000</del>
Total Weight of Particulates Collected			5.4305 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	122 ml	0	22.0
IMPINGER 2 (H2O)	172 ml	0	72.0
IMPINGER 3 (Dry)	4.6	0	4.6
IMPINGER 4 (Silica Gel)	316	300	16.0
Total Weight of Water Collected			114.6 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>	16.2	15.4	15.5	15.5	15.5
VOL % O <sub>2</sub>	4.2	4.4	4.5	4.5	4.4
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)

PRELIMINARY SURVEY DATA SHEET N° 1

(Stack Geometry)

BASE <b>Eielson AFB</b>	PLANT <b>CH &amp; PP</b>
DATE <b>14-20 July</b>	SAMPLING TEAM <b>ECQ</b>
SOURCE TYPE AND MAKE	

SOURCE NUMBER <b>Boilers #2, #3</b>	INSIDE STACK DIAMETER <b>52.5</b> Inches
--	---

RELATED CAPACITY <b>10</b>	TYPE FUEL <b>Coal</b>
-------------------------------	--------------------------

DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER <b>1.5</b> Inches
---

NUMBER OF TRAVERSES <b>2</b>	NUMBER OF POINTS/TRAVERSE <b>12</b>
---------------------------------	--

LOCATION OF SAMPLING POINTS ALONG TRAVERSE

POINT	PERCENT OF DIAMETER	DISTANCE FROM INSIDE WALL (Inches)	TOTAL DISTANCE FROM OUTSIDE OF NIPPLE TO SAMPLING POINT (Inches)
1			2.6
2			5.0
3			7.7
4			10.8
5			14.6
6			20.2
7			35.3
8			40.9
9			44.7
10			47.8
11			50.5
12			52.9

PRELIMINARY SURVEY DATA SHEET NO. 2  
(Velocity and Temperature Traverse)

BASE Eielson AFB	DATE 20 July 88
BOILER NUMBER Boiler # 3	
INSIDE STACK DIAMETER 52.5 Inches	
STATION PRESSURE 29.245 In Hg	
STACK STATIC PRESSURE -1.1 In H <sub>2</sub> O	
SAMPLING TEAM ECQ Air Function	

TRAVERSE POINT NUMBER	VELOCITY HEAD, $V_p$ IN H <sub>2</sub> O	CYCLONIC $\frac{V_p^2}{2g}$ - $\alpha$	STACK TEMPERATURE (°F)
1	<del>0.48</del> 0.52	4°	370
2	0.59	∅	371
3	0.83	∅	371
4	1.2	∅	372
5	1.4	1	375
6	1.4	∅	377
7	1.3	∅	377
8	1.2	∅	377
9	1.2	∅	377
10	1.1	10	377
11	0.87	∅	377
12	0.77	∅	376
		avg = 1.25°	
		FFS = 72	
		$\bar{V} = 1.03$	
		$T_s = 375$	
		corr. = .237	
AVERAGE			

US  
0552  
FORM 16  
MAY 79

NOZZLE CALIBRATION DATA FORM

Date 20 July 88 Calibrated by Seb

Nozzle identification number	Nozzle Diameter <sup>a</sup>			$\Delta D$ , <sup>b</sup> mm (in.)	$D_{avg}$ <sup>c</sup>
	$D_1$ , mm (in.)	$D_2$ , mm (in.)	$D_3$ , mm (in.)		
.25 $\phi$	.250	.250	.251	.001	.25 $\phi$

where:

<sup>a</sup> $D_{1,2,3}$  = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

<sup>b</sup>  $\Delta D$  = maximum difference between any two diameters, mm (in.),  
 $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

<sup>c</sup>  $D_{avg}$  = average of  $D_1$ ,  $D_2$ , and  $D_3$ .

Quality Assurance Handbook Mb-2.6



VISIBLE EMISSION OBSERVATION FORM

No.

COMPANY NAME  
**KIELSON**

STREET ADDRESS

CITY STATE ZIP

PHONE (KEY CONTACT) SOURCE ID NUMBER  
**EXILER # 3**

PROCESS EQUIPMENT OPERATING MODE  
**COAL-FIRED BOILER 90,000 lb/hr**

CONTROL EQUIPMENT OPERATING MODE  
**INVERTER CONTROL 3" H<sub>2</sub>O**

DESCRIBE EMISSION POINT

HEIGHT ABOVE GROUND LEVEL HEIGHT RELATIVE TO OBSERVER  
**14' ROOF Start 14' End**

DISTANCE FROM OBSERVER DIRECTION FROM OBSERVER  
**Start 90' End 577' Start W End**

DESCRIBE EMISSIONS **NIGHT - 1/4 INCH - BARELY VISIBLE**

Start **CROWN** End **STACK**

EMISSION COLOR IF WATER DROPLET PLUME  
**LT BROWN End 577' Attached: N/A Detached**

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
**Start 4' ABOVE STACK End 577'**


DESCRIBE PLUME BACKGROUND

Start **Hazy** End **577'**

BACKGROUND COLOR SKY CONDITIONS  
**SKY BLUE Start WINDY End 577'** **Start SCATTERED End 577'**

WIND SPEED WIND DIRECTION  
**Start CALM End 577'** **Start LHR End**

AMBIENT TEMP WET BULB TEMP RH percent  
**Start 75 End 577'**



ADDITIONAL INFORMATION

OBSERVATION DATE		START TIME		END TIME	COMMENTS
SEC	0	15	30	45	
MIN					
1	5	5	5	5	RUN # 1
2	5	5	5	5	INCL. DROSCOT
3	5	5	5	5	3/4 W
4	5	5	5	5	
5	5	5	5	5	
6	5	5	5	5	
7	5	5	5	5	
8	5	5	5	5	
9	5	5	5	5	
10	5	5	5	5	
11	5	5	5	5	
12	5	5	5	5	
13	5	5	5	5	
14	5	15	30	35	} SOOT BLEW
15	35	30	25	30	
16	35	35	20	5	
17	5	5	5	5	
18					
19					HAZY COND. FOR PUFF
20					THE SAME CLARITY
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT)

OBSERVER'S SIGNATURE DATE

ORGANIZATION

CHECKED BY DATE

CONTINUED ON VET FORM NUMBER

(This page left blank)

APPENDIX J

Acetone Blank Results and Emissions Calculations

(This page left blank)

ACETONE BLANK ANALYTICAL DATA FORM

Plant: CENTRAL HEAT + POWER PLANT

Location: EIELSON AFB

Date of analysis: 20 JULY 88

Density of acetone ( $p_a$ ): 0.79 g/ml

Acetone blank volume ( $V_a$ ): 200 ml

Acetone wash volume ( $V_{aw}$ ): 400 ml\*

Average gross wt: 95303.2 mg

Tare wt: 95302.1 mg

Weight of blank ( $m_{ab}$ ): 1.1 mg

Acetone blank residue concentration ( $C_a$ ):

$$C_a = \frac{m_{ab}}{V_a \times p_a} = \frac{1.1}{(200)(0.79)} = \underline{0.0070} \text{ mg/g}$$

Weight of residue in acetone wash ( $W_a$ ):

$$W_a = C_a \times V_{aw} \times p_a = (0.007)(400)(0.79) = \underline{2.2} \text{ mg}^{**}$$

\* ALL ACETONE WASH SAMPLES BROUGHT UP TO 400 ml  
 \*\* RESIDUE IN WASH SAMPLES INSIGNIFICANT IN EMISSION CALCULATIONS, THEREFORE NOT SUBTRACTED FROM FRONT HALF CATCH.

**AIR POLLUTION PARTICULATE ANALYTICAL DATA**

BASE <i>FIELSON AFB</i>	DATE <i>20 JULY 58</i>	RUN NUMBER <i>N/A</i>
BUILDING NUMBER <i>CP 411</i>	SOURCE NUMBER <i>200 ml. HCL/20% BLS/NTC</i>	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>N/A</i>	<i>→</i>	<i>→</i>
ACETONE WASHINGS (Probe, Front Half Filter) <i>BLS/NTC</i>	<i>95.3032</i>	<i>95.3021</i>	<i>0.0011</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>0.0011 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H <sub>2</sub> O)			
IMPINGER 2 (H <sub>2</sub> O)			
IMPINGER 3 (Dry)			
IMPINGER 4 (Silica Gel)			
Total Weight of Water Collected			<i>gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO <sub>2</sub>					
VOL % O <sub>2</sub>					
VOL % CO					
VOL % N <sub>2</sub>					

Vol % N<sub>2</sub> = (100% - % CO<sub>2</sub> - % O<sub>2</sub> - % CO)

# BOILER 2, 14 JULY

XROM "METH 5"  
 RUN NUMBER  
 B2 R1 14 JULY

METER BOX V?	RUN
1.0770	PUN
DELTA H?	PUN
3.7000	PUN
BAR PRESS ?	PUN
29.2350	PUN
METER VOL ?	PUN
53.2770	PUN
MTF TEMP F?	PUN
98.0000	RUN

% OTHER GAS  
 REMOVED BEFORE  
 DRY GAS METER ?

STATIC HOH IN ?	PUN
-1.4500	PUN

STACK TEMP.	PUN
412.0000	RUN

MO. WATER ?	PUN
255.3000	PUN

IMP. % HOH = 10.3  
 % HOH=10.3

% CO?	PUN
13.6000	PUN

% OXYGEN?	PUN
5.9000	RUN

% CO ?	PUN
	PUN

MOL WT OTHER?  
 RUN

MW =30.41	
MW NET=26.14	

SOP? PSTS ?	PUN
32.0000	PUN

TIME MIN ?	PUN
60.0000	RUN

NOZZLE DIA ?	PUN
.2520	PUN

STK DIA INCH ?	PUN
52.5000	PUN

- VOL MTF STI = 53.545
- STY PRES ABS = 29.13
- VOL HOH GAS = 12.02
- % MOISTURE = 10.33
- MO. DRY GAS = 0.217
- % NITROGEN = 80.50
- MO. WT DRY = 30.41
- MO. WT NET = 26.14
- VELOCITY FPS = 62.43
- STACK AREA = 15.03
- STACK AREA = 74.347
- STACK DSCFM = 35.793
- % ISOINETIC = 100.20

XROM "METH 5"

RUN NUMBER  
 B2 R1 14 JULY

VOL MTF STI ?	PUN
53.545	PUN

STACK DSCFM ?	PUN
35.793.00	PUN

FRONT 1/2 MG ?	PUN
534.70	PUN
BACK 1/2 MG ?	PUN

- F CF/DSCF = 0.15
- F MG/MM = 352.65
- F LB/HF = 47.20
- F KG/HF = 21.45

# BOILER 3, 17JULY

XROM "METH S"

RUN NUMBER  
B3 R1 17 July

METER BOX V? 1.0000 RUN  
DELTA H? 3.8900 RUN  
DAP PRESS ? 29.6200 RUN  
METER VOL ? 56.3230 RUN  
MTR TEMP F? 97.0000 RUN  
2 OTHER GAS REMOVED BEFORE DRY GAS METER ? RUN  
STATIC MOM IN ? -1.9000 RUN  
STACK TEMP. 363.0000 RUN  
ML. WATER ? 162.0000 RUN  
INF. 2. MOM = 11.7  
2. MOM = 11.7  
2. CO2? 10.6000 RUN  
2. OXYGEN? 8.0000 RUN  
2. CO ? RUN  
MOL. WT. OTHER? RUN  
MWD = 36.05  
MW MET = 28.64

SOFT PSTS ? 33.8050 RUN  
TIME MIN ? 60.0000 RUN  
NOZZLE DIA ? .2540 RUN  
STR DIA INCH ? 52.5000 RUN

- VOL. MTR STI = 57.675
- STI PRES AREA = 29.45
- VOL. MOM GAS = 7.94
- 2. MOISTURE = 11.87
- MOL. DRY GAS = 6.992
- 2. NITROGEN = 81.06
- MOL. WT. DRY = 36.05
- MOL. WT. MET = 28.64
- VELOCITY FPS = 82.45
- STACK AREA = 15.07
- STACK AREA = 75.306
- STACK BSCFM = 42.979
- 2. ISOINETIC = 119.2

XROM "METH S"

RUN NUMBER  
B3 R1 17 July

VOL. MTR STI ? 57.6750 RUN  
STACK BSCFM ? 42.9790000 RUN  
FRONT 1/2 NO ? 297.0000 RUN  
BACK 1/2 NO ? 760.0000 RUN  
F. GR BSCFM = 0.2075  
F. MCMH = 465.6657  
F. LB/HF = 73.5580  
F. KG/HF = 33.3654

XROM "METH S"

RUN NUMBER  
B3 P2 17 July

VOL. MTR STI ? 31.0990 RUN  
STACK BSCFM ? 42.9790000 RUN  
FRONT 1/2 NO ? 297.0000 RUN  
BACK 1/2 NO ? 760.0000 RUN

F. GR BSCFM = 0.1474  
F. MCMH = 377.2647  
F. LB/HF = 54.0449  
F. KG/HF = 24.6051

XROM "METH S"

RUN NUMBER  
B3 R2 17 July

METER BOX V? 1.0000 RUN  
DELTA H? .5200 RUN  
DAP PRESS ? 29.6200 RUN  
METER VOL ? 30.0300 RUN  
MTR TEMP F? 86.0000 RUN  
2 OTHER GAS REMOVED BEFORE DRY GAS METER ? RUN  
STATIC MOM IN ? -1.9000 RUN  
STACK TEMP. 363.0000 RUN  
ML. WATER ? 71.7000 RUN  
INF. 2. MOM = 9.8  
2. MOM = 9.8  
2. CO2? 10.6000 RUN  
2. OXYGEN? 8.4000 RUN  
2. CO ? RUN  
MOL. WT. OTHER? RUN  
MWD = 36.07  
MW MET = 28.85

SOFT PSTS ? 33.9057 RUN  
TIME MIN ? 72.0000 RUN  
NOZZLE DIA ? .1550 RUN  
STR DIA INCH ? 52.5000 RUN

- VOL. MTR STI = 31.099
- STI PRES AREA = 29.45
- VOL. MOM GAS = 7.94
- 2. MOISTURE = 9.79
- MOL. DRY GAS = 6.992
- 2. NITROGEN = 81.06
- MOL. WT. DRY = 36.05
- MOL. WT. MET = 28.85
- VELOCITY FPS = 82.45
- STACK AREA = 15.07
- STACK AREA = 75.306
- STACK BSCFM = 42.979
- 2. ISOINETIC = 119.2

XROM "METH S"

RUN NUMBER  
B3 R3 17 July

METER BOX V? 1.0000 RUN  
DELTA H? .4900 RUN  
DAP PRESS ? 29.6200 RUN  
METER VOL ? 32.3140 RUN  
MTR TEMP F? 86.0000 RUN  
2 OTHER GAS REMOVED BEFORE DRY GAS METER ? RUN  
STATIC MOM IN ? -1.9000 RUN  
STACK TEMP. 377.0000 RUN  
ML. WATER ? 82.6000 RUN  
INF. 2. MOM = 10.6  
2. MOM = 10.6  
2. CO2? 10.6000 RUN  
2. OXYGEN? 6.4000 RUN  
2. CO ? RUN  
MOL. WT. OTHER? RUN  
MWD = 36.07  
MW MET = 28.77

SOFT PSTS ? 33.2150 RUN  
TIME MIN ? 84.0000 RUN  
NOZZLE DIA ? .1550 RUN  
STR DIA INCH ? 52.5000 RUN

- VOL. MTR STI = 32.329
- STI PRES AREA = 29.45
- VOL. MOM GAS = 7.94
- 2. MOISTURE = 10.59
- MOL. DRY GAS = 6.992
- 2. NITROGEN = 81.06
- MOL. WT. DRY = 36.05
- MOL. WT. MET = 28.77
- VELOCITY FPS = 82.45
- STACK AREA = 15.07
- STACK AREA = 75.306
- STACK BSCFM = 42.979
- 2. ISOINETIC = 119.2

XROM "METH S"

RUN NUMBER  
B3 P3 17 July

VOL. MTR STI ? 32.3290 RUN  
STACK BSCFM ? 42.9790000 RUN  
FRONT 1/2 NO ? 297.0000 RUN  
BACK 1/2 NO ? 760.0000 RUN  
F. GR BSCFM = 0.1394  
F. MCMH = 319.4567  
F. LB/HF = 49.1455  
F. KG/HF = 22.2931



**BOILER 3, 18 JULY**

<p><b>XROM "METH 5"</b></p> <p><b>RUN NUMBER</b> B3 R1 <b>18 July</b></p> <p>METER BOX Y? <b>RUN</b></p> <p>METER BOX Y? 1.0770 <b>RUN</b></p> <p>DELTA H? 3.7300 <b>RUN</b></p> <p>BAR PRESS ? 29.7890 <b>RUN</b></p> <p>METER VOL ? 54.2510 <b>RUN</b></p> <p>MTR TEMP F? 103.0000 <b>RUN</b></p> <p>% OTHER GAS REMOVED BEFORE DRY GAS METER ? <b>RUN</b></p> <p>STATIC MOM IN ? -1.1000 <b>RUN</b></p> <p>STACK TEMP. 387.2000 <b>RUN</b></p> <p>ML. WATER ? 118.2000 <b>RUN</b></p> <p>IMP. % MOH = 9.2</p> <p>% MOH=9.2</p> <p>% CO2 ? 9.0000 <b>RUN</b></p> <p>% OXYGEN? 9.6000 <b>RUN</b></p> <p>% CO ? <b>RUN</b></p> <p>MOL WT OTHER? <b>RUN</b></p> <p>MWD =29.82 MW MET=26.74</p> <p><b>RUN NUMBER</b> B3 R2 18 JULY</p> <p>TIME MIN ? 34.0274 <b>RUN</b></p> <p>MOZZLE DIA ? 60.0000 <b>RUN</b></p> <p>STY DIA INCH ? 52.5000 <b>RUN</b></p> <p>* VOL MTR STD = 55.059 STY PRES ABS = 29.71 VOL MOH GAS = 5.56 % MOISTURE = 9.15 MOL DRY GAS = 0.989 % NITROGEN = 81.48 MOL WT DRY = 29.82 MOL WT MET = 26.74 VELOCITY FPS = 97.67 STACK AREA = 15.82 STACK ACFM = 75.471 * STACK BSCFM = 42.394 % ISOINETIC = 95.51</p>	<p><b>XROM "METH 5"</b></p> <p><b>RUN NUMBER</b> B3 R2 <b>18 July</b></p> <p>METER BOX Y? <b>RUN</b></p> <p>METER BOX Y? 1.0770 <b>RUN</b></p> <p>DELTA H? 3.4200 <b>RUN</b></p> <p>BAR PRESS ? 29.7890 <b>RUN</b></p> <p>METER VOL ? 49.5500 <b>RUN</b></p> <p>MTR TEMP F? 104.0000 <b>RUN</b></p> <p>% OTHER GAS REMOVED BEFORE DRY GAS METER ? <b>RUN</b></p> <p>STATIC MOM IN ? -1.1000 <b>RUN</b></p> <p>STACK TEMP. 386.0000 <b>RUN</b></p> <p>ML. WATER ? 117.4000 <b>RUN</b></p> <p>IMP. % MOH = 9.9</p> <p>% MOH=9.9</p> <p>% CO2? 10.0000 <b>RUN</b></p> <p>% OXYGEN? 9.4000 <b>RUN</b></p> <p>% CO ? <b>RUN</b></p> <p>MOL WT OTHER? <b>RUN</b></p> <p>MWD =29.96 MW MET=26.74</p> <p><b>RUN NUMBER</b> B3 R2 18 JULY</p> <p>TIME MIN ? 31.8630 <b>RUN</b></p> <p>MOZZLE DIA ? 60.0000 <b>RUN</b></p> <p>STY DIA INCH ? 52.5000 <b>RUN</b></p> <p>* VOL MTR STD = 50.169 STY PRES ABS = 29.71 VOL MOH GAS = 5.57 % MOISTURE = 9.92 MOL DRY GAS = 0.993 % NITROGEN = 80.69 MOL WT DRY = 29.82 MOL WT MET = 26.74 VELOCITY FPS = 78.24 STACK AREA = 15.82 STACK ACFM = 74.573 * STACK BSCFM = 39.794 % ISOINETIC = 97.64</p>	<p><b>XROM "METH 5"</b></p> <p><b>RUN NUMBER</b> B3 R3 <b>18 July</b></p> <p>METER BOX Y? <b>RUN</b></p> <p>METER BOX Y? 1.0770 <b>RUN</b></p> <p>DELTA H? 3.7400 <b>RUN</b></p> <p>BAR PRESS ? 29.7890 <b>RUN</b></p> <p>METER VOL ? 53.7120 <b>RUN</b></p> <p>MTR TEMP F? 106.0000 <b>RUN</b></p> <p>% OTHER GAS REMOVED BEFORE DRY GAS METER ? <b>RUN</b></p> <p>STATIC MOM IN ? -1.1000 <b>RUN</b></p> <p>STACK TEMP. 384.0000 <b>RUN</b></p> <p>ML. WATER ? 129.4000 <b>RUN</b></p> <p>IMP. % MOH = 10.1</p> <p>% MOH=10.1</p> <p>% CO2? 16.1000 <b>RUN</b></p> <p>% OXYGEN? 9.5000 <b>RUN</b></p> <p>% CO ? <b>RUN</b></p> <p>MOL WT OTHER? <b>RUN</b></p> <p>MWD =30.09 MW MET=26.78</p> <p><b>RUN NUMBER</b> B3 R3 18 JULY</p> <p>TIME MIN ? 33.0016 <b>RUN</b></p> <p>MOZZLE DIA ? 60.0000 <b>RUN</b></p> <p>STY DIA INCH ? 52.5000 <b>RUN</b></p> <p>* VOL MTR STD = 54.224 STY PRES ABS = 29.71 VOL MOH GAS = 6.09 % MOISTURE = 10.19 MOL DRY GAS = 0.994 % NITROGEN = 80.48 MOL WT DRY = 30.09 MOL WT MET = 26.78 VELOCITY FPS = 87.81 STACK AREA = 15.82 STACK ACFM = 74.871 * STACK BSCFM = 41.810 % ISOINETIC = 95.30</p>
---	---	--

# BOILER 3, 19 JULY

XROM METH 5-		XROM METH 5-		XROM METH 5-	
RUN NUMBER	RUN	RUN NUMBER	RUN	RUN NUMBER	RUN
B3 R1 19 JULY		B3 R2 19 JULY		B3 R3 19 JULY	
METER BOX Y?	RUN	METER BOX Y?	RUN	METER BOX Y?	RUN
1.0770	RUN	1.0770	RUN	1.0770	RUN
DELTA H?	RUN	DELTA H?	RUN	DELTA H?	RUN
3.3700	RUN	3.6000	RUN	3.4100	RUN
BAR PRESS ?	RUN	BAR PRESS ?	RUN	BAR PRESS ?	RUN
29.6200	RUN	29.6200	RUN	29.6200	RUN
METER VOL ?	RUN	METER VOL ?	RUN	METER VOL ?	RUN
52.2720	RUN	52.2590	RUN	52.4960	RUN
MTR TEMP F?	RUN	MTR TEMP F?	RUN	MTR TEMP F?	RUN
100.0000	RUN	112.0000	RUN	100.0000	RUN
% OTHER GAS	RUN	% OTHER GAS	RUN	% OTHER GAS	RUN
REMOVED BEFORE	RUN	REMOVED BEFORE	RUN	REMOVED BEFORE	RUN
DRY GAS METER ?	RUN	DRY GAS METER ?	RUN	DRY GAS METER ?	RUN
STATIC HOH IN ?	RUN	STATIC HOH IN ?	RUN	STATIC HOH IN ?	RUN
-1.0500	RUN	-1.0500	RUN	-1.0500	RUN
STACK TEMP.	RUN	STACK TEMP.	RUN	STACK TEMP.	RUN
370.0000	RUN	370.0000	RUN	370.0000	RUN
ML. WATER ?	RUN	ML. WATER ?	RUN	ML. WATER ?	RUN
100.3000	RUN	87.9000	RUN	107.6000	RUN
INF. % HOH = 6.5		INF. % HOH = 7.4		INF. % HOH = 8.0	
% HOH=6.5		% HOH=7.4		% HOH=8.0	
% CO2	RUN	% CO2	RUN	% CO2	RUN
8.5000	RUN	9.5000	RUN	7.3000	RUN
% OXYGEN	RUN	% OXYGEN	RUN	% OXYGEN	RUN
10.9000	RUN	9.9000	RUN	12.3000	RUN
% CO	RUN	% CO	RUN	% CO	RUN
MOL WT OTHER?	RUN	MOL WT OTHER?	RUN	MOL WT OTHER?	RUN
MW=29.80		MW=29.90		MW=29.60	
MW MET=28.80		MW MET=29.00		MW MET=28.60	
SOFT PSTE ?	RUN	SOFT PSTE ?	RUN	SOFT PSTE ?	RUN
31.1000	RUN	31.4700	RUN	31.4200	RUN
TIME MIN ?	RUN	TIME MIN ?	RUN	TIME MIN ?	RUN
60.0000	RUN	60.0000	RUN	60.0000	RUN
NOZZLE DIA ?	RUN	NOZZLE DIA ?	RUN	NOZZLE DIA ?	RUN
.2500	RUN	.2500	RUN	.2500	RUN
STK DIA INCH ?	RUN	STK DIA INCH ?	RUN	STK DIA INCH ?	RUN
52.5000	RUN	52.5000	RUN	52.5000	RUN
* VOL MTR STD = 50.100		* VOL MTR STD = 51.900		* VOL MTR STD = 50.400	
STK PRES ARE = 29.60		STK PRES ARE = 29.60		STK PRES ARE = 29.60	
VOL HOH GAS = 4.90		VOL HOH GAS = 4.10		VOL HOH GAS = 5.00	
% MOISTURE = 0.40		% MOISTURE = 0.70		% MOISTURE = 0.80	
MOL DR GAS = 0.90		MOL DR GAS = 0.90		MOL DR GAS = 0.90	
% NITROGEN = 80.60		% NITROGEN = 80.60		% NITROGEN = 80.60	
MOL WT DRY = 29.80		MOL WT DRY = 29.90		MOL WT DRY = 29.60	
MOL WT MET = 28.80		MOL WT MET = 29.00		MOL WT MET = 28.60	
VELOCITY FPS = 79.00		VELOCITY FPS = 79.60		VELOCITY FPS = 77.50	
STACK AREA = 15.00		STACK AREA = 15.00		STACK AREA = 15.00	
STACK BSCFM = 29.00		STACK BSCFM = 41.200		STACK BSCFM = 29.700	
% ISOINETIC = 97.00		% ISOINETIC = 92.70		% ISOINETIC = 97.00	

# BOILER 3, 20 JULY

## XROM "METH 5"

RUN NUMBER  
B3 R1 20 JULY

METER BOX Y? RUN  
1.0770 RUN  
DELTA H? RUN  
3.1900 RUN  
BAR PRESS ? RUN  
29.2450 RUN  
METER VOL ? RUN  
49.0000 RUN  
MTR TEMP F? RUN  
104.0000 RUN  
% OTHER GAS  
REMOVED BEFORE  
DRY GAS METER ? RUN  
STATIC HOH IN ? RUN  
-1.1000 RUN  
STACK TEMP. RUN  
373.0000 RUN  
ML. WATER ? RUN  
117.9000 RUN  
INF. % HOH = 10.1  
% HOH=10.1

% CO2? RUN  
9.7000 RUN  
% OXYGEN? RUN  
9.3000 RUN  
% CO ? RUN  
MOL WT OTHER? RUN

MW = 29.92  
MW MET = 26.72

SOFT PSTS ? RUN  
30.4430 RUN  
TIME MIN ? RUN  
60.0000 RUN  
NOZZLE DIA ? RUN  
.2500 RUN  
STK DIA INCH ? RUN  
52.5000 RUN

- VOL MTR STD = 49.481
- STK PRES AER = 29.14
- VOL HOH GAS = 5.55
- % MOISTURE = 10.00
- MOL BF: GAS = 0.999
- % NITROGEN = 81.00
- MOL WT DRY = 29.92
- MOL WT MET = 26.72
- VELOCITY FPS = 75.54
- STACK AREA = 15.07
- STACK ACFM = 68.130
- STACK BSCFM = 37.850
- % ISOINETIC = 96.14

## XROM "METH 5"

RUN NUMBER  
B3 R1 20 JULY

VOL MTR STD ? RUN  
49.481 RUN  
STACK BSCFM ? RUN  
37.850000 RUN  
FRONT 1/2 MTR ? RUN  
359.400 RUN  
BACK 1/2 MTR ? RUN  
0.000 RUN  
F GR/BSCF = 0.110  
F MG/MMH = 256.499  
F LB/HF = 36.365  
F KG/HF = 16.495

## XROM "METH 5"

RUN NUMBER  
B3 R2 20 JULY

VOL MTR STD ? RUN  
50.154 RUN  
STACK BSCFM ? RUN  
37.590000 RUN  
FRONT 1/2 MTR ? RUN  
287.400 RUN  
BACK 1/2 MTR ? RUN  
0.000 RUN  
F GR/BSCF = 0.097  
F MG/MMH = 199.545  
F LB/HF = 28.181  
F KG/HF = 12.746

F GR/BSCF = 0.097  
F MG/MMH = 199.545  
F LB/HF = 28.181  
F KG/HF = 12.746

## XROM "METH 5"

RUN NUMBER  
B3 R2 20 JULY

METER BOX Y? RUN  
1.0770 RUN  
DELTA H? RUN  
3.1300 RUN  
BAR PRESS ? RUN  
29.2300 RUN  
METER VOL ? RUN  
50.7750 RUN  
MTR TEMP F? RUN  
107.0000 RUN  
% OTHER GAS  
REMOVED BEFORE  
DRY GAS METER ? RUN  
STATIC HOH IN ? RUN  
-1.1000 RUN  
STACK TEMP. RUN  
373.0000 RUN  
ML. WATER ? RUN  
119.6000 RUN  
INF. % HOH = 9.8  
% HOH=9.8

% CO2? RUN  
10.3000 RUN  
% OXYGEN? RUN  
8.9000 RUN  
% CO ? RUN  
MOL WT OTHER? RUN

MW = 30.09  
MW MET = 26.87

SOFT PSTS ? RUN  
30.1990 RUN  
TIME MIN ? RUN  
60.0000 RUN  
NOZZLE DIA ? RUN  
.2500 RUN  
STK DIA INCH ? RUN  
52.5000 RUN

- VOL MTR STD = 50.154
- STK PRES AER = 29.14
- VOL HOH GAS = 5.44
- % MOISTURE = 9.74
- MOL DRY GAS = 0.901
- % NITROGEN = 80.60
- MOL WT DRY = 30.09
- MOL WT MET = 26.87
- VELOCITY FPS = 74.80
- STACK AREA = 15.07
- STACK ACFM = 67.449
- STACK BSCFM = 37.590
- % ISOINETIC = 96.11

## XROM "METH 5"

RUN NUMBER  
B3 R3 20 JULY

METER BOX Y? RUN  
1.0770 RUN  
DELTA H? RUN  
3.1900 RUN  
BAR PRESS ? RUN  
29.2300 RUN  
METER VOL ? RUN  
51.2550 RUN  
MTR TEMP F? RUN  
110.0000 RUN  
% OTHER GAS  
REMOVED BEFORE  
DRY GAS METER ? RUN  
STATIC HOH IN ? RUN  
-1.1000 RUN  
STACK TEMP. RUN  
372.0000 RUN  
ML. WATER ? RUN  
114.6000 RUN  
INF. % HOH = 9.7  
% HOH=9.7

% CO2? RUN  
10.3000 RUN  
% OXYGEN? RUN  
9.3000 RUN  
% CO ? RUN  
MOL WT OTHER? RUN

MW = 30.02  
MW MET = 26.84

SOFT PSTS ? RUN  
30.4120 RUN  
TIME MIN ? RUN  
60.0000 RUN  
NOZZLE DIA ? RUN  
.2500 RUN  
STK DIA INCH ? RUN  
52.5000 RUN

- VOL MTR STD = 50.254
- STK PRES AER = 29.14
- VOL HOH GAS = 5.79
- % MOISTURE = 9.61
- MOL BF: GAS = 0.907
- % NITROGEN = 80.40
- MOL WT DRY = 30.02
- MOL WT MET = 26.84
- VELOCITY FPS = 75.00
- STACK AREA = 15.07
- STACK ACFM = 67.921
- STACK BSCFM = 37.930
- % ISOINETIC = 97.64

RUN NUMBER  
B3 R3 20 JULY

VOL MTR STD ? RUN  
50.350 RUN  
STACK BSCFM ? RUN  
37.930.000 RUN  
FRONT 1/2 MTR ? RUN  
430.500 RUN  
BACK 1/2 MTR ? RUN  
0.000 RUN  
F GR/BSCF = 0.122  
F MG/MMH = 301.940  
F LB/HF = 42.057  
F KG/HF = 19.451

(This page left blank)

APPENDIX K  
Calibration Data

(This page left blank)

METER BOX CALIBRATION DATA AND CALCULATION FORM

(English units)

Date 12 Jul 88

Meter box number 200 NUFECH

Barometric pressure,  $P_b =$  29.119 in. Hg Calibrated by Fagin & Scott

Val in. H <sub>2</sub> O	Gas volume		Temperature				Time ( $\theta$ ), min	$Y_i$	$\Delta H_i^c$ in. H <sub>2</sub> O	
	Orifice manometer setting ( $\Delta H$ ), in. H <sub>2</sub> O	Wet test meter ( $V_w$ ), ft <sup>3</sup>	Dry gas meter ( $V_d$ ), ft <sup>3</sup>	Wet test meter ( $t_w$ ), °F/R	Dry gas meter					
					Inlet ( $t_{d_i}$ ), °F/R	Outlet ( $t_{d_o}$ ), °F/R				Avg <sup>a</sup> ( $t_d$ ), °F/R
4	0.5	5	4.668	<sup>78</sup> <sub>79</sub> 538	<sup>76</sup> <sub>83</sub> 539.5	<sup>75</sup> <sub>78</sub> 536.5	538	13.1	1.070	2.010
4	1.0	5	4.670	<sup>78</sup> <sub>78</sub> 538	<sup>89</sup> <sub>81</sub> 546.5	<sup>78</sup> <sub>81</sub> 539.5	543	9.3	1.078	2.008
4	1.5	10	9.390	<sup>78</sup> <sub>78</sub> 538	<sup>90</sup> <sub>96</sub> 553	<sup>82</sup> <sub>86</sub> 544	548.5	15.5	1.082	2.070
4	2.0	10	9.455	<sup>79</sup> <sub>80</sub> 539.5	<sup>96</sup> <sub>101</sub> 558.5	<sup>87</sup> <sub>90</sub> 548.5	553.5	13.5	1.070	2.087
4	3.0	10	9.470	<sup>80</sup> <sub>81</sub> 540.5	<sup>101</sup> <sub>106</sub> 563.5	<sup>90</sup> <sub>93</sub> 557.5	557.5	11.1	1.081	2.109
4	4.0	10.1	9.590	<sup>81</sup> <sub>81</sub> 541	<sup>106</sup> <sub>109</sub> 567.5	<sup>94</sup> <sub>96</sub> 555	561.3	9.8	1.082	2.138
								Avg	1.077	2.070

$\Delta H$ , in. H <sub>2</sub> O	$\frac{\Delta H}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H_i^c = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[ \frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	$Y_1 = \frac{(5)(29.119)(538)}{(4.668)(29.119 + \frac{0.5}{13.6})(538)}$	$H_{01} = \frac{(0.0317)(0.5)}{(29.119)(538)} \left[ \frac{(538)(13.1)}{5} \right]^2$
1.0	0.0737	$Y_2 = \frac{(5)(29.119)(543)}{(4.67)(29.119 + \frac{1}{13.6})(538)}$	$H_{02} = \frac{(0.0317)(1)}{(29.119)(543)} \left[ \frac{(538)(9.3)}{5} \right]^2$
1.5	0.110	$Y_3 = \frac{(10)(29.119)(548.5)}{(9.39)(29.119 + \frac{1.5}{13.6})(538)}$	$H_{03} = \frac{(0.0317)(1.5)}{(29.119)(538)} \left[ \frac{(538)(15.5)}{10} \right]^2$
2.0	0.147	$Y_4 = \frac{(10)(29.119)(553.5)}{(9.455)(29.119 + \frac{2}{13.6})(539.5)}$	$H_{04} = \frac{(0.0317)(2.0)}{(29.119)(553.5)} \left[ \frac{(539.5)(13.5)}{10} \right]^2$
3.0	0.221	$Y_5 = \frac{(10)(29.119)(557.5)}{(9.47)(29.119 + \frac{3}{13.6})(540.5)}$	$H_{05} = \frac{(0.0317)(3)}{(29.119)(557.5)} \left[ \frac{(540.5)(11.1)}{10} \right]^2$
4.0	0.294	$Y_6 = \frac{(10.1)(29.119)(561.3)}{(9.59)(29.119 + \frac{4}{13.6})(541)}$	$H_{06} = \frac{(0.0317)(4)}{(29.119)(561.3)} \left[ \frac{(541)(9.8)}{10.1} \right]^2$

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$ .

POSTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Plant Electron Res+ (Succo) AFB

Test number 21 Date 9 Aug 58 Meter box number

Barometric pressure,  $P_b = 29.7$  in. Hg Dry gas meter number NDTECH Pretest  $Y = 1.077$

Orifice manometer setting, $(\Delta H)$ , in. H <sub>2</sub> O	Gas volume		Temperature				Time $(\Theta)$ , min	Vacuum setting, in. HG	$Y_1$	$V_w P_b (t_d + 460)$ $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$
	Wet test meter $(V_w)$ , ft <sup>3</sup>	Dry gas meter $(V_d)$ , ft <sup>3</sup>	Wet test meter $(t_w)$ , °F	Dry gas meter		Average $(t_d)$ , °F				
				Inlet $(t_{d_i})$ , °F	Outlet $(t_{d_o})$ , °F					
2.0	10	9.327	79 84 86	545 545 545	79 80 80	542.75	12.2	1.072	$108 \times 29.76 \times 542.25$ $77.327 \times 29.76 \times 2.5/13.6 \times 539$	
2.5	10	9.336	79 80	539 547	82 82	544.0	12.2	1.071	$108 \times 29.76 \times 544$ $77.327 \times 29.76 \times 2.5/13.6 \times 539$	
2.5	10	9.368	79 80	549 549	84 84	546.25	17.2	1.074	$108 \times 29.76 \times 546.25$ $77.327 \times 29.76 \times 2.5/13.6 \times 539$	
$Y = 1.073$										

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$

where

$V_w$  = Gas volume passing through the wet test meter, ft<sup>3</sup>.

$V_d$  = Gas volume passing through the dry gas meter, ft<sup>3</sup>.

$t_w$  = Temperature of the gas in the wet test meter, °F.

$t_{d_i}$  = Temperature of the inlet gas of the dry gas meter, °F.

$t_{d_o}$  = Temperature of the outlet gas of the dry gas meter, °F.

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{d_i}$  and  $t_{d_o}$ , °F.

$\Delta H$  = Pressure differential across orifice, in. H<sub>2</sub>O.

$Y_i$  = Ratio of accuracy of wet test meter to dry gas meter for each run.

$Y$  = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest  $Y \pm 0.05Y$ .

$P_b$  = Barometric pressure, in. Hg.

$\Theta$  = Time of calibration run, min.

NOTY 1 MIN. R. CORRECTION  $Y \pm 0.05Y$   
 $= 1.0232 \rightarrow 1.1309$



METER BOX CALIBRATION DATA AND CALCULATION FORM

(English units)

Date 12 Jul 88

Meter box number PAC

Barometric pressure,  $P_b =$  29.131 in. Hg Calibrated by Edwin E Scott R. A. 10.1

Orifice manometer setting (ΔH), in. H <sub>2</sub> O	Gas volume		Temperature			Time (θ), min	Y <sub>i</sub>	ΔH <sub>0</sub> <sup>10</sup> , in. H <sub>2</sub> O
	Wet test meter (V <sub>w</sub> ), ft <sup>3</sup>	Dry gas meter (V <sub>d</sub> ), ft <sup>3</sup>	Wet test meter (t <sub>w</sub> ), °R	Dry gas meter				
				Inlet (t <sub>d<sub>i</sub></sub> ), °R	Outlet (t <sub>d<sub>o</sub></sub> ), °R			
4 0.5	5	4.712	77 537.5	76 537	78 537.5	12.0	1.081	1.652
4 1.0	5.2	4.940	77 537.5	78 539	78 537.5	8.9	1.080	1.666
4 1.5	10	9.600	78 538	81 542.5	79 538.5	15.0	1.075	1.908
4 2.0	10	9.529	78 538.5	85 545.5	79 538.5	13.0	1.087	1.902
4 3.0	10	9.636	79 539	87 547.5	79 539	16.6	1.076	1.872
4 4.0	10	9.605	79 539	88 548.5	79 539	9.1	1.080	1.391
						Avg	1.080	1.736

ΔH, in. H <sub>2</sub> O	$\frac{\Delta H}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H \theta_i = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[ \frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	$Y_1 = \frac{(5 \times 29.131)(548.25)}{(4.712)(29.131 + \frac{5}{13.6})(537.5)}$	$\Delta H \theta_1 = \frac{(0.0317)(5)}{(29.131)(548.25)} \left[ \frac{(537.5)(12.0)}{5} \right]^2$
1.0	0.0737	$Y_2 = \frac{(5.2 \times 29.131)(552.75)}{(4.94)(29.131 + \frac{5.2}{13.6})(537.5)}$	$\Delta H \theta_2 = \frac{(0.0317)(5.2)}{(29.131)(552.75)} \left[ \frac{(537.5)(8.9)}{5.2} \right]^2$
1.5	0.110	$Y_3 = \frac{(10 \times 29.131)(557.25)}{(9.6)(29.131 + \frac{10}{13.6})(538)}$	$\Delta H \theta_3 = \frac{(0.0317)(10)}{(29.131)(557.25)} \left[ \frac{(538)(15)}{10} \right]^2$
2.0	0.147	$Y_4 = \frac{(10 \times 29.131)(560.5)}{(9.529)(29.131 + \frac{10}{13.6})(538.5)}$	$\Delta H \theta_4 = \frac{(0.0317)(10)}{(29.131)(560.5)} \left[ \frac{(538.5)(13)}{10} \right]^2$
3.0	0.221	$Y_5 = \frac{(10 \times 29.131)(563)}{(9.636)(29.131 + \frac{10}{13.6})(539)}$	$\Delta H \theta_5 = \frac{(0.0317)(10)}{(29.131)(563)} \left[ \frac{(539)(16.6)}{10} \right]^2$
4.0	0.294	$Y_6 = \frac{(10 \times 29.131)(564.75)}{(9.605)(29.131 + \frac{10}{13.6})(539)}$	$\Delta H \theta_6 = \frac{(0.0317)(10)}{(29.131)(564.75)} \left[ \frac{(539)(9.1)}{10} \right]^2$

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under t<sub>d</sub>.

POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number #1 Date 9 Aug 58 Meter box number \_\_\_\_\_ Plant \_\_\_\_\_

Barometric pressure,  $P_b = 30.00$  in. Hg Dry gas meter number RAC Pretest  $Y = 1.080$

Facility (Inst)  
SARAC (Vic)

Orifice manometer setting, ( $\Delta H$ ), in. H <sub>2</sub> O	Gas volume		Temperature		Time ( $\theta$ ), min	Vacuum setting, in. Hg	$Y_i$	$V_w P_b (t_d + 460)$ $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$
	Wet test meter ( $V_w$ ), ft <sup>3</sup>	Dry gas meter ( $V_d$ ), ft <sup>3</sup>	Wet test meter ( $t_w$ ), °F	Dry gas meter				
			Inlet ( $t_i$ ), °F	Outlet ( $t_o$ ), °F	Average ( $t_d$ ), °F			
2.5	10	9.401	81	76	561.6	20.0	1.097	(10) (30.0) (1.76) (561)
2.5	10	9.516	80	83	571.5	20.0	1.104	(10) (30.0) (1.76) (571.5)
2.5	10	9.646	81	80	578.75	20.0	1.101	(10) (30.0) (1.76) (578.75)
							$Y = 1.101$	

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$

where

$V_w$  = Gas volume passing through the wet test meter, ft<sup>3</sup>

$V_d$  = Gas volume passing through the dry gas meter, ft<sup>3</sup>

$t_w$  = Temperature of the gas in the wet test meter, °F.

$t_{d_i}$  = Temperature of the inlet gas of the dry gas meter, °F.

$t_{d_o}$  = Temperature of the outlet gas of the dry gas meter, °F.

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{d_i}$  and  $t_{d_o}$ , °F.

$\Delta H$  = Pressure differential across orifice, in. H<sub>2</sub>O.

$Y_i$  = Ratio of accuracy of wet test meter to dry gas meter for each run.

$Y$  = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest  $Y \pm 0.05Y$ .

$P_b$  = Barometric pressure, in. Hg.

$\theta$  = Time of calibration run, min.

$Y = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$

$Y = 1.026 \rightarrow 1.134$

APPENDIX L

EPA Method 9 Certification Documentation

(This page left blank)

# VISIBLE EMISSIONS EVALUATION

This is to certify that

*Major James A. Harrison*

did complete a course in the opacity method of determining visible emissions from sources as specified by Federal Reference Method 9 conducted by Eastern Technical Associates of Raleigh, North Carolina.

*David Savage*  
Course Moderator

*Jacksonville*  
Location

*May 31 1988*  
Date

# VISIBLE EMISSIONS EVALUATOR

This is to certify that

*Major James A Harrison*

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

*Thomas H. Rose*  
President

*Willie J. Lee*  
Vice President

*David Savage*  
Program Manager

*220573*  
Certificate Number

*Jacksonville*  
Location

*June 2, 1988*  
Date of Issue

## DISTRIBUTION LIST

	COPIES
HQ AFSC/SGPB Andrews AFB DC 20334-5000	1
HQ USAF/SGPA Bolling AFB DC 20332-6188	1
HQ AAC/SGPB Elmendorf AFB AK 99506-5001	1
USAF Regional Medical Center Wiesbaden/SGB APO New York 09220-5300	1
OL AD. USAFOEHL APO San Francisco 96274-5000	1
USAFSAM/TSK Brooks AFB TX 78235-5301	1
USAFSAM/EDH Brooks AFB TX 78235-5301	1
Defense Technical Information Center(DTIC) Cameron Station Alexandria VA 22304-6145	2
HSD/EV Brooks AFB TX 78235-5000	1
HQ USAF/LEEV Bolling AFB DC 20330-5000	1
HQ AFESC/RDV Tyndall AFB FL 32403-6001	1
HQ AAC/DE Elmendorf AFB. AK 99506-5001	1
USAF Clinic Eielson/SGPB Eielson AFB AK 99702-5300	5