

DTIC FILE COPY

2

Naval Research Laboratory

Washington, DC 20375-5000



NRL Memorandum Report 6274

AD-A208 522

An X-Ray Source for Lithography Based on a Quasi-Optical Maser Undulator

P. SPRANGLE, B. HAFIZI* AND F. MAKO**

*Plasma Theory Branch
Plasma Physics Division*

**Science Applications International Corp., McLean, VA*

***FM Technologies, Inc., Alexandria, VA*

May 9, 1989

DTIC
ELECTE
JUN 05 1989
S E D

Approved for public release; distribution unlimited.

89 6 05 009

SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE				Form Approved OMB No 0704 0188	
1a REPORT SECURITY CLASSIFICATION UNCLASSIFIED			1b RESTRICTIVE MARKINGS		
2a SECURITY CLASSIFICATION AUTHORITY			3 DISTRIBUTION AVAILABILITY OF REPORT		
2b DECLASSIFICATION/DOWNGRADING SCHEDULE			Approved for public release; distribution unlimited.		
4 PERFORMING ORGANIZATION REPORT NUMBER(S) NRL Memorandum Report 6274			5 MONITORING ORGANIZATION REPORT NUMBER(S)		
6a NAME OF PERFORMING ORGANIZATION Naval Research Laboratory		6b OFFICE SYMBOL (If applicable) Code 4790		7a NAME OF MONITORING ORGANIZATION	
6c ADDRESS (City, State, and ZIP Code) Washington, DC 20375-5000			7b ADDRESS (City, State, and ZIP Code)		
8a NAME OF FUNDING/SPONSORING ORGANIZATION		8b OFFICE SYMBOL (If applicable)		9 PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER	
8c ADDRESS (City, State, and ZIP Code)			10 SOURCE OF FUNDING NUMBERS		
			PROGRAM ELEMENT NO	PROJECT NO ONR	TASK NO
			WORK UNIT ACCESSION NO		
11 TITLE (Include Security Classification) An X-Ray Source for Lithography Based on a Quasi-Optical Maser Undulator					
12 PERSONAL AUTHOR(S) Sprangle, P., Hafizi,* B. and Mako,** F.					
13a TYPE OF REPORT Interim		13b TIME COVERED FROM TO		14 DATE OF REPORT (Year, Month, Day) 1989 May 9	
				15 PAGE COUNT 47	
16 SUPPLEMENTARY NOTATION *Science Application International Corp., McLean, VA **FM Technologies, Alexandria, VA					
17 COSATI CODES			18 SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP	Integrated circuits		
			Lithography		
			X-Ray source		
			Quasi-optical maser		
			Electromagnetic undulator		
19 ABSTRACT (Continue on reverse if necessary and identify by block number) We propose the use of electromagnetic waves as an undulator in order to generate x-rays in the wavelength range required for fabrication of integrated circuits. The configuration consists of a quasi-optical maser cavity through which a beam of relativistic electrons is made to propagate, spontaneously emitting x-rays of the desired energy. For 5" silicon wafers covered with a sensitive resist such as PBS, this translates into a throughput of 26 wafers/hr using an aggressive stepper. The scaling of x-ray power with wavelength indicates that the throughput can be increased substantially using resists which are sensitive to shorter wavelength x-rays.					
20 DISTRIBUTION AVAILABILITY OF ABSTRACT <input checked="" type="checkbox"/> UNCLASSIFIED UNLIMITED <input type="checkbox"/> SAME AS RPT <input type="checkbox"/> DTIC USERS			21 ABSTRACT SECURITY CLASSIFICATION UNCLASSIFIED		
22a NAME OF RESPONSIBLE INDIVIDUAL P. Sprangle			22b TELEPHONE (Include Area Code) (202) 767-3493		22c OFFICE SYMBOL Code 4790

DD Form 1473, JUN 86

Previous editions are obsolete

S/N 0102-LF-014-6603

SECURITY CLASSIFICATION OF THIS PAGE

CONTENTS

I.	INTRODUCTION	1
II.	LITHOGRAPHY	2
	A. Resolution	2
	B. Sources	3
III.	X-RAY LITHOGRAPHY	4
	A. Electron-Impact	4
	B. High-Temperature Plasmas	5
IV.	X-RAY RADIATION IN AN ELECTROMAGNETIC UNDULATOR	7
V.	TECHNICAL DISCUSSION	9
VI.	DESIGN PARAMETERS FOR ELECTROMAGNETIC UNDULATOR	16
VII.	COMPARISON OF X-RAY SOURCE FOR LITHOGRAPHY	18
VIII.	CONCLUSION	20
	ACKNOWLEDGEMENT	20
	REFERENCES	21
	DISTRIBUTION LIST	25

Accession For	
NTIS GRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A-1	



AN X-RAY SOURCE FOR LITHOGRAPHY BASED ON A QUASI-OPTICAL MASER UNDULATOR

I. Introduction

A major contributor to the tremendous developments taking place in our ability to process information is the miniaturization of semiconductor devices marketed by the electronics industry. It is now recognized that over the next few decades the economic well-being of the United States is dependent on its ability to maintain a leadership position in the fast-developing technology for fabricating smaller and cheaper integrated circuits (IC) (see Ref. 1).

A process by which IC's are mass produced is lithography. Using this technique, a predetermined pattern can be rapidly replicated on the surface of a semiconductor chip using a beam of radiation or particles. A reliable, efficient and compact source of radiation or particles is critical to the economic viability of lithography. This is especially so because of the high capital expenditure required for the sources necessitated by further miniaturization.

In this report we propose a novel design concept for a source of x-ray radiation for the purposes of lithography. In order to motivate the design concept and to provide a comparison with other sources presently being considered, the following section is devoted to a brief description of the salient aspects of the lithographic technique. Section III describes the x-ray sources currently under study and/or development. Our proposed scheme is detailed in Sec. IV, followed by a derivation of the x-ray power formula in Sec. V. In Sec. VI we consider the availability of the two major components (electron beam and electromagnetic undulator) required by the proposed scheme, and we present parameters for an actual device based on a preliminary analysis of the power-formula scaling. In Sec. VII we compare our design-parameters with an x-ray source based on a conventional bending-magnet storage ring. Our conclusions are contained in Sec. VIII.

II. Lithography²

The crystal-growing industry routinely provides silicon crystals about 5" or more in diameter. Once a single-crystal ingot is grown, it is sliced into thin wafers, which are then used for device fabrication. Planar technology consists, for example, in selective introduction of dopant atoms into small precisely predetermined areas of the silicon surface to form regions of p- and n-type material. Dopant atoms can be introduced simultaneously into many separate, small regions of a wafer. Therefore, the use of larger diameter wafers and smaller device dimensions minimizes processing cost per device.

The technique for replication of a predetermined pattern on a silicon wafer is referred to as lithography. The pattern may correspond, for example, to an opening for introduction of dopant atoms by diffusion or implantation. Lithography consists in the application of a thin film of a radiation-sensitive plastic -- called a photoresist -- onto the surface of the wafer. The photoresist is then exposed to radiation through a mask, bearing the desired feature, to create a shadow image on the resist.

A. Resolution

Current state-of-the-art miniaturization requirements by the IC industry call for the ability to resolve submicron minimum features of patterns to be replicated. However, for mass-production of critical, leading-edge circuits for computers, memories, signal processors and other devices, resolutions approaching $\leq 0.1 \mu\text{m}$ will be required. Resolution, therefore, is a determining factor in the quest for greater device density. However, as is well-known, diffraction provides a fundamental barrier for resolution. If d is the line width of the feature on the mask to be replicated and λ is the wavelength of the radiation, the diffraction angle is λ/d , so that if s is the mask-to-resist separation, the blur on the

resist is $(\lambda/d)s$. Thus, to reduce blur, it is necessary to use short wavelength radiation (x-rays) or energetic particle beams.

B. Sources

As far as resolution is concerned, x-ray radiation or particle beams are satisfactory sources. It is, however, necessary to consider other factors such as throughput and yield in order to be able to select the most appropriate source for lithographic purposes. Direct-write with tightly focussed electron or ion beams is frequently used for extremely high-resolution processes. The wavelength λ of an electron of momentum p is $\lambda = h/p$ where h is Planck's constant. Thus, for a 20 keV electron beam $\lambda \approx 2.5 \times 10^{-2} \text{ \AA}$. With such short wavelengths, computer-controlled particle beams are ideal for making high-quality patterns on masks which are then used for resist exposure in quantity. However, the main problem with the electron-beam direct-write process for mass production is that it is slow compared to parallel exposure through a mask. In addition, particle beams spread out upon impinging on a resist, and there is also some backscattering and thus possible damage to the mask.

III. X-Ray Lithography

Since x-ray sources have high throughput compared to direct-write techniques, we now concentrate on three sources of x-ray radiation that are envisioned for lithography. These are: a) electron-impact (x-ray tube), b) high-temperature plasma, and c) synchrotron radiation. To compare these, we list the important characteristics that must be considered in making a choice between different sources.

- i) Emission intensity
- ii) Efficiency of x-ray generation and usage
- iii) Spectral character of radiation (lines, continuum, etc.)
- iv) Energy range of emitted photons
- v) Source size (important for resolution)
- vi) Emission solid angle (determines collimation and exposure area)
- vii) Pulsed or cw

In comparing the different x-ray sources, we shall consider the material polymethyl methacrylate (PMMA) which is a popular, high-resolution resist suitable for submicron work. To fully expose PMMA one requires 1 J/cm^2 of 12 \AA radiation. More generally, the range of useful photon energies is $0.5 - 1.5 \text{ keV}$ ($20-8 \text{ \AA}$). Photon energy influences resist absorption which, along with the intensity, determines the exposure time. In common with ordinary photography, faster resists than PMMA are found to exhibit poorer resolution. We now enumerate the properties of the three common sources of x-ray radiation.

A. Electron-Impact

X-ray tubes were the first to be used for x-ray lithography. The radiation is uncollimated and is in the form of lines (bound-to-bound transitions) and a continuum (free-to-free transitions in the nuclear Coulombic field). X-ray tubes are inefficient, with typically less than 1% of the electron beam energy being converted into (total) x-ray radiation.

B. High-Temperature Plasmas

X-ray radiation from plasmas at 10^6 - 10^7 °K is in the form of a line spectrum (bound-to-bound transitions), continua with a high-energy cut-off (free-to-bound transitions), and a continuum (free-to-free, bremsstrahlung). Heating of the plasma is via a discharge (as in a z-pinch) or a high-power laser,³ and the radiation is spread over a large solid angle (2π to 4π). The process is necessarily pulsed with a lifetime of 10-100 ns for discharge heating and 1-10 ns for laser heating. Efficiencies are in the range of 1-10%.

Some of the problems associated with high-temperature plasma lithography are the following:

- i) Contamination of mask and/or resist by debris from the plasma
- ii) Low repetition rate
- iii) Thermal response of mask and/or resist to very intense, pulsed heating
- iv) Significant shot-to-shot variability of plasma sources.

C. Synchrotron Radiation

Synchrotron radiation is generated by electrons in synchrotron accelerators and storage rings. It is basically magnetic bremsstrahlung due to the curved motions of the particles in the bending (dipole) magnets. Although the radiation process is efficient, usage of the emitted radiation is quite inefficient due to the large fraction that is lost onto the vacuum chamber walls. Since the radiation is highly collimated (≤ 1 mrad for a 1 GeV electron beam), the mask-wafer separation and wafer flatness are less critical than with x-rays from a point-source with highly-diverging rays. The spectrum is continuous so that filters and/or mirrors must be used to select the desired wavelength band for lithography work.

In existing and proposed storage rings electrons are typically injected at low energy (~ 150 MeV) and then accelerated to about 1 GeV while the bending magnets are ramped up to about 4-5 T. These are designed for compactness, with linear dimensions on the order of several meters. Superconducting magnet designs are also available and somewhat more compact, although there is the added cost and extra space for the cryogenic system. Thus far, the most important source of x-ray synchrotron radiation is that provided by dedicated storage rings to be found in many national laboratories throughout the world. However, these machines are extremely expensive and occupy a great deal of space. On the other hand, the commercial storage rings for x-ray lithography are only now becoming available.

Since there are inherent difficulties associated with each of the three x-ray sources we have mentioned, in what follows we propose the use of an electromagnetic undulator as another means of generating x-rays which may prove to be suitable for lithographic applications.

IV. X-Ray Radiation in an Electromagnetic Undulator

The use of periodic undulators and of wigglers to achieve higher brightness (energy radiated per unit bandwidth per unit solid angle) and to modify the spectral character of the radiation by storage rings is by now well-established.⁴ Due to complexity and construction costs of electromagnets (conventional or superconducting) recent developments in the fabrication of high-field, rare-earth cobalt permanent magnets^{5,6} have led to their almost-universal use as insertion devices in storage rings.

Defining the dimensionless magnetic field parameter

$$K = \frac{|e| B_0 \lambda_0}{2\pi mc}, \quad (1)$$

where e is the charge and m is the rest-mass of an electron, c is the speed of light in vacuo, B_0 is the peak magnetic induction and λ_0 is the period of the planar undulator or wiggler, the wavelength λ of the radiation emitted along the beam direction is given by

$$\lambda = \frac{\lambda_0 (1 + K^2/2)}{2\gamma^2}, \quad (2)$$

where γ is the relativistic mass factor. Typically, λ_0 ranges over 1-10 cm so that for x-ray radiation in the required range (8-20 Å) electron energies upwards of several GeV are required. On the other hand, one might use lower energy electrons, say 150 MeV, and use extremely short-period insertion devices. However, to maintain the same magnetic field strength there has to be a corresponding decrease in the gap spacing between opposite poles of the magnet.⁶ This implies very thin filamentary electron beams and correspondingly high electron-beam brightness.

As an alternative to the permanent magnet designs mentioned in the preceding, we propose herein to employ a high-power electromagnetic wave of moderate wavelength ($\lesssim 1$ mm) to generate x-ray radiation in the required wavelength range using moderate energy electrons ($\lesssim 1/4$ GeV). It is expected that with use of moderate energy electrons and one of a variety of recently-developed, efficient, high-power sources of coherent radiation, a compact source of x-ray radiation may be designed for commercial use without an excessive capital outlay.

V. Technical Discussion

As is well-known, the radiation emitted by a charged particle in instantaneous circular motion is confined to cone of half-angle $1/\gamma$ about the direction of dominant motion.⁷ It is also well-known that for motion in a periodic magnetic or electromagnetic field the transverse particle orbit is periodically deflected through an angle

$$\theta_d = K/\gamma. \quad (3)$$

We can now distinguish two limiting cases. For $K \leq 1$ we see that the transverse angular deflection of the particle lies within the natural opening angle of the emitted radiation. In this case, the insertion device is referred to as an undulator and the emitted radiation is confined to a very narrow angle about the direction of propagation and is thus of high brightness. For an insertion device for which $K > 1$ (referred to as a wiggler) we see from Eq. (3) that the emitted radiation is spread over an angle K/γ , which may be considerably larger than the natural opening angle $1/\gamma$, depending on the magnitude of K . In the limit $K \gg 1$, the wiggler radiation is similar to that from a bending magnet where particles undergo substantial deflection on traversing the bending field.

For the electromagnetic pump wave to be considered herein, one can define an equivalent parameter K as in Eq. (1). It turns out that for our configuration $K \ll 1$, so that the electromagnetic pump behaves like an undulator. Therefore, unlike wiggler fields and the commercially available bending-magnet designs, the radiation from the electromagnetic undulator would be highly collimated and entirely available for resist exposure. Additionally, for $K \ll 1$ the higher harmonics are negligible compared to the fundamental.

To evaluate the radiated power for the case of the electromagnetic undulator, we refer to Fig. 1. This is a schematic (not to scale) of a configuration wherein the electron beam propagates along the z-axis and interacts with the electromagnetic pump field stored in the cavity. If L is the interaction length, the cavity mirror on the right-hand side includes an orifice of diameter $2L/\gamma$ to permit extraction of the x-ray radiation. The opening in the mirror is connected to a Bragg reflector,⁸ which is simply a long, corrugated metallic tube, to effectively plug the resonant cavity against microwave power loss. Alternatively, the orifice may be connected to a tube across which a jet of neutral gas is pumped. If the gas density is sufficiently high, the microwaves will be reflected due to cutoff if the microwave electric field exceeds the breakdown field for ionization of the neutral gas.^{9,10}

From a well-known formula of electrodynamics the instantaneous power radiated by a single electron in arbitrary, relativistic motion is given by¹¹

$$P = \frac{2e^2}{3c} \gamma^6 \left[\dot{\underline{\beta}}^2 - (\underline{\beta} \times \dot{\underline{\beta}})^2 \right], \quad (4)$$

where $\underline{\beta} = \underline{v}/c$ is the particle velocity normalized to the speed of light, and $\dot{\underline{\beta}} = \dot{\underline{v}}/c$, where $\dot{\underline{v}} = \frac{d}{dt} \underline{v}$ is the acceleration. Making use of the Lorentz force formula, Eq. (4) may be rewritten as

$$P = \frac{2e^4}{3m^2 c^3} \gamma^2 \left[(\underline{E} + \underline{\beta} \times \underline{B})^2 - (\underline{E} \cdot \underline{\beta})^2 \right], \quad (5)$$

where \underline{E} and \underline{B} are the electric and the magnetic fields. Since the x-ray radiation field is small compared to the electromagnetic undulator field, we may neglect the excited radiation fields in Eq. (5). For the undulator field we take plane waves of the form

$$\underline{E} = E_0 \sin(k_0 z + \omega_0 t) \hat{e}_x, \quad (6)$$

$$\underline{B} = - \frac{c E_0 k_0}{\omega_0} \sin(k_0 z + \omega_0 t) \hat{e}_y, \quad (7)$$

where E_0 is the amplitude of the electric field, ω_0 is the radian frequency and $\underline{k}_0 = (0, 0, k_0)$ is the wave-vector. \hat{e}_z is a unit vector along the direction of propagation of the electron beam, with \hat{e}_x out of the plane of the paper and \hat{e}_y in the plane of the paper. We note that the electric and the magnetic field may be obtained from the following vector potential

$$\underline{A} = \frac{c}{\omega_0} E_0 \cos(\underline{k}_0 \cdot \underline{r} + \omega_0 t) \hat{e}_x, \quad (8)$$

where \underline{r} is the radius vector. Since the vector potential is not an explicit function of the x coordinate, the canonical momentum along the x -axis is conserved, whence

$$\beta_x \equiv v_x/c = (K/\gamma) \cos(\underline{k}_0 \cdot \underline{r} + \omega_0 t), \quad (9)$$

where

$$K = \frac{|e| (c E_0 / \omega_0)}{m c^2}, \quad (10)$$

is the undulator parameter [cf. Eq. (1)]. To evaluate the power according to the formula in Eq. (5) we make use of the Lorentz equation and after a simple analysis we obtain, for a single electron,

$$P \approx \frac{e^2 \gamma^2 \omega_0^2 K^2}{3c} (1 + \beta_z)^2. \quad (11)$$

The distribution in frequency and angle of energy radiated by the particle is obtained from¹²

$$\frac{d^2 \epsilon_s}{d\Omega_s d\omega_s} = \frac{e^2 \omega_s^2}{4\pi^2 c} \left| \int_{-L/2c}^{L/2c} dt \hat{n} \times (\hat{n} \times \beta) e^{i\omega_s \left[t - \frac{\hat{n} \cdot \underline{r}(t)}{c} \right]} \right|^2, \quad (12)$$

where \hat{n} is the unit vector in the direction of observation, and L is the length over which the electron interacts with the undulator. It is important to note that ω_s in Eq. (12) refers to the radian frequency of the scattered radiation (in the x-ray region), which is to be distinguished from the frequency of the electromagnetic undulator, denoted by ω_0 in Eqs. (6)-(8). Expressing the unit vector \hat{n} in terms of the polar (θ) and azimuthal (ϕ) angles,

$$\hat{n} = \hat{e}_z \cos\theta + (\hat{e}_y \sin\phi + \hat{e}_x \cos\phi) \sin\theta,$$

the distribution of the scattered radiation for $\theta \lesssim \frac{1}{\gamma}$ is given by

$$\frac{d^2 \epsilon_s}{d\Omega_s d\omega_s} \approx \frac{1}{c} \left[\frac{e\omega_0 L K \gamma}{\pi c (1 + \gamma^2 \theta^2)} \right]^2 \left[1 - \frac{4\gamma^2 \theta^2 \cos^2 \phi}{(1 + \gamma^2 \theta^2)^2} \right] \left(\frac{\sin x}{x} \right)^2, \quad (13a)$$

where

$$x \equiv \frac{\omega_0 L}{c} (1 + \beta_z) \left[\frac{\omega_s (1 - \beta_z \cos\theta)}{\omega_0 (1 + \beta_z)} - 1 \right]. \quad (13b)$$

From Eqs. (13) we find that for long interaction lengths ($L\omega_0/c \gg 1$) the scattered radiation has a peak centered at

$$\omega_s = \frac{\omega_0 (1 + \beta_z)}{(1 - \beta_z \cos\theta)},$$

$$\approx \frac{4\gamma^2 \omega_0}{1 + \gamma^2 \theta^2}. \quad (13c)$$

It must be noted that the forward scattered wavelength predicted by Eq. (13c) is half of that given by Eq. (2). This is well-known and is due to the traveling-wave nature of the electromagnetic undulator considered in this Section.

It is important to note that the frequency distribution given by Eq. (13) pertains to a single electron. The determination of the actual frequency distribution, in general, presents a complex problem. The factor $(\sin x/x)^2$ in Eq. (13a) indicates a line width on the order of $\lambda_0/2L$ about the central frequency (13c). For long interaction lengths, however, a number of other mechanisms limit the line width. Besides the damping due to the emission of radiation itself, there are several other causes which broaden a line. These include Doppler broadening, collisional broadening, and radiative widths induced by the high power microwaves inside the resonator cavity.

It is useful to express the power emitted as x-ray radiation, Eq. (11), in terms of the power in the electromagnetic pump rather than the undulator parameter K . To do so, we assume the fundamental Gaussian (resonator) mode is proportional to $\exp(-r^2/\sigma^2)$ where σ is the spot-size. It is simple to show that the undulator power and the undulator parameter K are related via

$$P_u = \left(\frac{m\omega_0 K}{4e} \right)^2 c^3 \sigma^2, \quad (14)$$

whence the total power (in x-rays) of an electron beam of current I_b emitted over a length L of interaction is expressible as

$$P_{x\text{-ray}} = \frac{64 |e|^3 \gamma^2 I_b L}{3 \sigma^2 \beta_z^2 m^2 c^5} P_u, \quad (15)$$

where use has been made of Eqs. (11) and (14). For applications it is necessary to refine this formula in two respects. First, in order to take into account the variation of the spot-size of the undulator field inside the resonator, we assume the waist to be at the center of cavity, $z=0$. From elementary diffraction theory, we have

$$\sigma(z) = \sigma_0 (1 + z^2/z_R^2)^{1/2}, \quad (16)$$

where σ_0 is the waist and $z_R = \pi\sigma_0^2/\lambda_0$ is the Rayleigh range corresponding to microwaves of wavelength λ_0 . Substituting Eq. (16) into Eq. (15) and averaging over the interaction length L , one obtains

$$\langle P_{x\text{-ray}} \rangle = \frac{32\pi |e|^3 I_b P_u}{3\beta_z m^2 c^5 \lambda_s} \tan^{-1}(L/2z_R), \quad (17)$$

where λ_s is wavelength of the x-rays.

A further refinement pertains to the angular distribution of the x-rays. From Eq. (13a) the power radiated per unit solid angle (in terms of the electrons' time) is given by

$$\frac{dP_{x\text{-ray}}}{d\Omega_s} \approx \frac{2}{\pi} \frac{e^2}{c} |\dot{\beta}|^2 \frac{1}{(1+\gamma^2\theta^2)^3} \left[1 - \frac{4\gamma^2\theta^2 \cos^2\phi}{(1+\gamma^2\theta^2)^2} \right].$$

Integrating over the cone of semi-angle $1/\gamma$ around the forward direction, Eq. (17) is modified to

$$\langle P_{x\text{-ray}} \rangle = \frac{25\pi |e|^3 I_b P_u}{3\beta_z m^2 c^5 \lambda_s} \tan^{-1}(L/2z_R),$$

or, in practical units.

$$\langle P_{\text{x-ray}} \rangle [\text{W}] = 0.045 \frac{I_b [\text{A}] P_u [\text{MW}]}{\lambda_s [\text{\AA}]} \tan^{-1}(L/2z_R), \quad (18)$$

where the x-ray radiation power is in watts, the electron beam current is in Amperes, the undulator stored power is in megawatts, and the x-ray wavelength is in Ångstroms.

VI. Design Parameters for Electromagnetic Undulator

As a concrete example of a synchrotron radiation source based on the electromagnetic undulator we present a set of design parameters which would be useful for x-ray lithography. There are basically two main components in our proposed device, the electromagnetic pump wave (undulator) and the electron beam. The goal is to have a powerful source of x-rays to be able to expose a commercially interesting number of wafers. Bearing this in mind and noting the scaling of the x-ray-power formula in Eq. (18) we consider each of these components separately.

For the undulator we have examined several sources of radiation. A good candidate is a pulsed CO_2 laser since gigawatt power levels are readily available from such a source. One of the problems, though, with using such high power levels is the difficulty in designing beam-line optical elements that can operate at high powers.

Our present choice for the undulator is the quasi-optical gyrotron.¹³ Quasi-optical gyrotrons employ an open resonator cavity containing a gyrating electron beam which propagates perpendicular to the resonator axis. Among the attractive features of this source are high cw operating powers and high efficiency. Quasi-optical gyrotrons are routinely and reliably operated at the Naval Research Laboratory.¹⁴ A schematic of the NRL quasi-optical gyrotron is shown in Fig. 2.

The other major component of the x-ray source is the electron beam. With the use of a short-wavelength electromagnetic undulator, we require moderately energetic electron beams at high average current levels. For electron beam energies of interest ($\lesssim 1/2$ GeV) race-track microtrons may be appropriate. Typically, microtrons are limited to very low currents ($\lesssim 1$ mA), and the linacs that are suitable are fairly expensive. Storage rings appear to be most suitable for our purposes.¹⁵ A closed vacuum

chamber threads through the components of the storage ring which include the bending magnets and the rf cavity. Electron injection can be below the energy of operation in which case the ring is used to accelerate the particles to their final energy within several minutes. The lifetime of the beam may be several hours depending on the average pressure in the ring.

If we assume the stored (circulating) power in the quasi-optical cavity is 1/4 GW, using a 1/4 GeV, 1/2 A (average current) storage ring, from Eq. (18) we find that the power emitted as x-ray radiation is about 3/4 W. From Eq. (13c) we find that if the x-rays are centered at about 12 \AA then the undulator (that is, the microwave radiation in the quasi-optical resonator) has a wavelength λ_0 of about 1.2 mm, which should be readily available with current quasi-optical technology. In making use of Eq. (18) we have assumed that the intramirror separation L in the quasi-optical cavity is much larger than the Rayleigh range z_R of the microwaves. This is true provided the waist of the microwaves is on the order of or less than several centimeters and L is on the order of 1 meter or longer. It is important to note that for $L/z_R \gg 1$, $\tan^{-1}(L/2z_R) \rightarrow \pi/2$ and the power formula in Eq. (18) is then independent of the cavity dimensions, the microwave spot-size and wavelength, and the electron beam energy. However, the latter two parameters determine the required x-ray wavelength, which is constrained by the composition of the resist material.

If we consider using gas breakdown instead of the Bragg reflector to stop microwave leakage through the mirror orifice, then for this configuration the electric field of the microwaves passing through the orifice in the right-hand cavity mirror exceeds the breakdown field of a typical gas at 20 torr. At this pressure, x-ray absorption is negligible, but the plasma density exceeds the microwave frequency and may therefore completely eliminate the loss of microwaves from the cavity.

VII. Comparison of X-Ray Sources for Lithography

In order to put the expected performance of the electromagnetic undulator x-ray source in perspective, we now briefly compare such a device with a conventional, bending-magnet source, such as a storage ring.

We assume the silicon wafer diameter is 5" and divided into chips of area $A_C = 3 \times 3 \text{ cm}^2$. When such a wafer is covered with a high-quality resist such as PMMA (resist sensitivity $\approx 1 \text{ J/cm}^2$) and placed at about 8.5 m from the source, we find that with the design parameters of Sec. VI the chip exposure time T_E is 12.3 sec. The throughput T of the lithography process, in terms of wafers/hr, can then be estimated from¹⁶

$$T = \frac{3600}{T_{L/U} + T_G + \frac{A_W}{A_C} \left(T_S + T_A + \frac{\sqrt{A_C}}{V} + T_E \right)},$$

where

	Aggressive	Very Aggressive
$T_{L/U}$ = wafer load/unload time, (sec),	20	12
T_G = global alignment time, (sec),	6	3
T_S = stage acceleration and settle time, (sec),	1/5	1/10
T_A = chip alignment time, (sec),	1/2	1/5
V = stage velocity, (cm/sec),	1/2	10

and A_W is the area of the wafer.

The columns on the right of the table indicate typical values for an aggressive and for a very aggressive stepper used in exposing the chips on a wafer.

Using an aggressive stepper, the wafer throughput is found to be 12 wafers/hr. With a more sensitive resist such as PBS (polybutene- ℓ -sulfone; resist sensitivity $\leq 100 \text{ mJ/cm}^2$) the throughput rises to 26 wafers/hr, which compares favorably with plasma and with storage ring throughputs. It is of interest to note that the demands on the quasi-optical gyrotron and the electron beam can be significantly reduced by using a very aggressive stepper. For example, a very modest gyrotron (50 MW) and electron beam (100 mA, 1/4 GeV), used in conjunction with PBS and a very aggressive stepper, have a throughput of 8 wafers/hr.

VIII. Conclusion

In this report we propose a novel application of an electromagnetic undulator; namely, as an x-ray source for lithography in the fabrication of high-density integrated circuits. The preliminary conclusion of this work is that it may very well be possible to design such a compact source of x-rays with a commercially-attractive throughput. A significant attribute of this system is that its throughput can be substantially enhanced should resists sensitive to shorter wavelength x-rays be available. In such a case it is necessary to adjust appropriately either the microwave wavelength in the quasi-optical maser or the electron beam energy.

In closing, we mention several problem areas requiring further investigation:

- (i) Heat loading of the resonator mirrors in the quasi-optical cavity.
- ii) Effect of the transverse distribution of the undulator field on electron motion and the generated x-rays.
- iii) Effect of finite electron-beam emittance on x-ray emission.
- iv) System design and cost for commercial applications.

Acknowledgment

The authors have greatly benefitted from technical discussions with Dr. D. J. Nagel, Dr. A. Fliflet and Dr. V. L. Jacobs. This work was supported in part by the Office of Naval Research.

References

1. Report of the Third Workshop Program for X-ray Lithography Development, Nov 17-18, 1986, Edited by J. B. Godel, W. Marcuse and G. P. Williams, Brookhaven National Laboratory Report 52046.
2. In preparing this and the following Section, we have borrowed heavily from a series of articles by Dr. D. J. Nagel and co-workers. The collection is entitled "X-ray Lithography Research: A Collection of NRL Contributions", Edited by R. R. Whitlock, Naval Research Laboratory Memorandum Report 5731 (1987).
3. D. J. Nagel, M. C. Peckerar, R. R. Whitlock, J. R. Greig, and R. E. Pechacek, *Electron. Lett.* 14, 781 (1978).
4. H. Winick and A. Bienenstock, *Phys. Today* 36, 49 (1983).
5. K. Halbach, *Nucl. Instr. and Meth.* 169, 1 (1980).
6. K. Halbach, J. Chin, E. Hoyer, H. Winick, R. Cronin, J. Yang, and Y. Zambre, *IEEE Trans. Nucl. Sci.* NS-28, 3136 (1981).
7. L. D. Landau and E. M. Lifshitz, *The Classical Theory of Fields* (Pergamon, New York, 1975) Section 73.
8. V. L. Bratman, G. G. Denisov, N. S. Ginzburg and M. I. Petelin, *IEEE J. Quantum Electron.* QE-19, 282 (1983).
9. A. D. MacDonald, *Microwave Breakdown in Gases*, (Wiley, New York, 1966).
10. F. Mako, J. A. Pasour, C. W. Roberson, R. Lucey, *Rev. Sci. Instrum.* 55, 712 (1984).
11. In Ref. 7, Section 73.
12. In Ref. 7, Section 77.
13. P. Sprangle, J. L. Vomvoridis, and W. M. Manheimer, *Phys. Rev. A* 23, 3127 (1981).
14. T. A. Hargreaves, K. J. Kim, J. H. McAdoo, S. Y. Park, R. D. Seelers, and M. E. Read, *Int. J. Electronics* 57, 977 (1984). Figure 2 was made available courtesy of Dr. A. Fliflet.
15. S. Penner (private correspondence).
16. A. D. Wilson, *Solid State Technology* 29, 249 (1986).




Fig. 1 Schematic top-view of an electron ring (thick line) interacting with the electromagnetic-undulator field inside a quasi-optical resonator cavity bounded by mirrors M. The x-ray radiation is confined to a cone of half-angle $1/\gamma$, γ being the electron beam relativistic factor. L is the interaction length. The function of the Bragg reflector is to reduce the loss of microwave power through the orifice in the right-hand mirror. It may be possible to replace the quasi-optical gyrotron with a CO_2 laser.




Fig. 2 Schematic of the quasi-optical gyrotron. The electron beam propagates along the magnetic field (~ 5 T) which is directed transverse to the axis of the resonator. Extremely high circulating power levels (~ 100 MWs) can be achieved at short wavelengths (~ 1 mm) with this configuration. The opening in the mirror allows for out-coupled radiation.

DISTRIBUTION LIST*

Naval Research Laboratory
4555 Overlook Avenue, S.W.
Washington, DC 20375-5000

Attn: Code 1000 - Commanding Officer, CAPT W. G. Clautice
1001 - Dr. T. Coffey
1005 - Head, Office of Management & Admin.
1005.1-Deputy Head, Office of Management & Admin.
1005.6-Head, Directives Staff
1200 - CAPT M. A. Howard
1201 - Deputy Head, Command Support Division
1220 - Mr. M. Ferguson
2000 - Director of Technical Services
2604 - NRL Historian
4000 - Dr. W. R. Ellis
0124 - ONR
4600 - Dr. D. Nagel
4603 - Dr. W. W. Zachary
4700 - Dr. S. Ossakow (26 copies)
4700.1-Dr A. W. Ali
4790 - Dr. P. Sprangle
4710 - Dr. C. A. Kapetanakos
4710 - Dr. J. Mathew
4730 - Dr. R. Elton
4740 - Dr. W. M. Manheimer
4740 - Dr. W. Black
4740 - Dr. A. W. Fliflet
4740 - Dr. S. Gold
4740 - Dr. D. L. Hardesty
4740 - Dr. A. K. Kinkead
4740 - Dr. M. Rhinewine
4770 - Dr. G. Cooperstein
4790 - Dr. C. M. Tang
4790 - Dr. G. Joyce
4790 - Dr. M. Lampe
4790 - Dr. Y. Y. Lau
4790 - Dr. A. Ting
4790 - Dr. E. Esarey
4790A- B. Pitcher (copies)
5700 - Dr. L. A. Cosby
5745 - Dr. J. Condon
6840 - Dr. S. Y. Ahn
6840 - Dr. A. Ganguly
6840 - Dr. R. K. Parker
6843 - Dr. R. H. Jackson
6843 - Dr. N. R. Vanderplaats
6843 - Dr. C. M. Armstrong
6875 - Dr. R. Wagner
2628 - Documents (22 copies)
2634 - D. Wilbanks

* Every name listed on distribution gets one copy except for those where extra copies are noted.

Dr. R. E. Aamodt
Lodestar Research Corp.
2400 Central Ave., P-5
Boulder, CO 80306-4545

Dr. J. Adamski
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. H. Agravante
TRW, Inc.
One Space Park
Redondo Beach, CA 90278 / R1-2020

Prof. I. Alexeff
University of Tennessee
Dept. of Electrical Engr.
Knoxville, TN 37916

Dr. L. Altgilbers
3805 Jamestown
Huntsville, AL 35810

Dr. A. Amir
Quantum Inst. and Dept. of Physics
University of California
Santa Barbara, CA 93106

Dr. Bruce Anderson
Air Force Weapons Laboratory
Kirtland AFB
Albuquerque, NM 87117

Dr. Antonio Anselmo
VARIAN
MS K-416
611 Hanson Way
Palo Alto, CA 94303

Dr. T. M. Antonsen
University of Maryland
College Park, MD 20742

Dr. Tony Armstrong
Science Applications Intl. Corp.
P.O. Box 2351
La Jolla, CA 92038

Dr. Joseph Ashkenazy
M.I.T.
Research Lab. of Electronics
Room 36-219
Cambridge, MA 02139

Assistant Secretary of the
Air Force (RD&L)
Room 4E856, The Pentagon
Washington, D.C. 20330

Dr. W. P. Ballard
Sandia National Laboratories
ORG. 1231, P.O. Box 5800
Albuquerque, NM 87185

Dr. W. A. Barletta
Lawrence Livermore National Lab.
P. O. Box 808
Livermore, CA 94550

Dr. John J. Barnard
Lawrence Livermore Nat. Lab.
P. O. Box 808, L-626
Livermore, CA 94550

Dr. L. R. Barnett
3053 Merrill Eng. Bldg.
University of Utah
Salt Lake City, UT 84112

Project Manager
Ground Based Laser Project Office
ATTN: CSSD-H-F
White Sands Miss. Range, NM 88002-1198

CDR George Bates, PMS 405-300
Naval Sea Systems Command
Department of the Navy
Washington, DC 20362

Dr. W. Becker
Univ. of New Mexico
Institute for Mod. Opt.
Albuquerque, NM 87131

Dr. Robert Behringer
9342 Balcon Ave.
Northridge, CA 91325

Dr. G. Bekefi (5 copies)
Mass. Institute of Tech.
Room 36-213
Cambridge, MA 02139

Dr. S. Bender
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. J. Benford
Physics International
2700 Merced Street
San Leandro, CA 94577

Dr. Herbert S. Bennett
National Bureau of Standards
Bldg. 225, Rm. A352
Washington, DC 20234

Dr. Steven V. Benson
Physics Department
Stanford, CA 94305

Dr. I. B. Bernstein (10 copies)
Mason Laboratory
Yale University
400 Temple Street
New Haven, CT 06520

Dr. Vladislav Bevc
Synergy Research Institute
P.O. Box 561
San Ramon, CA 94583

Dr. Amitava Bhattacharjee
Columbia University
S. W. Mudd 210
Dept. of Applied Phys.
New York, NY 10027

Dr. Anup Bhowmik
Rockwell International/Rocketdyne Div.
6633 Canoga Avenue, FA-40
Canoga Park, CA 91304

Dr. K. Jim Bickford
RDA
2301F Yale Blvd., S.E.
Albuquerque, NM 87106

Dr. D. L. Bix
Lawrence Livermore National Laboratory
P. O. Box 808, L-627
Livermore, CA 94550

Dr. J. Bisognano
CEBAF
Newport News, VA 23606

Dr. Steve Bitterly
Rockwell International/Rocketdyne Div.
6633 Canoga Avenue, FA-40
Canoga Park, CA 91304

Dr. H. Boehmer
TRW DSSG
One Space Park
Redondo Beach, CA 90278

Dr. John Booske
Energy Research Bldg.
University of Maryland
College Park, MD 20742

Dr. P. Bosco
KMS Fusion Inc.
Ann Arbor, MI 48106

Dr. B. Boswell
Lab for Laser Energetics
University of Rochester
250 E. River Road
Rochester, NY 14623

Dr. G. Bourianoff
1901 Rutland Drive
Austin, TX 78758

Dr. J. K. Boyd
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. E. Bozoki
NSLS
Brookhaven National Lab.
Upton, NY 11973

Dr. H. Brandt
Department of the Army
Harry Diamond Laboratory
2800 Powder Mill Rd.
Adelphi, MD 20783

Dr. R. Briggs
Lawrence Livermore National Lab.
MS-626
P.O. Box 808
Livermore, CA 94550

Dr. H. L. Buchanan
Defense Advanced Research Projects Agency
1400 Wilson Blvd.
Arlington, VA 22209

Dr. D. L. Bullock
Optical Sciences Department
TRW Space and Technology Group
Redondo Beach, CA 90278

Dr. Fred Burskirk
Physics Department
Naval Postgraduate School
Monterey, CA 93940

Dr. Ken Busby
Mission Research Corporation
1720 Randolph Road, S.E.
Albuquerque, NM 87106

Dr. K. J. Button
Francis Bitter Natl. Magnet Lab.
Box 72, M. I. T. Branch
Cambridge, MA 02139-0901

Dr. J. A. Byers
Lawrence Livermore National Lab.
Attn: (L-630)
P. O. Box 808
Livermore, CA 94550

Dr. Malcolm Caplan
4219 Garland Drive
Fremont, CA 94536

Dr. Maria Caponi
TRW, Building R-1, Room 1184
One Space Park
Redondo Beach, CA 90278

Dr. B. Carlsten
Los Alamos National Laboratory
MS-H827 AT-7
P. O. Box 1663
Los Alamos, NM 87545

Mr. A. Carmichael
GBL Project Office
ATTN: CSSD-H-F
White Sands Miss. Range, NM 88002-1198

Dr. David Cartwright
Los Alamos National Laboratory
E527
Los Alamos, NM 87545

Dr. J. Cary
University of Colorado
Box 391
Boulder, CO 80309

Prof. William Case
Dept. of Physics
Grinnell College
Grinnell, IA 50112

Mr. Charles Cason
U. S. Army Strategic Def. Command
ATTN: Code CSSD-H-D
P. O. Box 1500
Huntsville, AL 35807-3801

Dr. S. Caspi
Lawrence Berkeley Lab.
Bldg. 46
Berkeley, CA 94720

Dr. R. Center
Spectra Tech., Inc.
2755 Northup Way
Bellevue, WA 98004

Dr. K. C. Chan
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. V. S. Chan
GA Technologies
P.O. Box 85608
San Diego, CA 92138

Dr. Will E. Chandler
Pacific Missile Test Center
Code 3123
Point Muga, CA 93042-5000

Dr. J. Chase
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. S. Chattopadhyay
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Prof. Frank Chen
School of Eng. & Applied Sciences
Univ. of Calif. at Los Angeles
7731 K Boelter Hall
Los Angeles, CA 90024

Dr. S. Chen
MIT Plasma Fusion Center
NW16-176
Cambridge, MA 01890

Dr. Yu-Juan Chen
L-626
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. D. P. Chernin
Science Applications Intl. Corp.
1720 Goodridge Drive
McLean, VA 22102

Dr. Art Chester
Hughes E51
Mail Stop A269
P.O. Box 902
El Segundo, CA 90245

Dr. S. C. Chiu
GA Technologies Inc.
P.O. Box 85608
San Diego, CA 92138

Dr. J. Christiansen
Hughes Aircraft Co.
Electron Dynamics Division
3100 West Lomita Blvd.
Torrance, CA 90509

Dr. T. L. Churchill
Spectra Technology, Inc.
2755 Northrup Way
Bellevue, WA 98004

Major Bart Clare
USASDC
P. O. BOX 15280
Arlington, VA 22215-0500

Dr. Melville Clark
8 Richard Road
Wayland, MA 01778

Dr. Alan J. Cole
TRW
One Space Park
Redondo Beach, CA 90278

Dr. William Colson
Berkeley Research Assoc.
P. O. Box 241
Berkeley, CA 94701

Dr. Richard Cooper
Los Alamos National Scientific
Laboratory
P.O. Box 1663
Los Alamos, NM 87545

Dr. M. Cornacchia
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. R. A. Cover
Rockwell International/Rocketdyne Div.
6633 Canoga Avenue, FA-38
Canoga Park, CA 91304

Dr. D. Crandall
ER-55, GTN
Department of Energy
Washington, DC 20545

Mr. Thomas G. Crow
Ground Based Laser Project Office
ATTN: CSSD-H-FF
White Sands Missile Range, NM 88002-1198

Dr. Bruce Danly
MIT
NW16-174
Cambridge, MA 02139

Dr. R. Davidson (5 copies)
Plasma Fusion Center
Mass. Institute of Tech.
Cambridge, MA 02139

Dr. John Dawson (4 copies)
Physics Department
University of California
Los Angeles, CA 90024

Dr. David A. G. Deacon
Deacon Research
Suite 203
900 Welch Road
Palo Alto, CA 94304

Dr. Philip Debenham
Center for Radiation Research
National Bureau of Standards
Gaithersburg, MD 20899

Dr. T. L. Deloney
Dept. of Electrical Engineering
Stanford University
Stanford, CA 94305

Deputy Under Secretary of
Defense for R&AT
Room 3E114, The Pentagon
Washington, D.C. 20301

Prof. P. Diament
Dept. of Electrical Engineering
Columbia University
New York, NY 10027

Dr. N. Dionne
Raytheon Company
Microwave Power Tube Division
Foundry Avenue
Waltham, MA 02154

Director
National Security Agency
Fort Meade, MD 20755
ATTN: Dr. Richard Foss, A42
Dr. Thomas Handel, A243
Dr. Robert Madden, R/SA

Director of Research (2 copies)
U. S. Naval Academy
Annapolis, MD 21402

Dr. T. Doering
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. Gunter Dohler
Northrop Corporation
Defense Systems Division
600 Hicks Road
Rolling Meadows, IL 60008

Dr. Franklin Dolezal
Hughes Research Laboratory
3011 Malibu Canyon Rd.
Malibu, CA 90265

Dr. A. Drobot
Science Applications Intl. Corp.
1710 Goodridge Road
McLean, VA 22102

Dr. Dwight Duston
SDIO/IST
The Pentagon
Washington, DC 20301-7100

Dr. Joseph Eberly
Physics Department
Univ. of Rochester
Rochester, NY 14627

Dr. Jim Eckstein
VARIAN
MS K-214
611 Hanson Way
Palo Alto, CA 94303

Dr. J. A. Edighoffer
TRW, Bldg. R-1
One Space Park
Redondo Beach, CA 90278

Dr. O. C. Eldridge
University of Wisconsin
1500 Johnson Drive
Madison, WI 53706

Dr. Luis R. Elias (2 copies)
Creol-FEL Research Pavillion
Suite 400
12424 Research Parkway
Orlando, FL 32826

Dr. C. James Elliott
X1-Division, M.S. 531
Los Alamos Natl. Scientific Lab.
P. O. Box 1663
Los Alamos, NM 87545

Dr. A. England
Oak Ridge National Laboratory
P.O. Box Y
Mail Stop 3
Building 9201-2
Oak Ridge, TN 37830

Dr. William M. Fairbank
Phys. Dept. & High Energy
Phys. Laboratory
Stanford University
Stanford, CA 94305

Dr. Anne-Marie Fauchet
Brookhaven National Laboratories
Associated Universities, Inc.
Upton, L.I., NY 11973

Dr. J. Feinstein
Dept. of Electrical Engineering
Stanford University
Stanford, CA 94305

Dr. Frank S. Felber
JAYCOR
11011 Torreyana Road
San Diego, CA 92121

Dr. D. Feldman
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. Renee B. Feldman
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. L. A. Ferrari
Queens College
Department of Physics
Flushing, NY 11367

Dr. C. Finfgeld
ER-542, GTN
Department of Energy
Washington, DC 20545

Dr. A. S. Fisher
Dept. of Electrical Engineering
Stanford University
Stanford, CA 94305

Dr. R. G. Fleig
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. H. Fleischmann
Cornell University
Ithaca, NY 14850

Dr. E. Fontana
Dept. of Electrical Engineering
Stanford University
Stanford, CA 94305

Dr. Norval Fortson
University of Washington
Department of Physics
Seattle, WA 98195

Dr. Roger A. Freedman
Quantum Institute
University of California
Santa Barbara, CA 93106

Dr. Lazar Friedland
Dept. of Eng. & Appl. Science
Yale University
New Haven, CT 06520

Dr. Walter Friez
Air Force Avionics Laboratory
AFWAL/AADM-1
Wright/Paterson AFB, OH 45433

Dr. Shing F. Fung
Code 696
GSFC
NASA
Greenbelt, MD 20771

Dr. R. Gajewski
Div. of Advanced Energy Projects
U. S. Dept of Energy
Washington, DC 20545

Dr. H. E. Gallagher
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. James J. Gallagher
Georgia Tech. EES-EOD
Baker Building
Atlanta, GA 30332

Dr. W. J. Gallagher
Boeing Aerospace Co.
P. O. Box 3999
Seattle, WA 98124

Dr. J. Gallardo
Quantum Institute
University of California
Santa Barbara, CA 93106

Dr. E. P. Garate
15482 Pasedena Avenue, #120
Tustin, CA 92680

Dr. A. Garren
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. Richard L. Garwin
IBM, T. J. Watson Research Ctr.
P.O. Box 218
Yorktown Heights, NY 10598

Dr. J. Gea-Banacloche
Dept. of Physics & Astronomy
Univ. of New Mexico
800 Yale Blvd. NE
Albuquerque, NM 87131

DR. R. I. Gellert
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. T. V. George
ER-531, GTN
Department of Energy
Washington, DC 20545

Dr. Edward T. Gerry, President
W. J. Schafer Associates, Inc.
1901 N. Fort Myer Drive
Arlington, VA 22209

Dr. Roy Glauber
Physics Department
Harvard University
Cambridge, MA 02138

Dr. B. B. Godfrey
Mission Research Corporation
1720 Randolph Road, S. E.
Albuquerque, NM 87106

Dr. John C. Goldstein, X-1
Los Alamos Natl. Scientific Lab.
P.O. Box 1663
Los Alamos, NM 87545

Dr. Yee Fu Goul
Plasma Physics Lab., Rm 102
S.W. Mudd
Columbia University
New York, NY 10027

Dr. C. Grabbe
Department of Physics
University of Iowa
Iowa City, Iowa 52242

Dr. V. L. Granatstein
Dept. of Electrical Engineering
University of Maryland
College Park, MD 20742

Dr. D. D. Gregoire
Quantum Institute and Dept. of Physics
University of California
Santa Barbara, CA 93106

Dr. Y. Greenzweig
Quantum Inst. and Dept. of Physics
University of California
Santa Barbara, CA 93106

Dr. Morgan K. Grover
R&D Associates
P. O. Box 9695
4640 Admiralty Highway
Marina Del Rey, CA 90291

Dr. A. H. Guenter
Air Force Weapons Laboratory
Kirtland AFB, NM 87117

Lt Col Richard Gullickson
Strategic Def. Initiative Org.
OSD/SDIO/DEO
Washington, DC 20301-7100

Dr. K. Das Gupta
Physics Department
Texas Tech University
Lubbock, TX 79409

Dr. Benjamin Haberman
Associate Director, OSTP
Room 476, Old Exe. Office Bldg.
Washington, D.C. 20506

Dr. R. F. Hagland, Jr.
Director, Vanderbilt University
Nashville, TN 37235

Dr. K. Halbach
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. P. Hammerling
La Jolla Institute
P.O. Box 1434
La Jolla, CA 92038

Dr. John Hammond
Director, Directed Energy Office
SDIO
The Pentagon, T-DE Rm. 1E180
Washington, DC 20301-7100

Dr. R. Harvey
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Prof. Herman A Haus
Mass. Institute of Technology
Rm. 36-351
Cambridge, MA 02139

Dr. S. Hawkins
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. Carl Hess
MS B-118
VARIAN
611 Hanson Way
Palo Alto, CA 94303

Dr. K. Hizanidis
Physics Dept.
University of Maryland
College Park, MD 20742

Dr. A. H. Ho
Dept. of Electrical Engineering
Stanford University
Stanford, CA 94305

Dr. Darwin Ho
L-477
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. J. Hoffman
Sandia National Laboratories
ORG. 1231, P.O. Box 5800
Albuquerque, NM 87185

Dr. R. Hofland
Aerospace Corp.
P. O. Box 92957
Los Angeles, CA 90009

Dr. Fred Hopf
Optical Sciences Building, Room 602
University of Arizona
Tucson, AZ 85721

Dr. Heinrich Hora
Iowa Laser Facility
University of Iowa
Iowa City, Iowa

Dr. H. Hsuan
Princeton Plasma Physics Lab.
James Forrestal Campus
P.O. Box 451
Princeton, NJ 08544

Dr. James Hu
Quantum Inst. and Phys. Dept.
University of California
Santa Barbara, CA 93106

Dr. Benjamin Hubberman
Associate Director, OSTP
Rm. 476, Old Executive Office Bldg.
Washington, DC 20506

Dr. J. Hyman
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. H. Ishizuka
University of California
Department of Physics
Irvine, CA 92717

Prof. V. Jaccarino
Univ. of Calif. at Santa Barbara
Santa Barbara, CA 93106

Dr. A. Jackson
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. S. F. Jacobs
Optical Sciences Center
University of Arizona
Tucson, AZ 85721

Dr. Pravin C. Jain
Asst. for Communications Tech.
Defense Communications Agency
Washington, DC 20305

Dr. E. T. Jaynes
Physics Department
Washington University
St. Louis, MO 63130

Dr. B. Carol Johnson
Ctr. for Radiation Research
National Bureau of Standards
Gaithersburg, MD 20899

Dr. Bernadette Johnson
Lincoln Laboratory
Lexington, MA 02173

Dr. G. L. Johnston
NW 16-232
Mass. Institute of Tech.
Cambridge, MA 02139

Dr. Shayne Johnston
Physics Department
Jackson State University
Jackson, MS 39217

Dr. R. A. Jong
Lawrence Livermore National Laboratory
P. O. Box 808/L626
Livermore, CA 94550

Dr. Howard Jory (3 copies)
Varian Associates, Bldg. 1
611 Hansen Way
Palo Alto, CA 94303

Dr. C. Joshi
University of California
Los Angeles, CA 90024

Dr. Paul Kennedy
Rockwell International/Rocketdyne Div.
6633 Canoga Avenue, FA-40
Canoga Park, CA 91304

Dr. R. Kennedy
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. K. J. Kim, MS-101
Lawrence Berkeley Lab.
Rm. 223, B-80
Berkeley, CA 94720

Dr. I. Kimel
Creol-FEL Research Pavillion
Suite 400
12424 Research Parkway
Orlando, FL 32826

Dr. Brian Kincaid
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. A. Kolb
Maxwell Laboratories, Inc.
8835 Balboa Avenue
San Diego, CA 92123

Dr. Eugene Kopf
Principal Deputy Assistant
Secretary of the Air Force (RD&L)
Room 4E964, The Pentagon
Washington, D.C. 20330

Dr. P. Korn
Maxwell Laboratories, Inc.
8835 Balboa Avenue
San Diego, CA 92123

Dr. S. Krinsky
Nat. Synchrotron Light Source
Brookhaven National Laboratory
Upton, NY 11973

Prof. N. M. Kroll
Department of Physics
B-019, UCSD
La Jolla, CA 92093

Dr. Thomas Kwan
Los Alamos National Scientific
Laboratory, MS608
P. O. Box 1663
Los Alamos, NM 87545

Dr. Jean Labacqz
Stanford University
SLAC
Stanford, CA 94305

Dr. Ross H. Labbe
Rockwell International/Rocketdyne Div.
6633 Canoga Avenue, FA-40
Canoga Park, CA 91304

Dr. Willis Lamb
Optical Sciences Center
University of Arizona
Tucson, AZ 87521

Dr. H. Lancaster
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. D. J. Larson
Department of Physics
University of Virginia
Charlottesville, VA 22901

Dr. J. LaSala
Physics Dept.
U. S. M. A.
West Point, NY 10996

Dr. Bernard Laskowski
M.S. 230-3
NASA-Ames
Moffett Field, CA 94305

r. Michael Lavan
U.S. Army Strategic Def. Command
ATTN: Code CSSD-H-D
P. O. Box 1500
Huntsville, AL 35807-3801

Dr. Ray Leadabrand
SRI International
333 Ravenswood Avenue
Menlo Park, CA 94025

Dr. Kotik K. Lee
Perkin-Elmer
Optical Group
100 Wooster Heights Road
Danbury, CT 06810

Dr. K. Lee
Los Alamos Nat. Scientific Lab.
Attn: X-1 MS-E531
P. O. Box 1663
Los Alamos, NM 87545

Dr. Barry Leven
NISC/Code 20
4301 Suitland Road
Washington, D.C. 20390

Dr. B. Levush
Dept. of Physics & Astronomy
University of Maryland
College Park, MD 20742

Dr. Lewis Licht
Department of Physics
Box 4348
U. of Illinois at Chicago Cir.
Chicago, IL 60680

Dr. M. A. Lieberman
Dept. EECS
Univ. of Cal. at Berkeley
Berkeley, CA 94720

Dr. Anthony T. Lin
Dept. of Physics
University of California
Los Angeles, CA 90024

r. Chuan S. Liu
Dept. of Physics & Astronomy
University of Maryland
College Park, MD 20742

r. D. D. Lowenthal
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. A. Luccio
Brookhaven National Laboratory
Accelerator Dept.
Upton, NY 11973

Dr. A. Lumpkin
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. Phil Mace
W. J. Shafer Assoc., Inc.
1901 N. Fort Myer Drive
Arlington, VA 22209

Prof. J.M.J. Madey
117 Physics Bldg.
Duke University
Durham, NC 27706

Dr. R. Mako
205 South Whiting Street
Alexandria, VA 22304

Dr. Joseph Mangano
Science Research Laboratory
1600 Wilson Blvd.
Suite 1200
Arlington, VA 22209

Dr. Siva A. Mani
Science Applications Intl. Corp.
1040 Waltham Street
Lexington, MA 02173-8027

Dr. J. Mark
Lawrence Livermore National Lab.
Attn: L-477
P. O. Box 808
Livermore, CA 94550

Dr. T. C. Marshall
Applied Physics Department
Columbia University
New York, NY 10027

Dr. Xavier K. Maruyama
Dept. of Physics
Naval Postgraduate School
Monterey, CA 93943

Dr. Neville Marzwell
Jet Propulsion Lab.
MS 198-330
4800 Oak Grove Drive
Pasadena, CA 91109

Dr. A. Maschke
TRW
Mail Stop 01-1010
1 Space Park
Redondo Beach CA 90278

r. K. Matsuda
GA Technologies Inc.
P.O. Box 85608
San Diego, CA 92138

Dr. John McAdoo
8560 Cinderbed Road, Suite 700
Newington, VA 22122

Dr. D. B. McDermott
Electrical Engineering Dept.
University of California
Los Angeles, CA 90024

Dr. J. K. McIver
Dept. of Physics & Astronomy
Univ. of New Mexico
800 Yale Blvd. NE
Albuquerque, NM 87131

Dr. C. McKinstrie
Department of Mechanical Engineering
University of Rochester
Rochester, NY 14627

Dr. B. McVey
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. David Merritt
Space & Naval Warfare Command
Attn: PMW 145A
Washington, DC 20363-5100

Dr. John Meson
DARPA
1400 Wilson Boulevard
Arlington, VA 22209

Col Thomas Meyer
SDIO/DEO
The Pentagon, Rm. 1E180
Washington, DC 20301-7100

Dr. F. E. Mills
Fermilab
P.O., Box 500
Batavia, IL 60510

Dr. D. R. Mize
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. Mel Month
Brookhaven National Laboratories
Associated Universities, Inc.
Upton, L.I., NY 11973

Dr. B. N. Moore
Austin Research Assoc.
1901 Rutland Dr.
Austin, TX 78758

Dr. Gerald T. Moore
University of New Mexico
Albuquerque, NM 87131

Dr. Warren Mori
1-130 Knudsen Hall
U.C.L.A.
Los Angeles, CA 90024

Dr. Philip Morton
Stanford Linear Accelerator Center
P.O. Box 4349
Stanford, CA 94305

Dr. Jesper Munch
TRW
One Space Park
Redondo Beach, CA 90278

Dr. James S. Murphy
National Synchrotron Light Source
Brookhaven National Laboratory
Upton, NY 11975

Prof. J. Nation
224 Phillips Hall
School of Elec. Eng.
Cornell University
Ithaca, NY 14850

Dr. R. Neighbours
Physics Department
Naval Postgraduate School
Monterey, CA 93943

Dr. George Neil
TRW
One Space Park
Redondo Beach, CA 90278

Dr. Kelvin Neil
Lawrence Livermore National Lab.
Code L-321, P.O. Box 808
Livermore, CA 94550

Dr. W. M. Nevins
L-639
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. Brian Newnam
MSJ 564
Los Alamos National Scientific Lab.
P.O. Box 1663
Los Alamos, NM 87545

Dr. W. Nexsen
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. Milton L. Noble (2 copies)
General Electric Company
G. E. Electric Park
Syracuse, NY 13201

Dr. K. O'Brien
Div. 1241 SNLA
Albuquerque, NM 87185

Dr. John D. O'Keefe
TRW
One Space Park
Redondo Beach, CA 90278

Dr. T. Orzechowski
L-436
Lawrence Livermore National Lab.
P. O. Box 808
Livermore, CA 94550

Prof. E. Ott (2 copies)
Department of Physics
University of Maryland
College Park, MD 20742

OUSDRE (R&AT)
Room 3D1067, The Pentagon
Washington, D.C. 20301

Dr. A. J. Palmer
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. Robert B. Palmer
Brookhaven National Laboratories
Associated Universities, Inc.
Upton, L.I., NY 11973

Dr. J. Palmer
Hughes Research Laboratory
Malibu, CA 90265

Dr. Richard H. Pantell
Stanford University
Stanford, CA 94305

Dr. Dennis Papadopoulos
Astronomy Department
University of Maryland
College Park, Md. 20742

Dr. P. Parks
GA Technologies
P.O. Box 8560E
San Diego, Ca 92138

Dr. John A. Pasour
Mission Research Laboratory
8560 Cinderbed Road
Suite 700
Newington, VA 22122

Dr. C. K. N. Patel
Bell Laboratories
Murray Hill, NJ 07974

Dr. Richard M. Patrick
AVCO Everett Research Lab., Inc.
2385 Revere Beach Parkway
Everett, MA 02149

Dr. Claudio Pellegrini
Brookhaven National Laboratory
Associated Universities, Inc.
Upton, L.I., NY 11973

Dr. S. Penner
Center for Radiation Research
National Bureau of Standards
Gaithersburg, MD 20899

Dr. J. M. Peterson
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. M. Piestrup
Adelphi Technology
13800 Skyline Blvd. No. 2
Woodside, CA 94062

Dr. Alan Pike
DARPA
1400 Wilson Boulevard
Arlington, VA 22209

Dr. Hersch Pilloff
Code 421
Office of Naval Research
Arlington, VA 22217

Dr. A. L. Pindroh
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. D. J. Pistoiresi
Boeing Aerospace Company
P. O. Box 3999
Seattle, WA 98124-2499

Major E. W. Pogue
SDIO
The Pentagon, T-DE Rm. 1E180
Washington, DC 20301-7100

Dr. Peter Politzer
General Atomic Tech., Rm. 13/260
P. O. Box 85608
San Diego, CA 92138

Major Donald Ponikvar
U. S. Army SDC
P. O. Box 15280
Arlington, VA 22245-0280

Dr. S. E. Poor
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Prof. M. Porkolab
NW 36-213
Mass. Institute of Technology
Cambridge, MA 02139

Dr. R. V. Pound
Physics Department
Harvard University
Cambridge, MA 02138

Mr. J. E. Powell
Sandia National Laboratories
ORG. 1231, P.O. Box 5800
Albuquerque, NM 87185

Dr. Anand Prakash
Ballistic Research Laboratory
Aberdeen Proving Ground, MD 21005

Dr. Mark A. Prelas
Nuclear Engineering
Univ. of Missouri-Columbia
1033 Engineering
Columbia, Missouri 65211

Dr. Donald Prosnitz
Lawrence Livermore National Lab.
Box 5511 L-626
Livermore, CA 94550

Dr. D. C. Quimby
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. Paul Rabinowitz
Xerox Research and Eng. Comp.
P. O. Box 45
Linden, NJ 07036

Dr. G. Ramian
Quantum Institute
University of California
Santa Barbara, CA 93106

Dr. L. L. Reginato
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. M. B. Reid
Dept. of Electrical Engineering
Stanford University
Stanford, CA 94305

Dr. D. A. Reilly
AVCO Everett Research Lab.
Everett, MA 02149

Dr. M. Reiser
University of Maryland
Department of Physics
College Park, MD 20742

Dr. S. Ride
Arms Control
Stanford University
Stanford, CA 94305

Dr. C. W. Roberson
Office of Naval Research
Code 112S
800 N. Quincy Street
Arlington, VA 22217

Dr. B. Robinson
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. K. Robinson
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. D. Rogers
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. Jake Romero
Boeing Aerospace Company
P. O. Box 3999
Seattle, WA 98124-2499

Dr. T. Romesser
TRW, Inc.
One Space Park
Redondo Beach, Ca 90278

Dr. Marshall N. Rosenbluth
Dept. of Physics
B-019
Univ. of Calif., San Diego
LaJolla, CA 92093

Dr. J. B. Rosenzweig
The Inst. for Accelerator Physics
Department of Physics
University of Wisconsin-Madison
Madison, WI 53706

Dr. J. Ross
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. N. Rostoker
Department of Physics
University of California at Irvine
Irvine, CA 92717

Dr. Antonio Sanchez
Lincoln Laboratory
Mass. Institute of Tech.
Room B213
P. O. Box 73
Lexington, MA 02173

Dr. Aldric Saucier
BMD-PO
Ballistic Missile Defense
Program Office
P. O. Box 15280
Arlington, VA 22215

Dr. A. Saxman
Los Alamos National Scientific Lab.
P. O. Box 1663, MSE523
Los Alamos, NM 87545

Dr. J. Scharer
ECE Dept.
Univ. of Wisconsin
Madison, WI 53706

Dr. E. T. Scharlemann
L626
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Prof. S. P. Schlesinger
Dept. of Electrical Engineering
Columbia University
New York, NY 10027

Dr. Howard Schlossberg
AFOSR
Bolling AFB
Washington, D.C. 20332

Dr. George Schmidt
Stevens Institute of Technology
Physics Department
Hoboken, NJ 07030

Dr. M. J. Schmitt
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. Stanley Schneider
Rotodyne Corporation
26628 Fond Du Lac Road
Palos Verdes Peninsula, CA 90274

Dr. M. L. Scott
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. Richard L. Schriever (DP-23)
Director, Office of Inertial Fusion
U. S. Department of Energy
Washington, D.C. 20545

Dr. R. W. Schumacher
Hughes Research Laboratories
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. H. Schwettmann
Phys. Dept. & High Energy
Physics Laboratory
Stanford University
Stanford, CA 94305

Dr. Marlan O. Scully
Dept. of Physics & Astronomy
Univ. of New Mexico
800 Yale Blvd. NE
Albuquerque, NM 87131

Dr. S. B. Segall
KMS Fusion
3941 Research Park Dr.
P.O. Box 1567
Ann Arbor, MI 48106

Dr. Robert Sepucha
DARPA
1400 Wilson Boulevard
Arlington, VA 22209

Prof. P. Serafim
Northeastern University
Boston, MA 02115

Dr. A. M. Sessler
Lawrence Berkeley Laboratory
University of California
1 Cyclotron Road
Berkeley, CA 94720

Dr. W. Sharp
L-626
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. Earl D. Shaw
Bell Laboratories
600 Mountain Avenue
Murray Hill, NJ 07974

Dr. J. P. Sheerim
KMS Fusion
P.O. Box 1567
Ann Arbor, MI 48106

Dr. R. Shefer
Science Research Laboratory
15 Ward Street
Somerville, MA 02143

Dr. R. L. Sheffield
Los Alamos National Laboratory
P.O. Box 1663
Los Alamos, NM 87545

Dr. Shemwall
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. Shen Shey
DARPA/DEO
1400 Wilson Boulevard
Arlington, VA 22209

Dr. D. Shoffstall
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. I. Shokair
SNLA, Org. 1271
Albuquerque, NM 87185

Dr. J. S. Silverstein
Harry Diamond Laboratories
2800 Powder Mill Road.
Adelphi, MD 20783

Dr. Jack Slater
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. Kenneth Smith
Physical Dynamics, Inc.
P.O. Box 556
La Jolla, CA 92038

Dr. Lloyd Smith
Lawrence Berkeley Laboratory
University of California
1 Cyclotron Road
Berkeley, CA 94720

Dr. Stephen J. Smith
JILA
Boulder, CO 80302

Dr. Todd Smith
Hansen Labs
Stanford University
Stanford, CA 94305

Dr. J. Z. Soln (22300)
Harry Diamond Laboratories
2800 Powder Mill Road
Adelphi, MD 20783

Dr. G. Spalek
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Mrs. Alma Spring
DARPA/Administration
1400 Wilson Boulevard
Arlington, VA 22209

SRI/MP Reports Area G037 (2 copies)
ATTN: D. Leitner
333 Ravenswood Avenue
Menlo Park, CA 94025

Dr. W. Stein
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. L. Steinhauer
STI
2755 Northup Way
Bellevue, WA 98004

Dr. Efrem J. Sternbach
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. W. C. Stwalley
Iowa Laser Facility
University of Iowa
Iowa City, Iowa 52242

Dr. R. Sudan
Lab. of Plasma Studies
Cornell University
Ithaca, NY 14850

Dr. P. W. Sumner
Hughes Research Laboratory
3011 Malibu Canyon Road
Malibu, CA 90265

Dr. David F. Sutter
ER 224, GTN
Department of Energy
Washington, D.C. 20545

Dr. Abraham Szoke
ML/L-470
Lawrence Livermore Natl. Lab.
P.O. Box 808
Livermore, CA 94550

Dr. T. Tajima
Institute for Fusion Studies
University of Texas at Austin
Austin, TX 78712

Dr. H. Takeda
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. J. J. Tancredi
Hughes Aircraft Co.
Electron Dynamics Division
3100 West Lomita Blvd.
Torrance, CA 90509

Dr. Milan Tekula
AVCO Everett Research Lab.
2385 Revere Beach Parkway
Everett, MA 02149

Dr. R. Temkin (2 copies)
Mass. Institute of Technology
Plasma Fusion Center
Cambridge, MA 02139

Dr. L. Thode
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. Keith Thomassen, L-637
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. Harold Thompson
TRW, Inc.
R1/2120
One Space Park
Redondo Beach, Ca 90278

Dr. Norman H. Tolk
Physics Department
Vanderbilt University
Nashville, TN 37240

Dr. Kang Tsang
Science Applications Intl. Corp.
10260 Campus Point Drive
San Diego, CA 92121

Dr. E. Tyson
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. H. S. Uhm
Naval Surface Warfare Center
White Oak Lab.
Silver Spring, MD 20903-5000

Dr. L. Ulstrup
TRW, Inc.
One Space Park
Redondo Beach, Ca 90278

Under Secretary of Defense (R&D)
Office of the Secretary of Defense
Room 3E1006, The Pentagon
Washington, D.C. 20301

Dr. L. Vahala
Physics Dept.
College of William & Mary
Williamsburg, VA 23185

Dr. A. Valla
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. A. Vetter
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. A. A. Vetter
Spectra Technology
2755 Northup Way
Bellevue, WA 98004

Dr. G. Vignola
Brookhaven National Laboratories
Associated Universities, Inc.
Upton, L.I., NY 11973

Dr. S. A. Von Laven
KMS Fusion Inc.
Ann Arbor, MI 48106

Dr. John E. Walsh
Wilder Laboratory
Department of Physics (HB 6127)
Dartmouth College
Hanover NH 03755

Dr. Jiunn-Ming Wang
Brookhaven National Laboratories
Associated Universities, Inc.
Upton, L.I., NY 11973

Dr. T-S. Wang
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. J. F. Ward
Physics Department
1049 Randall
University of Michigan
Ann Arbor, MI 48109

Dr. Roger W. Warren
Los Alamos National Scientific Lab.
P.O. Box 1663
Los Alamos, NM 87545

Dr. J. Watson
Los Alamos National Laboratory
P. O. Box 1663
Los Alamos, NM 87545

Dr. B. Weber
Harry Diamond Laboratories
2800 Powder Mill Road
Adelphi, MD 20783

Dr. J. T. Weir
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Ms. Bettie Wilcox
Lawrence Livermore National Lab.
ATTN: Tech. Info. Dept. L-3
P.O. Box 808
Livermore, CA 94550

Dr. Mark Wilson
National Bureau of Standards
Bldg. 245, Rm. B-119
Gaithersburg, MD 20899

Dr. H. Winick
Stanford Synch. Rad. Lab.
SLAC Bin 69
P.O. Box 44349
Stanford, CA 94550

Dr. J. Workman
Berkeley Research Associates
P.O. Box 241
Berkeley, CA 94701

Dr. Jack Wong (L-71)
Lawrence Livermore National Lab.
P. O. Box 808
Livermore, CA 94550

Dr. Thomas P. Wright
Sandia National Laboratories
ORG. 1231, P.O. Box 5800
Albuquerque, NM 87185

Dr. J. Wurtele
M.I.T.
NW 16-234
Plasma Fusion Center
Cambridge, MA 02139

Dr. Ming Xie
Dept. of Physics
Stanford University
Stanford, CA 94305

Dr. Edward Yadlowsky
High-Tech Research
P. O. Box 3422
Radford, VA 24143

Dr. Yi-Ton Yan
SSC Central Design Group
c/o LBL 90-4040
University of California
1 Cyclotron Road
Berkeley, CA 94720

Dr. A. Yariv
California Institute of Tech.
Pasadena, CA 91125

Dr. J. Yeh
Allied Corporation
31717 La Tienda Dr.
Westlake Village, CA 91362

Dr. A. Yeremian
Boeing Aerospace Company
P.O. Box 3999
Seattle, WA 98124

Dr. Barbara Yoou
R & D Associates
1401 Wilson Blvd., Suite 500
Arlington, VA 22209

Dr. Li Hua Yu
725B, NSLS
Brookhaven National Laboratory
Upton, NY 11973

Dr. Simon S. Yu
Lawrence Livermore National Laboratory
P. O. Box 808
Livermore, CA 94550

Dr. M. S. Zisman
Lawrence Berkeley Laboratory
University of California, Berkeley
Berkeley, CA 94720

Dr. J. Zumdieck
Spectra Technology
2755 Northup Way
Bellevue, WA 98004