

FILE COPY

21

AFOEHL REPORT 89-052EQ0025FEF

AD-A211 778



**COMPLIANCE TESTING OF GRISSOM AFB
CENTRAL HEATING PLANT COAL-FIRED
BOILERS 3, 4, AND 5,
GRISSOM AFB IN**

DTIC
FLECTE
AUG 28 1989

JAMES A. GARRISON, Major, USAF, BSC

JUNE 1989

Final Report

Distribution is unlimited; approved for public release

**AF Occupational and Environmental Health Laboratory (AFSC)
Human Systems Division
Brooks Air Force Base, Texas 78235-5501**

89 8 28 48

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE

REPORT DOCUMENTATION PAGE

Form Approved
OMB No. 0704-0188

1a. REPORT SECURITY CLASSIFICATION Unclassified			1b. RESTRICTIVE MARKINGS N/A		
2a. SECURITY CLASSIFICATION AUTHORITY N/A			3. DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release. Distribution is unlimited.		
2b. DECLASSIFICATION/DOWNGRADING SCHEDULE N/A			5. MONITORING ORGANIZATION REPORT NUMBER(S)		
4. PERFORMING ORGANIZATION REPORT NUMBER(S) AFOEHL Report 89-052E00025FEF			7a. NAME OF MONITORING ORGANIZATION		
6a. NAME OF PERFORMING ORGANIZATION USAF Occupational and Environmental Health Laboratory.		6b. OFFICE SYMBOL (If applicable) ECO	7b. ADDRESS (City, State, and ZIP Code)		
6c. ADDRESS (City, State, and ZIP Code) Brooks AFB TX 78235-5501			9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER		
8a. NAME OF FUNDING/SPONSORING ORGANIZATION Same as 6a		8b. OFFICE SYMBOL (If applicable)	10. SOURCE OF FUNDING NUMBERS		
8c. ADDRESS (City, State, and ZIP Code) Same as 6c			PROGRAM ELEMENT NO	PROJECT NO	TASK NO
			WORK UNIT ACCESSION NO		
11. TITLE (Include Security Classification) Compliance Testing of Grissom AFB Central Heating Plant Coal-Fired Boilers 3, 4, and 5, Grissom AFB IN.					
12. PERSONAL AUTHOR(S) Mai James A. Garrison					
13a. TYPE OF REPORT Final		13b. TIME COVERED FROM 890129 TO 890215		14. DATE OF REPORT (Year, Month, Day) June 1989	
				15. PAGE COUNT 139	
16. SUPPLEMENTARY NOTATION					
17. COSATI CODES			18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUB-GROUP	Compliance Testing Grissom Source Emission Testing		
			Stack Sampling Particulates Air Pollution		
			Stack Emissions Boilers Garrison		
19. ABSTRACT (Continue on reverse if necessary and identify by block number)					
<p>At the request of HQ SAC/SGPB source compliance testing (particulate and visible emissions) of boilers 3, 4, and 5 in the Grissom AFB Central Heating Plant was accomplished 29 Jan - 15 Feb 89. The survey was conducted to determine compliance with regards to Indiana Administrative Code, Title 325 - Air Pollution Control Board, Article 5, Opacity Regulations, and Article 6, Particulate Regulations. Boiler 3 was tested through scrubber B, Boiler 4 through scrubber A and Boiler 5 through scrubber B and the bypass stack. Results indicate that each boiler met applicable visible and particulate emissions standards.</p>					
20. DISTRIBUTION/AVAILABILITY OF ABSTRACT <input checked="" type="checkbox"/> UNCLASSIFIED/UNLIMITED <input type="checkbox"/> SAME AS RPT <input type="checkbox"/> DTIC USERS			21. ABSTRACT SECURITY CLASSIFICATION Unclassified		
22a. NAME OF RESPONSIBLE INDIVIDUAL JAMES A. GARRISON, MAJ, USAF, BSC			22b. TELEPHONE (Include Area Code) (512) 536-2891 AV 240		22c. OFFICE SYMBOL USAFOEHL/ECO

CONTENTS

	Page
DD Form 1473	i
Illustrations	iv
I. INTRODUCTION	1
II. DISCUSSION	1
A. Background	1
B. Site Description	2
C. Applicable Standards	3
D. Sampling Methods and Procedures	6
III. CONCLUSIONS	7
IV. RECOMMENDATIONS	10
References	12
Appendix	
A Personnel Information	13
B State Regulations	17
C Plant Operating Logs	33
D Coal Analysis	39
E Boiler 3, Scrubber B Field Data	43
F Boiler 4, Scrubber A Field Data	57
G Boiler 5, Scrubber B Field Data	73
H Boiler 5, Bypass Stack Field Data	87
I Calibration Data	101
J Emissions Calculations	121
K EPA Method 9 Certification	131
Distribution List	135



Accession For	
NTIS	<input checked="" type="checkbox"/> CRA&I
ERIC	<input type="checkbox"/> TAB
Unannounced	<input type="checkbox"/>
Justification	
By	
Distribution	
Availability Codes	
Dist	Availability for Special
A-1	

Illustrations

Figure	Title	Page
1	Boiler Pass/Fail Status	1
2	View of Scrubbers and Bypass Stacks	4
3	Flue Gas Flow Diagram	5
4	ORSAT Sampling Train	8
5	ORSAT Apparatus	8
6	Particulate Sampling Train	9

Table

1	Emission Survey Results	11
---	-------------------------	----

I. INTRODUCTION

On 29 Jan to 15 Feb 1989, a stationary source sampling survey for particulate and visible emissions was conducted on coal-fired boilers 3, 4 and 5 at the Grissom AFB Central Heating Plant, by the Air Quality Function, Consultant Services Division, Air Force Occupational and Environmental Health Laboratory (AFOEHL). This survey was requested by HQ SAC/SGPB to determine particulate emission compliance status with regards to Indiana Administrative Code, Title 325 - Air Pollution Control Board, Article 5, Opacity Regulations (325 IAC 5), and Article 6, Particulate Regulations (325 IAC 6). Personnel involved with on-site testing are listed in Appendix A.

II. DISCUSSION

A. Background

On 7 Nov 1986, the Director, Air and Radiation Division, U.S. Environmental Protection Agency (EPA), Region V, issued a notice of violation (NOV) to Grissom AFB for violation of 325 IAC 5, Opacity Regulations. The NOV was based on information submitted by the State of Indiana Department of Environmental Management and by the EPA. Observations indicated that oil-fired boiler 1 and coal-fired boilers 3 and 4 (boiler 5 was out of service during the State observations) were out of compliance with respect to visible emissions.

To demonstrate and maintain compliance with 325 IAC 5 and other rules set forth by the Indiana Air Pollution Control Board, EPA, Region V required Grissom AFB to: (1) conduct stack particulate emission testing on boilers 3, 4 and 5 (when operational) as specified in Title 40, Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A, Reference Method 5, (2) determine visible emissions from boilers 1-4 and 5 (when operational) as specified in 40 CFR 60, Appendix A, Reference Method 9 and (3) request stack testing following future major modifications to the central heating plant.

This compliance testing project involved conducting source compliance testing (particulate and visible emissions determination) on boiler 3 through scrubber B, boiler 4 through scrubber A and boiler 5 through scrubber B and the bypass stack. Figure 1 below shows the pass/fail status of each boiler based on prior testing by AFOEHL during Nov 87 and Mar 88.

Figure 1. Boiler Pass/Fail Status

<u>Boiler</u>	<u>Bypass Stack</u>	<u>Scrubber A</u>	<u>Scrubber B</u>
3	P	P	F
4	P	-	P
5	F	P	-

P = passed emissions testing

F = failed emissions testing

- = not tested previously due to equipment failure

B. Site Description

The Central Heating Plant operates a total of five boilers for steam production:

<u>Boiler No./ Manufacturer</u>	<u>Steam Capacity (lb/hr)</u>	<u>Year Installed</u>	<u>Fuel</u>
1/Springfield Boiler Co.	40,000	1955	oil
2/Springfield Boiler Co.	40,000	1955	oil
3/Springfield Boiler Co.	40,000	1955	coal
4/E. Keeler Co.	40,000	1960	coal
5/Zurn Ind.	65,000	1980	coal

Coal-fired boilers 3, 4 and 5 are spreader-stoker fired units, each having forced-draft and induced-draft fans and mechanical fly ash collection systems. Each unit is fitted with a steam-operated soot blower to remove fly ash and soot from heat exchanger tubing. Boiler 5 is also fitted with an economizer to further increase operating efficiency by preheating the feed water using exhaust gas heat.

Air pollution control consists of individual multiclone dust collectors on each boiler and an optional wet scrubber common to the three coal-fired boilers. The multiclone dust collectors on boilers 3, 4 and 5 were manufactured by Western Precipitation Division-Joy Manufacturing Co. The collector on both boiler 3 and 4 is a Model 9VM-10 and consists of 36 nine-inch diameter cyclonic collectors operating in parallel. The collector on boiler 5 is a Model 9VMU-10 and consists of 48 nine-inch diameter cyclonic collectors operating in parallel. Each unit is located in the boiler exhaust duct upstream of the induced-draft fan. Ash collected by the multiclones is carried by gravity to a hopper.

The exhaust effluent from each boiler is ducted to a common breeching and can be routed to the wet-scrubber or to a bypass stack. The scrubber is a double-alkali flue-gas desulfurization system using soda ash (sodium carbonate) in the scrubbing fluid and lime (calcium hydroxide) slurry for regeneration of the scrubbing liquid. The primary purpose of the unit is to remove sulfur from the flue gas; a secondary purpose is to remove particulates from the flue gas. The system has two identical scrubber units, A and B, each designed to handle 50% of the flue gas from the three coal-fired boilers. Each unit has a 5 foot (ft) diameter stack and terminates about 70 feet above the ground. There is no requirement at this time to use the scrubber system because of the low-sulfur coal being used by the plant. The bypass stack has

a 5.5 ft diameter and terminates approximately 70 ft above ground level. The scrubber stacks and the bypass stack can be seen in Figure 2. A flue gas flow diagram is shown in Figure 3.

C. Applicable Standards

The monitoring requirements, opacity regulations and particulate regulations are defined under 325 IAC 3, 5 and 6, respectively. Article 3 states that emissions tests shall be conducted in accordance with the procedures and analysis methods specified in Chapter 40, Code of Federal Regulations, Part 60, Appendix A. EPA Methods 1-5 were used for the determination of particulate emissions and Method 9 for visible emissions.

Article 5 states that visible emissions shall not exceed an average of 40% opacity in 24 consecutive readings or 60% opacity for more than a cumulative total of 15 minutes (60 readings) in a 6-hour period. When conducting a soot blowing operation, visible emissions may exceed these standards except that visible emissions may not exceed 60% opacity nor shall visible emissions in excess of the standards continue for more than 5 minutes in any 60 minute period.

Under 325 IAC 6, the maximum allowable particulate emission rate from the combustion of fuel for indirect heating facilities (either existing and in operation or with permits to construct prior to the effective date of 325 IAC 6, 26 Sep 1980) is determined by the following equation:

$$Pt = \frac{C \times a \times h}{76.5 \times Q \times N}$$

0.75 0.25

Where:

Pt = Pounds of particulate matter emitted per million BTU heat input (lb/mm BTU).

C = Maximum ground level concentration with respect to distance from the point source at the "critical" wind speed for level terrain (50 micrograms per cubic meter - provided in standard).

Q = Total source maximum operating capacity rating in million BTU per hour (mmBTU/hr) heat input (50.0 mmBTU/hr for boilers 3 and 4, 83 mmBTU/hr for boiler 5 - determined from plant operation).

N = Number of stacks in fuel burning operation (1).

a = Plume rise factor (0.67 is used for Q less than or equal to 1,000 mmBTU/hr heat input).

h = Stack height in feet (70 ft).





Figure 2. View of Scrubbers and Bypass Stack

Figure 3. Flue Gas Flow Diagram



The limits on particulate emissions determined by the equation and values of the variables applicable to this facility are 1.6 lb/mmBTU for boilers 3 and 4 and 1.1 lb/mmBTU for boiler 5. However, particulate emissions from facilities used for indirect heating purposes shall in no case exceed the following emission limitations: (1) 0.8 lb/mmBtu heat input for facilities existing and in operation on or before 8 June 1972 or (2) 0.6 lb/mmBTU heat input for any facility which has 250 mmBTU/hr heat input or less and which began operation after 8 June 1972. Item (1) applies to boilers 3 and 4 and item (2) applies to boiler 5. State regulations are presented in Appendix B.

D. Sampling Methods and Procedures

Boiler 3 was tested through scrubber B, boiler 4 through scrubber A and boiler 5 through scrubber B and the bypass stack. Coordination was made with plant personnel to try and operate each boiler at 95% capacity or greater during testing. One of the three runs which comprised a complete test included a soot blow; this is indicated on the field data sheets. Boiler operating logs for the test periods are provided in Appendix C. These logs indicate hourly steam output and coal usage. Laboratory results for the coal analysis are provided in Appendix D. Each coal sample represents an integrated sample collected over a particular one hour test run as noted on the analysis sheet.

325 IAC 3 requires that all emissions tests be conducted in accordance with the procedures and analysis methods specified in 40 CFR 60, Appendix A, Methods 1-5. Therefore, test methods, equipment, sample train preparations, sampling and recovery, calibration requirements and quality assurance were done in accordance with the methods and procedures outlined in 40 CFR 60, Appendix A.

Sampling ports were in place on both scrubber stacks and located 1.4 stack diameters upstream from the stack exit and 5.6 stack diameters downstream from any disturbance (cyclonic separator). Based on a 5 ft inside stack diameter, port location and type of sample (particulate), a total of 20 traverse points were determined for emission evaluation. Sampling ports were also in place on the bypass stack and were located 2 stack diameters upstream from the stack exit and 7 stack diameters downstream from the nearest disturbance (common breeching inlet). Based on a 5.5 ft inside stack diameter, port location and type of sample (particulate), a total of 12 traverse points were determined for emission evaluation. The sampling time for each sampling run was 60 minutes; therefore, the sampling time per traverse point in each scrubber stack was 3 minutes and 5 minutes per point in the bypass stack. Illustrations showing port locations and sampling points are provided in Appendixes E, F, G and H.

Prior to each emissions test, a preliminary velocity pressure traverse was accomplished and cyclonic flow was determined. For acceptable flow conditions to exist in a stack, the average of the absolute values of the flow angles taken at each traverse point must be less than or equal to 20 degrees. Based on prior testing experience at this location, straightening vanes were installed directly above the cyclonic separator in both scrubber A and scrubber B to prevent cyclonic flow within the stack. The resulting flow

angle in the scrubber A stack averaged 14 degrees and that in the scrubber B stack averaged 15 degrees. The average of the flow angles in the bypass stack averaged 5 degrees. The flow angle averages indicated an acceptable flow condition existed in all three stacks.

During each sample run, a flue gas sample for ORSAT analysis (measures oxygen, and carbon dioxide for stack gas molecular weight determination and emissions correction) was taken. ORSAT sampling and analysis equipment are shown in Figures 4 and 5. Flue gas moisture content, also needed for determination of gas molecular weight, was obtained during particulate sampling.

Particulate samples were collected using the sampling train shown in Figure 6. The train consisted of a buttonhook probe nozzle, heated inconel probe, heated glass filter, impingers and pumping and metering device. The nozzle was sized prior to each test so that the gas stream could be sampled isokinetically; in other words, the velocity at the nozzle tip was the same as the stack gas velocity at each point sampled. Flue gas velocity pressure was measured at the nozzle tip using a Type-S pitot tube connected to a 10-inch inclined-vertical manometer. Type K thermocouples were used to measure flue gas as well as sampling train temperatures. The probe was heated to minimize moisture condensation. The heated filter was used to collect particulate materials. The impinger train (first, third and fourth impingers: modified Greenburg-Smith type, second impinger: standard Greenburg-Smith design) was used as a condenser to collect stack gas moisture. The pumping and metering system was used to control and monitor the sample gas flow rate. Equipment calibration data is presented in Appendix I.

Particulate emissions calculations were done using "Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators" (EPA-340/1-85-018) developed by the EPA Office of Air Quality Planning and Standards, Research Triangle Park NC. This is our standard method for calculating emissions data. Emissions calculations from the EPA programs are found in Appendix J.

Visible emissions determinations were accomplished during each sample run. Visible emissions results are presented in Appendixes E through H.

III. CONCLUSIONS

Table 1 provides operating parameters for boilers 3, 4 and 5 during testing and the resultant particulate and visible emissions determined from these tests. Results indicate that emissions from boilers 3 through scrubber B and boiler 4 through scrubber A were well below the emission standard of 0.8 lb/mmBTU with an emission rate of 0.37 lb/mmBTU for both units. Boiler 5 emissions through scrubber B and the bypass stack were well below the emission standard of 0.60 lb/mmBTU with particulate emission rates of 0.19 lb/mmBTU and 0.44 lb/mmBTU, respectively. All visible emissions were equal to or below applicable standards.

To date, boilers 3, 4 and 5 have been tested through both scrubbers and the bypass stack and meet applicable state particulate and visible standards.




Figure 4. ORSAT Sampling Train





Figure 5. ORSAT Apparatus

Figure 6. Particulate Sampling Train



IV. RECOMMENDATIONS

AFOEHL will remain active in providing consultant and testing services to Grissom AFB with respect to the central heating plant.

TABLE 1

STAGE EMISSION TESTING RESULTS

DATE	TIME (MILITARY)	BOILER NO.	STAGE NO.	RUE NO.	BOILER OPERATING CAPACITY (%)	SOOT SLOW	COAL HEAT VALUE (Btu/lb)	COAL USE (lb/hr)	HEAT INPUT (Btu/hr)	PM EMISSIONS** (lb/hr)	% CO ₂ IN FLUE GAS	PM EMISSIONS CORRECTED TO 1% CO ₂ (lb/mbtu)	WHEEL EMISSIONS (% OPACITY)
13 FEB 69	1013	3	SCB B	1	99.0		11209	4000	44.0	5.0	4.4	0.35	0.0
13 FEB 69	1204	3	SCB B	2	93.0	X	11281	4000	45.1	4.7	4.2	0.30	0.0
13 FEB 69	1347	3	SCB B	3	93.0		11316	4000	43.3	7.1	4.0	0.47	0.0
					AVG = 92.0							AVG = 0.37	
14 FEB 69	0944	4	SCB A	1	95.0		11033	4149	47.4	5.7	3.0	0.40	0.0
14 FEB 69	1134	4	SCB A	2	95.0		11369	4149	47.2	3.0	2.0	0.27	0.0
14 FEB 69	1214	4	SCB A	3	95.0	X	11365	4149	47.2	3.0	2.2	0.35	0.0
					AVG = 95.0							AVG = 0.37	
14 FEB 69	1020	5	SCB B	1	98.0	X	11784	4002	61.2	11.2	7.2	0.23	0.0
14 FEB 69	1217	5	SCB B	2	99.0		11403	4002	70.9	7.5	6.2	0.16	0.0
14 FEB 69	1417	5	SCB B	3	98.0		11095	4002	82.5	7.1	6.0	0.17	0.0
					AVG = 98.0							AVG = 0.19	
15 FEB 69	1011	5	SP	1	99.0		11339	4004	77.6	21.0	9.0	0.37	7.9
15 FEB 69	1220	5	SP	2	100.0		11359	4004	76.0	20.0	10.6	0.29	14.6
15 FEB 69	1422	5	SP	3	97.0	X	11364	4004	77.9	31.4	7.4	0.65	32.3
					AVG = 99.0							AVG = 0.44	

* SCE = SCUMBER
 SP = SPIN
 ** PARTICULATE EMISSIONS

REFERENCES

1. "Standards of Performance for New Stationary Sources", Title 40, Part 60, Code of Federal Regulations, July 1, 1987.
2. Quality Assurance Handbook for Air Pollution Measurement Systems - Volume III, Stationary Source Specific Methods, U.S. Environmental Protection Agency, EPA-600/4-77-027-b, Research Triangle Park, North Carolina, December 1984.
3. Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators. U.S. Environmental Protection Agency, EPA-340/1-85-018, Research Triangle Park, North Carolina, May 1987.

APPENDIX A
Personnel Information

(This page left blank)

1. AFOEHL Test Team

Maj James Garrison, Chief, Air Quality Function
Capt Paul Scott, Consultant, Air Resources Meteorologist
SSgt Daniel Schillings, Bioenvironmental Engineering Technician
SSgt Mary Fields, Bioenvironmental Engineering Technician
SrA James Jarbeau, Bioenvironmental Engineering Technician

AFOEHL/ECQ
Brooks AFB TX 78235-5501

Phone: AUTOVON 240-2891
Commercial (512) 536-2891

2. Grissom AFB on-site representatives

SSgt Paul Franco	USAF Clinic Grissom/SGPB AUTOVON 928-3017 Commercial (317) 689-3017
------------------	---

Ruel Burns	305 CSG/DEEV AUTOVON 928-2225 Commercial (317) 689-2225
------------	---

Smedley Graham Jim Williams Michael Esca Michael Ryan	305 CES/DEMMHZ AUTOVON 928-3253 Commercial (317) 689-3253
--	---

(This page left blank)

APPENDIX B
State Regulations

(This page left blank)

period over which they are limited must be consistent with existing applicable state rules but no longer than twenty-four (24) consecutive hours.

326 IAC 2-4-3 Compliance determination; guidelines

Sec. 3. (a) Compliance will be determined based on the emission limitations and conditions established in the permits issued in conjunction with the bubble. Compliance tests shall be performed in accordance with the test methods specified in individual rules under this title (326 IAC).

(b) Records must be kept in accordance with sub-section (f) of this section and with 326 IAC 2-4-2(a)(9). These records must be kept for a period of the length of the permit unless the commissioner requires they be kept for a longer period of time.

(c) The owner or operator of an emission source under a bubble shall make available copies of reports to the commissioner or its authorized representatives upon written request, at any reasonable time, which include but are not limited to, the nature, specific emission points, and total quantities of all emission.

(d) The bubble shall not exempt any owner/operator from complying with any other applicable rule.

(e) No owner or operator under the bubble is relieved the responsibility for achieving and maintaining a reduction of emissions as expeditiously as practicable, but no later than the compliance date required under the applicable regulation, unless the commissioner grants a later compliance date.

(f) VOC emission sources subject to this rule (326 IAC 2-4) shall maintain records which include as a minimum all data and production information necessary to determine compliance of the process, equipment, or process line under the bubble. This shall include, but not be limited to the following:

- (1) type of VOC materials applied;
- (2) VOC content of materials applied;
- (3) amount of VOC material used; and
- (4) estimated emission rates.

326 IAC 2-4-4 SIP revisions

Sec. 4. (a) The following types of bubbles shall be incorporated in the permits and submitted to U.S. EPA as SIP revisions.

- (1) Bubbles which do not have fixed

emission limitations for the emission points within the bubble but will have single overall emission limit for each pollutant for the entire bubble.

- (2) Bubbles including fugitive emissions (defined in 326 IAC 2-2-1).

(3) Bubbles which will include sources that are subject to a federal enforcement action. Federal enforcement action means an order issued under 42 USC, Section 7413(a), a civil action under 42 USC, Section 7413(c), a notice imposing non-compliance penalties under 42 USC, Section 7604.

(4) Bubbles resulting in extension of compliance dates.

(5) Bubbles not exempt from dispersion modeling under 326 IAC 2-4-2(a)(4)(A) and 326 IAC 2-4-2(a)(4)(B).

326 IAC 2-4-5 Public notice; comment procedure

Sec. 5. All bubble submittals shall be subject to public notice and comment procedures as specified in 326 IAC 2-1-5(a)(1) and 326 IAC 2-1-5(a)(3), and in the Clean Air Act, 42 USC, Section 7410(a)(2)(H). All bubble proposals received by the state shall be submitted to the U.S. EPA for its comments. However, only the bubbles submitted to the U.S. EPA pursuant to 326 IAC 2-4-4 shall constitute SIP revisions. All bubbles approved by the commissioner will become effective after they are approved by U.S. EPA.

326 IAC 2-4-6 Effect of future emission limitation requirements

Sec. 6. Should a new or more restrictive emission limitation, as required by the board, become applicable to any source included in a bubble under this rule (326 IAC 2-4) the source's permit shall be modified to demonstrate reductions in total bubble emissions equal to the reduction required by the new emission standards.

326 IAC 2-4-7 Enforceability

Sec. 7. All bubbles shall be enforced by the department and may be enforced by the U.S. EPA as part of the SIP.

ARTICLE 3. MONITORING REQUIREMENTS

Rule 1. Continuous Monitoring of Emissions

326 IAC 3-1-1 Applicability of rule

Sec. 1. (a) Sources in the following categories shall continuously monitor and record emissions of air pollutants in ac-

cordance with this rule (326 IAC 3-1).

(1) Fossil fuel-fired steam generators of greater than two hundred fifty (250) million Btu per hour heat input capacity.

(2) Nitric acid plants of greater than three hundred (300) tons per day production capacity, the production capacity being expressed at one hundred percent (100%) acid.

(3) Sulfuric acid plants of greater than three hundred (300) tons per day production capacity, the production capacity being expressed at one hundred percent (100%) acid.

(4) Petroleum refinery catalyst regenerators for fluid bed catalytic cracking units of greater than twenty thousand (20,000) barrels (eight hundred forty thousand (840,000) gallons) per day fresh feed capacity.

(b) Other monitoring requirements are contained in 326 IAC 2-1-3(h) and 326 IAC 7-1.

326 IAC 3-1-2 Compliance date

Sec. 2. All sources must be in compliance with this rule (326 IAC 3-1) by July 1, 1978.

326 IAC 3-1-3 Scope of rule

Sec. 3. This rule (326 IAC 3-1) sets forth the minimum requirements for continuous emission monitoring and recording. These requirements include the source categories to be affected; emission monitoring, recording, and reporting requirements for those sources; performance specifications for accuracy, reliability, and durability to acceptable monitoring systems; and techniques to convert emission data to units of the applicable state emission standard. Such data must be reported to the commissioner as an indication of whether proper maintenance and operating procedures are being utilized by source operators to maintain emission levels at or below emission standards. Such data may be used directly or indirectly for compliance determination or any other purpose deemed appropriate by the commissioner.

326 IAC 3-1-4 Monitoring requirements for applicable pollutants

Sec. 4. (a) The owner or operator of an emission source in a category listed in this rule (326 IAC 3-1) shall:

- (1) install, calibrate, operate, and maintain all monitoring equipment necessary for continuously monitoring the pollutants specified in this rule (326 IAC 3-1) for the applicable source category; and

(2) complete the installation and performance tests of such equipment and begin monitoring and recording by July 1, 1978.

(b) The source categories and the respective monitoring requirements are listed below:

(1) Fossil fuel-fired steam generators, as specified in 326 IAC 3-1-8(1), shall be monitored for opacity, nitrogen oxides emissions, sulfur dioxide emissions, and oxygen or carbon dioxide.

(2) Fluid bed catalytic cracking unit catalyst regenerators, as specified in 326 IAC 3-1-8(4), shall be monitored for opacity.

(3) Sulfuric acid plants, as specified in 326 IAC 3-1-8(3), shall be monitored for sulfur dioxide emissions.

(4) Nitric acid plants, as specified in 326 IAC 3-1-8(2), shall be monitored for nitrogen oxides emissions.

326 IAC 3-1-5 Monitoring requirements; exemptions

Sec. 5. Exemptions from the monitoring requirements of 326 IAC 3-1-4 shall be granted by the commissioner to any source which is:

(1) subject to new source performance standards promulgated in 40 CFR 60, pursuant to Section 111 of the Clean Air Act; or

(2) not subject to an applicable emission standard of the state implementation plan (SIP); or

(3) scheduled for retirement by October 6, 1980, provided that adequate evidence and guarantees are provided that clearly show that the source will cease operations prior to such date.

326 IAC 3-1-6 Extensions of time

Sec. 6. Extensions of the time provided for installation of monitors may be granted by the board for facilities unable to meet the prescribed timeframe (compliance by July 1, 1978) provided the owner or operator of such facility demonstrates that good faith efforts have been made to obtain and install such devices within such prescribed timeframe.

326 IAC 3-1-7 Monitoring system malfunction; report

Sec. 7. When a malfunction of any monitoring system lasts more than one (1) hour, the commissioner or the commissioner's appointed representative shall be notified by telephone, or telegraph, as soon as practicable but in no event later than four

(4) daytime business hours after the beginning of said occurrence. Information of the scope and expected duration of the malfunction shall be provided. A temporary exemption from the monitoring and reporting requirement of this rule (326 IAC 3-1) may be granted, provided that the owner or operator shows, to the satisfaction of the commissioner, that the malfunction was unavoidable and is being repaired as expeditiously as practicable.

326 IAC 3-1-8 Minimum monitoring requirements

Sec. 8. The sources listed in 326 IAC 3-1-4 shall, as a minimum, meet the following basic requirements:

(1) Each fossil fuel-fired steam generator, except as provided in the following subparagraphs, with an annual average capacity factor of greater than thirty percent (30%), as reported to the Federal Power Commission for calendar year 1974 or as otherwise demonstrated to the commissioner by the owner or operator, shall conform with the following monitoring requirements when such facility is subject to an emission standard of the SIP for the pollutant in question.

(A) A continuous monitoring system for the measurement of opacity which meets the performance specifications of 326 IAC 3-1-9(1)(A) of this rule shall be installed, calibrated, maintained, and operated in accordance with the procedures of this rule (326 IAC 3-1) by the owner or operator of any such steam generator of greater than two hundred fifty (250) million BTU per hour heat input except where:

(i) gaseous fuel is the only fuel burned; or

(ii) oil or a mixture of gas and oil are the only fuels burned and the source is able to comply with 326 IAC 5-1 and 326 IAC 6-2 without utilization of particulate matter collection equipment, and where the source has never been found, through any administrative or judicial proceedings, to be in violation of 326 IAC 5-1.

(B) A continuous monitoring system for the measurement of sulfur dioxide which meets the performance specifications of 326 IAC 3-1-9(1)(C) shall be installed, calibrated, maintained, and operated on any fossil fuel-fired steam generator of greater than two hundred fifty (250) million BTU per hour heat input which has installed sulfur dioxide pollutant control equipment.

(C) A continuous monitoring system for the measurement of nitrogen oxides which meets the performance specifications of 326 IAC 3-1-9(1)(B) shall be installed, calibrated, maintained, and operated on fossil fuel-fired steam generators or greater than one thousand (1,000) million BTU per hour heat input when such facility is located in an air quality control region (AQCR) where the administrator of the U.S. EPA has specifically determined that a control strategy for nitrogen dioxide is necessary to attain the national standards, unless the source owner or operator demonstrates during source compliance tests as required by the commissioner that such a source emits nitrogen oxides at levels thirty percent (30%) or more below the emission standard set forth in 326 IAC 12.

(D) A continuous monitoring system for the measurement of the percent oxygen or carbon dioxide which meets the performance specifications of 326 IAC 3-1-9(1)(D) or 326 IAC 3-1-9(1)(E) shall be installed, calibrated, operated, and maintained on all fossil fuel-fired steam generators where measurements of oxygen or carbon dioxide in the flue gas are required to convert either sulfur dioxide or nitrogen oxides continuous monitoring data, or both, to units of the emission standard in the SIP.

(2) Each nitric acid plant of greater than three hundred (300) tons per day production capacity, the production capacity being expressed as one hundred percent (100%) acid, located in an AQCR where the administrator of the U.S. EPA has specifically determined that a control strategy for nitrogen dioxide is necessary to attain the national standard shall install, calibrate, maintain, and operate a continuous monitoring system for the measurements of nitrogen oxides which meets the performance specifications of 326 IAC 3-1-9(1)(B) for each nitric acid producing facility within such plant.

(3) Each sulfuric acid plant of greater than three hundred (300) tons per day production capacity, the production capacity being expressed as one hundred percent (100%) acid, shall install, calibrate, maintain, and operate a continuous monitoring system for the measurement of sulfur dioxide which meets the performance specifications of 326 IAC 3-1-9(1)(C) for each sulfuric acid producing facility within such plant.

(4) Each catalyst regenerator for fluid bed catalytic cracking units of greater than twenty thousand (20,000) barrels per day of fresh feed capacity shall install, calibrate, maintain, and operate a continuous monitoring system for the measurement of opacity which meets the performance specifications of 326 IAC 3-1-9(1)(A).

326 IAC 3-1-9 Minimum performance specifications; alternative procedures

Sec. 9. Owners and operators of monitoring equipment installed to comply with this rule (326 IAC 3-1) except as provided in subdivision (2) of this section shall demonstrate compliance with the following performance specifications.

(1) **Performance specifications:** The performance specifications set forth in 40 CFR 60, Appendix B, are incorporated herein by reference, and shall be used to determine acceptability of monitoring equipment installed pursuant to this rule (326 IAC 3-1) except that where reference is made to the "Administrator" in 40 CFR 60, Appendix B, the term "commissioner" should be inserted for the purpose of this rule (326 IAC 3-1). Performance specifications to be used with each type of monitoring system are listed below.

(A) Continuous monitoring systems for measuring opacity shall comply with Performance Specification 1.

(B) Continuous monitoring systems for measuring nitrogen oxides shall comply with Performance Specification 2.

(C) Continuous monitoring systems for measuring sulfur dioxide shall comply with Performance Specification 2.

(D) Continuous monitoring systems for measuring oxygen shall comply with Performance Specification 3.

(E) Continuous monitoring systems for measuring carbon dioxide shall comply with Performance Specification 3.

(2) Any source which has purchased an emission monitoring system(s) prior to September 11, 1974, may be granted an exemption by the commissioner from meeting such test procedures prescribed in 40 CFR 60, Appendix B, for a period not to extend past October 1, 1981.

(3) For nitrogen oxides monitoring systems installed on fossil fuel-fired steam generators the pollutant gas used to prepare calibration gas mixtures (40 CFR 60, Section 2.1, Performance Specification 2, Appendix B) shall be nitrogen oxide

(NO). For nitrogen oxides monitoring systems installed in nitric acid plants the pollutant gas used to prepare calibration gas mixtures (40 CFR 60, Section 2.1, Performance Specification 2, Appendix B) shall be nitrogen dioxide (NO₂). This gas shall also be used for daily checks under subdivision (7) of this section as applicable. For sulfur dioxide monitoring systems installed on fossil fuel-fired steam generators or sulfuric acid plants the pollutant gas used to prepare calibration gas mixtures (40 CFR 60, Section 2.1, Performance Specification 2, Appendix B) shall be sulfur dioxide (SO₂). Span and zero gases should be traceable to National Bureau of Standards reference gases whenever these reference gases are available. Every six (6) months from date of manufacture, span and zero (0) gases shall be reanalyzed by conducting triplicate analyses using the reference methods in 40 CFR 60, Appendix A, as follows: for sulfur dioxide, use Reference Method 6; for nitrogen oxide, use Reference Method 7; and for carbon dioxide or oxygen, use Reference Method 3. The gases may be analyzed at less frequent intervals if longer shelf lives are guaranteed by the manufacturer.

(4) Cycling times include the total time a monitoring system requires to sample, analyze, and record an emission measurement.

(A) Continuous monitoring systems for measuring opacity shall complete a minimum of one (1) cycle of operation sampling, analyzing, and data recording for each successive ten (10) second period.

(B) Continuous monitoring systems for measuring oxides of nitrogen, carbon dioxide, oxygen, or sulfur dioxide shall complete a minimum of one (1) cycle of operation (sampling, analyzing, and data recording) for each successive fifteen (15) minute period.

(5) All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters (i.e., oxygen, or carbon dioxide) from the affected facility are obtained. Additional guidance for location of continuous monitoring systems to obtain representative samples are contained in the applicable 40 CFR 60, Performance Specifications of Appendix B.

(6) When the effluents from two (2) or more affected facilities of similar design

and operating characteristics are combined before being released to the atmosphere, the commissioner may allow monitoring systems to be installed on the combined effluent, if the owner or operator shows that measurement of the combined effluents is at least as accurate as simultaneous measurement of each effluent prior to their combining in their common stack.

(7) Owners or operators of all continuous monitoring systems installed in accordance with the requirements of this rule (326 IAC 3-1) shall record the zero (0) and span drift in accordance with the method prescribed by the manufacturer of such instruments; subject the instruments to the manufacturer's recommended zero (0) and span check at least once daily unless the manufacturer has recommended adjustments at shorter intervals, in which case such recommendations should be followed; adjust the zero (0) and span whenever the twenty-four (24) hour zero (0) drift or twenty-four (24) hour calibration drift limits of the applicable performance specifications in 40 CFR 60, Appendix B are exceeded; and adjust continuous monitoring systems referenced by subsection (2) of this section whenever the twenty-four (24) hour calibration drift exceeds ten percent (10%) of the emission standard.

(8) Instrument span should be approximately two hundred percent (200%) of the expected instrument data display output corresponding to the emission standard for the source.

(9) Alternative procedures and requirements:

(A) Alternative locations for installing continuous monitoring systems or monitoring devices may be approved by the commissioner when the owner or operator can demonstrate that installation at alternative locations will enable accurate and representative measurements.

(B) Alternative procedures for performing calibration checks may be approved by the commissioner when the owner or operator can demonstrate that such alternate procedures will still result in meeting the specifications set forth in tables 1.1 for opacity, 2.1 for sulfur dioxide and nitrogen oxides, and 3.1 for oxygen and carbon dioxide, as contained in 40 CFR 60, Appendix B.

(C) Alternative continuous monitoring

systems that do not meet the spectral response requirements in 40 CFR 60, Performance Specification 1, Appendix B, but adequately demonstrate a definite and consistent relationship between their measurements and the opacity measurement of a system complying with the requirements in Performance Specification 1 may be approved by the commissioner. The commissioner may require that such demonstration be performed for each affected facility.

326 IAC 3-1-10 Minimum data reporting requirements; retention of records

Sec. 10. (a) Owners or operators of facilities required to install continuous monitoring systems shall submit a written report of excess emissions for each calendar quarter and the nature and cause of the excess emissions, if known. The averaging periods used for data reporting shall be six (6) minutes for opacity and three (3) hours for gaseous measurements. The required report shall include, as a minimum, the data stipulated in this rule (326 IAC 3-1).

(A) When the owner or operator of a fossil fuel-fired steam generator elects under 326 IAC 3-1-8(1) to measure oxygen in the flue gases, the measurements of the pollutant concentration and oxygen shall be on a dry basis and the following conversion procedure used:

$$E = CF \frac{(20.9)}{(20.9 - \% O_2)}$$

(B) When the owner or operator elects under 326 IAC 3-1-8(1) to measure carbon dioxide in the flue gases, the measurement of the pollutant concentration and the carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure used:

$$F = CF_c \frac{(100)}{(\% CO_2)}$$

(C) When the owner or operator elects under 326 IAC 3-1-8(1) to measure sulfur dioxide or nitrogen oxides in the flue gases, the measurement of the pollutant concentration and the sulfur dioxide and/or the nitrogen oxides concentration(s) shall each be on a wet basis and the following conversion procedure used except where wet scrubbers are employed or where moisture is otherwise added to the stack gases:

(b) For opacity measurements, the summary shall consist of the magnitude in actual percent opacity of all six (6) minute averages of opacity greater than forty percent (40%) opacity for each hour of operation of the facility. Average values may be obtained by integration over six (6) minutes or by arithmetically averaging a minimum of four (4) equally spaced, instantaneous, opacity measurements per minute.

(c) For gaseous measurements the summary shall consist of emission averages, in units of the applicable standard for each three (3) hour period during which the applicable standard was exceeded.

(d) The date and time identifying each period during which the continuous monitoring system was inoperative, except for zero (0) and span checks, and the nature of system repair or adjustments shall be reported. The commissioner may require proof of continuous monitoring system performance whenever system repairs or adjustments have been made.

(e) When no excess emissions have oc-

curred and the continuous monitoring system(s) has not been inoperative, repaired or adjusted, such information shall be included in the report.

(f) Owners or operators of affected facilities shall maintain a file of all information reported in the quarterly summaries, and all other data collected either by the continuous monitoring system or as necessary to convert monitoring data to the units of the applicable standard for a minimum of two (2) years from the date of collection of such data or submission of such summaries.

326 IAC 3-1-11 Reduction; conversion factors

Sec. 11. Owners or operators of affected facilities shall use the following procedures for converting monitoring data to units of the standard where necessary.

(1) For fossil fuel-fired steam generators the following procedures shall be used to convert gaseous emission monitoring data in parts per million (ppm) to pounds per million BTU where necessary:

$$E = C_{ws} F_w \frac{(20.9)}{(20.9(1-B_{ws}) - \% O_{2ws})}$$

(D) When the owner or operator elects under 325 IAC 3-1-8(1) to measure sulfur dioxide or nitrogen oxides in the flue gases, the measurement of the pollutant concentration and the sulfur dioxide and/or the nitrogen oxides concentration(s) shall each be on a wet basis and the following conversion procedure used where wet scrubbers or moisture is otherwise present in the stack gases, provided water vapor content of the stack gas is measured at least once every fifteen (15) minutes at the same point as the pollutant and oxygen measurements are made:

$$E = C_{ws} F \frac{(20.9)}{(20.9(1-B_{ws}) - \% O_{2ws})}$$

(E) The values used in the equations under this section are derived as follows:

C_{ws} = pollutant concentration at stack conditions, g/wscm (grams/wet standard cubic meter), lb/wscm (pounds/wet standard cubic meter), determined by multiplying the average concentration (ppm) for each one (1) hour period by 4.15×10^{-5} Mg/wscm per ppm (2.59×10^{-9} M

lb/wscm per ppm) where M is pollutant molecular weight, g/g-mole (lb/lb-mole).

M = 64.07 for sulfur dioxide and 46.01 for nitrogen oxides.

C = as above but measured in terms of pounds/dry standard cubic meter (lb/dscm) or grams/dry standard cubic meter (g/dscm).

F_c = a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given in 40 CFR 60, Section 60.45(f), as applicable.

F_w = a factor representing a ratio of the volume of wet flue gases generated to the calorific value of the fuel combusted. Values of F_w are:

(i) For anthracite coal as classified according to A.S.T.M. D388-66, F_w = 1.188 wscm/million

calories (10580 wscf/million BTU).

(ii) For sub-bituminous and bituminous coal as classified according to A.S.T.M. D388-66, F_w = 1.200 wscm/million calories (10680 wscf/million BTU).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, F_w = 1.164 wscm/million calories (10360 wscf/million BTU).

(iv) For gaseous fossil fuels: for natural gas, F_w = 1.196 wscm/million calories (10650 wscf/million BTU); for propane, F_w = 1.150 wscm/million calories (10240 wscf/million BTU); for butane, F_w = 1.172 wscm/million calories (10430 wscf/million BTU).

B_{wa} = proportion by volume of water vapor in the ambient air.

B_{ws} = proportion by volume of water vapor in the stack gas.

%O₂, %CO₂ = Oxygen or carbon dioxide volume (expressed as percent) determined with equipment specified under 326 IAC 3-1-8.

E = pollutant emission, lb/million BTU.

(2) For sulfuric acid plants the owner or operator shall:

(A) establish a conversion factor three (3) times daily according to the procedures of 40 CFR 60, Section 60.84(b);

(B) multiply the conversion factor by the average sulfur dioxide concentration in the flue gases to obtain average sulfur dioxide emissions in lb/ton; and

(C) report the average sulfur dioxide emission for each three (3) hour period in excess of the emission standard set forth in 326 IAC 7-1, in the quarterly summary.

(3) For nitric acid plants the owner or operator shall:

(A) establish a conversion factor according to the procedures of 40 CFR 60, Section 60.73(b);

(B) multiply the conversion factor by the average nitrogen oxides concentration in the flue gases to obtain nitrogen oxides emissions in lb/ton;

(C) report the average nitrogen oxides for each averaging period in excess of the emission standard set forth in 326 IAC 12, in the quarterly summary.

(4) Alternate data reporting and reduction procedures:

(A) Alternate procedures for computing emission averages that do not require integration of data may be approved by the commissioner if the owner or operator shows that his procedures are at least as accurate as those in this rule (326 IAC 3-1).

(B) Alternative methods of converting pollutant concentration measurements to units of the emission standard may be approved by the commissioner if the owner or operator shows that his procedures are at least as accurate as those in this rule (326 IAC 3-2).

Rule 2. Source Sampling Procedures

326 IAC 3-2-1 Applicability

Sec. 1. This rule (326 IAC 3-2) applies to any emissions testing performed in the state to determine compliance with applicable emission limits contained in this title (326 IAC), or for any other purpose requiring review and approval by the commissioner.

326 IAC 3-2-2 Federal test procedures; adoption

Sec. 2. Emissions tests subject to this rule (326 IAC 3-2) shall be conducted in accordance with the procedures and analy-

sis methods specified in 40 CFR 60, Appendix A and 40 CFR 61, Appendix B. Such test methods, equipment, calibration requirements, and analysis must be strictly followed unless otherwise approved by the commissioner.

326 IAC 3-2-3 Privately conducted protocol tests; prior approval, form

Sec. 3. (a) When a test is to be performed by any person other than staff, a test protocol form shall be completed and received by the commissioner no later than thirty-five (35) days prior to the intended test date. Such test protocol shall be on a form approved by the commissioner. Any special or unique information relative to the scheduled test shall be included with the form.

(b) After evaluating the completed protocol form, the commissioner may:

(1) Inspect the test site.

(2) Require additional conditions, including, but not limited to the following:

(A) Reasonable modifications to the stack or duct to obtain acceptable test conditions.

(B) A pretest meeting to resolve an acceptable test protocol.

(C) Additional tests to allow for adverse conditions such as interferences, non-steady or cyclic processes.

(D) The keeping of process operating parameter records, operating logs or charts during the test.

(E) Conditions on control equipment operation to make it representative of future normal operation, or

(F) The recording of specified control equipment operating parameters during the test.

(c) If the commissioner requires modifications to the test methods, analytical methods, operational parameters or other matters included in the test protocol, or if a pretest meeting is required, the source operator and the testing firm shall be notified by letter or telephone at least twenty-five (25) days prior to the proposed test date. The source operator will receive notice of the acceptability of the test protocol from the commissioner within ten (10) days of its receipt. If the source operator or test firm desires to change any previously submitted procedures or conditions, the commissioner must be notified of such change at least twenty-five (25) days prior to intended test date, and such changes cannot be made unless approved by the commissioner prior to the test. Changes in the test protocol that result from emergency conditions must be approved by an authorized on-site staff member.

(d) The commissioner reserves the right to conduct any portion of the reference method tests. In such case, a twenty-five (25) day notice of proper test procedures will be given to the company and their testing representative.

(e) The source operator must notify the commissioner of the actual test date at least two (2) weeks prior to the date.

326 IAC 3-2-4 Required testing conditions; calibration of instruments

Sec. 4. (a) Staff may observe the field test procedures and plant operation during the test.

(b) All tests shall be conducted while the source is operating at between ninety-five (95%) to one hundred percent (100%) of its maximum operating capacity, or under other capacities or conditions specified and approved by the commissioner. For the purpose of this rule (326 IAC 3-2), maximum operating capacity means the maximum design capacity of the

source or other maximum operating capacities agreed to by the source and the commissioner.

(c) Sources subject to 326 IAC 12, New Source Performance Standards, shall be tested under conditions as specified in the applicable provision therein.

(d) Calibration results of the various sampling components must be available for examination at the test site. The information must include dates, methods used, data and results. All components requiring calibration must be calibrated within sixty (60) days prior to the actual test date. Post test calibrations must be performed on the components within forty-five (45) days after the actual test date or before the equipments' next field use, whichever comes first. Components requiring calibration are listed in the federal test methods specified in 326 IAC 3-2-2. Calibration need not be done between tests when several facilities at one (1) location are tested in series, as long as the units are calibrated prior to the first test and after the last test in the series which is conducted at that site.

326 IAC 3-2-5 Test results; reports

Sec. 5. (a) All tests shall be reported to the commissioner in the form of a test report containing the following information (which can be kept confidential upon request):

(1) Certification by team leader and reviewer.

(2) Introduction, containing:

(A) date and type of tests;

(B) type of process and control equipment;

(C) plant name and location;

(D) purpose of test; and

(E) test participants and titles.

(3) Results summary, containing:

(A) tabulated data and results of each test run, process weight rate or heat input rate, the stack gas flow rate, the measured emissions given in units consistent with the applicable emission limits, and the visible emissions or average opacity readings; and

(B) allowable emission rate.

(4) Process information, including:

(A) description of process and control device;

(B) process flow diagram;

(C) maximum design capacities;

(D) fuel analysis and heat value for heat input rate determination;

(E) process and control equipment oper-

ating conditions during tests;

(F) discussion of variations from normal plant operations; and

(G) stack height, exit diameter, volumetric flow rate (acfm), exit temperature, and exit velocity.

(5) Sampling information, including:

(A) description of sampling methods used;

(B) brief discussion of the analytical procedures with justification for any variance from standard procedures;

(C) specification of the number of sampling points, time per point, and total sampling time per run;

(D) cross sectional diagram showing sampling points, diagram showing stack dimensions, sampling location and distance from the nearest flow disturbance upstream and downstream of the sampling points; and

(E) sampling train diagram.

(6) Appendix, containing:

(A) sampling and analytical procedures;

(B) results and calculations: One (1) complete calculation using actual data for each type of test performed must be shown. Results must be stated in units consistent with the applicable emission limitation;

(C) raw production data signed by plant official;

(D) photocopies of all actual field data or original raw field data;

(E) laboratory report with chain of custody shown;

(F) copies of all calibration data;

(G) applicable regulations showing emission limitation; and

(H) copies of visible emissions observations or opacity monitor readings (for TSP tests).

(b) Unless previously agreed to in writing by the commissioner, all test reports must be received by the commissioner within forty-five (45) days of the completion of the testing.

326 IAC 3-2-6 Special testing procedures; particulate matter; sulfur dioxide; nitrogen oxide; volatile organic chemicals

Sec. 6. (a) Particulate matter tests shall be conducted in accordance with the following procedures:

(1) 40 CFR 60, Appendix A, Method 5, as in effect on December 2, 1981, or other procedures approved by the commissioner shall be used.

(2) Visible emissions (VE) evaluation

shall be performed in conjunction with a particulate emissions test by a qualified observer in accordance with the procedures contained in 326 IAC 5-1-4. VE readings shall be continuously recorded for at least thirty (30) minutes per hour of sampling time for each sampling repetition. A variance from this requirement may be granted by the on-site staff person for one (1) repetition only and provided that adverse conditions exist which would invalidate the VE readings. Sources equipped with continuous opacity monitors may submit the monitor's instantaneous or six (6) minute integrated readings during the sampling period, in lieu of performing VE observations; provided,

(A) The monitoring system meets the Performance Specifications Tests I as specified in 40 CFR 60, Appendix B as in effect on December 2, 1981, and

(B) The monitor readings submitted with the test include a zero (0) and span calibration check at the start and end of each test.

(3) At least three (3) repetitions of the test must be performed under identical source operating conditions unless otherwise allowed by the commissioner.

(4) During each of the repetitions, each sampling point shall be sampled for a minimum of two (2) minutes.

(5) The total test time per repetition shall be no less than sixty (60) minutes.

(6) The total sample volume per repetition shall be no less than thirty (30) dry standard cubic feet (dscf).

(7) The total particulate weight collected from the sampling nozzle, probe, cyclone (if used), filter holder (front half), filter and connecting glassware shall be reported. Particulate analysis of the impinger catch is not required unless specified by commissioner.

(b) Sulfur dioxide (SO₂) tests shall be conducted in accordance with the following procedures:

(1) 40 CFR 60, Appendix A, Method 6 or 40 CFR 60, Appendix A, Method 8, as in effect on December 2, 1981, or other procedures approved by the commissioner, shall be used.

(2) At least three (3) repetitions of two (2) samples, each of 40 CFR 60, Appendix A, Method 6, or three (3) repetitions of 40 CFR 60, Appendix A, Method 8, performed under identical source operating conditions, shall constitute a test.

(3) During each of the repetitions for 40 CFR 60, Appendix A, Method 8, each sampling point shall be sampled for a minimum of two (2) minutes.

(4) The total test time per repetition shall be as follows:

(A) 40 CFR 60, Appendix A, Method 6: a minimum of twenty (20) minutes per run with a thirty (30) minute interval between each run; or

(B) 40 CFR 60, Appendix A, Method 8: a minimum of sixty (60) minutes per run.

(5) The total sample volume per repetition under 40 CFR 60, Appendix A, Method 8, shall be no less than forty (40) dry standard cubic feet (dscf).

(c) Nitrogen oxide tests shall be conducted in accordance with the following procedures:

(1) 40 CFR 60, Appendix A, Method 7, as in effect on December 2, 1981, or other procedures approved by the commissioner, shall be used.

(2) At least three (3) repetitions of four (4) samples each shall constitute a test.

(d) Volatile organic compounds (VOC) emissions tests shall be conducted in accordance with the following procedures:

(1) 40 CFR 60, Appendix A, Method 25, as in effect on December 2, 1981, or other procedures approved by the commissioner, shall be used for the total nonmethane organic (TNMO) emissions.

(2) At least three (3) duplicate samples must be collected and analyzed.

(3) The total test time per repetition shall be a minimum of sixty (60) minutes.

326 IAC 3-2-7 Invalidity of nonconforming tests

Sec. 7. Any tests not meeting the requirements of this rule (326 IAC 3-2) are invalid for purposes of this rule.

326 IAC 3-2-8 Appeals

Sec. 8. A determination by the commissioner may be appealed in accordance with IC 13-1-1-4(f) and IC 4-21.5.

ARTICLE 4. BURNING REGULATIONS

Rule 1. Open Burning

326 IAC 4-1-1 Scope of rule

Sec. 1. The requirements of this rule (326 IAC 4-1) establish standards for the open burning of material which would result in emissions of regulated pollutants. This rule (326 IAC 4-1) applies everywhere in the state, except in areas where

acts permitted by 326 IAC 4-1-3 or authorized by variance pursuant to 326 IAC 4-1-4 are prohibited by other state or local laws, regulations, or ordinances.

326 IAC 4-1-2 Prohibition against open burning

Sec. 2. No persons shall open burn any material except as provided in 326 IAC 4-1-3 or 326 IAC 4-1-4, or 326 IAC 4-1-5.

326 IAC 4-1-3 Exemptions

Sec. 3. (a) The following types of fires are permitted:

(1) Fires celebrating Twelfth Night Ceremonies.

(2) Fires celebrating school pep rallies.

(3) Fires celebrating scouting activities.

(4) Fires used for recreational and cooking purposes, i.e., camp fires.

(5) Residential burning; where residence contains four or fewer units. Burning shall be in a noncombustible container sufficiently vented to induce adequate primary combustion air with enclosed sides, a bottom, and a mesh covering with openings no larger than one-fourth inch (1/4") square. Burning is prohibited in apartment complexes and mobile home parks.

(6) Farm burning: wood products derived from the following farm maintenance operations:

(A) Burning of fence rows and fields or materials derived therefrom.

(B) Burning of natural growth derived from clearing a drainage ditch.

(C) Burning of limbs and prunings, but only if so diseased or infected as to present a contamination problem.

(7) Waste oil burning: where the waste oil has been collected in a properly constructed and located pit as prescribed in 310 IAC 7-1-37(A) of the Division of Oil and Gas, Department of Natural Resources. Each oil pit may be burned once every two (2) months and all the oil must be completely burned within thirty (30) minutes after ignition.

(8) Department of natural resources burning: in order to facilitate "prescribed" burning on DNR controlled properties for wildlife habitat maintenance, forestry purposes, and natural area management.

(9) United States Department of the Interior burning: in order to facilitate a National Park Service Fire Management Plan for the Indiana Dunes National Lakeshore.

(b) All exemptions under subsection (a)

of this section shall be subject to the following:

(1) Only wood products shall be burned unless otherwise stated above.

(2) Fires shall be attended at all times until completely extinguished.

(3) If fires create an nuisance or a fire hazard, they shall be extinguished.

(4) All residential, farm and waste oil burning shall occur during daylight hours during which the fires may be replenished, but only in such a manner that nearly all of the burning material is consumed by sunset.

(5) No burning shall be conducted during unfavorable meteorological conditions such as temperature inversions, high winds, air stagnation, etc.

326 IAC 4-1-4 Variances

Sec. 4. (a) Burning with prior approval of the commissioner or the commissioner's designated agent may be authorized for the following:

(1) Emergency burning of spilled petroleum products when all reasonable efforts to recover the spilled material have been made and failure to burn would result in an imminent fire hazard or water pollution problem.

(2) Burning of refuse consisting of material resulting from a natural disaster.

(3) Burning for the purpose of fire training.

(4) Burning of natural growth derived from a clearing operation, i.e., removal of natural growth for change in use of the land.

(5) Burning of highly explosive or other dangerous materials for which no alternative disposal method exists or where transportation of such materials is impossible.

(b) Burning not exempted by 326 IAC 4-1-3 may be permitted with prior receipt of a variance application and approval of the commissioner or the commissioner's designated agent.

326 IAC 4-1-5 Liability for fire

Sec. 5. Any person who allows the accumulation or existence of combustible material which constitutes or contributes to a fire causing air pollution may not refute liability for violation of this rule (326 IAC 4-1) on the basis that said fire was set by vandals, accidental, or an act of God.

Rule 2. Incinerators

326 IAC 4-2-1 Applicability of rule

Sec. 1. This rule (326 IAC 4-2) establishes standards for the use of incinerators

which emit regulated pollutants. This rule (326 IAC 4-2) does not apply to incinerators in residential units consisting of four (4) or fewer families. All other incinerators are subject to this rule (326 IAC 4-2).

326 IAC 4-2-2 Stationary incinerators

Sec. 2. All stationary incinerators shall:

(1) Consist of primary and secondary chambers or the equivalent.

(2) Be equipped with a primary burner unless burning wood products.

(3) Comply with 326 IAC 5-1 and 326 IAC 2.

(4) Be maintained properly as specified by the manufacturer and approved by the commissioner or the commissioner's designated agent.

(5) Be operated according to the manufacturer's recommendations and only burn waste approved by the commissioner or its designated agent.

(6) Comply with other state and/or local rules or ordinances regarding installation and operation.

(7) Be operated so that emissions of hazardous material including, but not limited to, viable pathogenic bacteria, dangerous chemicals or gases, or noxious odors are prevented.

(8) Not emit particulate matter in excess of the following:

(A) Incinerators with a maximum refuse-burning capacity of two hundred (200) or more pounds per hour; 0.3 pounds of particulate matter per one thousand (1,000) pounds of dry exhaust gas at standard conditions corrected to fifty percent (50%) excess air.

(B) All other incinerators: 0.5 pounds of particulate matter per one thousand (1,000) pounds of dry exhaust gas at standard conditions corrected to fifty percent (50%) excess air.

(9) Not create a nuisance or a fire hazard. If any of the above result, the burning shall be terminated immediately.

326 IAC 4-2-3 Portable incinerators

Sec. 3. All portable incinerators shall be subject to the following conditions:

(1) Approval of the commissioner or its designated agent must be obtained prior to operation at a new project site.

(2) Only wood products shall be burned.

(3) Merchantable material may be salvaged where practicable.

(4) The local health department shall be notified prior to any burning.

(5) All burning shall be conducted under favorable meteorological conditions.

(6) Burning shall occur during daylight hours and all material shall be consumed by sunset.

(7) If burning creates an air pollution problem, a nuisance or a fire hazard, the burning shall be terminated immediately.

(8) The incinerator shall be maintained and operated according to the manufacturer's recommendations and in a manner approved by the commissioner or its designated agent.

(9) The installation and operation of such an apparatus shall comply with all other state and/or local rules or ordinances.

(10) A portable incinerator shall comply with both 326 IAC 5-1 and 326 IAC 2.

ARTICLE 5. OPACITY REGULATIONS

Rule 1. Opacity Limitations

326 IAC 5-1-1 Applicability of rule

Sec. 1. (a) This rule (326 IAC 5-1) shall apply to all visible emissions (not including condensed water vapor) emitted by or from any facility or source except those sources or facilities for which specific visible emission limitations are established by 326 IAC 11, 326 IAC 12, or 326 IAC 6.

(1) The requirements of 326 IAC 5-1-2(a)(1) shall apply to sources or facilities located in attainment areas for particulate matter, designated in 326 IAC 1-4.

(2) The requirements of 326 IAC 5-1-2(a)(2) shall apply to sources or facilities located in nonattainment areas for particulate matter as designated in 326 IAC 1-4.

326 IAC 5-1-2 Visible emission limitations

Sec. 2. (a) Visible emissions from any source or facility shall not exceed any of the following limitations. Unless otherwise stated, all visible emissions shall be observed in accordance with the procedures set forth in 326 IAC 5-1-4:

(1) Sources or facilities of visible emissions located in attainment areas for particulate matter shall meet the following limitations:

(A) Visible emissions shall not exceed an average of forty percent (40%) opacity in twenty-four (24) consecutive readings.

(B) Visible emissions shall not exceed sixty percent (60%) opacity for more than a cumulative total of fifteen (15) minutes (sixty (60) readings) in a six (6) hour period.

(2) Sources or facilities of visible emissions located in nonattainment areas shall meet the following limitations:

(A) Visible emissions shall not exceed, an average of thirty percent (30%) opacity in twenty-four (24) readings.

(B) Visible emissions shall not exceed sixty percent (60%) opacity for more than a cumulative total of fifteen (15) minutes (sixty (60) readings) in a six (6) hour period.

(3) Sources and facilities of visible emissions located in both attainment or nonattainment areas, for which an alternate visible emission limitation has been established pursuant to 326 IAC 5-1-5(b), shall comply with said limitations in lieu of the limitations set forth in subsection (a)(1) and (a)(2) of this section.

326 IAC 5-1-3 Temporary exemptions

Sec. 3. (a) Boiler startup and shutdown: When building a new fire in a boiler, or shutting down a boiler, visible emissions may exceed the applicable opacity limit established in 326 IAC 5-1-2(a); however, visible emissions shall not exceed an average of sixty percent (60%) opacity and emissions in excess of the applicable opacity limit shall not continue for more than ten (10) continuous minutes on one (1) occasion in any twenty-four (24) hour period.

(b) Cleaning boilers: When removing ashes from the fuel bed or furnace in a boiler or blowing tubes, visible emissions may exceed the applicable opacity limit established in 326 IAC 5-1-2(a) however, visible emissions shall not exceed sixty percent (60%) opacity and visible emissions in excess of the applicable opacity limit shall not continue for more than five (5) continuous minutes on one (1) occasion in any sixty (60) minute period. Such emissions shall not be permitted on more than three (3) occasions in any twelve (12) hour period.

(c) Facilities not temporarily exempted by subsections (a) and (b) of this section may be granted special temporary exemptions by the commissioner of the same duration and type authorized therein provided that the facility proves to the satisfaction of the commissioner that said ex-

emptions are needed and that during periods of startup and shutdown, owners and operators shall, to the extent practicable, maintain and operate any affected facility including air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the commissioner, which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures and inspection of the source.

(d) Sources or facilities not exempted through subsections (a), (b), or (c) of this section may also be granted special exemptions by the commissioner, provided that the source or facility owner or operator proves to the satisfaction of the commissioner that said exemption is justifiable. Said exemption(s) may be of longer duration and may apply to other types of facilities not provided for in subsections (a) or (b) of this section.

326 IAC 5-1-4 Compliance determination

Sec. 4. (a) Determination of visible emissions from sources or facilities to which this rule (326 IAC 5-1) applies may be made in accordance with subdivisions (1) or (2) below:

(1) Determination of visible emissions by means of a qualified observer shall be made according to the following:

(A) Position: The qualified observer shall stand at a distance sufficient to provide a clear view of the emissions with the sun, if visible, oriented in the 140° sector to his back. Consistent with maintaining the above requirement, the observer shall, as much as possible, make his observations from a position such that his line of vision is approximately perpendicular to the direction of the visible emissions (plume where applicable), and when observing opacity of emissions from rectangular outlets (e.g., monitors, open baghouses, non-circular stacks), approximately perpendicular to the longer axis of the outlet. The observer's line of sight should not include more than one (1) plume at a time when multiple stacks are involved, and in any case the observer should make his observations with his line of sight perpendicular to the longer axis of such a set of

multiple stacks (e.g., stub stacks on baghouses).

(B) Field records: The observer shall record the name of the plant, emission location, type of facility, observer's name and affiliation, and the date on a field data sheet. Time, estimated distance to the emission location, approximate wind direction, estimated wind speed, description of the sky conditions (presence and color of clouds), and visible emissions (plume where applicable) background are recorded on a field data sheet at the time opacity readings are initiated and completed.

(C) Observations: Opacity observations shall be made at the point of greatest opacity in that portion of the visible emissions, (plume where applicable) where condensed water vapor is not present. The observer shall not look continuously at the visible emissions, (plume where applicable) but instead shall observe the visible emissions, (plume where applicable) momentarily at fifteen (15) second intervals.

(D) Recording observations: Opacity observations shall be recorded to the nearest five percent (5%) at fifteen (15) second intervals on an observational record sheet. A minimum of twenty-four (24) observations shall be recorded. Each momentary observation shall be deemed to represent the average opacity of emissions for a fifteen (15) second period.

(E) Determination of opacity as an average of twenty-four (24) consecutive observations: Opacity shall be determined as an average of twenty-four (24) consecutive observations recorded at fifteen (15) second intervals. Divide the observations recorded on the record sheet into sets of twenty-four (24) consecutive observations. A set is composed of any twenty-four (24) consecutive observations. Sets need not be consecutive in time and in no case shall two (2) sets overlap. For each set of twenty-four (24) observations, calculate the average by summing the opacity of the twenty-four (24) observations and dividing this sum by twenty-four (24). Record the average opacity on a record sheet. For the purpose of determining an alternative visible emission limit in accordance with 326 IAC 5-1-5(b) following, an average of twenty-four (24) consecutive readings or more may be used to calculate the alternate visible emissions limit.

(F) Determination of opacity as a cu-

mulative total of fifteen (15) minutes: For emissions from intermittent sources, opacity shall be determined in accordance with clause (A), (B), (C), and the first sentence of (D). Each momentary observation shall be deemed to represent the average opacity of emissions for a fifteen (15) second period. All readings greater than the specified limit in 326 IAC 5-1-2 shall be accumulated as fifteen (15) second segments for comparison with the limit.

(G) Attached steam plumes. When condensed water vapor is present within the plume as it emerges from the emission outlet, opacity observations shall be made beyond the point in the plume at which condensed water vapor is no longer visible. The observer shall record the approximate distance from the emission outlet to the point in the plume at which the observations are made.

(H) Detached steam plumes: When water vapor in the plume condenses and becomes visible at a distinct distance from the emission outlet, the opacity of emissions should be evaluated at the emission outlet prior to the condensation of water vapor and the formation of the steam plume.

(2) Determination of compliance with visible emission limitations established in this rule (326 IAC 5-1) may also be made in accordance with a source's or facility's continuous monitoring equipment, for any source or facility in compliance with the requirements of 326 IAC 3-1.

(b) If the compliance determination procedures set forth in subsections (a)(1) and (a)(2) of this section results in any conflict in visible emission readings, the determination made in accordance with subsection (a)(2) of this section shall prevail for the purpose of compliance, provided that it can be shown that the continuous monitor has met the performance specifications as set forth in the 40 CFR 60, specifically Performance Specification 1.

326 IAC 5-1-5 Violations

Sec. 5. (a) A violation of this rule (326 IAC 5-1) shall constitute prima facie evidence of a violation of other applicable particulate emission control regulations. A violation of any such rule may be refuted by a performance test conducted in accordance with subsection (b) of this section. Such test shall refute the mass emission violation only if the source is shown to

be in compliance with the allowable mass emission limit. An exceedance of the allowable opacity emission limit will not be treated as a violation if, during the test described in subsection (b) of this section, the source demonstrates compliance with the allowable mass emission limit while simultaneously having visible emissions more than or equal to the reading at which the exceedance was originally observed.

(b) The owner or operator of a source or facility which believes it can operate in compliance with the applicable mass emission limitation, but exceeds the limits specified in 326 IAC 5-1-2, may submit a written petition to the commissioner requesting that an alternate opacity limitation be established pursuant to the following provisions. Additionally, if the commissioner has issued a notice of violation to an owner or operator of a source or facility for violation of the applicable opacity limitation, such owner or operator may, propose in notice of violation resolution, to disprove said violation by establishing an alternate opacity limit pursuant to the following provisions. This alternate limit shall be based upon a mass emission performance test conducted according to a method designated by the commissioner, and a visible emission test conducted simultaneously, according to 326 IAC 5-1-4. Where the commissioner determines there is no acceptable test method available, a request for an alternate visible emission limit shall be denied.

(1) The alternate emission limit shall be equal to that level of opacity at which the source or facility will be able, as indicated by the performance and opacity tests, to meet the opacity standard at all times during which the source or facility is meeting the mass emission limitation. However, the commissioner shall also reserve the right to determine the alternate visible emissions limit in the following manner:

(A) If a performance test of a source or facility demonstrates:

(i) that said source or facility is in compliance with the allowable mass emissions limit (as defined in 326 IAC 1-2) at the time that the test is done; and

(ii) simultaneously, said source's or facility's test demonstrates that the allowable opacity emission limit is being exceeded, then, the enforceable opacity limitation shall be equal to that level of opacity at which the source or facility will

be able as indicated by the performance and opacity tests to meet the opacity standard at all times during which the source or facility is meeting the mass emission limitation.

(B) If a performance test of a source or facility demonstrates:

(i) that said source or facility is in compliance with the allowable mass emission limit, and the test mass emission rate is within ten percent (10%) of the allowable emissions limit for that source or facility; and

(ii) simultaneously, said source's or facility's test demonstrates that the opacity observed is below the allowable opacity emission limit, the enforceable opacity limitation shall be equal to that level of opacity at which the source or facility will be able, as indicated by the performance and opacity tests, to meet the opacity standard at all times during which the source or facility is meeting the mass emission limitation.

(C) If a performance test of a source or facility demonstrates:

(i) that said source or facility is in compliance with the allowable mass emission limit, and the test mass emission rate is less than ninety percent (90%) of the allowable emissions limit; and

(ii) simultaneously, said source's or facility's test demonstrates that the opacity observed is below the allowable opacity emission limit, the enforceable opacity limitation shall remain the existing allowable opacity emission limitation for that source or facility.

(2) Compliance with 326 IAC 6-1, 326 IAC 6-2, 326 IAC 6-3, and 326 IAC 11-1, and other applicable rules must be demonstrated by the performance test.

(3) The commissioner may require a performance test in any case where it is necessary to determine the compliance status for a facility. However, the commissioner will not request a performance test for any facility which is known to be in compliance with the allowable opacity limitation.

(4) All alternate visible emission limits shall be established on a source or facility-specific basis. No limitation for any facility or source shall be established by reference to a similar or identical facility or source.

(5) The owner or operator of the source or facility shall notify the commissioner at

least fifteen (15) days prior to conducting a test for the purposes of demonstrating an alternate visible emission limit.

(6) A staff member who is a qualified observer, approved by the commissioner or other consultant approved by the commissioner shall be present during any performance tests.

(7) The cost of the performance test shall be at the expense of the owner or operator.

(8) Any alternate visible emission limit established for any source or facility shall not become effective until said limitation is established in the applicable operating permit. Said limitation will be incorporated, by amendment, into the operating permit for said source or facility and submitted to the U.S. EPA as a SIP revision.

(9) Where a visible emission limitation is based upon a new source performance standard, any new limitation must comply with the provisions of said standard.

326 IAC 5-1-6 Compliance schedule

Sec. 6. Sources newly subject to more stringent limitations on August 27, 1980, by 326 IAC 5-1-2 shall comply with the compliance schedule of 326 IAC 6-1.

326 IAC 5-1-7 State implementation plan revisions

Sec. 7. Any exemptions given or provisions granted to this rule (326 IAC 5-1) by the commissioner under 326 IAC 5-1-3(c), 326 IAC 5-1-3(d), or 326 IAC 5-1-5(b), shall be submitted to the U.S. EPA as a SIP revision.

ARTICLE 6. PARTICULATE RULES

Rule 1. Nonattainment Area Limitations

326 IAC 6-1-1 Applicability of rule

Sec. 1. Sources or facilities specifically listed in 326 IAC 6-1-7 shall comply with the limitations contained therein. Sources or facilities that are (1) located in the nonattainment counties listed in 326 IAC 6-1-7, (2) but which sources or facilities are not specifically listed in 326 IAC 6-1-7, and (3) have the potential to emit one hundred (100) tons or more of particulate matter per year or have actual emissions of ten (10) tons or more of particulate matter per year, shall comply with the limitations of 326 IAC 6-1-2.

326 IAC 6-1-2 Particulate emission limitations; fuel combustion steam generators, asphalt concrete plant, grain elevators, foundries, mineral aggregate oper-

ations; modification by commissioner

Sec. 2. (a) General sources: Facilities not limited by subsections (b) through (g) of this section shall not allow or permit discharge to the atmosphere of any gases which contain particulate matter in excess of 0.07 gram per dry standard cubic meter (g/dscm) (0.03 grain per dry standard cubic foot (dscf)). Where this limitation is more stringent than the applicable limitations of subsections (b) through (g) of this section, for facilities in existence prior to the applicability dates, or of a size not applicable to said subsections, emission limitations for those facilities shall be determined by the commissioner and will be established in accordance with the procedures set forth in subsection (h) of this section.

(b) Fuel combustion steam generators: No person shall operate a fossil fuel combustion steam generator (any furnace or boiler used in the process of burning solid, liquid, or gaseous fuel or any combination thereof for the purpose of producing steam by heat transfer) so as to discharge or cause to be discharged any gases unless such gases are limited to:

(1) A particulate matter content of no greater than 0.18 grams per million calories (0.10 pounds per million Btu) for solid fuel fired generators of greater than sixty-three million (63,000,000) kilocalories (kcal) per hour heat input (two hundred fifty (250) million Btu);

(2) A particulate matter content of no greater than 0.63 grams per million calories (0.35 pounds per million Btu) for solid fuel fired generators of equal to or greater than 6.3 but less than or equal to sixty-three million (63,000,000) kcal per hour heat input (twenty-five (25) but less than or equal to two hundred fifty (250) million Btu);

(3) A particulate matter content of no greater than 1.08 grams per million calories (0.6 pounds per million Btu) for solid fuel fired generators of less than 6.3 million kcal per hour heat input (twenty-five (25) million Btu);

(4) A particulate matter content of no greater than 0.27 grams per million kcal (0.15 pounds per million Btu) for all liquid fuel fired steam generators.

(5) A particulate matter content of no greater than .01 grains per dry standard cubic foot for all gaseous fuel-fired steam generators.

(c) Asphalt concrete plants: The requirements of this provision shall apply to any asphalt concrete plant (any facility used to manufacture asphalt concrete by heating and drying aggregate and mixing with asphalt cement). An asphalt concrete plant is deemed to consist only of the following: driers, systems for screening, handling, storing, and weighing hot aggregate; systems for loading, transferring, and storing mineral filler; systems for mixing asphalt concrete; and the loading, transfer, and storage systems associated with emission control systems.

(1) No person shall operate the affected facilities of an asphalt concrete plant which existed on or prior to June 11, 1973, so as to discharge or cause to be discharged into the atmosphere any gases unless such gases are limited to:

(A) A particulate matter content of no greater than 230 mg per dscm (0.10 grain per dscf).

(d) Grain Elevators: No person shall operate a grain elevator (a grain elevator is defined as any plant or installation at which grain is unloaded, handled, cleaned, dried, stored or loaded) without meeting the provisions of this subsection. Subdivision (1) of this subsection shall apply to any grain storage elevator located at any grain processing source which has a permanent grain storage capacity of thirty-five thousand two hundred (35,200) cubic meters (one (1) million U.S. bushels) and any grain terminal elevator which has a permanent grain storage capacity of eighty-eight thousand one hundred (88,100) cubic meters (two and one-half (2.5) million U.S. bushels). All grain elevators subject to this rule (326 IAC 6-1) shall comply with the requirements of subdivision (2) of this section.

(1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility except a grain dryer any process emission unless such emissions are limited to a particulate matter content of no greater than 0.07 gram per dry standard cubic meter (dscm) (0.03 grain per dry standard cubic foot (dscf)) for said facilities for which construction or modification commenced prior to January 13, 1977.

(2) Grain elevators subject to this subdivision shall provide for good housekeeping and good maintenance procedures. Good housekeeping and maintenance is defined

**Rule 2 Particulate Emission Limitations
for Sources of Indirect Heating****326 IAC 6-2-1 Applicability**

Sec. 1. This rule (326 IAC 6-2) establishes limitations for sources of indirect heating:

(a) Particulate emissions from the combustion of fuel for indirect heating from all facilities located in Lake, Porter, Marion, Boone, Hamilton, Hendricks, Johnson, Morgan, Shelby, and Hancock Counties which were existing and in operation or which received permit to construct prior to September 21, 1983, shall be limited by 326 IAC 6-2-2.

(b) Particulate emissions from the combustion of fuel for indirect heating from all facilities not specified in subsection (a) of this section which were existing and in operation or which received permits to construct prior to September 21, 1983 shall be limited by 326 IAC 6-2-3.

(c) Particulate emissions from the combustion of fuel for indirect heating from all facilities receiving permits to construct on or after September 21, 1983 shall be limited by 326 IAC 6-2-4.

(d) If any limitation established by this rule (326 IAC 6-2) is inconsistent with applicable limitations contained in 326 IAC 6-1, then the limitations contained in 326 IAC 6-1 prevail.

(e) If any limitation established by this rule (326 IAC 6-2) is inconsistent with applicable limitations contained in 326 IAC 12, New Source Performance Standards, then the limitations contained in 326 IAC 12 prevail.

(f) If any limitation established by this rule (326 IAC 6-2) is inconsistent with a limitation contained in a facility's construction or operation permit as issued pursuant to 326 IAC 2, Permit Review Regulations, then the limitations contained in the source's current permits prevail.

(g) If any limitation established by this rule (326 IAC 6-2) is inconsistent with a limitation required by 326 IAC 2, Permit Review Regulations, to prevent a violation of the ambient air quality standards set forth in 326 IAC 1-4, then the limitations required by 326 IAC 2 prevail.

(h) The addition of a new facility at a source does not affect the limitations of the existing facilities unless such changes in the limitations are required by the provisions of 326 IAC 2 or 326 IAC 6-1.

326 IAC 6-2-2 Emission limitations for facilities specified in 326 IAC 6-2-1(a)

Sec. 2. (a) Particulate emissions from existing indirect heating facilities located in the specified counties shall be limited by the following equation:

$$P_t = \frac{0.87}{Q^{0.16}}$$

Where:

P_t = Pounds of particulate matter emitted per million Btu (lb/mmBtu) heat input.

Q = Total source maximum operating capacity rating in million Btu per hour (mmBtu/hr) heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's operation permit application, except when some lower capacity is contained in the facility's operation permit, in which case, the capacity specified in the operation permit shall be used.

For Q less than 10 mmBtu/hr, P_t shall not exceed 0.6.
For Q greater than or equal to 10,000 mmBtu/hr, P_t shall not exceed 0.2. Figure 1 may be used to estimate allowable emissions.

(b) The emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall be calculated using the equation contained in subsection (a) of this section where: Q shall reflect the total source capacity on June 8, 1972. The resulting P_t is the emission limitation for each facility existing on that date and will not be affected by the addition of any subsequent facility. The particulate emissions from all of the facilities which were in existence on June 8, 1972, may be allocated in any way among these facilities provided that they will not result in a significantly greater air quality impact level at any receptor than that which would result if the particulate emissions from each of these facilities were limited to P_t ; and provided that the emission limitations for each facility are specified in its operation permit. Significant impact levels are defined in 326 IAC 2-3(d).

(c) The emission limitations for those indirect heating facilities which began operation after June 8, 1972, and before September 21, 1983, and those facilities which receive permits to construct prior to September 21, 1983 shall be calculated using the equation contained in subsection (a) of this section where: Q includes the capacity for the facility in question and the capacities for those facilities which were previously constructed or received prior permits to construct. The limitations for all previously permitted facilities do not change. The Q and P_t for each facility at a source which begins operation or receives a construction permit during this time period will be different.

326 IAC 6-2-3 Emission limitations for facilities specified in 326 IAC 6-2-1(b)

Sec. 3. (a) Particulate emissions from indirect heating facilities existing and in operation before September 21, 1983, shall be limited by the following equation:

$$P_t = \frac{C \times a \times h}{76.5 \times Q^{0.75} \times N^{0.25}}$$

Where:

C = Maximum ground level concentration with respect to distance from the point source at the "critical" wind speed for level terrain. This shall equal 50 micrograms per cubic meter (μ/m^3) for a period not to exceed a sixty (60) minute time period.

Pt = Pounds of particulate matter emitted per million Btu heat input (lb/mmBtu).

Q = Total source maximum operating capacity rating in million Btu per hour (mmBtu/hr) heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's operation permit application, except when some lower capacity is contained in the facility's operation permit; in which case, the capacity specified in the operation permit shall be used.

N = Number of stacks in fuel burning operation.

a = Plume rise factor which is used to make allowance for less than theoretical plume rise. The value 0.67 shall be used for Q less than or equal to 1,000 mmBtu/hr heat input. The value 0.8 shall be used for Q greater than 1,000 mmBtu/hr heat input.

h = Stack height in feet. If a number of stacks of different heights exist, the average stack height to represent "N" stacks shall be calculated by weighing each stack height with its particulate matter emission rate as follows:

$$h = \frac{\sum_{i=1}^N H_i \times pa_i \times Q}{\sum_{i=1}^N pa_i \times Q}$$

Where:

pa = the actual controlled emission rate in lb/mmBtu using the emission factor from AP-42 or stack test data. Stacks constructed after January 1, 1971, shall be credited with GEP stack height only. GEP stack height shall be calculated as specified in 326 IAC 1-7.

(b) The emission limitations for those indirect heating facilities which were existing and in operation on or before June 8, 1972, shall be calculated using the equation contained in subsection (a) of this section where: Q, N, and h shall include the parameters for all facilities in operation on June 8, 1972. The resulting Pt is the emission limitation for each facility existing on that date and will not be affected by the addition of any subsequent facility. The particulate emissions from all of the facilities which were in existence on June 8, 1972, may be allocated in any way among these facilities provided that they will not result in a significantly greater air quality impact level at any receptor than that which would result if the particulate emissions from each of these facilities were limited to Pt; and provided that the

emission limitations for each facility are specified in its operation permit. Significant impact levels are defined in 326 IAC 2-3-2(d).

(c) The emission limitations for those indirect heating facilities which began operation after June 8, 1972, and before September 21, 1983, and those facilities which receive permits to construct prior to September 21, 1983, shall be calculated using the equation contained in subsection (a) of this section where: Q, N, and h shall include the parameters for the facility in question and for those facilities which were previously constructed or received prior permits to construct. The limitations for all previously permitted facilities do not change. The Q, N, h, and Pt for each facility at a source which begins operation or receives a construction permit during

this time period will be different.

(d) Particulate emissions from all facilities used for indirect heating purposes which were existing and in operation on or before June 8, 1972, shall in no case exceed 0.8 lb/mmBtu heat input.

(e) Particulate emissions from any facility used for indirect heating purposes which has 250 mmBtu/hr heat input or less and which began operation after June 8, 1972, shall in no case exceed 0.6 lb/mmBtu heat input.

326 IAC 6-2-4 Emission limitations for facilities specified in 326 IAC 6-2-1(c)

Sec. 4. (a) Particulate emissions from indirect heating facilities constructed after September 21, 1983 shall be limited by the following equation:

$$Pt = \frac{1.09}{Q^{0.26}}$$

Where:

Pt = Pounds of particulate matter emitted per million Btu (lb/mm Btu) heat input.

Q = Total source maximum operating capacity rating in million Btu per hour (mmBtu/hr) heat input. The maximum operating capacity rating is defined as the maximum capacity at which the facility is operated or the nameplate capacity, whichever is specified in the facility's permit application, except when some lower capacity is contained in the facility's operation permit; in which case, the capacity specified in the operation permit shall be used.

For Q less than 10 mmBtu/hr, Pt shall not exceed 0.6. for Q greater than or equal to 10,000 mmBtu/hr, Pt shall not exceed 0.1. Figure 2 may be used to estimate allowable emissions.

(b) As each new indirect heating facility is added to a plant Q will increase. As a result, the emission limitation for each

progressively newer facility will be more stringent until the total plant capacity reaches 10,000 mmBtu/hr after which the emission limit for each newer facility will be 0.1 lb/mmBtu heat input. The rated capacities for facilities regulated by 326 IAC 12, New Source Performance Standards, shall be included when calculating Q for subsequent facilities.

APPENDIX C
Plant Operating Logs

(This page left blank)

MO.

13 FEB 89

DAILY STEAM BOILER PLANT OPERATING LOG

1. COMMAND

Sac

TIME HOUR	STEAM PRESS (PSIG)	STEAM PRODUCED (1000 Pounds)				FUEL USED D				FLUE GAS E					
						COAL - BTU/LB				O ₂ OR CO ₂ (AVE %)					
		C				OIL - BTU/GAL				GAS - BTU/1000CF					
		BOILER NO.				BOILER NO.				BOILER NO.				TEMP	
A.	B.	1	2	3	4	1	2	3	4	1	2	3	4	1	2
0030	118	28,000	13,000	29,000		248	115			11.0	10.0	11.0		410	420
0130	118	28,000	13,000	26,000		248	115			11.0	10.0	11.0		410	420
0230	118	27,000	13,000	29,000		239	115			11.0	10.0	11.0		410	420
0330	118	27,000	13,000	24,000		248	88			11.0	10.0	11.0		410	420
0430	118	27,000	13,000	33,000		239	97			10.5	10.0	11.0		410	420
0530	116	27,000	13,000	32,000		239	97			10.5	10.0	11.0		410	420
0630	116	30,000	13,000	32,000		245	115			11.0	10.5	11.5		410	420
0730	116	29,000	14,000	32,000		257	124			10.5	10.5	11.5		410	420
TOTAL	932	224,000	98,000	237,000		1983	826	26,333		86	81	89		359	8011
AVG.	117	28,000	12,250	29,625		248	108	3292		10.8	10.0	11.1		410	420
0830	120	25,000	12,000	34,000		221	106			10.0	10.0	11.5		410	420
0930	120	20,000	10,000	38,000		177	88			10.0	10.0	11.0		410	410
1030	112	19,000	12,000	36,000		168	106			11.0	10.0	12.0		410	420
1130	116	14,000	10,000	36,000		142	88			11.0	10.0	11.5		410	370
1230	102	16,000	10,000	38,000		164	88			11.0	10.0	12.0		410	370
1330	116	19,000	10,000	36,000		159	88			10.0	10.0	12.0		410	340
1430	110	15,000	10,000	37,000		159	88			10.0	10.0	12.0		410	360
1530	108	21,000	14,000	33,000		186	124			10.5	10.5	11.5		410	420
TOTAL	884	153,000	88,000	288,000		1354	779	32,000		80.5	80.5	93.5		3620	308
AVG.	111	19,125	11,000	36,000		169	97	4000*		10.1	10.1	11.7		410	386
1630	121	22,000	13,000	27,000		195	115			10.0	10.0	11.5		410	420
1730	113	23,000	11,000	26,000		204	97			10.5	10.0	11.5		410	410
1830	116	23,000	11,000	28,000		204	97			10.5	10.0	12.0		410	400
1930	119	22,000	11,000	29,000		195	97			11.0	10.0	12.0		410	400
2030	114	25,000	12,000	26,000		221	106			11.0	10.5	11.5		410	291
2130	112	24,000	12,000	27,000		212	106			11.0	10.5	11.5		410	340
2230	120	24,000	13,000	26,000		112	115			11.0	10.5	11.0		410	411
2330	118	29,000	10,000	26,000		204	97			11.0	10.5	11.0		410	410
TOTAL	933	186,000	93,000	215,000		1547	821	23,889		86.0	82	92		3520	322
AVG.	117	23,250	11,625	26,875		193	103	2,986		10.8	10.3	11.5		410	403
DAILY TOTAL	2749	563,000	279,000	740,010		4894	2466	82,222		253	244	275		10660	966
AVG.	115	23,458	11,625	30,833		204	103	3426		10.5	10.2	11.4		414	400

					OPERATING DATA				- 23 - 89	
	#1	#2 FIRST SHIFT		#3	SECOND SHIFT #13				#1	#2
A. STEAM FLOW FINAL (Integrator)	545439	756092	815000	547927	756386	819914	55	54	55	
B. STEAM FLOW START	541860	753670	810871	545439	756092	815000	54	54	54	
C. TOTAL STEAM PRODUCED	224,000	98,000	237,000	153,000	88,000	288,000	186	186	186	
D. LBS. STEAM PER UNIT OF FUEL										
E. SOOT BLOWN	0500	0455	0450	0924+1238				2010		
F. BLOW DOWN	TIME: 0100	GALS. 264+420=684		TIME:	GALS. 04+420=420		TIME:			
G. DEGREE DAY										
H. OPERATOR	RICHARD - (GRAND - L) TITTEBRINK			NEWERS - KICHHEALS - SCHERLO - BATES				mc G		
I. FIREMAN	BONNER									
J. TOTAL MANHOURS OPERATION	24			40						
K. REMARKS (Continue on reverse)										

13. REMARKS (Continue on reverse)

WD-06-0025

ASHES - 0610 - 0710 = 420

OIL TRANSFER TO 9"

WC-GG-DA-0810

ASHES - 1500 > 420
1600

HANGER 200 - 1355

DATE AND LOCATION
02/25/68
F.F.

CONTRACT NO.
5111

DATE
14 FEB 68

DAILY STEAM BOILER PLANT OPERATING LOG

TIME	STEAM PRODUCED (1000 POUNDS)	FUEL USED		STEAM PRODUCED (1000 POUNDS)	FUEL GAS	FUEL OIL	FEEDWATER HEATER	FEEDWATER FLOW (GPM)		MAKE UP WATER FLOW (GPM)	CONDENSATE FLOW (GPM)	FEEDWATER PRESSURE (PSI)	CONDENSATE PRESSURE (PSI)
		COAL - STEAMER	COAL - STOUTER					START	STOP				
00:00	115	2300	212	115	105	105	216	105	5122	662	125	125	125
01:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
02:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
03:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
04:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
05:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
06:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
07:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
08:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
09:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
10:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
11:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
12:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
13:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
14:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
15:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
16:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
17:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
18:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
19:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
20:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
21:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
22:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
23:00	116	2300	212	116	105	105	216	105	5122	662	125	125	125
TOTAL	116	2300	212	116	105	105	216	105	5122	662	125	125	125

STEAM FLOW (1000 POUNDS)
116

COAL - STEAMER
2300

COAL - STOUTER
212

FEEDWATER FLOW (GPM)
5122

MAKE UP WATER FLOW (GPM)
662

CONDENSATE FLOW (GPM)
125

FEEDWATER PRESSURE (PSI)
125

CONDENSATE PRESSURE (PSI)
125

PLANT EFFICIENCY (PERCENT)
82.16

PLANT FUEL USED (1000 POUNDS)
2416

PLANT BTU OUTPUT (1000 BTU)
146615425.6

PLANT BTU INPUT (1000 BTU)
179151750.0

PLANT EFFICIENCY (PERCENT)
82.16

PLANT OPERATOR
J. M. H. H.

PLANT SUPERVISOR
J. M. H. H.

PLANT ENGINEER
J. M. H. H.

12 FEB. 89

DAILY STEAM BOILER PLANT OPERATING LOG

1. COMMAND

SAC

	TIME HOUR	STEAM PRESS (PSIG)	STEAM PRODUCED (1000 Pounds)				FUEL USED D				FLUE GAS E					
			C				COAL - BTU/LB				O ₂ OR CO ₂ (Ave %)					
			BOILER NO.				BOILER NO.				BOILER NO.					
	A	B	1	2	3	5	1	2	3	5	1	2	3	5	1	2
FIRST SHIFT	0030	120	14000	7000		57600	124	62			10.0	9.5		11.0	440	34
	0130	104	22000			64000	195				10.5			11.0	440	
	0230	112	23000			59200	203				10.5			11.5	440	
	0330	98	24000			67200	212				11.0			10.5	440	
	0430	116	22000	7000		64000	195	62			10.5	9.5		11.0	440	32
	0530	114	15000	6000		67200	133	53			10.0	9.5		11.5	440	33
	0630	118	14000	8000		65600	124	71			10.5	9.5		11.0	440	33
	0730	112	13000	8000		67200	115	71			10.0	9.5		11.0	440	33
	TOTAL	900	147000	36000		512000	1301	318		55054	88.0	47.5		88.5	3520	165
	AVG.	113	18375	7200		64000	163	64		6887	10.4	9.5		11.1	440	33
SECOND SHIFT	0830	112	14000	7200		64300	124	64			10.5	10.0		12.5	440	34
	0930	110	14200	7200		64200	124	64			10.5	10.0		12.5	440	34
	1030	114	8000	8000		65600	71	71			10.0	10.0		12.5	440	34
	1130	113	8000	8000		63000	71	71			10.0	10.0		12.5	420	34
	1230	124	8000	8000		64000	71	71			10.0	10.0		13.0	420	34
	1330	110				14000								13.0		
	1430	116	8000			62800	71				10.0			12.5	420	
	1530	116	8000	8000		62800	71	71			10.0	10.0		13.0	440	34
	TOTAL	915	68000	46400		510700	602	441		54914	71.0	60.0		10.5	3020	204
	AVG.	114	9714	7733		63838	86	69		* 6864	10.1	10.0		12.7	431	34
THIRD SHIFT	1630	116	4000	5000		54400	35	62			10.0	10.0		12.5	440	30
	1730	114	15000	7000		52000	133	62			10.0	10.0		12.5	440	30
	1830	118	19000			52800	168				11.0			12.5	440	
	1930	118	19000			56000	168				10.5			12.5	440	
	2030	118	23000	4000	2000	40000	203	35			10.5	9.5	9.0	12.5	440	30
	2120	119	26000	11000	23000	25600	230	97			11.0	10.0	10.5	9.5	440	24
	2220	119	28000	14000	20000		248	124			11.0	10.0	11.0		440	42
	2330	120	35000	14000	35000		265	124			11.0	10.0	11.0		440	42
	TOTAL	142	119000	52000	94000	276800	1450	564	10444	29723	84	59.5	40.5	21.5	3520	208
	AVG.	119	20500	9500	23500	46133	181	84	2611	4961	10.5	9.9	10.1	11.9	440	34
DAILY	TOTAL	2751	279000	139400	440000	1299500	3353	1233	10444	139731	298	167	40.5	26.8	10000	57
	AVG.	115	15142	8200	23500	59068	140	73	2611	6351	7.9	7.8	10.1	11.9	419	33

OPERATING DATA

	#1	FIRST SHIFT	#5	#1	SECOND SHIFT	#5	#1
A. STEAM FLOW FINAL (Integrator)	538527	752906	979344	539340	752449	985725	5418
B. STEAM FLOW START	535965	752906	979054	538527	752906	979344	53936
C. TOTAL STEAM PRODUCED	147000	36000	512000	68000	46400	510700	1146
D. LBS. STEAM PER UNIT OF FUEL							
E. SOOT BLOWN			0200			1000	2145
F. BLOW DOWN	TIME: 0100		GALS. 352 + 40 = 842	TIME: 0900		GALS. 352 + 1240 = 1720	TIME:
G. DEGREE DAY							
H. OPERATOR	(McPHEARSON)	GASPARD	WITTE	WILLIAMS	DEWEES	SEITZ	FAIR
I. FIREMAN							
J. TOTAL MANHOURS OPERATION		24			48		

13. REMARKS (Continue on reverse)

WC-GG-DA-0015

ASHES 0420-0530=490

OIL TRANSFER TO 9'3"

HANGER 2ND OPEN 0735-0745

WC-GG-DA-0820

ASHES-0820 > 1260

1120 > 1260

1545 > 105

W

AS

B/I

B

DATE

SIGNATURE OF CHIEF OPERATING ENGINEER

FR
10 FEB 89

DAILY STEAM BOILER PLANT OPERATING LOG

1. COMMAND

SAC

TIME HOUR	STEAM PRESS (PSIG)	STEAM PRODUCED (1000 Pounds)				FUEL USED				FLUE GAS			
		C				D				E			
		BOILER NO.				BOILER NO.				BOILER NO.			
A	B	1	2	3	15	1	2	3	15	1	2	13	15
0030	119	27000	8000		59200	239	71			10.5	10.0		10.5
0130	118	27000	10000		56000	239	82			10.0	10.0		10.0
0230	119	28000	10000		52800	248	88			10.0	10.5		10.5
0330	118	27000	10000		56000	239	88			10.0	10.5		10.0
0430	118	27000	9000		57000	239	80			10.5	10.5		10.0
0530	118	26500	8000		56800	234	71			10.5	10.5		10.0
0630	118	25000	8000		62400	221	71			10.5	10.5		10.0
0730	114	22000	8000		63500	195	71			10.0	10.0		10.0
TOTAL	640	204500	71000		463700	1854	628		49860	82.0	82.5		81.0
AVG.	117	26187	8875		57962	232	78		6233	10.2	10.3		10.1
0830	116	17500	8000		64000	155	71			12.0	11.5		12.6
0930	114	16000	8000		64000	142	71			12.0	11.5		12.2
1030	112		8000		64000		71				11.5		11.1
1130	111	11000	10000		64000	97	88			11.0	11.5		11.6
1230	108	17000			64000	150				11.5			14.2
1330	111	18000			64000	159				12.0			14.2
1430	106	18000			64000	159				12.0			14.0
1530	118	11000			64000	97				12.0			14.0
TOTAL	896	108500	34000		512000	959	301		55054	82.5	14.0		11.3
AVG.	112	13563	8500		64000	137	75		6892	11.8	11.5		13.9
1630	74	4000	2600		27000	354	230			11.0	11.0		10.0
1730	88	3600	2300		41000	319	204			11.5	10.5		11.5
1830	116	32000	8000		48000	283	71			11.0	10.5		11.5
1930	120	31000	10000		48000	274	89			12.0	11.0		11.0
2030	123	25000	8000		48000	221	71			11.5	10.0		11.5
2130	114	26000	8000		48000	230	71			11.5	10.6		11.5
2230	120	28000	8000		52800	248	71			11.5	10.0		12.0
2330	121	26000	8000		52800	230	71			11.5	10.0		11.5
TOTAL	876	244000	99000		366400	2159	878		39398	91.5	83.0		90.5
AVG.	110	30500	12375		45800	270	110		4925	11.4	10.4		11.3
DAILY TOTAL	2712	562000	204000		1342100	4972	1807		144312	25.6	21.5		28.28
AVG.	113	24435	10200		55921	216	90		6013	11.1	10.6		11.9

5. OPERATING DATA

	#1	FIRST SHIFT	#5	#1	SECOND SHIFT	#5	#
A. STEAM FLOW FINAL (Integrator)	522924	750338	944799	524984	750695	951472	524
B. STEAM FLOW START	519417	749321	938869	522924	750338	944799	524
C. TOTAL STEAM PRODUCED	209500	71000	463700	108500	34000	512000	244
D. LBS. STEAM PER UNIT OF FUEL							
E. SOOT BLOWN	0415	0420	0425	1230	1240	1245	20
F. BLOW DOWN	TIME: 0100	GALS: 352+420=772	TIME: 0900	GALS: 484+420=904	TIME:		
G. DEGREE DAY							
H. OPERATOR	McPHEARS	GASPARD	Williams	Schleppinger, Banner	Grooc		
I. FIREMAN				(Ertinear) Richards			
J. TOTAL MANHOURS OPERATION		16		48			

13. REMARKS (Continue on reverse)

WC-GG-DA-0015

ASHES 0305-0325=140

0410-0650=280

WC-GG-DA-0810

ASHES 0830-0900=210

ASHES 1530-1600=210

Blowdown #3 - 420.5 to the inside of G60.

Next at 200 approx at 0814 to 0830

DATE SIGNATURE OF CHIEF OPERATING ENGINEER

APPENDIX D
Coal Analysis

(This page left blank)

The laboratory data sheets were not suitable for reproduction; therefore, the coal analysis results are presented in the following table.

BOILER #	RUN #	STACK ID*	AS RECEIVED BTU/LB VALUE
3	1	SCB	11209
3	2	SCB	11281
3	3	SCB	11316
4	1	SCA	11433
4	2	SCA	11369
4	3	SCA	11365
5	1	SCB	11794
5	2	SCB	11463
5	3	SCB	11995
5	1	BP	11339
5	2	BP	11359
5	3	BP	11344

* SCA = SCRUBBER A
 SCB = SCRUBBER B
 BP = BYPASS

(This page left blank)

APPENDIX E
Boiler 3, Scrubber B Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: SCRUBBER B Stack diameter at ports: 5.0 (ft)



Distance A (ft) 7.0 (duct diameters) 1.4

Recommended number of traverse points as determined by
distance A: 20

Distance B (ft) 28 (duct diameters) 5.6

Recommended number of traverse points as determined by
distance B: 20

Number of traverse points used: 20



(Stack Geometry)

OEHL FORM 15
APR 78

PRELIMINARY SURVEY DATA SHEET NO. 2 (Velocity and Temperature Traverse)			
BASE GRISSEY AFB		DATE 13 FEB 89	
BOILER NUMBER #3 SCRUBBER B			
INSIDE STACK DIAMETER 60		Inches	
STATION PRESSURE 29.975		In Hg	
STACK STATIC PRESSURE .16		In H2O	
SAMPLING TEAM			
TRAVERSE POINT NUMBER	VELOCITY HEAD, V_p IN H2O	$\sqrt{V_p} \propto$ CYCLONIC	STACK TEMPERATURE (°F)
1	.16	23 21	108
2	.16	23 22	108
3	.16	23 20	108
4	.16	10 11	109
5	.17	0 5	108
6	.23	8 6	108
7	.23	10 10	109
8	.26	15 12	108
9	.26	20 19	108
10	.275	18 20	108
		AVG = 15°	
FPS = 27			
Ts = 108			
NOZ DIA = .3221			
AVERAGE			

START 10:13 1058 STOP 1128


PARTICULATE SAMPLING DATA SHEET

SCHEMATIC OF STACK CROSS SECTION

$$H = \left[\frac{5130 \cdot P \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_a} \cdot V_p$$

$$^{\circ}R = ^{\circ}F + 460$$

EQUATIONS



RUN NUMBER 30123
#1 Scrubber B

DATE 13 Feb 89

PLANT

BASE
Grissom AFB

SAMPLE BOX NUMBER

Nutech #1

METER BOX NUMBER

Nutech #1

Q_{avg}

Static ΔP = -.16

AMBIENT TEMP
 STATION PRESS 28.975
 HEATER BOX TEMP 248 ± 25
 PROBE HEATER SETTING 190
 PROBE LENGTH 72
 NOZZLE AREA (A) .320
 C_p .84
 DRY GAS FRACTION (F_d)

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STAPLE PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			(°F)	(°F)				IN	AVG (T _m) (°F)		
1	0	3.0	108		.095	.99	530.0	87	85	247	48
2	3	4.6	106		.122	2.31	530.0	87	86	251	48
3	6	4.8	105		.121	2.22	530.0	91	87	250	50
4	9	4.9	106		.121	2.22	530.0	94	87	250	52
5	12	5.1	108		.124	2.32	530.0	98	88	252	54
6	15	5.3	107		.125	2.54	530.0	100	89	251	55
7	18	5.3	107		.125	2.66	530.0	101	90	248	57
8	21	5.6	107		.145	2.65	530.0	101	90	245	59
9	24	5.9	107		.126	2.61	530.0	102	91	247	60
10	27	5.9	108		.126	2.77	530.0	102	92	244	59
1	30 stop	4.3	106		.18	1.91	552.180	94	92	243	47
2	3	4.5	105		.175	1.87	552.160	98	93	241	47
3	6	4.4	106		.17	1.81		106	93	243	49
4	9	4.6	107		.175	1.87		102	94	244	50
5	12	5.0	107		.205	2.24		104	95	243	51
6	15	5.4	108		.25	2.60		105	96	242	52
7	18	6.0	107		.245	2.63		100	97	241	52
8	21	6.0	107		.25	2.69		107	97	243	53
9	24	6.6	107		.28	3.01		106	98	241	54
10	27	6.9	107		.28	3.02		107	98	242	56
30 stop							575.218				
Total 11.1156											21.6510

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE GRISMAN 1FB	DATE 12 FEB 89	RUN NUMBER ONE
BUILDING NUMBER POWER PLANT	SOURCE NUMBER BOILER 3 SCRUBBER B	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	.3451	.2918	0.0533
ACETONE WASHINGS (Probe, Front Half Filter)	96.6805 96.6805	96.6641 96.6641	0.0164 0.0164
BACK HALF (If needed)			
Total Weight of Particulates Collected			.0697 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	243.0	200.0	43.0
IMPINGER 2 (H2O)	211.0	200.0	11.0
IMPINGER 3 (Dry)	1.5	0.0	1.5
IMPINGER 4 (Silica Gel)	208.4	200.0	8.4
Total Weight of Water Collected			63.9 gm


III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	4.4	4.4	4.4		4.4
VOL % O ₂	14.4	14.4	14.2		14.3
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

START 1208 1243 STOP 1:13 Soot blow

PARTICULATE SAMPLING DATA SHEET

SCHEMATIC OF STACK CROSS SECTION



AMBIENT TEMP	
STATION PRESS	28.975
HEATER BOX TEMP	248 ± 25
PROBE HEATER SETTING	150
PROBE LENGTH	72
NOZZLE AREA (A)	320
Cp	.84
DRY GAS FRACTION (Pd)	

$$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_a}$$

$$^{\circ}R = ^{\circ}F + 460$$

Pitot good
 Preleak 15" Hg good
 Postleak 15" Hg good
 SOOT BLOW
 Static ΔP = .16

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STACK PRESSURE (in. H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in. H ₂ O)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			IN (°F)	OUT (°F)				IN (°F)	OUT (°F)		
1	9	4.2	106	106	.22	2.35	515.549	98	96	242	42
2	3	4.3	104	104	.225	2.42		100	98	244	43
3	6	4.5	105	105	.215	2.35		103	98	244	45
4	9	4.5	106	106	.215	2.32		105	99	243	46
5	12	4.5	106	106	.22	2.40		106	99	244	48
6	15	4.6	107	107	.22	2.37		107	100	244	50
7	18	4.9	107	107	.24	2.59		108	100	244	51
8	21	4.9	108	108	.24	2.59		109	101	241	53
9	24	4.9	109	109	.225	2.43		109	101	242	55
10	27	4.8	111	111	.20	2.15	598.260	110	101	241	56
30 sec											
1	0	4.0	105	105	.18	1.95	598.260	105	102	241	50
2	3	4.0	108	108	.165	1.78		107	102	242	52
3	6	4.0	110	110	.145	1.56		108	102	241	53
4	9	4.1	109	109	.155	1.67		109	102	240	53
5	12	4.9	108	108	.195	2.11		110	103	241	54
6	15	5.6	109	109	.235	2.55		112	103	243	54
7	18	5.6	108	108	.23	2.50		112	103	242	54
8	21	5.9	109	109	.235	2.55		112	104	241	55
9	24	6.4	108	108	.26	2.82		112	104	240	56
10	27	6.4	109	109	.26	2.82		112	104	242	56
30 sec											
		15 108	104	104	ΔH = 2.38	19515	11.0080	Total FP			
								44.5310			

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE GRISSEM AFB		DATE 13 FEB 89		RUN NUMBER Two	
BUILDING NUMBER POWER PLANT			SOURCE NUMBER Boiler 3 SCRUBBER B		
I. PARTICULATES					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	.3423	.2966	0.0517		
ACETONE WASHINGS (Probe, Front Half Filter)	98.7417 98.7417	98.7350	.0067		
BACK HALF (if needed)					
			Total Weight of Particulates Collected		.0584 gm
II. WATER					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	242.6	200.0	42.6		
IMPINGER 2 (H2O)	216.6	200.0	16.6		
IMPINGER 3 (Dry)	2.5	0.0	2.5		
IMPINGER 4 (Silica Gel)	211.5	200.0	11.5		
			Total Weight of Water Collected		72.6 gm
III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	4.2	4.2	4.2		4.2
VOL % O ₂	13.6	13.6	13.6		13.6
VOL % CO					
VOL % N ₂					
Vol % N ₂ = (100 - % CO ₂ - % O ₂ - % CO)					

START 1:47 2:22 STOP 2:52

PARTICULATE SAMPLING DATA SHEET

SCHEMATIC OF STACK CROSS SECTION

RUN NUMBER
#3 SC01413

DATE
13 Feb 89

PLANT

BASE

GRISSEMAN AFB

SAMPLE BOX NUMBER


Nuclech #1

METER BOX NUMBER

Nuclech #1

Q_{avg}/Q_m

Co



EQUATIONS

$$^{\circ}R = ^{\circ}F + 460$$

$$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$$

Pilot - good
Preleak - 15" Hg Good
Post leak - 15" Hg Good

Static $\Delta P = .16$

AMBIENT TEMP

STATION PRESS

28.915

in Hg

HEATER BOX TEMP

248 ± 25

°F

PROBE HEATER SETTING

190

PROBE LENGTH

72

in

NOZZLE AREA (A)

.320

sq ft

Co

DRY GAS FRACTION (F_D)

.84

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STACK PRESSURE (in. H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in. H ₂ O)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			#1 (°F)	(T _m) (°F)				IN (°F)	AVG (T _m) (°F)		
1	0	7.0	105		.21	2.26	620.418	100		235	44
2	3	7.0	108		.215	2.31		102		236	41
3	6	7.0	109		.215	2.30		103		237	41
4	9	7.1	108		.21	2.26		105		237	43
5	12	8.0	109		.22	2.37		106		238	45
6	15	8.9	108		.24	2.54		107		239	45
7	18	9.0	109		.23	2.48		107		239	47
8	21	9.1	109		.235	2.53		107		239	48
9	24	9.4	111		.235	2.41		107		239	49
10	27	9.1	110		.195	2.09	642.885	106		239	50
1	30 stop										
1	0	8.6	108		.185	1.98	642.886	102		239	46
2	3	8.2	108		.17	1.83		104		240	47
3	6	7.9	109		.155	1.66		105		239	48
4	9	8.4	109		.17	1.83		107		241	48
5	12	9.1	109		.19	2.05		108		239	48
6	15	11.4	110		.23	2.43		109		239	48
7	18	11.2	109		.22	2.48		109		242	48
8	21	12.0	109		.235	2.53		109		241	50
9	24	13.9	110		.215	2.46		109		240	51
10	27	14.1	110		.23	3.01	664.897	109		241	52
	30 stop										

OEHL FORM MAY 78 18

m = 103

ts = 109

ΔH = 2.32

11.0484

total

44.4790

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE Grissan AFB		DATE 13 FEB 89		RUN NUMBER THREE	
BUILDING NUMBER POWER PLANT			SOURCE NUMBER Boiler 3 SCRUBBER B		
I. PARTICULATES					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	.3681	.2969	0.0772		
ACETONE WASHINGS (Probe, Front Half Filter)	103.5373	103.5278	0.0095		
BACK HALF (if needed)					
			Total Weight of Particulates Collected		.0867 gm
II. WATER					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	253.0	200.0	53.0		
IMPINGER 2 (H2O)	210.0	200.0	10.0		
IMPINGER 3 (Dry)	0	0.0	0		
IMPINGER 4 (Silica Gel)	208.0	200.0	8		
			Total Weight of Water Collected		71.0 gm
III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	4.0	4.0	4.0		4.0
VOL % O ₂	14.0	14.0	13.8		13.9
VOL % CO					
VOL % N ₂					
Vol % N ₂ = (100% - % CO ₂ - % O ₂ - % CO)					

VISIBLE EMISSION OBSERVATION FORM

No. *Run #1*






COMPANY NAME <i>Carzon AFB Heating Plant</i>		
STREET ADDRESS <i>Box 223</i>		
CITY <i>Grissom AFB</i>	STATE <i>In</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Boiler #3</i>	OPERATING MODE <i>95-100%</i>
CONTROL EQUIPMENT <i>Scrubber B (wet)</i>	OPERATING MODE

DESCRIBE EMISSION POINT <i>Fiberglass stack 60" diameter</i>	
HEIGHT ABOVE GROUND LEVEL <i>95'</i>	HEIGHT RELATIVE TO OBSERVER Start <i>95'</i> End <i>✓</i>
DISTANCE FROM OBSERVER Start <i>300'</i> End <i>✓</i>	DIRECTION FROM OBSERVER Start <i>NW</i> End <i>✓</i>

DESCRIBE EMISSIONS	
Start <i>Coning</i> End	
EMISSION COLOR Start <i>2</i> End <i>✓</i>	IF WATER DROPLET PLUME Attached <i>✓</i> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>100</i> End <i>✓</i>	

DESCRIBE PLUME BACKGROUND	
Start <i>Stratus Layer</i> End <i>✓</i>	
BACKGROUND COLOR Start <i>Gray</i> End <i>✓</i>	SKY CONDITIONS Start <i>OVC</i> End <i>✓</i>
WIND SPEED Start <i>20 mph</i> End <i>✓</i>	WIND DIRECTION Start <i>SW</i> End <i>✓</i>
AMBIENT TEMP Start <i>34</i> End <i>✓</i>	WET BULB TEMP <i>90%</i>

Stack with Plume  Sun  Wind 	SOURCE LAYOUT SKETCH 	Draw North Arrow 
---	---	--

ADDITIONAL INFORMATION

OBSERVATION DATE <i>13 Feb 88</i>				START TIME <i>1106</i>	END TIME <i>1112</i>
SEC	0	15	30	45	COMMENTS
MIN					
1	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
2	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
3	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
4	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
5	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
6	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <i>Paul T. Scott</i>	DATE <i>13 Feb 88</i>
OBSERVER'S SIGNATURE <i>Paul T. Scott</i>	
ORGANIZATION <i>USAF CEHL/ECG</i>	
CERTIFIED BY <i>Inspector General Dwyer</i>	DATE <i>14 Sept 88</i>

VISIBLE EMISSION OBSERVATION FORM

No. TWO

COMPANY NAME <u>Grissom Heating Plant</u>		
STREET ADDRESS <u>Bldg 223</u>		
CITY <u>Grissom AFB</u>	STATE <u>In</u>	ZIP <u>46971</u>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <u>Boiler #3</u>	OPERATING MODE <u>95-100%</u>
CONTROL EQUIPMENT <u>Wet Scrubber #B</u>	OPERATING MODE

DESCRIBE EMISSION POINT <u>Fiberglass stack 60" diam</u>	
HEIGHT ABOVE GROUND LEVEL <u>95'</u>	HEIGHT RELATIVE TO OBSERVER Start <u>95'</u> End <input checked="" type="checkbox"/>
DISTANCE FROM OBSERVER Start <u>300'</u> End <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER Start <u>NU</u> End <input checked="" type="checkbox"/>

DESCRIBE EMISSIONS Start <u>lofting</u> End <u>Extinguishing</u>	
EMISSION COLOR Start <u>N/A</u> End	IF WATER DROPLET PLUME? Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <u>100'</u> End <input checked="" type="checkbox"/>	

DESCRIBE PLUME BACKGROUND Start <u>Gray Sky</u> End <u>STRATUS</u>	
BACKGROUND COLOR Start <u>Gray</u> End <input checked="" type="checkbox"/>	SKY CONDITIONS Start <u>OVC</u> End <input checked="" type="checkbox"/>
WIND SPEED Start <u>10</u> End <input checked="" type="checkbox"/>	WIND DIRECTION Start <u>SW</u> End <input checked="" type="checkbox"/>
AMBIENT TEMP Start <u>35</u> End <input checked="" type="checkbox"/>	WET BULB TEMP <u>95</u>

Stack with Plume	SOURCE LAYOUT SKETCH	Draw North Arrow
Sun		
Wind		

ADDITIONAL INFORMATION

OBSERVATION DATE <u>13 Feb</u>		START TIME <u>1235</u>		END TIME <u>1251</u>	COMMENTS
SEC MIN	0	15	30	45	
1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<u>sat blow at 1239</u>
5	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
8	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
9	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
10	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
11	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
12	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
13	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
14	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
15	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <u>Paul T. Scott</u>	
OBSERVER'S SIGNATURE <u>Paul T. Scott</u>	DATE <u>13 Feb 89</u>
ORGANIZATION <u>USAF OEHLE/ECQ</u>	
CERTIFIED BY <u>Texas Air Control Board</u>	DATE <u>16 Sept 89</u>

VISIBLE EMISSION OBSERVATION FORM

No. **THREE**

COMPANY NAME Grissom Heating Plant		
STREET ADDRESS Blg 223		
CITY Grissom AFB	STATE IN	ZIP 46971
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT Coal-Fired Boiler #3	OPERATING MODE 95-100%
CONTROL EQUIPMENT Wet Scrubber B	OPERATING MODE

DESCRIBE EMISSION POINT Fluegas stack 60" dia	
HEIGHT ABOVE GROUND LEVEL 95'	HEIGHT RELATIVE TO OBSERVER Start 95 End 1
DISTANCE FROM OBSERVER Start 300' End ✓	DIRECTION FROM OBSERVER Start NW End ✓

DESCRIBE EMISSIONS Start lighting End ✓	
EMISSION COLOR Start gray End ✓	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start 100' End ✓	

DESCRIBE PLUME BACKGROUND Start Clouds - Stratus End ✓	
BACKGROUND COLOR Start Gray End ✓	SKY CONDITIONS Start OVC End ✓
WIND SPEED Start 10 End ✓	WIND DIRECTION Start SW End ✓
AMBIENT TEMP Start 36 End ✓	WET BULB TEMP 95

Stack with Plume Sun Wind	SOURCE LAYOUT SKETCH Draw North Arrow
---------------------------------	--

Observer's Position

140°

Sun Location Line

OBSERVATION DATE 13 Feb 89		START TIME 1433				COMMENTS
SEC	MIN	0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

OBSERVER'S NAME (PRINT) Paul T. Scott	
OBSERVER'S SIGNATURE Paul T. Scott	DATE 13 Feb 89
ORGANIZATION USAF OEHLE/ECW	
CERTIFIED BY Texas Air Control Board	DATE 16 Sept 89

ADDITIONAL INFORMATION	56
------------------------	----

APPENDIX F
Boiler 4, Scrubber A Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: SCRUBBER A Stack diameter at ports: 5.0 (ft)



Distance A (ft) 7.0 (duct diameters) 1.4

Recommended number of traverse points as determined by
distance A: 20

Distance B (ft) 28 (duct diameters) 5.6

Recommended number of traverse points as determined by
distance B: 20

Number of traverse points used: 20



(Stack Geometry)

OEHL FORM 15
APR 78

PRELIMINARY SURVEY DATA SHEET NO. 2 (Velocity and Temperature Traverse)			
BASE GRISCOM AFB		DATE 14 FEB 79	
BOILER NUMBER #4 SCRUBBER A			
INSIDE STACK DIAMETER 60		Inches	
STATION PRESSURE 29.381		In Hg	
STACK STATIC PRESSURE - .29		In H2O	
SAMPLING TEAM			
TRAVERSE POINT NUMBER	VELOCITY HEAD, V_p IN H2O	$\sqrt{V_p}$ α CYCLONE	STACK TEMPERATURE (°F)
1	.19	25 23	102
2	.21	20 22	102
3	.22	14 15	102
4	.27	5 7	106
5	.30	5 5	102
6	.38	5 5	103
7	.43	10 9	102
8	.37	10 11	102
9	.33	18 17	102
10	.25	25 25	102
		AVE = 114°	
FPS - 32			
Ts - 103			
NOZZLE DIA = 0.2899			
AVERAGE			

2203

1021 STOP 1051


START 0944

$\Delta H = 2.07$

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER #1, October 4, Scribble A		EQUATIONS $OR = OF + 460$ $H = \left[\frac{5130 \cdot F \cdot C \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_b} \cdot V_p$		AMBIENT TEMP	
DATE 14 Feb 89				STATION PRESS 29.381	
PLANT Grissom AFB				HEATER BOX TEMP 248 ± 25	
SAMPLE BOX NUMBER Nutech #1				PROBE HEATER SETTING 190	
METER BOX NUMBER Nutech #1				PROBE LENGTH 96	
Qm/Qm				NOZZLE AREA (A) 30.3	
Co				Cp 84	
				DRY GAS FRACTION (Fd)	

SCHEMATIC OF STACK CROSS SECTION



Pitot good
Prehook ok 15" Hg good
Posthook ok 19" Hg good

Static AP = -29

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP (°F)		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPING OUTLET TEMP (°F)
			#1 (OF)	#2 (OF)				IN	OUT		
1	0	3.8	97		.105	.94	665.254	90	88	241	33
2	3	4.6	96		.145	1.30		91	89	246	24
3	6	5.4	91		.2	1.81		94	89	246	34
4	9	6.4	88		.225	2.05		96	90	247	33
5	12	8.1	85		.30	2.76		98	91	249	35
6	15	13.8	89		.48	4.39		100	91	249	39
7	18	17.5	91		.85	5.03		101	92	250	45
8	21	17.8	93		.63	5.74		102	92	249	48
9	24	17.9	93		.68	5.29 Fok		102	93	248	48
10	27	17.9	95		.47	4.27	689.511	101	93	245	51
30 stop											
1	0	8.9	90		.26	2.37	689.512	95	93	247	49
2	3	11.0	90		.315	2.88		98	94	242	50
3	6	10.0	85		.305	2.80		99	94	244	53
4	9	10.1	95		.355	3.23		101	94	243	54
5	12	11.5	95		.385	3.50		102	94	243	55
6	15	11.2	95		.375	3.42		104	95	244	57
7	18	8.8	95		.285	2.60		105	95	244	59
8	21	7.5	94		.245	2.24		105	96	241	57
9	24	6.9	94		.22	2.01		105	96	241	55
10	27	6.0	93		.18	1.65	713.648	106	96	240	54
36 stop											

OEHL FORM MAY 78 18
1m = 96 Ts 93
TPSIS = 13.1985
Total TFS = 42.3930

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>CRISCOM AFB</i>		DATE <i>14 Feb 89</i>		RUN NUMBER <i>0118</i>	
BUILDING NUMBER <i>TOWER PLANT</i>			SOURCE NUMBER <i>Boiler 4 Scrubber A</i>		
I. PARTICULATES					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)		
FILTER NUMBER	<i>.3149</i>	<i>.2898</i>	<i>0.0251</i>		
ACETONE WASHINGS (Probe, Front Half Filter)	<i>100.0882</i>	<i>100.0520</i>	<i>0.0362</i>		
BACK HALF (If needed)					
		Total Weight of Particulates Collected		<i>0.0613 gm</i>	
II. WATER					
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)		
IMPINGER 1 (H2O)	<i>230.0</i>	<i>200.0</i>	<i>30.0</i>		
IMPINGER 2 (H2O)	<i>212.0</i>	<i>200.0</i>	<i>12.0</i>		
IMPINGER 3 (Dry)	<i>2.5</i>	<i>0.0</i>	<i>2.5</i>		
IMPINGER 4 (Silica Gel)	<i>214.1</i>	<i>200.0</i>	<i>14.1</i>		
		Total Weight of Water Collected		<i>58.6 gm</i>	
III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>3.0</i>	<i>3.0</i>	<i>3.0</i>		<i>3.0</i>
VOL % O ₂	<i>17.6</i>	<i>17.6</i>	<i>17.6</i>		<i>17.6</i>
VOL % CO					
VOL % N ₂					
Vol % N ₂ = (100% - % CO ₂ - % O ₂ - % CO)					

START 11:24

STOP 12:29

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER				SCHEMATIC OF STACK CROSS SECTION				EQUATIONS				AMBIENT TEMP			
#2 Boiler 4 Scrubber A								$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$				STATION PRESS 29.381 in Hg			
DATE				14 Feb 89				$OR = OF + 460$				HEATER BOX TEMP 248 ± 25 OF			
PLANT								PROBE HEATER SETTING 190				PROBE LENGTH 96 in			
BASE				Grissom AFB				NOZZLE AREA (A) .303 sq ft				DRY GAS FRACTION (FG)			
SAMPLE BOX NUMBER				Nutech #1				Pitot - good Prelock dk 15" Hg good Postlock dk 18" Hg good							
METER BOX NUMBER				Nutech #1											
QW/Qm															
Co								Static AP = 29							
TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATION PRESS (in H ₂ O)	STATION TEMP (°F)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	IN (°F)	OUT (°F)	SAMPLE BOX TEMP (°F)	IMPIGNER OUTLET TEMP (°F)					
1	0	5.1	93	.185	1.68	714.255	94	94	235	34					
2	3	6.0	92	.22	2.00		95	94	236	34					
3	6	6.8	90	.235	2.15		96	94	237	35					
4	9	7.8	86	.27	2.49		99	94	239	37					
5	12	8.3	92	.32	2.92		100	94	238	43					
6	15	14.1	91	.475	4.35		101	94	239	47					
7	18	17.9	92	.56	5.13		102	95	240	51					
8	21	17.9	94	.57	5.20		102	95	240	61					
9	24	17.9	96	.645	5.86		102	95	235	63					
10	27	17.9	96	.52	4.13	740.079	102	95	240	62					
11	30 stop														
1	0	11.0	92	.35	3.19	740.079	98	95	235	52					
2	3	12.4	96	.39	3.54		100	95	241	53					
3	6	13.2	97	.37	3.55		104	96	240	54					
4	9	13.9	98	.40	3.64		105	96	239	56					
5	12	12.1	98	.41	3.73		107	96	241	58					
6	15	8.9	99	.29	2.64		107	97	243	59					
7	18	7.2	99	.245	2.23		108	98	243	58					
8	21	6.8	100	.225	2.05		109	98	242	56					
9	24	6.8	97	.22	2.01		104	98	243	55					
10	27	6.1	99	.195	1.78	764.675	110	99	242	54					
11	30 stop														

OEHL FORM MAY 78 18
 1 m = 99
 1 s = 45
 ΔH = 3.24
 P_{ST} = 13.8003
 Total P_{ST} = 50.42

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>CRISSEAN AFB</i>	DATE <i>14 FEB 89</i> ♥	RUN NUMBER <i>Two</i>
BUILDING NUMBER <i>POWER PLANT</i>		SOURCE NUMBER <i>Boiler 4 SCRUBBER A</i>

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.3143</i>	<i>.2889</i>	<i>0.0254</i>
ACETONE WASHINGS (Probe, Front Half Filter)	<i>102.2120</i>	<i>102.2047</i>	<i>0.0073</i>
BACK HALF (if needed)			
	Total Weight of Particulates Collected		<i>0.0327 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>232.0</i>	<i>200.0</i>	<i>32.0</i>
IMPINGER 2 (H2O)	<i>212.0</i>	<i>200.0</i>	<i>12.0</i>
IMPINGER 3 (Dry)	<i>2.0</i>	<i>0.0</i>	<i>2.0</i>
IMPINGER 4 (Silica Gel)	<i>216.1</i>	<i>200.0</i>	<i>16.1</i>
	Total Weight of Water Collected		<i>62.1 gm</i>

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>2.8</i>	<i>2.8</i>	<i>2.8</i>		<i>2.8</i>
VOL % O ₂	<i>15.4</i>	<i>15.4</i>	<i>15.2</i>		<i>15.3</i>
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>CRISSON AFB</i>	DATE <i>4 FEB 89</i> ♥	RUN NUMBER <i>THREE</i>
BUILDING NUMBER <i>POWER PLANT</i>		SOURCE NUMBER <i>Boiler 4 SCRUBBER A</i>

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.3132</i>	<i>0.2875</i>	<i>0.0257</i>
ACETONE WASHINGS (Probe, Front Half Filter)	<i>105.3842</i>	<i>105.3784</i>	<i>0.0058</i>
BACK HALF (if needed)			
Total Weight of Particulates Collected			<i>0.0315</i> <i>0.0358</i> gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	<i>209.0</i> <i>200.0</i>	<i>200.0</i>	<i>9.0</i> <i>10.0</i>
IMPINGER 2 (H2O)	<i>224.0</i>	<i>200.0</i>	<i>24.0</i>
IMPINGER 3 (Dry)	<i>10.0</i>	<i>0.0</i>	<i>10.0</i>
IMPINGER 4 (Silica Gel)	<i>210.7</i>	<i>200.0</i>	<i>10.7</i>
Total Weight of Water Collected			<i>53.7</i> gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>2.2</i>	<i>2.2</i>	<i>2.2</i>		<i>2.2</i>
VOL % O ₂	<i>15.4</i>	<i>15.4</i>	<i>15.4</i>		<i>15.4</i>
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverse)

BASE

Grissom AFB

DATE

14 Feb 89

BOILER NUMBER

44

INSIDE STACK DIAMETER

604

Inches

STATION PRESSURE

29.381

In Hg

STACK STATIC PRESSURE

~~25~~-29

In H₂O

SAMPLING TEAM

TRAVERSE POINT NUMBER	VELOCITY HEAD, V_p IN H ₂ O	$\sqrt{V_p} \propto$	STACK TEMPERATURE ($^{\circ}$ F)
1	.18	25	102
2	.21	20	102
3	.22	14	102
4	.27	5	106
5	.30	5	102
6	.38	5	103
7	.43	10	102
8	.37	10	102
9	.33	18	102
10	.25	25	102
FSP = 32			
T _s = 103			
Nozzle A _n = .2899			
AVERAGE			

VISIBLE EMISSION OBSERVATION FORM

No. *Run #1*


COMPANY NAME <i>Grissom AFB Hatz Plant</i>		
STREET ADDRESS <i>Bldg 223</i>		
CITY <i>Grissom AFB</i>	STATE <i>In</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Boal Field Bldg 4</i>	OPERATING MODE <i>95-100%</i>
CONTROL EQUIPMENT <i>Wet Scrubber A</i>	OPERATING MODE

DESCRIBE EMISSION POINT <i>Fiber Glass Stack 60" diameter</i>	
HEIGHT ABOVE GROUND LEVEL <i>95</i>	HEIGHT RELATIVE TO OBSERVER Start <i>95</i> End <i>✓</i>
DISTANCE FROM OBSERVER Start <i>300</i> End <i>✓</i>	DIRECTION FROM OBSERVER Start <i>NE</i> End <i>✓</i>

DESCRIBE EMISSIONS Start <i>Lofting</i> End <i>✓</i>	
EMISSION COLOR Start <i>N/A</i> End <i>✓</i>	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>150</i> End <i>✓</i>	

DESCRIBE PLUME BACKGROUND Start <i>SKY</i> End <i>✓</i>	
BACKGROUND COLOR Start <i>Blue</i> End <i>✓</i>	SKY CONDITIONS Start <i>SC</i> End <i>✓</i>
WIND SPEED Start <i>5</i> End <i>✓</i>	WIND DIRECTION Start <i>NNW</i> End <i>✓</i>
AMBIENT TEMP Start <i>35</i> End <i>✓</i>	WET BULB TEMP <i>65</i>



ADDITIONAL INFORMATION

OBSERVATION DATE <i>14 Feb 89</i>					START TIME <i>1026</i>	END TIME <i>1032</i>
SEC MIN	0	15	30	45	COMMENTS	
1	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>		
2	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>		
3	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>		
4	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>		
5	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>		
6	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>		
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

OBSERVER'S NAME (PRINT) <i>Paul T. Scott</i>	
OBSERVER'S SIGNATURE <i>Paul T. Scott</i>	DATE <i>14 Feb 89</i>
ORGANIZATION <i>USAF OEH/ECQ</i>	
CERTIFIED BY <i>Texas Air Control Board</i>	DATE <i>16 Feb 89</i>

VISIBLE EMISSION OBSERVATION FORM

No. TWØ

COMPANY NAME <i>Grissom AFB Heating</i>		
STREET ADDRESS <i>Bldg 223</i>		
CITY <i>Grissom AFB</i>	STATE <i>IN</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Coal-Fired Boiler #4</i>	OPERATING MODE <i>95-100%</i>
CONTROL EQUIPMENT <i>Wat Scrubber A</i>	OPERATING MODE

DESCRIBE EMISSION POINT <i>Em. glass stack 60" diameter</i>	
HEIGHT ABOVE GROUND LEVEL <i>95'</i>	HEIGHT RELATIVE TO OBSERVER Start <i>95'</i> End <i>✓</i>
DISTANCE FROM OBSERVER Start <i>300'</i> End <i>✓</i>	DIRECTION FROM OBSERVER Start <i>NW</i> End <i>✓</i>

DESCRIBE EMISSIONS Start <i>Lofting</i> End <i>✓</i>	
EMISSION COLOR Start <i>N/A</i> End <i>✓</i>	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>100'</i> End <i>✓</i>	

DESCRIBE PLUME BACKGROUND Start <i>SKY</i> End <i>✓</i>	
BACKGROUND COLOR Start <i>Blue/white</i> End <i>✓</i>	SKY CONDITIONS Start <i>BKN CI</i> End <i>✓</i>
WIND SPEED Start <i>5</i> End <i>✓</i>	WIND DIRECTION Start <i>NNE</i> End <i>✓</i>
AMBIENT TEMP Start <i>39</i> End <i>✓</i>	WET BULB TEMP <i>65</i>

<p>Stack with Plume </p> <p>Sun </p> <p>Wind </p>	<p>SOURCE LAYOUT SKETCH</p> <p>Draw North Arrow </p>
---	--

OBSERVATION DATE <i>14 Feb 88</i>				START TIME <i>1212</i>	END TIME <i>1218</i>
SEC	0	15	30	45	COMMENTS
MIN					
1	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
2	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
3	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
4	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
5	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
6	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <i>Paul J. Scott</i>	DATE <i>14 Feb 88</i>
OBSERVER'S SIGNATURE <i>Paul J. Scott</i>	
ORGANIZATION <i>USAF CEHL/ECW</i>	
CERTIFIED BY <i>12xw! Air Control Board</i>	DATE <i>16 Feb 88</i>

ADDITIONAL INFORMATION	70
------------------------	----

VISIBLE EMISSION OBSERVATION FORM

No. **THREE**



COMPANY NAME Grisson AFB Healy Plant		
STREET ADDRESS Bld 227		
CITY Grisson AFB	STATE IN	ZIP
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT Coal Fired Boiler #4	OPERATING MODE 95-100%
CONTROL EQUIPMENT Wet Scrubber A	OPERATING MODE

DESCRIBE EMISSION POINT Fiberglass stack w/ dust	
HEIGHT ABOVE GROUND LEVEL 95	HEIGHT RELATIVE TO OBSERVER Start 95 End <input checked="" type="checkbox"/>
DISTANCE FROM OBSERVER Start 350 End <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER Start N End <input checked="" type="checkbox"/>

DESCRIBE EMISSIONS Start loftm End <input checked="" type="checkbox"/>	
EMISSION COLOR Start gray End <input checked="" type="checkbox"/>	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start 100' End <input checked="" type="checkbox"/>	

DESCRIBE PLUME BACKGROUND Start SKY End <input checked="" type="checkbox"/>	
BACKGROUND COLOR Start Blue End <input checked="" type="checkbox"/>	SKY CONDITIONS Start SCC End <input checked="" type="checkbox"/>
WIND SPEED Start 5 End <input checked="" type="checkbox"/>	WIND DIRECTION Start NE End
AMBIENT TEMP Start 39 End <input checked="" type="checkbox"/>	WET BULB TEMP N/A
	RH, percent 65

Stick with Plume <input checked="" type="checkbox"/> Sun <input checked="" type="checkbox"/> Wind <input checked="" type="checkbox"/>	SOURCE LAYOUT SKETCH Draw North Arrow  
---	---

ADDITIONAL INFORMATION	71
------------------------	----

OBSERVATION DATE				START TIME		END TIME
14 Feb 89				1337		1349
SEC	0	15	30	45	COMMENTS	
MIN						
1	0	0	0	0		
2	0	0	0	0	South blow at 1338	
3	5	5	5	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	0	0		
10	0	0	0	0		
11	0	0	0	0		
12	0	0	0	0		
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

OBSERVER'S NAME (PRINT) Paul T. Scott	DATE 14 Feb 89
OBSERVER'S SIGNATURE Paul T. Scott	
ORGANIZATION USAF OEHZ	
CERTIFIED BY Texas Air Control Board	DATE 16 Sept 89

(This page left blank)

APPENDIX G
Boiler 5, Scrubber B Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: SCRUBBER B Stack diameter at ports: 5.0 (ft)

Distance A (ft) 7.0 (duct diameters) 1.4

Recommended number of traverse points as determined by



distance A: 20

Distance B (ft) 28 (duct diameters) 5.6

Recommended number of traverse points as determined by

distance B: 20

Number of traverse points used: 20



PRELIMINARY SURVEY DATA SHEET NO. 1

(Stack Geometry)

BASE

GRISSOM

PLANT

CENTRAL HEAT PLANT

DATE _____

10 FEB 89

SAMPLING TEAM

SOURCE TYPE AND MAKE	
1	1
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10
11	11
12	12
13	13
14	14
15	15
16	16
17	17
18	18
19	19
20	20
21	21
22	22
23	23
24	24
25	25
26	26
27	27
28	28
29	29
30	30
31	31
32	32
33	33
34	34
35	35
36	36
37	37
38	38
39	39
40	40
41	41
42	42
43	43
44	44
45	45
46	46
47	47
48	48
49	49
50	50
51	51
52	52
53	53
54	54
55	55
56	56
57	57
58	58
59	59
60	60
61	61
62	62
63	63
64	64
65	65
66	66
67	67
68	68
69	69
70	70
71	71
72	72
73	73
74	74
75	75
76	76
77	77
78	78
79	79
80	80
81	81
82	82
83	83
84	84
85	85
86	86
87	87
88	88
89	89
90	90
91	91
92	92
93	93
94	94
95	95
96	96
97	97
98	98
99	99
100	100

SOURCE NUMBER	DATE	DESCRIPTION	AMOUNT	CHECK NUMBER	ACCOUNT NUMBER
1	10/1/58
2	10/1/58
3	10/1/58
4	10/1/58
5	10/1/58
6	10/1/58
7	10/1/58
8	10/1/58
9	10/1/58
10	10/1/58
11	10/1/58
12	10/1/58
13	10/1/58
14	10/1/58
15	10/1/58
16	10/1/58
17	10/1/58
18	10/1/58
19	10/1/58
20	10/1/58
21	10/1/58
22	10/1/58
23	10/1/58
24	10/1/58
25	10/1/58
26	10/1/58
27	10/1/58
28	10/1/58
29	10/1/58
30	10/1/58
31	10/1/58
32	10/1/58
33	10/1/58
34	10/1/58
35	10/1/58
36	10/1/58
37	10/1/58
38	10/1/58
39	10/1/58
40	10/1/58
41	10/1/58
42	10/1/58
43	10/1/58
44	10/1/58
45	10/1/58
46	10/1/58
47	10/1/58
48	10/1/58
49	10/1/58
50	10/1/58
51	10/1/58
52	10/1/58
53	10/1/58
54	10/1/58
55	10/1/58
56	10/1/58
57	10/1/58
58	10/1/58
59	10/1/58
60	10/1/58
61	10/1/58
62	10/1/58
63	10/1/58
64	10/1/58
65	10/1/58
66	10/1/58
67	10/1/58
68	10/1/58
69	10/1/58
70	10/1/58
71	10/1/58
72	10/1/58
73	10/1/58
74	10/1/58
75	10/1/58
76	10/1/58
77	10/1/58
78	10/1/58	...			

INSIDE STACK DIAMETER

60

Inches

RELATED CAPACITY

TYPE FUEL

DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER

Inches

NUMBER OF TRAVERSES

2

NUMBER OF POINTS/TRAVERSE

10

LOCATION OF SAMPLING POINTS ALONG TRAVERSE

[illegible]

PRELIMINARY SURVEY DATA SHEET NO. 2

(Velocity and Temperature Traverse)

DATE
10 FEB 89

INSIDE STACK DIAMETER
60

Inches

In Hg

In H₂O

SAMPLING TEAM

[illegible]

Sheet

START 0946 1020 STOP 1012

PARTICULATE SAMPLING DATA SHEET

Alber 2.07

RUN NUMBER #1015 Scrubber B		SCHEMATIC OF STACK CROSS SECTION		EQUATIONS		AMBIENT TEMP	
DATE 10 Feb 89				$H = \left[\frac{5130 \cdot P \cdot Q \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_b} \cdot V_p$		STATION PRESS 29.455	
PLANT				HEATER BOX TEMP 248 ± 25			
BASE				PROBE HEATER SETTING 190		OF	
SAMPLE BOX NUMBER Grisson				PROBE LENGTH 72		in	
METER BOX NUMBER Nutech #1				NOZZLE AREA (A) .320		sq ft	
Nutech #1				Cp .84			
Co				DRY GAS FRACTION (F _d)			

Pitot good
Pre leak ch 18" Hg good
Post leak ch 17.5" Hg good
SOOT-BLOW
Static AP = -.19

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STACK PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
			A (°F)	B (°F)				IN (°F)	AVG (T _m) (°F)	OUT (°F)		
1	0	7.6	111		.22	2.35	236.901	87		86	245	44
2	3	8.8	111		.24	2.49		87		86	249	49
3	6	8.0	109		.23	2.41		87		87	249	50
4	9	8.1	109		.225	2.36		91		87	257	51
5	12	9.5	109		.245	2.57		93		88	259	51
6	15	9.8	110		.24	2.52		95		88	260	50
7	18	10.8	107		.26	2.75		96		85	261	48
8	21	12.4	108		.27	2.85		97		89	262	50
9	24	12.8	111		.27	2.84		98		90	264	52
10	27	11.2	113		.22	2.31	238.835	98		90	265	55
30 STOP												
1	0	9.0	110		.19	2.00	238.836	95		91	265	49
2	3	8.9	115		.17	1.78		98		92	266	52
3	6	8.4	118		.17	1.78		101		93	266	52
4	9	9.4	119		.18	1.88		102		93	265	51
5	12	9.9	120		.20	2.09		103		94	266	51
6	15	13.9	132		.27	2.77		105		95	267	52
7	18	14.8	148		.27	2.71		106		96	264	54
8	21	15.1	123		.27	2.82		107		96	265	55
9	24	17.0	121		.30	3.15		107		97	268	55
10	27	17.1	119		.29	3.06	240.392	107		98	267	55
30 STOP												

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE GRISSOM IND	DATE 10 FEB 89	RUN NUMBER ONE
BUILDING NUMBER Power Plant	SOURCE NUMBER 5 BOILER & SCRUBBER B	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	0.4057 0.4045	0.2948 0.5000	0.1190 0.1202
ACETONE WASHINGS (Probe, Front Half Filter)	100.0622 400.0638	0.2833 100.0497	0.0125 0.0141
BACK HALF (if needed)	—	—	—
Total Weight of Particulates Collected			0.1315 0.1343 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	246.5	200.0	46.5
IMPINGER 2 (H2O)	217.0	200.0	17.0
IMPINGER 3 (Dry)	7.5	0.0	7.5
IMPINGER 4 (Silica Gel)	210.6	200.0	10.6
Total Weight of Water Collected			71.6 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	7.2	7.3	7.2		7.2
VOL % O ₂	11.8	11.8	12.0		11.9
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

START: 1247

STOP: 1:19

1247

PARTICULATE SAMPLING DATA SHEET $\Delta H_a = 2.07$

RUN NUMBER 1341-5		SCHEMATIC OF STACK CROSS SECTION		EQUATIONS		AMBIENT TEMP						
DATE	PLANT			$OR = OF + 460$ $H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$	STATION PRESS	HEATER BOX TEMP	PROBE HEATER SETTING					
10 Feb 89					248.45	248.5	190					
							72					
							NOZZLE AREA					
							0.320					
							Cp					
							0.84					
							DRY GAS FRACTION (FG)					
TRaverse POINT NUMBER	SAMPLING TIME (min)	WIND SPEED (MPH)	STACK TEMP (°F)	STACK TEMP (°C)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP IN (°F)	GAS METER TEMP OUT (°F)	AVG (Tm) (°F)	SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)
1	0	4.0	113	113	0.23	2.43	280.672	98	98	103	266	44
2	3	4.4	113	113	0.23	2.60		101	98	103	268	51
3	6	4.5	101	101	0.23	2.50		104	99	100	269	52
4	9	4.8	100	100	0.235	2.57		106	100	100	268	52
5	12	5.0	98	98	0.245	2.68		108	100	100	268	52
6	15	5.2	100	100	0.26	2.86		110	101	101	270	51
7	18	5.5	100	100	0.25	2.74		110	101	101	271	52
8	21	6.0	101	101	0.26	2.85		112	102	102	269	57
9	24	6.1	101	101	0.255	2.79		112	102	102	270	64
10	27	5.8	102	102	0.215	2.39	283.885	112	103	103	270	67
1	0	5.3	106	106	0.2	2.17	283.885	109	103	103	255	66
2	3	5.3	104	104	0.19	2.07		110	103	103	252	67
3	6	5.2	107	107	0.18	1.96		112	104	104	248	67
4	9	5.2	111	111	0.18	1.95		113	104	104	241	63
5	12	6.0	116	116	0.21	2.25		113	105	105	240	58
6	15	6.9	116	116	0.27	2.90		115	105	105	240	55
7	18	6.5	112	112	0.25	2.71		115	105	105	243	53
8	21	7.5	113	113	0.27	2.92		114	106	106	239	51
9	24	8.0	112	112	0.3	3.24		113	105	105	243	50
10	27	8.9	112	112	0.32	3.46	306.754	113	106	106	242	51
	30.000											

Static AP = 1.9

Plot good
 Preleak ck 15" Hg good
 Postleak ck 15" Hg good

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE GRISSOM IND	DATE 19 FEB 89	RUN NUMBER TWO
BUILDING NUMBER POWER PLANT	SOURCE NUMBER Boiler #5 SCRUBBER B	

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	0.363 ³ 9	0.2883	0.075 ² 6
ACETONE WASHINGS (Probe, Front Half Filter)	2.174 102.202 0 2.174	102.202 0	0.0154 0.0174
BACK HALF (If needed)		—	—
Total Weight of Particulates Collected			0.0904 0.0930 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	237.0	200.0	37.0
IMPINGER 2 (H2O)	218.0	200.0	18.0
IMPINGER 3 (Dry)	5.5	0.0	5.5
IMPINGER 4 (Silica Gel)	213.8	200.0g	13.8
Total Weight of Water Collected			74.3 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	6.3	6.2	6.1		6.2
VOL % O ₂	11.5	11.6	11.7		11.6
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

START: 2:17 2:50 STOP:


PARTICULATE SAMPLING DATA SHEET $\Delta H_c = 2.07$

SCHEMATIC OF STACK CROSS SECTION

EQUATIONS

$$OR = OF + 460$$

$$H = \left[\frac{5130 \cdot F \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$$



RUN NUMBER *Run 5-*
 #3 *Scrubber B*
 DATE *10 Feb 89*
 PLANT
 BASE
 SAMPLE BOX NUMBER
Nutech #1
 METER BOX NUMBER
Nutech #1
 Qw/Qm
 Co

AMBIENT TEMP
 STATION PRESS *29.455*
 HEATER BOX TEMP *248.5*
 PROBE HEATER SETTING
190
 PROBE LENGTH
72
 NOZZLE AREA (in²) *0.330*
 Cp
84
 DRY GAS FRACTION (F_D)

Pilot ck good
 Releak ck 16" Hg good
 Postleak ck 18" Hg good

Static $\Delta P = -19$

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (OF)	IMPIRGER OUTLET TEMP (OF)
			(OF)	(TS) (OF)				IN (OF)	AVG (Tm) (OF)		
1	0	8.1	104		.225	2.44	207.442	103	102	246	32
2	3	9.0	98		.23	2.52		104	102	252	41
3	6	9.0	101		.22	2.40		106	102	255	45
4	9	9.0	105		.23	2.50		108	102	255	49
5	12	10.1	106		.245	2.66		109	103	257	51
6	15	10.2	107		.24	2.60		110	103	255	52
7	18	10.2	107		.24	2.60		110	103	254	52
8	21	11.5	116		.26	2.81		111	103	253	54
9	24	11.8	112		.26	2.80		111	103	255	56
10	27	10.4	112		.23	2.48		111	103	254	52
11											
1	0	7.6	103		.15	1.63	330.106	107	102	254	51
2	3	8.1	109		.17	1.83	350.107	107	102	255	51
3	6	8.2	112		.17	1.82		107	102	255	51
4	9	8.3	117		.17	1.81		108	102	254	52
5	12	10.3	121		.21	2.22		107	102	254	53
6	15	12.9	122		.26	2.74		108	102	255	55
7	18	15.0	121		.26	2.75		108	102	255	56
8	21	15.0	122		.27	2.85		108	102	255	52
9	24	15.0	121		.23	2.17		108	102	253	59
10	27	15.0	124		.23	2.15	352.097	108	102	253	62
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE CRISSOM IND	DATE 1 FEB 89	RUN NUMBER THREE
---	--	---

BUILDING NUMBER POWER PLANT	SOURCE NUMBER Boiler #5 SCRUBBER B
--	---

I. PARTICULATES

ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	0.3544 0.3554	0.2868	0.0676 0.0686
ACETONE WASHINGS (Probe, Front Half Filter)	105.3931 105.3947	105.3753	0.0178 0.0194
BACK HALF (if needed)	—	—	—
Total Weight of Particulates Collected			0.0854 0.0884 gm

II. WATER

ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	245.5	200.0	45.5
IMPINGER 2 (H2O)	216.0	200.0	16.0
IMPINGER 3 (Dry)	5.5	0.0	5.5
IMPINGER 4 (Silica Gel)	212.7	200.0g	12.7
Total Weight of Water Collected			79.7 gm

III. GASES (Dry)

ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	6.0	6.0	6.0		6.0
VOL % O ₂	11.4	11.4	11.4		11.4
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

Run #1

VISIBLE EMISSION OBSERVATION FORM

No. Run #1

COMPANY NAME <i>Grissom Power Plant</i>		
STREET ADDRESS <i>Bldg # 223</i>		
CITY <i>Grissom AFB</i>	STATE <i>In</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Coal Fired Boiler</i>	OPERATING MODE <i>15 100%</i>
CONTROL EQUIPMENT <i>Wet Scrubber AFB</i>	OPERATING MODE

DESCRIBE EMISSION POINT <i>Flue Gas Stack</i>	
HEIGHT ABOVE GROUND LEVEL <i>95 ft</i>	HEIGHT RELATIVE TO OBSERVER Start <i>95 ft</i> End
DISTANCE FROM OBSERVER Start <i>210 ft</i> End	DIRECTION FROM OBSERVER Start <i>NW</i> End

DESCRIBE EMISSIONS Start <i>Lighting</i> End	
EMISSION COLOR Start <i>incandescent</i> End	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>20 ft</i> End	

DESCRIBE PLUME BACKGROUND Start <i>sky</i> End	
BACKGROUND COLOR Start <i>Blue</i> End	SKY CONDITIONS Start <i>31%</i> End
WIND SPEED Start <i>10</i> End	WIND DIRECTION Start <i>270</i> End
AMBIENT TEMP Start <i>18</i> End	WET BULB TEMP <i>N/A</i> RH, percent <i>55</i>

Stack with Plume Sun Wind	SOURCE LAYOUT SKETCH Draw North Arrow
---------------------------------	--

OBSERVATION DATE <i>10/5/82</i>				START TIME <i>1032</i>	END TIME <i>1044</i>
SEC	0	15	30	45	COMMENTS
MIN					
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	start blow
7	0	0	0	0	start 1035
8	0	0	0	0	start blow line
9	0	0	0	0	start 1041
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <i>Paul T. Scott</i>		DATE <i>10/5/82</i>
OBSERVER'S SIGNATURE <i>Paul T. Scott</i>		
ORGANIZATION <i>USAF Civil Engineering</i>		
CERTIFIED BY <i>Texas Air Control Board / Eastern Technical</i>		DATE <i>10/5/82</i>

Run #2

VISIBLE EMISSION OBSERVATION FORM

No. Run #2

COMPANY NAME Grissom Power Plant		
STREET ADDRESS Bldg #223		
CITY Grissom AFB	STATE IN	ZIP 46971
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT Coal-Fired Boiler	OPERATING MODE 95-100%
CONTROL EQUIPMENT Wet Scrubber B	OPERATING MODE

DESCRIBE EMISSION POINT Fireigan Stack 60" diameter	
HEIGHT ABOVE GROUND LEVEL 95 ft	HEIGHT RELATIVE TO OBSERVER Start 95 ft End ✓
DISTANCE FROM OBSERVER Start 300 ft End	DIRECTION FROM OBSERVER Start NNW End ✓

DESCRIBE EMISSIONS Start 10 ft/mg End ✓	
EMISSION COLOR Start Nil End	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start 100 End ✓	

DESCRIBE PLUME BACKGROUND Start SKY End ✓	
BACKGROUND COLOR Start Blue End ✓	SKY CONDITIONS Start CLC End
WIND SPEED Start 10 End ✓	WIND DIRECTION Start SW End
AMBIENT TEMP Start 20 End ✓	WET BULB TEMP 58

Stack with Plume Sun Wind	SOURCE LAYOUT SKETCH Draw North Arrow
---------------------------------	--

ADDITIONAL INFORMATION

OBSERVATION DATE 10 Feb 89				START TIME 1218	END TIME 1230
SEC MIN	0	15	30	45	COMMENTS
1	✓	✓	✓	✓	
2	✓	✓	✓	✓	
3	✓	✓	✓	✓	
4	✓	✓	✓	✓	
5	✓	✓	✓	✓	
6	✓	✓	✓	✓	
7	✓	✓	✓	✓	
8	✓	✓	✓	✓	
9	✓	✓	✓	✓	
10	✓	✓	✓	✓	
11	✓	✓	✓	✓	
12	✓	✓	✓	✓	
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) Paul J. Scott	DATE 10 Feb 89
OBSERVER'S SIGNATURE Paul J. Scott	
ORGANIZATION USAF CEHL/ECG	
CERTIFIED BY Texas Air Control Board	DATE 16 Sept 88

Run #3

VISIBLE EMISSION OBSERVATION FORM

No. Run #3



COMPANY NAME <i>Grissom AFB Power Plant</i>		
STREET ADDRESS <i>Blvd #223</i>		
CITY <i>Grissom AFB</i>	STATE <i>IN</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Coal-Fired Boiler</i>	OPERATING MODE <i>95-100%</i>
CONTROL EQUIPMENT <i>Wet Scrubber</i>	OPERATING MODE

DESCRIBE EMISSION POINT <i>Fiberglass Stack 60" diameter</i>	
HEIGHT ABOVE GROUND LEVEL <i>95</i>	HEIGHT RELATIVE TO OBSERVER Start <i>95</i> End <input checked="" type="checkbox"/>
DISTANCE FROM OBSERVER Start <i>300'</i> End <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER Start <i>N</i> End <input checked="" type="checkbox"/>

DESCRIBE EMISSIONS Start <i>Lefting - Steam</i> End <input checked="" type="checkbox"/>	
EMISSION COLOR Start <i>N/A</i> End <input checked="" type="checkbox"/>	IF WATER DROPLET PLUME Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>180</i> End <input checked="" type="checkbox"/>	

DESCRIBE PLUME BACKGROUND Start <i>Blue Sky</i> End <input checked="" type="checkbox"/>	
BACKGROUND COLOR Start <i>Blue</i> End <input checked="" type="checkbox"/>	SKY CONDITIONS Start End
WIND SPEED Start <i>10</i> End <input checked="" type="checkbox"/>	WIND DIRECTION Start <i>SW</i> End
AMBIENT TEMP Start <i>24</i> End	WET BULB TEMP RH, percent <i>50</i>

Stack with Plume <input checked="" type="checkbox"/>	SOURCE LAYOUT SKETCH Draw North Arrow 
Sun <input checked="" type="checkbox"/>	
Wind <input checked="" type="checkbox"/>	
	

ADDITIONAL INFORMATION	86
------------------------	----

OBSERVATION DATE <i>10 Feb 89</i>		START TIME <i>1459</i>		END TIME <i>1513</i>	
SEC	0	15	30	45	COMMENTS
MIN					
1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
8	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
9	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
10	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
11	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
12	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <i>Paul T. Scott</i>	DATE <i>10 Feb 89</i>
OBSERVER'S SIGNATURE <i>Paul T. Scott</i>	
ORGANIZATION <i>CEHL / ECQ</i>	
CERTIFIED BY <i>Texas Air Control Board</i>	DATE <i>16 Sept 89</i>

APPENDIX H

Boiler 5, Bypass Stack Field Data

(This page left blank)

DETERMINATION OF MINIMUM NUMBER OF TRAVERSE POINTS

Stack ID: BYPASS Stack diameter at ports: 5.5 (ft)



Distance A (ft) 11.5 (duct diameters) 2.1

Recommended number of traverse points as determined by
distance A: 12

Distance B (ft) 39.5 (duct diameters) 7.2

Recommended number of traverse points as determined by
distance B: 12

Number of traverse points used: 12



PRELIMINARY SURVEY DATA SHEET NO. 1

(Stack Geometry)

BASE Grissom	PLANT Power Plant	
DATE 3 Feb 89	SAMPLING TEAM OEHL	
SOURCE TYPE AND MAKE Bypass Stack		
SOURCE NUMBER	INSIDE STACK DIAMETER 66	Inches
RELATED CAPACITY	TYPE FUEL COAL	
DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER 4.00		Inches
NUMBER OF TRAVERSES 2	NUMBER OF POINTS/TRAVERSE 6	

LOCATION OF SAMPLING POINTS ALONG TRAVERSE

[illegible]

(Velocity and Temperature Traverse)

BASE

Grissom AFB, In

DATE _____

Feb 89

BOILER NUMBER

NUMBER
Bv-Pass Stack

INSIDE STACK DIAMETER

66.0

Inches

STATION PRESSURE

29.6.17

In Hg

STACK STATIC PRESSURE

16

In H₂O

SAMPLING TEAM

TEAM
OEHL / EEQ

[illegible]

一、

PARTICULATE SAMPLING DATA SHEET

$$= 2.07$$

OEHL FORM 18

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE GRISCOM AFB	DATE 12 FEB 89	RUN NUMBER ONE ONE
BUILDING NUMBER Power Plant		SOURCE NUMBER Boiler 5 Bypass

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER H1	.4596	0.2898 0.2898	0.1698
ACETONE WASHINGS (Probe, Front Half Filter)	95.6105	95.5190	0.0915
Back Half (if needed) Filter #2	.3820	0.2945	0.0875
Total Weight of Particulates Collected			0.3488 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	232.5	200.0	32.5 32.5
IMPINGER 2 (H2O)	212.0	200.0	12.0
IMPINGER 3 (Dry)	0	0.0	0
IMPINGER 4 (Silica Gel)	206.0	200.0	6.0
Total Weight of Water Collected			50.5 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	9.0	9.0	9.0		9.0
VOL % O ₂	9.2	9.2	9.2		9.2
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100 - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE Gribsom AFB, In	DATE 12 Feb 89	RUN NUMBER TWO
--------------------------------	--------------------------	--------------------------

BUILDING NUMBER Bldg 223 - Power Plant	SOURCE NUMBER Boiler #5 By Pass
--	---

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER A	.4402	0.2941 0.2945	0.1461
ACETONE WASHINGS (Probe, Front Half Filter)	105.1356 105.4698	105.0880	0.0470
Filter B BAG HALF (Humed)	.4202	0.2914	0.1292
Total Weight of Particulates Collected			0.3223 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	229.5	200.0	29.5
IMPINGER 2 (H2O)	216.00	200.0	16.0
IMPINGER 3 (Dry)	2.0	0.0	2.0
IMPINGER 4 (Silica Gel)	211.2	200.0	11.2
Total Weight of Water Collected			gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	10.6	10.6	10.6		10.6
VOL % O ₂	7.6	7.8	7.8		7.7
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE GRISMAN AFB	DATE 12 FEB 89	RUN NUMBER THREE
BUILDING NUMBER POWER PLANT		SOURCE NUMBER BOILER 5 BYPASS

PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER A	.4529	0.2859	0.1670
ACETONE WASHINGS (Probe, Front Half Filter)	105.9698	105.8062	0.1636
Filter BACK HALF (if needed) B	.4661	0.2913	0.1748
Total Weight of Particulates Collected			0.5054 gm

I. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	240.0	200.0	40.0
IMPINGER 2 (H2O)	210.0	200.0	10.0
IMPINGER 3 (Dry)	0	0.0	0
IMPINGER 4 (Silica Gel)	207.0	200.0	7
Total Weight of Water Collected			57.0 gm

II. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	7.4	7.4	7.4		7.4
VOL % O ₂	10.4	10.4	10.2		10.3
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

VISIBLE EMISSION OBSERVATION FORM

No. *ONE*

COMPANY NAME <i>En3son AFB Power Plant</i>		
STREET ADDRESS <i>Bldg 223</i>		
CITY <i>En3son AFB</i>	STATE <i>IN</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Boiler # 5</i>	OPERATING MODE <i>95-100%</i>
CONTROL EQUIPMENT <i>None - By Pass</i>	OPERATING MODE <i>—</i>

DESCRIBE EMISSION POINT <i>Steel stack 66" diameter</i>	
HEIGHT ABOVE GROUND LEVEL <i>100 ft</i>	HEIGHT RELATIVE TO OBSERVER Start <i>8</i> End <input checked="" type="checkbox"/>
DISTANCE FROM OBSERVER Start <i>40</i> End <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER Start <i>N</i> End <input checked="" type="checkbox"/>

DESCRIBE EMISSIONS Start <i>lighting</i> End <input checked="" type="checkbox"/>	
EMISSION COLOR Start <i>Brown</i> End <input checked="" type="checkbox"/>	IF WATER DROPLET PLUME Attached <input type="checkbox"/> <i>20'</i> Detached <input checked="" type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>5</i> End <input checked="" type="checkbox"/>	

DESCRIBE PLUME BACKGROUND Start <i>Sky</i> End <input checked="" type="checkbox"/>	
BACKGROUND COLOR Start <i>Blue</i> End <input checked="" type="checkbox"/>	SKY CONDITIONS Start <i>CLR</i> End <input checked="" type="checkbox"/>
WIND SPEED Start <i>5</i> End <input checked="" type="checkbox"/>	WIND DIRECTION Start <i>W</i> End <input checked="" type="checkbox"/>
AMBIENT TEMP Start <i>28</i> End <input checked="" type="checkbox"/>	WET BULB TEMP <i>W/B</i> RH, percent <i>45</i>

Stack with Plume Sun Wind	<div style="display: flex; justify-content: space-between;"> <div> <p>SOURCE LAYOUT SKETCH</p> </div> <div> <p>Draw North Arrow </p> </div> </div>
---------------------------------	--

ADDITIONAL INFORMATION

OBSERVATION DATE 12 Feb 89				START TIME 1018	END TIME
SEC MIN	0	15	30	45	COMMENTS
1	5	5	5	5	
2	5	10	10	10	
3	10	5	5	5	
4	5	5	10	5	
5	5	10	15	15	
6	10	10	10	10	
7	5	5	5	5	
8	5	5	5	5	
9	10	10	5	5	
10	5	5	5	5	
11	10	10	5	5	
12	5	10	10	5	
13	10	5	5	5	
14	5	5	5	10	
15	5	10	10	10	
16	5	10	5	0	
17	0	5	5	5	
18	5	5	10	5	
19	0	0	0	0	
20	5	10	10	5	
21	5	5	5	5	
22	5	5	5	5	
23	5	0	0	0	
24	0	0	5	5	
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <i>Paul T. Scott</i>	
OBSERVER'S SIGNATURE <i>Paul T. Scott</i>	DATE 12 Feb
ORGANIZATION <i>USAF OEHLE/ECR</i>	
CERTIFIED BY <i>Transmittal Control Board</i>	DATE 16 Sept

VISIBLE EMISSION OBSERVATION FORM

No. *Two*






COMPANY NAME <i>Grisson AFB Heating Plant</i>		
STREET ADDRESS <i>Bldg 223</i>		
CITY <i>Grisson AFB</i>	STATE <i>In</i>	ZIP <i>46971</i>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <i>Boiler #5</i>	OPERATING MODE <i>95-100%</i>
CONTROL EQUIPMENT <i>non-By Pass</i>	OPERATING MODE

DESCRIBE EMISSION POINT <i>steel stack 66" dia</i>	
HEIGHT ABOVE GROUND LEVEL <i>100 ft</i>	HEIGHT RELATIVE TO OBSERVER Start <i>8'</i> End
DISTANCE FROM OBSERVER Start <i>40'</i> End <input checked="" type="checkbox"/>	DIRECTION FROM OBSERVER Start <i>N</i> End <input checked="" type="checkbox"/>

DESCRIBE EMISSIONS Start <i>Brown / light</i> End <input checked="" type="checkbox"/>	
EMISSION COLOR Start <i>Brown</i> End <input checked="" type="checkbox"/>	IF WATER DROPLET PLUME Attached <input type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <i>5'</i> End <input checked="" type="checkbox"/>	

DESCRIBE PLUME BACKGROUND Start <i>SKY</i> End <input checked="" type="checkbox"/>	
BACKGROUND COLOR Start <i>Blue</i> End <input checked="" type="checkbox"/>	SKY CONDITIONS Start <i>CLR</i> End <input checked="" type="checkbox"/>
WIND SPEED Start <i>LS</i> End	WIND DIRECTION Start <i>WSW</i> End
AMBIENT TEMP Start <i>71</i> End <input checked="" type="checkbox"/>	WET BULB TEMP <i>N/A</i>
	RH, percent <i>45</i>

Stack with Plume  Sun  Wind 	SOURCE LAYOUT SKETCH Draw North Arrow  
---	---

ADDITIONAL INFORMATION	99
------------------------	----

OBSERVATION DATE <i>12 Feb 89</i>		START TIME <i>1322</i>		END TIME <i>1332</i>	
SEC MIN	0	15	30	45	COMMENTS
1	10	5	5	5	
2	5	5	5	5	
3	0	5	10	10	
4	30	25	20	20	
5	30	30	30	15	
6	20	25	10	15	
7	5	5	0	5	
8	5	5	0	5	
9	10	15	20	5	
10	5	5	10	10	
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <i>Paul T. Scott</i>	DATE <i>12 Feb 89</i>
OBSERVER'S SIGNATURE <i>Paul T. Scott</i>	
ORGANIZATION <i>USAF/OEHL / EOC</i>	
CERTIFIED BY <i>Texas Air Control Board</i>	DATE <i>16 Sept 88</i>

VISIBLE EMISSION OBSERVATION FORM

No. THREE






COMPANY NAME <u>Grissom AFB Heating Plant</u>		
STREET ADDRESS <u>Bldg 223</u>		
CITY <u>Grissom AFB</u>	STATE <u>IN</u>	ZIP <u>46971</u>
PHONE (KEY CONTACT)		SOURCE ID NUMBER

PROCESS EQUIPMENT <u>Burner # 5</u>	OPERATING MODE <u>95-100%</u>
CONTROL EQUIPMENT <u>None - By Hand</u>	OPERATING MODE

DESCRIBE EMISSION POINT <u>Steel stack 66" diameter</u>	
HEIGHT ABOVE GROUND LEVEL <u>100 ft</u>	HEIGHT RELATIVE TO OBSERVER Start <u>8'</u> End <u>✓</u>
DISTANCE FROM OBSERVER Start <u>40'</u> End <u>✓</u>	DIRECTION FROM OBSERVER Start <u>N</u> End <u>✓</u>

DESCRIBE EMISSIONS Start <u>Buoyant</u> End <u>Lighting</u>	
EMISSION COLOR Start <u>Brown</u> End <u>✓</u>	IF WATER DROPLET PLUME Attached <input type="checkbox"/> Detached <input type="checkbox"/>
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED Start <u>5'</u> End <u>✓</u>	

DESCRIBE PLUME BACKGROUND Start <u>Blue Sky</u> End <u>Lighting</u> ✓	
BACKGROUND COLOR Start <u>Blue</u> End <u>✓</u>	SKY CONDITIONS Start <u>CLR</u> End <u>✓</u>
WIND SPEED Start <u>CALM</u> End <u>< 5</u>	WIND DIRECTION Start <u>VAR</u> End <u>SW</u>
AMBIENT TEMP Start <u>39</u> End <u>✓</u>	WET BULB TEMP <u>N/A</u>
	RH, percent <u>45</u>

Stack with Plume  Sun  Wind 	SOURCE LAYOUT SKETCH Draw North Arrow  
---	---

ADDITIONAL INFORMATION	100
------------------------	-----

OBSERVATION DATE 12 Feb 89				START TIME 1519	END TIME 1538
SEC MIN	0	15	30	45	COMMENTS
1	5	5	5	15	
2	20	10	5	10	
3	20	10	5	5	
4	5	10	10	15	
5	15	15	15	15	
6	10	5	10	15	
7	20	25	20	20	
8	20	15	15	10	
9	10	5	10	10	
10	15	25	20	30	sun below 1528 24
11	60	60	60	30	
12	40	50	60	60	
13	30	25	50	30	
14	20	25	25	15	
15	15	15	10	15	
16	10	10	15	10	
17	10	10	5	5	
18	5	5	5	5	
19	5	5	5	10	
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

OBSERVER'S NAME (PRINT) <u>Paul T. Scott</u>		DATE <u>12 Feb 89</u>
OBSERVER'S SIGNATURE <u>Paul T. Scott</u>		
ORGANIZATION <u>USAF CETHL/ECQ</u>		
CERTIFIED BY <u>Ther M. M. M. M. M.</u>		DATE <u>16 Feb 89</u>

APPENDIX I
Calibration Data

(This page left blank)

NOZZLE CALIBRATION DATA FORM

Date 10 Feb 89

Calibrated by May Garrison

Nozzle identification number	Nozzle Diameter ^a			ΔD , ^b mm (in.)	D_{avg} ^c
	D_1 , mm (in.)	D_2 , mm (in.)	D_3 , mm (in.)		
	.320	.319	.320	.001	.320

where:

^a $D_{1,2,3}$ = three different nozzles diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

^b ΔD = maximum difference between any two diameters, mm (in.),
 $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

^c D_{avg} = average of D_1 , D_2 , and D_3 .

Quality Assurance Handbook M5-2.6

NOZZLE CALIBRATION DATA FORM

Date Feb 89 Calibrated by Garrison

Nozzle identification number	Nozzle Diameter ^a			ΔD , ^b mm (in.)	D_{avg} ^c
	D_1 , mm (in.)	D_2 , mm (in.)	D_3 , mm (in.)		
• H 4 <u>1276-89</u>	.377	.377	.377	.001	.377
	.394	.395	.395	.0001	.395

where:

^a $D_{1,2,3}$ = three different nozzles diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

^b ΔD = maximum difference between any two diameters, mm (in.),
 $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

^c D_{avg} = average of D_1 , D_2 , and D_3 .

Quality Assurance Handbook M5-2.6

NOZZLE CALIBRATION DATA FORM

Date 14 Feb 89 Calibrated by Garrison Major

Nozzle identification number	Nozzle Diameter ^a			ΔD , ^b mm (in.)	D_{avg} ^c
	D_1 , mm (in.)	D_2 , mm (in.)	D_3 , mm (in.)		
	.302	.303	.304	.002	.303

where:

^a $D_{1,2,3}$ = three different nozzles diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

^b ΔD = maximum difference between any two diameters, mm (in.),
 $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

^c D_{avg} = average of D_1 , D_2 , and D_3 .

Quality Assurance Handbook M5-2.6

TYPE S PITOT TUBE INSPECTION DATA FORM

#6A

Pitot tube assembly level? ☒ yes ☐ no

Pitot tube openings damaged? ☐ yes (explain below) ☒ no

$\alpha_1 = 1^\circ (<10^\circ)$, $\alpha_2 = 2^\circ (<10^\circ)$, $\beta_1 = 2^\circ (<5^\circ)$,

$\beta_2 = 3^\circ (<5^\circ)$

$\gamma = 4^\circ$, $\theta = 0^\circ$, $A = \frac{1.1875}{13/16}$ (in.)

$z = A \sin \gamma = 0.0828$ (in.); <0.32 cm ($<1/8$ in.), ^{0.125}

$w = A \sin \theta = 0.0$ (in.); <0.08 cm ($<1/32$ in.), ^{0.0313}

$P_A = \frac{19}{32} (0.5938)$ (in.) $P_B = \frac{19}{32} (0.5938)$ (in.)

$D_t = 0.375$ cm (in.)

Comments: CONSTRUCTED IAW 40 CFR 60, APPA, METH 2,
FIG 2.2. ASSIGNED BASELINE COEFFICIENT = 0.84

Calibration required? ☐ yes ☒ no

TYPE S PITOT TUBE INSPECTION DATA FORM

#8A

Pitot tube assembly level? ✓ yes no

Pitot tube openings damaged? yes (explain below) ✓ no

$\alpha_1 = \underline{1}^\circ (<10^\circ)$, $\alpha_2 = \underline{2}^\circ (<10^\circ)$, $\beta_1 = \underline{\phi}^\circ (<5^\circ)$,

$\beta_2 = \underline{2}^\circ (<5^\circ)$

$\gamma = \underline{1}^\circ$, $\theta = \underline{1}^\circ$, $A = \underline{15/16} \text{ cm (in.)}$ ^(0.938)

$z = A \sin \gamma = \underline{0.0164} \text{ cm (in.)}$; ^{0.1250} $<0.32 \text{ cm (<1/8 in.)}$,

$w = A \sin \theta = \underline{0.0164} \text{ cm (in.)}$; ^{0.0313} $<.08 \text{ cm (<1/32 in.)}$

$P_A \underline{15/32 (0.469)} \text{ cm (in.)}$ $P_B \underline{15/32 (0.469)} \text{ cm (in.)}$

$D_t = \underline{3/8 (.375)} \text{ cm (in.)}$

Comments: CONSTRUCTED IAW 40CFR 60, APP A, METH 2,
FIG 2.2 ASSIGNED BASELINE COEFFICIENT = 0.84

Calibration required? yes ✓ no

Quality Assurance Handbook M2-1.7

METER BOX CALIBRATION DATA AND CALCULATION FORM

(English units)

Date 21 Nov 88

Meter box number Nutch #2

Barometric pressure, $P_b = 30.02$ in. Hg Calibrated by Scott & Vaughn

VAC

Orifice manometer setting (ΔH), in. H_2O	Gas volume		Temperature				Time (θ), min	Y_i	$\Delta H @ i$ in. H_2O
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Dry gas meter					
				Inlet (t_{d_i}), °F	Outlet (t_{d_o}), °F	Avg ^a (t_d), °F			
0.5	5	5.057	75 535	77 82	75 77	537.75	12.40	0.9926	1.73
1.0	5	5.031	76 536	76 89	77 80	542.5	9.14	1.0034	1.87
1.5	10	10.101	77 537	77 90	81 84	547.75	15.35	1.0061	1.97
2.0	10	10.230	78 538	78 99	85 87	552.0	13.45	0.9981	2.00
3.0	10	10.170	78 538	78 100	87 89	554.75	10.92	1.0065	1.97
4.0	10	10.191	78 538	78 103	87 91	557.0	9.35	1.0061	1.92
Avg								1.002	1.91

ΔH , in. H_2O	$\frac{\Delta H}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t + 460)}$	$\Delta H @ i = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	$\frac{(5)(30.02)(537.75)}{(5.057)(30.02 + \frac{0.5}{13.6})(535)}$	$\frac{(0.0317)(0.5)}{(30.02)(537.75)} \left[\frac{(535)(12.4)}{5} \right]^2$
1.0	0.0737	$\frac{(5)(30.02)(542.5)}{(5.031)(30.02 + \frac{1.0}{13.6})(536)}$	$\frac{(0.0317)(1.0)}{(30.02)(542.5)} \left[\frac{(536)(9.14)}{5} \right]^2$
1.5	0.110	$\frac{(10)(30.02)(547.75)}{(10.101)(30.02 + \frac{1.5}{13.6})(537)}$	$\frac{(0.0317)(1.5)}{(30.02)(547.75)} \left[\frac{(537)(15.35)}{10} \right]^2$
2.0	0.147	$\frac{(10)(30.02)(552)}{(10.230)(30.02 + \frac{2.0}{13.6})(538)}$	$\frac{(0.0317)(2.0)}{(30.02)(552)} \left[\frac{(538)(13.45)}{10} \right]^2$
3.0	0.221	$\frac{(10)(30.02)(554.75)}{(10.170)(30.02 + \frac{3.0}{13.6})(538)}$	$\frac{(0.0317)(3.0)}{(30.02)(554.75)} \left[\frac{(538)(10.92)}{10} \right]^2$
4.0	0.294	$\frac{(10)(30.02)(557)}{(10.191)(30.02 + \frac{4.0}{13.6})(538)}$	$\frac{(0.0317)(4.0)}{(30.02)(557)} \left[\frac{(538)(9.35)}{10} \right]^2$

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d .

POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

PRETEST FOR GRASSMAN 49 FEB

Test number Post Date 18 Nov 88 Meter box number Nutech #1 Plant O'Fallon

Barometric pressure, $P_b = 29.82$ in. Hg Dry gas meter number Rockwell Pretest Y 1.077

Orifice manometer setting, (ΔH), in. H_2O	Gas volume		Temperature				Time (θ), min	Vacuum Setting, in. Hg	Y_i	Y_i $V_w P_b (t_d + 460)$ $V_d \left(P_b + \frac{\Delta H}{13.6} \right) (t_w + 460)$
	Wet test meter (V_w), ft^3	Dry gas meter (V_d), ft^3	Wet test meter (t_w), $^{\circ}F$	Dry gas meter						
				Inlet (t_{d_i}), $^{\circ}F$	Outlet (t_{d_o}), $^{\circ}F$	Average (t_d), $^{\circ}F$				
0.9 0.9	10	9.152	81.543	85.543	79.538	540.5	20.95	4	1.085	$(10)(29.82)(540.5)$ $(9.152)(29.82 + \frac{13.6}{13.6})(543)$
0.9 0.9	10	9.214	83.546	85.547	84.545	544.25	20.18	4	1.079	$(10)(29.82)(544.25)$ $(9.214)(29.82 + \frac{13.6}{13.6})(546)$
0.9 0.9	10	9.272	87.547.5	89.549.5	88.549.5	547.0	20.10	4	1.075	$(10)(29.82)(547.0)$ $(9.272)(29.82 + \frac{13.6}{13.6})(547.5)$
									$Y = 1.080$	

* If there is only one thermometer on the dry gas meter, record the temperature under t_d

where

$$1.02315 \leftarrow 1.077 \rightarrow 1.13085$$

V_w = Gas volume passing through the wet test meter, ft^3 .

V_d = Gas volume passing through the dry gas meter, ft^3 .

t_w = Temperature of the gas in the wet test meter, $^{\circ}F$.

t_{d_i} = Temperature of the inlet gas of the dry gas meter, $^{\circ}F$.

t_{d_o} = Temperature of the outlet gas of the dry gas meter, $^{\circ}F$.

t_d = Average temperature of the gas in the dry gas meter, obtained by the average of t_{d_i} and t_{d_o} , $^{\circ}F$.

ΔH = Pressure differential across orifice, in. H_2O .

Y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.

Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs;

tolerance = pretest $Y \pm 0.05Y$. 0.05385

P_b = Barometric pressure, in. Hg.

θ = Time of calibration run, min.

POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number _____ Date 22 Feb 89 Meter box number one-Nutech Plant Post Office/CARISOM
 Barometric pressure, $P_b = 29.740$ in. Hg Dry gas meter number standard Pretest Y 1.077

Orifice manometer setting, (ΔH), in. H_2O	Gas volume		Temperature				Time (θ), min	Vacuum setting, in. Hg	Y_i	Y_i $V_w P_b (t_d + 460)$ $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$
	Wet test meter, (V_w), ft^3	Dry gas meter (V_d), ft^3	Wet test meter (t_w), $^{\circ}F$	Dry gas meter		Average (t_d), $^{\circ}F$				
				Inlet (t_{d_i}), $^{\circ}F$	Outlet (t_{d_o}), $^{\circ}F$					
2.5	10	9.280	77 537.2	81 543.5	77 533.0	538.25	12.33	8.0	1.074	$\frac{(10)(29.74)(538.25)}{(9.280)(29.74 + \frac{0}{13.6})(537)}$
2.5	10	9.306	77 537.2	81 547.5	77 536.5	542.00	12.31	8.0	1.078	$\frac{(10)(29.74)(542)}{(9.306)(29.74 + \frac{0}{13.6})(537)}$
2.5	10	9.343	77 537.2	81 551.0	77 541.0	546.00	12.32	8.0	1.082	$\frac{(10)(29.74)(546)}{(9.343)(29.74 + \frac{0}{13.6})(537)}$
									$Y = 1.078$	

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d where

V_w = Gas volume passing through the wet test meter, ft^3 .

V_d = Gas volume passing through the dry gas meter, ft^3 .

t_w = Temperature of the gas in the wet test meter, $^{\circ}F$.

t_{d_i} = Temperature of the inlet gas of the dry gas meter, $^{\circ}F$.

t_{d_o} = Temperature of the outlet gas of the dry gas meter, $^{\circ}F$.

t_d = Average temperature of the gas in the dry gas meter, obtained by the average of t_{d_i} and t_{d_o} , $^{\circ}F$.

ΔH = Pressure differential across orifice, in. H_2O .

Y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.

Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest $Y \pm 0.05Y$.

P_b = Barometric pressure, in. Hg.

θ = Time of calibration run, min.

$$[1.077 \pm 0.0537] \Rightarrow 1.0231 \leftrightarrow 1.1369$$

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

NOTECH #2

Date 3 JAN 89

Thermocouple number INLET/OUTLET

Ambient temperature 26 °C Barometric pressure _____ in. Hg

Calibrator GARRISON Reference: mercury-in-glass ASTM 63 F
SCOTT other _____

Reference point number	Source ^a (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, ^b °C *
INLET				
-	HOT WATER BATH	43.5	43	.5
-	ROOM TEMP	26	26	0
OUTLET				
-	HOT WATER BATH	43.5	42	1
-	ROOM TEMP	26	26.5	.5

^a type of calibration system used.

^b
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

Quality Assurance Handbook M5-2.5

* MUST BE WITHIN 3°C OF REFERENCE

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 19/10/88 Thermocouple number DI IMPINGER
 Ambient temperature 26 °C Barometric pressure 29.232 in. Hg
 Calibrator GARRISON/ Reference: mercury-in-glass NBS
SCOTT other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C % °C *
0	ICE BATH	0	0	—
—	ROOM TEMP	25.5	26.1	0.6

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 19²⁰ OCT 88 Thermocouple number 1 IMPINGER D2
 Ambient temperature 26° °C Barometric pressure 29.232/29.175 in. Hg
 Calibrator GARRISON SCOTT Reference: mercury-in-glass NBS
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C ^c % °C *
0	ICE BATH	0	0	—
—	ROOM TEMP	26.0	26.6	0.6

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

IMPINGER

Date 19/10/88 Thermocouple number D3
 Ambient temperature 26 °C Barometric pressure 29.232/29.175 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C % °C *
C	ICE BATH	0	0.6	0.6
—	ROOM TEMP	25.8	25.6	0.2

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

IMPINGER

Date 19/10/88 Thermocouple number DY
 Ambient temperature 26 °C Barometric pressure 29.232 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C ^c % °C *
0	ICE BATH	0	0.6	0.6
-	ROOM TEMP	25.5	25.6	0.1

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

IMPINGER

Date 19 Oct 88 Thermocouple number D5
 Ambient temperature 26 °C Barometric pressure 29.232 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C ^c *
0	ICE BATH	0	0.6	0.6
—	ROOM TEMP	26	25.5	0.5

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 19/20 Oct 88 Thermocouple number IMPINGER D6
 Ambient temperature 26 °C Barometric pressure 29.232 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference ^c , °C *
0	ICE BATH	0	0.6	0.6
—	ROOM TEMP	26	25.5	0.5

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 19/20 Oct 88 Thermocouple number IMPINGER D7
 Ambient temperature 26 °C Barometric pressure 29.232 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other ~

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C ^c %
0	ICE BATH	0	0.6	0.6
-	ROOM TEMP	26	25.5	0.5

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook 12-2.10

STACK SENSOR CALIBRATION: 19-20 Oct 88

SENSOR #	REFERENCE TEMPERATURE (deg K) X axis	TEST TEMPERATURE (deg K) Y axis
----------	---	------------------------------------

P1	273.30	273.60
	371.90	373.60
	447.00	450.20

Regression Output:

Constant	-4.30
Std Err of Y Est	0.20
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.02
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.29%

P2	273.30	273.60
	371.80	373.60
	447.60	450.80

Regression Output:

Constant	-4.27
Std Err of Y Est	0.11
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.02
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.25%

P3	273.30	274.10
	371.90	374.10
	447.60	450.80

Regression Output:

Constant	-2.96
Std Err of Y Est	0.03
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.01
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.11%

P4	273.30	273.60
	371.80	373.60
	447.60	450.80

Regression Output:

Constant	-4.27
Std Err of Y Est	0.11
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.02
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.27%

P5

273.30	274.10
371.90	373.60
447.60	450.80

Regression Output:

Constant	-3.03
Std Err of Y Est	0.37
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.01
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.08%

P6

273.30	273.30
371.90	373.60
447.60	450.80

Regression Output:

Constant	-5.03
Std Err of Y Est	0.09
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.02
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.37%

P7

273.30	273.30
371.90	373.60
447.60	450.80

Regression Output:

Constant	-5.03
Std Err of Y Est	0.09
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.02
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.37%

P8

273.60	273.60
371.80	373.00
449.40	452.40

Regression Output:

Constant	-4.75
Std Err of Y Est	0.39
R Squared	1.00
No. of Observations	3.00
Degrees of Freedom	1.00

X Coefficient(s)	1.02
Std Err of Coef.	0.00

% Deviation @ 2000 F(1093.3 K) = 1.25%

APPENDIX J

EPA Computer Program Emissions Calculations

(This page left blank)

XROM "METH 5"

RUN NUMBER
B3 R1 SCR: B RUN
METER BOX Y?
1.0770 RUN
DELTA H?
2.3500 RUN
BAR PRESS ?
28.9750 RUN
METER VOL ?
43.9090 RUN
MTR TEMP F?
96.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ?
-1.1600 RUN
STACK TEMP.
107.0000 RUN
ML. WATER ?
63.9000 RUN
SAT % = 8.2

IMP. % HOH = 6.4

% HOH=6.4

% CO2?
4.4000 RUN
% OXYGEN?
14.3000 RUN
% CO ? RUN
MOL WT OTHER? RUN

MWd =29.28
MW WET=28.55

SQRT PSTS ?
11.1156 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3200 RUN
STK DIA INCH ?
60.0000 RUN

* VOL MTR STD = 43.749
STK PRES ABS = 28.96
VOL HOH GAS = 3.01
% MOISTURE = 6.43
MOL DRY GAS = 0.936
% NITROGEN = 81.30
MOL WT DRY = 29.28
MOL WT WET = 28.55
VELOCITY FPS = 27.76
STACK AREA = 19.63
STACK ACFM = 32.702.
* STACK DSCFM = 27,583.
% ISOKINETIC = 92.99

XROM "METH 5"

RUN NUMBER
B3 R2 SCR: B RUN
METER BOX Y?
1.0770 RUN
DELTA H?
2.3100 RUN
BAR PRESS ?
28.9750 RUN
METER VOL ?
44.5310 RUN
MTR TEMP F?
104.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ?
-1.1600 RUN
STACK TEMP.
108.0000 RUN
ML. WATER ?
72.0000 RUN
SAT % = 8.4

IMP. % HOH = 7.2

% HOH=7.2

% CO2?
4.2000 RUN
% OXYGEN?
13.6000 RUN
% CO ? RUN
MOL WT OTHER? RUN

MWd =29.22
MW WET=28.41

SQRT PSTS ?
11.0021 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3200 RUN
STK DIA INCH ?
60.0000 RUN

* VOL MTR STD = 43.735
STK PRES ABS = 28.96
VOL HOH GAS = 3.39
% MOISTURE = 7.19
MOL DRY GAS = 0.928
% NITROGEN = 82.20
MOL WT DRY = 29.22
MOL WT WET = 28.41
VELOCITY FPS = 27.54
STACK AREA = 19.63
STACK ACFM = 32.449.
* STACK DSCFM = 27,099.
% ISOKINETIC = 94.62

XROM "METH 5"

RUN NUMBER
B3 R3 SCR: B RUN
METER BOX Y?
1.0770 RUN
DELTA H?
2.3200 RUN
BAR PRESS ?
28.9750 RUN
METER VOL ?
44.4790 RUN
MTR TEMP F?
103.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ?
-1.1600 RUN
STACK TEMP.
109.0000 RUN
ML. WATER ?
71.0000 RUN
SAT % = 8.7

IMP. % HOH = 7.1

% HOH=7.1

% CO2?
4.0000 RUN
% OXYGEN?
13.9000 RUN
% CO ? RUN
MOL WT OTHER? RUN

MWd =29.20
MW WET=28.40

SQRT PSTS ?
11.0489 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3200 RUN
STK DIA INCH ?
60.0000 RUN

* VOL MTR STD = 43.763
STK PRES ABS = 28.96
VOL HOH GAS = 3.34
% MOISTURE = 7.09
MOL DRY GAS = 0.929
% NITROGEN = 82.10
MOL WT DRY = 29.20
MOL WT WET = 28.40
VELOCITY FPS = 27.66
STACK AREA = 19.63
STACK ACFM = 32.591.
* STACK DSCFM = 27,199.
% ISOKINETIC = 94.33

XROM "MASSFLO"

RUN NUMBER
B3 R1 SCR: B

RUN

VOL MTR STD ?

43.7490 RUN

STACK DSCFM ?

27,583.0000 RUN

FRONT 1/2 MG ?

69.7000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.0246

F MG/MMM = 56.2615

F LB/HR = 5.8128

F KG/HR = 2.6367

XROM "MASSFLO"

RUN NUMBER
B3 R2 SCR: B

RUN

VOL MTR STD ?

43.7350 RUN

STACK DSCFM ?

27,099.0000 RUN

FRONT 1/2 MG ?

58.4000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.0206

F MG/MMM = 47.1553

F LB/HR = 4.7865

F KG/HR = 2.1711

XROM "MASSFLO"

RUN NUMBER
B3 R3 SCR: B

RUN

VOL MTR STD ?

43.7630 RUN

STACK DSCFM ?

27,199.0000 RUN

FRONT 1/2 MG ?

.0000 CLX

86.7000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.0306

F MG/MMM = 69.9615

F LB/HR = 7.1276

F KG/HR = 3.2331

XROM "METH 5"

RUN NUMBER
B4 R1 SCR: A
RUN
METER BOX Y?
1.0770 RUN
DELTA H?
3.0100 RUN
BAR PRESS ?
29.3810 RUN
METER VOL ?
48.3930 RUN
MTR TEMP F?
96.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ?
RUN
STATIC HOH IN ?
-.2900 RUN
STACK TEMP.
93.0000 RUN
ML. WATER ?
58.6000 RUN
SAT % = 5.3

IMP. % HOH = 5.3

% HOH=5.3

% CO2?
3.0000 RUN
% OXYGEN?
17.6000 RUN
% CO ?
RUN
MOL WT OTHER?
RUN

MWd =29.18
MW WET=28.59

SQRT PSTS ?
13.1919 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3030 RUN
STK DIA INCH ?
60.0000 RUN

* VOL MTR STD = 48.969
STK PRES ABS = 29.36
VOL HOH GAS = 2.76
% MOISTURE = 5.31
MOL DRY GAS = 0.947
% NITROGEN = 79.40
MOL WT DRY = 29.18
MOL WT WET = 28.59
VELOCITY FPS = 32.70
STACK AREA = 19.63
STACK ACFM = 38.521.
* STACK BSCFM = 34,175.
% ISOKINETIC = 93.70

XROM "METH 5"

RUN NUMBER
B4 R2 SCR: A
RUN
METER BOX Y?
1.0770 RUN
DELTA H?
3.2400 RUN
BAR PRESS ?
29.3810 RUN
METER VOL ?
50.4200 RUN
MTR TEMP F?
99.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ?
RUN
STATIC HOH IN ?
-.2900 RUN
STACK TEMP.
95.0000 RUN
ML. WATER ?
62.1000 RUN
SAT % = 5.6

IMP. % HOH = 5.4

% HOH=5.4

% CO2?
2.0000 RUN
% OXYGEN?
15.3000 RUN
% CO ?
RUN
MOL WT OTHER?
RUN

MWd =29.06
MW WET=28.46

SQRT PSTS ?
13.0003 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3030 RUN
STK DIA INCH ?
60.0000 RUN

* VOL MTR STD = 50.775
STK PRES ABS = 29.36
VOL HOH GAS = 2.92
% MOISTURE = 5.44
MOL DRY GAS = 0.946
% NITROGEN = 81.90
MOL WT DRY = 29.06
MOL WT WET = 28.46
VELOCITY FPS = 34.29
STACK AREA = 19.63
STACK ACFM = 40,391.
* STACK BSCFM = 35,654.
% ISOKINETIC = 93.12

XROM "METH 5"

RUN NUMBER
B4 R3 SCR: A
RUN
METER BOX Y?
1.0770 RUN
DELTA H?
3.3500 RUN
BAR PRESS ?
29.3810 RUN
METER VOL ?
50.2570 RUN
MTR TEMP F?
104.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ?
RUN
STATIC HOH IN ?
-.2900 RUN
STACK TEMP.
98.0000 RUN
ML. WATER ?
53.7000 RUN
SAT % = 6.2

IMP. % HOH = 4.8

% HOH=4.8

% CO2?
2.2000 RUN
% OXYGEN?
15.4000 RUN
% CO ?
RUN
MOL WT OTHER?
RUN

MWd =28.97
MW WET=28.44

SQRT PSTS ?
14.1679 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3030 RUN
STK DIA INCH ?
60.0000 RUN

* VOL MTR STD = 50.176
STK PRES ABS = 29.36
VOL HOH GAS = 2.53
% MOISTURE = 4.80
MOL DRY GAS = 0.952
% NITROGEN = 82.40
MOL WT DRY = 28.97
MOL WT WET = 28.44
VELOCITY FPS = 35.06
STACK AREA = 19.63
STACK ACFM = 41,303.
* STACK BSCFM = 36,511.
% ISOKINETIC = 89.86

XROM "MASSFLO"

RUN NUMBER
B4 R1 SCR: A
RUN
VOL MTR STD ?
48.9690 RUN
STACK DSCFM ?
34,175.0000 RUN
FRONT 1/2 MG ?
61.3000 RUN
BACK 1/2 MG ?
0.0000 RUN

F GR/DSCF = 0.0193
F MG/MMM = 44.2065
F LB/HR = 5.6500
F KG/HR = 2.5660

XROM "MASSFLO"

RUN NUMBER
B4 R2 SCR: A
RUN
VOL MTR STD ?
50.7750 RUN
STACK DSCFM ?
35,654.0000 RUN
FRONT 1/2 MG ?
32.7000 RUN
BACK 1/2 MG ?
0.0000 RUN

F GR/DSCF = 0.0099
F MG/MMM = 22.7420
F LB/HR = 3.0373
F KG/HR = 1.3777

XROM "MASSFLO"

RUN NUMBER
B4 R3 SCR: A
RUN
VOL MTR STD ?
50.1760 RUN
STACK DSCFM ?
36,511.0000 RUN
FRONT 1/2 MG ?
31.5000 RUN
BACK 1/2 MG ?
0.0000 RUN

F GR/DSCF = 0.0097
F MG/MMM = 22.1690
F LB/HR = 3.0319
F KG/HR = 1.3753

RUN NUMBER
B5 R1 SCR: 8

METER BOX Y? RUN
1.0770 RUN
DELTA H? RUN
2.4800 RUN
BAR PRESS ? RUN
29.4550 RUN
METER VOL ? RUN
43.4910 RUN
MTR TEMP F? RUN
95.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ? RUN
-1.1900 RUN
STACK TEMP. RUN
116.0000 RUN
ML. WATER ? RUN
71.6000 RUN
SAT % = 10.4

IMP. % HOH = 7.1

% HOH=7.1

% CO2?

7.2000 RUN

% OXYGEN?

11.9000 RUN

% CO ?

RUN

MOL WT OTHER?

RUN

MWd =29.63

MW WET=28.80

SQRT PSTS ?

11.6471 RUN

TIME MIN ?

60.0000 RUN

NOZZLE DIA ?

.3200 RUN

STK DIA INCH ?

60.0000 RUN

* VOL MTR STD = 44.140

STK PRES ABS = 29.44

VOL HOH GAS = 3.37

% MOISTURE = 7.09

MOL DRY GAS = 0.929

% NITROGEN = 80.90

MOL WT DRY = 29.63

MOL WT WET = 28.80

VELOCITY FPS = 28.72

STACK AREA = 19.63

STACK ACFM = 33.837.

* STACK DSCFM = 28.356.

% ISOKINETIC = 91.26

RUN NUMBER
B5 R2 SCR: 8

METER BOX Y? RUN
1.0770 RUN
DELTA H? RUN
2.6000 RUN
BAR PRESS ? RUN
29.4550 RUN
METER VOL ? RUN
46.0820 RUN
MTR TEMP F? RUN
106.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ? RUN
-1.1900 RUN
STACK TEMP. RUN
107.0000 RUN
ML. WATER ? RUN
74.3000 RUN
SAT % = 8.1

IMP. % HOH = 7.1

% HOH=7.1

% CO2?

6.2000 RUN

% OXYGEN?

11.6000 RUN

% CO ?

RUN

MOL WT OTHER?

RUN

MWd =29.46

MW WET=28.64

SQRT PSTS ?

11.6253 RUN

TIME MIN ?

60.0000 RUN

NOZZLE DIA ?

.3200 RUN

STK DIA INCH ?

60.0000 RUN

* VOL MTR STD = 45.874

STK PRES ABS = 29.44

VOL HOH GAS = 3.50

% MOISTURE = 7.06

MOL DRY GAS = 0.929

% NITROGEN = 82.20

MOL WT DRY = 29.46

MOL WT WET = 28.64

VELOCITY FPS = 28.75

STACK AREA = 19.63

STACK ACFM = 33.867.

* STACK DSCFM = 28.835.

% ISOKINETIC = 93.27

RUN NUMBER
B5 R3 SCR: 8

METER BOX Y? RUN
1.0770 RUN
DELTA H? RUN
2.4900 RUN
BAR PRESS ? RUN
29.4550 RUN
METER VOL ? RUN
44.6550 RUN
MTR TEMP F? RUN
105.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ? RUN
-1.1900 RUN
STACK TEMP. RUN
112.0000 RUN
ML. WATER ? RUN
79.7000 RUN
SAT % = 9.3

IMP. % HOH = 7.8

% HOH=7.8

% CO2?

6.0000 RUN

% OXYGEN?

11.4000 RUN

% CO ?

RUN

MOL WT OTHER?

RUN

MWd =29.42

MW WET=28.53

SQRT PSTS ?

11.4725 RUN

TIME MIN ?

60.0000 RUN

NOZZLE DIA ?

.3200 RUN

STK DIA INCH ?

60.0000 RUN

* VOL MTR STD = 44.520

STK PRES ABS = 29.44

VOL HOH GAS = 3.75

% MOISTURE = 7.77

MOL DRY GAS = 0.922

% NITROGEN = 82.60

MOL WT DRY = 29.42

MOL WT WET = 28.53

VELOCITY FPS = 28.47

STACK AREA = 19.63

STACK ACFM = 33.490.

* STACK DSCFM = 28.055.

% ISOKINETIC = 93.04

XROM "MASSFLO"

RUN NUMBER
B5 R1 SCR: 8

RUN

VOL MTR STD ?

44.1400 RUN

STACK DSCFM ?

28.356.0000 RUN

FRONT 1/2 MG ?

131.5000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.0460
F MG/MMH = 105.2060
F LB/HR = 11.1742
F KG/HR = 5.0686

XROM "MASSFLO"

RUN NUMBER
B5 R1 SCR: 8

RUN

VOL MTR STD ?

45.8740 RUN

STACK DSCFM ?

28.835.0000 RUN

FRONT 1/2 MG ?

90.4000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.0304
F MG/MMH = 69.5903
F LB/HR = 7.5162
F KG/HR = 3.4094

XROM "MASSFLO"

RUN NUMBER
B5 R3 SCR: 8

RUN

VOL MTR STD ?

44.5200 RUN

STACK DSCFM ?

28.055.0000 RUN

FRONT 1/2 MG ?

85.4000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.0296
F MG/MMH = 67.7407
F LB/HR = 7.1185
F KG/HR = 3.2290

XROM "MASSFLO"

RUN NUMBER

B5 R1 BP

RUN

VOL MTR STD ?

37.7110 RUN

STACK DSCFM ?

17,484.0000 RUN

FRONT 1/2 MG ?

348.8000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.1427

F MG/MMH = 326.6295

F LB/HR = 21.3908

F KG/HR = 9.7029

XROM "MASSFLO"

RUN NUMBER

B5 R2 BP

RUN

VOL MTR STD ?

34.8650 RUN

STACK DSCFM ?

16,370.0000 RUN

FRONT 1/2 MG ?

322.3000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.1427

F MG/MMH = 326.4507

F LB/HR = 20.0169

F KG/HR = 9.0797

XROM "MASSFLO"

RUN NUMBER

B5 R3 BP

RUN

VOL MTR STD ?

36.3100 RUN

STACK DSCFM ?

17,075.0000 RUN

FRONT 1/2 MG ?

505.4000 RUN

BACK 1/2 MG ?

0.0000 RUN

F GR/DSCF = 0.2148

F MG/MMH = 491.5366

F LB/HR = 31.4375

F KG/HR = 14.2600

XROM -METH 5-

RUN NUMBER
B5 R1 BP

METER BOX Y? RUN
1.0770 RUN
DELTA H? RUN
1.4600 RUN
BAR PRESS ? RUN
29.4100 RUN
METER VOL ? RUN
34.2830 RUN
MTR TEMP F? RUN
50.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ? RUN
-.1200 RUN
STACK TEMP.
296.0000 RUN
ML. WATER ? RUN
50.5000 RUN
IMP. % HOH = 5.9
% HOH=5.9

% CO2? RUN
9.0000 RUN
% OXYGEN? RUN
9.2000 RUN
% CO ? RUN
MOL WT OTHER? RUN

MWD =29.81
MW WET=29.11

SORT PSTS ?
7.7591 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3950 RUN
STK DIA INCH ?
66.0000 RUN

* VOL MTR STD = 37.711
STK PRES ABS = 29.40
VOL HOH GAS = 2.38
% MOISTURE = 5.93
MOL DRY GAS = 0.941
% NITROGEN = 81.88
MOL WT DRY = 29.81
MOL WT WET = 29.11
VELOCITY FPS = 19.00
STACK AREA = 23.76
STACK ACFM = 27.001.
* STACK DSCFM = 17,484.
% ISOKINETIC = 100.42

XROM -METH 5-

RUN NUMBER
B5 R2 BP

METER BOX Y? RUN
1.0770 RUN
DELTA H? RUN
1.3600 RUN
BAR PRESS ? RUN
29.4100 RUN
METER VOL ? RUN
32.2010 RUN
MTR TEMP F? RUN
50.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ? RUN
-.1200 RUN
STACK TEMP.
281.0000 RUN
ML. WATER ? RUN
50.7000 RUN
IMP. % HOH = 7.3
% HOH=7.3

% CO2? RUN
10.6000 RUN
% OXYGEN? RUN
7.7000 RUN
% CO ? RUN
MOL WT OTHER? RUN

MWD =30.00
MW WET=29.12

SORT PSTS ?
7.2127 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3950 RUN
STK DIA INCH ?
66.0000 RUN

* VOL MTR STD = 34.865
STK PRES ABS = 29.40
VOL HOH GAS = 2.76
% MOISTURE = 7.34
MOL DRY GAS = 0.927
% NITROGEN = 81.70
MOL WT DRY = 30.00
MOL WT WET = 29.12
VELOCITY FPS = 17.70
STACK AREA = 23.76
STACK ACFM = 25.233.
* STACK DSCFM = 16,370.
% ISOKINETIC = 99.16

XROM -METH 5-

RUN NUMBER
B5 R3 BP

METER BOX Y? RUN
1.0770 RUN
DELTA H? RUN
1.4700 RUN
BAR PRESS ? RUN
29.4100 RUN
METER VOL ? RUN
34.4970 RUN
MTR TEMP F? RUN
73.0000 RUN
% OTHER GAS
REMOVED BEFORE
DRY GAS METER ? RUN
STATIC HOH IN ? RUN
-.1200 RUN
STACK TEMP.
281.0000 RUN
ML. WATER ? RUN
57.0000 RUN
IMP. % HOH = 6.9
% HOH=6.9

% CO2? RUN
7.4000 RUN
% OXYGEN? RUN
10.3000 RUN
% CO ? RUN
MOL WT OTHER? RUN

MWD =29.60
MW WET=28.80

SORT PSTS ?
7.4441 RUN
TIME MIN ?
60.0000 RUN
NOZZLE DIA ?
.3950 RUN
STK DIA INCH ?
66.0000 RUN

* VOL MTR STD = 36.310
STK PRES ABS = 29.40
VOL HOH GAS = 2.68
% MOISTURE = 6.88
MOL DRY GAS = 0.931
% NITROGEN = 82.30
MOL WT DRY = 29.60
MOL WT WET = 28.80
VELOCITY FPS = 18.37
STACK AREA = 23.76
STACK ACFM = 26.180.
* STACK DSCFM = 17,075.
% ISOKINETIC = 99.01


APPENDIX K
EPA Method 9 Certification

(This page left blank)

The Texas Air Control Board
Certifies That

PAUL T. SCOTT

Has completed a course conducted by The Texas Air Control Board and
has met the requirements for evaluating visible emissions.

 March 17, 1989
Date Certified

September 15, 1989
This Certificate Expires

[Signature] [Signature]
Certifying Officer Date

This is a recertification; initial certification was Sept 1988.

(This page left blank)

DISTRIBUTION LIST

	Copies
HQ AFSC/SGPB Andrews AFB DC 20334-5000	1
HQ USAF/SGPA Bolling AFB DC 20332-6188	1
HQ SAC/SGPB Offutt AFB NE 68113-5001	1
USAF Regional Medical Center Wiesbaden/SGB APO New York 09220-5300	1
OL AD, AFOEHL APO San Francisco 96274-5000	1
USAFSAM/TSK Brooks AFB TX 78235-5301	1
USAFSAM/EDH Brooks AFB TX 78235-5301	1
Defense Technical Information Center(DTIC) Cameron Station Alexandria VA 22304-6145	2
HQ HSD/XAE Brooks AFB TX 78235-5501	1
HQ USAF/LEEV Bolling AFB DC 20330-5000	1
HQ AFESC/RDV Tyndall AFB FL 32403-6001	1
HQ SAC/DE Offutt AFB NE 68113-5001	1
USAF Hospital Grissom/SGPB Grissom AFB IN 46971-5300	2
USAF Hospital Grissom/SGPB Grissom AFB IN 46971-5300	2