

DTIC FILE COPY

AFOEHL REPORT 89-128EQ0013LEF



AD-A218 621

**Source Emission Testing of Hospital Pathological
Waste Incinerator, Beale AFB CA**

ROBERT W. VAUGHN, Capt, USAF, BSC

December 1989

Final Report



Distribution is unlimited; approved for public release

**AF Occupational and Environmental Health Laboratory (AFSC)
Human Systems Division
Brooks Air Force Base, Texas 78235-5501**

90 03 02 085

NOTICES

When Government drawings, specifications, or other data are used for any purpose other than a definitely related Government procurement operation, the Government incurs no responsibility or any obligation whatsoever. The fact that the Government may have formulated, or in any way supplied the drawing, specifications, or other data, is not to be regarded by implication, or otherwise, as in any manner licensing the holder or any other person or corporation; or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

The mention of trade names or commercial products in this publication is for illustration purposes and does not constitute endorsement or recommendation for use by the United States Air Force.

The Public Affairs Office has reviewed this report, and it is releasable to the National Technical Information Service, where it will be available to the general public, including foreign nations.


This report has been reviewed and is approved for publication.

Air Force installations may direct requests for copies of this report to: Air Force Occupational and Environmental Health Laboratory (AFOEHL) Library, Brooks AFB TX 78235-5501.

Other Government agencies and their contractors registered with the DTIC should direct requests for copies of this report to: Defense Technical Information Center (DTIC), Cameron Station, Alexandria VA 22304-6145.

Non-Government agencies may purchase copies of this report from: National Technical Information Service (NTIS), 5285 Port Royal Road, Springfield VA 22161


RONALD W. VAUGHN, Capt, USAF, BSC
Consultant, Air Quality Function


ROBERT D. BINOVI, Lt Col, USAF, BSC
Chief, Environmental Quality Division

REPORT DOCUMENTATION PAGE

Form Approved
OMB No 0704-0188

1a. REPORT SECURITY CLASSIFICATION Unclassified		1b. RESTRICTIVE MARKINGS N/A	
2a. SECURITY CLASSIFICATION AUTHORITY N/A		3. DISTRIBUTION / AVAILABILITY OF REPORT Approved for public release. Distribution is unlimited.	
2b. DECLASSIFICATION / DOWNGRADING SCHEDULE N/A			
4. PERFORMING ORGANIZATION REPORT NUMBER(S) AFOEHL Report 89-128EQ0013LEF		5. MONITORING ORGANIZATION REPORT NUMBER(S)	
6a. NAME OF PERFORMING ORGANIZATION AF Occupational and Environmental Health Laboratory.	6b. OFFICE SYMBOL (if applicable) EQE	7a. NAME OF MONITORING ORGANIZATION	
6c. ADDRESS (City, State, and ZIP Code) Brooks AFB TX 78235-5501		7b. ADDRESS (City, State, and ZIP Code)	
8a. NAME OF FUNDING / SPONSORING ORGANIZATION Same as 6a	8b. OFFICE SYMBOL (if applicable)	9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER	
8c. ADDRESS (City, State, and ZIP Code) Same as 6c		10. SOURCE OF FUNDING NUMBERS	
		PROGRAM ELEMENT NO	PROJECT NO
		TASK NO	WORK UNIT ACCESSION NO
11. TITLE (Include Security Classification) Source Emission Testing of Hospital Pathological Waste Incinerator, Beale AFB CA			
12. PERSONAL AUTHOR(S) Capt Ronald W. Vaughn			
13a. TYPE OF REPORT Final	13b. TIME COVERED FROM 28 Aug TO 1 Sep 89	14. DATE OF REPORT (Year, Month, Day) December 1989	15. PAGE COUNT 62
16. SUPPLEMENTARY NOTATION			
17. COSATI CODES		18. SUBJECT TERMS (Continue on reverse if necessary and identify by block number)	
FIELD	GROUP	SUB-GROUP	
		Stationary Source Testing, Beale, Particulates, Stack Sampling, Vaughn, Hydrogen Chloride, Pathological Incinerator, Air Pollution (EG)	
19. ABSTRACT (Continue on reverse if necessary and identify by block number)			
At the request of HQ SAC/SGPB, source testing for particulate, chloride and visible emissions was conducted on the hospital Pathological Waste Incinerator. Testing was accomplished on 30 Aug 89. The survey was conducted to determine if the incinerator will meet the hospital's future needs. Incinerator usage will increase due to the closure of Mather AFB. Results indicate that the incinerator met both particulate and visible emissions standards. There is no standard for chloride emissions in the Yuba Air Pollution Control District. However, the incinerator will not be capable of handling an increased workload. A long term disposal method for pathological waste needs to be developed.			
20. DISTRIBUTION / AVAILABILITY OF ABSTRACT <input type="checkbox"/> UNCLASSIFIED/UNLIMITED <input checked="" type="checkbox"/> SAME AS RPT <input type="checkbox"/> DTIC USERS		21. ABSTRACT SECURITY CLASSIFICATION Unclassified	
22a. NAME OF RESPONSIBLE INDIVIDUAL Capt Ronald W. Vaughn		22b. TELEPHONE (Include Area Code) (512) 536-2891 AV 240	22c. OFFICE SYMBOL AFOEHL/EQE

(This page left blank)

Contents

	Page
DD Form 1473	i
Illustrations	iv
I. INTRODUCTION	1
II. DISCUSSION	1
III. CONCLUSIONS	6
IV. RECOMMENDATIONS	7
References	8
Appendix	
A Personal Information	9
B State Regulations	13
C Field Data	21
D Calibration Data	35
E Acetone Blank Results and Particulate Emissions Calculations	49
F Hydrogen Chloride Emissions Calculations	55
Distribution List	59

Accession For	
NTIS GRA&I	<input checked="" type="checkbox"/>
DTIC TAB	<input type="checkbox"/>
Unannounced	<input type="checkbox"/>
Justification	
By _____	
Distribution/	
Availability Codes	
Dist	Avail and/or Special
A-1	

Illustrations

Figure	Title	Page
1	Pathological Waste Incinerator	2
2	Grab Sampling Train	3
3	Orgat Apparatus	3
4	Particulate Sampling Train	4
5	Visible Emissions	6

Table

1	Particulate Emissions Test Results	5
2	Hydrogen Chloride Emissions Results	5

I. INTRODUCTION

On 30 Aug 89, source emission testing for particulates, chloride, and visible emissions was conducted at the 9 Strategic Hospital pathological incinerator at Beale AFB by personnel from the Air Quality Function of the AF Occupational and Environmental Health Laboratory (AFOEHL). This survey was requested by the 9 Strategic Hospital Commander to determine if the incinerator will meet their future needs. Increased incinerator use is anticipated due to the closure of Mather AFB. Personnel involved with on-site testing are listed in Appendix A.

II. DISCUSSION

A. Background

The 9 Strategic Hospital Commander has become concerned about the environmental impact of a hospital expansion. The mission of the hospital is expected to increase due to the projected closure of Mather AFB and the transfer of navigator training to Beale AFB. Pathological waste is presently incinerated in the hospital pathological incinerator. Hospital administrators are concerned the incinerator may become overburdened if the mission increases.

B. Site Description

The pathological waste incinerator is located inside a small building behind the hospital. The exhaust stack extends through the roof. A photograph of the exhaust stack is shown in Figure 1. The incinerator was manufactured by Bayco (Model PR2B-100) and was designed for Type 4 waste (defined as human and animal solid refuse consisting of carcasses and organs from hospitals, laboratories, and slaughterhouses). The unit does not have any air pollution control equipment and has the following operational parameters:

1. two-chamber design
2. propane fired
3. 100 pounds per hour(lb/hr) load capacity

The incinerator is operated on a batch cycle at about 100 lb per burn. The burn time is about one hour. Approximately 14 batches of waste are burned per week.

C. Applicable Standards: Local standards applicable to incinerators used for disposal of pathological waste are defined under the County of Yuba, Air Pollution Control District Regulation III, Prohibition - Stationary Emission Sources, Rules 3.0 and 3.2. These regulations, detailed in Appendix B, address two areas:

1. "Rule 3.0 - Visible emissions: Prohibits emissions from any single source which are as dark or darker as that designated as No. 2 on the Ringelmann Chart or equivalent opacity of 40%."



Figure 1. Pathological Waste Incinerator, Beale AFB CA

2. "Rule 3.2 - Particulate Matter Concentration: prohibits the emission of particulate matter in excess of 0.3 grains of particulate matter per dry cubic foot of exhaust gas (gr/dscf), corrected to 12% carbon dioxide (CO₂), from any source involving a combustion process."

D. Sampling Methods and Procedures

Present regulations require that all emissions testing be conducted in accordance with Appendix A to Title 40, Code of Federal Regulations, Part 60 (40 CFR 60). Therefore, sample train preparation, sampling and recovery, calculations and quality assurance were done in accordance with the methods and procedures outlined in 40 CFR 60, Appendix A and California Method 421.

Two sampling ports were installed at right angles in the stack. Two traverses of the stack cross section were completed. These ports were installed approximately 8 duct diameters downstream and 7 duct diameters upstream from any flow disturbance. Based on the inside stack diameter, port location and type of sample (particulate), 12 traverse points (6 per diameter) were used to collect a representative particulate sample. Appendix C shows port locations and sampling points.

Prior to every sample run, cyclonic flow was determined by using the Type S pitot tube and measuring the stack gas rotational angle at each traverse point. Flow conditions were considered acceptable when the arithmetic average of the rotational angles was 20 degrees or less. A preliminary velocity pressure traverse was also accomplished at this time.

A grab sample for ORSAT analysis (measures oxygen and carbon dioxide for stack gas molecular weight determination) was taken during each sample run. ORSAT sampling and analysis equipment are shown in Figures 2 and 3. Flue gas moisture content, needed for determination of flue gas molecular weight determination, was obtained during particulate sampling.




Figure 2. Grab Sampling Train




Figure 3. ORSAT Apparatus

Particulate and HCl samples were collected using the sampling train shown in Figure 4. The train consisted of a buttonhook probe nozzle, heated incoond probe, heated glass filter, impingers and a pumping and metering device. The nozzle was sized prior to each sample run so that the gas stream could be sampled isokinetically (the velocity at the nozzle tip was the same as the stack gas velocity at each point sampled). Flue gas velocity pressure was measured at the nozzle tip using a Type S pitot tube connected to a 10-inch inclined-vertical manometer. Type K thermocouples were used to measure flue gas and sampling train temperatures. The probe liner was heated to minimize moisture condensation. The heated filter was used to collect particulates. The impinger train consisted of the following components:

1. First, third and fourth impingers: Modified Greenburg-Smith type.
2. Second impinger: Standard Greenburg-Smith design. The apparatus was used as a condenser to collect stack gas moisture and hydrochloric acid (HCl). California Method 421 was used to collect HCl; the distilled water normally used in the first two impingers was replaced with known quantities of 0.003M sodium carbonate and 0.0024M sodium bicarbonate to remove water from the gas sample, as well as act as the collection media for the HCl. The pumping and metering system was used to control and monitor the sample gas flow rate. Equipment calibration data are found in Appendix D.

All calculations were made using the Environmental Protection Agency publication entitled "Source Test Calculation and Check Programs for Hewlett-Packard 41 Calculators", (EPA-340/1-85-013) and associated software programs. Particulate samples were analyzed according to the methods specified in Method 5. HCl samples were analyzed by ion chromatography.




Figure 4. Particulate Sampling Train

E. Results

1. Visible Emissions: Visible emissions averaged less than 40% for all runs. Flame were seen shooting from the top of the incinerator during loading. This probably resulted from excess propane.

2. Particulate Emissions: Gravimetric analysis of the front half of the collector on filterable particulate matter (material collected on sampling train surfaces up to and including the filter) was determined for compliance purposes. Field data sheets are found in Appendix C and the resulting particulate emission calculations are presented in Appendix E. Table 1 provides the final particulate emissions test results. Particulate emissions averaged 0.493 lb/hr. This complies with the applicable limits. This corresponds to an average of 0.25 gr/dscf, below the limit of 0.3 gr/dscf.

3. HCl Emissions: Table 2 presents the final HCl emissions test results. HCl calculations are found in Appendix F. At this time, there are no State standards for HCl emissions.

Table 1. Particulate Emission Test Results

Run	STACK GAS		TOTAL CATCH (mg)	EMISSIONS		
	%CO ₂	%O ₂		(gr/dscf)	CORRECTED TO 12% CO- (gr/dscf)	
1	7.2	10.0	236.8	0.089	0.148	
2	7.4	9.8	449.8	0.159	0.258	
3	8.4	8.4	695.0	0.259	0.370	
				AVG =	0.169	0.259

Table 2: Hydrogen Chloride Emission Test Results

Run #	TOTAL HCL COLLECTED (mg)	SAMPLE VOLUME (dscf)	STACK GAS FLOW RATE (dscfm)	EMISSIONS		
				(gr/dscf)	(lb/hr)	
1	34.9	40.9	313.0	0.013	0.035	
2	13.8	43.5	359.0	0.005	0.015	
3	45.4	41.5	337.0	0.017	0.049	
				AVG =	0.012	0.033

Abbreviations used in Tables 1 and 2

mg = milligrams

gr/dscf = grains per dry standard cubic foot

dscf = dry standard cubic foot

dscfm = dry standard cubic foot per minute

III. CONCLUSIONS

Compliance testing results indicate the incinerator is in compliance with applicable Yuba County visible and particulate emissions standards. However, the following problems were observed during operation of the incinerator:

1. Flames were seen shooting from the top of the incinerator during loading; the stack refractory glowed red throughout the test; and, the stack temperature was observed to reach above 2200°F on several occasions before testing began. These problems were probably the result of excess propane (Figure 5). In addition, the high temperatures precipitated other problems:

- a. low residence time and uncombusted material being blown out of the stack,
- b. increasing the possibility of the formation of dioxins and furans which are carcinogens, and
- c. a hole being burned through the refractory and incinerator wall.




Figure 5. Visible Emission

2. During operation, fugitive emissions leaked from the incinerator door. This exposed the operator to potentially hazardous pollutants.

3. There were no devices for monitoring the primary and secondary chamber temperatures.

4. Although visible emissions met limits, opacity was greater than 40% during loading. The overloading of the incinerator resulted in reduced air circulation and high opacity readings.

The hospital incinerator is presently operating at a capacity that barely meets particulate emission limits. An increase in the incinerator workload will probably increase particulate emissions above the 0.3 gr/dscf limit and cause the visible emissions to exceed the 40% opacity limit (averaged over three minutes). Alternative methods of disposal of pathological waste should be investigated to meet the base's future needs. Two acceptable methods would be contract disposal or procurement of a new incinerator capable of handling the increased workload.

In the interim, the hole in the refractory and incinerator wall should be fixed and thermocouples installed on the primary and secondary chambers. The incinerator's operational components should also be checked, their operation verified, and the unit operated according to good engineering practices. Good engineering practices for pathological waste incinerators are:

1. primary chamber temperatures between 1000 - 1200°F,
2. secondary chamber temperatures between 1600 - 1800°F, and
3. residence time in the secondary chamber of 0.5 seconds.

IV. RECOMMENDATIONS

The pathological waste incinerator will not meet the hospital's future needs. A long term disposal method for pathological waste needs to be developed. AFOEHL will remain active in supporting the base's present and future needs.

REFERENCES

1. Standards of Performance for New Stationary Sources, Title 40, Part 60, Code of Federal Regulations, July 1, 1984.
2. Quality Assurance Handbook for Air Pollution Measurement Systems- Volume III, Stationary Source Specific Methods, U.S. Environmental Protection Agency, EPA-600/4-77-027-b, Research Triangle Park, North Carolina, April 1977.
3. Source Test Calculations and Check Programs for Hewlett-Packard 41 Calculators, U.S. Environmental Protection Agency, EPA-340/1-85-018, Research Triangle Park, North Carolina, September 1985.
4. California Air Resources Board Method 421, Determination of Hydrochloric Acid Emissions from Stationary Sources, adopted 18 March 1987.

APPENDIX A
Personnel Information

(This page left blank)

1. AFOEHL Test Team

Capt Paul Scott, Chief, Air Quality Function
Capt Ronald Vaughn, Consultant, Air Quality Engineer
Capt David Goldblum, Consultant, Environmental Quality
1Lt Charles Attebery, Consultant, Air Quality Engineer

AFOEHL/EQE
Brooks AFB TX 78235-5501

Phone: AUTOVON 240-2891
Commercial (512) 536-2891

2. Beale AFB on-site representatives

Capt Christopher Sherman, 9 Strat Hosp/SGPB
SSgt Maria Ares-Banez, 9 Strat Hosp/SGPB
Phone: AUTOVON 368-2635
Commercial (916) 634-2635

Mr Jack Wise
9 Strat Hosp/SGAL
Phone: AUTOVON 368-2328
Commercial (916) 634-2328

(This page left blank)

APPENDIX B
State Regulations

(This page left blank)

County of Yuba

Air Pollution Control District

DATE AUGUST 10, 1989

PERMIT

NO: BE-01-42

IS HEREBY GRANTED TO

UNITED STATES AIR FORCE - BEALE AIR FORCE BASE

TO OPERATE

SUBJECT TO THE FOLLOWING CONDITIONS

SEE ATTACHED FOR SPECIFIC CONDITIONS:

This permit does not authorize the emission of air contaminants in excess of those allowed by the State of California or the Rules and Regulations of the Air Pollution Control District. This Permit expires one (1) year from date of issuance and must be renewed before the expiration date.

By *Bernie Egan*
Air Pollution Control Officer

938 14th Street
Marysville, California

REVOCABLE AND NOT TRANSFERABLE

BEALE AIR FORCE BASE PERMIT CONDITIONS

1. This permit is valid for one year from date of issue and must be renewed by permittee.
2. This permit does not guarantee that the equipment will comply with the "Rules and Regulations Governing Air Pollution Control in Yuba County" or any applicable state or federal regulations.
3. All equipment, including both process and pollution abatement equipment must be maintained in good working order at all times. In the absence of specific permit conditions to the contrary, the throughputs, fuel and material consumptions, capacities, and hours of operation described in the permit application will be considered maximum allowable limits.
4. The Air Pollution Control Office must be notified of any upset/breakdown or removal of air pollution equipment within 24-hours of such event(s).
5. Prior to adding a new emission source or making any modification to an existing source, permittee must first obtain an approved "Authorization to Construct" from the Yuba County Air Pollution Control Office.

REGULATION III

PROHIBITION - STATIONARY EMISSION SOURCES

Rule 3.0

Visible Emissions: As provided by Section 41701 of the California Health and Safety Code, a person shall not discharge into the atmosphere from any single source of emissions whatsoever, any air contaminants for a period or periods aggregating more than three minutes in any one hour which is:

- a. As dark or darker in shade as that designated as No. 2 on the Ringlemen Chart, as published by the United States Bureau of Mines; or
- b. Of such opacity as to obscure an observers view to a degree equal to or greater than does smoke described in Subsection 'a' above.

Rule 3.1

Exceptions to Rule 3.0: In accordance with Section 41704 of the California Health and Safety Code, nothing in Rule 3.0 shall be construed to prohibit:

- a. Open burning as authorized un Rule 2.1;
- b. The use or orchard and citrus grove heaters which are in compliance with Rule 2.15;
- c. Emissions resulting from food preparation, heating or comfort fires in single or two-family dwellings, providing prohibited materials as outlined in Rule 2.9 of these Rules and Regulations, are not burned.
- d. Emissions from Tee Pee burners or from forestry/agricultural residue burners used to produce energy when such emissions result from start up or shut down of the process or from the malfunction of emission control equipment providing:
 - 1) These emissions shall not exceed a period or periods of time aggregating more than 30 minutes in any 24 hour period.
 - 2) The emissions do not result from the failure to operate and maintain in good working order any emission control equipment.
 - 3) Fuels used are forestry and/or agricultural residue with supplementary fossil fuels.

Rule 3.2

Particulate Matter Concentration: A person shall not discharge into the atmosphere from any source, except as allowed by Rule 3.1, section 'a' and 'c' of these Rules and Regulations, particulate matter in excess of 0.3 grains per cubic foot of gas at standard conditions.

When the source involves a combustion process, the concentration must be calculated to 12 per cent carbon dioxide (CO₂). In measuring the combustion contaminants from incinerators used to dispose of combustible refuse by burning the carbon dioxide (CO₂) produced by combustion of any liquid or gaseous fuels shall be excluded from the calculation to 12 percent of Carbon Dioxide (CO₂).

Rule 3.3

Dust and Fumes: A person shall not discharge in any one hour from any source whatsoever, except as provided by Rule 3.1, section 'a' and 'c' of these Rules and Regulations, dust or fumes in total quantities in excess of the amounts shown in the following table:

To use the following table, take the process weight per hour as such is defined in the attached definitions. Then find this figure on the table opposite which is the maximum number of pounds of contaminants which may be discharged into the atmosphere in any one hour. As an example: if "A" has a process which emits contaminants into the atmosphere and which process takes four (4) hours to complete, he will divide the weight of all materials in the specific process, in this example, 2,400 lbs., by '4', giving a process weight per hour of 600 lbs. The table shows that "A" may not discharge more than 1.83 lbs. in any one hour during the process. Interpolation of the data in the table for process weights up to 60,000 pounds/hour shall be accomplished by use of the equation:

$$E = 4.10 p^{0.67}$$

and interpolation and extrapolation of the data for process weight rates in excess of 60,000 pounds/hour shall be accomplished by use of the equation:

$$E = (55.0 p^{0.11}) - 40$$

E = Rate of emission in pounds/hour;
P = Process weight rate in ton/hour.

ALLOWABLE RATE OF EMISSION BASED ON
PROCESS WEIGHT RATE

Process Weight Rate		Rate of Emission	Process Weight Rate		Rate of Emission
Lb. Hr.	Ton Hr.	Lb. Hr.	Lb. Hr.	tons Hr.	Lb. Hr.
100	0.15	0.551	16,000	8.00	16.5
200	0.10	0.877	18,000	9.00	17.9
400	0.20	1.40	20,000	10.00	19.2
600	0.30	1.83	30,000	15.	25.2
800	0.40	2.22	40,000	20.	30.5
1,000	0.50	2.58	50,000	25.	35.4
1,500	0.75	3.38	60,000	30.	40.0
2,000	1.00	4.10	70,000	35.	41.3
2,500	1.25	4.70	80,000	40.	42.5
3,000	1.50	5.38	90,000	45.	43.8
3,500	1.75	5.96	100,000	50.	44.6
4,000	2.00	6.52	120,000	60.	46.3
5,000	2.50	7.58	140,000	70.	47.8
6,000	3.00	8.56	180,000	80.	49.0
7,000	3.50	9.49	200,000	100.	51.2
8,000	4.00	10.4	1,000,000	500.	69.0
9,000	4.50	11.2	2,000,000	1,000.	77.6
10,000	5.00	12.0	6,000,000	3,000.	92.7
12,000	6.00	13.6			

Table for Rule 3.3

This page left blank

APPENDIX C

Field Data

(This page left blank)

PARTICULATE SAMPLING DATA SHEET

RUN NUMBER			SCHEMATIC OF STACK CROSS SECTION				EQUATIONS				AMBIENT TEMP			
TRAVERSE POINT NUMBER	SAMPLING TIME (min)	VAC STATIC PRESSURE (in H ₂ O)	STACK TEMP (°F)	STACK TEMP (T _s) (°R)	VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (in)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (°F)	IMPINGER OUTLET TEMP (°F)	STATION PRESS	OF	
			(°F)	(°R)		(in)	(cu ft)	IN (°F)	AVG (T _m) (°R)	OUT (°F)		HEATER BOX TEMP	in Hg	
												PROBE HEATER SETTING	OF	
												PROBE LENGTH	in	
												NOZZLE AREA (A)	sq ft	
												Cp		
												DRY GAS FRACTION (Fd)		
30 Aug 79							$H = \left[\frac{5130 \cdot F_d \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$				76			
Hosp Incinerator							Pre Pitot checks good				27.65			
Beale							Pre Leak good 15 in Hg				247			
ONE							Post Pitot good							
two							Post Leak at 15 in Hg good							
							$MAD = 29$							
							$RS = 0.65$							
1	0	2.0	1986		.02	1.30	745.75	71	69	225	68			
2	5	2.0	1356		.02	1.20		75	71	249	68			
3	10	2.0	1516		.03	1.65		86	72	224	68			
4	15	2.5	1731		.03	2.52		85	75	247	68			
5	20	2.5	1783		.03	2.56		87	76	245	68			
6	25	2.5	1685		.04	2.07		89	77	256	67			
9054														
7	0	2.0	1211		.02	1.32	766.93	82	80	247	68			
8	5	2.0	1248		.03	1.96		81	83	248	68			
9	10	10.0	1192		.035	2.57		93	83	256	68			
10	15	14.0	1361		.04	2.47		97	81	247	68			
11	20	11.0	1474		.04	2.33		95	84	247	68			
12	25	10.0	1560		.03	1.68		98	87	247	67			
							788.09							
			$TM = 83$								$101 = 42.15$			
			$TS = 14.57$											
			$ΔH = 198$											
			$ΔP_{ST} = 7.9409$											

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>Beil AF2</i>	DATE <i>30 April 1979</i>	RUN NUMBER
-------------------------	------------------------------	------------

BUILDING NUMBER <i>HOSPITAL</i>	SOURCE NUMBER <i>Room 1</i>
------------------------------------	--------------------------------

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.4167</i>	<i>0.2939</i>	<i>0.1228</i>
ACETONE WASHINGS (<i>Probe, Front Hall Filter</i>)	<i>93.8744</i>	<i>93.7504</i>	<i>0.1240</i>
BACK HALF (<i>if needed</i>)			
Total Weight of Particulates Collected			<i>0.2368 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (<i>H2O</i>)	<i>252.5</i>	<i>200</i>	<i>52.5</i>
IMPINGER 2 (<i>H2O</i>)	<i>225.0</i>	<i>200</i>	<i>25.0</i>
IMPINGER 3 (<i>Dry</i>)	<i>2.0</i>	<i>0</i>	<i>2.0</i>
IMPINGER 4 (<i>Silica Gel</i>)	<i>217.5</i>	<i>200</i>	<i>17.5</i>
Total Weight of Water Collected			<i>77.0 gm</i>


III. GASES (<i>Dry</i>)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>7.2</i>	<i>7.2</i>	<i>7.4</i>	—	<i>7.2</i>
VOL % O ₂	<i>9.8</i>	<i>10.0</i>	<i>10.0</i>	—	<i>10.0</i>
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

PARTICULATE SAMPLING DATA SHEET

1.91

SCHEMATIC OF STACK CROSS SECTION



EQUATIONS

$^{\circ}R = ^{\circ}F + 460$

$$H = \left[\frac{5130 \cdot F_d \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m}{T_s} \cdot V_p$$

Pie Pitot Coaxial
 Pie Leak at 15 in good
 Post leak at 23 in ok - good
 Post Pitot good

AMBIENT TEMP	82	OF
STATION PRESS	29.65	in Hg
HEATER BOX TEMP		OF
PROBE HEATER SETTING		OF
PROBE LENGTH	8	in
NOZZLE AREA (A)	.659	sq ft
Cp	.54	
DRY GAS FRACTION (F _d)		

TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H ₂ O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE DIFF. PRESS. (H)	GAS SAMPLE VOLUME (cu ft)	GAS METER TEMP			SAMPLE BOX TEMP (OF)	IMPINGER OUTLET TEMP (OF)
			(OF)	(TS) (OR)				IN (OF)	AVG (T _m) (OR)	OUT (OF)		

A	1	0	3	111	.02	1.59	798.105	88	85	85	276	67
A	2	5	3	152	.04	2.72		91	86	86	241	66
A	3	10	4	124	.03	2.22		92	86	86	247	69
A	4	15	6	146	.05	2.57		96	87	87	246	67
A	5	20	18	168	.07	3.09		97	87	87	246	68
A	6	30	stop	169	.06	3.07		97	88	88	247	68
B	1	0	12.0	122	.02	1.29	811.890	87	86	86	255	69
B	2	5	11.5	122	.035	2.27		91	87	87	258	66
B	3	10	19.0	128	.04	2.51		93	87	87	261	67
B	4	15	20.0	140	.04	2.36		92	87	87	239	68
B	5	20	20.0	155	.04	2.19		91	87	87	234	68
B	6	25	20.5	158	.04	2.14	832.713	91	87	87	233	68
			T _m = 89									
			T _s = 138.5									
							45.314					

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE <i>BEALE HFB</i>	DATE <i>30 AUG 1977</i>	RUN NUMBER
--------------------------	----------------------------	------------

BUILDING NUMBER <i>HOSPITAL</i>	SOURCE NUMBER <i>TWOO</i>
------------------------------------	------------------------------

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER	<i>0.5301</i>	<i>.2858</i>	<i>2.2471</i>
ACETONE WASHINGS (<i>Probe, Front Half Filter</i>)	<i>119.7367</i>	<i>119.5320</i>	<i>.2047</i>
BACK HALF (<i>If needed</i>)			<i>0</i>
Total Weight of Particulates Collected			<i>0.4493 gm</i>

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (<i>H2O</i>)	<i>227.0</i>	<i>200.0</i>	<i>27.0</i>
IMPINGER 2 (<i>H2O</i>)	<i>226.4</i>	<i>200.0</i>	<i>26.4</i>
IMPINGER 3 (<i>Dry</i>)	<i>7.6</i>	<i>0</i>	<i>7.6</i>
IMPINGER 4 (<i>Silica Gel</i>)	<i>221.0</i>	<i>200.0</i>	<i>21.0</i>
Total Weight of Water Collected			<i>84.0 gm</i>

III. GASES (<i>Dry</i>)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	<i>7.4</i>	<i>7.4</i>	<i>7.6</i>	<i>—</i>	<i>7.4</i>
VOL % O ₂	<i>9.8</i>	<i>9.8</i>	<i>9.8</i>	<i>—</i>	<i>9.8</i>
VOL % CO					
VOL % N ₂					

$$\text{Vol \% N}_2 = (100\% - \% \text{CO}_2 - \% \text{O}_2 - \% \text{CO})$$

PARTICULATE SAMPLING DATA SHEET

Date 1.21

SCHEMATIC OF STACK CROSS SECTION

EQUATIONS

AMBIENT TEMP

STATION PRESS 29.65
HEATER BOX TEMP
PROBE HEATER SETTING
PROBE LENGTH 8'
NOZZLE AREA (A) 1.654
Cp .84
DRY GAS FRACTION (F_d)

oF
in Hg
oF
in
sq ft

$OR = OF + 460$

$H = \left[\frac{5130 \cdot F_d \cdot C_p \cdot A}{C_o} \right]^2 \cdot \frac{T_m \cdot V_p}{T_s}$

Pre Pilot - good
Pre Leaking 18 in. by - good
D_p = 10
C_o = 7.3

MAP = 29
ΔP_s = 70.65

RUN NUMBER THREE
DATE 30 Aug 89
PLANT Hesp Inc. incinerator
BASE Beale
SAMPLE BOX NUMBER
METER BOX NUMBER 2
Qw/Qm
Co



TRAVERSE POINT NUMBER	SAMPLING TIME (min)	STATIC PRESSURE (in H2O)	STACK TEMP		VELOCITY HEAD (Vp)	ORIFICE PRESS. (H)	GAS VOLUME (cu ft)	GAS METER TEMP		SAMPLE BOX TEMP (oF)	IMPINGER OUTLET TEMP (oF)
			(oF)	(T _s) (oR)				IN (oF)	OUT (oF)		
A1	0	2	1098	.02	1.40	834.945	90	85	234	67	
A2	5	18	1245	.03	1.94		93	90	230	67	
A3	10	21	1332	.03	3.08		97	98	245	68	
A4	15	21	1472	.03	2.86		97	90	238	68	
A5	20	21	1466	.03	2.87		98	91	241	68	
A6	25	21	1594	.03	2.69		99	91	241	68	
	20.569				int int	855.369					
					int int	856.1305					
B1	0	2	1014	.02	1.50		95	92	240	68	
B2	5	3	1288	.03	1.90		97	91	238	68	
B3	10	3	1368	.03	2.13		102	94	238	68	
B4	15	14	1516	.04	2.26		103	93	241	68	
B5	20	11	1611	.04	2.29		109	92	240	68	
B6	25	13	1613	.05	2.69		109	93	240	68	
					ΔP = 2.30	43.635 ft ³					
					ΔP = 8.3796						

AIR POLLUTION PARTICULATE ANALYTICAL DATA

BASE BEALE AFB	DATE 30 AUG 1987	RUN NUMBER
--------------------------	----------------------------	------------

BUILDING NUMBER HOSPITAL	SOURCE NUMBER THREE
------------------------------------	-------------------------------

I. PARTICULATES			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT PARTICLES (gm)
FILTER NUMBER 3.2	0.5571	2.858	0.2463
3.1	0.5682	2.881	0.3301
ACETONE WASHINGS (Probe, Front Half Filter)	100.7777	100.001	0.6216
BACK HALF (if needed)			0
Total Weight of Particulates Collected			0.6750 gm

II. WATER			
ITEM	FINAL WEIGHT (gm)	INITIAL WEIGHT (gm)	WEIGHT WATER (gm)
IMPINGER 1 (H2O)	225.5	200.0	25.5
IMPINGER 2 (H2O)	220.5	200.0	20.5
IMPINGER 3 (Dry)	3.2	0	3.2
IMPINGER 4 (Silica Gel)	221.0	200.0	21.0
Total Weight of Water Collected			110.2 gm

III. GASES (Dry)					
ITEM	ANALYSIS 1	ANALYSIS 2	ANALYSIS 3	ANALYSIS 4	AVERAGE
VOL % CO ₂	8.6	8.4	8.4	—	8.4
VOL % O ₂	8.4	8.4	8.2	—	8.4
VOL % CO					
VOL % N ₂					

Vol % N₂ = (100% - % CO₂ - % O₂ - % CO)

PRELIMINARY SURVEY DATA SHEET NO. 1

(Stack Geometry)

BASE		PLANT	
DATE <i>29 Aug 89</i>		SAMPLING TEAM <i>OEHL</i>	
SOURCE TYPE AND MAKE <i>2 Chamber Type 4 Incinerator</i>			
SOURCE NUMBER <i>-</i>		INSIDE STACK DIAMETER <i>14"</i> Inches	
RELATED CAPACITY <i>100 lbs/hr</i>		TYPE FUEL <i>propane</i>	
DISTANCE FROM OUTSIDE OF NIPPLE TO INSIDE DIAMETER <i>0</i> Inches			
NUMBER OF TRAVERSES <i>2</i>		NUMBER OF POINTS/TRAVERSE <i>6</i>	

LOCATION OF SAMPLING POINTS ALONG TRAVERSE

POINT	PERCENT OF DIAMETER	DISTANCE FROM INSIDE WALL (Inches)	TOTAL DISTANCE FROM OUTSIDE OF NIPPLE TO SAMPLING POINT (Inches)
<i>1</i>			<i>0.6</i>
<i>2</i>			<i>2.1</i>
<i>3</i>			<i>4.1</i>
<i>4</i>			<i>9.9</i>
<i>5</i>			<i>11.9</i>
<i>6</i>			<i>13.4</i>

PRELIMINARY SURVEY DATA SHEET NO. 2
(Velocity and Temperature Traverse)

BASE	DATE
BOILER NUMBER	
INSIDE STACK DIAMETER	
STATION PRESSURE	Inches
29.65	In Hg
STACK STATIC PRESSURE	In H ₂ O
-0.15	1 1/2 H ₂ O
SAMPLING TEAM	

SO₂, SO₃

TRAVERSE POINT NUMBER	VELOCITY HEAD, v_p IN H ₂ O	$\sqrt{v_p} \propto$	STACK TEMPERATURE (°F)
1	.02	0	1800
2	.02	5	1800
3	.025	6	1884
4	.03	8	1884
5	.05	1	1883
6	.04	3	1886
		FPS = 20	
		F = 1857	
		716 @	
AVERAGE			

VISIBLE EMISSION OBSERVATION FORM

No. 3

COMPANY NAME
USAF

STREET ADDRESS
BEALE AFB

CITY
Ft. Huachuca

STATE
CA

ZIP

PHONE (KEY CONTACT)
Capt Chris Sherman

SOURCE ID NUMBER

PROCESS EQUIPMENT
Pathological Incinerator

OPERATING MODE
High Fuel

CONTROL EQUIPMENT
None

OPERATING MODE

DESCRIBE EMISSION POINT
Stack extending 10' from top of roof

HEIGHT ABOVE GROUND LEVEL
30'

HEIGHT RELATIVE TO OBSERVER
Start 30' End ✓

DISTANCE FROM OBSERVER
Start 100' End ✓

DIRECTION FROM OBSERVER
Start NNE End ✓

DESCRIBE EMISSIONS
Start Clear hazy End

EMISSION COLOR
Start Clear End ✓

IF WATER DROPLET PLUME
Attached N/A Detached

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED
Start 0-5' End ✓

DESCRIBE PLUME BACKGROUND
Start Sky End ✓

BACKGROUND COLOR
Start Blue End ✓


WIND SPEED
Start 0-5 mph End ✓

WIND DIRECTION
Start SE End ✓

AMBIENT TEMP
Start 85 End

WET BULB TEMP
30

RH, percent



OBSERVATION DATE		START TIME				END TIME
30 Aug 87		1321				1333
SEC	0	15	30	45	COMMENTS	
MIN						
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0	ADDED FUEL	
5	0	0	0	60		
6	55	55	50	50		
7	50	40	40	30		
8	20	25	25	20		
9	15	10	5	5		
10	0	0	0	0		
11	0	0	0	0		
12	0	0	0	0		
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

OBSERVER'S NAME (PRINT)
CHARLES W ATTIEBERT

OBSERVER'S SIGNATURE
Charles W. Attiebert

DATE
30 Aug 87

ORGANIZATION
AFCL/HL/ERE

CERTIFIED BY
Texas Air Control Board

DATE
17 Nov 87

ADDITIONAL INFORMATION

VISIBLE EMISSION OBSERVATION FORM

No. 2

COMPANY NAME
BEALE AFB CLINIC

STREET ADDRESS
BEALE AFB

CITY STATE ZIP
Yuba City CA

PHONE (KEY CONTACT) SOURCE ID NUMBER
Capt. Chris Sherman

PROCESS EQUIPMENT OPERATING MODE
Pathological Incubator High Fire

CONTROL EQUIPMENT OPERATING MODE
None

OBSERVATION DATE		START TIME				END TIME
30 Aug 89		1130				1138
SEC	0	15	30	45	COMMENTS	
MIN						
1	0	5	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	5	5	5		
5	0	0	5	0		
6	0	0	0	0		
7	0	5	0	0		
8	0	0	0	0		
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

DESCRIBE EMISSION POINT
Stack extending 10' from TOP of building

HEIGHT ABOVE GROUND LEVEL HEIGHT RELATIVE TO OBSERVER
30' Start **6'** End

DISTANCE FROM OBSERVER DIRECTION FROM OBSERVER
Start **20'** End Start **W** End

DESCRIBE EMISSIONS
Start **Clear lifting** End

EMISSION COLOR IF WATER DROPLET PLUME
Start **Clear** End Attached **NA** Detached


POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED
Start **0-5'** End

DESCRIBE PLUME BACKGROUND
Start **sky** End

BACKGROUND COLOR SKY CONDITIONS
Start **blue** End Start **clear** End

WIND SPEED WIND DIRECTION
Start **0-5 mph** End Start **S** End

AMBIENT TEMP WET BULB TEMP RH, percent
Start **80** End **30**



ADDITIONAL INFORMATION

OBSERVER'S NAME (PRINT)
CHARLES W ATTEBORY

OBSERVER'S SIGNATURE
Charles W. Attebery DATE
30 Aug 89

ORGANIZATION
AFCOHL/CGE

CERTIFIED BY
Texas Air Control Board DATE
12/1/89

VISIBLE EMISSION OBSERVATION FORM

No. 1

COMPANY NAME
Bottle AFB CLINIC

STREET ADDRESS
BOTTLE AFB

CITY
Yuba City

STATE
CA

ZIP

PHONE (KEY CONTACT)
CHPT CHRIS SHERMAN

SOURCE ID NUMBER

OBSERVATION DATE		START TIME		END TIME	COMMENTS
30 Aug 89		0430		0938	
SEC	0	15	30	45	
MIN					
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	5	0	
5	0	0	0	0	
6	0	5	0	0	
7	0	5	5	5	
8	0	0	0	0	
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

PROCESS EQUIPMENT
PATHOLOGICAL INCINERATOR

OPERATING MODE
HIGH FIRE

CONTROL EQUIPMENT
NONE

OPERATING MODE

DESCRIBE EMISSION POINT
STACK EXTENDING 10' FROM TOP OF BUILDING

HEIGHT ABOVE GROUND LEVEL
30'

HEIGHT RELATIVE TO OBSERVER
 Start **6'** End **6'**

DISTANCE FROM OBSERVER
 Start **20'** End **20'**

DIRECTION FROM OBSERVER
 Start **W** End **✓**

DESCRIBE EMISSIONS
 Start **CLEAR / HEAT** End **✓**

EMISSION COLOR
 Start **CLEAR** End **✓**

IF WATER DROPLET PLUME
 Attached N/A Detached

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED
 Start **0-5'** End **✓**

DESCRIBE PLUME BACKGROUND
 Start **sky** End **✓**

BACKGROUND COLOR
 Start **BLUE** End **✓**

SKY CONDITIONS
 Start **CLEAR** End **✓**


WIND SPEED
 Start **0-5 mph** End **✓**

WIND DIRECTION
 Start **SOUTH** End **✓**

AMBIENT TEMP
 Start **75** End **✓**

WET BULB TEMP
30

RH, percent



OBSERVER'S NAME (PRINT)
CHARLES W. ATRIGERY

OBSERVER'S SIGNATURE

DATE
30 AUG 89

ORGANIZATION
USAF OCCUPATIONAL & ENVIRONMENTAL HEALTH

CERTIFIED BY
TEXAS AIR CONTROL BOARD

DATE
17 MAR 89

(This page left blank)

APPENDIX D
Calibration Data

(This page left blank)

METER BOX CALIBRATION DATA AND CALCULATION FORM

(English units)

Date 21 Nov 88

Meter box number Natch #2

Barometric pressure, $P_b = 30.02$ in. Hg Calibrated by Scott & Vaughn

VAC

4.0
4.0
4.0
4.0
4.0
4.0

Orifice manometer setting (ΔH), in. H ₂ O	Gas volume		Temperature				Time (θ), min	Y_i	ΔH_i in. H ₂ O	
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Dry gas meter						
				Inlet (t_{d_i}), °F	Outlet (t_{d_o}), °F	Avg ^a (t_d), °F				
0.5	5	5.057	75 75	535	77 82	75 77	537.75	12.40	0.9926	1.73
1.0	5	5.031	76 76	536	81 89	77 80	542.5	9.14	1.0034	1.87
1.5	10	10.101	77 77	537	90 96	81 84	547.75	15.35	1.0061	1.97
2.0	10	10.230	78 78	538	97 99	85 87	552.0	13.45	0.9981	2.00
3.0	10	10.170	78 78	538	100 103	87 89	554.75	10.92	1.0065	1.97
4.0	10	10.191	78 78	538	105 105	89 91	557.0	9.35	1.0061	1.92
								Avg	1.002	1.91

ΔH , in. H ₂ O	$\frac{\Delta H}{13.6}$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H_i = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	$\frac{(5)(30.02)(537.75)}{5.057(30.02 + \frac{0.5}{13.6})(535)}$	$\frac{(0.0317)(0.5)}{(30.02)(537.75)} \left[\frac{(535)(12.4)}{5} \right]^2$
1.0	0.0737	$\frac{(5)(30.02)(542.5)}{5.031(30.02 + \frac{1.0}{13.6})(536)}$	$\frac{(0.0317)(1.0)}{(30.02)(542.5)} \left[\frac{(536)(9.14)}{5} \right]^2$
1.5	0.110	$\frac{(10)(30.02)(547.75)}{10.101(30.02 + \frac{1.5}{13.6})(537)}$	$\frac{(0.0317)(1.5)}{(30.02)(547.75)} \left[\frac{(537)(15.35)}{10} \right]^2$
2.0	0.147	$\frac{(10)(30.02)(552)}{10.230(30.02 + \frac{2.0}{13.6})(538)}$	$\frac{(0.0317)(2.0)}{(30.02)(552)} \left[\frac{(538)(13.45)}{10} \right]^2$
3.0	0.221	$\frac{(10)(30.02)(554.75)}{10.170(30.02 + \frac{3.0}{13.6})(538)}$	$\frac{(0.0317)(3.0)}{(30.02)(554.75)} \left[\frac{(538)(10.92)}{10} \right]^2$
4.0	0.294	$\frac{(10)(30.02)(557)}{10.191(30.02 + \frac{4.0}{13.6})(538)}$	$\frac{(0.0317)(4.0)}{(30.02)(557)} \left[\frac{(538)(9.35)}{10} \right]^2$

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d .

Ve Beule AFB

POSTTEST DRY GAS METER CALIBRATION DATA FORM (English units)

Test number One Date 23 Jun 89 Meter box number Nutech 2 Post Plant Clear Eielson

Barometric pressure, $P_b = 29.123$ in. Hg Dry gas meter number _____ Pretest Y 1.007

Orifice manometer setting, (ΔH) , in. H ₂ O	Gas volume		Temperature			Time (Θ) , min	Vacuum setting, in. Hg	Y_i	$V_w P_b (t_d + 460)$ $V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)$
	Wet test meter (V_w) , ft ³	Dry gas meter (V_d) , ft ³	Wet test meter (t_w) , °F	Inlet (t_{d_i}) , °F	Outlet (t_{d_o}) , °F				
<u>1.4</u>	<u>10</u>	<u>10.212</u>	<u>80</u> <u>80</u> <u>540</u>	<u>87</u> <u>93</u> <u>550</u>	<u>85</u> <u>85</u> <u>545</u>	<u>547.5</u>	<u>4.0</u>	<u>0.981</u>	<u>10.212 (29.123) (540 + 460)</u> <u>10.212 (29.123 + 13.6) (540 + 460)</u>
<u>1.4</u>	<u>10</u>	<u>10.223</u>	<u>81</u> <u>81</u> <u>541</u>	<u>93</u> <u>93</u> <u>554</u>	<u>87</u> <u>87</u> <u>546</u>	<u>550</u>	<u>4.0</u>	<u>0.981</u>	<u>10.223 (29.123) (541 + 460)</u> <u>10.223 (29.123 + 13.6) (541 + 460)</u>
<u>1.4</u>	<u>10</u>	<u>10.247</u>	<u>81</u> <u>81</u> <u>541</u>	<u>96</u> <u>96</u> <u>555</u>	<u>87</u> <u>88</u> <u>547.5</u>	<u>551.5</u>	<u>4.0</u>	<u>0.981</u>	<u>10.247 (29.123) (541 + 460)</u> <u>10.247 (29.123 + 13.6) (541 + 460)</u>

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d

where

V_w = Gas volume passing through the wet test meter, ft³.

V_d = Gas volume passing through the dry gas meter, ft³.

t_w = Temperature of the gas in the wet test meter, °F.

t_{d_i} = Temperature of the inlet gas of the dry gas meter, °F.

t_{d_o} = Temperature of the outlet gas of the dry gas meter, °F.

t_d = Average temperature of the gas in the dry gas meter, obtained by the average of t_{d_i} and t_{d_o} , °F.

ΔH = Pressure differential across orifice, in. H₂O.

Y_i = Ratio of accuracy of wet test meter to dry gas meter for each run.

Y = Average ratio of accuracy of wet test meter to dry gas meter for all three runs; tolerance = pretest Y \pm 0.05Y.

P_b = Barometric pressure, in. Hg.

Θ = Time of calibration run, min.

METER BOX CALIBRATION DATA AND CALCULATION FORM

(English units)

Post Beale AFB

Date 28 Sept 89

Meter box number Nutech 2

Barometric pressure, $P_b =$ 29.82 in. Hg Calibrated by Scott & Vaughan

IAC

Orifice manometer setting (ΔH), in. H ₂ O	Gas volume		Temperature			Time (θ), min	y_i	ΔH_{e_i} , in. H ₂ O	
	Wet test meter (V_w), ft ³	Dry gas meter (V_d), ft ³	Wet test meter (t_w), °F	Dry gas meter					
				Inlet (t_{d_i}), °F	Outlet (t_{d_o}), °F				Avg ^a (t_d), °F
0.5	5	5.060	78 78 538	77 84 541.5	77 79 538	539.8	12.9	0.990	1.897
1.0	5	5.060	79 79 539	87 81 549	80 81 540.5	544.8	9.7	0.996	1.837 1.870
1.5	10	10.150	80 79 539.5	86 88 557	86 87 546.5	551.8	15.2	1.004	1.943
2.0	10	10.195	79 78 539	85 80 559	87 89 549	553.5	13.2	1.002	1.944
3.0	10	10.155	79 87 539.5	81 81 552.5	80 89 550.5	556.5	10.7	1.008	1.910
4.0	10	10.025 10.139	80 77 538.5	80 89 544.5	74 77 535.5	540	10.0	0.991	2.283
							Avg	0.999	1.969

ΔH , in. H ₂ O	$\frac{\Delta H}{13.6}$	$y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	$\Delta H_{e_i} = \frac{0.0317 \Delta H}{P_b (t_d + 460)} \left[\frac{(t_w + 460) \theta}{V_w} \right]^2$
0.5	0.0368	$y_1 = \frac{(5)(29.82)(539.8)}{(5.06)(29.82 + 0.2/13.6)(538)}$	$H_{e1} = \frac{(0.0317)(0.5)}{(29.82)(539.8)} \left[\frac{(538)(12.9)}{5} \right]^2$
1.0	0.0737	$y_2 = \frac{(5)(29.82)(544.8)}{(5.06)(29.82 + 1.0/13.6)(539)}$	$H_{e2} = \frac{(0.0317)(1)}{(29.82)(544.8)} \left[\frac{(539.8)(9.7)}{5} \right]^2$
1.5	0.110	$y_3 = \frac{(10)(29.82)(551.8)}{(10.15)(29.82 + 1.5/13.6)(539.5)}$	$H_{e3} = \frac{(0.0317)(1.5)}{(29.82)(551.8)} \left[\frac{(539.5)(15.2)}{10} \right]^2$
2.0	0.147	$y_4 = \frac{(10)(29.82)(553.5)}{(10.195)(29.82 + 2.0/13.6)(539)}$	$H_{e4} = \frac{(0.0317)(2.0)}{(29.82)(553.5)} \left[\frac{(539)(13.2)}{10} \right]^2$
3.0	0.221	$y_5 = \frac{(10)(29.82)(556.5)}{(10.155)(29.82 + 3/13.6)(539.5)}$	$H_{e5} = \frac{(0.0317)(3.0)}{(29.82)(556.5)} \left[\frac{(539.5)(10.7)}{10} \right]^2$
4.0	0.294	$y_6 = \frac{(10)(29.82)(540)}{(10.025)(29.82 + 4/13.6)(538.5)}$	$H_{e6} = \frac{(0.0317)(4.0)}{(29.82)(540)} \left[\frac{(538.5)(10.0)}{10} \right]^2$

^a If there is only one thermometer on the dry gas meter, record the temperature under t_d .

$y_{range} = 1.0521 \longleftrightarrow 0.9519$

Quality Assurance Handbook M4-2.3A (front side)

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 19²⁰/OCT 88 Thermocouple number DI IMPINGER
 Ambient temperature 26 °C Barometric pressure 29.232/29.175 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, % °C ^c *
0	ICE BATH	0	0	—
—	ROOM TEMP	25.5	26.1	0.6

^a Every 30°C (50°F) for each reference point.

^b Type of calibration system used.

^c $\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$

* MUST BE WITHIN 1°C OF REF

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

Date 19²⁰ OCT 88 Thermocouple number IMPINGER D2
 Ambient temperature 26° °C Barometric pressure 29.232/29.175 in. Hg
 Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C % °C*
0	ICE BATH	0	0	—
—	ROOM TEMP	26.0	26.6	0.6

^aEvery 30°C (50°F) for each reference point.

^bType of calibration system used.

^c
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 < 1.5\%$$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

IMPINGER

Date 19/30 OCT 88 Thermocouple number D3

Ambient temperature 26 °C Barometric pressure 29.2321 in. Hg
29.175

Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
 other _____

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C ^c % °C*
C	ICE BATH	0	0.6	0.6
-	ROOM TEMP	25.8	25.6	0.2

^a Every 30°C (50°F) for each reference point.

^b Type of calibration system used.

^c $\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$

* MUST BE WITHIN 1°C OF REF

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

IMPINGER

Date 19/10/88 Thermocouple number D4

Ambient temperature 26 °C Barometric pressure 29.732 in. Hg

Calibrator GARRISON/SCOTT Reference: mercury-in-glass NBS
other

Reference point number ^a	Source ^b (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C % °C*
0	ICE BATH	0	0.6	0.6
-	ROOM TEMP	25.5	25.6	0.1

^a Every 30°C (50°F) for each reference point.

^b Type of calibration system used.

^c $\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 < 1.5\%$

* MUST BE WITHIN 1°C OF REF

Quality Assurance Handbook M2-2.10

STACK SENSOR CALIBRATION: 19-20 Oct 88

SENSOR #	REFERENCE TEMPERATURE (deg K) X axis	TEST TEMPERATURE (deg K) Y axis	
P1	273.30	273.60	Regression Output:
	371.90	373.60	Constant -4.30
	447.00	450.20	Std Err of Y Est 0.20
			R Squared 1.00
			No. of Observations 3.00
			Degrees of Freedom 1.00
			X Coefficient(s) 1.02
			Std Err of Coef. 0.00
			% Deviation @ 2000 F(1093.3 K) = 1.29%
P2	273.30	273.60	Regression Output:
	371.80	373.60	Constant -4.27
	447.60	450.80	Std Err of Y Est 0.11
			R Squared 1.00
			No. of Observations 3.00
			Degrees of Freedom 1.00
			X Coefficient(s) 1.02
			Std Err of Coef. 0.00
			% Deviation @ 2000 F(1093.3 K) = 1.25%
P3	273.30	274.10	Regression Output:
	371.90	374.10	Constant -2.96
	447.60	450.80	Std Err of Y Est 0.03
			R Squared 1.00
			No. of Observations 3.00
			Degrees of Freedom 1.00
			X Coefficient(s) 1.01
			Std Err of Coef. 0.00
			% Deviation @ 2000 F(1093.3 K) = 1.11%
P4	273.30	273.60	Regression Output:
	371.80	373.60	Constant -4.27
	447.60	450.80	Std Err of Y Est 0.11
			R Squared 1.00
			No. of Observations 3.00
			Degrees of Freedom 1.00
			X Coefficient(s) 1.02
			Std Err of Coef. 0.00
			% Deviation @ 2000 F(1093.3 K) = 1.27%

P5	273.30	274.10	Regression Output:	
	371.90	373.60	Constant	-3.03
	447.60	450.80	Std Err of Y Est	0.37
			R Squared	1.00
			No. of Observations	3.00
			Degrees of Freedom	1.00
			X Coefficient(s)	1.01
			Std Err of Coef.	0.00
			% Deviation @ 2000 F(1093.3 K) = 1.08%	

P6	273.30	273.30	Regression Output:	
	371.90	373.60	Constant	-5.03
	447.60	450.80	Std Err of Y Est	0.09
			R Squared	1.00
			No. of Observations	3.00
			Degrees of Freedom	1.00
			X Coefficient(s)	1.02
			Std Err of Coef.	0.00
			% Deviation @ 2000 F(1093.3 K) = 1.37%	

P7	273.30	273.30	Regression Output:	
	371.90	373.60	Constant	-5.03
	447.60	450.80	Std Err of Y Est	0.09
			R Squared	1.00
			No. of Observations	3.00
			Degrees of Freedom	1.00
			X Coefficient(s)	1.02
			Std Err of Coef.	0.00
			% Deviation @ 2000 F(1093.3 K) = 1.37%	

P8	273.60	273.60	Regression Output:	
	371.80	373.00	Constant	-4.75
	449.40	452.40	Std Err of Y Est	0.39
			R Squared	1.00
			No. of Observations	3.00
			Degrees of Freedom	1.00
			X Coefficient(s)	1.02
			Std Err of Coef.	0.00
			% Deviation @ 2000 F(1093.3 K) = 1.25%	

TYPE S PITOT TUBE INSPECTION DATA FORM

#8A

Pitot tube assembly level? yes no

Pitot tube openings damaged? yes (explain below) no

$\alpha_1 = 1^\circ (<10^\circ)$, $\alpha_2 = 2^\circ (<10^\circ)$, $\beta_1 = \phi^\circ (<5^\circ)$,

$\beta_2 = 2^\circ (<5^\circ)$

$\gamma = 1^\circ$, $\theta = 1^\circ$, $A = \frac{15}{16} \text{ cm (in.)}$ (0.938)

$z = A \sin \gamma = 0.0164 \text{ cm (in.)}$; 0.1250
 $< 0.32 \text{ cm (<1/8 in.)}$,

$w = A \sin \theta = 0.0164 \text{ cm (in.)}$; 0.0313
 $< .08 \text{ cm (<1/32 in.)}$

$P_A = \frac{15}{32} (0.469) \text{ cm (in.)}$ $P_D = \frac{15}{32} (0.469) \text{ cm (in.)}$

$D_t = \frac{3}{8} (.375) \text{ cm (in.)}$

Comments: CONSTRUCTED IAW 40CFR 60, APP A, METH 2,
FIG 2.2 ASSIGNED BASELINE COEFFICIENT = 0.84

Calibration required? yes no

NOZZLE CALIBRATION DATA FORM

Date 30 Aug 89 Calibrated by Sut

Nozzle identification number	Nozzle Diameter ^a			ΔD , ^b mm (in.)	D_{avg} ^c
	D_1 , mm (in.)	D_2 , mm (in.)	D_3 , mm (in.)		
7	.653	.654	.654	.001	.654

where:

^a $D_{1,2,3}$ = three different nozzle diameters, mm (in.); each diameter must be within (0.025 mm) 0.001 in.

^b ΔD = maximum difference between any two diameters, mm (in.), $\Delta D \leq (0.10 \text{ mm}) 0.004 \text{ in.}$

^c D_{avg} = average of D_1 , D_2 , and D_3 .

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

NOTECH #2

Date 3 JAN 89 Thermocouple number INLET/OUTLET

Ambient temperature 26 °C Barometric pressure _____ in. Hg

Calibrator GARRISON Reference: mercury-in-glass ASTM 63F
SCOTT other _____

Reference point number	Source ^a (specify)	Reference thermometer temperature, °C	Thermocouple potentiometer temperature, °C	Temperature difference, °C ^b *
INLET				
-	HOT WATER BATH	43.5	43	.5
-	ROOM TEMP	26	26	0
OUTLET				
-	HOT WATER BATH	43.5	42	1
-	ROOM TEMP	26	26.5	.5

^aType of calibration system used.

^b
$$\left[\frac{(\text{ref temp, } ^\circ\text{C} + 273) - (\text{test thermom temp, } ^\circ\text{C} + 273)}{\text{ref temp, } ^\circ\text{C} + 273} \right] 100 \leq 1.5\%$$

Quality Assurance Handbook M5-2.5

* MUST BE WITHIN 3°C OF REFERENCE

APPENDIX E

Acetone Blank Results and
Particulate Emissions Results

(This page left blank)

BLANK ANALYTICAL DATA FORM

Plant Beale AFB
 Sample location Blank
 Relative humidity —
 Liquid level marked and container sealed —
 Density of acetone (ρ_a) 0.78 g/ml
 Blank volume (V_a) 100 ml
 Date and time of wt 15 Sept 0900 hr Gross wt 104.8797 mg
 Date and time of wt 21 Sept 1445 hr Gross wt 104.8809 mg
 Average gross wt 104.8809 mg
 Tare wt 104.8797 mg
 Weight of blank (m_{ab}) .0012 mg

$$C_a = \frac{m_{ab}}{V_a \rho_a} = \frac{(.0012)}{(100)(0.78)} = 0.0000154 \text{ mg/g}$$

Note: In no case should a blank residue greater than 0.01 mg/g (or 0.001% of the blank weight) be subtracted from the sample weight.

Filters Filter number _____
 Date and time of wt _____ Gross wt _____ mg
 Date and time of wt _____ Gross wt _____ mg
 Average gross wt _____ mg
 Tare wt _____ mg
 Difference wt _____ mg

Note: Average difference must be less than ± 5 mg or 2% of total sample weight whichever is greater.

Remarks _____

Signature of analyst Ronald W. Vaughn
 Signature of reviewer _____

XROM *METH F
 RUN NUMBER
 ONE
 METER BOX ?
 1.0000
 DELTA H ?
 1.9100
 BAR PRESS ?
 29.6500
 METER VOL ?
 42.1150
 MTR TEMP F ?
 83.0000
 STATIC HOH IN ?
 -1.0650
 STACK TEMP.
 1,427.0000
 ML. WATER ?
 97.0000

IMP. % HOH = 10.1

% HOH=10.1

% CO2 ?
 7.2000
 % OXYGEN ?
 10.0000
 % CO ?
 0.0000

MWd =29.55
 MW WET=29.39

SORT PSTS ?
 7.9404
 TIME MIN ?
 60.0000
 NOZZLE DIA ?
 .6540
 STK DIA INCH ?
 14.0000

* VOL MTR STD = 40.856
 STK PRES ABS = 29.65
 VOL HOH GAS = 4.57
 % MOISTURE = 10.05
 MOL DRY GAS = 0.899
 % NITROGEN = 80.00
 MOL WT DRY = 29.55
 MOL WT WET = 29.39
 VELOCITY FPS = 19.65
 STACK AREA = 1.07
 STACK ACFM = 1,261.
 * STACK DSCFM = 313.
 % ISOkinetic = 99.34

XROM *METH F
 RUN NUMBER
 TWO
 METER BOX ?
 1.0000
 DELTA H ?
 2.4700
 BAR PRESS ?
 29.6500
 METER VOL ?
 45.3100
 MTR TEMP F ?
 89.0000
 STATIC HOH IN ?
 -1.0650
 STACK TEMP.
 1,385.0000
 ML. WATER ?
 84.0000

IMP. % HOH = 8.3

% HOH=8.3

% CO2 ?
 7.4000
 % OXYGEN ?
 9.8000
 % CO ?
 0.0000

MWd =29.58
 MW WET=29.61

SORT PSTS ?
 8.7310
 TIME MIN ?
 60.0000
 NOZZLE DIA ?
 .6540
 STK DIA INCH ?
 14.0000

* VOL MTR STD = 43.535
 STK PRES ABS = 29.65
 VOL HOH GAS = 3.95
 % MOISTURE = 8.37
 MOL DRY GAS = 0.917
 % NITROGEN = 80.00
 MOL WT DRY = 29.58
 MOL WT WET = 29.61
 VELOCITY FPS = 21.52
 STACK AREA = 1.07
 STACK ACFM = 1,301.
 * STACK DSCFM = 359.
 % ISOkinetic = 90.69

XROM *METH F

RUN NUMBER
 ONE
 VOL MTR STD ?
 40.8560
 STACK DSCFM ?
 313.0000
 FRONT 1/2 MG ?
 236.0000
 BACK 1/2 MG ?
 0.0000

F GR/DSCF = 0.0094
 F MG/MMH = 204.6798
 F LB/HR = 0.2400
 F KG/HR = 0.1088

XROM *METH F

RUN NUMBER
 TWO
 VOL MTR STD ?
 43.5350
 STACK DSCFM ?
 359.0000
 FRONT 1/2 MG ?
 449.0000
 BACK 1/2 MG ?
 0.0000

F GR/DSCF = 0.1594
 F MG/MMH = 364.8613
 F LB/HR = 0.4900
 F KG/HR = 0.2225

XROM "METH 5"

RUN NUMBER

THREE RUN
 METER BOX Y? 1.0020 RUN
 DELTA H? 2.3000 RUN
 BAR PRESS ? 29.6500 RUN
 METER VOL ? 43.6350 RUN
 MTR TEMP F? 95.0000 RUN
 STATIC HOH IN ? -0.0650 RUN
 STACK TEMP. 1.375.0000 RUN
 ML. WATER ? 110.2000 RUN

IMP. % HOH = 11.1

% HOH=11.1

% CO2? 8.4000 RUN
 % OXYGEN? 8.4000 RUN
 % CO ? 0.0000 RUN

MWd =29.68
 MW WET=28.38

SORT PSTS ? 8.3796 RUN
 TIME MIN ? 60.0000 RUN
 NOZZLE DIA ? .6540 RUN
 STK DIA INCH ? 14.0000 RUN

* VOL MTR STD = 41.455
 STK PRES ABS = 29.65
 VOL HOH GAS = 5.19
 % MOISTURE = 11.12
 MOL DRY GAS = 0.829
 % NITROGEN = 83.20
 MOL WT DRY = 29.68
 MOL WT WET = 28.38
 VELOCITY FPS = 20.75
 STACK AREA = 1.07
 STACK ACFM = 1.331
 * STACK DSCFM = 337.
 % ISOKINETIC = 93.96

XROM "MASSFLO"

RUN NUMBER THREE RUN
 VOL MTR STD ? 41.4550 RUN
 STACK DSCFM ? 337.0000 RUN
 FRONT 1/2 MG ? 695.0000 RUN
 BACK 1/2 MG ? 0.0000 RUN

F GR/DSCF = 0.2587
 F MG/MMM = 592.0451
 F LB/HR = 0.7473
 F KG/HR = 0.3390

(This page left blank)

APPENDIX F

Hydrogen Chloride Emissions Calculations

(This page left blank)

XROM "MASSFLO"

XROM "MASSFLO"

RUN NUMBER	
ONE HCL	RUN
VOL MTR STD ?	
40.8560	RUN
STACK DSCFM ?	
313.0000	RUN
FRONT 1/2 MG ?	
34.9200	RUN
BACK 1/2 MG ?	
0.0000	RUN

F GR/DSCF = 0.0132
 F MG/MMH = 30.1832
 F LB/HR = 0.0354
 F KG/HR = 0.0161

RUN NUMBER	
TWO HCL	RUN
VOL MTR STD ?	
43.5350	RUN
STACK DSCFM ?	
359.0000	RUN
FRONT 1/2 MG ?	
13.7750	RUN
BACK 1/2 MG ?	
0.0000	RUN

F GR/DSCF = 0.0049
 F MG/MMH = 11.1738
 F LB/HR = 0.0150
 F KG/HR = 0.0068

XROM "MASSFLO"

RUN NUMBER	
THREE HCL	RUN
VOL MTR STD ?	
41.4550	RUN
STACK DSCFM ?	
337.0000	RUN
FRONT 1/2 MG ?	
45.3600	RUN
BACK 1/2 MG ?	
0.0000	RUN

F GR/DSCF = 0.0169
 F MG/MMH = 38.6485
 F LB/HR = 0.0488
 F KG/HR = 0.0221

(This page left blank)

Distribution List

	Copies
HQ SAC/SGPB Offutt AFB NE 68113-500	1
HQ USAF/SCPA Bolling AFB DC 20332-6188	1
HQ AFSC/SGP Andrews AFB DC 20334-5000	1
7100 CSW Med Cen/SGB APO New York 09220-5300	1
OL AD, AFOEHL APO San Francisco 96274-5000	1
USAFSAM/TSK Brooks AFB TX 78235-5301	1
USAFSAM/ED/EDH/EDZ Brooks AFB TX 78235-5301	1 ea
Defense Technical Information Center (DTIC) Cameron Station Alexandria VA 22304-6145	2
HSD/XA Brooks AFB TX 78235-5000	1
HQ USAF/LEEV Bolling AFB DC 20330-5000	1
HQ AFESC/RDV Tyndall AFB FL 32403-6001	1
9 Strat Hosp/SGPB Beale AFB CA 95903-5300	5