ARMY RESEARCH LABORATORY

Water-Based Halon Replacement Sprays

Anthony E. Finnerty Robert L. McGill U.S. ARMY RESEARCH LABORATORY

Wayne A. Slack DYNAMIC SCIENCE INCORPORATED

ARL-TR-1138

July 1996

19960718 087

DIIC QUALITY INSPECTED 3

APPROVED FOR PUBLIC RELEASE; DISTRIBUTION IS UNLIMITED.

DISCLAIMER NOTICE



THIS DOCUMENT IS BEST QUALITY AVAILABLE. THE COPY FURNISHED TO DTIC CONTAINED A SIGNIFICANT NUMBER OF PAGES WHICH DO NOT REPRODUCE LEGIBLY.

NOTICES


Destroy this report when it is no longer needed. DO NOT return it to the originator.

Additional copies of this report may be obtained from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161.

The findings of this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

The use of trade names or manufacturers' names in this report does not constitute indorsement of any commercial product.

DISCLAIMER NOTICE



THIS DOCUMENT IS BEST QUALITY AVAILABLE. THE COPY FURNISHED TO DTIC CONTAINED A SIGNIFICANT NUMBER OF COLOR PAGES WHICH DO NOT REPRODUCE LEGIBLY ON BLACK AND WHITE MICROFICHE.

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188
Public reporting burden for this collection of gathering and maintaining the data needed, a collection of information, including suggestio Davis Highway. Suite 1204 Artification v4 222	Information is estimated to average 1 hour ind completing and reviewing the collection ins for reducing this burden, to Washington 024302 and to the Office of Management	per response, including the time for revi of information. Send comments regard Headquarters Services, Directorate for in	ewing instructions, searching existing data source ng this burden estimate or any other aspect of th iformation Operations and Reports, 1215 Jefferso t (0704-0188), Washington, DC 20503.
1. AGENCY USE ONLY (Leave bla	(14302) and to the once of management (1302) and to the once of management (1302) and (1	3. REPORT TYPE AND Final, Jan-Sep 199	DATES COVERED
4. TITLE AND SUBTITLE		1	. FUNDING NUMBERS
Water-Based Halon Replacer	nent Sprays		4G592-462-T5-W2YY
6. AUTHOR(S)			
Anthony E. Finnerty, Robert	L. McGill, and Wayne A. Sla	ack*	
PERFORMING ORGANIZATION N	IAME(S) AND ADDRESS(ES)	8	PERFORMING ORGANIZATION REPORT NUMBER
U.S. Army Research Laborate ATTN: AMSRL-WT-TB Aberdeen Proving Ground, M	-		ARL-TR-1138
). SPONSORING/MONITORING AG	ENCY NAME(S) AND ADDRESS(ES) 1	0. SPONSORING/MONITORING AGENCY REPORT NUMBER
1. SUPPLEMENTARY NOTES			
*Mr. Slack is an employee of	Dynamic Science Incorporate	ed (DSI).	
2a. DISTRIBUTION / AVAILABILITY	STATEMENT		26. DISTRIBUTION CODE
Approved for public release; of	distribution is unlimited.		
3. ABSTRACT (Maximum 200 word	ls)		
Water delivered as a sprav	is more effective against hydr	markon first than a stream	
combat vehicle is freezing at lo may be usable under all expect with additives to extinguish JI improve the fire-extinguishing for extinguishing JP-8 pool fi	system influences the effection ow temperatures. Additives can ed operating conditions. Exper- P-8 pool fires. Additives wer capability of the water. As fires. Water with calcium ch	veness of water. The major in be added to lower the free priments have been conducted the chosen to provide low free expected, sprays of just wat alloride, added to give a -5	of water. Water as a mist is even or problem with using water in a zing point. Thus, water solutions d using sprays of water and water eezing points to the water and to er were not particularly effective 5° C freezing point, showed no showed remarkable improvements
combat vehicle is freezing at lo may be usable under all expect with additives to extinguish JJ improve the fire-extinguishing for extinguishing JP-8 pool fi improvement in fire suppression	system influences the effection ow temperatures. Additives can ed operating conditions. Exper- P-8 pool fires. Additives wer capability of the water. As a ires. Water with calcium ch n over the baseline water tests.	veness of water. The majo in be added to lower the free eriments have been conducte e chosen to provide low free expected, sprays of just wat iloride, added to give a -5 Other additives, however, s	or problem with using water in a zing point. Thus, water solutions d using sprays of water and water eczing points to the water and to er were not particularly effective 5° C freezing point should be
Combat vehicle is freezing at lo may be usable under all expect with additives to extinguish JJ improve the fire-extinguishing for extinguishing JP-8 pool fi improvement in fire suppression over the water case.	system influences the effection ow temperatures. Additives can ed operating conditions. Exper- P-8 pool fires. Additives wer capability of the water. As a ires. Water with calcium ch n over the baseline water tests.	veness of water. The majo in be added to lower the free eriments have been conducte e chosen to provide low free expected, sprays of just wat iloride, added to give a -5 Other additives, however, s	ar problem with using water in a szing point. Thus, water solutions d using sprays of water and water ending sprays of water and to er were not particularly effective 5° C freezing point, showed no showed remarkable improvements 15. NUMBER OF PAGES 28 16. PRICE CODE

Prescribed b		C + 4 7	20 10	
ricscibed b	Y MIN3I	3(Q. 2	23-10	
298-102				
230.102				

INTENTIONALLY LEFT BLANK.

.

ACKNOWLEDGMENTS

The authors wish to express their thanks to Mr. Steve McCormack and Mr. Mike Claussen of the Survivability Systems, U.S. Army Tank Automotive Research, Development, and Engineering Center (TARDEC), Warren, MI, for their support and encouragement during this project. It was greatly appreciated.

The authors are grateful to Mr. Chad Monk, a summer student from Harford Technical High School, for performing the spray droplet measurement work.

INTENTIONALLY LEFT BLANK.

· · ·

c

TABLE OF CONTENTS

		Page Page
	ACKNOWLEDGMENTS	iii
	LIST OF FIGURES	vii
	LIST OF TABLES	vii
1.	INTRODUCTION	1
2.	EXPERIMENTAL	1
2.1	Fuel	1
2.2	Spray Device	2
2.3	Setup	2
3.	RESULTS AND DISCUSSIONS	3
3.1	Fire-Out Times	3
3.2	Size of Droplets	3
3.3	Comparison of Water-Based Sprays	4
3.4	Comparison of Sprays Which Were Liquids at -18° C	4
3.5	Comparison of Individual Ions	4
4.	MECHANISM	9
4.1	Lowering Flame Temperature	9
4.2	Lowering Liquid Temperature	9
4.3	Steam Dilutes Air	13
4.4	Quenching by Solid Particles	13
4.5	Blowoff	13
4.6	Application of Mechanisms to Specific Agents	13
5.	CONCLUSIONS	18
6.	REFERENCES	19
,	DISTRIBUTION LIST	21

INTENTIONALLY LEFT BLANK.

vi

LIST OF FIGURES

Figure		Page
1.	Test setup	2
2.	Water and various agents vs. JP-8 flame I	5
3.	Water and various agents vs. JP-8 flame II	5
4.	Water and various agents vs. JP-8 flame III	6
5.	Water and various agents vs. JP-8 flame IV	6
6.	Water and low-temperature agents vs. JP-8 flame I	7
7.	Water and low-temperature agents vs. JP-8 flame II	7
8.	29% calcium chloride vs. 29% calcium iodide	8
9.	10% ammonium bromide vs. 10% ammonium iodide	8
10.	10% ammonium bromide vs. 10% sodium bromide	10
11.	10% sodium bromide vs. 10% potassium bromide	10
12.	Mechanism I - Droplets evaporate cooling flame	11
13.	Mechanism II - Droplets cool liquid fuel	12
14.	Mechanism III - Droplets evaporate forming steam	14
15.	Mechanism IV - Water evaporates forming solid particles	15
16.	Mechanism V - Flame blown off surface of fuel	16

LIST OF TABLES

<u>Table</u>		Page
1.	Rankings of Fire-Extinguishing Sprays	3

INTENTIONALLY LEFT BLANK.

1. INTRODUCTION

The U.S. Army has been involved in the search for a replacement for Halon 1301 ever since halons were identified as ozone-depleting agents in the Montreal Protocol of 1987. Halon 1301 is currently used in Army combat vehicles to suppress hydrocarbon fires in both crew and engine compartments. Several agents (perfluorocarbons) have been identified as nonozone depleting and of very low toxicity. However, other environmental concerns have been raised, such as the agents' potential contribution to global warming. While any global warming potential has not been accurately defined, there is a hesitancy to pick a halon replacement agent that may eventually be classed in an environmentally unacceptable group. This would require a new search for a replacement agent. A halon replacement with no environmental problems is desired. An attractive candidate for this role is water.

It has been found that water is not really very effective in extinguishing a hydrocarbon fire unless that water is delivered to the fire in the form of a mist (very small droplets). Large droplets of water are far less effective, and water in the form of a stream is still less effective. The principal problem with very small droplets of water is that they do not penetrate through the air easily. Large droplets have less air resistance than small droplets; hence, the large droplets travel more easily through air. But the large droplets can pass through a flame with little evaporation since their surface-to-volume ratio is small. The smaller mist droplets with larger surface-to-volume ratios can evaporate easily in a flame, making them more efficient than the large droplets.

The approach reported in this paper is to add materials to water, which can increase the efficiency of the large spray droplets. These large water-based droplets might approach the efficiency of the small mist droplets in extinguishing flame, while retaining the ability to penetrate air more easily than mist droplets. The addition of certain salts to water might also solve the problem of the water freezing in vehicles during cold weather.

2. EXPERIMENTAL

2.1 <u>Fuel</u>. The fuel used in this study was JP-8, which the Army has chosen as the single fuel for use on the battlefield. This fuel has a flashpoint above room temperature, typically about 50° C (122° F). The JP-8 used in this work had a flashpoint of 55° C (130° F).

2.2 <u>Spray Device</u>. A commercial airless paint sprayer was used to spray droplets of water-based agents onto fuel fires. Tests showed that the device sprayed water at the rate of 4.2 g/s. Droplets of spray were collected and analyzed for particle size using an optical microscope.

2.3 <u>Setup</u>. The setup used in these fire-extinguishing experiments consisted of a pan, 14 cm in diameter \times 6.3 cm high, into which 700 ml of JP-8 fuel was poured. The fuel surface was approximately 2.5 cm below the top of the container. Two strands of absorbent paper (wicks) were placed over the rim of the pan, dipping into the fuel.

The spray nozzle was placed 46 cm from the center of the fuel container, elevated 23 cm higher than the rim of the container. The nozzle was aimed at a point 2.5 cm above the top of the container, depressed 26.5° from the horizontal. Tests showed that, when the sprayer was activated, water was collected in the pan at the rate of 1.35-1.50 g/s. A photograph of the setup is given in Figure 1.




Figure 1. Test setup.

3. RESULTS AND DISCUSSIONS

3.1 <u>Fire-Out Times</u>. Table 1 gives the fire-out times for sprays of water and 12 water-based solutions. Data are presented for agents at three temperatures: 5° C, 22° C, and 77° C. Each fire-out time in the table is an average of two to four tests. The sums of the fire-out times at the three temperatures are added to give an overall ranking, the lowest time being best. The physical state of the agents at -18° C is also given. This is the lowest temperature available using a conventional laboratory freezer.

Rank	Agent	Time (5° C) (s)	Time (23° C) (s)	Time (77° C) (s)	Total Time (s)	State at -18° C
1	60% K lactate	0.3	2.4	0.5	3.2	liquiđ
2	60% K acetate	1.8	1.0	0.5	3.3	frozen
3	10% Na Br	2.4	0.7	3.1	6.2	frozen
4	8% K Br in 29% CaCl ₂	5.1	4.6	2.7	12.4	liquid
5	29% CaI ₂	7.6	3.4	5.4	16.4	frozen
6	10% K Br	6.2	6.8	3.4	16.6	frozen
7	12% Pyrocap in 29% CaCl ₂	7.0	4.9	5.1	17.0	thick liquid
8	10% NH ₄ I	5.2	5.7	9.4	20.3	frozen
9	12% Na Br in 29% CaCl ₂	5.3	14.4	5.0	24.7	liquid
10	water	15.5	9.0	7.4	31.9	frozen
11	10% ammonium citrate	8.4	9.3	17.4	35.1	frozen
12	10% NH ₄ Br	10.3	6.0	21.4	37.7	frozen
13	29% CaCl ₂	16.0	6.5	20.2	42.7	liquid

Table 1. Rankings of Fire-Extinguishing Sprays

3.2 <u>Size of Droplets</u>. Spray droplets were collected and examined under an optical microscope. Initially, water droplets from the airless sprayer were collected. It was found that these droplets

evaporated quickly due to the heat from the high-intensity lamp of the microscope. Therefore, droplets of a 60% potassium lactate in water solution were collected on a greased microscope slide and photographed in the optical microscope.


It was found that the droplets from the airless spray were smaller than expected. The maximum of the particle number vs. size distribution was in the $50-100 \mu m$ diameter range. Approximately 95% of the droplets were 200 μm diameter or smaller. No droplets over 400 μm diameter were found.


3.3 <u>Comparison of Water-Based Sprays</u>. Figures 2–5 present, in graphical form, comparisons of the 12 water-based solutions with water as the baseline. It can be easily seen that, while some of the solutions are significantly more effective than water, other solutions are less effective than water. All solutions were tested for fire-extinguishing effectiveness at liquid temperatures of 5° C, 23° C, and 77° C. This gave an indication of the effectiveness of the spray materials over a range of expected vehicle temperatures.


3.4 <u>Comparison of Sprays Which Were Liquids at -18° C</u>. The five agents that were liquid at -18° C are compared to water and each other in Figures 6 and 7. It can be seen that the 60% potassium lactate in water solution is the best performing of the solutions that have low-temperature possibilities. It should be mentioned that the 60% potassium lactate in water solution had a freezing point of -63° C, measured by the Chemistry Lab at the U.S. Army Aberdeen Test Center. One low-temperature agent, a 40% solution of potassium carbonate in water, was rejected from consideration due to its excessively caustic nature. Its pH was measured as 12.9. A pH above 12 identifies a material as hazardous waste requiring special treatment in cleanup and disposal.


3.5 <u>Comparison of Individual Ions</u>. Figure 8 gives the comparison of two solutions, the first, a 29% by weight calcium chloride in water solution, and the second, a 29% by weight calcium iodide in water solution. The iodide solution is significantly better as a fire-extinguishing agent at all three temperatures. The nature of the anion does have an effect on the fire-extinguishing ability of the salt solution. The iodide is more effective than the chloride, on an equal weight of salt basis, at all three temperatures.


Figure 9 gives the comparison of a 10% by weight ammonium bromide in water solution vs. a 10% by weight ammonium iodide in water solution. The two solutions are approximately equivalent at 5° C and 23° C. It is only at 77° C that the ammonium bromide is inferior as an extinguishing agent. It would














be expected that the bromide anion and the iodide anion would be approximately equivalent in their ability to extinguish fires. The poor performance of ammonium bromide at 77° C was unexpected.

Figure 10, a comparison of 10% by weight solutions of ammonium bromide in water and sodium bromide in water, shows that the sodium cation is much more effective than the ammonium cation, in extinguishing fire, on an equal weight of salt basis. It is also apparent, from the figure, that sodium bromide also loses some of its effectiveness at 77° C, compared to 5° C and 23° C.

Figure 11 shows the comparison of 10% by weight in water solutions of sodium bromide vs. potassium bromide. The sodium cation was found to be more effective than the potassium cation on an equal weight of salt basis. While potassium salts are reported to be more effective than sodium salts as extinguishing agents (Allman et al. 1983), those comparisons are on a molar basis, not on a weight basis.

4. MECHANISM

Possible mechanisms by which the water-based sprays extinguished the fuel fires include the following.

4.1 <u>Lowering Flame Temperature</u>. There is a cooling effect, in which droplets enter the flame zone and evaporate. This cooling lowers the flame temperatures and can lead to extinction of the flame. This scenario is shown in Figure 12. The flame of a hydrocarbon will be extinguished when the flame temperature falls to approximately 1,600° C (Lewis and von Elbe 1961).

4.2 Lowering Liquid Temperature. There can be a cooling effect, in which droplets fall into the liquid fuel and lower the fuel temperature. This lowers the rate of fuel evaporation. When the liquid is cooled below its firepoint, the flame will be extinguished. Figure 13 shows this situation. For this mechanism to be viable, it is necessary for the firepoint of the liquid fuel to be a higher temperature than the temperature of the droplets. Thus, the droplets can have a cooling effect on the liquid sufficient to cause extinguishment. Typically, with liquid hydrocarbon fuels, the firepoints are only a few degrees above the flashpoints. Thus, for the JP-8 fuel used in this study, with a measured flash point of 55° C, the firepoint should be 60° C, maximum. This mechanism can be important for the tests where the agents were at 5° C and 23° C. For the tests with hot agents, 77° C, this mechanism would not be important.




Figure 11. 10% sodium bromide vs. 10% potassium bromide.

Figure 12. Mechanism I - Droplets evaporate cooling flame.

Flame temperature drops until flame is extinguished

Water droplets evaporate,

> Water droplets into flame

cooling flame





Figure 13. Mechanism II - Droplets cool liquid fuel

Temperature of liquid falls below fire point and flame is extinguished




s Temper





Water droplets into flame




4.3 <u>Steam Dilutes Air</u>. When a water-bearing droplet enters the flame, there will be at least some evaporation of the liquid water. If the water droplets are with the air that is needed for combustion, the water vapor dilutes all components of the air, including the oxygen. This is shown in Figure 14. A fall in oxygen partial pressure will lower the rate of combustion. In a hexane-air system, diluted with steam (Coward and Jones 1952), all mixtures with less than 13.5% oxygen are nonflammable.

4.4 <u>Quenching by Solid Particles</u>. When droplets of a solution of a salt in water are heated by the flame, water can evaporate, leaving solid particles of the salt. This is depicted in Figure 15. Particles of any noncombustible solid can be used to quench flames. However, some solids are much more efficient than others. Powders, such as purple K (potassium bicarbonate with a purple dye for identification), sodium bicarbonate, and Super K (potassium chloride) are common fire-extinguishing agents. In general, it has been found that potassium salts are more effective than sodium salts. The use of sprays containing dissolved salts that are effective fire-extinguishing agents allows one to direct a powder into the flame of a hydrocarbon fire without filling an entire enclosure with powder. The powder forms due to evaporation of water from the droplets, only where the powder is needed—in the flame zone. It is also possible to dissolve a salt that has the ability to lower the freezing point of water, forming an all-weather agent.

4.5 <u>Blowoff</u>. Figure 16 shows the case in which liquid droplets and entrained air are directed to the flame. The airstream can lift the flame off the liquid surface and off anything that may be acting as a flame holder (rim of the container for the liquid fuel). The lifted-off flame will have a decreased heat feedback to the fuel. As the temperature of the fuel falls, the rate of fuel evaporation decreases. This leads to flame extinction.

4.6 <u>Application of Mechanisms to Specific Agents</u>. In actuality, more than one of these mechanisms will be operational in most cases of using sprays to extinguish a hydrocarbon fire. In some cases, one of the mechanisms may be much more important than any of the others; in other cases, a combination of mechanisms may be responsible for extinguishing fires.


In the case of a water spray, it was observed that the spray caused lift-off of the flame from both the liquid fuel surface and the rim of the pan. There were also liquid water droplets which struck the fuel surface. The temperature of the fuel decreased until the flame was extinguished. At a water temperature of 5° C, the fire-out time was 15.5 s. At a water temperature of 23° C, the fire-out time was less, 9.0 s. This indicates another phenomenon; most likely evaporation of the water droplets in the flame was



Water droplets into flame




Water droplets evaporate, forming steam



Steam dilutes air, causing partial pressure to oxygen to fall below minimum required for flame

Figure 14. Mechanism III - Droplets evaporate forming steam.




Droplets of water with dissolved salt into flame




Water

evaporates leaving solid particles of salt in flame



flame is quenched by solid particles of salt

Figure 15. Mechanism IV - Water evaporates forming solid particles.



Water droplets and entrained air into flame



Air stream blows flame off surface of liquid fuel reducing heat feedback from flame to fuel.



Temperature of liquid falls below fire point and flame is extinguished

Figure 16. Mechanism V - Flame blown off surface of fuel.

greater at 23° C, cooling the flame and causing even less heat feedback to the liquid fuel. At 77° C, the fire-out time with water was 7.4 s, indicating even more evaporation of water droplets in the flame and an even cooler flame. The decrease in the partial pressure of oxygen due to steam formation will also lower the rate of combustion and heat generation. This contributes to cooling of the fuel by lowering the heat feedback mechanism.

In the case of the 29% calcium chloride in water solution, the fire-out time at an agent temperature of 5° C was 16.0 s, indicating the flame blowoff and droplets impinging the fuel surface was responsible for flame extinction, just as for water at 5° C. At 23° C, the fire-out time was 6.5 s, quite similar to water at the same temperature. An increase in the evaporation of water from the droplets may be responsible for a lower fire-out time than was found at 5° C. At 77° C, the fire-out time is quite long, 20.2 s. A possible explanation is that the water droplets evaporated quickly when they entered the heated leading edge of the flame. There was less water per droplet, since the droplets are only 71% water. Therefore, there was less cooling of the flame. Any solid calcium chloride that formed would not be an effective fire-extinguishing salt. Therefore, the 29% calcium chloride solution was less effective than neat water as a fire-extinguishing spray, at least at high-agent temperature.

Using a 10% ammonium iodide spray, the fire-out times are reasonably identical at the three agent temperatures, between 5.2 s at low temperatures to 9.4 s at the high temperature. Some of the water droplets are evaporating even at the low temperature. The ammonium iodide salt has an effective solid surface for flame quenching.

In the case of the 29% calcium iodide in water solution, the fire-out times were uniformly low. There was evaporation of water from some droplets in the flame. The calcium iodide is effective as a flamequenching salt.

The final examples are the 60% by weight solutions of potassium lactate and potassium acetate in water. Each solution was found to be extremely effective in extinguishing the pan fires. The flames were extinguished as soon as the spray arrived at the pan fire. The water evaporated quickly since the droplets were only 40% water. The potassium lactate and potassium acetate solids were extremely effective as solid fire extinguishers. The sprays of these materials provided a convenient method of putting powder fire extinguishing agents into flames without having an excess of powder. The powder formed from the evaporation of water, only where required, in the flame.

5. CONCLUSIONS

- (1) Two of the sprays tested, a solution of 60% potassium lactate in water and a solution of 60% potassium acetate in water, were far superior to the other sprays for extinguishing JP-8 pan fires. It is believed that the high salt content of these solutions is important. The evaporation of the 40% water can occur quickly once the spray droplets encounter a flame. The solid salts released are excellent fire-extinguishing agents. The solids form only in the flame zone, where they are needed. Thus, there is no excess of fire-extinguishing powder. The powder particles are formed only where they can quench the flames.
- (2) All of the sprays, at 23° C and 5° C, had the ability to extinguish JP-8 pan fires. Some of the sprays extinguished simply by cooling the liquid fuel to a temperature below the fire point. These sprays did not have the ability to extinguish by interacting with the flames.
- (3) Sprays of solutions containing iodide salts were superior to sprays of bromide salt solutions, when used to extinguish JP-8 pan fires.
- (4) Solutions of both sodium and potassium salts exhibited good fire-extinguishing ability when used as sprays against the pan fires.
- (5) Salts containing chloride anions did not enhance the fire-extinguishing ability of the sprays. In fact, a 29% calcium chloride in water spray was a poorer fire-extinguishing agent than neat water.

6. REFERENCES

- Allman, Robert L., A. Campbell Ting, Ludwig A. Mayer, and Donald J. Myronuk. "Development and Testing of Dry Chemicals in Advanced Extinguishing Systems for Jet Engine Nacelle Fires." Report JTCG/AS-82-T-002, 1983.
- Lewis, Bernard, and Guenther von Elbe. "Combustion; Flames and Explosions of Gases." New York and London: Academic Press, Inc., 2d edition, 1961.
- Coward, H. F., and G. W. Jones. "Limits of Flammability of Gases and Vapors." U.S. Bureau of Mines Bulletin No. 503, 1952.

INTENTIONALLY LEFT BLANK.

NO. OF

<u>COPIES</u> <u>ORGANIZATION</u>

- 2 DEFENSE TECHNICAL INFO CTR ATTN DTIC DDA 8725 JOHN J KINGMAN RD STE 0944 FT BELVOIR VA 22060-6218
- 1 DIRECTOR US ARMY RESEARCH LAB ATTN AMSRL OP SD TA 2800 POWDER MILL RD ADELPHI MD 20783-1145
- 3 DIRECTOR US ARMY RESEARCH LAB ATTN AMSRL OP SD TL 2800 POWDER MILL RD ADELPHI MD 20783-1145
- 1 DIRECTOR US ARMY RESEARCH LAB ATTN AMSRL OP SD TP 2800 POWDER MILL RD ADELPHI MD 20783-1145

ABERDEEN PROVING GROUND

2 DIR USARL ATTN AMSRL OP AP L (305)

NO. OF COPIES ORGANIZATION

- 1 OSD OT&E LFT PENTAGON ATTN J OBRYON DEP DIR RM 1C730 DOT&E OST WASHINGTON DC 20301
- 1 HQ AMC ATTN AMSMC SFP R LOYD ROCK ISLAND IL 61299-6000
- 1 DIRECTOR USARL ATTN AMSRL OP IS FI E CZAJKOWSKI JR 2800 POWDER MILL RD ADELPHI MD 20783-1145
- 1 COMMANDER US AMC ATTN AMCPD T BUSH 5001 EISENHOWER AVE ALEXANDRIA VA 22333-0001
- 3 COMMANDER USA TARDEC ATTN AMSTA JSS J THOMPSON S MCCORMACK M CLAUSON WARREN MI 48397-5000
- 2 COMMANDER USA TARDEC ATTN AMSTA UEB MR RAO AMSTA WF J MIATECH WARREN MI 48397-5000
- 1 PEO ASM USA TARDEC ATTN SFAE ASM S C BEAUDETTE WARREN MI 48397-5000
- 1 PM AFAS USA TARDEC ATTN SFAE ASM AF T KURIATA PICATINNY ARSENAL NJ 07806-5000

NO. OF COPIES ORGANIZATION

- 2 COMMANDER PM AMMUNITION LOGISTICS ATTN R ROSSI R HO BLDG 455 PICATINNY ARSENAL NJ 07806-5000
- 1 DIR FIRE SERVICES ATTN CEHSC FB I B PARK USA ENGNRNG & HOUSING SUPPORT CTR FORT BELVOIR VA 22060-5516
- 2 COMMANDER USA TRADOC ATTN SFAE ASM SS M RYZYI PM SURVIVABILITY SYSTEMS WARREN MI 48397-5000
- 1 COMMANDER USA TRADOC ATTN SFAE ASM SS T DEAN WARREN MI 48397-5000
- 1 COMMANDER USA ARMOR SCHOOL ATTN ATSB CD S G SKAFF FORT KNOX KY 40121-5215
- 1 US NRL NAVY TECH CTR FOR SAFETY & SURV ATTN CODE 6180 R SHEINSON WASHINGTON DC 20375-5000
- 1 USAF WRIGHT LABS MATL DIR ATTN M BENNETT WRIGHT PATTERSON AFB OH 45433
- 1 US BUREAU OF MINES PITTSBURGH RSRCH CTR ATTN M SAPKO COCKRANS MILL RD PITTSBURGH PA 15236

NO. OF

COPIES ORGANIZATION

- 1 UNIV OF MASSACHUSETTS AT LOWELL DEPT OF CHEMISTRY ATTN DR W BANNISTER 1 UNIVERSITY AVE LOWELL MA 01854
- 2 NATL INST OF STAND & TEST NATL BUR OF STANDARDS ATTN R GANN W TSANG GAITHERSBURG MD 20899
- 1 NM ENG RSRCH INST CTR FOR GLOB ENV TECH ATTN R TAPSCOTT 901 UNIVERSITY BLVD SE ALBURQUERQUE NM 87106-4339
- 1 NM ENG RSRCH INST CTR FOR GLOB ENV TECH ATTN T MOORE 901 UNIVERSITY BLVD SE ALBUQUERQUE NM 87106-4339
- 2 SW RESEARCH INSTITUTE ATTN B WRIGHT P ZABEL 6220 CULEBRA RD SAN ANTONIO TX 78284
- 1 BRTRC ATTN A REMSON 370 MAPLE AVE W VIENNA VA 22180
- 1 SUPRS SYS ENGINEERING INC ATTN R GORDON 2005 DE LA CRUZ BLVD 118 SANTA CARLA CA 95055
- 1 BMY COMBAT SYSTEMS ATTN J JOHNSON PO BOX 15512 YORK PA 17405-1512
- 1 TRW SYS ENGRNG & DEV DIV SYS INTEGRATION GROUP ATTN G SCHNEICKERT 1650 RESEARCH DR STE 115 TROY MI 48083

NO. OF COPIES ORGANIZATION .

- 1 D R KENNEDY & ASSOC INC ATTN D KENNEDY PO BOX 4003 MOUNTAIN VIEW CA 94040-0003
- 1 ZALLEN INTL ASSOC ATTN D ZALLEN 14216 TURNER COURT NE ALBUQUERQUE NM 87123
- 1 BP EXPLORATION INC ATTN D CATCHPOLE PO BOX 196612 ANCHORAGE AK 99519-6612
- 1 BLAZE TECH ATTN N MOUSSA 145 HIGHLAND AVE WINCHESTER MA 01890-1435
- 1 SYSTRON DONNER SAFETY SYSTEMS DIV ATTN D WARREN 935 DETRIOT AVE CONCORD CA 94518-2592
- 1 SURVICE ENGINEERING ATTN R LEVY 1003 OLD PHILADELPHIA RD STE 103 ABERDEEN MD 21001
- 1 HALON ALTERNATIVE RSRCH CORP ATTN T CORTINA 2111 WILSON BLVD STE 850 ARLINGTON VA 22201-3001
- 1 OLIN AEROSPACE ATTN G HOLLAND 11441 WILLOWS RD NE REDMOND WA 98073-9709
- 1 FENWAL SAFETY SYSTEMS ATTN J SENECAL 700 NICKERSON RD MARLBORO MA 01752

NO. OF COPIES ORGANIZATION

- 2 US EPA STRAT PROT DIV ATTN R RUBENSTEIN K METCHIS 401 M ST SW MS 6205J WASHINGTON DC 20460
- 1 GAMBOA INTL ATTN F GAMBOA 3920 OAK ST FAIRFAX VA 22030
- 1 GENERAL DYNAMICS LAND SYS ATTN A GERARD MS 436 21 24 PO BOX 2074 WARREN MI 48090-2074
- 1 US DEPT OF ENERGY PITTSBURGH ENERGY TECH CTR ATTN D WILDMAN PO BOX 10940 PITTSBURGH PA 15236

NO. OF

22

COPIES ORGANIZATION

ABERDEEN PROVING GROUND

ъ

DIR, USARL ATTN: AMSRL-WT-WG, L. PUCKETT AMSRL-WT-PC, A. MIZIOLEK J. HEIMERL AMSRL-WT-TA, J. DEHN AMSRL-WT-TB. **R. FREY** J. WATSON W. HILLSTROM R. MCGILL A. CARDAMONE A. FINNERTY (10 CPS) AMSRL-SL-BS, **R. WOJCIECHOWSKI** P. KUSS AMSRL-SL-BV, J. PLOSKONKA

6 DIR, USAATC

- ATTN: STECS-LI-U, S. POLYANSKI J. MILLER B. SOKOLIS D. ERDLEY STEAC-TS-PC (BLDG 363) C. HERUD B. BOLT
- 2 DIR, USAMSAA ATTN: M. CARROL L. KRAVITZ

1 CDR, USATECOM ATTN: N. HARRINGTON

NO. OF COPIES ORGANIZATION

1 KIDDE GRAVINER ATTN D BALL PAYLE ROAD COLNBROOK SLOUGH BERKSHIRE SL3 OHB UNITED KINGDOM INTENTIONALLY LEFT BLANK.

USER EVALUATION SHEET/CHANGE OF ADDRESS

This Laboratory undertakes a continuing effort to improve the quality of the reports it publishes. Your comments/answers to the items/questions below will aid us in our efforts.

1. ARL Report Number/Author <u>ARL-TR-1138 (Finnerty)</u> Date of Report <u>July 1996</u>

2. Date Report Received _____

3. Does this report satisfy a need? (Comment on purpose, related project, or other area of interest for which the report will be used.)

4. Specifically, how is the report being used? (Information source, design data, procedure, source of ideas, etc.) _____

5. Has the information in this report led to any quantitative savings as far as man-hours or dollars saved, operating costs avoided, or efficiencies achieved, etc? If so, please elaborate.

6. General Comments. What do you think should be changed to improve future reports? (Indicate changes to organization, technical content, format, etc.)

Organization

Name

CURRENT ADDRESS

Street or P.O. Box No.

City, State, Zip Code

7. If indicating a Change of Address or Address Correction, please provide the Current or Correct address above and the Old or Incorrect address below.

Organization

OLD ADDRESS

Name

Street or P.O. Box No.

City, State, Zip Code

(Remove this sheet, fold as indicated, tape closed, and mail.) (DO NOT STAPLE)