


ENERGY ENGINEERING ANALYSIS PROGRAM
STUDY REPORT

EXECUTIVE SUMMARY
FINAL REPORT

ANNISTON ARMY DEPOT
ANNISTON, ALABAMA



MOBILE DISTRICT
CORPS OF ENGINEERS

Best Available Copy

CONTRACT DACA01-80-C-0097
JUNE 1982

19971016 202

DAY & ZIMMERMANN, INC.




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORY, CORPS OF ENGINEERS
PO BOX 245
CHAMPAIN, ILLINOIS 61820-0245

Approved by TR-T Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.


Marie Wakefield,
Librarian Engineering

EXECUTIVE SUMMARY

This is a summary of the Energy Engineering Analysis performed for the Anniston Army Depot (ANAD) in Anniston, Alabama. It includes recommendations to be considered in the development of a Basewide Energy Plan, consisting of energy conservation projects and other recommendations for reduction of the installation's 1985 source energy consumption.

Anniston Army Depot is located in Northeastern Alabama, approximately 10 miles west of the City of Anniston. The Depot is the largest combat vehicle rebuilding facility in the free world. The eastern part of the property is gently rolling land, while the western part is hilly with some steep slopes. The Coosa River Storage Annex is operated as part of the Depot, with land ranging from gently rolling to mountainous.

This summary presents data on:

- Historical and predicted energy consumption
- Energy conservation procedures for distribution systems
- Energy conservation procedures for buildings and processes
- Utilization of energy monitoring and control systems (EMCS)
- Utilization of wood biomass and waste fuels
- Cogeneration and Replacement Boilers

The conservation of energy in existing facilities can be accomplished in the following two ways:

- Reduce the basic system energy requirements and source energy use
- Recover energy discharged from one user and utilize this waste energy for other purposes

A reduction in system energy requirements is represented by such activities as lowering equipment operating temperatures, reduction of transmission losses by better insulation, and night/weekend setback or shutdown of energy users and associated distribution systems.

Recovery of energy discharged by one user and utilization of this waste energy for other purposes is demonstrated by such activities as returning condensate to boiler systems and recovery of heat from process exhaust air systems to preheat replacement air. Examples of energy below the level of practical utilization are exhaust flue gases from boilers (cooled to near the dew point), and air exhausted from buildings near ambient temperature conditions.

This study has been directed towards identifying means of energy conservation conforming to those two methods identified as reduction in overall use and recovery of waste energy. Although the above discussion may appear to be confined to heat energy, investigations covered electrical usage, water usage, compressed air, wood biomass and solar energy.


The number and type of viable ECIP funded projects has been restricted by direction of the COE, Mobile to those which qualify at an Energy/Cost ratio of 13 or greater for fiscal year 1985, and which exceed a Capital Cost Value of \$100,000. The total energy savings presented in this report can be obtained only upon full implementation of the viable ECIP projects, compliance with the recommended conservation measures requiring capital investments less than \$100,000, and those measures requiring policy changes at the management level.

Computer simulations of building energy use were modeled using the DOE-2.1 program. Computer simulations for energy utilization were performed on typical building types. Categorizing and prototyping methodology followed procedures outlined in the Black & Veatch Study "Engineering Instructions for Preparation of a Basewide Energy Systems Plan", dated January 1980. After careful examination of the ANAD facilities during field surveys, taking into consideration the building construction, building functions, and plant operating procedures, a total of 13 typical buildings were computer modeled to determine their energy use, both thermal and electrical, and to verify recorded historical energy consumption figures during the base year 1975. The final analysis resulted in a correlation which was within 2 percent of recorded consumption figures.

Energy conservation projects were generated from the energy model for conservation measures involving building insulation, reduction in fenestration area, temperature controls installation, re-lighting with energy-efficient fixtures, and a basewide EMS. A detailed analysis is provided in the main report.

The following is a tabulation of the ANAD source energy consumption for the fiscal year ending September 1980.

Electricity	$491,724 \times 10^6$ BTU
Fuel Oil No. 2	$118,363 \times 10^6$ BTU
Coal	$314,058 \times 10^6$ BTU
Natural Gas	78.6×10^6 BTU
LP	$6,275.8 \times 10^6$ BTU
Total	130,480 Mera BTU



BASEWIDE CONSUMPTION FY-80
TOTAL 930,480 x 10⁶ BTU

FIGURE 1

This yields a total of 930,480 Mega BTU's for FY-80 (see Figure 1). It is reported that operations during this period were at the normal production level for this facility.


Figure 2 shows the historical and predicted annual energy consumption for a ten-year period through fiscal year 1986, reflecting the effect of proposed conservation measures.

It was determined that the fuel consumption rate for this facility is partially weather-dependent. Since about 43% of the steam generated in the boilers is consumed in process operations, the remainder is therefore consumed in building heating and transmission line losses getting the steam to the buildings. Figure 3 shows the monthly fuel consumption for fiscal year 1980. Note the peaks during the cold winter months.

Figure 4 shows the basevide electrical consumption for the past three fiscal years. Recent annual consumption shows a slight decline due to the shaving of peaks in cold winter months, while the average yearly consumption remains relatively constant between 42 and 43 million kilowatt hours. It is apparent the peaks have been reduced as a result of an Executive Order prohibiting supplemental electrical heating units where a building already contains a main source of heat.

Production levels in the near future can be expected to remain the same as for fiscal year 1980. Therefore, assuming similar weather conditions for the Annapolis Area, future fuel consumption on a short term basis should remain relatively constant.

PROJECTED ENERGY CONSUMPTION
 ANNISTON ARMY DEPOT
 BASEWIDE FUEL & ELECTRIC



SAVINGS
 135,000 x 10⁶
 BTU

FIGURE 2
 ES-6

BASEWIDE FUEL CONSUMPTION
ANNISTON ARMY DEPOT FY-80




FIGURE 3

AMBIION ARMY DEPOT ELECTRICAL LOAD




FIGURE 6

The projected basewide energy costs through fiscal year 1986 are shown on Figure 5. Projections are made for the facility if operated in its 1980 mode plus proposed steam load increases. Predicted costs resulting from the anticipated energy savings from implementation of all energy conservation projects and recommendations in FF-85 are shown by the solid line graph. The following escalation rates were used for calculation purposes:

Fuel Oil:	1.14 (14%)
Coal:	1.10 (10%)
Electricity:	1.13 (13%)

A total of 13.6% or 135,000 Mega BTU can be saved annually upon implementation of all viable ECIP projects and energy conservation recommendations determined by this study. Figure 6 shows the total source energy reduction. Further breakdown of the total savings yields the following:

Fuel Oil:	$5,290 \times 10^6$ BTU saved
Coal:	$30,290 \times 10^6$ BTU saved
Electricity:	$99,200 \times 10^6$ BTU saved

Projects for source energy reduction are listed in Table i with their corresponding E/C ratio. Table A-1 contains projects not qualifying for ECIP funding, requiring less than \$100,000 capital expenditure, but which are considered to be good energy-saving measures. (See Appendix A of this summary.)

PROJECTED ENERGY COSTS
FUEL & ELECTRICITY
ANNISTON ARMY DEPOT





FIGURE 3



BASELOAD ENERGY CONSUMPTION
F1-35
AFTER ECIP PROJECTS

FIGURE 6

Further explanation of the historical energy consumption, basewide energy model, and energy conservation analysis can be found in the Energy Use Survey. The analysis for control schemes and basewide EMS applications is included in the report on Energy Monitoring and Control Systems.

The composite total in energy reduction for building improvement projects is not a simple algebraic summation of individual project's energy savings. Due to synergistic effects, the composite total savings are approximately 85% of the simple sum. Consideration must be given to these synergistic effects when arriving at energy savings using different combinations of energy conservation projects.

The addition of simple temperature controls or the installation of a basewide EMS essentially accounts for the same block of energy to be saved. One or the other must be chosen, and thus the energy savings can only be taken credit for one time. Although the initial cost is greater to install the EMS, it does have a decided advantage over the simpler temperature controls arrangement due to its inherent ability to monitor and report out of state operating conditions. This discourages tampering by personnel and ultimately guarantees energy savings, provided the system is properly installed and maintained.

ECIP PROJECT SUMMARY
ANNISTON ARMY DEPOT

PROJECT TITLE	PROJECT NUMBER	COST \$1000	ENERGY SAVED MEGA BTU ELEC. OIL COAL	B/C	E/C	PB YEARS
Temperature Controls - 83 Buildings	M-204	323.9	8008.1 3790.2 15276.1	5.34	87.5	1.98
Upgrade District Steam Insulation - East End	A-10	209.9	- 11600	3.1	61.3	4.3
Sealight 61 Buildings	M-206	2079.2	77261.6 - -	2.9	79.0	3.8
Decrease Windows 53 Buildings	M-203	374.1	4652.3 2437.7 6008.6	3.65	38.4	4.27
Insulate EMCS - 83 Buildings	M-205	1185.1	8008.1 3790.2 15376.1	1.20	24.0	10.0
Install (2) Regenerative Dynamometers	A-3	851.1	11207 - -	1.01	14.5	10.2

TABIX 1

A detailed study of the utilization of Biomass material from the 14,000 acre Anniston Site as an energy source was conducted. This study indicated that it would take 20 to 25 years to develop woodlands capable of maintaining a reasonably uniform level of Biomass material. However, there is opposition to increasing the amount of woodlands at ANAD for security reasons which prevents production of enough wood capable of generating the steam required by this facility.

At present, wood biomass would be a more expensive fuel than coal or oil at Anniston Army Depot. Due to the high moisture content of wood and handling expenses, the cost of burning wood grown on site would be about 1.7 times that of coal per BTU equivalent.

However, since there already exists a Forestry Program which involves the regular removal of timber, any wood which is not of sawtimber quality may be utilized in the following ways:

- used as a fuel at ANAD
- sold to pulp mills
- separated, using the low quality wood for fuel at Anniston and selling the high quality wood to pulp mills.

A complete analysis on the burning of wood materials is presented in the Biomass Survey section of the report.

An analysis was performed for the application of central boiler plants as a method of meeting the projected growth in steam demand as established in the ANAD Master Plan. It was determined that under present levels of summer steam demand, the installation of

cogeneration equipment was not economical, making a life cycle cost analysis (LCC) of this alternative a meaningless calculation. The final recommendations suggest the installation of new coal fired steam generators at a location in the east end of the depot. We recommend the installation of (3) - 30,000 lbs./hr. boilers, one at a time, at convenient intervals based on anticipated steam demand increases from the present time through the year 1988. Details of the study are presented in the section on Central Boiler Plants.

APPENDIX A
POTENTIAL CONSERVATION MEASURES

TABLE A-1

POTENTIAL CONSERVATION MEASURES REQUIRING CAPITAL INVESTMENT

<u>Project Studied</u>	<u>Comments</u>
1. Insulate walls of chemical cleaning tanks	Good Project
2. Install retractable covers on chemical cleaning tanks	Good Project
3. Install boiler economizers, oxygen trim controls, blowdown heat reclaim devices, etc.	Viable for process loads; short heating season does not justify capital cost of retrofit
4. Reset outside air dampers to minimum requirements of ASHRAE 62-73	Good project; very limited application
5. Add floor, ceiling, and wall insulation	This is a viable project for specific buildings only
6. Install storm windows	Limited applications to non-industrial structures
7. Install solar shading devices: - Solar window film - Solar screens - Overhangs - Awnings	Solar energy currently provides assistance to building heating in some buildings with significant window area
8. Weatherscrip doors	Limited applications to non-industrial structures
9. Install vestibules around high traffic doors	This project has limited application due to size of vehicles
10. Install setback temperature controls	Good Project
11. Install regenerative engine	Good Project
12. Reduce glass area by adding insulated panels	Good Project

POTENTIAL CONSERVATION MEASURES REQUIRING CAPITAL INVESTMENT
(Continued)

Project Studied	Comments
13. Install flue dampers, smaller jets, dual burners, electronic ignition, etc. in small furnaces	Short heating season does not justify capital cost of retrofit
14. Replace manual control valves or install temperature regulators in cast-iron radiators	Not cost effective where central controls are recommended
15. Replace existing coal boilers with gas/oil conversion kits with modern packaged boilers	This project does not meet the criteria
16. Replace incandescent lighting with higher efficiency lighting systems	Good Project
17. Install photocell lighting controls	This project has limited application
18. Replace existing motors with motors of the high efficiency type	There is an engineering disagreement concerning this project particularly where large older motors are involved
19. Reduce lighting levels to minimum standards	Limited application - many facilities are below minimum standards
20. Install water closer tank inserts, flow reducing shower heads, or other water conserving devices to reduce pumping energy consumption	Limited Application
21. Insulate existing steam lines	Good Project
22. Revise existing chilled water/hot water pumping schemes to more efficient methods	N/A
23. Deactivate individual room thermostats in barracks and install temperature reset controls on chilled and hot water	N/A
24. Shut down steam plants in the summer and satisfy process steam needs with electric boilers	N/A

POTENTIAL CONSERVATION MEASURES REQUIRING CAPITAL INVESTMENT
(Continued)

Project Studied	Comments
25. Install infrared heating in warehouses, hangars, and shops	This project does not meet the criteria due to short heating duty cycles
26. Install economizer systems for "Free cooling" in intermediate seasons	This project does not meet the criteria in retrofit applications
27. Modify multizone systems to include hot/cold deck reset	N/A
28. Modify cooling tower systems to cycle fan with load and/or install bypass valving	N/A
29. Install load-shedding system to minimize demand charges	N/A
30. Correct power factor	This project does not meet the criteria
31. Install chilled and hot water reset controls	N/A
32. Install FM radio control system	N/A
33. Replace existing windows with insulating panels	Very limited application
34. Insulate temporary buildings	N/A
35. Upgrade electrical distribution voltage	N/A
36. Install total or selective energy plants	This project does not meet the criteria
37. Install energy monitoring and control system (EMCS)	Good Project
38. Install heat reclaim devices on air-cooled condensers	Limited Application
39. Replace remotely located absorption chillers with more efficient electric-driven chillers	N/A
40. Install solid waste-burning boilers	This project does not meet the criteria

POTENTIAL CONSERVATION MEASURES REQUIRING CAPITAL INVESTMENT
(Continued)

Project Studied	Comments
41. Install trailer enclosing devices at loading docks	This project has limited additional application
42. Install solar energy systems where feasible	This project does not meet the criteria
43. Install air-to-air heat reclaim devices in high exhaust areas, such as messhall kitchens	This project does not meet the criteria

TABLE A-2

POTENTIAL CONSERVATION MEASURES REQUIRING POLICY CHANGES
AT INSTALLATION LEVEL

Project Studied	Comments
1. Replace domestic water heaters with higher efficiency models as replacement is required.	Good Project
2. Shut down steam boilers and branch lines in summer	Currently Practiced
3. Reduce domestic hot water temperatures from 140°F to 110-120°F	Good Project
4. Replace electric motors with motors of the high efficiency type on replacement basis	Good project, limited application due to motor frame sizes of older equipment
5. Use task lighting	Currently Practiced
6. Install temporary 4-mil plastic storm windows	Good Project
7. Shut down HVAC and DRW systems in unoccupied buildings	Currently Practiced
8. Caulk cracks on self-help basis	Good Project
9. Install high-efficiency transformers on replacement basis	Good project - recommend replacement of all oversized transformers
10. Enforce indoor space temperature regulations	Good Project
11. Repair steam and condensate leaks	Good Project
12. Repair air leakage in ducts	N/A
13. Turn pilot lights for heating equipment off for the summer	Good project
14. Replace air-conditioning units with high efficiency models as replacement is required	Good project

APPENDIX 3
BUILDING DATA

INDEX

APPENDIX B

		<u>PAGE NO.</u>
TABLE 1	Prototype Buildings	ES-24
	Legend for Table 1	ES-25
TABLE 2	Typical Building Energy Consumption Data	ES-26
TABLE 3	Air Change Rates Used for Infiltration	ES-27
TABLE 4	Monthly Thermal Computer Analysis Data	ES-28
TABLE 5	Tabulation of Energy Requirements By Typical Building Groups & Areas	ES-29 to ES-42
TABLE 6	Tabulation of Energy Requirements By Building Number and Area	ES-43 to ES-52

TABLE 2

Prototype/Computer Simulated			
Category Code	AD Bldg. No.	Function	Similar Buildings
A-1-E	7	Headquarters	None
A-1-E	33	Security	None
A-1-E W-1-E	162	Office Warehouse	None
A-1-W	1	Office	2, 75, 220, 221, S-15, S-16, S-47, S-48, S-49, S-274
A-1-O	103	General Purpose	106, 363 (Air Condition area only)
A-1-O	140	Administration	100, 141, 302
M-1-E	301	Tank Repair Shop	None
M-1-W	21	Shop	3, 4, 5, 8, 9, 10, 19, 22, 27, 38 46, 55
M-2-S	34	Shipping	58, 59, 65, 87, 88, 171, 172, 380, 381, 600, 652, 654, 638, 669, 670, 673, 678, 676, 677, 680, 688, S-84
M-1-O	129	Small Arms Shop	104, 111-113, 127, 128, 130
M-1-O	143	Tank Repair Shop	107, 108, 117, 144, 146, 147, 402, 411, 411, 503, S-142
M-1-O	400	Tank Repair Shop	None
M-1-O	409	Vehicle Maint. Shop	410, 433

TABLE 1

LEGEND

<u>Category Code</u>	<u>Building Type</u>	<u>HVAC System</u>
A-1-E	Administration	- Permanent Air Condition - Oil-fired individual heating plant
A-1-N	Office	- Permanent Air Condition - Coal-fired individual heating plant
A-1-O	Administration	- Permanent Air condition - Coal-fired central boiler plant
M-1-E	Maintenance/Production	- Permanent In-air condition - Oil-fired individual heating plant
M-1-N	Maintenance/Production	- Permanent In-air condition - Coal-fired individual heating plant
M-1-N	Maintenance/Production	- Permanent Partially Air Condition - Coal-fired individual heating plant
M-1-O	Maintenance/Production	- Permanent In-air condition - Coal-fired central boiler plant
M-1-E	Warehouse	- Permanent In-air condition - Oil-fired individual heating plant

C

TABLE 2
 TYPICAL BUILDING ENERGY CONSUMPTION DATA
 AAD

Group No.	Bldg. No.	Building Description	Annual Energy Source Consumption, BTU x 10 ⁶			Elec. Energy Source Consumption, kWh/Year		Elec. Energy Consumption kWh/Year	Peak kW	Area x 10 ⁴ Sq. Ft.
			Coal	Oil	Nat. Gas	Total	Peak			
A-1-K	7	Headquarters	-	2066.0	9,910.4	11,981.4	1,011,224	366.4	8,221	
A-1-B	53	Security	-	548.3	7,146.0	7,695.1	663,371	262.9	8,257	
A-1-E	362	Office Warehouse	-	8861.6	10,907.0	23,049.4	2,055,983	480.7	1,890	
A-1-N	1	Office	507.1	-	1,625.1	2,132.2	183,010	41.6	0,169	
A-1-O	103	General Purpose	680.9	-	11,515.4	12,196.3	1,051,405	260.6	0,410	
A-1-Q	140	Administration	270.5	-	1,675.6	1,946.1	167,767	79.3	0,224	
M-1-B	501	Tank Repair Shop	-	3125.5	2,730.3	5,866.0	595,586	101.7	0,096	
M-1-C	21	Shop	896.1	-	4,385.3	5,281.4	455,253	62.3	0,322	
M-1-D	54	Shipping	247.5	-	715.9	963.4	83,052	31.0	0,129	
M-1-E	129	Small Arms Shop	3132.5	-	8,651.0	10,783.5	929,612	175.4	0,112	
M-1-F	143	Tank Repair Shop	3122.2	-	3,390.7	6,520.9	562,147	110.7	0,071	
M-1-G	400	Tank Repair Shop	7694.3	-	13,113.4	20,807.7	1,783,767	496.5	0,092	
M-1-H	409	Vehicle Maint. Shop	914.0	-	1,454.3	2,378.1	205,095	55.1	0,043	

TABLE 3

WINSTON AD

AIR CHANGE RATES USED FOR INFILTRATION

<u>BLDG. NO.</u>	<u>AS IS</u>	<u>INSUL. ROOF</u>	<u>INSUL. WALLS</u>	<u>REDUCE GLASS</u>
1	3	-	-	2
7	1.5	-	-	-
21	4	1.5	1.5	-
33	3	-	-	-
34	4	-	1.5	-
104	4	-	1.5	-
109	1.5	-	-	-
129	3	2.5	1.5	-
140	3	-	-	-
143	7	4.5	6.5	-
362 (Office)	3	-	-	-
362 (Warehouse)	5	4.5	4.5	-
400	7	6.5	6.5	-
409	5	-	-	-
502	5	-	-	-

TABLE 3
ABD

TABLE 3 - MONTHLY THERMAL COMPUTER ANALYSIS OUTPUT (MBTU)
AS IS CONDITION

Bldg. No. Bldg. End	J	F	M	A	M	J	J	A	S	O	N	D	Total
104	218.1	217.2	165.4	5.5	0	0	0	0	0	11.2	31.5	127.6	718.5
105	165.9	177.4	134.5	19.1	0	0	0	0	0	21.5	41.9	116.6	680.9
129	597.7	597.4	653.1	15.0	0	0	0	0	0	34.7	91.6	149.0	2,132.5
140	70.4	67.1	57.7	5.5	0	0	0	0	0	7.0	16.0	46.0	270.5
143	837.9	812.2	613.1	20.9	0	0	0	0	0	78.6	162.0	589.7	3,122.3
400	2,124.6	2,848.2	1,564.5	62.4	0	0	0	0	0	152.9	361.1	1,340.5	7,694.1
409	261.7	254.8	195.5	2.4	0	0	0	0	0	8.9	29.7	161.8	924.8
Other Bldg. End Bldgs.													
00-106,107,108, 11-115,117,127, 28-130,141,144, 46,147,402,410, 11,421,433,502, 03.5-142	6,938.3	4,867.0	3,715.3	159.1						337.9	653.7	3,148.5	17,990.6
TOTAL MBTU	9,218.6	9,040.1	6,899.1	297.9	0	0	0	0	0	648.7	1,600.3	5,889.7	33,594.4
Boiler/Bldg. Eff.	65	60	55	50	-	-	-	-	-	50	60	65	Avg. 60.6
RTU & Boiler	14,183	15,067	12,544	596	0	0	0	0	0	1,297	2,667	9,061	55,415
8 Dev.	-19	-10	4274	-41	0	0	0	0	0	-29	-22	417	15

TABLE 5 - MONTHLY THERMAL COMPUTER ANALYSIS OUTPUT (MBTU) AS IS CONDITION

Boiler MBTU	17,411	16,689	4,568	1,018	0	0	0	0	0	1,812	3,415	7,734	52,669
ADJ. 6 YEAR AVERAGE - RECORDED DATA (From Exhibit 1)													

TABLE 5

ACQUISITION AREA REPORT - East Bank FUEL: Coal BOILER EFFICIENCY: 60%

LINE NO.	DATE	BOILER INSULATION				EXHAUST INSULATION				DECREASE WINDOWS SEA				TEMPERATURE CONTROL					
		AREA	PERCENTAGE	PERCENTAGE	PERCENTAGE	AREA	PERCENTAGE	PERCENTAGE	PERCENTAGE	AREA	PERCENTAGE	PERCENTAGE	PERCENTAGE	AREA	PERCENTAGE	PERCENTAGE	PERCENTAGE		
126	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
127	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
128	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
129	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
130	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
131	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
132	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
133	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
134	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
135	129	106557	1114.5	.0110	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100	20137	199.0	.0100
TOTAL		537092	6109.5	N/A	115615	2290.1	N/A	115615	2290.1	N/A	115615	2290.1	N/A	115615	2290.1	N/A	115615	2290.1	N/A

REMARKS:

ADMINISTRATIVE BUDGET - Base Bid

2014-2015

WALL EFFICIENCY: 100

CLAS. NO.	L'VEP BUDG. BUDG. AREA	ROOF INSULATION				WALL INSULATION				DECREASE IN MECA BTUS				MECA BTUS				TEMPERATURE COMFORT				
		MECA BTUS	TELEC-MAJ	ELC-TVIC	FTT-ROOF	WALL AREA	TELEC-MAJ	ELC-TVIC	FTT-ROOF	MECA BTUS	TELEC-MAJ	ELC-TVIC	FTT-ROOF	FLOOR AREA	TELEC-MAJ	ELC-TVIC	FTT-ROOF	MECA BTUS	TELEC-MAJ	ELC-TVIC	FTT-ROOF	
149	149	23150	2821.1			58904	879.0			4770	832.5			91910	245.1							
151	151	4491	20.0			2693	39.6			202	2.0			4291	44.1							
152	152	31553	660.1			10411	272.3			1028	28.1			30313	302.5							
153	153	31553	660.1			10411	272.3			1028	28.1			30313	302.5							
154	154	3539	71.0			205	16.5			159	3.2			3360	35.0							
155	155	27071	581.6			16312	289.3			1281	17.0			26520	275.0							
156	156	10660	203.0			833	126.0			658	9.3			14080	140.6							
157	157	5637	113.3			3163	66.6			200	3.5			5193	53.6							
158	158	10251	222.6			637	80.6			470	6.6			16077	164.2							
159	159	10251	222.6			637	80.6			470	6.6			16077	164.2							
160	160	610	130.2			1603	51.3			270	3.0			5910	61.2							
161	161	15218	315.6			20520	202.2			1500	22.5			33090	340.2							
TOTAL		101261	5910.9			160810	2438.0							269233	2804.2							

NOTES: * indicates increase in MECA BTUS and is not included in Project R-203.

RESISTOR ARRAY REPORT - Model No. 604
 FROM: Cool
 BOILER EFFICIENCY: 604

LINE NO.	LOADING	DAILY INSULATION				WALL INSULATION				CONCRETE IN MASS STUDS				DECKING STUDS 50%				TEMPERATURE CONTROL										
		WALL AREA	TRNS- KAL.	MEGA BTUS	PER SQ FT	WALL AREA	TRNS- KAL.	MEGA BTUS	PER SQ FT	WALL AREA	TRNS- KAL.	MEGA BTUS	PER SQ FT	WALL AREA	TRNS- KAL.	MEGA BTUS	PER SQ FT	FLOOR AREA	TRNS- KAL.	MEGA BTUS	PER SQ FT	ROOF AREA	TRNS- KAL.	MEGA BTUS	PER SQ FT			
1	21	16640	425.2	.0256	3097	343.3	.0244	697	391.5	.0213	16706	389.3	.0179	16706	389.3	.0179	16706	389.3	.0179	16706	389.3	.0179	16706	389.3	.0179	16706	389.3	.0179
2	21	852	22.2	.0256	318	17.7	.0243	26	15.2	.0213	653	15.1	.0179	653	15.1	.0179	653	15.1	.0179	653	15.1	.0179	653	15.1	.0179	653	15.1	.0179
3	21	14720	191.0	.0256	3990	346.2	.0240	626	362.7	.0195	14213	362.7	.0179	14213	362.7	.0179	14213	362.7	.0179	14213	362.7	.0179	14213	362.7	.0179	14213	362.7	.0179
4	21	82240	467.1	.0256	18016	374.0	.0246	766	320.3	.0195	17274	320.3	.0179	17274	320.3	.0179	17274	320.3	.0179	17274	320.3	.0179	17274	320.3	.0179	17274	320.3	.0179
5	21	1320	69.8	.0256	1103	39.3	.0245	60	33.0	.0220	1892	33.0	.0179	1892	33.0	.0179	1892	33.0	.0179	1892	33.0	.0179	1892	33.0	.0179	1892	33.0	.0179
6	21	6517	167.3	.0256	3990	374.0	.0240	276	116.8	.0190	6440	116.8	.0179	6440	116.8	.0179	6440	116.8	.0179	6440	116.8	.0179	6440	116.8	.0179	6440	116.8	.0179
7	21	1720	60.2	.0256	8027	35.8	.0245	72	30.3	.0212	1700	30.3	.0179	1700	30.3	.0179	1700	30.3	.0179	1700	30.3	.0179	1700	30.3	.0179	1700	30.3	.0179
8	21	6176	392.7	.0256	30302	605.2	.0246	1726	733.5	.0196	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179
9	21	4126	294.7	.0256	28502	605.2	.0240	1726	733.5	.0196	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179
10	21	2176	104.7	.0256	30502	605.2	.0240	1726	733.5	.0196	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179	48567	733.5	.0179
11	21	256	6.5	.0256	132	5.3	.0250	11	0.6	.0090	252	0.6	.0179	252	0.6	.0179	252	0.6	.0179	252	0.6	.0179	252	0.6	.0179	252	0.6	.0179
12	21	82240	492.0	.0256	13606	290.0	.0240	805	330.0	.0199	19250	330.0	.0179	19250	330.0	.0179	19250	330.0	.0179	19250	330.0	.0179	19250	330.0	.0179	19250	330.0	.0179
TOTAL		405023	5238.2		132033	4236.6		8417	4413.6		282163	3660.3																

UNITS: BTUS

MURKIN		BOILER EFFICIENCY, 60%																		
		SOOT INSULATION					RECORDS IN MESA PITS					TEMPERATURE CONTROL								
BLDG. NO.	CLASS	SOOT INSULATION			RECORDS IN MESA PITS			RECORDS IN MESA PITS			TEMPERATURE CONTROL			TEMPERATURE CONTROL						
		SOOT AREA	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC	TRIC	ELEC-TRIC		
1	1																			
2	1																			
15	1																			
220	1																			
221	1																			
5-15	1																			
5-16	1																			
5-17	1																			
5-18	1																			
5-19	1																			
5-20	1																			
5-21	1																			
TOTAL																				

REMARKS:

BOILER EFFICIENCY: 60%

COAL

ADJUSTED UNIT HEAT - Restricted Area

BY THE NO.	NEW IMMERATION			WELL IMMERSION			RESEARCH 88 AREA FROM			MEASURED SURFACE 309			TEMPERATURE CONTROL		
	WATER-TRAP-VAL	ELEC-TAIC	PER-FEET	WELL-TIME-VAL	ELEC-TAIC	PER-FEET	CLASS-AREA	WATER-VAL	ELEC-TAIC	PER-FEET	FLOOR-AREA	WATER-VAL	ELEC-TAIC	PER-FEET	
24	54			1771	56.2	12.1	.0257	575	47.3	16.2	1324	2834	22.7	0.111	
50	56			6008	336.0	20.0	.0158	595	117.0	25.5	1523	12298	13.0	0.116	
50	50			30898	427.0	27.0	.0226	3738	338.0	22.0	1431	35639	106.9	0.118	
65	54			2501	36.5	7.0	.0292	500	42.5	18.3	1436	8718	50.0	0.116	
07	54			1870	42.1	3.4	.0255	279	31.0	12.2	1622	2320	17.1	0.116	
00	50			2828	59.5	8.0	.0256	379	44.7	17.4	1630	9900	31.0	0.116	
171	56			909	10.2	2.4	.0237	122	10.2	5.6	1421	1600	17.0	0.116	
172	50			3133	10.7	2.5	.0255	881	55.0	20.7	1574	3095	61.0	0.116	
200	54			8901	800.5	16.6	.0246	620	62.2	17.0	1411	3130	17.1	0.116	
201	50			7746	170.0	20.3	.0245	1122	111.2	21.0	1410	18370	152.2	0.116	
600	54			5001	173.7	17.7	.0256	646	89.5	20.9	1039	18099	117.0	0.116	
452	54			5240	120.0	16.0	.0256	703	90.0	25.0	1433	10000	106.5	0.116	
454	54			4120	130.6	10.5	.0256	586	156.0	20.5	1614	11362	121.1	0.116	
658	50			1279	20.2	6.0	.0256	102	22.5	9.0	1615	2208	25.0	0.116	
662	50			1165	26.0	3.3	.0255	171	28.1	7.0	1631	2236	23.0	0.116	
670	50			2176	55.2	7.5	.0257	337	42.1	16.6	1038	4672	69.0	0.116	
511	54			416	9.2	3.2	.0260	60	7.0	2.7	1626	789	0.1	0.117	
675	56			218	6.7	0.8	.0230	22	5.0	1.9	1607	367	5.0	0.116	
ADJUSTED				76201	1737.6	210.0	0.024	1012	2294.0	202.0	2192	34222	1228	11.1	0.116

Continued on Next Page

WIPARK-1

UNIT STATUS AREA DESPT - Restricted Area Contained VENT. Coas										COOLING EFFICIENCY: 600																													
LOC. NO.	TYPE OF BUILDING	ROOF INSULATION					WALL INSULATION					FLOORING TO MEAS STDS					TEMPERATURE CONTROL																						
		MEAS- THER- MAL	MEAS- ELEC- TRIC	MEAS- STRE- NGTH	MEAS- PER- FT	MEAS- PER- FT	MEAS- THER- MAL	MEAS- ELEC- TRIC	MEAS- STRE- NGTH	MEAS- PER- FT	MEAS- PER- FT	MEAS- THER- MAL	MEAS- ELEC- TRIC	MEAS- STRE- NGTH	MEAS- PER- FT	MEAS- PER- FT	MEAS- THER- MAL	MEAS- ELEC- TRIC	MEAS- STRE- NGTH	MEAS- PER- FT	MEAS- PER- FT																		
176	1	7680	1277.0	290.0	0/A	1012	1294.0	502.0	0/A	131229	1534.7	411.2	M/A	701	0.1	2.6	0.137	992	10.5	2.2	0.135	20218	238.0	72.7	0.136	2096	10.0	2.7	0.136	2160	15.0	10.1	0.116						
177	5	412	0.5	1.3	0.268	58	7.0	2.7	1.616																														
190	3	524	11.0	1.6	0.238	76	8.0	3.0	1.605																														
198	3	23866	291.0	20.0	0.236	1024	310.2	04.0	1.614																														
200	3	1510	34.0	8.7	0.256	221	26.0	10.2	1.608																														
24	3	1781	60.2	5.0	0.256	257	28.2	11.0	1.625																														
TOTAL		33302	2110.0	302.2	M/A	17600	1505.2	614.7	M/A	376194	2070.7	520.7	M/A																										

1948-1951

ANNISTON ARMY AMMUNITION DEPOT - (EAST END)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSUMED MBTU YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED KWH YEARLY TOTAL (KWH x 0.0116)				
	1	2	3	4	5	1	2	3	4	5
0	7,549	234.8	-	150.2	195.2	1451.2	-	1276.5	1221.2	-
TOTALS/ (1)	.0311	-	-	.0252	.0259	.1925	-	.1691	.1691	.1691
4	35,227	770.5	535.9	620.4	704.5	3163.4	3163.4	3163.4	-	1163.4
TOTALS/ (1)	.0221	.0152	.0196	-	.0209	.0898	.0898	.0898	-	.0898
5	29,732	690.9	-	-	327.1	11515.4	-	-	-	10003.8
TOTALS/ (1)	.1729	-	-	-	.0110	.3673	-	-	-	.3165
6	29,317	671.6	-	-	322.5	11254.2	-	-	-	9865.2
TOTALS/ (1)	.0229	-	-	-	.0110	.3673	-	-	-	.3165
7	4,291	145.3	89.1	122.3	147.2	119.9	150.0	150.0	150.0	150.0
TOTALS/ (1)	.0339	.0208	.0208	.0205	.0363	.0277	.0370	.0370	.0370	.0370
8	30,232	1024.9	620.0	661.6	1037.0	637.6	1110.6	1110.6	1118.6	1100.6
TOTALS/ (1)	.0339	.0208	.0208	.0343	.0277	.0370	.0370	.0370	.0370	.0370
1	13,702	300.6	209.3	270.1	-	275.6	1237.6	1237.6	-	1237.6
TOTALS/ (1)	.0221	.0152	.0196	-	.0206	.0898	.0898	.0898	-	.0898
2	34,053	752.8	517.6	667.4	-	601.1	3050.0	3050.0	-	3050.0
TOTALS/ (1)	.0221	.0152	.0196	-	.0209	.0898	.0898	.0898	-	.0898
3	34,053	752.6	517.6	667.4	-	601.1	3050.0	3050.0	-	3050.0
TOTALS/ (1)	.0221	.0152	.0196	-	.0209	.0898	.0898	.0898	-	.0898
4	38,260	1066.5	733.6	945.9	-	865.2	4333.7	4333.7	-	4333.7
TOTALS/ (1)	.0221	.0152	.0196	-	.0209	.0898	.0898	.0898	-	.0898

ADMINISTRATIVE ARMY ACQUISITION DEPOT - (EAST BAY)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSUMED MBTU YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED MBTU YEARLY TOTAL (MBTU = KWH x 0.0116)				
	1	2	3	4	5	1	2	3	4	5
2,609	57.7	39.7	51.1	-	52.2	234.3	234.3	234.3	-	234.3
TOTALS/ (f)	.0221	.0152	.0196	-	.0200	.0898	.0898	.0898	-	.0898
30,232	1034.9	620.0	861.6	1037.0	837.6	1110.6	1110.6	1110.6	1110.6	1110.6
TOTALS/ (f)	.0319	.0200	.0285	.0303	.0277	.0370	.0370	.0370	.0370	.0370
36,310	2122.5	1463.0	1892.7	-	1927.6	8651.0	8651.0	8651.0	-	8651.0
TOTALS/ (f)	.0271	.0152	.0196	-	.0200	.0898	.0898	.0898	-	.0898
36,310	2122.5	1463.0	1892.7	-	1927.6	8651.0	8651.0	8651.0	-	8651.0
TOTALS/ (f)	.0221	.0152	.0196	-	.0200	.0898	.0898	.0898	-	.0898
36,310	2122.5	1463.0	1892.7	-	1927.6	8651.0	8651.0	8651.0	-	8651.0
TOTALS/ (f)	.0221	.0152	.0196	-	.0200	.0898	.0898	.0898	-	.0898
8,705	270.5	-	-	219.0	225.5	1675.6	-	1471.0	1409.0	1409.0
TOTALS/ (f)	.0311	-	-	.0252	.0259	.1925	-	.1691	.1619	.1619
11,291	351.2	-	-	284.5	292.4	2177.5	-	1909.3	1820.0	1820.0
TOTALS/ (f)	.0311	-	-	.0252	.0259	.1925	-	.1691	.1619	.1619
91,910	3122.2	1908.2	2621.9	3151.0	2542.4	3390.7	3390.7	3390.7	3193.7	3190.7
TOTALS/ (f)	.0319	.0288	.0285	.0303	.0277	.0370	.0370	.0370	.0370	.0370
3,180	116.6	70.3	96.3	115.9	93.6	125.1	125.1	125.1	125.1	125.1
TOTALS/ (f)	.0119	.0208	.0285	.0162	.0277	.0370	.0370	.0370	.0370	.0370

ARMISTICE ARMY AMMUNITION DEPOT - (EAST END)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSUMED MBTU YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED MBTU YEARLY TOTAL (MBTU x 0.0116)				
	1	2	3	4	5	1	2	3	4	5
36,620	902.4	553.7	758.7	913.1	737.4	984.9	984.9	984.9	984.9	984.9
TOTALS/	.0139	.0208	.0205	.0343	.0277	.0370	.0370	.0370	.0370	.0370
14,010	476.9	391.4	399.3	480.5	300.1	510.4	510.4	510.4	510.4	510.4
TOTALS/	.0139	.0208	.0205	.0343	.0277	.0370	.0370	.0370	.0370	.0370
255,657	7694.3	4863.2	6084.2	7881.4	6302.4	13113.4	13113.4	13113.4	13113.4	13113.4
TOTALS/	.0341	.0216	.0305	.0349	.0279	.0501	.0501	.0501	.0501	.0501
5,193	176.0	108.0	140.0	170.1	143.0	192.1	192.1	192.1	192.1	192.1
TOTALS/	.0319	.0208	.0205	.0343	.0377	.0370	.0370	.0370	.0370	.0370
55,060	924.0	-	-	-	646.0	1454.3	-	-	-	1454.3
TOTALS/	.0160	-	-	-	.0154	.0264	-	-	-	.0264
27,500	463.5	-	-	-	424.9	728.3	-	-	-	728.3
TOTALS/	.0160	-	-	-	.0154	.0264	-	-	-	.0264
10,077	301.6	209.6	287.2	345.6	279.1	372.0	372.0	372.0	372.0	372.0
TOTALS/	.0139	.0208	.0205	.0343	.0277	.0370	.0370	.0370	.0370	.0370
14,400	480.2	299.5	410.4	493.9	198.9	532.0	532.0	532.0	532.0	532.0
TOTALS/	.0139	.0208	.0205	.0343	.0277	.0370	.0370	.0370	.0370	.0370
41,200	725.0	-	-	-	665.3	1140.5	-	-	-	1140.5
TOTALS/	.0160	-	-	-	.0154	.0264	-	-	-	.0264
61,004	3125.5	-	-	-	2402.6	2739.3	-	-	-	2739.3
TOTALS/	.0512	-	-	-	.0407	.0449	-	-	-	.0449

ARLINGTON ARMY ASSIGNMENT DEPOT - (MOST END)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSUMED MBTU YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED MBTU YEARLY TOTAL (NETU - KWHR @ 0.0116)				
	1	2	3	4	5	1	2	3	4	5
13,606	507.1	-	-	608.8	414.6	1635.1	-	-	1541.0	1433.0
TOTALS/()	.0402	-	-	.0324	.0329	.1289	-	-	.1064	.1137
10,536	423.5	-	-	361.4	346.6	1358.1	-	-	1121.0	1197.9
TOTALS/()	.0402	-	-	.0324	.0329	.1289	-	-	.1064	.1137
852	46.6	33.3	36.0	37.5	37.4	228.1	228.1	228.1	228.1	228.1
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677
14,732	805.8	576.0	621.7	608.2	606.7	3043.8	3943.8	3943.8	3943.8	3943.8
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677
17,974	981.2	702.0	758.5	790.9	789.1	4811.6	4811.6	4811.6	4811.6	4811.6
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677
54,332	2066.0	-	-	-	1541.7	9919.4	-	-	-	8788.8
TOTALS/()	.0380	-	-	-	.0284	.1026	-	-	-	.1618
1,892	101.5	74.0	79.8	83.2	83.1	506.5	506.5	506.5	506.5	506.5
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677
1,492	101.5	74.0	79.8	83.2	83.1	506.5	506.5	506.5	506.5	506.5
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677
6,440	352.3	251.8	271.0	283.6	282.7	1724.0	1724.0	1724.0	1724.0	1724.0
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677
1,709	93.8	66.5	71.7	74.8	74.6	455.1	455.1	455.1	455.1	455.1
TOTALS/()	.0547	.0391	.0422	.0440	.0439	.2677	.2677	.2677	.2677	.2677

ARMISTICE ARMY AMBULANCE DEPOT - (WEST END)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSIDERED NETO YEARLY TOTAL						BLDG. ELECTRICAL ENERGY CONSUMED NETO YEARLY TOTAL. (NETU = KWH x 0.0116)				
	1	2	3	4	5	6	1	2	3	4	5
16,304		896.1	641.0	691.3	721.2	720.0	4385.3	4385.3	4385.3	4385.3	4385.3
TOTALS/ ()	.0547	.0391	.0422	.0440	.0439	.0439	.2677	.2677	.2677	.2677	.2677
40,567	2219.0	1586.2	1711.9	1704.9	1780.9	1780.9	10859.0	10859.0	10859.0	10859.0	10859.0
TOTALS/ ()	.0547	.0391	.0422	.0440	.0439	.0439	.2677	.2677	.2677	.2677	.2677
40,567	2219.0	1586.2	1711.9	1704.9	1780.9	1780.9	10859.0	10859.0	10859.0	10859.0	10859.0
TOTALS/ ()	.0547	.0391	.0422	.0440	.0439	.0439	.2677	.2677	.2677	.2677	.2677
352	13.0	9.9	10.6	11.1	11.1	11.1	67.5	67.5	67.5	67.5	67.5
TOTALS/ ()	.0507	.0391	.0422	.0440	.0439	.0439	.2677	.2677	.2677	.2677	.2677
30,000	548.3	-	-	417.4	448.0	448.0	7146.0	-	-	6579.0	6717.4
TOTALS/ ()	.0183	-	-	.0137	.0150	.0150	.2302	-	-	.2193	.2239
10,950	1036.6	740.9	799.7	833.8	831.9	831.9	5072.9	5072.9	5072.9	5072.9	5072.9
TOTALS/ ()	.0547	.0391	.0422	.0440	.0439	.0439	.2677	.2677	.2677	.2677	.2677
6,567	266.0	-	-	212.8	215.1	215.1	846.5	-	-	690.7	746.7
TOTALS/ ()	.0402	-	-	.0324	.0329	.0329	.1209	-	-	.1064	.1137
5,954	239.4	-	-	192.9	195.9	195.9	767.5	-	-	633.5	677.0
TOTALS/ ()	.0402	-	-	.0324	.0329	.0329	.1209	-	-	.1064	.1137
10,121	406.9	-	-	327.9	333.0	333.0	1304.6	-	-	1076.9	1150.0
TOTALS/ ()	.0402	-	-	.0324	.0329	.0329	.1209	-	-	.1064	.1137

WHEELSTON ARMY AMMUNITION DEPOT - (WEST END)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSUMED NETS YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED NETS YEARLY TOTAL (NETS - kWh x 0.0116)				
	1	2	3	4	5	1	2	3	4	5
243,760	8861.6	-	-	7535.8	7854.1	14987.8	-	-	14172.41	14351.2
TOTALS/(\$)	.0364	-	-	.0309	.0322	.0613	-	-	.0581	.0589
12,800	293.1	-	-	-	-	4957.4	-	-	-	-
TOTALS/(\$)	.0229	-	-	-	-	.3873	-	-	-	-
4,500	180.9	-	-	145.8	146.1	580.1	-	-	478.8	511.7
TOTALS/(\$)	.0402	-	-	.0324	.0329	.1209	-	-	.1064	.1137
4,500	180.9	-	-	145.8	146.1	580.1	-	-	478.8	511.7
TOTALS/(\$)	.0402	-	-	.0324	.0329	.1209	-	-	.1064	.1137
15,422	429.8	-	-	499.7	507.4	1987.9	-	-	1640.1	1751.5
TOTALS/(\$)	.0402	-	-	.0324	.0329	.1209	-	-	.1064	.1137
2,800	112.6	-	-	90.7	92.1	360.9	-	-	227.9	318.4
TOTALS/(\$)	.0402	-	-	.0324	.0329	.1209	-	-	.1064	.1137
5,720	229.9	-	-	185.3	198.2	737.3	-	-	608.6	658.4
TOTALS/(\$)	.0402	-	-	.0324	.0329	.1209	-	-	.1064	.1137
4,518	182.6	-	-	146.8	148.6	582.4	-	-	480.7	513.7
TOTALS/(\$)	.0402	-	-	.0324	.0329	.1209	-	-	.1064	.1137
TOTAL	676,907	202,782	202,782	532,773	614,197	626,207	202,769	202,769	559,775	614,107
WAPS	26,986.2	7,928.8	8,556.6	19,571.2	21,881.2	102,022.6	54,200.7	54,200.7	83,881.1	91,801.7
TOTALS/(\$)	0.047	0.019	0.0477	0.015	0.015	0.163	0.268	0.268	0.150	0.157

ARMISTON ARMY AMMUNITION DEPOT - (RESTRICTED AREA)

BLDG. SQ. FT.	BLDG. TRIMENAL ENERGY CONSUMED KWH YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED KWH YEARLY TOTAL (KWHU - KWH x 0.016)				
	1	2	3	4	5	1	2	3	4	5
7,494	247.5	-	193.3	267.1	199.5	715.9	-	703.0	689.7	691.2
TOTALS/()	.0730	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
12,998	420.9	-	315.3	350.7	345.7	1241.3	-	1220.5	1195.0	1202.3
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
35,659	1176.7	-	920.6	986.2	940.5	3405.6	-	3348.4	3280.6	3290.5
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
4,718	155.7	-	121.7	130.2	125.5	450.6	-	443.0	434.1	436.4
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
3,528	116.4	-	91.0	97.4	93.0	316.9	-	311.3	324.6	326.3
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
4,960	163.7	-	120.0	136.9	131.9	473.7	-	465.7	456.3	450.0
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
1,600	52.0	-	41.3	46.2	42.5	152.0	-	150.2	147.2	148.0
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
3,095	194.5	-	152.1	162.7	156.0	563.0	-	553.5	542.3	545.1
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
9,134	301.6	-	235.7	252.3	243.0	872.3	-	857.7	840.1	844.9
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
10,576	401.1	-	376.2	402.4	387.0	1392.2	-	1360.9	1341.2	1340.5
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925

ADMINISTRATIVE ENERGY CONSUMPTION DEPT - (RESTRICTED AREA)

BLDG. SQ. FT.	BLDG. THERMAL ENERGY CONSUMED MBTU YEARLY TOTAL					BLDG. ELECTRICAL ENERGY CONSUMED MBTU YEARLY TOTAL (MBTU = kWh x 0.0116)				
	1	2	3	4	5	1	2	3	4	5
11,059	364.9	-	265.3	305.2	294.2	1056.1	-	1030.4	1017.4	1021.0
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
10,000	330.0	-	250.6	276.0	266.0	955.0	-	939.0	920.0	925.0
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
11,562	381.5	-	298.3	319.1	307.5	1104.2	-	1085.7	1061.7	1069.5
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
2,500	82.0	-	64.7	69.2	66.7	239.5	-	235.5	230.7	232.0
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
2,236	73.0	-	57.7	61.7	59.5	213.5	-	210.0	205.7	206.0
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
4,672	154.2	-	120.5	130.9	124.3	446.2	-	438.7	429.0	432.2
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
781	25.0	-	20.1	21.6	20.8	76.6	-	71.3	71.9	72.2
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
547	18.1	-	14.1	15.1	14.6	52.2	-	51.6	50.3	50.6
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
701	25.0	-	20.1	21.6	20.8	74.6	-	73.3	71.9	72.2
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925
952	32.7	-	35.6	27.4	26.4	94.7	-	93.1	91.3	91.8
TOTALS/()	.0330	-	.0250	.0276	.0266	.0955	-	.0919	.0920	.0925

APPENDIX C
LIST OF REPORTS

LIST OF REPORTS

ENERGY USE SURVEY

Narrative - Volume I, Section 3

Supporting Data - Volume II & III

ENERGY MONITORING AND CONTROL SYSTEMS

Narrative - Volume I, Section 4

Supporting Data - Volume II

BIOMASS SURVEY

Narrative - Volume I, Section 5

Supporting Data - Volume III

CENTRAL BOILER PLANTS

Narrative - Volume I, Section 6

Supporting Data - Volume III

BASEWIDE ENERGY PLAN RECOMMENDATIONS

Narrative - Volume I, Section 7

ECIP PROJECT BROCHURES

Narrative - Volume I, Section 8