



19971016 228

DISTRIBUTION STATEMENT A

Approved for public release;
Distribution Unlimited

Enc 1 3

DTIC QUALITY INSPECTED 2




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.



A handwritten signature in black ink, appearing to read "Marie Wakefield".

Marie Wakefield,
Librarian Engineering

FINAL REPORT
EXECUTIVE SUMMARY
INCREMENT A AND B STUDY
AT
ABERDEEN PROVING GROUNDS, MARYLAND

Prepared for:

Department of the Army
Norfolk District, Corps of Engineers
Norfolk, Virginia 23510

Under Contract No. DACA-65-84-C-0105

March 1988

B.N. Gidwani, P.E.
Project Manager

ROY F. WESTON, INC.
Weston Way
West Chester, Pennsylvania 19380

W.O. #0335-72-01/02

TABLE OF CONTENTS

| <u>SECTION</u> | | <u>PAGE</u> |
|--------------------------------|-----------------------------------|-------------|
| <u>Aberdeen Area</u> | | |
| | <u>Executive Summary</u> | |
| 1.1 | Introduction | ES-1 |
| 1.2 | Historical Energy Consumption | ES-1 |
| 1.3 | Special Instructions | ES-2 |
| 1.4 | Findings | ES-3 |
| 1.5 | Recommended Projects | ES-21 |
| <u>Volume I: Survey Report</u> | | |
| | Table of Contents | i |
| 1 | Introduction | 1-1 |
| 2 | ECO's Investigated and ECO Matrix | 2-1 |
| 3 | Building Survey Forms | 3-1 |

TABLE OF CONTENTS (Continued)

| <u>Section</u> | | <u>Page</u> |
|------------------------------------|---|-------------|
| <u>Volume II: ECO Calculations</u> | | |
| | Table of Contents | 1 |
| 1 | Basis of Analysis | 1-1 |
| 2 | ECO's Investigated | |
| | ECO 2.1 Install Light Motion Sensors | 2-1 |
| | ECO 2.2 Install Thermostat and Control Valves in Building 670 | 2-2 |
| | ECO 2.3 Solar Films | 2-7 |
| | ECO 2.4 Window Weatherization | 2-8 |
| | ECO 2.5 Insulate Low Leakage Doors in Building 670 | 2-17 |
| | ECO 2.6 Infrared Heaters | 2-29 |
| | ECO 2.7 Destratification of High Bay Areas | 2-33 |
| | ECO 2.8 Improve Power Factor | 2-62 |
| | ECO 2.9 Centralized Chiller Plant | 2-63 |
| | ECO 2.10 Reduced Lighting Levels | 2-64 |
| | ECO 2.11 Replace Incandescent with Energy-Saving Fluorescent Lighting | 2-71 |
| | ECO 2.12 Replacing Existing Fluorescent Lamps with Energy-Saving Fluorescents | 2-77 |
| | ECO 2.13 Replace Existing Incandescent with HPS Lighting | 2-84 |
| | ECO 2.14 Upgrade HVAC Controls in Building 390 and 393 | 2-95 |

TABLE OF CONTENTS (CONTINUED)

| <u>Section</u> | | <u>Page</u> |
|----------------|---|-------------|
| | ECO 2.15 Expand EMCS to Include Night Setback | 2-101 |
| Appendix A | Scope of Work | A-1 |
| Appendix B | Response to Review Comments | B-1 |
| Appendix C | Computer Modelling Results | C-1 |

TABLE OF CONTENTS (Continued)

| <u>SECTION</u> | | <u>PAGE</u> |
|--------------------------------|-----------------------------------|-------------|
| <u>Edgewood Area</u> | | |
| <u>Executive Summary</u> | | |
| 1.1 | Introduction | ES-1 |
| 1.2 | Historical Energy Consumption | ES-1 |
| 1.3 | Special Instructions | ES-2 |
| 1.4 | Findings | ES-3 |
| 1.5 | Recommended Projects | ES-21 |
| <u>Volume I: Survey Report</u> | | |
| Table of Contents i | | |
| 1 | Introduction | 1-1 |
| 2 | ECO's Investigated and ECO Matrix | 2-1 |
| 3 | Building Survey Forms | 3-1 |

SECTION 1

EXECUTIVE SUMMARY

1.1 INTRODUCTION

This report presents the results of the Energy Engineering Analysis Program conducted by Roy F. Weston, Inc. at the Aberdeen and Edgewood Areas of Aberdeen Proving Grounds under Contract No. DACA-65-84-C-0105. The study includes identification and evaluation of specific energy conservation opportunities that are applicable to the 44 buildings at Aberdeen and Edgewood.

The Increments of Work to be provided as stated in the Scope of Work:

Increment A - Projects involving modifying, improving or retrofitting existing buildings to make them more energy efficient.

Increment B - Energy conservation investigations of utilities and energy distribution systems, and energy monitoring and control systems (EMCS).

The study involved field surveying the various buildings to find out the present operating conditions and schedules, and to identify energy conservation opportunities that may be applicable. Detailed calculations were performed to evaluate the opportunities and package them into QRIP/PECIP projects.

1.2 HISTORICAL ENERGY CONSUMPTION

The annual fuel consumption at Aberdeen and Edgewood for FY 1985 (October 1984 to September 1985) was:

- Annual Electric Consumption at Aberdeen - 86,823,988 kWh
- Annual Electric Consumption at Edgewood - 60,406,319 kWh
- Total Electric Consumption at Base - 147,230,307 kWh
- Annual Fuel Oil Consumption at Aberdeen - 5,284,904 Gallons
- Annual Fuel Oil Consumption at Edgewood - 7,649,696 Gallons

- Total Fuel Oil Consumption at Base - 12,934,600 Gallons

The average fuel oil cost for FY 1985 was 0.95 per gallon.

The latest electric consumption and cost data available for the Aberdeen and Edgewood areas is for the year beginning in October of 1984 and continuing through September of 1985. Electricity is supplied to the base by four utility companies - Baltimore Gas and Electric Company, Delmarva Power Company, Conowingo Power Company and Choptank Electric Cooperative, Inc. In FY 1985 a total of 147,230,307 kWh of electricity was consumed at Aberdeen and Edgewood, costing \$7,398,316.22. This results in an average electric cost of \$0.05/kWh which was used in this report.

For FY 1984 (October 1983 to September 1984) the total consumption of fuel oil and electricity was:

- Annual Electric Consumption at Aberdeen - 82,884,291 kWh
- Annual Electric Consumption at Edgewood - 58,579,513 kWh
- Total Electric Consumption at Base - 141,463,804 kWh
- Annual Fuel Oil Consumption at Aberdeen - 6,319,126 Gallons
- Annual Fuel Oil Consumption at Edgewood - 8,953,330 Gallons
- Total Fuel Oil Consumption at Base - 15,272,456 Gallons

Fuel oil consumption for FY 1985 was 18.1% lower than for FY 1984 and electric consumption for FY 1985 was 4.1% higher than for FY 1984.

In comparison fuel oil consumption for FY 1984 was 10.76% higher than for FY 1983 and electric consumption was up 6.59% over FY 1983.

1.3 SPECIAL INSTRUCTIONS

Since the scope of work was written for a base-wide study and this study includes only a few buildings at the base, some items were deleted from the scope of work. This includes:

- (i) Paragraph 2.5 Future Population
- (ii) Paragraph 6.2.4 Information on Meters
- (iii) Paragraph 6.3.1 Distribution Systems
- (iv) Paragraph 6.3.4 EMCS Study, which was deleted from the scope of work by the post.

It was established that three buildings will be computer modelled, using the Carrier E20-II program. These are buildings 2353, E1930 and E5185, which have the highest annual energy savings.

The "expected lives" of the buildings used for the life cycle cost analysis were obtained from the Building Information Schedules (BIS) and verified by the post.

1.4 FINDINGS

The work done was performed in two phases. The first phase involved site visits and data collection on the various buildings. The data collected included drawings and building information schedule (BIS). Site visits were performed to collect information on cooling and heating equipment, lighting type, lighting levels, operating schedules and function of the building. Conversations and interviews were conducted with the building administrators to gain an insight into the operation of the building and to help in identifying energy conservation opportunities (ECO's). All information collected was used to identify the various ECO's applicable. The second phase involved evaluation of the various energy conservation opportunities and life cycle cost analysis.

A list of Energy Conservation Opportunities (ECO's) to be investigated is contained in Table 1-1. This list along with previous energy conservation retrofit experience, and observations and data obtained from site visits provided a basis for a list of ECO's to be quantitatively analyzed. The opportunities involved are:

- Wall Insulation
- Window Weatheriztion
- Weatherstripping
- Upgrading EMCS
- Infrared Heaters
- Destratification
- Return Condensate
- Reduce Lighting Levels
- High Efficiency Lighting

- Improve Power Factor
- Revise/Repair HVAC Controls
- Low Leakage Rolling Doors
- Light Motion Sensors
- Centralized Chiller Plant
- Expand EMCS to Include Night Setback

After analysis of the above ECO's, life cycle cost analysis was performed to calculate their SIR values. Tables 1.2 and 1.3 summarize the results of the ECO's evaluated for the Aberdeen and Edgewood areas. Projects having SIR value less than 1.2 are not recommended per directions from the post. The tables show the total savings for projects having SIR greater than 1 and 1.2.

| Building Envelope | | Heating | | | | | | | | | | | | | | | Remarks | | | |
|-------------------|--|---------------------------|--|--|--|--|--|--|--|--|--|--|--|--|--|--|---------------------|--|--|--|
| | | DHW | | | | | | | | | | | | | | | | | | |
| Building No. | Location: Aberdeen Proving Grounds, Edgewood Area | Shutdown Hot Water Heater | | | | | | | | | | | | | | | Very Sensitive Area | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |
| | | Shutdown Hot Water Heater | | | | | | | | | | | | | | | | | | |

| ENERGY CONSERVATION OPPORTUNITIES | | Building No. | Remarks | Very Sensitive Area | Sentry Station | Being Renovated |
|-----------------------------------|---------------------------------|--------------|---------|---------------------|----------------|-----------------|
| Category | Opportunity Description | | | | | |
| Air-Conditioning | Centralized CHW Plant | E1930 | | | | |
| | Convert to VAV System | E2100 | | | | |
| | D/C, Unocc. Control | E2101 | | | | |
| | Duty Cycling | E3081 | ● ▲ | | | |
| | Demand Limiting | E3100 | ● | | | |
| | Economizer Cycle | E3160 | ● | | | |
| | Heat Reclaim From Hot Ret. Gas | E3220 | ● | | | |
| | High Efficiency Lighting Level | E3222 | | | | |
| | Improve Energy Efficiency Motor | E3226 | ● | | | |
| | F.M. Radio Power Factor | E3244 | ● | | | |
| | Optimize Transformer Loss | E3300 | ● | | | |
| | Revise Transformer Light | E3550 | ● | | | |
| | EMCS | E3580 | | | | |
| | Reduce Street HVAC Controls | E3725 | | | | |
| | Improve Exhaust System | E3728 | | | | |
| | Thermal Barrier for Food Cases | E5100 | ● | | | |
| Lighting and Electrical | Revise Transformer Loss | | | | | |
| Misc. | | | | | | |

Legend

- Retrofit to be Investigated by WESTON
- ▲ Retrofit Implemented or Being Implemented by Post
- Retrofit Investigated by WESTON for Boiler Plant/Chiller Plant Study
- △ Retrofit Investigated by JRB Assoc.
- Current ECIP Project

Location: Aberdeen Proving Grounds,
Edgewood Area

TABLE 1.1.1 (CONTINUED)

WESTON
COMPAÑIA

ENERGY CONSERVATION OPPORTUNITIES

Building Envelope

Location: Aberdeen Proving Grounds,
Edgewood Area

Retracted by Weston

- Retrill to be Investigated by WESTON
 - ▲ Retrill Implemented or Being Implemented by Post
 - Retrill Investigated by WESTON
 - ▶ Boiler Plant/Chiller Plant Study
 - ▶ Retrill Investigated by JRB Assoc.
 - ▶ Current EICIP Project

TABLE 1.1 (CONTINUED)

ENERGY CONSERVATION OPPORTUNITIES

TABLE 1.1 (CONTINUED)

| ENERGY CONSERVATION OPPORTUNITIES | | Building No. | Remarks | | | | | | | | | | | | | |
|-----------------------------------|-----------------------------|--------------|---------|---|---|---|---|---|---|---|---|---|---|---|---|---|
| Building Envelope | Heating | | | | | | | | | | | | | | | |
| • Roof/Ceiling Insulation | △ Low Leakage Rolling Doors | 120 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Storm Windows/Double Glazing | ● Plastic Strip Doors | 309 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Weatherstripping/Panels | ● Radiator Controls | 316 | E | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● High-Res Heat Traps | 321 | △ | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Decentralize DHW Heaters | 328 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Boiler Trim Controls | 390 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Insulate DHW Lines | 393 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Return Heat Pumps | 394 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Shower Heat Pumps | 400 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Shutdown Hot Water Heater | 436 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Insulate Steam Lines | 670 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● DHW Heat Exchangers | 699 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● Return Flow Restrictor | 700 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● DHW Heat Exchangers | 745 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● DHW Heat Exchangers | 2353 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |
| • Vestibules | ● DHW Heat Exchangers | 2501 | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● | ● |

Location: Aberdeen Proving Grounds,
Aberdeen Area




Table 1.1 ENERGY CONSERVATION OPPORTUNITIES MATRIX

| ENERGY CONSERVATION OPPORTUNITIES | | Building No. | Building Description | | | | | | | | | | | | | | | |
|--|--|--------------|----------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|------|
| | | | 120 | 309 | 316 | 321 | 328 | 390 | 393 | 394 | 400 | 436 | 670 | 699 | 700 | 745 | 2353 | 2501 |
| Legend | | | | | | | | | | | | | | | | | | |
| ● | Retrofit Implemented by WESTON | | | | | | | | | | | | | | | | | |
| ▲ | Retrofit Implemented or Being Investigated by Post | | | | | | | | | | | | | | | | | |
| ■ | Retrofit Investigated by WESTON for Boiler Plant/Chiller Plant Study | | | | | | | | | | | | | | | | | |
| △ | Retrofit Investigated by JRB Assoc. | | | | | | | | | | | | | | | | | |
| E | Current ECIP Project | | | | | | | | | | | | | | | | | |
| Location: Aberdeen Proving Grounds, Aberdeen Area | | | | | | | | | | | | | | | | | | |
| Centralized CHW Plant | | | | | | | | | | | | | | | | | | |
| Convert to VAV System | | | | | | | | | | | | | | | | | | |
| Duty Cycling | | | | | | | | | | | | | | | | | | |
| Demand Limiting | | | | | | | | | | | | | | | | | | |
| Heat Recclaim From Hot Water | | | | | | | | | | | | | | | | | | |
| High Efficiency Lighting | | | | | | | | | | | | | | | | | | |
| Improve Lighting Level | | | | | | | | | | | | | | | | | | |
| FM Radio Control | | | | | | | | | | | | | | | | | | |
| Optimize HVAC Controls | | | | | | | | | | | | | | | | | | |
| Reduce Street Light | | | | | | | | | | | | | | | | | | |
| Revise/Replace HVAC Controls | | | | | | | | | | | | | | | | | | |
| EMCS | | | | | | | | | | | | | | | | | | |
| Heat Recovery-Compressor | | | | | | | | | | | | | | | | | | |
| Improve Exhaust System | | | | | | | | | | | | | | | | | | |
| Improve Barriers for Food Cases | | | | | | | | | | | | | | | | | | |
| Misc. | | | | | | | | | | | | | | | | | | |

Table 1.1 (CONTINUED)

| ENERGY CONSERVATION OPPORTUNITIES | | Remarks | | | | | | | | | | | | |
|-----------------------------------|--|---------|---------|--|-------|--|------------|--|-------|--|---------|--|--|--|
| Building No. | Location: Aberdeen Proving Grounds, Aberdeen Area | | Heating | | Water | | Electrical | | Waste | | Process | | | |
| 4024 | | | | | | | | | | | | | | |
| 4025 | | | | | | | | | | | | | | |
| 5043 | | | | | | | | | | | | | | |
| 5220 | | | | | | | | | | | | | | |
| 5221 | | | | | | | | | | | | | | |

Legend

- Retrofit Investigated by WESTON
- ▲ Retrofit Implemented or Being Implemented by Peat
- Retrofit Investigated by WESTON for Boiler Plant/Chiller Plant Study
- △ Retrofit Investigated by JRB Assoc.
- E Current EClP Project

Building Envelope

Storm/Ceiling Insulation
Roof/Ceiling Insulation
Reduce Glass Areas
Weatherstripping/Double Glazing
Insulation Panels
Solar Films
Vestibules
Low Leaking Vestibules
Plastic Strip Doors
Radiator Controls
Night Setback/Timed Clocks
Desratilize Heat Loss
Boiler Trim Controls
Revise Steam Lines
DHW Heat Exchangers
Return Condensate
Shower Pumps
Shutdown Hot Water Heater

Heating

Boiler Centralize DHW Heaters
Revise Trim Controls
Insulate Boiler Controls
Revised Steam Lines
DHW Heat Exchangers
Return Condensate
Revise Boiler Controls
Boiler Trim Controls
Revise Trim Controls
Insulate Steam Lines
DHW Heat Exchangers
Return Condensate
Shower Pumps
Shutdown Hot Water Heater

Remarks

Table 1.1 (CONTINUED)

ENERGY CONSERVATION OPPORTUNITIES

| ENERGY CONSERVATION OPPORTUNITIES | | Building No. | Location: Aberdeen Proving Grounds, Aberdeen Area | Legend | Centralized CHW Plant Connver to VAV System Dcc/Unicc Control Duty Cyclic Demand Limiting Heat Reclaim From Hot Ref. Gas High Efficiency Lighting FM Radio Power Factor Optimize Transformer Loss Revise/Replace HVAC Controls Reduce Kitchen Light EMCS Recovery-Commissary Thermal Barriers for Food Cases Misc. |
|-----------------------------------|-----------------------|--------------|--|--------|---|
| Opportunities | Implementation Status | | | | |
| Air-Conditioning | | 4024 | | ● | ● |
| Lighting and Electrical | | 4025 | | ● | ● |
| Misc. | | 5043 | | ● | ● |
| Heat Recovery-Commissary | | 5220 | | ● | ● |
| Thermal Barriers for Food Cases | | 5221 | | ● | ● |

Table 1.1 (CONTINUED)

**Location: Aberdeen Proving Grounds,
Aberdeen Area**

Legend

- Retrill Investigated by WESTON
- ▲ Retrill Implemented or Being Implemented by Post
- Retrill Investigated by WESTON for Boiler Plant/Chiller Plant Study
- △ Retrill Investigated by JRB Assoc.
- E Current ECIP Project

TABLE 1-2

SUMMARY OF EVALUATED ECO'S - ABERDEEN AREA

| <u>Opportunity</u> | <u>Annual Energy Savings</u> | | | <u>Annual Non-Energy Cost Savings (\$)</u> | <u>Unescalated Current Working Estimate (\$)</u> | <u>Simple Payback (Yrs)</u> | <u>SIR</u> |
|--|--|------------------------|---------------------|--|--|-----------------------------|------------|
| | <u>Electricity (MBTU)</u> | <u>Fuel Oil (MBTU)</u> | <u>Total (MBTU)</u> | | | | |
| ECO 2.1: Install Light Motion Sensors in Building 393 | 1,039.44 | ---- | 1,039.44 | 4,480 | 10,600 | 2.4 | 2.7 |
| ECO 2.2: Install Thermostat and Control Valve in Bldg. 670 | ---- | 124.4 | 124.4 | 860 | 484 | 0.56 | 12.7 |
| ECO 2.4: Window Weatherization (#436,670) | 265.50 | 265.50 | 265.50 | 1,835 | 8,457 | 4.60 | 1.23 |
| ECO 2.5: Insulated Low Leakage Rolling Doors | ---- | ---- | 45.75 | 45.75 | 316 | 9,693 | 30.70 |
| 15 x 18 Door | ---- | ---- | 45.75 | 45.75 | 316 | 9,693 | 30.70 |
| (2) 10 x 12 Door | ---- | 38.26 | 38.26 | 264 | 8,220 | 31.10 | 0.11 |
| ECO 2.6: Infrared eaters | (No cost savings even though there is energy savings.) | | | | | | |

TABLE 1-2 (CONTINUED)

SUMMARY OF EVALUATED ECO'S - ABERDEEN AREA

| <u>Opportunity</u> | <u>Annual Energy Savings</u> | | <u>Non-Energy Cost Savings (\$)</u> | <u>Unescalated Current Working Estimate (\$)</u> | | <u>Simple Payback (Yrs)</u> | <u>SIR</u> |
|--|-------------------------------------|----------------------------------|-------------------------------------|--|-------------|-----------------------------|------------|
| | <u>Electricity</u> <u>(MBTU)</u> | <u>Fuel Oil Total (MBTU)</u> | | <u>8,214</u> | <u>2.40</u> | | |
| ECO 2.7: Decentralization of High Bay Areas | | | | | | | |
| Building 2353: | -65.2 | 542.90 | 477.70 | 3,470 | 8,214 | 2.40 | 2.98 |
| Building 5943: | -214.1 | 635.10 | 421.00 | 3,467 | 23,770 | 6.90 | 1.01 |
| Building 5220: | -46.6 | 210.20 | 163.60 | 1,250 | 5,867 | 4.70 | 2.37 |
| Building 5221: | -46.6 | 210.20 | 163.60 | 1,250 | 5,867 | 4.70 | 2.37 |
| ECO 2.9: Centralized Chiller Plant (Building 120) | 531.5 | ---- | 531.50 | 2,290 | 80,000 | 34.90 | --- |
| ECO 2.10: Reduced Lighting Levels | | | | | | | |
| Building 5220: | 6.03 | ---- | 6.03 | 26 | 54 | 2.10 | 4.35 |
| Office No. 1 | 6.03 | ---- | 6.03 | 26 | 54 | 2.10 | 4.35 |
| Office No. 2 | 6.03 | ---- | 6.03 | 26 | 54 | 2.10 | 4.35 |
| Building 5221: | 6.03 | ---- | 6.03 | 26 | 54 | 2.10 | 4.35 |
| Office No. 1 | 6.03 | ---- | 6.03 | 26 | 54 | 2.10 | 4.35 |
| Office No. 2 | 6.03 | ---- | 6.03 | 26 | 54 | 2.10 | 4.35 |

TABLE I-2 (CONTINUED)
SUMMARY OF EVALUATED ECO'S - ABERDEEN AREA

| <u>Opportunity</u> | <u>Annual Energy Savings</u> | | | <u>Unescalated</u> | | |
|--|-------------------------------------|--|--|---|--|-------------------------------------|
| | <u>Electricity</u> <u>(MBTU)</u> | <u>Fuel Oil</u> <u>Total</u> <u>(MBTU)</u> | <u>Annual Savings</u> <u>(\$)</u> | <u>Non-Energy Cost Savings</u> <u>(\$)</u> | <u>Current Working Estimate</u> <u>(\$)</u> | <u>Simple Payback (Yrs)</u> |
| ICO 2.11: Replace Incandescent with Fluorescent Lighting | 71.70 | ---- | 71.70 | 744 | 1,031 | 1.40 |
| ICO 2.12: Replace fluorescent with energy-saving Fluorescent | 388.70 | ---- | 388.70 | 1,675 | 932 | 0.56 |
| ICO 2.13: Replace incandescent with HPS lighting | 65.63 | ---- | 65.63 | 283 | 1,630 | 5.8 |
| Building 699 | 51.53 | ---- | 51.53 | 222 | 2,685 | 12.1 |
| Building 700 | 535.64 | ---- | 535.64 | 2,309 | 9,782 | 4.2 |
| Building 2353 | 535.64 | ---- | 535.64 | 539 | 399 | 0.74 |
| ICO 2.14: Upgrade HVAC Controls in building 393 | 78.0 | 78.0 | 78.0 | 78.0 | 78.0 | 9.65 |
| ICO 2.15: Expand EMCS o Include Night Setback | ----- | ----- | ----- | ----- | ----- | ----- |
| Building 394 | ----- | 1,428.35 | 1,428.35 | 9,870 | 3,200 | 0.33 |
| Building 4025 | ----- | 244.56 | 244.56 | 1,552 | 3,970 | 2.60 |
| Totals (SIR>1.2) | 2,020.84 | 3,104.10 | 5,124.94 | 30,221 | ----- | 34.30 |
| Totals (SIR>1) | 1,806.74 | 3,739.20 | 5,145.94 | 33,688 | ----- | 4.15 |
| | | | | | 60,649 | |
| | | | | | 84,419 | |

TABLE 1-3
SUMMARY OF ECO'S EVALUATED - EDGEWOOD AREA

| <u>Opportunity</u> | <u>Annual Energy Savings</u> | | <u>Annual Savings (\$)</u> | Unescalated | | |
|---|-------------------------------------|--|----------------------------|--------------------------------------|-----------------------------|------------|
| | <u>Electricity</u> <u>(MBTU)</u> | <u>Fuel Oil Total</u> <u>(MBTU)</u> | | <u>Current Working Estimate (\$)</u> | <u>Simple Payback (Yrs)</u> | <u>SIR</u> |
| ECO 2.1: Wall Insulation | | | | | | |
| Applied to Plastic Wall (Building E1930) | ---- | 241.50 | 241.50 | 1,669 | 3,139 | 1.90 |
| Applied to Clay Tile Wall (Building E1930) | ---- | 227.90 | 227.90 | 1,575 | 13,526 | 8.60 |
| ECO 2.2: Window Weatherization | ---- | 1,924.40 | 1,924.40 | 13,298 | 61,747 | 4.60 |
| ECO 2.5: Replace incandescent with Fluorescent Lighting | 19.8 | ---- | 19.80 | 205 | 285 | 1.40 |
| ECO 2.8: Destratification of High Bay Areas | -31.1 | 300.80 | 269.70 | 1,944 | 3,520 | 1.80 |
| *ECO 2.10: Condensate Return | -338.7 | 13,412.40 | 13,073.70 | 91,220 | 714,000 | 7.80 |
| ECO 2.12: Reduced Lighting Levels | 71.7 | ---- | 71.70 | 309 | 518 | 1.70 |
| Total (SIR>1.2 or SIR>1) | -278.3 | 16,107.00 | 15,828.70 | 110,220 | 796,735 | |

*Note 1: This ECO was evaluated in an earlier study by JRB Associates. WESTON has updated numbers to utilize existing fuel costs.


Three buildings were modelled using the Carrier E20-II operating Cost Analysis program to predict the existing annual operating costs of the buildings HVAC and non-HVAC energy consuming systems.

Comparing this with the annual energy savings per building, gives the percent energy savings for each building. The results are summarized below:


| <u>Bldg. No.</u> | <u>Total Savings</u> Energy (MBTU) | <u>Cost</u> (\$) | <u>Computed</u> Annual Operating Cost (\$) | <u>Percent Cost</u> <u>Savings (%)</u> |
|------------------|--|---------------------|---|---|
| 2353 | 1013.3 | 5,779 | 17,417 | 33.2 |
| E1930 | 739.1 | 5,188 | 109,229 | 4.7 |
| E5185 | 1,924.4 | 13,298 | 83,662 | 15.9 |

Figures 1-1 through 1-3 present the existing and projected annual energy consumption for Buildings 2353, E1930 and E5185. The existing consumption figures show the percent energy used for electricity and fuel-oil. The projected consumption shows the future fuel-oil and electric consumption and savings if the recommended ECO's for that building are implemented.

FIGURE 1-1
EXISTING AND PROJECTED ANNUAL ENERGY CONSUMPTION FOR BUILDING 2353
(BASE = FY 1985)




A. EXISTING




B. PROJECTED

FIGURE 1-2
**EXISTING AND PROJECTED ANNUAL ENERGY
CONSUMPTION FOR BUILDING E1930
(BASE = FY 1985)**




A. EXISTING




B. PROJECTED

FIGURE 1-3
EXISTING AND PROJECTED ANNUAL ENERGY
CONSUMPTION FOR BUILDING E5185
(BASE = FY 1985)



A. EXISTING



B. PROJECTED

1.5 RECOMMENDED PROJECTS

Projects having SIR greater than 1.2 are grouped into one QRIP project, one PECIP project and one locally funded project. Two projects not included in the documentations are night setback and condensate return. Both these projects were documented as ECIP projects in an earlier study.

The projects recommended are:

PECIP Project #1: Miscellaneous building envelope and controls projects.

QRIP Project #1: Miscellaneous lighting projects.

Locally Funded Project: Wall insulation (Clay wall) - Building E1930

Table 1-4 through 1-6 summarize the PECIP, QRIP and locally funded projects. The total savings resulting from the various projects are:

- Total Annual Energy Savings = 1742.54 MBTU Electricity and 19211.1 MBTU Fuel-Oil
- Total Investment Required = \$857,384
- Total Annual Savings = \$140,441
- Simple Payback Period = 6.1 years.

TABLE 1-4

PECIP PROJECT 1: MISCELLANEOUS BUILDING ENVELOPE AND CONTROL PROJECTS

| <u>Opportunity</u> | <u>Electricity Fuel Oil (MBTU)</u> | <u>Annual Energy Savings (MBTU)</u> | <u>Total (MBTU)</u> | <u>Annual Savings (\$)</u> | Unescalated | | |
|--|--|---|-------------------------|------------------------------------|--|-------------------------------------|------------|
| | | | | | <u>Current Working Estimate (\$)</u> | <u>Simple Payback (Yrs)</u> | <u>SIR</u> |
| Window Weatherization | | | | | | | |
| - Aberdeen (ECO 2.4) | ---- | 265.4 | 265.5 | 1,835 | 8,457 | 4.6 | 1.23 |
| - Edgewood (ECO 2.2) | ---- | 1,924.4 | 1,924.4 | 13,298 | 61,747 | 4.6 | 1.22 |
| Destratification: | | | | | | | |
| - Aberdeen (ECO 2.7) | -65.2 | 542.9 | 477.7 | 3,470 | 8,214 | 2.4 | 2.98 |
| Bldg. 2353 | -46.6 | 210.2 | 163.6 | 1,250 | 5,867 | 4.7 | 2.37 |
| Bldg. 5220 | -46.6 | 210.2 | 163.6 | 1,250 | 5,867 | 4.7 | 2.37 |
| Bldg. 5221 | -31.1 | 300.8 | 269.7 | 1,944 | 3,520 | 1.8 | 6.17 |
| Wall Insulation: | | | | | | | |
| - Edgewood (ECO 2.1) | ---- | 241.5 | 241.5 | 1,669 | 3,139 | 1.9 | 8.82 |
| E1930 Plastic Wall | ----- | ----- | ----- | ----- | ----- | ----- | ----- |
| Install Thermostat and Control Valve in | | | | | | | |
| Bldg. 670 (ECO 2.2) | ---- | 124.4 | 124.4 | 860 | 484 | 0.56 | 12.7 |
| Upgrade Controls in | | | | | | | |
| Bldg. 393 (ECO 2.14) | ---- | 78.0 | 78.0 | 539 | 399 | 0.74 | 9.65 |
| Totals | | | | | | | |
| ECIP Criteria: | Cost > \$3,000 Payback < 4 Years | | ----- | ----- | ----- | ----- | ----- |
| | | | | 26,115 | 97,694 | 3.74 | |
| | | | | 3,708.4 | ----- | ----- | |
| | | | | 3,897.9 | ----- | ----- | |
| | | | | -189.5 | ----- | ----- | |

TABLE 1-5

QRIP PROJECT 1: MISCELLANEOUS LIGHTING PROJECTS

| Opportunity | Annual Energy Savings | | | Unescalated | | |
|--|-----------------------|--------------------|-----------------|---------------------------|--|----------------------------|
| | Electricity (MBTU) | Fuel Oil (MBTU) | Total (MBTU) | Annual Savings (\$) | Current Working Estimate (\$) | Simple Payback (Yrs) |
| reduce Lighting Levels: | | | | | | |
| - Aberdeen (ECO 2.10) | 24.12 | --- | 24.12 | 104 | 216 | 2.1 |
| - Edgewood (ECO 2.12) | 71.70 | --- | 71.70 | 309 | 518 | 1.7 |
| replace Incandescent with Fluorescent Light | | | | | | |
| - Aberdeen (ECO 2.11) | 71.70 | --- | 71.70 | 744 | 1,031 | 1.4 |
| - Edgewood (ECO 2.5) | 19.8 | --- | 19.8 | 205 | 285 | 1.4 |
| replace Standard Fluorescent with Energy-Saving Fluorescent | | | | | | |
| - Aberdeen (ECO 2.12) | 388.7 | --- | 388.7 | 1,675 | 932 | 0.56 |
| replace Incandescent with HPS Lighting | | | | | | |
| - Aberdeen (ECO 2-13) | 65.63 | --- | 65.63 | 283 | 1,630 | 5.8 |
| | 535.64 | --- | 535.64 | 2,309 | 9,782 | 4.2 |
| Install Light Motion Sensors in Bldg. 393 | | | | | | |
| | 1,039.44 | --- | 1,039.44 | 4,480 | 10,600 | 2.4 |
| Totals | | 2,216.73 | --- | 2,216.73 | 10,109 | 25,264 |
| DTE/OMA QRIP Criteria: Cost < \$100,000 Payback < 2 years | | | | | | |

TABLE 1-6

LOCALLY FUNDED PROJECT - WALL INSULATION (CLAY WALL) FOR BUILDING E1930

| <u>Opportunity</u> | <u>Annual Energy savings</u> | | | <u>Annual savings (\$)</u> | <u>Current Working Estimate (\$)</u> | <u>Simple Payback (Yrs)</u> | <u>SIR</u> |
|--|-------------------------------|----------------------------|-------------------------|------------------------------------|--|-------------------------------------|------------|
| | <u>Electricity (MBTU)</u> | <u>Fuel Oil (MBTU)</u> | <u>Total (MBTU)</u> | | | | |
| WALL INSULATION (Clay Wall) Building E1930 | 227.9 | 227.9 | 455.8 | 1,575 | 13,526 | 8.60 | 1.93 |