

FINAL SUBMITTAL

VOLUME II OF II, APPENDICES E & F

ENERGY SAVINGS OPPORTUNITY SURVEY FORT MC PHERSON, GEORGIA

Prepared for

**SAVANNAH DISTRICT
CORPS OF ENGINEERS
SAVANNAH, GEORGIA**

Under

CONTRACT NO. DACA21-91-C-0097

September 1992

EMC No. 3105-000

BEIG QUALITY INSPECTED 8

INSTRUMENT STATEMENT A

Approved for public release
Distribution Unlimited

E M C ENGINEERS, INC.
1950 Spectrum Circle
Suite B-312
Marietta, Georgia 30067
Phone (404) 952-3697

19971017 134

APPENDIX E
COMPUTER ENERGY SIMULATION BACKUP DATA




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.


Marie Wakefield,
Librarian Engineering

This report has been prepared at the request of the client, and the observations, conclusions, and recommendations contained herein constitute the opinions of E M C Engineers, Inc. In preparing this report, EMC has relied on some information supplied by the client, the client's employees, and others, which we gratefully acknowledge. Because no warranties were given with this source of information, E M C Engineers, Inc. cannot make certification or give assurances except as explicitly defined in this report.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
VOLUME I	
List of Abbreviations	ix
EXECUTIVE SUMMARY	
1.0 INTRODUCTION	
1.1 Authority for Study	1-1
1.2 Purpose of Study	1-1
1.3 Scope of Work	1-1
1.4 Organization of Submittal	1-2
1.5 Work Accomplished	1-2
1.6 Previous Utility Conservation Studies	1-6
2.0 UTILITY CONSUMPTION AND RATES	
2.1 General	2-1
2.2 Utility Rates	2-1
2.2.1 Electrical Rates	2-1
2.2.2 Natural Gas Rates	2-2
2.2.3 Water and Sewer Rates	2-3
2.3 Historical Consumption of Utilities	2-3
2.3.1 Historical Electrical Energy Consumption	2-3
2.3.2 Historical Natural Gas Consumption	2-6
2.4 Summary of Utilities	2-8
2.5 Basis for Economic Analysis	2-8
2.5.1 ECIP Guidance	2-8
2.5.2 Basis for Energy Cost Savings Benefits	2-9
2.5.3 Basis for Labor and Material Costs	2-10
2.6 Demand Side Management	2-10
3.0 EVALUATION OF ENERGY CONSERVATION OPPORTUNITIES	
3.1 General	3-1
3.2 ECOs Evaluated	3-1
3.3 Analysis Methodology	3-9
3.4 ECO Analysis	3-10
3.4.1 ECO 1 - Insulation	3-12
3.4.1.1 - Insulate Walls and Roofs	3-12
3.4.1.2 - Insulate Pipes and Ducts	3-17
3.4.2 ECO 2 - Insulated Windows	3-23
3.4.3 ECO 3 - Weatherstripping and Caulking	3-26
3.4.4 ECO 4 - Domestic Hot Water Temperature	3-30

TABLE OF CONTENTS (Continued)

<u>Section</u>	<u>Page</u>
3.4.5 ECO 5 - Install High Efficiency Electric Motors	3-33
3.4.6 ECO 6 - Economizers	3-37
3.4.7 ECO 7 - Control Hot Water Circulation Pump	3-40
3.4.8 ECO 8 - Install Low-Flow Shower and Faucet Fixtures	3-43
3.4.9 ECO 9 - Heat Reclaim from Hot Refrigerant Gas	3-46
3.4.10 ECO 10 - Prevent Air Stratification	3-49
3.4.11 ECO 11 - Replace Street Lights	3-52
3.4.12 ECO 12 - Revise or Repair HVAC Controls	3-55
3.4.13 ECO 13 - Thermal Storage	3-60
3.4.14 ECO 14 - Radiant Heaters and Loading Dock Seals	3-62
3.4.14.1 - Radiant Heaters	3-62
3.4.14.2 - Loading Dock Seals	3-62
3.4.15 ECO 15 - Separate Light Switches	3-63
3.4.15 ECO 15 - Automatic Lighting Controls in Building 200	3-68
3.4.16 ECO 16 - Investigate Post Demand Usage	3-71
3.4.17 ECO 17 - Boiler Operation Schedule	3-81
3.4.18 ECO 18 - Replace Exit Sign Bulbs with Fluorescent Bulb Kit	3-82
3.4.19 ECO 19 - Previous Lighting Study Review	3-84
3.5 ECO Project Summary	3-87
3.6 Results	3-93
4.0 ENERGY CONSERVATION PROJECTS	
4.1 Project Development	4-1
4.2 ECIP Projects	4-3
4.3 Non-ECIP Projects	4-6
4.3.1 QRIP Project	4-6
4.3.2 MCA Project	4-6
4.3.3 Low-Cost/No-Cost Project	4-6
4.4 Family Housing Project	4-6
4.5 NAF Projects	4-7
4.6 Other Energy Projects	4-9
5.0 SUMMARY AND RECOMMENDATIONS	
5.1 Summary	5-1
5.1.1 ECOs Evaluated	5-1
5.1.2 Results	5-1
5.1.3 Energy Project Development	5-6
5.2 Recommendations	5-9

TABLE OF CONTENTS (Continued)

LIST OF APPENDICES

VOLUME I

- A SCOPE OF WORK AND CONFIRMATION NOTICES
- B UTILITY RATES AND HISTORICAL CALCULATIONS
- C ECO BACKUP CALCULATIONS
 - C-1.1 WALL INSULATION
 - C-1.2 ROOF INSULATION
 - C-1.3 PIPE AND DUCT INSULATION
 - C-2 INSULATED GLASS
 - C-3 WEATHERSTRIPPING AND CAULKING
 - C-4 MEASURE HOT WATER TEMPERATURES
 - C-5 ELECTRIC MOTORS
 - C-6 ADD ECONOMIZERS
 - C-7 CONTROL HOT WATER CIRCULATION PUMPS
 - C-8 INSTALL LOW-FLOW SHOWER AND FAUCET FIXTURES
 - C-9 HEAT RECLAIM FOR HOT REFRIGERANT GAS
 - C-10 PREVENT AIR STRATIFICATION
 - C-11 REPLACE STREET LIGHTS
 - C-12 REVISE OR REPAIR HVAC CONTROLS
 - C-13 THERMAL STORAGE
 - C-14.1 LOADING DOCK SEALS
 - C-14.2 RADIANT HEATERS
 - C-15.1 BUILDING 200 LIGHTING CONTROLS
 - C-15.2 SEPARATE SWITCHES TO CONTROL LIGHTING
 - C-16 INVESTIGATE POST DEMAND USAGE
 - C-17 EVALUATE BOILER OPERATION
 - C-18 EXIT SIGN RETROFIT
 - C-19 LIGHTING UPGRADES
 - C-20 COMPUTER SIMULATION SUMMARIES
- D ECO PROJECT BACKUP CALCULATIONS
 - D-1 ECIP PROJECT
 - D-2 QRIP PROJECT
 - D-3 FAMILY HOUSING PROJECT
 - D-4 NAF PROJECT
 - D-5 OTHER ENERGY PROJECTS

VOLUME II

- E COMPUTER SIMULATIONS
- F FIELD SURVEY NOTES

TABLE OF CONTENTS (Continued)

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1-1	Scope of Work Summary	1-4
2-1	Electrical Energy Consumption	2-4
2-2	Natural Gas Consumption	2-6
2-3	FY91 Utility Usage and Cost Comparison	2-8
2-4	Uniform Present Worth Factors	2-9
3-1	Energy Conservation Opportunities List	3-2
3-2	Nonfeasible ECOs	3-3
3-3	Buildings Added	3-5
3-4	Building ECO Matrix	3-6
3-5	Computer Simulation Buildings	3-11
3-6	Wall Insulation	3-15
3-7	Roof Insulation	3-16
3-8	Duct and Pipe Recommended Thicknesses	3-20
3-9	Pipe Insulation	3-21
3-10	Duct Insulation	3-22
3-11	Insulated Windows	3-24
3-12	Weatherstripping and Caulking	3-28
3-13	Domestic Hot Water Temperature Measurements	3-31
3-14	Install High Efficiency Electric Motors	3-35
3-15	Economizers	3-39
3-16	Control Hot Water Circulation Pump	3-42
3-17	Install Low-Flow Shower and Faucet Fixtures	3-45
3-18	Heat Reclaim from Hot Refrigerant Gas	3-48
3-19	Prevent Air Stratification	3-51
3-20	Replace Street Lights	3-54
3-21	Revise or Repair HVAC Controls	3-58
3-22	Thermal Storage	3-61
3-23	Separate Light Switches	3-66
3-24	Automatic Lighting Controls in Building 200	3-70
3-25	FY91 Historical Electrical Demand - Fort McPherson	3-76
3-26	Demand Savings Comparison	3-79
3-27	FM Radio Control System	3-80
3-28	Replace Exit Sign Bulbs with Fluorescent Bulb Kit	3-83
3-29	Previous Lighting Study Review	3-86
3-30	Energy Conservation Opportunities List	3-88
3-31	Economic Summary of ECOs, Listed by ECO Number	3-89
3-32	Economic Summary of ECOs, Listed by SIR	3-91

TABLE OF CONTENTS (Continued)

LIST OF TABLES

<u>Table</u>		<u>Page</u>
4-1	ECIP Project Summary	4-5
4-2	NAF Economic Summary	4-8
4-3	Other Energy Projects Summary	4-10
5-1	Economic Summary of ECOs, Listed by ECO Number	5-2
5-2	Economic Summary of ECOs, Listed by SIR	5-4
5-3	Projects Economic Summary	5-8

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
2-1	Electrical Consumption	2-5
2-2	Natural Gas Consumption	2-7
3-1	FY91 Typical Hourly Demand, Summer - Fort McPherson	3-77
3-2	FY91 Typical Hourly Demand, Winter - Fort McPherson	3-78

LIST OF ABBREVIATIONS

ACH	-	air changes per hour
AAFES	-	Army Air Force Exchange Service
AHU	-	air handling unit
Bldg	-	building
cfm	-	cubic feet per minute
conf.	-	confirmation
DCU	-	digital control unit
DDC	-	direct digital control
DEH	-	Director of Engineering and Housing
DHW	-	domestic hot water
DX	-	direct expansion
ECIP	-	Energy Conservation Investment Program
ECO(s)	-	Energy Conservation Opportunity(ies)
ESOS	-	energy savings opportunity survey
F	-	Fahrenheit
FCU	-	fan coil unit
ft	-	foot, feet
FY	-	fiscal year
gpm	-	gallons per minute
hp	-	horsepower
HPS	-	high pressure sodium
hr	-	hour(s)
HW	-	hot water
in.	-	inch(es)
kVar	-	kilovolt amp reactive
kW	-	kilowatt, one thousand watts
kWh	-	kilowatt-hour, one thousand watthours
LAPS	-	lighting automation panels
LBH	-	pounds per hour
lbm	-	pounds mass
LCCID	-	Life Cycle Cost in Design
MBtu	-	British thermal units (thousand)
mcf	-	thousand cubic feet

LIST OF ABBREVIATIONS

(Continued)

MCA	-	Military Construction Army Program
MCP	-	Military Construction Program
NAF	-	non-appropriated funds
PRV	-	pressure reducing valve
psia	-	pounds per square inch, absolute
psig	-	pounds per square inch, gauge
QRIP	-	Quick Return on Investment Program
RCU	-	remote control unit
rpm	-	revolutions per minute
SES	-	Shared Energy Savings
SIOH	-	supervision, inspection, and overhead
SIR	-	Savings-to-Investment Ratio
SOW	-	Scope of Work
therm	-	100,000 Btus
UCS	-	utility control system
UPW	-	uniform present worth

BUILDING 27

E M C ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 10-APR-92
 FILE: M027ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M027	Area: 8,280 ft ²										
Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	38,225	793	14,952	27,682	4,544	12,510	12,421	72,902	26	38	287
ECO#2	51,128	933	15,590	27,682	4,544	12,510	12,421	73,679	27	51	303
Savings/(Loss)	(12,903)	(140)	(637)	0	0	0	0	(777)	(1)	(13)	(16)
ECO#3	37,667	792	14,951	27,682	4,544	12,510	12,421	72,900	26	38	286
Savings/(Loss)	557	1	2	0	0	0	0	2	0	1	1

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105 000
SHEET NO. 1 OF 3
CALCULATED BY EMC DATE 2/21/92
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation - Bldg 127. Base Run

Bldg Type: Frame V0Q

Area: 9,156 ft²

Ecd: 3

Total Bldgs: 022,028,104

Assumptions:

- 4 people / Apt w/ 5 apts occupied
- Infiltration = 1/2 ACH
- heating db = 72°F
- cooling db = 76°F
- Lights: assume 50% diversity


E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
 SHEET NO. 2 OF 3
 CALCULATED BY Rmpd DATE 2/21/92
 CHECKED BY _____ DATE _____
 SCALE _____

Blg 27 - Comp Sim


Wall U-Value - ASHRAE Table F22.4



Material	R-Value
Outside Surface (rough wind)	0.17
Aluminum Siding	0.61
1 1/2" polystyrene	4.17
1" plywood	1.25
4" batt Insulation	11.0
1/2" gypsum board	0.45
Inside surface (still air)	0.68
	<u>18.33</u>

$$U = \frac{1}{R} = \frac{1}{18.33} = \boxed{0.054}$$

Roof U-Value - ASHRAE Table F22.4



Material	R-Value
Outside Air (rough wind)	0.17
shingles (Asph/Flt)	0.44
1/2" Plywood	0.62
6" Batt Insulation	19.0
1/2" Gypsum	0.45
Inside surface (still air)	0.68
	<u>21.36</u>

$$U = \frac{1}{R} = \frac{1}{21.36} = \boxed{0.047}$$

Window U-Value

- assuming: double Pane w/ 1/4" air space - 1" frame

$$U = 0.70 \text{ - ASHRAE Table F.27.13}$$

Internal shading - ASHRAE Table F27.26

Blinds shading coefficient = 0.57

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

Bldg 27 - Comp. Svc.

People

5 apt. at 4 people/apartment = 20 people
 sensible load: 250 Btu/h/person
 latent load: 200 Btu/h/person

Lights - Fluorescent

9500 Watts x 50% x $\frac{5}{6}$ Apt. = 3958 Watts

Misc. Equipment

per Apartment Appliance	Watts	# Appliances
Refrigerator	200	200
Stove	1250	1250
Dishwasher	200	200
Freezer	250	250
Television	200	200
Misc.	10	10
		<u>1660 w/Apt</u>

1.66 kW/Apt * 5 Apt = 8.3 kW

Infiltration Calculations - use $\frac{1}{2}$ Air Change per Hour (ACH) for design

$Q = L(A \Delta t + BV^2)^{1/2}$

A - leak coeff. at = 0.0313 - ASHRAE Table F23.7 - two - Dry hours
 B - wind coefficient = 0.0051 - ASHRAE Table F23.8 - Windy conditions
 V - average wind speed = 12.65 mph
 L - effective leakage area: ASHRAE Table F23.3

- 8 - single doors - weatherstripped - $8(0.15 \frac{in}{ft^2}) (\frac{83 \times 80}{144}) = 22 \text{ in}$
 - 58 - windows - double slider weatherstripped - $58(0.0313) (\frac{40 \times 54}{144}) = 32.2 \text{ in}$
 - 58 - win frame - wood wall, caulked - $58(0.004) (\frac{40 \times 54}{144}) = 3.5 \text{ in}$
 - 8 - door frame - wood wall, caulked - $8(0.004) (\frac{40 \times 54}{144}) = 0.5 \text{ in}$
 - Sill Foundation - wall, caulked - $(0.04)(336) = 13.4 \text{ in}$
- 71.6 in

heating \downarrow Average indoor \downarrow Average outdoor
 $\Delta t = 72^\circ F - 55^\circ F = 17^\circ F$

$Q = 71.6(0.0313(17) + 0.0051(12.65)^2)^{1/2} = 83.7 \text{ cfm}$

cooling \downarrow indoor \downarrow outdoor
 $\Delta t = 76^\circ F - 88^\circ F = 12^\circ F$

$Q = 71.6(0.0313(12) + 0.0051(12.65)^2)^{1/2} = 78.2 \text{ cfm}$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

- Bldg 027, McPherson

Baseline Trend

Loop

$$\text{CHW Pump} = \frac{(0.5 \text{ HP}) (1.745 \frac{\text{kWh}}{\text{hr}}) (0.85 \frac{\text{hr}}{\text{day}})}{0.764 \text{ eff}} = 0.41 \text{ kW} * 4,380 \frac{\text{hr}}{\text{yr}} = 1,817.6 \text{ kWh/yr}$$

$$\text{HW Pump} = \frac{(0.75 \text{ HP}) (1.746 \frac{\text{kWh}}{\text{hr}}) (0.85 \frac{\text{hr}}{\text{day}})}{0.754 \text{ eff}} = 0.62 \text{ kW} * 4,380 \frac{\text{hr}}{\text{yr}} = 2,726.5 \text{ kWh/yr}$$

4,544 kWh/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - Bldg 027, McPherson,

ECO #2 - Insulated Glass
Window U-Value - ASHRAE Table F.27.13

- Use single pane, wood frame, sliding to develop energy factor for takeoff buildings.

$$U = 0.90$$

Window Shading - ASHRAE Table F 27.25

- Use light blinds

$$\Rightarrow 0.67$$

Window Area = 869 ft²

- note: Since ΔU was negative, losses were incurred \therefore For takeoff, energy losses converted to savings

Electric Savings

Total Electric Savings = 777 kWh/yr

Electric Savings = 0.89 kWh/ft²

Demand Savings

Peak Demand Savings = 1 kW

Demand Savings = 1.2×10^{-3} kW/ft²

Gas Savings

Total Gas Savings = 13 MBtu/h

Gas Savings = 0.015 MBtu/h/ft²

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - Bldg 027, McPherson

ECO #3 - Weather stripping + Caulking

Presently : - ASHRAE Table F23.3

Windows: weather stripped + caulked, double sliding, wood wall

windows: $0.026 \text{ in}^2/\text{ft}^2$

frames: $0.004 \text{ in}^2/\text{ft}^2$

Doors: not weather stripped + caulked, single doors, wood walls

doors: $0.157 \text{ in}^2/\text{ft}^2$

frames: $0.024 \text{ in}^2/\text{ft}^2$

Improvement: weather strip + caulk doors

doors: $0.114 \text{ in}^2/\text{ft}^2$

frames: $0.004 \text{ in}^2/\text{ft}^2$

Calculation

$$Q = L (A \Delta t + B v^2)^{1/2}$$

A - stack coefficient = 0.0313

- two story - ASHRAE Table F23.7

B - wind coefficient = 0.0051

- heavy shielding - ASHRAE Table F23.8

v - average windspeed = 12.65 mph

- average winter wind speed

$\Delta t = T_i - T_o = 72^\circ\text{F} - 55^\circ\text{F} = 17^\circ\text{F}$

- average Δt in winter

L - effective length = Area $\times (\text{in}^2/\text{ft}^2)$

Presently

$$58 - 40'' \times 54'' \text{ windows} - 58(15)(0.026) = 22.62 \text{ in}^2$$

$$58 - 40'' \times 54'' \text{ window frames} - 58(15)(0.004) = 3.48 \text{ in}^2$$

$$8 - 33'' \times 80'' \text{ doors} - 8(18.3)(0.157) = 23.03 \text{ in}^2$$

$$8 - 33'' \times 80'' \text{ door frames} - 8(18.3)(0.024) = \underline{3.52 \text{ in}^2}$$

$$Q = 52.65 (0.0313(17) + (0.0051)(12.65)^2)^{1/2} = 52.65 \text{ in}^2$$

$$Q = 61.1 \text{ cfh}$$

Improvement

$$\text{doors} - 8(18.3)(0.114) = 16.68 \text{ in}^2$$

$$\text{door frame} - 8(18.3)(0.004) = 0.59 \text{ in}^2$$

$$\text{windows + frames} = \underline{26.10}$$

$$Q = 43.37 (0.0313(17) + (0.0051)(12.65)^2)^{1/2} = 50.4 \text{ cfh}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Proj 0211 McPherson

ECU # 3 (low)

$Acfm = 61.1 - 50.4 = 10.7 \text{ cfm} \quad - \text{ball cfm}$

Percent infiltration = $0.5 ACH = 552 \text{ cfm}$

Improved infiltration = $552 \text{ cfm} - 10.7 \text{ cfm} = \boxed{541 \text{ cfm}}$

Electric Savings

Total Electric savings = 2 kWh/yr

Electric saving = $\boxed{3.7 \times 10^{-3}}$ kWh/cfm

Demand Savings

Peak Demand Savings = 0 kW/cfm

Gas Savings

Total Gas Savings = 0.56 MBtu/yr

Gas Savings = $\boxed{0.052}$ MBtu/cfm

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EEAP
 Location: FT MCPHERSON, BLDG 027
 Program User: R. GERRANS

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month Cooling Simulation	Last Month Cooling Simulation	Peak Cooling Load Hr	1st Month Summer Period	Last Month Summer Period	1st Month Daylight Savings	Last Month Daylight Savings
MAY		OCT				

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG M027, BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	INTERIOR SPACE	138	60		2		10			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room Design RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location Flag	T'stat Location	Mass / No. Hrs	Carpet On Floor
1	76		CLG		72		HTG				

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	138	34	.047	38			

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M	1	30	20	.054	55	0			
1	1	30				0			
1	2	138				90			
1	3	30				180			
1	4	138				270			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
M	1	4.5	3.33	4	.70	.57					
1	1			4							
1	2			21			3				
1	3			5							
1	4			28			3				

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
1	RESO	RESL	OFF	AVAIL		AVAIL				

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	--- Daylighting --- Reference Point 1	Reference Point 2
1	20	PEOPLE	250	200	3958	WATTS					

-----CARD 28-- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
1	1	ELEC APPLIANCES	8.3	KW	RESE	ELEC					

```

-----CARD 29--- Room Airflows -----
-----Ventilation-----
Room      ---Cooling---   ---Heating---   ---Cooling---   ---Heating---   --Reheat Minimum--
Number  Value      Units      Value      Units      Value      Units      Value      Units
1              .5              ACH-HR      .5              ACH-HR

```

```

-----CARD 30- Fan Airflows -----
-----Main-----
Room      ---Cooling---   ---Heating---   ---Cooling---   ---Heating---   --Room Exhaust--
Number  Value      Units      Value      Units      Value      Units      Value      Units
1      10000      CFM      10000      CFM

```

```

-----CARD 32-- Exposed Floor Parameters-----
Exposed Slab-----
Room      Floor  Perimeter  Loss      Floor  Floor  Const  Temp  Cooling  Heating  Adjacent
Number  Number  Length      Coefficient  Area      U-Value  Type  Flag  Temp  Temp  Room No
1        1        336          .8

```

```

-----CARD 33-- External Shading -----
-----OVERHANG-----
Shading  Glass  Height  Projection  Glass  Projection  Left  Const  Temp  Right  Adjacent
Type     Height  Glass  Out      Width  Left      Out  Right  Out  Projection  Building
3        13.67  -1.17  3.5

```

----- System Section Alternative #1 -----

```

-----CARD 39-- System Alternative -----
Number      Description
1           BLDG M027, BASELINE

```

```

-----CARD 40--- System Type -----
-----OPTIONAL VENTILATION SYSTEM-----
System      Ventil      Fan
Set      System  Deck  Cooling  Heating  Cooling  Heating  Static
Number  Type  Location  SADBvh  SADBvh  Schedule  Schedule  Pressure
1        FC

```

-----CARD 41-- Zone Assignment -----

System Set	Ref #1	Ref #2	Ref #3	Ref #4	Ref #5	Ref #6
Number	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
1	1 1					

-----CARD 42--- Fan SP and Duct Parameters-----

System Set	Cool Fan	Heat Fan	Return Fan	Mn Exh Fan	Aux Fan	Rm Exh Fan	Cool Fan Mtr	Return Fan Mtr	Supply Duct	Supply Duct	Return Air
Number	SP	SP	SP	SP	SP	SP	Loc	Loc	Ht Gn	Loc	Path
1	.5						RETAIR			OTHER	ROOMDK

-----CARD 45--- Equipment Schedules -----

System Set	Main Cooling	Direct Evap	Indirect Evap	Auxiliary Cooling	Main Heating	Main Preheat	Reheat	Mech. Humidity	Auxiliary Heating
Number	Coil	Economizer	Coil	Coil	Coil	Coil	Coil	Coil	Coil
1	CLGC				HTGC				

----- Equipment Section Alternative #1 -----

-----CARD 59-- Equipment Description / TOD Schedules -----

Alternative Number	Elec Consump	Elec Demand	Demand	Alternative Description
Number	Time of Day	Time of Day	Limit	
1	Schedule	Schedule	Max KW	BLDG M027, BASELINE

-----CARD 60--- Cooling Load Assignment-----

Load Asgn	All Coil	Cooling Loads To	Equipment	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-
Ref	Coil Ref	Sizing	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
1	1	BLKPLANT	1 1									

-----CARD 62-- Cooling Equipment Parameters -----

Cool Equip Ref Code	Num	Of	-----COOLING-----				-----HEAT RECOVERY-----				Seq Order	Demand Limit		
Num Name	Units	Value	Units	Value	Units	Value	Units	Value	Units	Value	Units	Num	Seq Type	Number
1 EQ1113	1													

-----CARD 63-- Cooling Pumps and References -----

Cool Ref	---CHILLED WATER---	---CONDENSER---	---HT REC or AUX---	Switch-over	Cold Storage	Cooling Tower	Misc. Access.
Num	Full Load Value	Full Load Units	Full Load Value	Full Load Units	Full Load Value	Full Load Units	Control
1	.41	KW					

-----CARD 65-- Heating Load Assignment -----

Load	All Coil										
Assignment	Loads To	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-	
Reference	Heating Ref	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
1	1	1	1								

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld	Cap'y Value	Units	Energy Rate	Units	Seq Order	Switch over	Hot Strg	Misc. Acc.	Cogen	Demand Limit
Number	Name	Units	Value	Value	Units	Value	Units	Number	Control	Strg	Acc.	Cogen	Number
1	EQ2001	1	.62		KW								

-----CARD 69-- Fan Equipment Parameters -----

System Set	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	EQ4371						

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
CLG COOLING TSTAT SCHEDULE
CLGC COOLING COIL SCHEDULE
HTG HEATING TSTAT SCHEDULE
HTGC HEATING COIL SCHEDULE
OFF ALWAYS OFF
RESE RESIDENCE EQUIPMENT SCHEDULE
RESL RESIDENCE LIGHTING SCHEDULE
RESO RESIDENCE OCCUPANCY SCHEDULE

System:

FC FAN COIL

Equipment:

Cooling:
EQ1113 AIR-CLD RECIP <15 TONS
Heating:
EQ2001 GAS FIRE TUBE HOT WATER
Fan:
EQ4371 FAN COIL SUPPLY FAN

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: NOV Ending Month: ETG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: RESE
Project: RESIDENCE EQUIPMENT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	5
5	40
7	5
16	40
18	30
19	100
20	20
22	5
24	

Schedule Name: RESL
Project: RESIDENCE LIGHTING SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
5	90
8	10
16	50
19	100
23	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
7	50
9	20
16	50
19	100
23	0
24	

Schedule Name: RESO
Project: RESIDENCE OCCUPANCY SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util	Percent
0	40	
8	20	
16	100	
20	60	
23	40	
24		

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util	Percent
0	40	
10	30	
17	90	
20	60	
23	40	
24		

```
*****  
*****  
**  
**          T R A C E    6 0 0    A N A L Y S I S          **  
**  
**          by          **  
**  
*****  
*****
```

FT MCPHERSON & FT GILLEM EEAP
FT MCPHERSON, BLDG 027

R. GERRANS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 19: 9:59 4/ 7/92
Dataset Name: M027-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M027, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	FC	0	10,000	10,000	10,552	552	0	0
Totals		0	10,000	10,000	10,552	552	0	0

CAPACITY - ALTERNATIVE 1
 BLDG M027, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating								
		Main Capacity (Tons)	Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Capacity (Btuh)	Sys. Capacity (Btuh)	Aux. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)
1	FC	10.6	0.0	0.0	0.0	10.6	-98,036	0	0	0	0	0	0	0	-98,036
Totals		10.6	0.0	0.0	0.0	10.6	-98,036	0	0	0	0	0	0	0	-98,036

The building peaked at hour 17 month 6 with a capacity of 10.6 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M027, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	FC	0.00	1.21	944.8	782.3	15.34	1.21	-11.84	8,280

System 1 Block FC - FAN COIL

***** COOLING COIL PEAK *****						***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****		
Peaked at Time ==>						Mo/Hr: 6/17			Mo/Hr: 13/ 1		
Outside Air ==>						OADB/WB/HR: 94/ 70/ 77.0			OADB: 22		
Space	Ret. Air	Ret. Air	Net	Perct	*	Space	Perct	*	Space Peak	Coil Peak	Perct
Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Space Sens	Tot Sens	Of Tot
(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%)
Envelope Loads											
Skylite Solr	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	16,377	16,377	12.90	*	0	0.00	*	0	-9,918	10.12
Glass Solar	44,326	0	44,326	34.90	*	44,326	36.58	*	0	0	0.00
Glass Cond	11,134	0	11,134	8.77	*	11,134	9.19	*	-32,306	-32,306	32.95
Wall Cond	12,290	3,126	15,416	12.14	*	12,290	10.14	*	-12,169	-15,433	15.74
Partition	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0	0	0	0.00	*	0	0.00	*	-13,440	-13,440	13.71
Infiltration	9,112	0	9,112	7.17	*	10,836	8.94	*	-29,606	-29,606	30.20
Sub Total==>	76,861	19,503	96,364	75.87	*	78,585	64.85	*	-87,520	-100,702	102.72
Internal Loads					*			*			
Lights	6,754	0	6,754	5.32	*	6,754	5.57	*	0	0	0.00
People	9,000	0	9,000	7.09	*	5,000	4.13	*	0	0	0.00
Misc	11,331	0	11,331	8.92	*	11,331	9.35	*	0	0	0.00
Sub Total==>	27,085	0	27,085	21.33	*	23,085	19.05	*	0	0	0.00
Ceiling Load	19,503	-19,503	0	0.00	*	19,503	16.10	*	-13,182	0	0.00
Outside Air	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sup. Fan Heat			2,667	2.10	*		0.00	*		2,667	-2.72
Ret. Fan Heat		889	889	0.70	*		0.00	*		0	0.00
Duct Heat Pkup		0	0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	-0.00	*		0.00	*		0	0.00
Grand Total==>	123,450	889	127,005	100.00	*	121,174	100.00	*	-100,702	-98,036	100.00

-----COOLING COIL SELECTION-----											-----AREAS-----		
Total Capacity	Sens Cap.	Coil Airfl	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total	Glass (sf)	(%)		
(Tons)	(Mbh)	(Mbh)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Part	Roof		
Main Clg	10.6	127.0	76.1	65.6	81.6	64.5	61.7	81.2	8,280	0	0		
Aux Clg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0		
Opt Vent	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	336	0	0		
Totals	10.6	127.0							Wall	6,720	869 13		

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg		
(Mbh)	(cfm)	Deg F	Deg F	Vent			Clg Cfm/Sqft	1.21	SADB	64.7	81.4		
Main Htg	-98.0	10,000	72.2	Infil	552	552	Clg Cfm/Ton	944.84	Plenum	83.4	67.0		
Aux Htg	0.0	0	0.0	Supply	10,000	10,000	Clg Sqft/Ton	782.33	Return	76.0	72.0		
Preheat	-0.0	10,000	72.2	Mincfm	0	0	Clg Btuh/Sqft	15.34	Ret/OA	76.0	72.0		
Reheat	0.0	0	0.0	Return	10,000	10,000	No. People	20	Runarnd	76.0	72.0		
Humidif	0.0	0	0.0	Exhaust	0	0	Htg % OA	0.0	Fn MtrTD	0.1	0.0		
Opt Vent	0.0	0	0.0	Rm Exh	0	0	Htg Cfm/SqFt	1.21	Fn BldTD	0.1	0.0		
Total	-98.0			Auxil	0	0	Htg Btuh/SqFt	-11.84	Fn Frict	0.2	0.0		

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M027, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room	1						
		Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space		76.0	65.6	58.3	81.6	31.0	
Main System							-0.1
Return Air Heat Pickup							0.1
Return Fan							
Return Air		76.0	65.6	58.3	81.6	31.0	
Outdoor Air		94.3	70.3	30.6	77.0	34.8	
Return/Outdoor Air Mix		76.0	65.6	58.3	81.6	31.0	
Blow through Fan							0.1
Entering Coil		76.1	65.6	58.2	81.6	31.0	
Leaving Coil		64.5	61.8	86.2	81.6	28.2	
Draw Through Fan							0.0
Duct Frictional Heat							0.2
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		64.7	61.8	85.7	81.6	28.2	
Supply Air		64.7	61.8	85.6	81.6	28.2	
Percent Outside Air			0.00	(%)			
Sensible Heat Ratio (SHR)			0.982				
Percent Supply Air Bypassing Coil			0.00	(%)			
Coil Airflow			10,000	(Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M027, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)									Room Mass (lb/ sqft)	Room Capac. (Btu/ sqft/F)
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Roof	Summr Windo	Wintr Windo	Wall	Ceill.		
1	INTERIOR SPACE	0.000	0.800	0.000	0.000	0.047	0.700	0.743	0.054	0.317	29.9	7.19
Zone	1 Total/Ave.	0.000	0.800	0.000	0.000	0.047	0.700	0.743	0.054	0.317	29.9	7.19
System	1 Total/Ave.	0.000	0.800	0.000	0.000	0.047	0.700	0.743	0.054	0.317	29.9	7.19
Building		0.000	0.800	0.000	0.000	0.047	0.700	0.743	0.054	0.317	29.9	7.19

BUILDING AREAS - ALTERNATIVE 1
 BLDG M027, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate Flr	Rm	Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	SKL /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
1	INTERIOR SPACE	1	1	8,280	8,280	0	336	0	0	4,692	869	13	5,851
Zone	1 Total/Ave.				8,280	0	336	0	0	4,692	869	13	5,851
System	1 Total/Ave.				8,280	0	336	0	0	4,692	869	13	5,851
Building					8,280	0	336	0	0	4,692	869	13	5,851

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
 BLDG M027, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.047 (Btu/Hr/Sq Ft/F)
 Overall Wall U-Value = 0.138 (Btu/Hr/Sq Ft/F)
 Overall Building U-Value = 0.100 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTvr) = 2.44 (Btu/Hr/Sq Ft)
 Wall Overall Thermal Transfer Value (OTTWw) = 12.51 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M027, BASELINE

Main System 1 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.5	5	161	-4,902	9	123	500.0	0	0	0.0	0	0
5 - 10	1.1	6	190	-9,804	10	139	1,000.0	0	0	0.0	0	0
10 - 15	1.6	8	225	-14,705	10	137	1,500.0	0	0	0.0	0	0
15 - 20	2.1	7	202	-19,607	20	262	2,000.0	0	0	0.0	0	0
20 - 25	2.6	11	336	-24,509	12	155	2,500.0	0	0	0.0	0	0
25 - 30	3.2	14	418	-29,411	6	74	3,000.0	0	0	0.0	0	0
30 - 35	3.7	12	350	-34,313	0	0	3,500.0	0	0	0.0	0	0
35 - 40	4.2	7	218	-39,214	8	109	4,000.0	0	0	0.0	0	0
40 - 45	4.8	6	180	-44,116	14	189	4,500.0	0	0	0.0	0	0
45 - 50	5.3	3	93	-49,018	11	149	5,000.0	0	0	0.0	0	0
50 - 55	5.8	6	188	-53,920	0	0	5,500.0	0	0	0.0	0	0
55 - 60	6.4	2	66	-58,821	0	0	6,000.0	0	0	0.0	0	0
60 - 65	6.9	9	266	-63,723	0	0	6,500.0	0	0	0.0	0	0
65 - 70	7.4	1	19	-68,625	0	0	7,000.0	0	0	0.0	0	0
70 - 75	7.9	2	51	-73,527	0	0	7,500.0	0	0	0.0	0	0
75 - 80	8.5	1	22	-78,429	0	0	8,000.0	0	0	0.0	0	0
80 - 85	9.0	0	0	-83,330	0	0	8,500.0	0	0	0.0	0	0
85 - 90	9.5	0	0	-88,232	0	0	9,000.0	0	0	0.0	0	0
90 - 95	10.1	0	0	-93,134	0	0	9,500.0	0	0	0.0	0	0
95 - 100	10.6	0	0	-98,036	0	0	10,000.0	100	8,760	0.0	0	0
Hours Off	0.0	0	5,775	0	0	7,423	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M027, BASELINE

----- S Y S T E M L O A D P R O F I L E -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.5	5	161	-4,902	9	123	500.0	0	0	0.0	0	0
5 - 10	1.1	6	190	-9,804	10	139	1,000.0	0	0	0.0	0	0
10 - 15	1.6	8	225	-14,705	10	137	1,500.0	0	0	0.0	0	0
15 - 20	2.1	7	202	-19,607	20	262	2,000.0	0	0	0.0	0	0
20 - 25	2.6	11	336	-24,509	12	155	2,500.0	0	0	0.0	0	0
25 - 30	3.2	14	418	-29,411	6	74	3,000.0	0	0	0.0	0	0
30 - 35	3.7	12	350	-34,313	0	0	3,500.0	0	0	0.0	0	0
35 - 40	4.2	7	218	-39,214	8	109	4,000.0	0	0	0.0	0	0
40 - 45	4.8	6	180	-44,116	14	189	4,500.0	0	0	0.0	0	0
45 - 50	5.3	3	93	-49,018	11	149	5,000.0	0	0	0.0	0	0
50 - 55	5.8	6	188	-53,920	0	0	5,500.0	0	0	0.0	0	0
55 - 60	6.4	2	66	-58,821	0	0	6,000.0	0	0	0.0	0	0
60 - 65	6.9	9	266	-63,723	0	0	6,500.0	0	0	0.0	0	0
65 - 70	7.4	1	19	-68,625	0	0	7,000.0	0	0	0.0	0	0
70 - 75	7.9	2	51	-73,527	0	0	7,500.0	0	0	0.0	0	0
75 - 80	8.5	1	22	-78,429	0	0	8,000.0	0	0	0.0	0	0
80 - 85	9.0	0	0	-83,330	0	0	8,500.0	0	0	0.0	0	0
85 - 90	9.5	0	0	-88,232	0	0	9,000.0	0	0	0.0	0	0
90 - 95	10.1	0	0	-93,134	0	0	9,500.0	0	0	0.0	0	0
95 - 100	10.6	0	0	-98,036	0	0	10,000.0	100	8,760	0.0	0	0
Hours Off	0.0	0	5,775	0	0	7,423	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M027, BASELINE

January			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-43,613	0.0	-14,410	0.0	-41,305	0.0	-41,305	0.0	-41,305	0.0
2	32.1	29.3	-45,525	0.0	-43,728	0.0	-43,717	0.0	-43,717	0.0	-43,717	0.0
3	31.7	29.3	-47,318	0.0	-44,620	0.0	-44,620	0.0	-44,620	0.0	-44,620	0.0
4	31.9	29.5	-47,878	0.0	-45,504	0.0	-45,504	0.0	-45,504	0.0	-45,504	0.0
5	32.6	30.3	-49,112	0.0	-45,870	0.0	-45,870	0.0	-45,870	0.0	-45,870	0.0
6	33.6	31.3	-27,066	0.0	-24,484	0.0	-36,642	0.0	-36,642	0.0	-24,484	0.0
7	35.0	32.6	-25,741	0.0	-22,614	0.0	-34,771	0.0	-34,771	0.0	-22,614	0.0
8	36.6	34.4	-10,741	0.0	-19,403	0.0	-24,806	0.0	-24,806	0.0	-19,403	0.0
9	38.5	36.3	-6,080	0.0	-22,289	0.0	-15,886	0.0	-15,886	0.0	-22,289	0.0
10	40.4	37.7	0	0.0	-15,086	0.0	-12,735	0.0	-12,735	0.0	-15,086	0.0
11	42.3	38.7	0	0.0	-14,500	0.0	-12,649	0.0	-12,649	0.0	-14,500	0.0
12	44.2	39.6	0	0.0	-13,928	0.0	-12,077	0.0	-12,077	0.0	-13,928	0.0
13	45.8	40.5	0	0.0	-9,635	0.0	-7,785	0.0	-7,785	0.0	-9,635	0.0
14	47.2	41.1	0	0.0	-4,605	0.0	-2,754	0.0	-2,754	0.0	-4,605	0.0
15	48.2	41.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	47.4	41.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	45.5	40.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	43.1	38.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	40.4	36.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	37.7	34.3	0	0.0	-17,917	0.0	-19,228	0.0	-19,228	0.0	-17,917	0.0
24	35.3	32.3	0	0.0	-39,202	0.0	-39,202	0.0	-39,202	0.0	-39,202	0.0

February			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	-43,554	0.0	0	0.0	-38,742	0.0	-38,742	0.0	-38,742	0.0
2	36.0	33.0	-45,406	0.0	-15,637	0.0	-41,166	0.0	-41,166	0.0	-41,166	0.0
3	34.7	31.8	-47,141	0.0	-42,793	0.0	-42,783	0.0	-42,783	0.0	-42,783	0.0
4	33.6	30.9	-47,641	0.0	-44,123	0.0	-44,123	0.0	-44,123	0.0	-44,123	0.0
5	32.8	30.1	-48,023	0.0	-45,665	0.0	-45,665	0.0	-45,665	0.0	-45,665	0.0
6	32.2	29.8	-25,773	0.0	-25,151	0.0	-37,308	0.0	-37,308	0.0	-25,151	0.0
7	32.1	29.6	-23,654	0.0	-23,850	0.0	-36,008	0.0	-36,008	0.0	-23,850	0.0
8	32.5	30.3	-615	0.0	-17,101	0.0	-22,505	0.0	-22,505	0.0	-17,101	0.0
9	33.9	31.6	-1,377	0.0	-24,726	0.0	-18,323	0.0	-18,323	0.0	-24,726	0.0
10	36.0	33.0	0	0.0	-22,878	0.0	-20,528	0.0	-20,528	0.0	-22,878	0.0
11	38.5	34.8	0	0.0	-22,646	0.0	-20,795	0.0	-20,795	0.0	-22,646	0.0
12	41.3	36.5	0	0.0	-19,131	0.0	-17,280	0.0	-17,280	0.0	-19,131	0.0
13	43.8	38.1	0	0.0	-15,378	0.0	-13,527	0.0	-13,527	0.0	-15,378	0.0
14	45.9	39.5	0	0.0	-8,662	0.0	-6,811	0.0	-6,811	0.0	-8,662	0.0
15	47.2	40.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	46.2	39.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	45.1	39.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	43.8	39.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	42.3	38.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	40.7	37.2	0	0.0	-7,167	0.0	-8,482	0.0	-8,482	0.0	-7,167	0.0
24	39.1	35.8	0	0.0	-36,052	0.0	-36,051	0.0	-36,051	0.0	-36,052	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M027, BASELINE

May Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	10.6	0	0.0	0	0.0	0	0.0	0	0.0
2	64.5	60.4	0	10.6	0	0.0	0	0.0	0	0.0	0	0.0
3	62.7	59.1	0	10.6	0	0.0	0	0.0	0	0.0	0	0.0
4	61.2	58.1	0	7.3	0	0.0	0	0.0	0	0.0	0	0.0
5	60.0	57.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	59.3	56.6	0	2.2	0	0.0	0	0.0	0	0.0	0	0.0
7	59.0	56.5	0	4.4	0	0.0	0	0.0	0	0.0	0	0.0
8	59.5	56.6	0	4.2	0	0.8	0	0.0	0	0.0	0	0.7
9	60.9	56.6	0	3.7	0	0.7	0	0.0	0	0.0	0	0.7
10	63.0	57.2	0	3.9	0	1.3	0	1.1	0	1.1	0	1.3
11	65.7	58.1	0	4.0	0	1.4	0	1.6	0	1.6	0	1.4
12	68.7	59.8	0	4.5	0	1.8	0	1.9	0	1.9	0	1.8
13	71.7	61.6	0	4.9	0	2.3	0	2.4	0	2.4	0	2.3
14	74.5	63.4	0	6.0	0	3.2	0	3.4	0	3.4	0	3.2
15	76.6	64.8	0	7.1	0	4.3	0	4.4	0	4.4	0	4.3
16	78.0	65.6	0	7.6	0	4.1	0	4.3	0	4.3	0	4.1
17	78.5	65.6	0	9.0	0	5.9	0	5.6	0	5.6	0	5.9
18	78.2	65.8	0	7.4	0	5.0	0	5.0	0	5.0	0	5.0
19	77.5	65.6	0	4.1	0	3.1	0	3.1	0	3.1	0	3.1
20	76.3	66.1	0	5.6	0	4.9	0	4.8	0	4.8	0	4.9
21	74.8	67.2	0	2.8	0	2.4	0	2.4	0	2.4	0	2.4
22	73.0	66.4	0	2.3	0	2.0	0	2.0	0	2.0	0	2.0
23	70.9	65.4	0	1.6	0	1.4	0	1.4	0	1.4	0	1.4
24	68.7	64.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

June Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	0.9	0	0.3	0	0.4	0	0.4	0	0.4
2	71.2	66.1	0	0.9	0	0.0	0	0.0	0	0.0	0	0.0
3	69.7	65.2	0	0.8	0	0.0	0	0.0	0	0.0	0	0.0
4	68.5	64.3	0	0.6	0	0.0	0	0.0	0	0.0	0	0.0
5	67.8	64.2	0	0.6	0	0.0	0	0.0	0	0.0	0	0.0
6	67.6	64.2	0	4.2	0	1.5	0	0.5	0	0.5	0	1.5
7	68.1	64.8	0	5.7	0	3.3	0	2.3	0	2.3	0	3.5
8	69.4	65.7	0	5.5	0	2.9	0	2.5	0	2.5	0	3.0
9	71.6	66.2	0	5.0	0	2.3	0	2.9	0	2.9	0	2.3
10	74.2	67.2	0	5.1	0	3.2	0	3.6	0	3.6	0	3.3
11	77.2	68.5	0	5.2	0	3.3	0	3.5	0	3.5	0	3.3
12	80.2	70.0	0	5.9	0	3.7	0	4.0	0	4.0	0	3.8
13	82.8	70.8	0	6.4	0	4.2	0	4.4	0	4.4	0	4.2
14	85.0	71.6	0	7.7	0	5.5	0	5.7	0	5.7	0	5.5
15	86.3	72.3	0	8.8	0	6.6	0	6.8	0	6.8	0	6.6
16	86.8	72.1	0	9.2	0	6.4	0	6.5	0	6.5	0	6.4
17	86.6	71.7	0	10.6	0	8.1	0	7.6	0	7.6	0	8.1
18	85.8	71.5	0	9.9	0	6.9	0	6.8	0	6.8	0	6.9
19	84.7	71.2	0	5.5	0	4.3	0	4.3	0	4.3	0	4.3
20	83.2	71.5	0	6.9	0	6.8	0	6.7	0	6.7	0	6.8
21	81.4	71.7	0	4.1	0	3.3	0	3.3	0	3.3	0	3.3
22	79.3	71.4	0	3.6	0	2.9	0	2.9	0	2.9	0	2.9
23	77.2	70.5	0	2.8	0	2.2	0	2.2	0	2.2	0	2.2
24	75.1	69.1	0	1.3	0	0.7	0	0.7	0	0.7	0	0.7

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M027, BASELINE

July		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0 69.3	0	1.2	0	0.2	0	0.3	0	0.3	0	0.3
2	70.5 68.0	0	0.9	0	0.0	0	0.0	0	0.0	0	0.0
3	69.4 67.1	0	0.8	0	0.0	0	0.0	0	0.0	0	0.0
4	68.5 66.4	0	0.7	0	0.0	0	0.0	0	0.0	0	0.0
5	67.9 66.0	0	0.6	0	0.0	0	0.0	0	0.0	0	0.0
6	67.7 65.9	0	3.8	0	1.2	0	0.0	0	0.0	0	1.4
7	68.1 66.3	0	5.8	0	3.5	0	2.8	0	2.8	0	4.1
8	69.1 67.3	0	5.6	0	3.1	0	3.1	0	3.1	0	3.4
9	70.8 68.0	0	4.8	0	2.3	0	3.2	0	3.2	0	2.5
10	72.9 69.1	0	5.1	0	3.2	0	3.5	0	3.5	0	3.2
11	75.2 70.5	0	5.2	0	3.2	0	3.4	0	3.4	0	3.2
12	77.5 71.7	0	5.8	0	3.6	0	3.8	0	3.8	0	3.6
13	79.6 72.7	0	6.4	0	4.0	0	4.2	0	4.2	0	4.0
14	81.3 73.5	0	7.5	0	5.0	0	5.2	0	5.2	0	5.0
15	82.3 73.7	0	8.6	0	6.1	0	6.4	0	6.4	0	6.1
16	82.7 73.5	0	9.1	0	6.2	0	6.4	0	6.4	0	6.2
17	82.5 73.1	0	10.6	0	7.8	0	7.3	0	7.3	0	7.8
18	82.0 72.6	0	9.0	0	6.5	0	6.4	0	6.4	0	6.5
19	81.1 73.2	0	5.0	0	3.9	0	3.9	0	3.9	0	3.9
20	79.9 73.8	0	6.8	0	6.7	0	6.6	0	6.6	0	6.7
21	78.5 73.9	0	3.8	0	3.0	0	3.0	0	3.0	0	3.0
22	76.9 73.1	0	3.3	0	2.9	0	2.9	0	2.9	0	2.9
23	75.2 71.9	0	2.6	0	2.2	0	2.2	0	2.2	0	2.2
24	73.5 70.8	0	1.3	0	0.5	0	0.5	0	0.5	0	0.5

August		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7 70.2	0	1.2	0	0.2	0	0.3	0	0.3	0	0.3
2	71.2 69.0	0	0.9	0	0.0	0	0.0	0	0.0	0	0.0
3	69.9 68.0	0	0.7	0	0.0	0	0.0	0	0.0	0	0.0
4	68.8 67.1	0	0.6	0	0.0	0	0.0	0	0.0	0	0.0
5	68.0 66.6	0	0.5	0	0.0	0	0.0	0	0.0	0	0.0
6	67.5 66.2	0	2.9	0	0.9	0	0.0	0	0.0	0	1.0
7	67.3 66.1	0	5.7	0	3.4	0	2.1	0	2.1	0	3.8
8	67.8 66.5	0	5.6	0	2.9	0	2.8	0	2.8	0	3.2
9	69.1 67.0	0	4.9	0	2.1	0	3.0	0	3.0	0	2.2
10	71.2 67.8	0	5.3	0	2.9	0	3.4	0	3.4	0	3.0
11	73.8 68.7	0	5.4	0	2.9	0	3.3	0	3.3	0	3.0
12	76.5 70.0	0	5.7	0	3.3	0	3.5	0	3.5	0	3.3
13	79.1 71.2	0	6.4	0	4.2	0	4.4	0	4.4	0	4.2
14	81.1 72.6	0	7.6	0	5.4	0	5.6	0	5.6	0	5.4
15	82.5 73.6	0	8.8	0	6.6	0	6.8	0	6.8	0	6.6
16	83.0 73.7	0	9.1	0	5.4	0	5.6	0	5.6	0	5.4
17	82.8 73.5	0	10.5	0	7.7	0	7.2	0	7.2	0	7.7
18	82.3 73.5	0	7.6	0	5.7	0	5.6	0	5.6	0	5.7
19	81.5 73.1	0	4.8	0	3.8	0	3.8	0	3.8	0	3.8
20	80.4 73.7	0	6.8	0	6.5	0	6.4	0	6.4	0	6.5
21	79.1 74.9	0	3.7	0	3.0	0	3.0	0	3.0	0	3.0
22	77.6 73.9	0	3.3	0	2.9	0	2.9	0	2.9	0	2.9
23	76.0 72.7	0	2.6	0	2.3	0	2.3	0	2.3	0	2.3
24	74.3 71.3	0	1.3	0	0.6	0	0.6	0	0.6	0	0.6

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG MO27, BASELINE

November			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	46.9	44.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	45.5	42.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	44.6	41.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	44.4	42.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	44.8	42.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	45.9	43.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	47.8	46.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	50.2	48.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	52.9	49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	55.8	51.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	58.5	52.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	60.9	52.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	62.8	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	64.0	53.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	64.4	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	64.1	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	63.2	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	61.8	54.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	60.0	53.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	57.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	53.2	49.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	50.8	47.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

December			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	0	0.0	0	0.0	-39,738	0.0	-39,738	0.0	-39,738	0.0
2	37.1	35.1	0	0.0	0	0.0	-41,349	0.0	-41,349	0.0	-41,349	0.0
3	37.4	35.5	0	0.0	-16,183	0.0	-41,685	0.0	-41,685	0.0	-41,685	0.0
4	38.1	36.2	0	0.0	-40,233	0.0	-40,223	0.0	-40,223	0.0	-40,223	0.0
5	39.3	37.6	-37,979	0.0	-40,353	0.0	-40,353	0.0	-40,353	0.0	-40,353	0.0
6	40.9	39.2	-17,118	0.0	-15,957	0.0	-28,114	0.0	-28,114	0.0	-15,957	0.0
7	42.7	41.2	-16,907	0.0	-15,050	0.0	-27,208	0.0	-27,208	0.0	-15,050	0.0
8	44.7	43.1	-1,503	0.0	-9,031	0.0	-14,434	0.0	-14,434	0.0	-9,031	0.0
9	46.8	45.3	0	0.0	-10,119	0.0	-3,716	0.0	-3,716	0.0	-10,119	0.0
10	48.8	47.0	0	0.0	-5,763	0.0	-3,413	0.0	-3,413	0.0	-5,763	0.0
11	50.7	48.1	0	0.0	-4,593	0.0	-2,742	0.0	-2,742	0.0	-4,593	0.0
12	52.2	48.8	0	0.0	-3,295	0.0	-1,444	0.0	-1,444	0.0	-3,295	0.0
13	53.4	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	54.1	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	54.4	48.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	54.0	48.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	53.0	47.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	51.4	46.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	49.3	45.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	47.0	43.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	44.5	41.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	42.2	39.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	40.1	37.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	38.5	36.2	0	0.0	-17,593	0.0	-15,939	0.0	-15,939	0.0	-17,593	0.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M027, BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	5,071	15	154	1
Feb	4,561	15	136	1
March	4,524	15	6	0
April	4,321	15	0	0
May	6,666	24	0	0
June	8,119	27	0	0
July	8,144	26	0	0
Aug	8,063	26	0	0
Sept	6,739	24	0	0
Oct	4,970	21	0	0
Nov	4,321	15	0	0
Dec	4,898	15	86	1
Total	70,398	27	382	1

Building Energy Consumption = 33,634 (Btu/Sq Ft/Year)
 Source Energy Consumption = 91,922 (Btu/Sq Ft/Year)

Floor Area = 8,280 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M027, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 26.5 (kW)
 Yearly Time of Peak 20 (hr) 6 (mo)
 Hour 20 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1113	AIR-CLD RECIP <15 TONS	11.1	41.86
Sub Total			11.1	41.86
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	3.2	11.92
Sub Total			3.2	11.92
Sub Total			0.0	0.00
Miscellaneous				
	Lights		4.0	14.93
	Base Utilities		0.0	0.00
	Misc Equipment		8.3	31.30
Sub Total			12.3	46.23
Grand Total			26.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M027, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 8,280
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	793.0	38,224.6	14.7	48,356.7	6.0
Primary Cooling					
Compressor	12,401.1	0.0	15.2	126,988.0	15.7
Tower/Cond Fans	1,660.2	0.0	2.0	17,000.3	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	891.0	0.0	1.1	9,123.9	1.1
Auxiliary					
Supply Fans	27,681.6	0.0	33.9	283,460.2	35.1
Circulation Pumps	2,039.8	0.0	2.5	20,887.8	2.6
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	29,721.4	0.0	36.4	304,348.0	37.7
Lighting	12,510.1	0.0	15.3	128,103.2	15.5
Receptacle	12,420.9	0.0	15.2	127,190.8	15.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	70,397.7	38,224.6	100.0	761,110.9	93.4

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M027, ECO #2

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	5,222	15	196	1
Feb	4,657	15	174	1
March	4,578	15	15	0
April	4,321	15	0	0
May	6,765	24	0	0
June	8,397	28	0	0
July	8,371	27	0	0
Aug	8,271	27	0	0
Sept	6,849	24	0	0
Oct	4,904	20	0	0
Nov	4,375	15	8	0
Dec	5,004	15	119	1
Total	71,715	28	511	1

Building Energy Consumption = 35,736 (Btu/Sq Ft/Year)
 Source Energy Consumption = 95,191 (Btu/Sq Ft/Year)

Floor Area = 8,280 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M027, ECO #2

1	EQ2001		GAS FIRE TUBE HOT WATER												
	GAS	196	174	15	0	0	0	0	0	0	0	8	119	511	
	PK	0.7	0.7	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.6	0.7	
1	EQ5020		HEAT WATER CIRC. PUMP C.V.												
	ELEC	416	343	57	0	0	0	0	0	0	0	30	298	1,144	
	PK	0.7	0.7	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.7	0.7	
1	EQ5240		BOILER FORCED DRAFT FAN												
	ELEC	60	50	8	0	0	0	0	0	0	0	4	43	166	
	PK	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	
1	EQ5307		BOILER CONTROLS												
	ELEC	279	230	38	0	0	0	0	0	0	0	20	200	767	
	PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M027, ECO #2

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 28.1 (kW)
 Yearly Time of Peak 17 (hr) 6 (mo)

Hour 17 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1113	AIR-CLD RECIP <15 TONS	19.6	69.86
Sub Total			19.6	69.86
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	3.2	11.26
Sub Total			3.2	11.26
Sub Total			0.0	0.00
Miscellaneous				
	Lights		2.0	7.05
	Base Utilities		0.0	0.00
	Misc Equipment		3.3	11.83
Sub Total			5.3	18.88
Grand Total			28.1	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M027, ECO #2

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 8,280
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	932.6	51,127.3	18.4	63,368.3	7.8
Primary Cooling					
Compressor	12,979.7	0.0	15.0	132,912.9	16.5
Tower/Cond Fans	1,742.8	0.0	2.0	17,846.2	2.2
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	867.0	0.0	1.0	8,878.1	1.1
Auxiliary					
Supply Fans	27,681.6	0.0	31.9	283,460.2	35.1
Circulation Pumps	2,580.6	0.0	3.0	26,425.7	3.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	30,262.2	0.0	34.9	309,885.9	38.4
Lighting	12,510.1	0.0	14.4	128,103.2	15.5
Receptacle	12,420.9	0.0	14.3	127,190.8	15.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	71,715.4	51,127.3	100.0	788,185.4	96.8

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M027, ECO #3

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	5,133	15	153	1
Feb	4,615	15	134	1
March	4,529	15	6	0
April	4,321	15	0	0
May	6,712	24	0	0
June	8,167	27	0	0
July	8,191	26	0	0
Aug	8,112	26	0	0
Sept	6,784	24	0	0
Oct	4,991	21	0	0
Nov	4,321	15	0	0
Dec	4,943	15	85	0
Total	70,821	27	377	1

Building Energy Consumption = 33,741 (Btu/Sq Ft/Year)
 Source Energy Consumption = 92,374 (Btu/Sq Ft/Year)

Floor Area = 8,280 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M027, ECO #3

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 26.6 (kW)
Yearly Time of Peak 20 (hr) 6 (mo)

Hour 20 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1113	AIR-CLD RECIP <15 TONS	11.2	42.01
Sub Total			11.2	42.01
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	3.2	11.88
Sub Total			3.2	11.88
Sub Total			0.0	0.00
Miscellaneous				
	Lights		4.0	14.89
	Base Utilities		0.0	0.00
	Misc Equipment		8.3	31.22
Sub Total			12.3	46.10
Grand Total			26.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M027, ECO #3

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 8,280
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	792.2	37,667.2	14.5	47,762.0	5.9
Primary Cooling					
Compressor	12,400.2	0.0	15.1	126,978.4	15.7
Tower/Cond Fans	1,659.5	0.0	2.0	16,993.4	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	891.0	0.0	1.1	9,123.9	1.1
Auxiliary					
Supply Fans	27,681.6	0.0	33.8	283,460.2	35.1
Circulation Pumps	2,465.3	0.0	3.0	25,244.6	3.1
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	30,146.9	0.0	36.8	308,704.8	38.2
Lighting	12,510.1	0.0	15.3	128,103.2	15.5
Receptacle	12,420.9	0.0	15.2	127,190.8	15.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	70,820.8	37,667.2	100.0	764,856.4	93.9

BUILDING 60

E M C ENGINEERS, INC.

PROJECT: FORT MCPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT MCPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 10-APR-92
 FILE: M060ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M060 Area: 20,856 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (Mbtu/yr)
Baseline	534,362	3,570	50,115	63,955	22,803	25,412	45,045	210,900	88	534	1,254
ECO#2	432,898	3,140	49,003	63,955	22,803	25,412	45,045	209,358	86	433	1,147
Savings/(Loss)	101,464	430	1,112	0	0	0	0	1,542	2	101	107
ECO#3	516,436	3,445	49,754	63,955	22,803	25,412	45,045	210,413	87	516	1,234
Savings/(Loss)	17,926	126	361	0	0	0	0	487	1	18	20
ECO#12	450,478	3,101	36,635	63,955	21,056	25,412	45,045	195,204	83	450	1,117
Savings/(Loss)	83,884	469	13,480	0	1,747	0	0	15,696	5	84	137
ECO#13	534,362	3,570	59,514	63,955	22,803	25,412	45,045	220,299	66	534	1,286
Savings/(Loss)	0	0	(9,399)	0	0	0	0	(9,399)	22	0	(32)
ECO#15	540,173	3,576	49,501	63,955	22,803	22,618	45,045	207,497	87	540	1,248
Savings/(Loss)	(5,811)	(6)	614	0	0	2,794	0	3,402	1	(6)	6

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000

SHEET NO. 1 OF 3

CALCULATED BY Royce DATE 2/21/92

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - Bldg 060, Barafine
Bldg Type: Brick Housing Area: $\approx 1,262 \text{ ft}^2$
ERO 2, 3, 12, 13
Take off bldgs: 040, 056, 058, 062

Assumptions


- occupants = 48 people
- Infiltration: summer = $1\frac{1}{2}$ ACH
winter = $1\frac{1}{2}$ ACH
- heating db = 72°F
- cooling db = 76°F
- Lighting: assume 75% diversity and 48/71% occupancy

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
 SHEET NO. 2 OF 3
 CALCULATED BY Romya DATE 2/2/02
 CHECKED BY _____ DATE _____
 SCALE _____

Comp Sim - R10 760




Wall U-Value - ASHRAE Table F 22.4

Material	R-Value
Outside Surface	0.17
4" brick - face	1.24
16" concrete	1.60
Inside Surface	<u>0.68</u>
	3.69

$$U = \frac{1}{3.69} = \boxed{0.27}$$

Roof U-Value - ASHRAE Table F 22.4



Material	R-Value
Outside Surface	0.17
Shingles (Asphalt)	0.44
1/2" Plywood	0.62
Air Space	1.24
Insulation - R19	19.0
5/8" Gypsum board	0.56
Inside Surface	<u>0.62</u>
	22.65

$$U = \frac{1}{22.65} = \boxed{0.044}$$

Window U-Value - ASHRAE Table F 27.13

- single pane, wood frame Type R

$$U = \boxed{0.90}$$

- Internal shading - ASHRAE Table F 27.25

white draper \Rightarrow coefficient $\boxed{0.67}$

People

48 Rooms @ 1 person / room = $\boxed{48 \text{ People}}$

\rightarrow observed average occupancy

sensible : 250 Btu-h / person

latent : 200 Btu-h / person

Light - From ECO #15

$$(75\%) \left(\frac{48}{71} \right) (15,858 \text{ W}) = \boxed{8,040 \text{ W}}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105 000

SHEET NO. 3 OF 3

CALCULATED BY Romy DATE 2/21/92

CHECKED BY _____ DATE _____

SCALE _____

Equip Load - 950

Misc loads - 1

<u>Equip Load</u>	<u>Watts</u>	<u>Q feet</u>
Stove	200	48 (200)
TV	200	48 (75)
Refrigerator	75	49 (260)
coffee pot	260	
microwave	65	
Misc	10	48 (10)
<u>for 1 year</u>		
3 year	375	3 (375)
3 glass	750	3 (750)
3 water cooler	100	6 (100)

30.1 kw

Infiltration

- Assume $\frac{1}{2}$ ACH for heating + $\frac{1}{2}$ ACH for cooling

for $r = 3$

$Q = L(A \Delta t + B V)^{\frac{1}{2}}$

- A - Stack coefficient = 0.0313 - ASHRAE Table F 227
- B - Wind coefficient = 0.0051 - ASHRAE Table F 228
- V - Wind velocity = 12.65 mph
- L - Effective leakage area:

door double door weatherstrip	(.13) (315)	= 41.0 in ²
door frame, masonry, weatherstripped	(.072) (215)	= 22.7 in ²
window single pane not weatherstripped	(0.052) (2,717)	= 141.3 in ²
door frame, masonry, weatherstripped	(0.095) (2,717)	= 252.7 in ²
2" Foundation not weatherstripped	(0.19) (698)	= 132.6 in ²
		<u>590.3 in²</u>

heating

$\Delta t = 72 - 53 = 19^{\circ}F$

$Q = 590.3 (0.0313(19) + 0.0051(12.65)^{\frac{1}{2}})^{\frac{1}{2}} = 701 \text{ cfm}$

cooling

$\Delta t = 88 - 76 = 12^{\circ}F$

$Q = 590.3 (0.0313(12) + 0.0051(12.65)^{\frac{1}{2}})^{\frac{1}{2}} = 644 \text{ cfm}$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 060, McPherson

Baseline (cool)

Inputs

DTW Pump = 10 HP for 3 buildings \Rightarrow 3.3 kW

$$(Observed) \frac{3.3 \text{ kW} \times 8760 \text{ hr/yr}}{0.812 \text{ eff}} = 2.6 \text{ kW} \times 8760 \text{ hr/yr} = \boxed{22,803} \text{ kWh/yr}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg. 060, McPherson

ECO # 2 - Insulated Glass

Window U-Value - ASHRAE Table = 27.13

- use double pane, wood frame, sliding

$$U = 0.54$$

Window Shading - ASHRAE Table F 27.26

- use blinds

$$\Rightarrow 0.55$$

Window Area = 2,717 ft²

Electric Savings

Total Electric Savings = 1,542 kWh/yr

Electric Savings / ft² = 0.57 kWh / ft²

Demand Savings

Peak Demand Savings = 2 kW

Demand Savings / ft² = 7.4×10^{-4} kW / ft²

Gas Savings

Total Gas Savings = 101.5 MBtu/yr

Gas Savings / ft² = 0.037 MBtu / ft²

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulator - Bldg 50, Ft. McPherson

ECO # 3 - Weatherstripping + Caulking

Presently - ASHRAE Table F 23.3

Windows: not w.s/c, single sliding, mason wall 152 - 73' x 75"
window: 0.052 in²/ft²
frame: 0.093 in²/ft²

Doors: not w.s/c, double, mason wall 9 - 30" x 84"
door: 0.16 in²/ft²
frame: 0.072 in²/ft²

Improvement: w.s/c doors + windows

windows: 0.026 in²/ft²
frame: 0.019 in²/ft²
door: 0.114 in²/ft²
frame: 0.004 in²/ft²

Calculation

$$Q = L(A \Delta t + B v^{1/2})$$

A - stack coefficient = 0.0313 - Two story ASHRAE Table F 23.7

E - wind coefficient = 0.0051 - heavy shielding ASHRAE Table F 23.8

v - average wind velocity = 12.65 mph - avg winter

$\Delta t = 72^\circ\text{F} - 55^\circ\text{F} = 17^\circ\text{F}$ - avg winter

L - effective length = Area * (in²/ft²)

Percent

$$\text{windows: } (0.052)(2,717) = 141.3$$

$$\text{frame: } (0.093)(2,717) = 252.7$$

$$\text{door: } (0.16)(157.5) = 25.2$$

$$\text{frame: } (0.072)(157.5) = 11.3$$

$$430.5 \text{ in}^2$$

$$Q = 430.5(0.0313(17) + 0.0051(12.65)^{1/2})$$

$$Q = 500 \text{ ftm}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - Bldg 050, Ed McPherson (ERO#3-roat)

Improved

$$\begin{aligned} \text{windows: } & (0.026)(27.7) = 70.6 \\ \text{frame: } & (0.019)(27.7) = 51.6 \\ \text{door: } & (0.114)(157.5) = 13.0 \\ \text{frame: } & (0.004)(157.5) = 0.6 \\ & \underline{140.8 \text{ m}^2} \end{aligned}$$

$$Q = 140.8(0.023(17) + 0.0051(12.65)^2)^{1/2}$$

$$Q = 164 \text{ cfm}$$

$$\Delta Q = 500 - 164 = 336 \text{ cfm}$$

Present: design infiltration = 1.5 ACH = 4,171 cfm

Improved 4,171 - 336 = 3,835 cfm

Electric Savings

$$\text{Total Electric Savings} = 487 \text{ kWh/yr}$$

$$\text{Electric Savings}/\Delta \text{cfm} = \boxed{1.4} \text{ kWh}/\Delta \text{cfm}$$

Demand Savings

$$\text{Peak Demand Savings} = 1 \text{ kW}$$

$$\text{Demand Savings}/\Delta \text{cfm} = \boxed{3.0 \times 10^{-3}} \text{ kW}/\Delta \text{cfm}$$

Gas Savings

$$\text{Total Gas Savings} = 17.9 \text{ MBtu/yr}$$

$$\text{Gas Savings}/\Delta \text{cfm} = \boxed{0.053} \text{ MBtu/yr}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 060, McPherson

ECO #12 - HVAC Controls

- Temp Setpoint: 70°F - heating - 78°F - cooling
- Turn pump off _____, between heating + cooling seasons

Pump Savings

- Assume 4 wks/yr = 672 hrs/yr
- savings = 2.6 kW × 672 hrs/yr = 1747 kWh/yr

Electric Savings

Total Electric Savings = 15,696 kWh/yr

Demand Savings

Peak Demand Savings = 5 kW

Gas Savings

Total Gas Savings = 34 MBtu/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Eddy Ofo. McPherson

ECO #13 - Thermal Storage

Tank discharge : 12:00 - 16:00 M-Sun

Tank charge : 00:00 - 06:00

Tank capacity: 111.1 Tons/hr - From Trace 500 for August Daily Cooling

Chiller capacity: 18.5 Tons/hr Use 20 Ton

Demand Savings

kw/ton for existing chiller = 1.278

Tons saved at Peak = 16.9 Tons

Demand Savings = $16.9 \times 1.278 = 21.6 = \boxed{22}$ kw

Electric Loss

Total Electric Loss = $\boxed{9,399}$ kWh/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 060, McPherson

ECO #15 - Lighting Control

Lighting Reduction

Present = 8040 W

reduce 11%

reduced = 7,156 W

Reduced kWh = 2,794 kWh/yr

Electric Factor

Reduced electric use = cooling - heating = 614 - 6 = 608 kWh

Electric Savings/kWh = 0.22 kWh/kWh

Gas Factor

Increased gas use = 5.8 MBtu/yr

Gas increased/kWh = 2.1×10^{-5} MBtu/kWh

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EEAP
 Location: FT MCPHERSON, BLDG 060
 Program User: R. GERRANS

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month	Last Month	Peak	1st Month	Last Month	1st Month	Last Month
Cooling Simulation	Cooling Simulation	Cooling Load Hr	Summer Period	Summer Period	Daylight Savings	Daylight Savings
MAY						OCT

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG. M060, BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	INTERIOR	316	66		2		10			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room Design RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location Flag	T'stat Location	Mass / No. Hrs On Average	Carpet On Floor
1	76			CLG	72		HTG				

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	316	43	.044	38			

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M	1		25	.27	66				
1	1	316				0			
1	2	33				90			
1	3	316				180			
1	4	33				270			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
M	1	6.5	2.75		.9	.67					
1	1			72			3				
1	2			4							
1	3			72			3				
1	4			4							

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
1	RESO	RESL	OFF	AVAIL		AVAIL				

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	Percent Reference Point 1	Percent Daylighting Reference Point 2
1	48	PEOPLE	250	200	8040	WATTS					

-----CARD 28-- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
1	1	MISC	30.1	KW	RESE	ELEC					


```

-----CARD 42--- Fan SP and Duct Parameters-----
System Cool Heat Return Mn Exh Aux Rm Exh Cool Return Supply Supply Return
Set Fan Fan Fan Fan Fan Fan Fan Mtr Fan Mtr Duct Duct Air
Number SP SP SP SP SP SP SP Loc Loc Ht Gn Loc Path
1 .5 RETAIR OTHER ROOMDK

```

```

-----CARD 45--- Equipment Schedules -----
System Main Direct Indirect Auxiliary Main Main Auxiliary
Set Cooling Evap Evap Cooling Heating Preheat Reheat Mech. Heating
Number Coil Economizer Coil Coil Coil Coil Coil Coil Humidity Coil
1 CLGC HTGC

```

```

----- Equipment Section Alternative #1 -----

```

```

-----CARD 59-- Equipment Description / TOD Schedules -----
Elec Consump Elec Demand Demand
Alternative Time of Day Time of Day Limit
Number Schedule Schedule Max KW Alternative Description
1 BLDG M060, BASELINE

```

```

-----CARD 60--- Cooling Load Assignment-----
Load All Coil Cooling
Asgn Loads To Equipment -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
Ref Cool Ref Sizing Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
1 1 BLKPLANT 1 1

```

```

-----CARD 62-- Cooling Equipment Parameters -----
Cool Equip Num -----COOLING----- HEAT RECOVERY----- Seq Demand
Ref Code Of --Capacity-- --Energy-- --Capacity-- --Energy-- Order Seq Limit
Num Name Units Value Units Value Units Value Units Value Units Num Type Number
1 EQ1100S 1

```

```

-----CARD 63-- Cooling Pumps and References -----
Cool ---CHILLED WATER--- ---CONDENSER--- ---HT REC or AUX--- Switch-
Ref Full Load Full Load Full Load Full Load Full Load Full Load over Cold Cooling Misc.
Num Value Units Value Units Value Units Control Storage Tower Access.
1 2.6 KW

```

```

-----CARD 65-- Heating Load Assignment -----
Load All Coil
Assignment Loads To -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
Reference Heating Ref Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
1 1 1 1

```

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref Number	Equip Code Name	Number Of Units	HW Pmp Full Ld Value	Units	Cap'y Value	Units	Energy Rate Value	Units	Seq Order Number	Switch over Control	Hot Strg	Misc. Acc.	Cogen	Demand Limit Number
1	EQ2001	1	2.6	KW										

-----CARD 69-- Fan Equipment Parameters -----

System Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	EQ4371						

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
CLG COOLING TSTAT SCHEDULE
CLGC COOLING COIL SCHEDULE
HTG HEATING TSTAT SCHEDULE
HTGC HEATING COIL SCHEDULE
OFF ALWAYS OFF
RESE RESIDENCE EQUIPMENT SCHEDULE
RESL RESIDENCE LIGHTING SCHEDULE
RESO RESIDENCE OCCUPANCY SCHEDULE

System:

FC FAN COIL

Equipment:

Cooling:
EQ1100S AIR-CLD RECIP 25-45 TONS
Heating:
EQ2001 GAS FIRE TUBE HOT WATER
Fan:
EQ4371 FAN COIL SUPPLY FAN

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: NOV Ending Month: ETG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Schedule Name: RESE
Project: RESIDENCE EQUIPMENT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	5
5	40
7	5
16	40
18	30
19	100
20	20
22	5
24	

Schedule Name: RESL
Project: RESIDENCE LIGHTING SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
5	90
8	10
16	50
19	100
23	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
7	50
9	20
16	50
19	100
23	0
24	

Schedule Name: RESO
Project: RESIDENCE OCCUPANCY SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util	Percent
0		40
8		20
16		100
20		60
23		40
24		

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util	Percent
0		40
10		30
17		90
20		60
23		40
24		

**
** T R A C E 6 0 0 A N A L Y S I S **
**
** by **
**

FT MCPHERSON & FT GILLEM EEAP
FT MCPHERSON, BLDG 060

R. GERRANS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 20:29:23 4/ 7/92
Dataset Name: M060-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	FC	0	23,104	23,104	27,275	4,171	0	0
Totals		0	23,104	23,104	27,275	4,171	0	0

CAPACITY - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	Cooling				Cooling Totals (Tons)	Heating				Heating Totals (Btuh)		
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)		Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)		Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)
1	FC	34.0	0.0	0.0	34.0	-591,757	0	0	0	0	0	0	-591,757
Totals		34.0	0.0	0.0	34.0	-591,757	0	0	0	0	0	0	-591,757

The building peaked at hour 17 month 8 with a capacity of 34.0 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	FC	0.00	1.11	680.4	614.2	19.54	1.11	-28.37	20,856

System 1 Block FC - FAN COIL

***** COOLING COIL PEAK *****					***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****		
Peaked at Time ==> Mo/Hr: 8/17					Mo/Hr: 6/17			Mo/Hr: 13/ 1		
Outside Air ==> OADB/WB/HR: 91/ 73/ 98.0					OADB: 94			OADB: 22		
Space	Ret. Air	Ret. Air	Net	Percnt	Space	Percnt	Space Peak	Coil Peak	Percnt	
Sens.+Lat.	Sensible	Latent	Total	Of Tot	Sensible	Of Tot	Space Sens	Tot Sens	Of Tot	
(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	(Btuh)	(%)	(Btuh)	(Btuh)	(%)	
Envelope Loads										
Skylite Solr	0	0	0	0.00	0	0.00	0	0	0.00	
Skylite Cond	0	0	0	0.00	0	0.00	0	0	0.00	
Roof Cond	0	39,579	39,579	9.71	0	0.00	0	-24,243	4.10	
Glass Solar	43,472	0	43,472	10.67	59,774	16.58	0	0	0.00	
Glass Cond	35,946	0	35,946	8.82	44,749	12.41	-132,046	-132,046	22.31	
Wall Cond	50,088	8,668	58,756	14.42	54,034	14.99	-151,781	-189,990	32.11	
Partition	0	0	0	0.00	0	0.00	0	0	0.00	
Exposed Floor	0	0	0	0.00	0	0.00	-27,920	-27,920	4.72	
Infiltration	145,093	0	145,093	35.61	81,881	22.72	-223,718	-223,718	37.81	
Sub Total==>	274,598	48,247	322,845	79.23	240,438	66.70	-535,465	-597,918	101.04	
Internal Loads										
Lights	13,720	0	13,720	3.37	13,720	3.81	0	0	0.00	
People	21,600	0	21,600	5.30	12,000	3.33	0	0	0.00	
Misc	41,093	0	41,093	10.08	41,093	11.40	0	0	0.00	
Sub Total==>	76,413	0	76,413	18.75	66,813	18.54	0	0	0.00	
Ceiling Load	48,247	-48,247	0	0.00	53,216	14.76	-62,453	0	0.00	
Outside Air	0	0	0	0.00	0	0.00	0	0	0.00	
Sup. Fan Heat			6,161	1.51		0.00		6,161	-1.04	
Ret. Fan Heat		2,054	2,054	0.50		0.00		0	0.00	
Duct Heat Pkup		0	0	0.00		0.00		0	0.00	
CV/UNDR Sizing	0	0	0	0.00	0	0.00	0	0	0.00	
Exhaust Heat		0	0	0.00		0.00		0	0.00	
Terminal Bypass		0	0	-0.00		0.00		0	0.00	
Grand Total==>	399,258	2,054	407,473	100.00	360,467	100.00	-597,918	-591,757	100.00	

-----COOLING COIL SELECTION-----											-----AREAS-----				
	Total Capacity	Sens Cap.	Coil Airfl	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total	Glass (sf)	(%)			
	(Tons)	(Mbh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Part	ExFlr	Roof	Wall
Main Clg	34.0	407.5	318.6	23,104	76.1	63.2	69.8	61.3	57.4	67.2	20,856	0	698	13,588	0
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0					
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0					
Totals	34.0	407.5									17,450			2,717	16

-----HEATING COIL SELECTION-----				-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg	
(Mbh)	(cfm)	Deg F	Deg F	Vent			Clg Cfm/Sqft	1.11	SADB	61.5	96.1	
Main Htg	-591.8	23,104	72.2	96.1	Infil	4,171	4,171	Clg Cfm/Ton	680.40	Plenum	83.3	62.5
Aux Htg	0.0	0	0.0	0.0	Supply	23,104	23,104	Clg Sqft/Ton	614.21	Return	76.0	72.0
Preheat	-0.0	23,104	72.2	61.5	Mincfm	0	0	Clg Btuh/Sqft	19.54	Ret/OA	76.0	72.0
Reheat	0.0	0	0.0	0.0	Return	23,104	23,104	No. People	48	Runarnd	76.0	72.0
Humidif	0.0	0	0.0	0.0	Exhaust	0	0	Htg % OA	0.0	Fn MtrTD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg Cfm/Sqft	1.11	Fn BldTD	0.1	0.0
Total	-591.8				Auxil	0	0	Htg Btuh/Sqft	-28.37	Fn Frict	0.2	0.0

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room	1						
Space		Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space		76.0	63.2	50.0	69.8	29.2	
Main System							
Return Air Heat Pickup							-0.1
Return Fan							0.1
Return Air		76.0	63.2	50.0	69.8	29.2	
Outdoor Air		90.7	72.9	43.4	98.0	37.2	
Return/Outdoor Air Mix		76.0	63.2	50.0	69.8	29.2	
Blow through Fan							0.1
Entering Coil		76.1	63.2	49.9	69.8	29.2	
Leaving Coil		61.3	57.7	81.2	68.3	25.3	
Draw Through Fan							0.0
Duct Frictional Heat							0.2
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		61.5	57.7	80.6	68.3	25.4	
Supply Air		61.5	57.7	80.6	68.3	25.4	
Percent Outside Air				0.00 (%)			
Sensible Heat Ratio (SHR)				0.924			
Percent Supply Air Bypassing Coil				0.00 (%)			
Coil Airflow				23,104 (Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)								Room Mass (lb/ sqft)	Room Capac. (Btu/ sqft/F)	
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Roof	Summr Windo	Wintr Windo	Wall			Cell.
1	INTERIOR	0.000	0.800	0.000	0.000	0.044	0.900	0.973	0.270	0.317	124.6	26.14
Zone	1 Total/Ave.	0.000	0.800	0.000	0.000	0.044	0.900	0.973	0.270	0.317	124.6	26.14
System	1 Total/Ave.	0.000	0.800	0.000	0.000	0.044	0.900	0.973	0.270	0.317	124.6	26.14
Building		0.000	0.800	0.000	0.000	0.044	0.900	0.973	0.270	0.317	124.6	26.14

BUILDING AREAS - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Skl /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
1	INTERIOR	1	1	20,856	20,856	0	698	0	0	13,588	2,717	16	14,733
Zone	1 Total/Ave.				20,856	0	698	0	0	13,588	2,717	16	14,733
System	1 Total/Ave.				20,856	0	698	0	0	13,588	2,717	16	14,733
Building					20,856	0	698	0	0	13,588	2,717	16	14,733

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
 BLDG. M060, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.044 (Btu/Hr/Sq Ft/F)
 Overall Wall U-Value = 0.368 (Btu/Hr/Sq Ft/F)
 Overall Building U-Value = 0.226 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 2.25 (Btu/Hr/Sq Ft)
 Wall Overall Thermal Transfer Value (OTTVw) = 15.08 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M060, BASELINE

Main System 1 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.7	9	263	-29,588	4	140	1,155.2	0	0	0.0	0	0
5 - 10	3.4	8	231	-59,176	9	308	2,310.4	0	0	0.0	0	0
10 - 15	5.1	11	307	-88,764	12	403	3,465.6	0	0	0.0	0	0
15 - 20	6.8	8	213	-118,351	14	446	4,620.8	0	0	0.0	0	0
20 - 25	8.5	11	295	-147,939	16	519	5,776.0	0	0	0.0	0	0
25 - 30	10.2	9	266	-177,527	16	520	6,931.2	0	0	0.0	0	0
30 - 35	11.9	10	277	-207,115	10	319	8,086.3	0	0	0.0	0	0
35 - 40	13.6	5	154	-236,703	15	500	9,241.5	0	0	0.0	0	0
40 - 45	15.3	7	185	-266,291	4	115	10,396.7	0	0	0.0	0	0
45 - 50	17.0	6	176	-295,879	0	0	11,551.9	0	0	0.0	0	0
50 - 55	18.7	5	130	-325,466	0	0	12,707.1	0	0	0.0	0	0
55 - 60	20.4	4	110	-355,054	0	0	13,862.3	0	0	0.0	0	0
60 - 65	22.1	3	81	-384,642	0	0	15,017.5	0	0	0.0	0	0
65 - 70	23.8	1	22	-414,230	0	0	16,172.7	0	0	0.0	0	0
70 - 75	25.5	2	62	-443,818	0	0	17,327.9	0	0	0.0	0	0
75 - 80	27.2	1	30	-473,406	0	0	18,483.1	0	0	0.0	0	0
80 - 85	28.9	0	0	-502,994	0	0	19,638.3	0	0	0.0	0	0
85 - 90	30.6	0	0	-532,581	0	0	20,793.5	0	0	0.0	0	0
90 - 95	32.3	0	0	-562,169	0	0	21,948.7	0	0	0.0	0	0
95 - 100	34.0	0	0	-591,757	0	0	23,103.8	100	8,760	0.0	0	0
Hours Off	0.0	0	5,958	0	0	5,490	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M060, BASELINE

----- S Y S T E M L O A D P R O F I L E -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.7	9	263	-29,588	4	140	1,155.2	0	0	0.0	0	0
5 - 10	3.4	8	231	-59,176	9	308	2,310.4	0	0	0.0	0	0
10 - 15	5.1	11	307	-88,764	12	403	3,465.6	0	0	0.0	0	0
15 - 20	6.8	8	213	-118,351	14	446	4,620.8	0	0	0.0	0	0
20 - 25	8.5	11	295	-147,939	16	519	5,776.0	0	0	0.0	0	0
25 - 30	10.2	9	266	-177,527	16	520	6,931.2	0	0	0.0	0	0
30 - 35	11.9	10	277	-207,115	10	319	8,086.3	0	0	0.0	0	0
35 - 40	13.6	5	154	-236,703	15	500	9,241.5	0	0	0.0	0	0
40 - 45	15.3	7	185	-266,291	4	115	10,396.7	0	0	0.0	0	0
45 - 50	17.0	6	176	-295,879	0	0	11,551.9	0	0	0.0	0	0
50 - 55	18.7	5	130	-325,466	0	0	12,707.1	0	0	0.0	0	0
55 - 60	20.4	4	110	-355,054	0	0	13,862.3	0	0	0.0	0	0
60 - 65	22.1	3	81	-384,642	0	0	15,017.5	0	0	0.0	0	0
65 - 70	23.8	1	22	-414,230	0	0	16,172.7	0	0	0.0	0	0
70 - 75	25.5	2	62	-443,818	0	0	17,327.9	0	0	0.0	0	0
75 - 80	27.2	1	30	-473,406	0	0	18,483.1	0	0	0.0	0	0
80 - 85	28.9	0	0	-502,994	0	0	19,638.3	0	0	0.0	0	0
85 - 90	30.6	0	0	-532,581	0	0	20,793.5	0	0	0.0	0	0
90 - 95	32.3	0	0	-562,169	0	0	21,948.7	0	0	0.0	0	0
95 - 100	34.0	0	0	-591,757	0	0	23,103.8	100	8,760	0.0	0	0
Hours Off	0.0	0	5,958	0	0	5,490	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M060, BASELINE

March			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6	-132,358	0.0	-62,156	0.0	-154,276	0.0	-154,276	0.0	-154,276	0.0
2	43.3	39.7	-143,560	0.0	-163,319	0.0	-163,319	0.0	-163,319	0.0	-163,319	0.0
3	41.6	38.6	-155,120	0.0	-166,506	0.0	-166,506	0.0	-166,506	0.0	-166,506	0.0
4	40.6	37.5	-159,501	0.0	-171,057	0.0	-171,057	0.0	-171,057	0.0	-171,057	0.0
5	40.2	37.3	-167,126	0.0	-172,921	0.0	-172,921	0.0	-172,921	0.0	-172,921	0.0
6	40.6	37.8	-105,930	0.0	-117,736	0.0	-142,433	0.0	-142,433	0.0	-117,736	0.0
7	41.6	39.0	-78,118	0.0	-108,696	0.0	-133,389	0.0	-133,389	0.0	-108,696	0.0
8	43.3	40.7	-72,144	0.0	-122,803	0.0	-133,781	0.0	-133,781	0.0	-122,803	0.0
9	45.4	42.5	-62,564	0.0	-143,860	0.0	-130,482	0.0	-130,482	0.0	-143,860	0.0
10	47.9	44.3	-51,224	0.0	-152,961	0.0	-147,816	0.0	-147,816	0.0	-152,961	0.0
11	50.6	45.5	-21,011	0.0	-120,906	0.0	-116,962	0.0	-116,962	0.0	-120,906	0.0
12	53.3	46.8	0	0.0	-97,690	0.0	-93,746	0.0	-93,746	0.0	-97,690	0.0
13	55.8	48.5	0	0.0	-79,632	0.0	-75,688	0.0	-75,688	0.0	-79,632	0.0
14	58.0	49.6	0	0.0	-62,398	0.0	-58,450	0.0	-58,450	0.0	-62,398	0.0
15	59.6	50.3	0	0.0	-60,263	0.0	-56,320	0.0	-56,320	0.0	-60,263	0.0
16	60.7	50.9	0	0.0	-65,151	0.0	-61,208	0.0	-61,208	0.0	-65,151	0.0
17	61.0	50.9	0	0.0	-14,680	0.0	-23,083	0.0	-23,083	0.0	-14,680	0.0
18	60.7	50.7	0	0.0	-34,868	0.0	-36,066	0.0	-36,066	0.0	-34,868	0.0
19	59.6	50.7	0	0.0	-52,181	0.0	-53,379	0.0	-53,379	0.0	-52,181	0.0
20	58.0	50.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	55.8	49.4	0	0.0	-23,711	0.0	-24,892	0.0	-24,892	0.0	-23,711	0.0
22	53.3	47.8	0	0.0	-70,364	0.0	-70,364	0.0	-70,364	0.0	-70,364	0.0
23	50.6	45.9	0	0.0	-96,883	0.0	-96,883	0.0	-96,883	0.0	-96,883	0.0
24	47.9	43.8	0	0.0	-136,093	0.0	-136,093	0.0	-136,093	0.0	-136,093	0.0
April			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9	-22,213	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9	52.7	-29,185	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2	51.3	-39,048	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	52.9	50.2	-48,462	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9	49.6	-50,608	0.0	0	0.0	0	0.0	0	0.0	-43,470	0.0
6	51.2	49.2	0	0.0	0	0.0	0	0.0	0	0.0	-27,887	0.0
7	51.0	49.3	0	0.0	0	0.0	0	0.0	0	0.0	-15,974	0.0
8	51.6	49.9	0	0.0	0	0.0	0	0.0	0	0.0	-38,582	0.0
9	53.3	50.6	0	0.0	0	0.0	0	0.0	-30,063	0.0	-66,495	0.0
10	55.9	51.8	0	0.0	0	0.0	0	0.0	-35,205	0.0	-40,346	0.0
11	59.0	53.4	0	0.0	0	0.0	0	0.0	-14,035	0.0	-17,979	0.0
12	62.4	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5	57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8	60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2	60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2	59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M060, BASELINE

May Hour	OADB	OAWB	----- Design -----		----- Weekday -----			----- Saturday-----		----- Sunday -----		----- Monday -----		
			Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	66.6	62.3		0		0.0		0		0.0		0		0.0
2	64.5	60.4		0		0.0		0		0.0		0		0.0
3	62.7	59.1		0		0.0		0		0.0		0		0.0
4	61.2	58.1		0		0.0		0		0.0		0		0.0
5	60.0	57.1		0		0.0		0		0.0		0		0.0
6	59.3	56.6		0		0.0		0		0.0		0		0.0
7	59.0	56.5		0		0.0		0		0.0		0		0.0
8	59.5	56.6		0		0.0		0		0.0		0		0.0
9	60.9	56.6		0		0.0		0		0.0		0		0.0
10	63.0	57.2		0		0.0		0		0.0		0		0.0
11	65.7	58.1		0		0.0		0		0.0		0		0.0
12	68.7	59.8		0		0.0		0		0.0		0		0.0
13	71.7	61.6		0		0.0		0		0.0		0		0.0
14	74.5	63.4		0		0.0		0		0.0		0		0.0
15	76.6	64.8		0		6.2		0		0.0		0		0.0
16	78.0	65.6		0		18.2		0		0.0		0		0.0
17	78.5	65.6		0		21.7		0		9.5		0		11.2
18	78.2	65.8		0		19.7		0		10.4		0		10.5
19	77.5	65.6		0		13.6		0		6.9		0		7.0
20	76.3	66.1		0		18.8		0		13.3		0		13.4
21	74.8	67.2		0		10.2		0		5.0		0		5.0
22	73.0	66.4		0		8.7		0		4.2		0		4.2
23	70.9	65.4		0		6.5		0		1.9		0		1.9
24	68.7	64.0		0		2.9		0		0.0		0		0.0

June Hour	OADB	OAWB	----- Design -----		----- Weekday -----			----- Saturday-----		----- Sunday -----		----- Monday -----		
			Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	73.0	67.9		0		8.7		0		3.7		0		3.7
2	71.2	66.1		0		9.2		0		3.3		0		3.3
3	69.7	65.2		0		8.8		0		2.0		0		2.0
4	68.5	64.3		0		8.0		0		1.0		0		1.0
5	67.8	64.2		0		7.8		0		0.5		0		0.5
6	67.6	64.2		0		16.4		0		5.7		0		7.8
7	68.1	64.8		0		17.9		0		6.2		0		8.3
8	69.4	65.7		0		16.8		0		4.8		0		5.7
9	71.6	66.2		0		17.2		0		6.3		0		5.2
10	74.2	67.2		0		20.1		0		9.5		0		8.9
11	77.2	68.5		0		23.6		0		11.7		0		11.3
12	80.2	70.0		0		26.8		0		14.2		0		13.7
13	82.8	70.8		0		28.9		0		16.9		0		16.5
14	85.0	71.6		0		30.4		0		18.6		0		18.2
15	86.3	72.3		0		31.0		0		19.7		0		19.3
16	86.8	72.1		0		29.3		0		18.2		0		17.8
17	86.6	71.7		0		33.9		0		21.5		0		22.8
18	85.8	71.5		0		29.9		0		21.3		0		21.5
19	84.7	71.2		0		21.5		0		15.5		0		15.7
20	83.2	71.5		0		29.5		0		26.1		0		26.3
21	81.4	71.7		0		18.1		0		11.2		0		11.2
22	79.3	71.4		0		17.0		0		11.8		0		11.8
23	77.2	70.5		0		14.4		0		8.9		0		8.9
24	75.1	69.1		0		11.2		0		4.9		0		4.9

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M060, BASELINE

July Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0	69.3	0	10.4	0	2.9	0	3.3	0	3.3	0	3.3
2	70.5	68.0	0	8.7	0	1.8	0	2.1	0	2.1	0	2.1
3	69.4	67.1	0	8.2	0	1.5	0	1.6	0	1.6	0	1.6
4	68.5	66.4	0	7.4	0	0.7	0	0.7	0	0.7	0	0.7
5	67.9	66.0	0	7.3	0	0.7	0	0.8	0	0.8	0	0.8
6	67.7	65.9	0	15.3	0	7.3	0	5.2	0	5.2	0	7.8
7	68.1	66.3	0	18.1	0	8.3	0	6.3	0	6.3	0	8.6
8	69.1	67.3	0	16.2	0	5.4	0	4.7	0	4.7	0	5.4
9	70.8	68.0	0	16.0	0	4.5	0	5.9	0	5.9	0	4.5
10	72.9	69.1	0	19.6	0	8.0	0	8.7	0	8.7	0	8.0
11	75.2	70.5	0	22.9	0	10.1	0	10.6	0	10.6	0	10.1
12	77.5	71.7	0	25.7	0	12.1	0	12.5	0	12.5	0	12.1
13	79.6	72.7	0	28.4	0	14.5	0	14.9	0	14.9	0	14.5
14	81.3	73.5	0	29.0	0	16.5	0	16.9	0	16.9	0	16.5
15	82.3	73.7	0	29.7	0	17.0	0	17.4	0	17.4	0	17.0
16	82.7	73.5	0	27.7	0	16.1	0	16.6	0	16.6	0	16.1
17	82.5	73.1	0	32.0	0	20.9	0	19.5	0	19.5	0	20.9
18	82.0	72.6	0	28.4	0	19.4	0	19.2	0	19.2	0	19.4
19	81.1	73.2	0	20.7	0	14.5	0	14.3	0	14.3	0	14.5
20	79.9	73.8	0	30.0	0	25.0	0	24.8	0	24.8	0	25.0
21	78.5	73.9	0	16.3	0	10.2	0	10.2	0	10.2	0	10.2
22	76.9	73.1	0	16.4	0	11.9	0	11.9	0	11.9	0	11.9
23	75.2	71.9	0	13.8	0	8.3	0	8.3	0	8.3	0	8.3
24	73.5	70.8	0	9.8	0	4.5	0	4.5	0	4.5	0	4.5

August Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7	70.2	0	12.2	0	2.9	0	3.5	0	3.5	0	3.5
2	71.2	69.0	0	8.9	0	2.0	0	2.3	0	2.3	0	2.3
3	69.9	68.0	0	8.1	0	1.5	0	1.7	0	1.7	0	1.7
4	68.8	67.1	0	7.3	0	0.7	0	0.8	0	0.8	0	0.8
5	68.0	66.6	0	7.1	0	0.0	0	0.0	0	0.0	0	0.0
6	67.5	66.2	0	12.7	0	5.8	0	3.5	0	3.5	0	6.0
7	67.3	66.1	0	16.8	0	7.5	0	5.2	0	5.2	0	7.7
8	67.8	66.5	0	14.9	0	4.2	0	3.4	0	3.4	0	4.3
9	69.1	67.0	0	16.1	0	3.5	0	4.8	0	4.8	0	3.6
10	71.2	67.8	0	19.7	0	5.8	0	6.5	0	6.5	0	5.9
11	73.8	68.7	0	22.4	0	7.8	0	8.2	0	8.2	0	7.8
12	76.5	70.0	0	24.7	0	10.2	0	10.7	0	10.7	0	10.2
13	79.1	71.2	0	26.6	0	13.8	0	14.2	0	14.2	0	13.8
14	81.1	72.6	0	28.0	0	15.6	0	16.1	0	16.1	0	15.6
15	82.5	73.6	0	29.2	0	16.9	0	17.4	0	17.4	0	16.9
16	83.0	73.7	0	27.3	0	14.8	0	15.2	0	15.2	0	14.8
17	82.8	73.5	0	31.3	0	20.7	0	19.4	0	19.4	0	20.7
18	82.3	73.5	0	26.3	0	17.3	0	17.2	0	17.2	0	17.3
19	81.5	73.1	0	21.4	0	14.2	0	14.0	0	14.0	0	14.2
20	80.4	73.7	0	29.6	0	24.8	0	24.6	0	24.6	0	24.8
21	79.1	74.9	0	17.2	0	10.9	0	10.9	0	10.9	0	10.9
22	77.6	73.9	0	16.8	0	12.1	0	12.1	0	12.1	0	12.1
23	76.0	72.7	0	13.7	0	9.6	0	9.6	0	9.6	0	9.6
24	74.3	71.3	0	9.7	0	4.6	0	4.6	0	4.6	0	4.6

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M060, BASELINE

September			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	69.8	66.1	0	7.1	0	0.0	0	0.0	0	0.0	0	0.0
2	68.0	64.5	0	5.2	0	0.0	0	0.0	0	0.0	0	0.0
3	66.3	63.0	0	4.7	0	0.0	0	0.0	0	0.0	0	0.0
4	64.9	61.9	0	3.9	0	0.0	0	0.0	0	0.0	0	0.0
5	63.9	61.3	0	3.3	0	0.0	0	0.0	0	0.0	0	0.0
6	63.2	61.0	0	8.4	0	0.0	0	0.0	0	0.0	0	0.0
7	63.0	60.8	0	11.4	0	0.0	0	0.0	0	0.0	0	0.0
8	63.4	61.4	0	11.6	0	0.0	0	0.0	0	0.0	0	0.0
9	64.7	61.8	0	11.8	0	0.0	0	0.0	0	0.0	0	0.0
10	66.6	62.1	0	13.0	0	0.0	0	0.0	0	0.0	0	0.0
11	69.1	62.9	0	15.6	0	0.0	0	0.0	0	0.0	0	0.0
12	71.8	63.7	0	18.1	0	4.2	0	1.8	0	1.8	0	4.2
13	74.5	65.5	0	20.1	0	6.9	0	7.2	0	7.2	0	6.9
14	77.0	67.1	0	21.4	0	8.4	0	8.7	0	8.7	0	8.4
15	78.9	68.2	0	23.5	0	9.2	0	9.6	0	9.6	0	9.2
16	80.2	68.6	0	21.8	0	9.2	0	9.5	0	9.5	0	9.2
17	80.6	68.5	0	23.7	0	13.3	0	12.3	0	12.3	0	13.3
18	80.4	68.9	0	19.0	0	11.4	0	11.2	0	11.2	0	11.4
19	79.7	70.0	0	16.4	0	10.0	0	9.8	0	9.8	0	10.0
20	78.7	71.2	0	22.6	0	20.2	0	20.0	0	20.0	0	20.2
21	77.3	71.6	0	13.4	0	7.7	0	7.7	0	7.7	0	7.7
22	75.6	70.5	0	12.5	0	8.5	0	8.5	0	8.5	0	8.5
23	73.7	69.4	0	10.1	0	5.5	0	5.5	0	5.5	0	5.5
24	71.8	67.7	0	6.9	0	1.4	0	1.4	0	1.4	0	1.4

October			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	54.8	51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	52.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	51.2	48.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	49.8	47.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	48.8	46.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	48.2	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	47.9	45.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	48.5	46.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	50.3	47.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	52.9	48.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	56.2	49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	59.6	51.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	62.9	53.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	65.5	55.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	67.3	56.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	67.9	56.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	67.7	56.4	0	5.5	0	0.0	0	0.0	0	0.0	0	0.0
18	67.0	56.6	0	5.6	0	0.0	0	0.0	0	0.0	0	0.0
19	66.0	57.6	0	3.5	0	0.0	0	0.0	0	0.0	0	0.0
20	64.6	57.9	0	8.9	0	0.0	0	0.0	0	0.0	0	0.0
21	62.9	57.3	0	0.5	0	0.0	0	0.0	0	0.0	0	0.0
22	61.0	56.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	59.0	54.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	56.9	53.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M060, BASELINE

November			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	-591,757	0.0	0	0.0	-108,684	0.0	-108,684	0.0	-108,684	0.0
2	46.9	44.1	-98,422	0.0	0	0.0	-117,220	0.0	-117,220	0.0	-117,220	0.0
3	45.5	42.8	-103,925	0.0	0	0.0	-113,518	0.0	-113,518	0.0	-113,518	0.0
4	44.6	41.9	-113,339	0.0	0	0.0	-127,586	0.0	-127,586	0.0	-127,586	0.0
5	44.4	42.0	-115,485	0.0	0	0.0	-132,969	0.0	-132,969	0.0	-132,969	0.0
6	44.8	42.7	-59,773	0.0	0	0.0	-106,704	0.0	-106,704	0.0	-82,007	0.0
7	45.9	43.9	-49,352	0.0	-45,492	0.0	-98,617	0.0	-98,617	0.0	-73,920	0.0
8	47.8	46.0	0	0.0	-56,557	0.0	-67,535	0.0	-67,535	0.0	-56,557	0.0
9	50.2	48.0	0	0.0	-59,240	0.0	-45,862	0.0	-45,862	0.0	-59,240	0.0
10	52.9	49.9	0	0.0	-52,019	0.0	-46,873	0.0	-46,873	0.0	-52,019	0.0
11	55.8	51.1	0	0.0	-58,217	0.0	-54,273	0.0	-54,273	0.0	-58,217	0.0
12	58.5	52.0	0	0.0	-48,936	0.0	-44,993	0.0	-44,993	0.0	-48,936	0.0
13	60.9	52.5	0	0.0	-23,836	0.0	-19,892	0.0	-19,892	0.0	-23,836	0.0
14	62.8	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	64.0	53.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	64.4	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	64.1	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	63.2	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	61.8	54.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	60.0	53.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	57.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	53.2	49.5	0	0.0	-38,046	0.0	-40,159	0.0	-40,159	0.0	-38,046	0.0
24	50.8	47.6	0	0.0	-94,636	0.0	-94,636	0.0	-94,636	0.0	-94,636	0.0

December			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	-176,631	0.0	-204,531	0.0	-204,531	0.0	-204,531	0.0	-204,531	0.0
2	37.1	35.1	-187,388	0.0	-207,593	0.0	-207,593	0.0	-207,593	0.0	-207,593	0.0
3	37.4	35.5	-191,773	0.0	-214,868	0.0	-214,868	0.0	-214,868	0.0	-214,868	0.0
4	38.1	36.2	-200,737	0.0	-209,519	0.0	-209,519	0.0	-209,519	0.0	-209,519	0.0
5	39.3	37.6	-208,362	0.0	-204,269	0.0	-204,269	0.0	-204,269	0.0	-204,269	0.0
6	40.9	39.2	-147,171	0.0	-138,934	0.0	-163,627	0.0	-163,627	0.0	-138,934	0.0
7	42.7	41.2	-144,837	0.0	-141,759	0.0	-166,460	0.0	-166,460	0.0	-141,759	0.0
8	44.7	43.1	-97,465	0.0	-123,763	0.0	-134,737	0.0	-134,737	0.0	-123,763	0.0
9	46.8	45.3	-62,789	0.0	-116,413	0.0	-103,035	0.0	-103,035	0.0	-116,413	0.0
10	48.8	47.0	-45,330	0.0	-100,655	0.0	-95,510	0.0	-95,510	0.0	-100,655	0.0
11	50.7	48.1	-33,765	0.0	-102,207	0.0	-98,264	0.0	-98,264	0.0	-102,207	0.0
12	52.2	48.8	-13,203	0.0	-93,584	0.0	-89,640	0.0	-89,640	0.0	-93,584	0.0
13	53.4	49.2	0	0.0	-86,412	0.0	-82,469	0.0	-82,469	0.0	-86,412	0.0
14	54.1	49.2	0	0.0	-66,903	0.0	-62,959	0.0	-62,959	0.0	-66,903	0.0
15	54.4	48.9	0	0.0	-60,775	0.0	-56,832	0.0	-56,832	0.0	-60,775	0.0
16	54.0	48.2	0	0.0	-77,352	0.0	-73,409	0.0	-73,409	0.0	-77,352	0.0
17	53.0	47.3	0	0.0	-78,783	0.0	-87,182	0.0	-87,182	0.0	-78,783	0.0
18	51.4	46.3	0	0.0	-81,013	0.0	-82,211	0.0	-82,211	0.0	-81,013	0.0
19	49.3	45.4	-15,375	0.0	-91,808	0.0	-93,006	0.0	-93,006	0.0	-91,808	0.0
20	47.0	43.5	0	0.0	-12,005	0.0	-13,203	0.0	-13,203	0.0	-12,005	0.0
21	44.5	41.5	-74,894	0.0	-113,501	0.0	-113,501	0.0	-113,501	0.0	-113,501	0.0
22	42.2	39.3	-100,660	0.0	-125,740	0.0	-125,740	0.0	-125,740	0.0	-125,740	0.0
23	40.1	37.6	-130,311	0.0	-150,387	0.0	-150,387	0.0	-150,387	0.0	-150,387	0.0
24	38.5	36.2	-166,323	0.0	-188,765	0.0	-188,765	0.0	-188,765	0.0	-188,765	0.0

BUILDING TEMPERATURE PROFILES - ALTERNATIVE 1
BLDG M060, BASELINE

----- B U I L D I N G T E M P E R A T U R E P R O F I L E S -----

Temperature	-----	Room Number	-----
Range	1		
(F)			
Max. Temp.	76.0		
Mo./Hr.	5 15		
Day Type	1		
	 Number of Hours	
Above 100	0		
95 - 100	0		
90 - 95	0		
85 - 90	0		
80 - 85	0		
75 - 80	3,723		
70 - 75	5,037		
65 - 70	0		
60 - 65	0		
55 - 60	0		
50 - 55	0		
Below 50	0		
Min. Temp.	70.4		
Mo./Hr.	10 12		
Day Type	5		

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	14,159	49	1,496	3
Feb	12,789	49	1,548	3
March	14,062	45	871	2
April	11,200	45	17	1
May	15,392	76	0	0
June	26,763	88	0	0
July	26,580	88	0	0
Aug	25,884	88	0	0
Sept	19,019	80	0	0
Oct	11,421	67	0	0
Nov	12,348	45	295	7
Dec	14,150	49	1,117	3
Total	203,767	88	5,344	7

Building Energy Consumption = 58,967 (Btu/Sq Ft/Year)
 Source Energy Consumption = 127,017 (Btu/Sq Ft/Year)

Floor Area = 20,856 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, BASELINE

1	EQ2001	GAS FIRE TUBE HOT WATER												
	GAS	1496	1548	871	17	0	0	0	0	0	0	295	1117	5,344
	PK	3.2	3.2	2.1	0.8	0.0	0.0	0.0	0.0	0.0	0.0	7.1	2.6	7.1
1	EQ5020	HEAT WATER CIRC. PUMP C.V.												
	ELEC	1934	1747	1854	112	0	0	0	0	0	920	1934		8,502
	PK	2.6	2.6	2.6	2.6	0.0	0.0	0.0	0.0	0.0	2.6	2.6		2.6
1	EQ5240	BOILER FORCED DRAFT FAN												
	ELEC	440	398	422	25	0	0	0	0	0	209	440		1,935
	PK	0.6	0.6	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.6	0.6		0.6
1	EQ5307	BOILER CONTROLS												
	ELEC	372	336	356	22	0	0	0	0	0	177	372		1,635
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.5	0.5		0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M060, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 88.4 (kW)
 Yearly Time of Peak 20 (hr) 6 (mo)
 Hour 20 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1100S	AIR-CLD RECIP 25-45 TONS	42.9	48.57
Sub Total			42.9	48.57
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.3	8.26
Sub Total			7.3	8.26
Sub Total			0.0	0.00
Miscellaneous				
	Lights		8.0	9.10
	Base Utilities		0.0	0.00
	Misc Equipment		30.1	34.07
Sub Total			38.1	43.17
Grand Total			88.4	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M060, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 20,856
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-bf)
Primary Heating	3,570.0	534,361.8	44.4	599,043.5	29.4
Primary Cooling					
Compressor	45,556.4	0.0	12.6	466,498.8	22.9
Tower/Cond Fans	3,731.3	0.0	1.0	38,208.4	1.9
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	827.1	0.0	0.2	8,469.5	0.4
Auxiliary					
Supply Fans	63,955.1	0.0	17.7	654,901.7	32.2
Circulation Pumps	15,670.2	0.0	4.3	160,463.3	7.9
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	79,625.3	0.0	22.1	815,365.0	40.1
Lighting	25,412.0	0.0	7.1	260,219.7	12.5
Receptacle	45,044.6	0.0	12.5	461,258.2	22.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	203,766.8	534,361.8	100.0	2,649,063.0	129.3

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#2

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	12,193	46	1,251	3
Feb	11,013	46	1,305	3
March	12,101	45	683	2
April	11,041	45	0	0
May	15,141	72	0	0
June	24,326	84	0	0
July	24,185	84	0	0
Aug	23,604	83	0	0
Sept	18,102	76	0	0
Oct	11,421	64	0	0
Nov	11,314	45	175	1
Dec	12,151	45	915	2
Total	186,593	84	4,329	3

Building Energy Consumption = 51,292 (Btu/Sq Ft/Year)
 Source Energy Consumption = 113,464 (Btu/Sq Ft/Year)

Floor Area = 20,856 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#2

1	EQ2001	GAS FIRE TUBE HOT WATER												
	GAS	1251	1305	683	0	0	0	0	0	0	0	175	915	4,329
	PK	2.8	2.8	1.7	0.5	0.0	0.0	0.0	0.0	0.0	0.0	1.3	2.2	2.8
1	EQ5020	HEAT WATER CIRC. PUMP C.V.												
	ELEC	9	8	8	0	0	0	0	0	0	0	3	9	37
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ5240	BOILER FORCED DRAFT FAN												
	ELEC	399	361	343	0	0	0	0	0	0	0	140	383	1,625
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5
1	EQ5307	BOILER CONTROLS												
	ELEC	372	336	320	0	0	0	0	0	0	0	130	356	1,514
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M060, ECO#2

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 83.7 (kW)
Yearly Time of Peak 20 (hr) 6 (mo)

Hour 20 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1100S	AIR-CLD RECIP 25-45 TONS	38.2	45.68
Sub Total			38.2	45.68
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.3	8.73
Sub Total			7.3	8.73
Sub Total			0.0	0.00
Miscellaneous				
	Lights		8.0	9.61
	Base Utilities		0.0	0.00
	Misc Equipment		30.1	35.98
Sub Total			38.1	45.59
Grand Total			83.7	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M060, ECO#2

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 20,856
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	3,139.8	432,898.1	41.5	487,834.2	24.0
Primary Cooling					
Compressor	44,473.5	0.0	14.2	455,409.8	22.4
Tower/Cond Fans	3,646.6	0.0	1.2	37,341.7	1.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	883.2	0.0	0.3	9,044.0	0.4
Auxiliary					
Supply Fans	63,955.6	0.0	20.4	654,907.0	32.2
Circulation Pumps	37.4	0.0	0.0	382.8	0.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	63,993.0	0.0	20.4	655,289.8	32.2
Lighting	25,412.0	0.0	8.1	260,219.7	12.5
Receptacle	45,044.6	0.0	14.4	461,258.2	22.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	186,592.8	432,898.1	100.0	2,366,397.2	115.4

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 60
PAGE

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M060, ECO#3

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	12,221	47	1,460	3
Feb	11,039	47	1,508	3
March	12,205	45	832	2
April	11,072	45	10	1
May	14,944	73	0	0
June	24,744	85	0	0
July	24,493	85	0	0
Aug	23,877	84	0	0
Sept	18,050	77	0	0
Oct	11,421	64	0	0
Nov	11,409	45	270	6
Dec	12,178	45	1,085	3
Total	187,653	85	5,164	6

Building Energy Consumption = 55,471 (Btu/Sq Ft/Year)
Source Energy Consumption = 118,200 (Btu/Sq Ft/Year)

Floor Area = 20,856 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#3

1	EQ2001		GAS FIRE TUBE HOT WATER												
	GAS	1460	1508	832	10	0	0	0	0	0	270	1085		5,164	
	PK	3.1	3.0	2.0	0.8	0.0	0.0	0.0	0.0	0.0	6.1	2.5		6.1	
1	EQ5020		HEAT WATER CIRC. PUMP C.V.												
	ELEC	10	9	9	0	0	0	0	0	0	4	9		42	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.0	
1	EQ5240		BOILER FORCED DRAFT FAN												
	ELEC	427	386	409	16	0	0	0	0	0	194	409		1,841	
	PK	0.6	0.6	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.6	0.6		0.6	
1	EQ5307		BOILER CONTROLS												
	ELEC	372	336	356	14	0	0	0	0	0	169	356		1,604	
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.5	0.5		0.5	

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M060, ECO#3

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 84.9 (kW)
 Yearly Time of Peak 20 (hr) 6 (mo)

Hour 20 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1100S	AIR-CLD RECIP 25-45 TONS	39.5	46.50
Sub Total			39.5	46.50
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.3	8.60
Sub Total			7.3	8.60
Sub Total			0.0	0.00
Miscellaneous				
	Lights		8.0	9.47
	Base Utilities		0.0	0.00
	Misc Equipment		30.1	35.44
Sub Total			38.1	44.91
Grand Total			84.9	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M060, ECO#3

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 20,856
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	3,444.5	516,435.6	45.7	578,888.3	28.5
Primary Cooling					
Compressor	45,206.7	0.0	13.3	462,917.8	22.8
Tower/Cond Fans	3,705.7	0.0	1.1	37,946.8	1.9
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	841.5	0.0	0.2	8,617.0	0.4
Auxiliary					
Supply Fans	63,955.6	0.0	18.9	654,907.0	32.2
Circulation Pumps	42.3	0.0	0.0	433.5	0.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	63,997.9	0.0	18.9	655,340.5	32.2
Lighting	25,412.0	0.0	7.5	260,219.7	12.5
Receptacle	45,044.6	0.0	13.3	461,258.2	22.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	187,653.1	516,435.6	100.0	2,465,188.3	120.3

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M060, ECO #12

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	14,141	49	1,344	3
Feb	12,773	49	1,406	3
March	13,678	45	658	2
April	11,041	45	0	0
May	12,846	68	0	0
June	23,967	83	0	0
July	23,314	84	0	0
Aug	22,489	83	0	0
Sept	16,145	77	0	0
Oct	11,421	45	0	0
Nov	11,635	45	130	1
Dec	14,019	45	966	2
Total	187,471	84	4,505	3

Building Energy Consumption = 52,278 (Btu/Sq Ft/Year)
Source Energy Consumption = 114,782 (Btu/Sq Ft/Year)

Floor Area = 20,856 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO #12

1	EQ2001	GAS FIRE TUBE HOT WATER												
	GAS	1344	1406	658	0	0	0	0	0	0	0	130	966	4,505
	PK	2.9	2.9	1.9	0.3	0.0	0.0	0.0	0.0	0.0	0.0	1.4	2.4	2.9
1	EQ5020	HEAT WATER CIRC. PUMP C.V.												
	ELEC	1934	1747	1594	0	0	0	0	0	0	0	421	1854	7,550
	PK	2.6	2.6	2.6	2.6	0.0	0.0	0.0	0.0	0.0	0.0	2.6	2.6	2.6
1	EQ5240	BOILER FORCED DRAFT FAN												
	ELEC	423	382	348	0	0	0	0	0	0	0	92	405	1,649
	PK	0.6	0.6	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.6	0.6
1	EQ5307	BOILER CONTROLS												
	ELEC	372	336	306	0	0	0	0	0	0	0	81	356	1,452
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M060, ECO #12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 83.6 (kW)
 Yearly Time of Peak 20 (hr) 7 (mo)

Hour 20 Month 7

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1100S	AIR-CLD RECIP 25-45 TONS	38.1	45.62
Sub Total			38.1	45.62
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.3	8.74
Sub Total			7.3	8.74
Sub Total			0.0	0.00
Miscellaneous				
	Lights		8.0	9.62
	Base Utilities		0.0	0.00
	Misc Equipment		30.1	36.02
Sub Total			38.1	45.64
Grand Total			83.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M060, ECO #12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 20,856
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	3,101.4	450,478.1	42.3	505,946.3	24.9
Primary Cooling					
Compressor	33,219.4	0.0	10.4	340,167.9	16.7
Tower/Cond Fans	2,749.4	0.0	0.9	28,153.9	1.4
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	666.0	0.0	0.2	6,819.9	0.3
Auxiliary					
Supply Fans	63,955.6	0.0	20.0	654,907.0	32.2
Circulation Pumps	13,322.4	0.0	4.2	136,421.8	6.7
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	77,278.0	0.0	24.2	791,328.8	38.9
Lighting	25,412.0	0.0	8.0	260,219.7	12.5
Receptacle	45,044.6	0.0	14.1	461,258.2	22.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	187,471.0	450,478.1	100.0	2,393,894.5	116.8

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

V 60
 PAGE

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#13

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	14,902	49	1,496	3
Feb	13,471	49	1,548	3
March	14,817	45	871	2
April	11,931	45	17	1
May	16,954	82	0	0
June	28,136	94	0	0
July	27,799	93	0	0
Aug	27,304	93	0	0
Sept	19,796	86	0	0
Oct	12,182	75	0	0
Nov	13,079	45	295	7
Dec	14,905	49	1,117	3
Total	215,274	94	5,344	7

Building Energy Consumption = 60,850 (Btu/Sq Ft/Year)
 Source Energy Consumption = 132,667 (Btu/Sq Ft/Year)

Floor Area = 20,856 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#13

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	----- Monthly Consumption -----												Total	
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec		
0	LIGHTS														
	ELEC	2155	1946	2172	2082	2164	2100	2146	2172	2082	2164	2082	2146	25,412	
	PK	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	
1	MISC LD														
	ELEC	3826	3455	3826	3702	3826	3702	3826	3826	3702	3826	3702	3826	45,045	
	PK	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	
2	MISC LD														
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
3	MISC LD														
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
4	MISC LD														
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
5	MISC LD														
	P HOTH2O	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
6	MISC LD														
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1	EQ1100S														
	ELEC	0	AIR-CLD RECIP 25-45 TONS				3390	10783	10235	9658	4810	0	0	0	38,875
	PK	0.0	0.0	0.0	0.0	35.1	48.2	44.9	44.4	37.3	25.7	0.0	0.0	48.2	
1	EQ5200														
	ELEC	0	CONDENSER FANS				243	803	757	710	356	0	0	0	2,869
	PK	0.0	0.0	0.0	0.0	3.0	6.5	4.2	4.2	3.3	1.0	0.0	0.0	6.5	
1	EQ5001														
	ELEC	0	CHILLED WATER PUMP C.V.				564	1435	1451	1451	702	0	0	0	5,603
	PK	0.0	0.0	0.0	0.0	2.6	2.6	2.6	2.6	2.6	2.6	0.0	0.0	2.6	
1	EQ5303														
	ELEC	0	CONTROLS				65	166	167	167	81	0	0	0	646
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3	
2	EQ1750														
	ELEC	609	AIR-CLD CTV ICE-CHILL H2O				1098	3544	3428	3542	2506	627	601	621	18,358
	PK	9.2	9.2	9.2	9.2	22.4	22.4	23.2	23.1	22.4	22.4	9.2	9.2	23.2	

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#13

2	EQ5205		CONDENSER FANS											
	ELEC	10	9	10	10	12	16	16	17	14	10	10	10	144
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
2	EQ5001		CHILLED WATER PUMP C.V.											
	ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	EQ5309		CONTROLS											
	ELEC	124	112	124	120	160	330	341	329	286	124	120	124	2,294
	PK	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
1	EQ4371		FAN COIL SUPPLY FAN											
	ELEC	5432	4906	5432	5257	5432	5257	5432	5432	5257	5432	5257	5432	63,956
	PK	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
1	EQ2001		GAS FIRE TUBE HOT WATER											
	GAS	1496	1548	871	17	0	0	0	0	0	0	295	1117	5,344
	PK	3.2	3.2	2.1	0.8	0.0	0.0	0.0	0.0	0.0	0.0	7.1	2.6	7.1
1	EQ5020		HEAT WATER CIRC. PUMP C.V.											
	ELEC	1934	1747	1854	112	0	0	0	0	0	0	920	1934	8,502
	PK	2.6	2.6	2.6	2.6	0.0	0.0	0.0	0.0	0.0	0.0	2.6	2.6	2.6
1	EQ5240		BOILER FORCED DRAFT FAN											
	ELEC	440	398	422	25	0	0	0	0	0	0	209	440	1,935
	PK	0.6	0.6	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.6	0.6
1	EQ5307		BOILER CONTROLS											
	ELEC	372	336	356	22	0	0	0	0	0	0	177	372	1,630
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M060, ECO#13

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 93.8 (kW)
 Yearly Time of Peak 20 (hr) 6 (mo)

Hour 20 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1100S	AIR-CLD RECIP 25-45 TONS	48.4	51.55
Sub Total			48.4	51.55
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.3	7.78
Sub Total			7.3	7.78
Sub Total			0.0	0.00
Miscellaneous				
	Lights		8.0	8.57
	Base Utilities		0.0	0.00
	Misc Equipment		30.1	32.09
Sub Total			38.1	40.66
Grand Total			93.8	100.00

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

January

Hour	Design		Design			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity
			(Ton)	(Ton)	(kW)	(Ton-Hr)
1	42.7	35.4	0.0	0.0	0.0	110
2	41.8	34.7	0.0	2.2	3.6	111
3	41.1	34.4	0.0	0.0	0.0	110
4	40.6	34.0	0.0	2.2	3.6	111
5	40.4	34.0	0.0	0.0	0.0	110
6	40.8	34.4	0.0	2.2	3.6	111
7	41.6	35.0	0.0	0.0	0.0	110
8	43.2	36.5	0.0	2.2	3.6	111
9	45.5	38.5	0.0	0.0	0.0	111
10	48.1	40.4	0.0	0.0	0.0	111
11	51.0	42.2	0.0	0.0	0.0	111
12	53.8	43.8	0.0	0.0	0.0	111
13	55.9	45.0	0.0	0.0	0.0	110
14	57.3	45.5	0.0	0.0	0.0	109
15	57.8	45.6	0.0	0.0	0.0	108
16	57.3	44.8	0.0	0.0	0.0	107
17	56.1	43.9	0.0	0.0	0.0	107
18	54.2	42.7	0.0	0.0	0.0	107
19	51.9	41.6	0.0	0.0	0.0	107
20	49.6	40.2	0.0	0.0	0.0	107
21	47.7	39.1	0.0	0.0	0.0	107
22	46.0	37.9	0.0	0.0	0.0	107
23	44.6	36.8	0.0	0.0	0.0	107
24	43.6	36.1	0.0	0.0	0.0	107

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
			(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	33.4	30.4	0.0	5.4	8.5	111	0.0	6.5	9.2	111
2	32.1	29.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	31.7	29.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	31.9	29.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	32.6	30.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	33.6	31.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	35.0	32.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	36.6	34.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	38.5	36.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	40.4	37.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	42.3	38.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	44.2	39.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	45.8	40.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	47.2	41.1	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	48.2	41.6	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	48.9	41.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	49.1	41.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	48.7	41.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	47.4	41.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	45.5	40.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	43.1	38.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	40.4	36.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	37.7	34.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	35.3	32.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	33.4	30.4	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	32.1	29.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	31.7	29.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	31.9	29.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	32.6	30.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	33.6	31.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	35.0	32.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	36.6	34.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	38.5	36.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	40.4	37.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	42.3	38.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	44.2	39.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	45.8	40.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	47.2	41.1	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	48.2	41.6	0.0	0.0	0.0	107	0.0	0.0	0.0	107
16	48.9	41.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	49.1	41.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	48.7	41.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	47.4	41.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	45.5	40.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	43.1	38.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	40.4	36.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	37.7	34.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	35.3	32.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

---- B U I L D I N G C O O L I N G D E M A N D S A N D T H E R M A L S T O R A G E ----

February

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	
	(F)	(F)	(Ton)	(Ton)	(kW)	
1	42.8	35.6	0.0	6.5	9.2	111
2	42.0	34.9	0.0	0.0	0.0	110
3	41.4	34.5	0.0	2.2	3.6	111
4	41.0	34.2	0.0	0.0	0.0	110
5	40.8	34.0	0.0	2.2	3.6	111
6	41.1	34.4	0.0	0.0	0.0	110
7	41.9	35.0	0.0	2.2	3.6	111
8	43.3	36.5	0.0	0.0	0.0	110
9	45.3	38.2	0.0	0.0	0.0	110
10	47.7	39.5	0.0	0.0	0.0	110
11	50.3	41.3	0.0	0.0	0.0	110
12	52.8	42.5	0.0	0.0	0.0	110
13	54.7	43.4	0.0	0.0	0.0	109
14	55.9	44.0	0.0	0.0	0.0	108
15	56.4	44.2	0.0	0.0	0.0	107
16	55.9	43.6	0.0	0.0	0.0	106
17	54.8	42.6	0.0	0.0	0.0	106
18	53.1	41.4	0.0	0.0	0.0	106
19	51.1	40.4	0.0	0.0	0.0	106
20	49.1	39.4	0.0	0.0	0.0	106
21	47.4	38.5	0.0	0.0	0.0	106
22	45.8	37.6	0.0	0.0	0.0	106
23	44.5	36.9	0.0	0.0	0.0	106
24	43.6	36.1	0.0	0.0	0.0	106

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	37.5	34.5	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	36.0	33.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	34.7	31.8	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	33.6	30.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	32.8	30.1	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	32.2	29.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	32.1	29.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	32.5	30.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	33.9	31.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	36.0	33.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	38.5	34.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	41.3	36.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	43.8	38.1	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	45.9	39.5	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	47.2	40.4	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	QAWB (F)									
16	47.7	40.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
17	47.5	40.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
18	47.0	39.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
19	46.2	39.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
20	45.1	39.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
21	43.8	39.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
22	42.3	38.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
23	40.7	37.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
24	39.1	35.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	

Hour	----- Sunday -----						----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	QAWB (F)									
1	37.5	34.5	0.0	6.5	9.2	111	0.0	6.5	9.2	111	
2	36.0	33.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
3	34.7	31.8	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
4	33.6	30.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
5	32.8	30.1	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
6	32.2	29.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
7	32.1	29.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
8	32.5	30.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
9	33.9	31.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
10	36.0	33.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
11	38.5	34.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
12	41.3	36.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
13	43.8	38.1	0.0	0.0	0.0	109	0.0	0.0	0.0	109	
14	45.9	39.5	0.0	0.0	0.0	108	0.0	0.0	0.0	108	
15	47.2	40.4	0.0	0.0	0.0	107	0.0	0.0	0.0	107	
16	47.7	40.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
17	47.5	40.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
18	47.0	39.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
19	46.2	39.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
20	45.1	39.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
21	43.8	39.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
22	42.3	38.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
23	40.7	37.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
24	39.1	35.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

--- B U I L D I N G C O O L I N G D E M A N D S A N D T H E R M A L S T O R A G E ---

March

Hour	Design		----- Design -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	51.8	42.9	0.0	6.5	9.2	111
2	50.8	42.1	0.0	0.0	0.0	110
3	50.0	41.8	0.0	2.2	3.6	111
4	49.3	41.1	0.0	0.0	0.0	110
5	49.1	41.1	0.0	2.2	3.6	111
6	49.5	41.6	0.0	0.0	0.0	110
7	50.6	42.7	0.0	2.2	3.6	111
8	52.5	44.3	0.0	0.0	0.0	110
9	55.2	46.4	0.0	0.0	0.0	110
10	58.3	48.5	0.0	0.0	0.0	110
11	61.8	50.3	0.0	0.0	0.0	110
12	65.1	51.9	0.0	0.0	0.0	110
13	67.6	53.4	0.0	0.0	0.0	109
14	69.3	53.9	0.0	0.0	0.0	108
15	69.9	53.8	0.0	0.0	0.0	107
16	69.3	53.1	0.0	0.0	0.0	106
17	67.8	51.8	0.0	0.0	0.0	106
18	65.6	50.2	0.0	0.0	0.0	106
19	62.9	48.9	0.0	0.0	0.0	106
20	60.2	47.7	0.0	0.0	0.0	106
21	57.9	46.5	0.0	0.0	0.0	106
22	55.8	45.3	0.0	0.0	0.0	106
23	54.1	44.4	0.0	0.0	0.0	106
24	52.9	43.7	0.0	0.0	0.0	106

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	45.4	41.6	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	43.3	39.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	41.6	38.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	40.6	37.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	40.2	37.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	40.6	37.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	41.6	39.0	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	43.3	40.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	45.4	42.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	47.9	44.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	50.6	45.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	53.3	46.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	55.8	48.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	58.0	49.6	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	59.6	50.3	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
16	60.7	50.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
17	61.0	50.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
18	60.7	50.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
19	59.6	50.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
20	58.0	50.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
21	55.8	49.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
22	53.3	47.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
23	50.6	45.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
24	47.9	43.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
Hour	----- Sunday -----						----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
1	45.4	41.6	0.0	6.5	9.2	111	0.0	6.5	9.2	111	
2	43.3	39.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
3	41.6	38.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
4	40.6	37.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
5	40.2	37.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
6	40.6	37.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
7	41.6	39.0	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
8	43.3	40.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
9	45.4	42.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
10	47.9	44.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
11	50.6	45.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
12	53.3	46.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
13	55.8	48.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109	
14	58.0	49.6	0.0	0.0	0.0	108	0.0	0.0	0.0	108	
15	59.6	50.3	0.0	0.0	0.0	107	0.0	0.0	0.0	107	
16	60.7	50.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
17	61.0	50.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
18	60.7	50.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
19	59.6	50.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
20	58.0	50.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
21	55.8	49.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
22	53.3	47.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
23	50.6	45.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106	
24	47.9	43.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

April

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	
	(F)	(F)	(Ton)	(Ton)	(kW)	
1	62.6	52.5	0.0	6.5	9.2	111
2	61.6	52.1	0.0	0.0	0.0	110
3	60.9	51.6	0.0	2.2	3.6	111
4	60.3	51.2	0.0	0.0	0.0	110
5	60.1	51.3	0.0	2.2	3.6	111
6	60.5	51.9	0.0	0.0	0.0	110
7	61.4	53.0	0.0	2.2	3.6	111
8	63.2	54.5	0.0	0.0	0.0	110
9	65.7	55.8	0.0	0.0	0.0	110
10	68.6	57.1	0.0	0.0	0.0	110
11	71.9	58.6	0.0	0.0	0.0	110
12	75.0	60.3	0.0	0.0	0.0	110
13	77.4	61.5	0.0	0.0	0.0	109
14	78.9	62.2	0.0	0.0	0.0	108
15	79.5	62.5	0.0	0.0	0.0	107
16	78.9	61.8	0.0	0.0	0.0	106
17	77.5	60.3	0.0	0.0	0.0	106
18	75.4	59.1	0.0	0.0	0.0	106
19	72.9	57.3	0.0	0.0	0.0	106
20	70.4	56.5	0.0	0.0	0.0	106
21	68.2	55.7	0.0	0.0	0.0	106
22	66.3	55.0	0.0	0.0	0.0	106
23	64.7	54.0	0.0	0.0	0.0	106
24	63.6	53.2	0.0	0.0	0.0	106

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	57.7	53.9	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	55.9	52.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	54.2	51.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	52.9	50.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	51.9	49.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	51.2	49.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	51.0	49.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	51.6	49.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	53.3	50.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	55.9	51.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	59.0	53.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	62.4	55.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	65.5	57.7	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	68.1	59.4	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	69.8	60.7	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	70.4	60.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	70.2	60.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	69.5	60.1	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	68.5	59.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	67.2	59.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	65.5	59.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	63.7	58.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	61.7	57.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	59.7	55.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106

Hour	Typical		Sunday				Monday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	57.7	53.9	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	55.9	52.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	54.2	51.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	52.9	50.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	51.9	49.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	51.2	49.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	51.0	49.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	51.6	49.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	53.3	50.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	55.9	51.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	59.0	53.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	62.4	55.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	65.5	57.7	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	68.1	59.4	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	69.8	60.7	0.0	0.0	0.0	107	0.0	0.0	0.0	107
16	70.4	60.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	70.2	60.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	69.5	60.1	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	68.5	59.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	67.2	59.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	65.5	59.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	63.7	58.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	61.7	57.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	59.7	55.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

---- B U I L D I N G C O O L I N G D E M A N D S A N D T H E R M A L S T O R A G E ----

May

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	70.8	59.3	0.0	6.5	
2	69.8	58.5	0.0	0.0	0.0	110
3	69.0	58.2	0.0	2.2	3.6	111
4	68.4	58.1	0.0	0.0	0.0	110
5	68.2	58.0	0.0	2.2	3.6	111
6	68.6	58.5	0.0	0.0	0.0	110
7	69.6	59.5	0.0	2.2	3.6	111
8	71.3	60.6	0.0	0.0	0.0	110
9	73.9	61.5	0.0	0.0	0.0	110
10	76.8	62.7	0.0	0.0	0.0	110
11	80.1	63.9	0.0	0.0	0.0	110
12	83.2	65.4	0.0	0.0	0.0	110
13	85.6	66.5	0.0	0.0	0.0	109
14	87.1	67.1	0.0	0.0	0.0	108
15	87.7	67.2	6.2	0.0	0.0	100
16	87.1	66.5	18.2	0.0	0.0	81
17	85.8	65.1	0.0	0.0	0.0	81
18	83.6	63.9	0.0	0.0	0.0	81
19	81.1	62.4	0.0	0.0	0.0	81
20	78.6	61.6	0.0	0.0	0.0	81
21	76.4	61.8	0.0	0.0	0.0	81
22	74.5	60.9	0.0	0.0	0.0	81
23	72.9	60.3	0.0	0.0	0.0	81
24	71.7	59.9	0.0	0.0	0.0	81

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	66.6	62.3	0.0	20.0	22.4	100	0.0	6.5	9.2	111
2	64.5	60.4	0.0	11.6	13.3	111	0.0	0.0	0.0	110
3	62.7	59.1	0.0	0.0	0.0	110	0.0	2.2	3.6	111
4	61.2	58.1	0.0	2.2	3.6	111	0.0	0.0	0.0	110
5	60.0	57.1	0.0	0.0	0.0	110	0.0	2.2	3.6	111
6	59.3	56.6	0.0	2.2	3.6	111	0.0	0.0	0.0	110
7	59.0	56.5	0.0	0.0	0.0	110	0.0	2.2	3.6	111
8	59.5	56.6	0.0	2.2	3.6	111	0.0	0.0	0.0	110
9	60.9	56.6	0.0	0.0	0.0	111	0.0	0.0	0.0	110
10	63.0	57.2	0.0	0.0	0.0	111	0.0	0.0	0.0	110
11	65.7	58.1	0.0	0.0	0.0	111	0.0	0.0	0.0	110
12	68.7	59.8	0.0	0.0	0.0	111	0.0	0.0	0.0	110
13	71.7	61.6	0.0	0.0	0.0	110	0.0	0.0	0.0	109
14	74.5	63.4	0.0	0.0	0.0	109	0.0	0.0	0.0	108
15	76.6	64.8	0.0	0.0	0.0	108	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	78.0	65.6	1.1	0.0	0.0	106	0.0	0.0	0.0	106
17	78.5	65.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	78.2	65.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	77.5	65.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	76.3	66.1	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	74.8	67.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	73.0	66.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	70.9	65.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	68.7	64.0	0.0	0.0	0.0	106	0.0	0.0	0.0	106

Hour	Typical		Sunday				Monday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	66.6	62.3	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	64.5	60.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	62.7	59.1	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	61.2	58.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	60.0	57.1	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	59.3	56.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	59.0	56.5	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	59.5	56.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	60.9	56.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	63.0	57.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	65.7	58.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	68.7	59.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	71.7	61.6	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	74.5	63.4	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	76.6	64.8	0.0	0.0	0.0	107	0.0	0.0	0.0	107
16	78.0	65.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	78.5	65.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	78.2	65.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	77.5	65.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	76.3	66.1	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	74.8	67.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	73.0	66.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	70.9	65.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	68.7	64.0	0.0	0.0	0.0	106	0.0	0.0	0.0	106

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

June

Hour	----- Design -----					
	Design		Cooling	Chiller	Chiller	Storage
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)
1	79.5	66.2	0.0	6.5	9.5	111
2	78.5	65.3	0.0	0.0	0.0	110
3	77.7	65.1	0.0	2.2	3.7	111
4	77.2	64.8	0.0	0.0	0.0	110
5	77.0	65.1	0.0	2.2	3.7	111
6	77.4	65.6	0.0	0.0	0.0	110
7	78.3	66.5	0.0	2.2	3.7	111
8	80.0	67.7	0.0	0.0	0.0	110
9	82.5	68.3	0.0	0.0	0.0	110
10	85.4	69.5	0.0	0.0	0.0	110
11	88.7	70.8	0.0	0.0	0.0	110
12	91.8	72.2	0.0	0.0	0.0	110
13	94.1	72.6	28.9	0.0	0.0	80
14	95.6	72.9	30.4	0.0	0.0	49
15	96.2	72.9	31.0	0.0	0.0	17
16	95.6	72.0	29.3	0.0	0.0	0
17	94.3	70.8	0.0	0.0	0.0	0
18	92.1	69.7	0.0	0.0	0.0	0
19	89.6	68.3	0.0	0.0	0.0	0
20	87.1	67.7	0.0	0.0	0.0	0
21	85.0	67.5	0.0	0.0	0.0	0
22	83.1	67.3	0.0	0.0	0.0	0
23	81.6	66.8	0.0	0.0	0.0	0
24	80.4	66.3	0.0	0.0	0.0	0

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage	
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	
1	73.0	67.9	0.0	20.0	22.4	20	0.0	20.0	22.4	56	
2	71.2	66.1	0.0	20.0	22.4	40	0.0	20.0	22.4	75	
3	69.7	65.2	0.0	20.0	22.4	59	0.0	20.0	22.4	94	
4	68.5	64.3	0.9	20.0	22.4	78	0.0	17.6	19.5	111	
5	67.8	64.2	0.4	20.0	22.4	97	0.5	0.0	0.0	110	
6	67.6	64.2	0.0	15.3	16.9	111	0.0	2.7	4.4	111	
7	68.1	64.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
8	69.4	65.7	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
9	71.6	66.2	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
10	74.2	67.2	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
11	77.2	68.5	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
12	80.2	70.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
13	82.8	70.8	16.5	0.0	0.0	94	16.9	0.0	0.0	93	
14	85.0	71.6	18.2	0.0	0.0	74	18.6	0.0	0.0	74	
15	86.3	72.3	19.3	0.0	0.0	54	19.7	0.0	0.0	53	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----					----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	86.8	72.1	17.8	0.0	0.0	36	18.2	0.0	0.0	34
17	86.6	71.7	0.0	0.0	0.0	36	0.0	0.0	0.0	34
18	85.8	71.5	0.0	0.0	0.0	36	0.0	0.0	0.0	34
19	84.7	71.2	0.0	0.0	0.0	36	0.0	0.0	0.0	34
20	83.2	71.5	0.0	0.0	0.0	36	0.0	0.0	0.0	34
21	81.4	71.7	0.0	0.0	0.0	36	0.0	0.0	0.0	34
22	79.3	71.4	0.0	0.0	0.0	36	0.0	0.0	0.0	34
23	77.2	70.5	0.0	0.0	0.0	36	0.0	0.0	0.0	34
24	75.1	69.1	0.0	0.0	0.0	36	0.0	0.0	0.0	34
Hour	----- Sunday -----					----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	73.0	67.9	0.0	20.0	22.4	54	0.0	20.0	22.4	54
2	71.2	66.1	0.0	20.0	22.4	73	0.0	20.0	22.4	73
3	69.7	65.2	0.0	20.0	22.4	93	0.0	20.0	22.4	93
4	68.5	64.3	0.0	19.4	21.6	111	0.0	19.4	21.6	111
5	67.8	64.2	0.5	0.0	0.0	110	0.5	0.0	0.0	110
6	67.6	64.2	0.0	2.7	4.4	111	0.0	2.7	4.4	111
7	68.1	64.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
8	69.4	65.7	0.0	2.2	3.6	111	0.0	2.2	3.6	111
9	71.6	66.2	0.0	0.0	0.0	111	0.0	0.0	0.0	111
10	74.2	67.2	0.0	0.0	0.0	111	0.0	0.0	0.0	111
11	77.2	68.5	0.0	0.0	0.0	111	0.0	0.0	0.0	111
12	80.2	70.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111
13	82.8	70.8	16.9	0.0	0.0	93	16.5	0.0	0.0	94
14	85.0	71.6	18.6	0.0	0.0	74	18.2	0.0	0.0	74
15	86.3	72.3	19.7	0.0	0.0	53	19.3	0.0	0.0	54
16	86.8	72.1	18.2	0.0	0.0	34	17.8	0.0	0.0	36
17	86.6	71.7	0.0	0.0	0.0	34	0.0	0.0	0.0	36
18	85.8	71.5	0.0	0.0	0.0	34	0.0	0.0	0.0	36
19	84.7	71.2	0.0	0.0	0.0	34	0.0	0.0	0.0	36
20	83.2	71.5	0.0	0.0	0.0	34	0.0	0.0	0.0	36
21	81.4	71.7	0.0	0.0	0.0	34	0.0	0.0	0.0	36
22	79.3	71.4	0.0	0.0	0.0	34	0.0	0.0	0.0	36
23	77.2	70.5	0.0	0.0	0.0	34	0.0	0.0	0.0	36
24	75.1	69.1	0.0	0.0	0.0	34	0.0	0.0	0.0	36

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

--- B U I L D I N G C O O L I N G D E M A N D S A N D T H E R M A L S T O R A G E ---

July

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	78.9	67.7	0.0	20.0	
2	78.2	67.2	0.0	20.0	23.0	75
3	77.6	66.8	0.0	20.0	22.9	94
4	77.1	66.6	0.0	17.6	19.9	111
5	77.0	66.6	0.0	0.0	0.0	110
6	77.3	66.9	0.0	2.2	3.7	111
7	78.0	67.6	0.0	0.0	0.0	110
8	79.4	68.8	0.0	2.2	3.8	111
9	81.3	69.6	0.0	0.0	0.0	111
10	83.6	70.7	0.0	0.0	0.0	111
11	86.1	72.2	0.0	0.0	0.0	111
12	88.5	73.3	0.0	0.0	0.0	111
13	90.3	74.0	28.4	0.0	0.0	82
14	91.5	74.3	29.0	0.0	0.0	52
15	92.0	74.0	29.7	0.0	0.0	22
16	91.5	73.2	27.7	0.0	0.0	0
17	90.5	72.1	0.0	0.0	0.0	0
18	88.8	70.8	0.0	0.0	0.0	0
19	86.9	70.4	0.0	0.0	0.0	0
20	84.9	70.2	0.0	0.0	0.0	0
21	83.3	70.0	0.0	0.0	0.0	0
22	81.8	69.4	0.0	0.0	0.0	0
23	80.6	68.7	0.0	0.0	0.0	0
24	79.7	68.4	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	72.0	69.3	0.0	20.0	22.4	20	0.0	20.0	22.4
2	70.5	68.0	0.0	20.0	22.4	40	0.0	20.0	22.4	83
3	69.4	67.1	0.0	20.0	22.4	59	0.0	20.0	22.4	102
4	68.5	66.4	0.7	20.0	22.4	78	0.7	11.2	12.8	111
5	67.9	66.0	0.7	20.0	22.4	97	0.8	0.0	0.0	109
6	67.7	65.9	0.0	15.4	17.0	111	0.0	3.0	4.9	111
7	68.1	66.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
8	69.1	67.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
9	70.8	68.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111
10	72.9	69.1	0.0	0.0	0.0	111	0.0	0.0	0.0	111
11	75.2	70.5	0.0	0.0	0.0	111	0.0	0.0	0.0	111
12	77.5	71.7	0.0	0.0	0.0	111	0.0	0.0	0.0	111
13	79.6	72.7	14.5	0.0	0.0	96	14.9	0.0	0.0	95
14	81.3	73.5	16.5	0.0	0.0	78	16.9	0.0	0.0	77
15	82.3	73.7	17.0	0.0	0.0	60	17.4	0.0	0.0	59

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	82.7	73.5	16.1	0.0	0.0	44	16.6	0.0	0.0	42
17	82.5	73.1	0.0	0.0	0.0	44	0.0	0.0	0.0	42
18	82.0	72.6	0.0	0.0	0.0	44	0.0	0.0	0.0	42
19	81.1	73.2	0.0	0.0	0.0	44	0.0	0.0	0.0	42
20	79.9	73.8	0.0	0.0	0.0	44	0.0	0.0	0.0	42
21	78.5	73.9	0.0	0.0	0.0	44	0.0	0.0	0.0	42
22	76.9	73.1	0.0	0.0	0.0	44	0.0	0.0	0.0	42
23	75.2	71.9	0.0	0.0	0.0	44	0.0	0.0	0.0	42
24	73.5	70.8	0.0	0.0	0.0	44	0.0	0.0	0.0	42

Hour	Typical		Sunday				Monday			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	72.0	69.3	0.0	20.0	22.4	61	0.0	20.0	22.4	61
2	70.5	68.0	0.0	20.0	22.4	81	0.0	20.0	22.4	81
3	69.4	67.1	0.0	20.0	22.4	100	0.0	20.0	22.4	100
4	68.5	66.4	0.7	12.9	14.4	111	0.7	12.9	14.4	111
5	67.9	66.0	0.8	0.0	0.0	109	0.8	0.0	0.0	109
6	67.7	65.9	0.0	3.0	4.9	111	0.0	3.0	4.9	111
7	68.1	66.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
8	69.1	67.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
9	70.8	68.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111
10	72.9	69.1	0.0	0.0	0.0	111	0.0	0.0	0.0	111
11	75.2	70.5	0.0	0.0	0.0	111	0.0	0.0	0.0	111
12	77.5	71.7	0.0	0.0	0.0	111	0.0	0.0	0.0	111
13	79.6	72.7	14.9	0.0	0.0	95	14.5	0.0	0.0	96
14	81.3	73.5	16.9	0.0	0.0	77	16.5	0.0	0.0	78
15	82.3	73.7	17.4	0.0	0.0	59	17.0	0.0	0.0	60
16	82.7	73.5	16.6	0.0	0.0	42	16.1	0.0	0.0	44
17	82.5	73.1	0.0	0.0	0.0	42	0.0	0.0	0.0	44
18	82.0	72.6	0.0	0.0	0.0	42	0.0	0.0	0.0	44
19	81.1	73.2	0.0	0.0	0.0	42	0.0	0.0	0.0	44
20	79.9	73.8	0.0	0.0	0.0	42	0.0	0.0	0.0	44
21	78.5	73.9	0.0	0.0	0.0	42	0.0	0.0	0.0	44
22	76.9	73.1	0.0	0.0	0.0	42	0.0	0.0	0.0	44
23	75.2	71.9	0.0	0.0	0.0	42	0.0	0.0	0.0	44
24	73.5	70.8	0.0	0.0	0.0	42	0.0	0.0	0.0	44

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

--- B U I L D I N G C O O L I N G D E M A N D S A N D T H E R M A L S T O R A G E ---

August

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	78.6	67.6	0.0	20.0	
2	77.9	67.2	0.0	20.0	23.0	83
3	77.2	66.9	0.0	20.0	22.8	102
4	76.8	66.6	0.0	10.4	12.4	111
5	76.6	66.7	0.0	0.0	0.0	110
6	76.9	67.1	0.0	2.2	3.7	111
7	77.7	67.8	0.0	0.0	0.0	110
8	79.1	69.0	0.0	2.2	3.7	111
9	81.2	70.0	0.0	0.0	0.0	111
10	83.5	70.9	0.0	0.0	0.0	111
11	86.2	71.8	0.0	0.0	0.0	111
12	88.7	72.7	0.0	0.0	0.0	111
13	90.6	73.2	25.6	0.0	0.0	83
14	91.8	73.8	28.0	0.0	0.0	55
15	92.3	74.0	29.2	0.0	0.0	25
16	91.8	73.3	27.3	0.0	0.0	0
17	90.7	72.4	0.0	0.0	0.0	0
18	89.0	71.4	0.0	0.0	0.0	0
19	87.0	70.1	0.0	0.0	0.0	0
20	84.9	69.8	0.0	0.0	0.0	0
21	83.2	70.3	0.0	0.0	0.0	0
22	81.6	69.3	0.0	0.0	0.0	0
23	80.4	68.5	0.0	0.0	0.0	0
24	79.4	67.9	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	72.7	70.2	0.0	20.0	22.4	20	0.0	20.0	22.4
2	71.2	69.0	0.0	20.0	22.4	40	0.0	20.0	22.4	85
3	69.9	68.0	0.0	20.0	22.4	59	0.0	20.0	22.4	105
4	68.8	67.1	0.7	20.0	22.4	78	0.8	8.4	10.5	111
5	68.0	66.6	0.0	20.0	22.4	97	0.0	0.0	0.0	110
6	67.5	66.2	0.0	14.8	16.3	111	0.0	2.2	3.6	111
7	67.3	66.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
8	67.8	66.5	0.0	2.2	3.6	111	0.0	2.2	3.6	111
9	69.1	67.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111
10	71.2	67.8	0.0	0.0	0.0	111	0.0	0.0	0.0	111
11	73.8	68.7	0.0	0.0	0.0	111	0.0	0.0	0.0	111
12	76.5	70.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111
13	79.1	71.2	13.8	0.0	0.0	96	14.2	0.0	0.0	96
14	81.1	72.6	15.6	0.0	0.0	80	16.1	0.0	0.0	79
15	82.5	73.6	16.9	0.0	0.0	62	17.4	0.0	0.0	61

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
16	83.0	73.7	14.8	0.0	0.0	47	15.2	0.0	0.0	45	
17	82.8	73.5	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
18	82.3	73.5	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
19	81.5	73.1	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
20	80.4	73.7	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
21	79.1	74.9	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
22	77.6	73.9	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
23	76.0	72.7	0.0	0.0	0.0	47	0.0	0.0	0.0	45	
24	74.3	71.3	0.0	0.0	0.0	47	0.0	0.0	0.0	45	

Hour	----- Sunday -----						----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
1	72.7	70.2	0.0	20.0	22.4	64	0.0	20.0	22.4	64	
2	71.2	69.0	0.0	20.0	22.4	84	0.0	20.0	22.4	84	
3	69.9	68.0	0.0	20.0	22.4	103	0.0	20.0	22.4	103	
4	68.8	67.1	0.8	10.1	11.9	111	0.8	10.1	11.9	111	
5	68.0	66.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
6	67.5	66.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
7	67.3	66.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110	
8	67.8	66.5	0.0	2.2	3.6	111	0.0	2.2	3.6	111	
9	69.1	67.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
10	71.2	67.8	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
11	73.8	68.7	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
12	76.5	70.0	0.0	0.0	0.0	111	0.0	0.0	0.0	111	
13	79.1	71.2	14.2	0.0	0.0	96	13.8	0.0	0.0	96	
14	81.1	72.6	16.1	0.0	0.0	79	15.6	0.0	0.0	80	
15	82.5	73.6	17.4	0.0	0.0	61	16.9	0.0	0.0	62	
16	83.0	73.7	15.2	0.0	0.0	45	14.8	0.0	0.0	47	
17	82.8	73.5	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
18	82.3	73.5	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
19	81.5	73.1	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
20	80.4	73.7	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
21	79.1	74.9	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
22	77.6	73.9	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
23	76.0	72.7	0.0	0.0	0.0	45	0.0	0.0	0.0	47	
24	74.3	71.3	0.0	0.0	0.0	45	0.0	0.0	0.0	47	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

September

Hour	----- Design -----					
	Design		Cooling	Chiller	Chiller	Storage
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)
1	74.6	63.1	0.0	20.0	22.4	66
2	73.7	62.4	0.0	20.0	22.4	85
3	73.0	61.9	0.0	20.0	22.4	105
4	72.4	61.7	0.0	7.6	9.9	111
5	72.3	61.8	0.0	0.0	0.0	110
6	72.6	62.5	0.0	2.2	3.6	111
7	73.5	63.2	0.0	0.0	0.0	110
8	75.1	64.8	0.0	2.2	3.6	111
9	77.4	65.9	0.0	0.0	0.0	111
10	80.0	66.8	0.0	0.0	0.0	111
11	83.0	67.8	0.0	0.0	0.0	111
12	85.8	68.5	0.0	0.0	0.0	111
13	87.9	69.7	20.1	0.0	0.0	90
14	89.3	70.2	21.4	0.0	0.0	68
15	89.9	70.1	23.5	0.0	0.0	43
16	89.3	69.1	21.8	0.0	0.0	21
17	88.1	67.8	0.0	0.0	0.0	21
18	86.2	66.8	0.0	0.0	0.0	21
19	83.9	66.5	0.0	0.0	0.0	21
20	81.6	66.3	0.0	0.0	0.0	21
21	79.7	66.1	0.0	0.0	0.0	21
22	77.9	65.0	0.0	0.0	0.0	21
23	76.5	64.4	0.0	0.0	0.0	21
24	75.4	63.6	0.0	0.0	0.0	21

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)
1	69.8	66.1	0.0	20.0	22.4	41	0.0	20.0	22.4	92
2	68.0	64.5	0.0	20.0	22.4	61	0.0	20.0	22.4	111
3	66.3	63.0	0.0	20.0	22.4	80	0.0	1.4	2.3	111
4	64.9	61.9	0.0	20.0	22.4	99	0.0	0.0	0.0	110
5	63.9	61.3	0.0	12.9	14.5	111	0.0	2.2	3.6	111
6	63.2	61.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	63.0	60.8	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	63.4	61.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	64.7	61.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	66.6	62.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	69.1	62.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	71.8	63.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	74.5	65.5	6.9	0.0	0.0	102	7.2	0.0	0.0	102
14	77.0	67.1	8.4	0.0	0.0	93	8.7	0.0	0.0	92
15	78.9	68.2	9.2	0.0	0.0	82	9.6	0.0	0.0	81

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----					----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	80.2	68.6	9.2	0.0	0.0	72	9.5	0.0	0.0	71
17	80.6	68.5	0.0	0.0	0.0	72	0.0	0.0	0.0	71
18	80.4	68.9	0.0	0.0	0.0	72	0.0	0.0	0.0	71
19	79.7	70.0	0.0	0.0	0.0	72	0.0	0.0	0.0	71
20	78.7	71.2	0.0	0.0	0.0	72	0.0	0.0	0.0	71
21	77.3	71.6	0.0	0.0	0.0	72	0.0	0.0	0.0	71
22	75.6	70.5	0.0	0.0	0.0	72	0.0	0.0	0.0	71
23	73.7	69.4	0.0	0.0	0.0	72	0.0	0.0	0.0	71
24	71.8	67.7	0.0	0.0	0.0	72	0.0	0.0	0.0	71

Hour	----- Sunday -----					----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	69.8	66.1	0.0	20.0	22.4	90	0.0	20.0	22.4	90
2	68.0	64.5	0.0	20.0	22.4	110	0.0	20.0	22.4	110
3	66.3	63.0	0.0	2.7	4.4	111	0.0	2.7	4.4	111
4	64.9	61.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	63.9	61.3	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	63.2	61.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	63.0	60.8	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	63.4	61.4	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	64.7	61.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	66.6	62.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	69.1	62.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	71.8	63.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	74.5	65.5	7.2	0.0	0.0	102	6.9	0.0	0.0	102
14	77.0	67.1	8.7	0.0	0.0	92	8.4	0.0	0.0	93
15	78.9	68.2	9.6	0.0	0.0	81	9.2	0.0	0.0	82
16	80.2	68.6	9.5	0.0	0.0	71	9.2	0.0	0.0	72
17	80.6	68.5	0.0	0.0	0.0	71	0.0	0.0	0.0	72
18	80.4	68.9	0.0	0.0	0.0	71	0.0	0.0	0.0	72
19	79.7	70.0	0.0	0.0	0.0	71	0.0	0.0	0.0	72
20	78.7	71.2	0.0	0.0	0.0	71	0.0	0.0	0.0	72
21	77.3	71.6	0.0	0.0	0.0	71	0.0	0.0	0.0	72
22	75.6	70.5	0.0	0.0	0.0	71	0.0	0.0	0.0	72
23	73.7	69.4	0.0	0.0	0.0	71	0.0	0.0	0.0	72
24	71.8	67.7	0.0	0.0	0.0	71	0.0	0.0	0.0	72

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

October

Hour	----- Design -----					
	Design		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)				
1	59.5	50.0	0.0	20.0	22.4	92
2	58.5	49.3	0.0	20.0	22.4	111
3	57.7	48.8	0.0	1.4	2.3	111
4	57.1	48.5	0.0	0.0	0.0	110
5	56.9	48.3	0.0	2.2	3.6	111
6	57.3	48.7	0.0	0.0	0.0	110
7	58.3	49.7	0.0	2.2	3.6	111
8	60.1	51.3	0.0	0.0	0.0	110
9	62.7	52.9	0.0	0.0	0.0	110
10	65.7	54.4	0.0	0.0	0.0	110
11	69.1	55.5	0.0	0.0	0.0	110
12	72.3	56.7	0.0	0.0	0.0	110
13	74.7	57.8	0.0	0.0	0.0	109
14	76.3	58.6	0.0	0.0	0.0	108
15	76.9	58.7	0.0	0.0	0.0	107
16	76.3	58.0	0.0	0.0	0.0	106
17	74.9	57.0	0.0	0.0	0.0	106
18	72.7	56.0	0.0	0.0	0.0	106
19	70.1	55.5	0.0	0.0	0.0	106
20	67.5	54.7	0.0	0.0	0.0	106
21	65.3	53.6	0.5	0.0	0.0	105
22	63.3	52.4	0.0	0.0	0.0	105
23	61.7	51.5	0.0	0.0	0.0	105
24	60.5	50.7	0.0	0.0	0.0	105

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	54.8	51.3	0.0	7.0	9.5	111	0.0	6.5	9.2	111
2	52.9	49.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	51.2	48.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	49.8	47.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	48.8	46.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	48.2	45.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	47.9	45.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	48.5	46.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	50.3	47.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	52.9	48.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	56.2	49.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	59.6	51.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	62.9	53.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	65.5	55.2	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	67.3	56.3	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
16	67.9	56.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	67.7	56.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	67.0	56.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	66.0	57.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	64.6	57.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	62.9	57.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	61.0	56.0	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	59.0	54.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	56.9	53.0	0.0	0.0	0.0	106	0.0	0.0	0.0	106

Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
1	54.8	51.3	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	52.9	49.6	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	51.2	48.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	49.8	47.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	48.8	46.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	48.2	45.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	47.9	45.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	48.5	46.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	50.3	47.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	52.9	48.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	56.2	49.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	59.6	51.5	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	62.9	53.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	65.5	55.2	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	67.3	56.3	0.0	0.0	0.0	107	0.0	0.0	0.0	107
16	67.9	56.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	67.7	56.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	67.0	56.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	66.0	57.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	64.6	57.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	62.9	57.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	61.0	56.0	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	59.0	54.8	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	56.9	53.0	0.0	0.0	0.0	106	0.0	0.0	0.0	106

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

November

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	56.0	47.2	0.0	6.5	
2	55.0	46.4	0.0	0.0	0.0	110
3	54.2	45.8	0.0	2.2	3.6	111
4	53.6	45.2	0.0	0.0	0.0	110
5	53.4	45.3	0.0	2.2	3.6	111
6	53.8	45.9	0.0	0.0	0.0	110
7	54.8	46.9	0.0	2.2	3.6	111
8	56.6	48.7	0.0	0.0	0.0	110
9	59.2	50.6	0.0	0.0	0.0	110
10	62.2	52.6	0.0	0.0	0.0	110
11	65.6	54.1	0.0	0.0	0.0	110
12	68.8	55.3	0.0	0.0	0.0	110
13	71.2	55.7	0.0	0.0	0.0	109
14	72.8	56.3	0.0	0.0	0.0	108
15	73.4	56.2	0.0	0.0	0.0	107
16	72.8	55.6	0.0	0.0	0.0	106
17	71.4	54.6	0.0	0.0	0.0	106
18	69.2	53.6	0.0	0.0	0.0	106
19	66.6	53.0	0.0	0.0	0.0	106
20	64.0	51.7	0.0	0.0	0.0	106
21	61.8	50.7	0.0	0.0	0.0	106
22	59.8	49.6	0.0	0.0	0.0	106
23	58.2	48.7	0.0	0.0	0.0	106
24	57.0	48.0	0.0	0.0	0.0	106

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	48.7	45.7	0.0	6.5	9.2	111	0.0	6.5	9.2
2	46.9	44.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	45.5	42.8	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	44.6	41.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	44.4	42.0	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	44.8	42.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	45.9	43.9	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	47.8	46.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	50.2	48.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	52.9	49.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	55.8	51.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	58.5	52.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	60.9	52.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	62.8	53.4	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	64.0	53.8	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	64.4	53.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	64.1	53.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	63.2	53.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	61.8	54.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	60.0	53.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	57.9	52.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	55.6	51.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	53.2	49.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	50.8	47.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106

Hour	Typical		Sunday				Monday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	48.7	45.7	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	46.9	44.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	45.5	42.8	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	44.6	41.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	44.4	42.0	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	44.8	42.7	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	45.9	43.9	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	47.8	46.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	50.2	48.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	52.9	49.9	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	55.8	51.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	58.5	52.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	60.9	52.5	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	62.8	53.4	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	64.0	53.8	0.0	0.0	0.0	107	0.0	0.0	0.0	107
16	64.4	53.9	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	64.1	53.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	63.2	53.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	61.8	54.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	60.0	53.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	57.9	52.7	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	55.6	51.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	53.2	49.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	50.8	47.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

December

Hour	Design		Design			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity
	(Ton)	(Ton)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	48.2	40.8	0.0	6.5	9.2	111
2	47.3	40.2	0.0	0.0	0.0	110
3	46.6	39.7	0.0	2.2	3.6	111
4	46.1	39.3	0.0	0.0	0.0	110
5	45.9	39.4	0.0	2.2	3.6	111
6	46.3	39.7	0.0	0.0	0.0	110
7	47.1	40.6	0.0	2.2	3.6	111
8	48.7	42.0	0.0	0.0	0.0	110
9	50.9	44.0	0.0	0.0	0.0	110
10	53.5	46.1	0.0	0.0	0.0	110
11	56.5	48.0	0.0	0.0	0.0	110
12	59.2	49.7	0.0	0.0	0.0	110
13	61.3	50.8	0.0	0.0	0.0	109
14	62.7	51.4	0.0	0.0	0.0	108
15	63.2	51.4	0.0	0.0	0.0	107
16	62.7	50.7	0.0	0.0	0.0	106
17	61.5	49.7	0.0	0.0	0.0	106
18	59.6	48.5	0.0	0.0	0.0	106
19	57.3	47.6	0.0	0.0	0.0	106
20	55.1	45.9	0.0	0.0	0.0	106
21	53.2	44.6	0.0	0.0	0.0	106
22	51.5	43.1	0.0	0.0	0.0	106
23	50.1	42.2	0.0	0.0	0.0	106
24	49.0	41.5	0.0	0.0	0.0	106

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(Ton)	(Ton)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	37.5	35.3	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	37.1	35.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	37.4	35.5	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	38.1	36.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	39.3	37.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	40.9	39.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	42.7	41.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	44.7	43.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	46.8	45.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	48.8	47.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	50.7	48.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	52.2	48.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	53.4	49.2	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	54.1	49.2	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	54.4	48.9	0.0	0.0	0.0	107	0.0	0.0	0.0	107

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M060, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	54.0	48.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	53.0	47.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	51.4	46.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	49.3	45.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	47.0	43.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	44.5	41.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	42.2	39.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	40.1	37.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	38.5	36.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	37.5	35.3	0.0	6.5	9.2	111	0.0	6.5	9.2	111
2	37.1	35.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
3	37.4	35.5	0.0	2.2	3.6	111	0.0	2.2	3.6	111
4	38.1	36.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
5	39.3	37.6	0.0	2.2	3.6	111	0.0	2.2	3.6	111
6	40.9	39.2	0.0	0.0	0.0	110	0.0	0.0	0.0	110
7	42.7	41.2	0.0	2.2	3.6	111	0.0	2.2	3.6	111
8	44.7	43.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
9	46.8	45.3	0.0	0.0	0.0	110	0.0	0.0	0.0	110
10	48.8	47.0	0.0	0.0	0.0	110	0.0	0.0	0.0	110
11	50.7	48.1	0.0	0.0	0.0	110	0.0	0.0	0.0	110
12	52.2	48.8	0.0	0.0	0.0	110	0.0	0.0	0.0	110
13	53.4	49.2	0.0	0.0	0.0	109	0.0	0.0	0.0	109
14	54.1	49.2	0.0	0.0	0.0	108	0.0	0.0	0.0	108
15	54.4	48.9	0.0	0.0	0.0	107	0.0	0.0	0.0	107
16	54.0	48.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106
17	53.0	47.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
18	51.4	46.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
19	49.3	45.4	0.0	0.0	0.0	106	0.0	0.0	0.0	106
20	47.0	43.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
21	44.5	41.5	0.0	0.0	0.0	106	0.0	0.0	0.0	106
22	42.2	39.3	0.0	0.0	0.0	106	0.0	0.0	0.0	106
23	40.1	37.6	0.0	0.0	0.0	106	0.0	0.0	0.0	106
24	38.5	36.2	0.0	0.0	0.0	106	0.0	0.0	0.0	106

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M060, ECO#13

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 20,856
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	3,570.0	534,361.6	43.1	599,043.2	29.4
Primary Cooling					
Compressor	57,232.8	0.0	15.4	586,065.5	28.8
Tower/Cond Fans	3,013.5	0.0	0.8	30,858.3	1.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	2,940.5	0.0	0.8	30,110.8	1.5
Auxiliary					
Supply Fans	63,955.6	0.0	17.2	654,907.0	32.2
Circulation Pumps	14,105.0	0.0	3.8	144,435.6	7.1
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	78,060.6	0.0	21.0	799,342.6	39.3
Lighting	25,412.0	0.0	6.8	260,219.7	12.5
Receptacle	45,044.6	0.0	12.1	461,258.2	22.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	215,274.1	534,361.6	100.0	2,766,898.0	135.1

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#15

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	11,998	46	1,505	3
Feb	10,837	46	1,557	3
March	11,979	45	884	2
April	10,865	45	21	1
May	14,413	72	0	0
June	24,624	84	0	0
July	24,332	84	0	0
Aug	23,669	84	0	0
Sept	17,646	76	0	0
Oct	11,183	63	0	0
Nov	11,204	45	307	7
Dec	11,990	46	1,127	3
Total	184,740	84	5,402	7

Building Energy Consumption = 56,132 (Btu/Sq Ft/Year)
 Source Energy Consumption = 117,968 (Btu/Sq Ft/Year)

Floor Area = 20,856 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#15

----- EQUIPMENT ENERGY CONSUMPTION -----															
Ref Num	Equip Code	----- Monthly Consumption -----												Total	
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec		
0	LIGHTS														
	ELEC	1918	1732	1934	1853	1926	1869	1910	1934	1853	1926	1853	1910	22,618	
	PK	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	
1	MISC LD														
	ELEC	3826	3455	3826	3702	3826	3702	3826	3826	3702	3826	3702	3826	45,045	
	PK	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	
2	MISC LD														
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
3	MISC LD														
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
4	MISC LD														
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
5	MISC LD														
	P HOTH2O	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0	
6	MISC LD														
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1	EQ1100S														
	ELEC	0				2938	12538	11955	11333	6232	0	0	0	44,995	
	PK	0.0	0.0	0.0	0.0	29.0	42.9	39.5	38.9	31.7	17.5	0.0	0.0	42.9	
				AIR-CLD RECIP 25-45 TONS											
1	EQ5200														
	ELEC	0	0	0	0	227	1051	990	931	485	0	0	0	3,684	
	PK	0.0	0.0	0.0	0.0	2.8	4.4	4.1	4.0	3.1	0.9	0.0	0.0	4.4	
				CONDENSER FANS											
1	EQ5001														
	ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
				CHILLED WATER PUMP C.V.											
1	EQ5303														
	ELEC	0	0	0	0	65	207	219	214	117	0	0	0	822	
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3	
				CONTROLS											
1	EQ4371														
	ELEC	5432	4906	5432	5257	5432	5257	5432	5432	5257	5432	5257	5432	63,956	
	PK	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	
				FAN COIL SUPPLY FAN											

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M060, ECO#15

1	EQ2001		GAS FIRE TUBE HOT WATER												
	GAS	1505	1557	884	21	0	0	0	0	0	0	307	1127	5,402	
	ELEC														
	PK	3.2	3.2	2.1	0.8	0.0	0.0	0.0	0.0	0.0	0.0	7.1	2.6	7.1	
1	EQ5020		HEAT WATER CIRC. PUMP C.V.												
	ELEC	10	9	10	1	0	0	0	0	0	0	5	10	45	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1	EQ5240		BOILER FORCED DRAFT FAN												
	ELEC	440	398	422	28	0	0	0	0	0	0	209	440	1,938	
	PK	0.6	0.6	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.6	0.6	
1	EQ5307		BOILER CONTROLS												
	ELEC	372	336	356	24	0	0	0	0	0	0	177	372	1,638	
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M060, ECO#15

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 84.5 (kW)
Yearly Time of Peak 20 (hr) 6 (mo)

Hour 20 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1100S	AIR-CLD RECIP 25-45 TONS	39.9	47.26
Sub Total			39.9	47.26
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.3	8.64
Sub Total			7.3	8.64
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.2	8.47
	Base Utilities		0.0	0.00
	Misc Equipment		30.1	35.63
Sub Total			37.3	44.10
Grand Total			84.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M060, ECO#15

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 20,856
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	3,575.5	540,173.1	47.2	605,216.6	29.7
Primary Cooling					
Compressor	44,995.3	0.0	13.1	460,753.3	22.6
Tower/Cond Fans	3,684.2	0.0	1.1	37,726.2	1.9
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	821.7	0.0	0.2	8,414.2	0.4
Auxiliary					
Supply Fans	63,955.6	0.0	18.6	654,907.0	32.2
Circulation Pumps	44.6	0.0	0.0	456.4	0.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	64,000.2	0.0	18.7	655,363.5	32.2
Lighting	22,618.0	0.0	6.6	231,608.7	11.1
Receptacle	45,044.6	0.0	13.1	461,258.2	22.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	184,739.5	540,173.1	100.0	2,460,340.7	120.1

BUILDING 100

E M C ENGINEERS, INC.

PROJECT: FORT MCPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT MCPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 10-APR-92
 FILE: M100ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M100 Area: 7,393 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	8,311	691	22,050	82,003	1,212	21,272	17,993	145,221	41	8	504
ECO#1 - Wall Savings/(Loss)	19,616 (11,305)	748 (57)	23,581 (1,531)	82,003	1,212	21,272	17,993	146,809 (1,588)	41	20 (11)	521 (17)
ECO#1 - Roof Savings/(Loss)	17,513 (9,202)	726 (35)	23,974 (1,924)	82,003	1,212	21,272	17,993	147,180 (1,959)	41	18 (9)	520 (16)
ECO#2 Savings/(Loss)	9,011 (700)	691	22,089 (38)	82,003	1,212	21,272	17,993	145,259 (38)	41	9 (1)	505 (1)
ECO#3 Savings/(Loss)	8,186 125	678 13	22,040 10	82,003	1,212	21,272	17,993	145,198 23	41	8 0	504 0
ECO#12 Savings/(Loss)	8,127 184	161 530	6,023 16,027	28,616 53,387	60 1,152	21,272	17,993	74,125 71,096	36 5	8 0	261 243
ECO#15 Savings/(Loss)	10,150 (1,839)	847 (156)	20,341 1,710	82,003	1,212	13,186	17,993	135,582 9,639	41	10 (2)	473 31

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
SHEET NO. 1 OF _____
CALCULATED BY [Signature] DATE 2/23/83
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation - Bldg 100
1000000 Erick Admin Area 700000 ft²
E.O. 3, 12 For Takeoff: 12
Take off Bldg 04, 04a, 05, 05a, 06, 06a, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20
21, 22, 24, 26

Assumptions

- Occupancy - Upstairs: 18 people
Basement: 2 people
- Floor load: 15 psf/ft²
Basement: 10 psf/ft²
- Heating: Upstairs: 1/2 ACH
Basement: 1/4 ACH
- Cooling: 76°F


Comments

- no OA available

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

Camp Site B/W 20


Wall U-Value - ASHRAE Table F22.4



Material	R-Value
Outside Surface (15 mph wind)	0.17
4" brick	1.24
1/2" sheathing board	1.32
R-11 Insulation	11.0
1/2" Gypsum	0.45
Inside Surface (still air)	0.68
Total	14.86

$$U = \frac{1}{R} = \frac{1}{14.86} = \boxed{0.067}$$

Roof U-Value - ASHRAE Table F22.4



Material	R
Outside Surface (15 mph)	0.17
shingles	0.44
1/2" Plywood	0.62
Air space	1.24
R-19 Insulation	19.0
1/2" Gyp Board	0.45
Inside Surface (still air)	0.62
Total	22.54

$$U = \frac{1}{22.54} = \boxed{0.044}$$

Basement Wall U-Value - ASHRAE Table F25.3

↳ no insulation

ft. below grade	U-Value / ft length
1 st	0.41
2 nd	0.22
3 rd	0.155
4 th	0.119
5 th	0.096
6 th	0.079
7 th	0.069

$$\boxed{1.15 \text{ BTU/h/ft}^2 \cdot \text{F}}$$

- for simulation input wall height = 1.0 ft + U = 1.15

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
SHEET NO. 3 OF _____
CALCULATED BY WMA DATE 2/25/92
CHECKED BY _____ DATE _____
SCALE _____

Comp Sim. Bldg 100

Window U-Value - ASHRAE Table F 27.13

- Double pane, metal frame, type R
- Assumes 1/2" air space without break

$$\Rightarrow U = 0.70$$

Indoor Climate - ASHRAE Table F 27.26

- Blinds

$$\Rightarrow 0.58$$

Basement Floor - ASHRAE Table F 25.4

- shortest width of house = 32 ft. ±
- Depth below grade 57 ft

$$U = 0.021 \text{ Btuh/ft}^2 \text{ °F}$$

People

Room 1 - Upstairs

- Normal occupancy: 18 people - From field survey

Room 2 - Basement

- Normal occupancy: 1 person - from field survey

Heat Gain - ASHRAE Table F 26.3

Sensible: 250 Btuh/person

Latent: 200 Btuh/person

Lights

Room 1 - Upstairs - From plans

$$6,312 \text{ W}$$

Room 2 - Basement

4,110 W - from plans

- assume only 33% on \Rightarrow 1,370 W

JOB 3105.000

SHEET NO. 4 OF _____

CALCULATED BY Pump DATE 2/20/68

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Comp. m $V_{10} = 100$

Misc load.

Room 1

- no survey data
- use 5 BTU/H²

Room 2

- no survey data
- use 1 BTU/H²

Infiltration

Room 1

- For simple Assume $\frac{1}{3}$ ACH

- For $E_{10} = 3$:

$$Q = L(AAE + BV^2)^{1/2}$$

- A - stack coefficient = 0.0156
- B - wind coefficient = 0.0039
- V - wind velocity = 12.65 mph
- L - Effective leakage area:

ASHRAE Table F 23.7
ASHRAE Table F 23.8

- window, double slider, weatherstripped $(0.037)(23)(5.25) = 10.64$
- window frame, mason wall, caulked $(0.019)(23)(5.25) = 5.46$
- door, single weatherstripped $(0.114)(1)(3.667) = 2.28$
- door, single, not weatherstripped $(0.157)(1)(3.667) = 3.14$
- door frame, mason wall, caulked $(0.019)(2)(3.667) = 0.76$

22.28 in²

heating $T_i = T_o$
 $\Delta t = 72 - 53 = 19^\circ F$

$$Q = 22.28(0.0156(19) + 0.0039(12.65)^2)^{1/2} = 21.4 \text{ cfm}$$

cooling $T_o = T_i$
 $\Delta t = 88 - 76 = 12^\circ F$

$$Q = 22.28(0.0156(12) + 0.0039(12.65)^2)^{1/2} = 20.1 \text{ cfm}$$

JOB 3105.000

SHEET NO. 5 OF _____

CALCULATED BY R. J. PA DATE 2/25/07

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

2000.000

2000.000

Loss

for simulation assume 1/3 loss

For E.C.D.#?

L:

- door single, not weatherstripped $(10.5' \times 12') (5.25) = 7.26$

- door frame, window unit sealed $(10.5' \times 12') (0.25) = 0.76$

8.04 in²

heating

$$Q = 3.04 (0.056 (10) + 0.0039 (12.65)^2)^{1/2} = 7.7 \text{ cfm}$$

cooling

$$Q = 8.64 (0.055 (12) + 0.0039 (12.65)^2)^{1/2} = 7.2 \text{ cfm}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 100, McPherson

Baseline (cont)

$$\text{Heat Pump} = \frac{1/2 \text{ hr} (0.746 \text{ kW} \cdot \text{hr} \cdot \text{hr}^{-1})}{(0.764 \text{ kWh})} = 0.76 \text{ kW} \cdot \text{hr} \cdot \text{hr}^{-1} = \boxed{1,212} \text{ kWh/yr}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 100, McPherson

ECO #1 - Wall Insulation

Wall U-Value - ASHRAE Table F 22.4

- Remove R-11 Wall Insulation to develop energy factor for take off buildings

$$R = 3.26$$

$$U = 0.26$$

$$\text{original } U\text{-Value} = 0.067$$

$$\text{Wall Area} = 2,939 \text{ ft}^2$$

$$\text{original } UA = 198.9$$

$$\text{improved } UA = 764.1$$

$$\Delta UA = -567.2$$

Electric Savings

$$\text{Total Electric Savings} = -1,588 \text{ kWh/yr}$$

$$\text{Electric Savings}/\Delta UA = \boxed{2.8} \text{ kWh}/\Delta UA$$

Demand Savings

$$\text{Peak Demand Savings} = -0 \text{ kW}/\Delta UA$$

Gas Savings

$$\text{Total Gas Savings} = -11.3 \text{ MBtu/yr}$$

$$\text{Gas Savings}/\Delta UA = \boxed{0.020} \text{ MBtu}/\Delta UA$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 100, McPherson

ECO # 1 - Roof Insulation

Roof U-Value - ASHRAE Table F 22.4

Remove R-19 Roof insulation to develop energy factor for take off buildings

$$\begin{matrix} R = 3.54 \\ \boxed{U = 0.28} \end{matrix}$$

Roof Area = 4,688 ft²

original U = 0.044

original UA = 206.3

new UA = 1,312.6

Delta UA = -1,106.4

Electric Savings

Total Electric Savings = -1,959 kWh/yr

Electric Savings/dUA = $\boxed{1.77}$ kWh/UA

Demand Savings

Peak Demand Savings = 0 kW/UA

Gas Savings

Total Gas Savings = -9.20 MBtu/yr

Gas Savings/dUA = $\boxed{0.0083}$ MBtu/UA

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 100, Mc Pk. cov

ECO #2 - Insulated Glass

Window U-Value - ASHRAE Table F 27.13

- Single pane, Al frame, Type R - No develop energy factor for takeoff buildings

$U = 1.09$

Window Shading - ASHRAE Table F 27.25

- Light blinds

$\Rightarrow 0.67$

Window Area = 238 ft²

Electric Savings

Total Electric Savings = 38 kWh/yr

Electric Savings / ft² = 0.13 kWh/yr/ft²

Demand Savings

Peak Demand Savings = 0 kW

Gas Savings

Total Gas Savings = 0.700 MBtu/yr

Gas Savings / ft² = 0.0024 MBtu/yr/ft²

Computer Simulation - Bldg 100, McPherson

ECO # 3 - Weatherstripping + Caulking

$$Q = L(A \Delta T + E V^2)^{1/2}$$

A - stack coefficient = 0.0156 - one story ASHRAE Table F 23.7

E - wind coefficient = 0.0039 - medium building ASHRAE Table F 23.8

V - avg. wind velocity = 12.65 mph

$\Delta T = 72^\circ F - 55^\circ F = 17^\circ F$

L - effective Area = Area + (10% A) - ASHRAE Table F 23.3

Present

windows: w.s./c, double + door, mason wall - 23 - 5' x 25'

window: 0.037

frame: 0.019

door: w.s./c, single mason wall 1 - 3' x 6 3/4'

door: 0.114

frame: 0.0143

door: net w.s./c, single mason wall 1 - 3' x 6 3/4', 2 - 3' x 6 3/4'

door: 0.157

frame: 0.072

Improvement

door: w.s./c, single, mason wall - see above

Result

Present

$$\text{window: } (0.037)(287.5) = 10.6$$

$$\text{frame: } (0.019)(287.5) = 5.5$$

$$\text{door-1: } (0.114)(20) = 2.3$$

$$\text{frame: } (0.0143)(20) = 0.3$$

$$\text{door-2: } (0.157)(20) = 3.1$$

$$\text{frame: } (0.072)(20) = 1.4$$

23.2

$$Q = 23.2(0.0156(17) + 0.0039(12.65)^2)^{1/2}$$

$$Q = 22 \text{ cfh}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 100, Mc Pherson 370 ft²/room

Room 1 (cont)

Improved

door : (0.114) (20) = 2.3

frame : (0.014) (20) = 0.3

Unimproved : = 18.7
21.3

$Q = 21.3 / (0.0156(17) + 0.0039(12.65)^2)^{1/2}$

Q = 20 cfm

$\Delta cfm = 22 - 20 = 2 cfm$

- for simulation, assume 1/2 ACH = 293 cfm

improved = 293 - 2 = 291 cfm

Room 2

Unimproved

door : (0.157) (40) = 6.3

frame : (0.072) (40) = 2.9

9.2

$Q = 9.2 / (0.0156(17) + 0.0039(12.65)^2)^{1/2}$

Q = 9 cfm

Improved

door : (0.118) (40) = 4.6

frame : (0.014) (40) = 0.6

5.2

$Q = 5.9 / (0.0156(17) + 0.0039(12.65)^2)^{1/2}$

Q = 6 cfm

$\Delta cfm = 9 - 6 = 3 cfm$

- for simulation, assume 1/2 ACH = 131 cfm

- improved = 131 - 3 = 128 cfm

Total Delta cfm

2 + 3 = 5 cfm

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 100, McPherson

ECO # 3 (cont)

Electric Savings

Total Electric Savings = 23 kWh/yr

Electric Savings/dftm = 4.6 kWh/yr/dftm

Demand Savings

Peak Demand Savings = 0 kW

Gas Savings

Total Gas Savings = 0.125 MBtu/yr

Gas Savings/dftm = 0.025 MBtu/yr/dftm

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 100, Mc Pherson

ECO #12 - HVAC Controls

- Setback thermostats + change setpoints to 78°F Cooling + 70°F Heating
- Turn off fans with timer lock
- Reset deck temperature for demand
- Turn off pump w/ timer lock + cycle with load

Electric Savings

Total Electric Savings = $\boxed{71,096}$ kWh/yr

Demand Savings

Peak Demand Savings = $\boxed{5}$ kW

Gas Savings

Total Gas Savings $\boxed{0.18}$ MBtu/yr

Pump + Fan Schedule

- On 06:00 - 18:00 M-F, otherwise off

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 100, McPherson

ECO # 15 - Lighting Reduction

Lighting Reduction

reduction = 38%

<u>Rm</u>	<u>Incand (w)</u>	<u>Reduced (w)</u>
1	6,312	3,913
2	1,370	849

kWh Reduction = 8,086 kWh

Electric Factor

Reduced Electric Use = cooling - heating = 1,710 - 156 = 1554 kWh/yr

Electric savings/lighting kWh = 0.19 kWh/kWh

Gas Factor

Increased Gas Use = 1.8 MBtu/yr

Gas increase/lighting kWh = 2.2×10^{-4} MBtu/kWh

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EAP
 Location: FT MCPHERSON, BLDG 100
 Program User: R. GERRANS

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month Cooling Simulation	Last Month Cooling Simulation	Peak Load Hr	1st Month Summer Period	Last Month Summer Period	1st Month Daylight Savings	Last Month Daylight Savings
MAY						OCT

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG M100, BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	UPSTAIRS	114.33	32.33		1.5		11			
2	2	BASEMENT	114.33	32.33		1.5		10			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location Flag	T'stat Location	Mass / Average No. Hrs On Floor	Carpet
1	76			CLG	72		HTG				
2	76			CLG	72		HTG				

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	114.33	41	.044	38	90	55	.9

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M1	1		11	.067	79				
1	1	32.33				0			
1	2	114.33				90			
1	3	32.33				180			
1	4	114.33				270			
M2	1		1.0	1.15	91				
2	1	32.33				0			
2	2	114.33				90			
2	3	32.33				180			
2	4	114.33				270			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar to Ret. Air	Visible Transmittance	Inside Visible Reflectance
M1	1	5	2.5		.7	.58					
1	1			3							
1	2			9							
1	3			2							
1	4			9							

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
M1	ADMPPL	ADMLGTEQ	OFF	AVAIL		AVAIL				

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	Daylighting Reference Point 1	Daylighting Reference Point 2
1	18	PEOPLE	250	200	6312	WATTS					
2	1	PEOPLE	250	200	1370	WATTS					

-----CARD 28--- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
1	1	MISC EQUIP	5		BTUH-SF	ADMLGTEQ	ELEC				
2	1	MISC EQUIP	1		BTUH-SF	ADMLGTEQ	ELEC				

-----CARD 29--- Room Airflows -----

Room Number	-----Ventilation-----				-----Infiltration-----				--Reheat Minimum--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
	Value	Units	Value	Units	Value	Units	Value	Units	Value	Units
1					.5	ACH-HR	.5	ACH-HR		
2					.25	ACH-HR	.25	ACH-HR		

-----CARD 30- Fan Airflows -----

Room Number	-----Main-----				-----Auxiliary-----				--Room Exhaust--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
	Value	Units	Value	Units	Value	Units	Value	Units	Value	Units
1									1045	CFM
2	1740	CFM								

-----CARD 32-- Exposed Floor Parameters-----

Room Number	Exposed			-----Exposed Floor-----						
	Floor Number	Perimeter Length	Slab Loss Coefficient	Floor Area	Floor U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No
2	1	3696	.021							

----- System Section Alternative #1 -----

-----CARD 39-- System Alternative -----

Number	Description
1	BLDG M100, BASELINE

-----CARD 40--- System Type -----

System Set Number	System Type	-----OPTIONAL VENTILATION SYSTEM-----						Fan
		Ventil Deck Location	Cooling SADBvh	Heating SADBvh	Cooling Schedule	Heating Schedule	Static Pressure	
1	SZ							
2	SZ							

-----CARD 65-- Heating Load Assignment -----

Load	All Coil										
Assignment	Loads To	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-	
Reference	Heating Ref	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
1	1	1	2								

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number	HW Pmp Full Ld	Energy Rate	Seq Order	Switch over	Hot Strg	Misc. Acc.	Cogen	Demand Limit				
Number	Name	Units	Value	Units	Value	Units	Value	Units	Number	Control	Strg	Acc.	Cogen	Number
1	EQ2001	1	.28	KW	250	MBH								

-----CARD 69-- Fan Equipment Parameters -----

System Set	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	EQ4003					EQ4372	
2	EQ4003						

Utility Description Reference Table

Schedules:

ADMLGTEQ ADMIN LIGHTING AND EQUIPMENT
ADMPPL ADMIN PEOPLE SCHEDULE
AVAIL AVAILABLE (100%)
CLG COOLING TSTAT SCHEDULE
CLGC COOLING COIL SCHEDULE
HTG HEATING TSTAT SCHEDULE
HTGC HEATING COIL SCHEDULE
OFF ALWAYS OFF

System:

SZ SINGLE ZONE

Equipment:

Cooling:

EQ1161 AIR-CLD COND COMP <15 TONS

Heating:

EQ2001 GAS FIRE TUBE HOT WATER

Fan:

EQ4003 FC CENTRIF. FAN C.V.
EQ4372 UNIT VENTILATOR FAN

Schedule Name: ADMLGTEQ

Project: ADMIN LIGHTING AND EQUIPMENT SC

Location:

Client:

Program User:

Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

0 5
7 80
8 100
12 80
13 100
16 80
17 40
18 5
24

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

0 5
24

Schedule Name: ADMPPL
Project: ADMIN PEOPLE SCHEDULE
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

```
*****  
*****  
**  
**          T R A C E    6 0 0    A N A L Y S I S          **  
**  
**          by          **  
**  
*****  
*****
```

FT MCPHERSON & FT GILLEM EEAP
FT MCPHERSON, BLDG 100

R. GERRANS

Weather File Code:	ATLANTA.
Location:	ATLANTA, GEORGIA
Latitude:	33.0 (deg)
Longitude:	84.0 (deg)
Time Zone:	6
Elevation:	1,005 (ft)
Barometric Pressure:	28.8 (in. Hg)
Summer Clearness Number:	0.90
Winter Clearness Number:	0.90
Summer Design Dry Bulb:	92 (F)
Summer Design Wet Bulb:	74 (F)
Winter Design Dry Bulb:	22 (F)
Summer Ground Relectance:	0.20
Winter Ground Relectance:	0.20
Air Density:	0.0731 (Lbm/cuft)
Air Specific Heat:	0.2444 (Btu/lbm/F)
Density-Specific Heat Prod:	1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor:	4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor:	4.3883 (Lb-min./hr/cuft)
Design Simulation Period:	May To October
System Simulation Period:	January To December
Cooling Load Methodology:	TETD/Time Averaging
Time/Date Program was Run:	8:28:40 4/ 8/92
Dataset Name:	M100-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M100, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Main Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Auxil. Supply Airflow (Cfm)	Room Exhaust Airflow (Cfm)
1	SZ	0	6,648	6,648	6,941	293	0	1,045
2	SZ	0	1,740	1,740	1,871	131	0	0
Totals		0	8,388	8,388	8,812	424	0	1,045

CAPACITY - ALTERNATIVE 1
 BLDG M100, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	Cooling				Heating						
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Vent Capacity (Btuh)	Heating Totals (Btuh)
1	SZ	9.0	0.0	0.0	9.0	-32,746	0	0	0	0	0	-32,746
2	SZ	2.1	0.0	0.0	2.1	-24,570	0	0	0	0	0	-24,570
Totals		11.1	0.0	0.0	11.1	-57,316	0	0	0	0	0	-57,316

The building peaked at hour 15 month 6 with a capacity of 11.1 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M100, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/Sq Ft	Cfm/Ton	Sq Ft/Ton	Btuh/Sq Ft	Cfm/Sq Ft	Btuh/Sq Ft	
1	Main	SZ	0.00	1.80	735.8	409.1	29.33	1.80	-8.86	3,696
2	Main	SZ	0.00	0.47	828.2	1,759.4	6.82	0.47	-6.65	3,696

System 1 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****					CLG SPACE PEAK *****			HEATING COIL PEAK *****		
Peaked at Time ==>	Mo/Hr: 6/15				Mo/Hr: 6/16	*		Mo/Hr: 13/ 1		
Outside Air ==>	OADB/WB/HR: 96/ 73/ 91.0				OADB: 96	*		OADB: 22		
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	Space Sensible (Btuh)	Perct Of Tot (%)	Space Peak Space Sens (Btuh)	Coil Peak Tot Sens (Btuh)	Perct Of Tot (%)
Skylite Solr	0	0	0	0	0.00	0	0.00	0	0	0.00
Skylite Cond	0	0	0	0	0.00	0	0.00	0	0	0.00
Roof Cond	0	13,130	0	13,130	12.11	0	0.00	0	-8,585	26.22
Glass Solar	14,662	0	0	14,662	13.52	15,812	17.72	0	-10,686	32.63
Glass Cond	4,065	0	0	4,065	3.75	3,945	4.42	-10,686	-9,599	29.31
Wall Cond	5,475	618	0	6,093	5.62	5,910	6.62	-8,372	-9,599	29.31
Partition	0	0	0	0	0.00	0	0.00	0	0	0.00
Exposed Floor	0	0	0	0	0.00	0	0.00	0	0	0.00
Infiltration	10,523	0	0	10,523	9.71	6,152	6.89	-15,695	-15,695	47.93
Sub Total==>	34,726	13,748	0	48,474	44.71	31,820	35.66	-34,753	-44,564	136.09
Internal Loads										
Lights	21,543	0	0	21,543	19.87	21,543	24.14	0	0	0.00
People	8,100	0	0	8,100	7.47	4,500	5.04	0	0	0.00
Misc	18,481	0	0	18,481	17.05	18,481	20.71	0	0	0.00
Sub Total==>	48,124	0	0	48,124	44.39	44,524	49.90	0	0	0.00
Ceiling Load	13,748	-13,748	0	0	0.00	12,885	14.44	-9,812	0	0.00
Outside Air	0	0	0	0	0.00	0	0.00	0	11,819	-36.09
Sup. Fan Heat	0	0	0	11,819	10.90	0	0.00	0	0	0.00
Ret. Fan Heat	0	0	0	0	0.00	0	0.00	0	0	0.00
Duct Heat Pkup	0	0	0	0	0.00	0	0.00	0	0	0.00
CV/UNDR Sizing	0	0	0	0	0.00	0	0.00	0	0	0.00
Exhaust Heat	0	0	0	0	0.00	0	0.00	0	0	0.00
Terminal Bypass	0	0	0	0	0.00	0	0.00	0	0	0.00
Grand Total==>	96,599	0	0	108,417	100.00	89,229	100.00	-44,564	-32,746	100.00

-----COOLING COIL SELECTION-----											AREAS	
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total	Glass (sf)	(%)
				Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor		
Main Clg	9.0	108.4	6,648	76.0	63.2	69.8	61.8	57.9	68.2	3,696		
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0	
0										Roof	4,688	0
Totals	9.0	108.4								Wall	3,227	288

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			--ENGINEERING CHECKS--			--TEMPERATURES (F)---		
	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA		Type	Clg	Htg	
								Clg Cfm/Sqft					
Main Htg	-32.7	6,648	72.0	76.6	Vent	0	0	1.80	0.0	SADB	63.5	78.2	
Aux Htg	0.0	0	0.0	0.0	Infil	293	293	Clg Cfm/Ton	735.82	Plenum	87.7	63.6	
Preheat	-0.0	6,648	72.0	61.8	Supply	6,648	6,648	Clg Sqft/Ton	409.12	Return	76.0	72.0	
Reheat	0.0	0	0.0	0.0	Mincfm	0	0	Clg Btuh/Sqft	29.33	Ret/OA	76.0	72.0	
Humidif	0.0	0	0.0	0.0	Return	5,896	6,648	No. People	18	Runarnd	76.0	72.0	
Opt Vent	0.0	0	0.0	0.0	Exhaust	0	0	Htg % OA	0.0	Fn MtrTD	0.4	0.0	
Total	-32.7				Rm Exh	1,045	0	Htg Cfm/SqFt	1.80	Fn BldTD	0.3	0.0	
					Auxil	0	0	Htg Btuh/SqFt	-8.86	Fn Frict	0.9	0.0	

System 2 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****					CLG SPACE PEAK *****			***** HEATING COIL PEAK *****					
Peaked at Time ==>					Mo/Hr: 7/15			Mo/Hr: 6/16			Mo/Hr: 13/ 1		
Outside Air ==>					OADB/WB/HR: 92/ 74/105.0			OADB: 96			OADB: 22		
	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	Space Sensible (Btuh)	Perct Of Tot (%)	Space Peak Sens (Btuh)	Coil Peak Tot Sens (Btuh)	Perct Of Tot (%)			
Envelope Loads													
Skylite Solr	0	0	0	0	0.00	0	0.00	0	0	0.00			
Skylite Cond	0	0	0	0	0.00	0	0.00	0	0	0.00			
Roof Cond	0	0	0	0	0.00	0	0.00	0	0	0.00			
Glass Solar	0	0	0	0	0.00	0	0.00	0	0	0.00			
Glass Cond	0	0	0	0	0.00	0	0.00	0	0	0.00			
Wall Cond	7,082	1,198	0	8,280	32.84	8,114	38.90	-14,336	-16,761	68.22			
Partition	0	0	0	0	0.00	0	0.00	0	0	0.00			
Exposed Floor	0	0	0	0	0.00	0	0.00	-3,881	-3,881	15.79			
Infiltration	5,015	0	0	5,015	19.89	2,752	13.19	-7,021	-7,021	28.58			
Sub Total==>	12,097	1,198	0	13,295	52.74	10,867	52.09	-25,238	-27,663	112.59			
Internal Loads													
Lights	4,676	0	0	4,676	18.55	4,676	22.41	0	0	0.00			
People	450	0	0	450	1.79	250	1.20	0	0	0.00			
Misc	3,696	0	0	3,696	14.66	3,696	17.72	0	0	0.00			
Sub Total==>	8,822	0	0	8,822	34.99	8,622	41.33	0	0	0.00			
Ceiling Load	1,198	-1,198	0	0	0.00	1,373	6.58	-2,425	0	0.00			
Outside Air	0	0	0	0	0.00	0	0.00	0	0	0.00			
Sup. Fan Heat	0	0	0	3,093	12.27	0	0.00	0	3,093	-12.59			
Ret. Fan Heat	0	0	0	0	0.00	0	0.00	0	0	0.00			
Duct Heat Pkup	0	0	0	0	0.00	0	0.00	0	0	0.00			
OV/UNDR Sizing	0	0	0	0	-0.00	0	-0.00	0	0	0.00			
Exhaust Heat	0	0	0	0	0.00	0	0.00	0	0	0.00			
Terminal Bypass	0	0	0	0	0.00	0	0.00	0	0	0.00			
Grand Total==>	22,117	0	0	25,210	100.00	20,861	100.00	-27,663	-24,570	100.00			

-----COOLING COIL SELECTION-----											-----AREAS-----	
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)
Main Clg	2.1	25.2	1,740	76.0	64.0	73.7	63.2	59.3	72.6	3,696		
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	3,696		
0												
Totals	2.1	25.2								Wall	293	0
0												

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg	
Main Htg	-24.6	1,740	72.0	85.2	Vent	0	0	Clg Cfm/Sqft	0.47	SADB	64.8	86.8	
Aux Htg	0.0	0	0.0	0.0	Infil	131	131	Clg Cfm/Ton	828.24	Plenum	77.0	69.9	
Preheat	-0.0	1,740	72.0	63.2	Supply	1,740	1,740	Clg Sqft/Ton	1759.44	Return	76.0	72.0	
Reheat	0.0	0	0.0	0.0	Mincfm	0	0	Clg Btuh/Sqft	6.82	Ret/OA	76.0	72.0	
Humidif	0.0	0	0.0	0.0	Return	1,740	1,740	No. People	1	Runarnd	76.0	72.0	
Opt Vent	0.0	0	0.0	0.0	Exhaust	0	0	Htg % OA	0.0	Fn MtrTD	0.4	0.0	
Total	-24.6				Rm Exh	0	0	Htg Cfm/SqFt	0.47	Fn BldTD	0.3	0.0	
					Auxil	0	0	Htg Btuh/SqFt	-6.65	Fn Frict	0.9	0.0	

COOLING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M100, BASELINE

----- A I R F L O W H E A T G A I N A N D L O S S -----
 (At time of Coil Peak)

Room Number	Description	Duct Heat Pickup (Btuh)	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Cooling							
						Total (Btuh)	System Exhaust (Cfm)	Room Exhaust (Cfm)	Ducted (Cfm)	Plenum (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)
1	UPSTAIRS	0	11,819	0	0	11,819	0	1,045	0	0	0	5,896	5,896
Zone	1 Total/Ave.	0	11,819	0	0	11,819	0	1,045	0	0	0	5,896	5,896
Zone	1 Block	0	11,819	0	0	11,819	0	1,045	0	0	0	5,896	5,896
System	1 Total/Ave.	0	11,819	0	0	11,819	0	1,045	0	0	0	5,896	5,896
System	1 Block	0	11,819	0	0	11,819	0	1,045	0	0	0	5,896	5,896
2	BASEMENT	0	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
Zone	2 Total/Ave.	0	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
Zone	2 Block	0	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
System	2 Total/Ave.	0	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
System	2 Block	0	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740

HEATING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M100, BASELINE

----- A I R F L O W H E A T G A I N A N D L O S S -----
 (At time of Coil Peak)

Room Number	Description	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Total (Btuh)	Heating						
						System Exhaust (Cfm)	Room Exhaust (Cfm)	Ducted (Cfm)	Plenum (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)
1	UPSTAIRS	11,819	0	0	11,819	0	0	0	0	0	6,648	6,648
Zone	1 Total/Ave.	11,819	0	0	11,819	0	0	0	0	0	6,648	6,648
Zone	1 Block	11,819	0	0	11,819	0	0	0	0	0	6,648	6,648
System	1 Total/Ave.	11,819	0	0	11,819	0	0	0	0	0	6,648	6,648
System	1 Block	11,819	0	0	11,819	0	0	0	0	0	6,648	6,648
2	BASEMENT	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
Zone	2 Total/Ave.	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
Zone	2 Block	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
System	2 Total/Ave.	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740
System	2 Block	3,093	0	0	3,093	0	0	1,740	0	0	0	1,740

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

ZONE PSYCHROMETRICS - ALTERNATIVE 1
BLDG M100, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone	1						
		Dry	Wet	Relat.	Humid.		Temp.
		Bulb	Bulb	Humid.	Ratio	Enthalpy	Diff.
		(F)	(F)	(%)	(GR)	(Btu/Lb)	(F)
Space		76.0	63.2	50.0	69.8	29.2	
Main System							0.0
Return Air Heat Pickup							0.0
Return Fan							
Return Air		76.0	63.2	50.0	69.8	29.2	
Outdoor Air		96.2	73.2	34.1	91.0	37.4	
Return/Outdoor Air Mix		76.0	63.2	50.0	69.8	29.2	
Blow through Fan							0.0
Entering Coil		76.0	63.2	50.0	69.8	29.2	
Leaving Coil		61.8	58.0	80.0	68.7	25.5	
Draw Through Fan							0.7
Duct Frictional Heat							0.9
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		63.5	58.6	75.5	68.7	25.9	
Supply Air		63.5	58.6	75.5	68.7	25.9	
Percent Outside Air			0.00	(%)			
Sensible Heat Ratio (SHR)			0.933				
Percent Supply Air Bypassing Coil			0.00	(%)			
Coil Airflow			6,648	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M100, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone	2						
	Dry	Wet	Relat.	Humid.		Temp.	
	Bulb	Bulb	Humid.	Ratio	Enthalpy	Diff.	
	(F)	(F)	(%)	(GR)	(Btu/Lb)	(F)	
Space	76.0	64.0	52.7	73.7	29.8		
Main System							
Return Air Heat Pickup						0.0	
Return Fan						0.0	
Return Air	76.0	64.0	52.7	73.7	29.8		
Outdoor Air	92.0	74.4	44.6	105.0	38.6		
Return/Outdoor Air Mix	76.0	64.0	52.7	73.7	29.8		
Blow through Fan						0.0	
Entering Coil	76.0	64.0	52.7	73.7	29.8		
Leaving Coil	63.2	59.3	80.6	72.6	26.5		
Draw Through Fan						0.7	
Duct Frictional Heat						0.9	
Supply Duct Heat Gain						0.0	
Cold Deck Supply Air	64.8	59.9	76.0	72.6	26.9		
Supply Air	64.8	59.9	76.0	72.6	26.9		
Percent Outside Air		0.00	(%)				
Sensible Heat Ratio (SHR)		0.935					
Percent Supply Air Bypassing Coil		0.00	(%)				
Coil Airflow		1,740	(Cfm)				

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M100, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Part.	ExFlr	Room U-Values (Btu/hr/sqft/F)							Room Mass (lb/sqft)	Room Capac. (Btu/sqft/F)
				Summr Skylt	Wintr Skylt	Summr Roof	Wintr Windo	Summr Windo	Wall	Ceil.		
1	UPSTAIRS	0.000	0.000	0.000	0.000	0.044	0.700	0.743	0.067	0.317	47.7	12.24
Zone 1	Total/Ave.	0.000	0.000	0.000	0.000	0.044	0.700	0.743	0.067	0.317	47.7	12.24
System 1	Total/Ave.	0.000	0.000	0.000	0.000	0.044	0.700	0.743	0.067	0.317	47.7	12.24
2	BASEMENT	0.000	0.021	0.000	0.000	0.000	0.000	0.000	1.150	0.317	16.7	3.33
Zone 2	Total/Ave.	0.000	0.021	0.000	0.000	0.000	0.000	0.000	1.150	0.317	16.7	3.33
System 2	Total/Ave.	0.000	0.021	0.000	0.000	0.000	0.000	0.000	1.150	0.317	16.7	3.33
Building		0.000	0.021	0.000	0.000	0.044	0.700	0.743	0.165	0.317	32.2	7.79

BUILDING AREAS - ALTERNATIVE 1
 BLDG M100, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed			Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
		Flr	Rm				Floor Area (sqft)	Skylight Area (sqft)	SKl /Rf (%)				
1	UPSTAIRS	1	1	3,696	3,696	0	0	0	0	4,688	288	9	2,939
Zone 1	Total/Ave.				3,696	0	0	0	0	4,688	288	9	2,939
System 1	Total/Ave.				3,696	0	0	0	0	4,688	288	9	2,939
2	BASEMENT	1	1	3,696	3,696	0	3,696	0	0	0	0	0	293
Zone 2	Total/Ave.				3,696	0	3,696	0	0	0	0	0	293
System 2	Total/Ave.				3,696	0	3,696	0	0	0	0	0	293
Building					7,393	0	3,696	0	0	4,688	288	8	3,232

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
BLDG M100, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.044 (Btu/Hr/Sq Ft/F)
Overall Wall U-Value = 0.209 (Btu/Hr/Sq Ft/F)
Overall Building U-Value = 0.115 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 2.25 (Btu/Hr/Sq Ft)
Wall Overall Thermal Transfer Value (OTTVw) = 12.20 (Btu/Hr/Sq Ft)

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M100, BASELINE

----- SYSTEM LOAD PROFILE -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.6	4	164	-2,866	26	367	419.4	0	0	0.0	0	0
5 - 10	1.1	9	401	-5,732	34	476	838.8	0	0	0.0	0	0
10 - 15	1.7	12	507	-8,597	30	423	1,258.2	0	0	0.0	0	0
15 - 20	2.2	13	570	-11,463	11	153	1,677.6	0	0	0.0	0	0
20 - 25	2.8	12	489	-14,329	0	0	2,097.0	0	0	0.0	0	0
25 - 30	3.3	8	346	-17,195	0	0	2,516.4	0	0	0.0	0	0
30 - 35	3.9	6	246	-20,060	0	0	2,935.8	0	0	0.0	0	0
35 - 40	4.5	4	163	-22,926	0	0	3,355.2	0	0	0.0	0	0
40 - 45	5.0	5	207	-25,792	0	0	3,774.6	0	0	0.0	0	0
45 - 50	5.6	1	41	-28,658	0	0	4,194.0	0	0	0.0	0	0
50 - 55	6.1	6	237	-31,524	0	0	4,613.4	0	0	0.0	0	0
55 - 60	6.7	2	88	-34,389	0	0	5,032.8	0	0	0.0	0	0
60 - 65	7.2	3	147	-37,255	0	0	5,452.2	0	0	0.0	0	0
65 - 70	7.8	5	219	-40,121	0	0	5,871.6	0	0	0.0	0	0
70 - 75	8.4	5	232	-42,987	0	0	6,291.0	0	0	0.0	0	0
75 - 80	8.9	0	0	-45,852	0	0	6,710.4	0	0	0.0	0	0
80 - 85	9.5	4	173	-48,718	0	0	7,129.8	0	0	0.0	0	0
85 - 90	10.0	1	22	-51,584	0	0	7,549.2	0	0	0.0	0	0
90 - 95	10.6	0	0	-54,450	0	0	7,968.6	0	0	0.0	0	0
95 - 100	11.1	0	0	-57,316	0	0	8,388.0	100	8,760	0.0	0	0
Hours Off	0.0	0	4,508	0	0	7,341	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M100, BASELINE

January			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-14,345	0.0	0	0.0	-5,104	0.0	-5,104	0.0	-5,104	0.0
2	32.1	29.3	-16,890	0.0	0	0.0	-5,755	0.0	-5,755	0.0	-5,755	0.0
3	31.7	29.3	-19,008	0.0	-5,085	0.0	-6,514	0.0	-6,514	0.0	-6,514	0.0
4	31.9	29.5	-20,135	0.0	-7,065	0.0	-7,067	0.0	-7,067	0.0	-7,067	0.0
5	32.6	30.3	-21,093	0.0	-7,963	0.0	-7,964	0.0	-7,964	0.0	-7,964	0.0
6	33.6	31.3	-22,146	0.0	-8,399	0.0	-8,399	0.0	-8,399	0.0	-8,399	0.0
7	35.0	32.6	-22,314	0.0	-8,828	0.0	-8,828	0.0	-8,828	0.0	-8,828	0.0
8	36.6	34.4	-2,509	0.0	-2,856	0.0	-9,260	0.0	-9,260	0.0	-2,856	0.0
9	38.5	36.3	-722	0.0	-1,364	0.0	-9,568	0.0	-9,568	0.0	-1,364	0.0
10	40.4	37.7	-357	0.0	-1,422	0.0	-9,626	0.0	-9,626	0.0	-1,422	0.0
11	42.3	38.7	0	0.0	-764	0.0	-8,968	0.0	-8,968	0.0	-764	0.0
12	44.2	39.6	0	0.0	0	0.0	-8,241	0.0	-8,241	0.0	0	0.0
13	45.8	40.5	0	0.0	-1,173	0.0	-7,552	0.0	-7,552	0.0	-1,173	0.0
14	47.2	41.1	0	0.0	0	0.0	-6,817	0.0	-6,817	0.0	0	0.0
15	48.2	41.6	0	0.0	0	0.0	-6,155	0.0	-6,155	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	-5,366	0.0	-5,366	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	-4,729	0.0	-4,729	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	-3,851	0.0	-3,851	0.0	0	0.0
19	47.4	41.7	0	0.0	0	0.0	-3,063	0.0	-3,063	0.0	0	0.0
20	45.5	40.5	0	0.0	0	0.0	-2,909	0.0	-2,909	0.0	0	0.0
21	43.1	38.9	0	0.0	-2,586	0.0	-3,193	0.0	-3,193	0.0	-2,586	0.0
22	40.4	36.7	0	0.0	-3,563	0.0	-3,564	0.0	-3,564	0.0	-3,563	0.0
23	37.7	34.3	0	0.0	-4,017	0.0	-4,017	0.0	-4,017	0.0	-4,017	0.0
24	35.3	32.3	0	0.0	-4,861	0.0	-4,861	0.0	-4,861	0.0	-4,861	0.0

February			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	-4,276	0.0	0	0.0	-5,562	0.0	-5,562	0.0	-5,562	0.0
2	36.0	33.0	-5,059	0.0	0	0.0	-6,145	0.0	-6,145	0.0	-6,145	0.0
3	34.7	31.8	-6,149	0.0	-253	0.0	-6,670	0.0	-6,670	0.0	-6,670	0.0
4	33.6	30.9	-6,875	0.0	-7,061	0.0	-7,058	0.0	-7,058	0.0	-7,058	0.0
5	32.8	30.1	-7,574	0.0	-7,764	0.0	-7,768	0.0	-7,768	0.0	-7,768	0.0
6	32.2	29.8	-7,867	0.0	-8,208	0.0	-8,208	0.0	-8,208	0.0	-8,208	0.0
7	32.1	29.6	-8,425	0.0	-8,960	0.0	-8,960	0.0	-8,960	0.0	-8,960	0.0
8	32.5	30.3	-2,160	0.0	-3,025	0.0	-9,429	0.0	-9,429	0.0	-3,025	0.0
9	33.9	31.6	-414	0.0	-1,407	0.0	-9,611	0.0	-9,611	0.0	-1,407	0.0
10	36.0	33.0	0	0.0	-1,616	0.0	-9,820	0.0	-9,820	0.0	-1,616	0.0
11	38.5	34.8	0	0.0	-1,468	0.0	-9,672	0.0	-9,672	0.0	-1,468	0.0
12	41.3	36.5	0	0.0	-1,173	0.0	-9,326	0.0	-9,326	0.0	-1,173	0.0
13	43.8	38.1	0	0.0	-2,321	0.0	-8,700	0.0	-8,700	0.0	-2,321	0.0
14	45.9	39.5	0	0.0	0	0.0	-7,787	0.0	-7,787	0.0	0	0.0
15	47.2	40.4	0	0.0	0	0.0	-6,898	0.0	-6,898	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	-6,680	0.0	-6,680	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	-5,737	0.0	-5,737	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	-5,184	0.0	-5,184	0.0	0	0.0
19	46.2	39.9	0	0.0	-2,610	0.0	-4,148	0.0	-4,148	0.0	-2,610	0.0
20	45.1	39.7	0	0.0	-3,722	0.0	-3,721	0.0	-3,721	0.0	-3,722	0.0
21	43.8	39.2	0	0.0	-3,575	0.0	-3,576	0.0	-3,576	0.0	-3,575	0.0
22	42.3	38.3	0	0.0	-3,872	0.0	-3,872	0.0	-3,872	0.0	-3,872	0.0
23	40.7	37.2	0	0.0	-4,459	0.0	-4,459	0.0	-4,459	0.0	-4,459	0.0
24	39.1	35.8	0	0.0	-4,782	0.0	-4,782	0.0	-4,782	0.0	-4,782	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M100, BASELINE

March			----- Design -----		----- Weekday -----		----- Saturday -----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	43.3	39.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	41.6	38.6	0	0.0	0	0.0	0	0.0	0	0.0	-732	0.0
4	40.6	37.5	-1,132	0.0	0	0.0	0	0.0	0	0.0	-3,034	0.0
5	40.2	37.3	-2,386	0.0	0	0.0	0	0.0	0	0.0	-3,722	0.0
6	40.6	37.8	-2,999	0.0	0	0.0	0	0.0	0	0.0	-4,314	0.0
7	41.6	39.0	-3,516	0.0	0	0.0	0	0.0	-4,326	0.0	-5,231	0.0
8	43.3	40.7	0	0.0	0	0.0	0	0.0	-5,386	0.0	0	0.0
9	45.4	42.5	0	0.0	0	0.0	0	0.0	-5,874	0.0	0	0.0
10	47.9	44.3	0	0.0	0	0.0	0	0.0	-6,093	0.0	0	0.0
11	50.6	45.5	0	0.0	0	0.0	0	0.0	-5,142	0.0	0	0.0
12	53.3	46.8	0	0.0	0	0.0	0	0.0	-4,229	0.0	0	0.0
13	55.8	48.5	0	0.0	0	0.0	0	0.0	-3,495	0.0	0	0.0
14	58.0	49.6	0	0.0	0	0.0	0	0.0	-2,543	0.0	0	0.0
15	59.6	50.3	0	0.0	0	0.0	0	0.0	-2,130	0.0	0	0.0
16	60.7	50.9	0	0.0	0	0.0	0	0.0	-1,460	0.0	0	0.0
17	61.0	50.9	0	0.0	0	0.0	0	0.0	-740	0.0	0	0.0
18	60.7	50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	59.6	50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	58.0	50.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	55.8	49.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	53.3	47.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	50.6	45.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	47.9	43.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

April			----- Design -----		----- Weekday -----		----- Saturday -----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2	51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	52.9	50.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	51.2	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.0	49.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	51.6	49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	53.3	50.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	55.9	51.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	59.0	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	62.4	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5	57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8	60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2	60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2	59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M100, BASELINE

May Hour	OADB	OAWB	----- Design -----		----- Weekday -----			----- Saturday-----		----- Sunday -----			----- Monday -----					
			Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	66.6	62.3		0		11.1		0		1.4		0		1.4		0		1.4
2	64.5	60.4		0		11.1		0		1.1		0		1.1		0		1.1
3	62.7	59.1		0		11.1		0		0.9		0		0.9		0		0.9
4	61.2	58.1		0		11.1		0		0.7		0		0.7		0		0.7
5	60.0	57.1		0		11.1		0		0.5		0		0.5		0		0.5
6	59.3	56.6		0		11.1		0		0.8		0		0.8		0		0.8
7	59.0	56.5		0		10.8		0		1.0		0		1.0		0		1.0
8	59.5	56.6		0		9.9		0		4.4		0		1.2		0		4.6
9	60.9	56.6		0		10.1		0		5.5		0		1.2		0		5.6
10	63.0	57.2		0		10.1		0		6.1		0		1.7		0		6.1
11	65.7	58.1		0		10.3		0		6.3		0		1.9		0		6.3
12	68.7	59.8		0		10.4		0		6.3		0		2.0		0		6.3
13	71.7	61.6		0		10.3		0		5.8		0		2.5		0		5.8
14	74.5	63.4		0		10.6		0		7.2		0		2.9		0		7.2
15	76.6	64.8		0		10.6		0		7.7		0		3.3		0		7.7
16	78.0	65.6		0		10.7		0		7.7		0		3.1		0		7.7
17	78.5	65.6		0		10.6		0		6.7		0		3.2		0		6.7
18	78.2	65.8		0		10.4		0		4.5		0		2.9		0		4.5
19	77.5	65.6		0		10.1		0		2.4		0		2.4		0		2.4
20	76.3	66.1		0		6.7		0		2.3		0		2.3		0		2.3
21	74.8	67.2		0		3.0		0		2.2		0		2.2		0		2.2
22	73.0	66.4		0		2.7		0		2.0		0		2.0		0		2.0
23	70.9	65.4		0		2.3		0		1.9		0		1.9		0		1.9
24	68.7	64.0		0		2.0		0		1.6		0		1.6		0		1.6

June Hour	OADB	OAWB	----- Design -----		----- Weekday -----			----- Saturday-----		----- Sunday -----			----- Monday -----					
			Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	73.0	67.9		0		3.0		0		2.3		0		2.3		0		2.3
2	71.2	66.1		0		2.7		0		2.0		0		2.0		0		2.0
3	69.7	65.2		0		2.5		0		1.8		0		1.8		0		1.8
4	68.5	64.3		0		2.3		0		1.6		0		1.6		0		1.6
5	67.8	64.2		0		2.2		0		1.4		0		1.4		0		1.4
6	67.6	64.2		0		2.8		0		1.7		0		1.8		0		1.8
7	68.1	64.8		0		3.4		0		2.0		0		2.0		0		2.0
8	69.4	65.7		0		7.2		0		5.8		0		2.2		0		5.8
9	71.6	66.2		0		8.6		0		7.1		0		2.6		0		7.1
10	74.2	67.2		0		9.0		0		7.8		0		3.2		0		7.8
11	77.2	68.5		0		9.4		0		7.9		0		3.4		0		7.9
12	80.2	70.0		0		9.6		0		8.1		0		3.6		0		8.1
13	82.8	70.8		0		9.1		0		7.5		0		4.1		0		7.5
14	85.0	71.6		0		10.6		0		9.1		0		4.7		0		9.1
15	86.3	72.3		0		11.1		0		9.5		0		5.0		0		9.5
16	86.8	72.1		0		11.1		0		9.5		0		4.9		0		9.5
17	86.6	71.7		0		9.8		0		8.2		0		4.6		0		8.2
18	85.8	71.5		0		7.3		0		6.0		0		4.4		0		6.0
19	84.7	71.2		0		4.7		0		3.7		0		3.7		0		3.7
20	83.2	71.5		0		4.4		0		3.6		0		3.7		0		3.6
21	81.4	71.7		0		4.1		0		3.4		0		3.4		0		3.4
22	79.3	71.4		0		3.8		0		3.1		0		3.1		0		3.1
23	77.2	70.5		0		3.4		0		2.8		0		2.8		0		2.8
24	75.1	69.1		0		3.1		0		2.5		0		2.5		0		2.5

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M100, BASELINE

July Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0	69.3	0	2.9	0	2.1	0	2.2	0	2.2	0	2.2
2	70.5	68.0	0	2.7	0	1.8	0	1.9	0	1.9	0	1.9
3	69.4	67.1	0	2.5	0	1.7	0	1.7	0	1.7	0	1.7
4	68.5	66.4	0	2.3	0	1.5	0	1.6	0	1.6	0	1.6
5	67.9	66.0	0	2.2	0	1.4	0	1.4	0	1.4	0	1.4
6	67.7	65.9	0	2.7	0	1.6	0	1.6	0	1.6	0	1.6
7	68.1	66.3	0	3.4	0	2.0	0	2.0	0	2.0	0	2.0
8	69.1	67.3	0	7.3	0	5.9	0	2.3	0	2.3	0	5.9
9	70.8	68.0	0	8.6	0	7.1	0	2.5	0	2.5	0	7.1
10	72.9	69.1	0	9.1	0	7.7	0	3.1	0	3.1	0	7.7
11	75.2	70.5	0	9.4	0	7.9	0	3.3	0	3.3	0	7.9
12	77.5	71.7	0	9.6	0	8.0	0	3.5	0	3.5	0	8.0
13	79.6	72.7	0	9.0	0	7.4	0	4.0	0	4.0	0	7.4
14	81.3	73.5	0	10.6	0	9.0	0	4.5	0	4.5	0	9.0
15	82.3	73.7	0	11.0	0	9.4	0	4.8	0	4.8	0	9.4
16	82.7	73.5	0	11.0	0	9.3	0	4.8	0	4.8	0	9.3
17	82.5	73.1	0	9.7	0	8.0	0	4.5	0	4.5	0	8.0
18	82.0	72.6	0	7.2	0	5.7	0	4.2	0	4.2	0	5.7
19	81.1	73.2	0	4.5	0	3.5	0	3.5	0	3.5	0	3.5
20	79.9	73.8	0	4.3	0	3.4	0	3.4	0	3.4	0	3.4
21	78.5	73.9	0	4.0	0	3.2	0	3.2	0	3.2	0	3.2
22	76.9	73.1	0	3.7	0	3.0	0	3.0	0	3.0	0	3.0
23	75.2	71.9	0	3.4	0	2.7	0	2.7	0	2.7	0	2.7
24	73.5	70.8	0	3.1	0	2.4	0	2.4	0	2.4	0	2.4

August Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7	70.2	0	3.0	0	2.1	0	2.2	0	2.2	0	2.2
2	71.2	69.0	0	2.7	0	1.9	0	2.0	0	2.0	0	2.0
3	69.9	68.0	0	2.5	0	1.7	0	1.8	0	1.8	0	1.8
4	68.8	67.1	0	2.3	0	1.6	0	1.6	0	1.6	0	1.6
5	68.0	66.6	0	2.1	0	1.4	0	1.4	0	1.4	0	1.4
6	67.5	66.2	0	2.3	0	1.5	0	1.5	0	1.5	0	1.5
7	67.3	66.1	0	3.2	0	1.9	0	2.0	0	2.0	0	2.0
8	67.8	66.5	0	7.2	0	5.9	0	2.1	0	2.1	0	5.9
9	69.1	67.0	0	8.6	0	7.0	0	2.4	0	2.4	0	7.0
10	71.2	67.8	0	9.0	0	7.5	0	2.9	0	2.9	0	7.5
11	73.8	68.7	0	9.3	0	7.6	0	3.0	0	3.0	0	7.6
12	76.5	70.0	0	9.4	0	7.8	0	3.3	0	3.3	0	7.8
13	79.1	71.2	0	8.8	0	7.3	0	3.9	0	3.9	0	7.3
14	81.1	72.6	0	10.5	0	8.9	0	4.5	0	4.5	0	8.9
15	82.5	73.6	0	11.0	0	9.4	0	4.8	0	4.8	0	9.4
16	83.0	73.7	0	11.0	0	9.1	0	4.5	0	4.5	0	9.1
17	82.8	73.5	0	9.6	0	7.9	0	4.3	0	4.3	0	7.9
18	82.3	73.5	0	6.9	0	5.4	0	3.8	0	3.8	0	5.4
19	81.5	73.1	0	4.4	0	3.3	0	3.4	0	3.4	0	3.3
20	80.4	73.7	0	4.3	0	3.3	0	3.3	0	3.3	0	3.3
21	79.1	74.9	0	4.0	0	3.2	0	3.2	0	3.2	0	3.2
22	77.6	73.9	0	3.7	0	2.9	0	2.9	0	2.9	0	2.9
23	76.0	72.7	0	3.4	0	2.7	0	2.7	0	2.7	0	2.7
24	74.3	71.3	0	3.1	0	2.4	0	2.4	0	2.4	0	2.4

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M100, BASELINE

September			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	69.8	66.1		0		2.4		0		1.5		0		1.7		0		1.7
2	68.0	64.5		0		2.1		0		1.3		0		1.5		0		1.5
3	66.3	63.0		0		1.9		0		1.2		0		1.2		0		1.2
4	64.9	61.9		0		1.7		0		1.0		0		1.0		0		1.0
5	63.9	61.3		0		1.6		0		0.8		0		0.9		0		0.9
6	63.2	61.0		0		1.4		0		0.7		0		0.7		0		0.7
7	63.0	60.8		0		2.4		0		1.2		0		1.2		0		1.2
8	63.4	61.4		0		6.3		0		4.9		0		1.4		0		5.0
9	64.7	61.8		0		7.7		0		6.1		0		1.6		0		6.1
10	66.6	62.1		0		8.1		0		6.3		0		1.8		0		6.4
11	69.1	62.9		0		8.4		0		6.8		0		2.2		0		6.8
12	71.8	63.7		0		8.6		0		6.8		0		2.4		0		6.8
13	74.5	65.5		0		8.2		0		6.3		0		2.9		0		6.3
14	77.0	67.1		0		9.7		0		7.9		0		3.5		0		7.9
15	78.9	68.2		0		10.1		0		8.1		0		3.5		0		8.1
16	80.2	68.6		0		10.0		0		8.1		0		3.5		0		8.1
17	80.6	68.5		0		8.5		0		6.9		0		3.4		0		6.9
18	80.4	68.9		0		5.6		0		4.4		0		2.8		0		4.4
19	79.7	70.0		0		3.7		0		2.7		0		2.8		0		2.7
20	78.7	71.2		0		3.5		0		2.7		0		2.7		0		2.7
21	77.3	71.6		0		3.2		0		2.6		0		2.6		0		2.6
22	75.6	70.5		0		2.9		0		2.4		0		2.4		0		2.4
23	73.7	69.4		0		2.6		0		2.2		0		2.2		0		2.2
24	71.8	67.7		0		2.3		0		2.0		0		2.0		0		2.0

October			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	54.8	51.3		0		0.4		0		0.3		0		0.3		0		0.2
2	52.9	49.6		0		0.1		0		0.1		0		0.1		0		0.1
3	51.2	48.2		0		0.0		0		0.0		0		0.0		0		0.0
4	49.8	47.2		0		0.0		0		0.0		0		0.0		0		0.0
5	48.8	46.2		0		0.0		0		0.0		0		0.0		0		0.0
6	48.2	45.7		0		0.0		0		0.0		0		0.0		0		0.0
7	47.9	45.6		0		0.0		0		0.0		0		0.0		0		0.0
8	48.5	46.2		0		3.6		0		2.6		0		0.0		0		2.6
9	50.3	47.3		0		5.3		0		4.0		0		0.4		0		4.0
10	52.9	48.7		0		5.7		0		4.4		0		0.7		0		4.2
11	56.2	49.9		0		6.0		0		4.7		0		0.8		0		4.3
12	59.6	51.5		0		6.3		0		5.0		0		1.1		0		4.5
13	62.9	53.5		0		5.9		0		4.4		0		1.4		0		4.3
14	65.5	55.2		0		7.4		0		5.6		0		1.6		0		5.7
15	67.3	56.3		0		7.7		0		5.9		0		1.7		0		5.9
16	67.9	56.6		0		7.6		0		6.0		0		1.6		0		6.0
17	67.7	56.4		0		5.8		0		4.6		0		1.1		0		4.6
18	67.0	56.6		0		3.6		0		2.6		0		0.9		0		2.6
19	66.0	57.6		0		1.9		0		1.1		0		0.9		0		1.1
20	64.6	57.9		0		1.6		0		1.0		0		0.8		0		1.0
21	62.9	57.3		0		1.3		0		0.9		0		0.7		0		0.9
22	61.0	56.0		0		1.0		0		0.7		0		0.6		0		0.7
23	59.0	54.8		0		0.8		0		0.5		0		0.4		0		0.5
24	56.9	53.0		0		0.5		0		0.4		0		0.3		0		0.4

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M100, BASELINE

November			----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	48.7	45.7	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
2	46.9	44.1	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
3	45.5	42.8	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
4	44.6	41.9	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
5	44.4	42.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
6	44.8	42.7	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
7	45.9	43.9	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
8	47.8	46.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
9	50.2	48.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
10	52.9	49.9	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
11	55.8	51.1	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
12	58.5	52.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
13	60.9	52.5	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
14	62.8	53.4	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
15	64.0	53.8	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
16	64.4	53.9	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
17	64.1	53.7	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
18	63.2	53.7	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
19	61.8	54.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
20	60.0	53.6	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
21	57.9	52.7	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
22	55.6	51.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
23	53.2	49.5	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0
24	50.8	47.6	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0

December			----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	37.5	35.3	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-4,456	0.0	0.0	0.0	-4,456	0.0	0.0	0.0
2	37.1	35.1	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-5,183	0.0	0.0	0.0	-5,183	0.0	0.0	0.0
3	37.4	35.5	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-5,871	0.0	0.0	0.0	-5,871	0.0	0.0	0.0
4	38.1	36.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-6,334	0.0	0.0	0.0	-6,334	0.0	0.0	0.0
5	39.3	37.6	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-4,857	0.0	0.0	0.0	-6,637	0.0	0.0	0.0	-6,637	0.0	0.0	0.0
6	40.9	39.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-7,159	0.0	0.0	0.0	-7,161	0.0	0.0	0.0	-7,161	0.0	0.0	0.0
7	42.7	41.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-7,544	0.0	0.0	0.0	-7,545	0.0	0.0	0.0	-7,545	0.0	0.0	0.0
8	44.7	43.1	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-7,793	0.0	0.0	0.0	-7,793	0.0	0.0	0.0	-1,389	0.0	0.0	0.0
9	46.8	45.3	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-7,622	0.0	0.0	0.0	-7,622	0.0	0.0	0.0	0	0.0	0.0	0.0
10	48.8	47.0	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-7,464	0.0	0.0	0.0	-7,464	0.0	0.0	0.0	0	0.0	0.0	0.0
11	50.7	48.1	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-6,712	0.0	0.0	0.0	-6,712	0.0	0.0	0.0	0	0.0	0.0	0.0
12	52.2	48.8	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-5,959	0.0	0.0	0.0	-5,959	0.0	0.0	0.0	0	0.0	0.0	0.0
13	53.4	49.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-4,961	0.0	0.0	0.0	-4,961	0.0	0.0	0.0	0	0.0	0.0	0.0
14	54.1	49.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-4,178	0.0	0.0	0.0	-4,178	0.0	0.0	0.0	0	0.0	0.0	0.0
15	54.4	48.9	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-3,543	0.0	0.0	0.0	-3,543	0.0	0.0	0.0	0	0.0	0.0	0.0
16	54.0	48.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-2,420	0.0	0.0	0.0	-2,420	0.0	0.0	0.0	0	0.0	0.0	0.0
17	53.0	47.3	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-1,929	0.0	0.0	0.0	-1,929	0.0	0.0	0.0	0	0.0	0.0	0.0
18	51.4	46.3	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-1,270	0.0	0.0	0.0	-1,270	0.0	0.0	0.0	0	0.0	0.0	0.0
19	49.3	45.4	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-872	0.0	0.0	0.0	-872	0.0	0.0	0.0	0	0.0	0.0	0.0
20	47.0	43.5	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-977	0.0	0.0	0.0	-977	0.0	0.0	0.0	0	0.0	0.0	0.0
21	44.5	41.5	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-1,556	0.0	0.0	0.0	-1,556	0.0	0.0	0.0	0	0.0	0.0	0.0
22	42.2	39.3	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-2,400	0.0	0.0	0.0	-2,400	0.0	0.0	0.0	0	0.0	0.0	0.0
23	40.1	37.6	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-2,814	0.0	0.0	0.0	-2,814	0.0	0.0	0.0	0	0.0	0.0	0.0
24	38.5	36.2	0	0.0	0.0	0.0	0	0.0	0.0	0.0	-3,502	0.0	0.0	0.0	-3,502	0.0	0.0	0.0	0	0.0	0.0	0.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M100, BASELINE

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	10,634	25	34	0
Feb	9,620	25	32	0
March	10,542	24	3	0
April	9,874	24	0	0
May	13,619	40	0	0
June	14,759	41	0	0
July	14,536	41	0	0
Aug	15,008	41	0	0
Sept	13,289	40	0	0
Oct	12,230	38	0	0
Nov	9,874	24	0	0
Dec	10,283	24	14	0
Total	144,267	41	83	0

Building Energy Consumption = 67,729 (Btu/Sq Ft/Year)
Source Energy Consumption = 201,018 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M100, BASELINE

EQUIPMENT ENERGY CONSUMPTION

Ref Num	Equip Code	Monthly Consumption												Total	
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec		
0	LIGHTS ELEC PK	1778 7.7	1608 7.7	1920 7.7	1698 7.7	1849 7.7	1840 7.7	1707 7.7	1920 7.7	1698 7.7	1849 7.7	1698 7.7	1707 7.7	21,271 7.7	
1	MISC LD ELEC PK	1504 6.5	1360 6.5	1624 6.5	1436 6.5	1564 6.5	1556 6.5	1444 6.5	1624 6.5	1436 6.5	1564 6.5	1436 6.5	1444 6.5	17,993 6.5	
2	MISC LD GAS PK	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	
3	MISC LD OIL PK	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	
4	MISC LD P STEAM PK	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	
5	MISC LD P HOTW20 PK	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	
6	MISC LD P CHILL PK	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	
1	EQ1161 ELEC PK	0 0.0	AIR-CLD COND COMP <15 TONS				2770 15.0	4013 16.2	3819 15.6	3895 15.6	2925 15.3	1582 13.4	0 0.0	0 0.0	19,005 16.2
1	EQ5200 ELEC PK	0 0.0	CONDENSER FANS				248 1.4	394 1.5	378 1.5	381 1.5	274 1.3	105 1.0	0 0.0	0 0.0	1,779 1.5
1	EQ5303 ELEC PK	0 0.0	CONTROLS				223 0.3	216 0.3	223 0.3	223 0.3	216 0.3	165 0.3	0 0.0	0 0.0	1,266 0.3
1	EQ4003 ELEC PK	5292 7.1	FC CENTRIF. FAN C.V.				5122 7.1	5122 7.1	5292 7.1	5292 7.1	5122 7.1	5292 7.1	5122 7.1	5292 7.1	62,313 7.1
1	EQ4372 ELEC PK	287 0.4	UNIT VENTILATOR FAN				278 0.4	287 0.4	278 0.4	287 0.4	278 0.4	287 0.4	278 0.4	287 0.4	3,381 0.4

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M100, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 41.5 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	18.0	43.26
Sub Total			18.0	43.26
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	18.07
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	4.49
Sub Total			9.4	22.56
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.7	18.51
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	15.66
Sub Total			14.2	34.18
Grand Total			41.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M100, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 7,393
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	690.8	8,310.9	2.1	15,821.6	2.2
Primary Cooling					
Compressor	19,004.6	0.0	13.0	194,607.2	27.0
Tower/Cond Fans	1,779.3	0.0	1.2	18,219.9	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,266.3	0.0	0.9	12,966.9	1.8
Auxiliary					
Supply Fans	82,003.4	0.0	55.9	839,716.6	116.4
Circulation Pumps	257.9	0.0	0.2	2,640.7	0.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	82,261.3	0.0	56.1	842,357.3	116.8
Lighting	21,271.5	0.0	14.5	217,820.3	29.5
Receptacle	17,993.0	0.0	12.3	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	144,266.6	8,310.9	100.0	1,486,042.0	204.7

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M100, ECO#1 -WALL

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	10,696	25	83	0
Feb	9,667	25	74	0
March	10,544	24	3	0
April	9,874	24	0	0
May	13,783	40	0	0
June	15,333	41	0	0
July	15,049	40	0	0
Aug	15,484	40	0	0
Sept	13,519	40	0	0
Oct	11,803	38	0	0
Nov	9,874	24	0	0
Dec	10,301	24	37	0
Total	145,927	41	196	0

Building Energy Consumption = 70,025 (Btu/Sq Ft/Year)
Source Energy Consumption = 204,927 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M100, ECO#1 -WALL

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 41.0 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	17.5	42.59
Sub Total			17.5	42.59
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	18.29
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	4.54
Sub Total			9.4	22.83
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.7	18.73
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	15.85
Sub Total			14.2	34.58
Grand Total			41.0	100.00

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
BLDG M100, ECO#1 -WALL

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
Gross Conditioned Floor Area (sqft)..... 7,393
ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	747.8	19,616.1	4.3	28,305.5	3.9
Primary Cooling					
Compressor	20,413.3	0.0	13.5	209,033.2	29.0
Tower/Cond Fans	1,945.3	0.0	1.3	19,920.0	2.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,222.2	0.0	0.8	12,515.4	1.7
Auxiliary					
Supply Fans	82,003.4	0.0	54.1	839,716.6	116.4
Circulation Pumps	330.4	0.0	0.2	3,383.3	0.5
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	82,333.8	0.0	54.3	843,099.9	116.9
Lighting	21,271.5	0.0	14.0	217,820.3	29.5
Receptacle	17,993.0	0.0	11.9	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	145,926.9	19,616.1	100.0	1,514,943.0	208.7

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M100, ECO#1 -ROOF

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kwh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	10,675	25	75	0
Feb	9,657	25	65	0
March	10,544	24	3	0
April	9,874	24	0	0
May	13,881	40	0	0
June	15,432	41	0	0
July	15,147	41	0	0
Aug	15,515	41	0	0
Sept	13,524	40	0	0
Oct	11,865	38	0	0
Nov	9,874	24	0	0
Dec	10,301	24	32	0
Total	146,289	41	175	0

Building Energy Consumption = 69,907 (Btu/Sq Ft/Year)
Source Energy Consumption = 205,129 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M100, ECO#1 -ROOF

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 41.3 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	17.8	43.01
Sub Total			17.8	43.01
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	18.16
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	4.51
Sub Total			9.4	22.66
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.7	18.60
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	15.73
Sub Total			14.2	34.33
Grand Total			41.3	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M100, ECO#1 -ROOF

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 7,393
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	726.0	17,513.2	3.9	25,869.2	3.6
Primary Cooling					
Compressor	20,807.8	0.0	13.7	213,072.0	29.5
Tower/Cond Fans	1,987.7	0.0	1.3	20,353.7	2.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,178.7	0.0	0.8	12,069.9	1.7
Auxiliary					
Supply Fans	82,003.4	0.0	54.2	839,716.6	116.4
Circulation Pumps	320.8	0.0	0.2	3,284.9	0.5
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	82,324.2	0.0	54.4	843,001.4	116.9
Lighting	21,271.5	0.0	14.0	217,820.3	29.5
Receptacle	17,993.0	0.0	11.9	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	146,288.8	17,513.2	100.0	1,516,435.4	208.9

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M100, ECO#2

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	10,653	25	38	0
Feb	9,638	25	35	0
March	10,544	24	3	0
April	9,874	24	0	0
May	13,611	40	0	0
June	14,831	41	0	0
July	14,589	41	0	0
Aug	15,057	41	0	0
Sept	13,301	40	0	0
Oct	12,090	38	0	0
Nov	9,874	24	0	0
Dec	10,292	24	14	0
Total	144,352	41	90	0

Building Energy Consumption = 67,863 (Btu/Sq Ft/Year)
Source Energy Consumption = 201,236 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M100, ECO#2

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 41.4 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	17.8	43.10
Sub Total			17.8	43.10
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	18.13
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	4.50
Sub Total			9.4	22.63
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.7	18.57
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	15.71
Sub Total			14.2	34.27
Grand Total			41.4	100.00

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
BLDG M100, ECO#2

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
Gross Conditioned Floor Area (sqft)..... 7,393
ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	690.8	9,010.7	2.3	16,558.2	2.3
Primary Cooling					
Compressor	19,049.9	0.0	13.0	195,071.5	27.0
Tower/Cond Fans	1,791.3	0.0	1.2	18,343.1	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,247.4	0.0	0.8	12,773.4	1.8
Auxiliary					
Supply Fans	82,003.4	0.0	55.8	839,716.6	116.4
Circulation Pumps	305.2	0.0	0.2	3,125.4	0.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	82,308.6	0.0	56.0	842,841.9	116.9
Lighting	21,271.5	0.0	14.5	217,820.3	29.5
Receptacle	17,993.0	0.0	12.2	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	144,352.4	9,010.7	100.0	1,487,657.2	204.9

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M100, ECO#3

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	10,635	25	33	0
Feb	9,638	25	32	0
March	10,544	24	3	0
April	9,874	24	0	0
May	13,620	40	0	0
June	14,755	41	0	0
July	14,531	41	0	0
Aug	15,004	41	0	0
Sept	13,288	40	0	0
Oct	12,232	38	0	0
Nov	9,874	24	0	0
Dec	10,292	24	14	0
Total	144,285	41	82	0

Building Energy Consumption = 67,721 (Btu/Sq Ft/Year)
 Source Energy Consumption = 201,026 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M100, ECO#3

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 41.5 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	17.9	43.21
Sub Total			17.9	43.21
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	18.09
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	4.49
Sub Total			9.4	22.58
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.7	18.53
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	15.67
Sub Total			14.2	34.21
Grand Total			41.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M100, ECO#3

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 7,393
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	678.0	8,185.9	2.1	15,559.5	2.2
Primary Cooling					
Compressor	18,995.4	0.0	12.9	194,513.3	27.0
Tower/Cond Fans	1,778.2	0.0	1.2	18,208.6	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,266.3	0.0	0.9	12,966.9	1.8
Auxiliary					
Supply Fans	82,003.4	0.0	55.9	839,716.6	116.4
Circulation Pumps	299.6	0.0	0.2	3,067.7	0.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	82,303.0	0.0	56.1	842,784.2	116.9
Lighting	21,271.5	0.0	14.5	217,820.3	29.5
Receptacle	17,993.0	0.0	12.3	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	144,285.3	8,185.9	100.0	1,486,101.6	204.7

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M100, ECO#12

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	5,739	25	33	1
Feb	5,192	25	27	1
March	6,170	25	6	0
April	5,402	24	0	0
May	6,709	35	0	0
June	7,392	36	0	0
July	6,714	36	0	0
Aug	7,531	36	0	0
Sept	6,189	36	0	0
Oct	6,222	34	0	0
Nov	5,406	24	2	0
Dec	5,460	25	13	1
Total	74,125	36	81	1

Building Energy Consumption = 35,322 (Btu/Sq Ft/Year)
 Source Energy Consumption = 103,834 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M100, ECO#12

2	EQ4003		FC CENTRIF. FAN C.V.										5,630	
	ELEC	469	424	514	447	492	492	447	514	447	492	447	447	1.9
	PK	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
1	EQ2001		GAS FIRE TUBE HOT WATER										81	
	GAS	33	27	6	0	0	0	0	0	0	0	2	13	0.8
	PK	0.8	0.8	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.8	0.8
1	EQ5020		HEAT WATER CIRC. PUMP C.V.										60	
	ELEC	22	19	6	0	0	0	0	0	0	0	2	11	0.3
	PK	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3
1	EQ5240		BOILER FORCED DRAFT FAN										54	
	ELEC	20	17	5	0	0	0	0	0	0	0	2	10	0.3
	PK	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3
1	EQ5307		BOILER CONTROLS										108	
	ELEC	39	34	10	0	0	0	0	0	0	0	4	20	0.5
	PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M100, ECO#12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 36.4 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	12.9	35.33
Sub Total			12.9	35.33
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	20.60
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	5.11
Sub Total			9.4	25.72
Sub Total			0.0	0.00
Miscellaneous				
	Lights		7.7	21.10
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	17.85
Sub Total			14.2	38.96
Grand Total			36.4	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M100, ECO#12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 7,393
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	161.2	8,127.1	3.3	10,206.0	1.4
Primary Cooling					
Compressor	5,206.7	0.0	6.8	53,317.2	7.4
Tower/Cond Fans	519.6	0.0	0.7	5,320.8	0.7
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	297.0	0.0	0.4	3,041.3	0.4
Auxiliary					
Supply Fans	28,616.1	0.0	37.4	293,029.9	40.6
Circulation Pumps	60.2	0.0	0.1	616.4	0.1
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	28,676.3	0.0	37.5	293,646.3	40.7
Lighting	21,271.5	0.0	27.8	217,820.3	29.5
Receptacle	17,993.0	0.0	23.5	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	74,125.4	8,127.1	100.0	767,600.6	105.1

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M100, ECO#15

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	10,041	22	39	0
Feb	9,105	22	40	0
March	9,822	21	4	0
April	9,228	21	0	0
May	12,628	36	0	0
June	13,753	37	0	0
July	13,609	37	0	0
Aug	13,968	37	0	0
Sept	12,373	36	0	0
Oct	11,271	34	0	0
Nov	9,228	21	0	0
Dec	9,716	22	19	0
Total	134,744	37	102	0

Building Energy Consumption = 63,582 (Btu/Sq Ft/Year)
Source Energy Consumption = 188,089 (Btu/Sq Ft/Year)

Floor Area = 7,393 (Sq Ft)

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M100, ECO#15

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 37.1 (KW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (KW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1161	AIR-CLD COND COMP <15 TONS	16.5	44.46
Sub Total			16.5	44.46
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.5	20.20
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	5.01
Sub Total			9.4	25.21
Sub Total			0.0	0.00
Miscellaneous				
	Lights		4.8	12.83
	Base Utilities		0.0	0.00
	Misc Equipment		6.5	17.50
Sub Total			11.3	30.33
Grand Total			37.1	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M100, ECO#15

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 7,393
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	846.7	10,150.4	2.8	19,355.3	2.7
Primary Cooling					
Compressor	17,437.4	0.0	12.7	178,559.4	24.8
Tower/Cond Fans	1,638.5	0.0	1.2	16,778.8	2.3
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,264.8	0.0	0.9	12,951.6	1.8
Auxiliary					
Supply Fans	82,003.4	0.0	59.5	839,716.5	116.4
Circulation Pumps	374.1	0.0	0.3	3,831.2	0.5
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	82,377.5	0.0	59.8	843,547.7	117.0
Lighting	13,186.0	0.0	9.6	135,024.7	18.3
Receptacle	17,993.0	0.0	13.1	184,248.8	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	134,744.0	10,150.4	100.0	1,390,466.3	191.7

BUILDING 168

E M C ENGINEERS, INC.

PROJECT: FORT MCPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT MCPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 10-APR-92
 FILE: M168ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M168 Area: 11,720 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	80,140	1,126	22,484	47,061	33,103	41,081	24,305	169,161	48	80	657
ECO#1 - Roof Savings/(Loss)	29,493	666	19,765	47,061	33,103	41,081	24,305	165,981	44	29	596
	50,647	460	2,720	0	0	0	0	3,180	4	51	61
ECO#3 Savings/(Loss)	79,452	1,125	22,476	47,061	33,103	41,081	24,305	169,150	48	79	657
	688	2	8	0	0	0	0	10	0	1	1
ECO#12 Savings/(Loss)	61,627	875	16,630	40,030	15,029	41,081	24,305	137,950	46	62	532
	18,513	252	5,854	7,031	2,554	0	0	31,210	2	19	125

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
SHEET NO. 1 OF 5
CALCULATED BY RMP DATE 2/21/92
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation Bldg 168, Base Run

Bldg Type: Brick UOQ Area: 11,643 ft²
Eco: 1, 12 For take off: 3
Take off Bldg: 522

Assumptions:


- Occupancy: top: 17 apt @ 1 person/Apt @ 75% diversity
basement: 13 people
- wall insulation: R-11
- heating db: 72°F
- cooling db: 76°F
- basement walls: 12" concrete
- Lighting + misc loads: 75% diversity - top floors
- Infiltration Top floors: $\frac{1}{2}$ ACH
Basement: $\frac{1}{4}$ ACH

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Comp Simulations Bldg 168


Wall U-Value - ASHRAE Table F22.4



Material	R-Value
Outside Surface (15 mph wind)	0.17
4" Face Brick	1.24
1/2" Gyp board	0.45
R-11 Insulation	11.0
1/2" Gyp Board	0.45
Inside Surface (still air)	<u>0.68</u>
	13.99

$$U = \frac{1}{R} = \frac{1}{13.99} = \boxed{0.07}$$

Roof U-Value - ASHRAE Table F22.4



Material	R-Value
Outside Surface (15 mph wind)	0.17
Shingles (asphalt)	0.44
1/2" plywood	0.62
Air Space	1.24
1/2" Gyp Board	0.45
Inside Surface (still air)	<u>0.68</u>
	3.65

$$U = \frac{1}{R} = \frac{1}{3.65} = \boxed{0.27}$$

Window U-Value - ASHRAE Table F27.13

- Double Pane w/ 1/4" air space, Al Frame, Type R

$$U = 0.70$$

Internal Shading - ASHRAE Table F27.26

- Blinds

$$\text{shading coefficient} = 0.58$$

JOB 3105.000

SHEET NO. 3 OF 5

CALCULATED BY kmga DATE 2/21/95

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Comp. Sur. Bldg. 1K8

People - Room 1 (Apartment)

17 Apartments @ 1 person / Apt. * 75% = 12.75 = 13 people

sensible: 250 Btu/h / person > ASHRAE TABLE F 26.3

latent: 200 Btu/h / person

- Room 2 (Recomm.)

Assume: 18 people

sensible: 250 Btu/h / person

latent: 200 Btu/h / person

Lights

- from field survey

Rm 1 (apartment): 8,182 wats * 75% = 6,137 Wats

Rm 2 (Recomm.): 7,831 Wats

Misc load:

Rm 1 - ASHRAE Table F 26.8, 26.9, 28.1

for Apartment:

Appliance	Watt	@ Peak
TU	200	1 (200)
Refrigerator	75	1 (75)
Misc	10	1 (10)

Kitchen:

coffee machine	300	300
ice machine	2000	2000
refrigerator	200	200
stove	1250	1250
micro wave	65	
dishwasher	700	

Laundry

2-washer	375	2 (375)
2-dryer	750	2 (750)

Misc

Water cooler	100	100
--------------	-----	-----

10.8 kW

10.8 kW * 75% = 8.1 kW

Comp Sys Bldg 158

misc load

from 2 (Basement)

Appliances	Watt:
1 TV	200
11 Computer	11(200)
8 printer	8(100)
1 coffee pot	260
1 copy machine	600
1 water fountain	100
3 Elec Typewriter	
fax machine	75
1 microwave	
1 Refrigerator	200
	4.4 kW

Infiltration

$$Q = L(A \Delta t + B v^2)^{1/2}$$

A = Stack coefficient = 0.0313 - ASHRAE Table F23.7

B = Wind coefficient = 0.0051 - ASHRAE Table F23.8

v = Avg. Windspeed = 12.65 mph

Use $\frac{1}{4}$ ACH

L = Effective leakage Area:

single door, weather dripped (0.114)(122.0) = 13.9 in²

door frame, radbr, Masonry wall (0.0143)(122.0) = 1.7 in²

Windows, double slider, weatherdripped (0.037)(925) = 34.2 in²

Window frame, Masonry wall, radbr (0.019)(925) = 17.6 in²

67.4 in²

heating

$\Delta t = \begin{matrix} \text{indoor} \\ \text{indoor} \end{matrix} 72^\circ\text{F} - \begin{matrix} \text{outdoor} \\ \text{outdoor} \end{matrix} 55^\circ\text{F} = 19^\circ\text{F}$

$Q = 67.4 + (0.0313(17) + 0.0051(12.65)^2)^{1/2} = 78.3 \text{ cfm}$

cooling

$\Delta t = \begin{matrix} \text{outdoor} \\ \text{outdoor} \end{matrix} 88^\circ\text{F} - \begin{matrix} \text{indoor} \\ \text{indoor} \end{matrix} 76^\circ\text{F} = 12^\circ\text{F}$

$Q = 67.4 (0.0313(12) + 0.0051(12.65)^2)^{1/2} = 73.6 \text{ cfm}$

683 cfm

Basement - Use $\frac{1}{4}$ ACH

A = 0.0156 B = 0.0039 v = 12.65 mph

L: single door, weatherdripped (0.114)(93.8) = 10.7 in

door frame, Mason, radbr (0.0143)(93.8) = 1.3 in

Windows, double slider, dripped (0.037)(88.2) = 3.3 in

Window frame, Mason, radbr (0.019)(88.2) = 1.7

17.0 in

heating

$Q = 17.0(0.0156(17) + 0.0039(12.65)^2) = 16.0 \text{ cfm}$

cooling

$Q = 17.0(0.0156(12) + 0.0039(12.65)^2) = 15.3 \text{ cfm}$

163 cfm

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
 SHEET NO. 5 OF 5
 CALCULATED BY RMA DATE 2/21/92
 CHECKED BY _____ DATE _____
 SCALE _____

Cond. Calc Bids '88

Basement wall 1/2" Gyp ASHRAE Table F22.4

Assuming 12" concrete wall w/ 1/2" Gyp



<u>material</u>	<u>R-Value</u>
outside air (15 mph)	0.17
12" concrete	1.70
1/2" Gyp Board	0.45
Inside Surface (still air)	<u>0.68</u>
	2.50

$$U = \frac{1}{2.50} = \boxed{0.40}$$

Assuming 4' high will account for exposed + unexposed losses.

Insulation

4" R-11 Insulation
 2906,6 Ft

0.022 R-value ASHRAE Table F25.4

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

- Bldg 100 - 1/2" dia

Pump

$$DTW \text{ Pump} = \frac{15.4 \text{ ft} \cdot (9.81 \text{ m/s}^2) \cdot (0.35 \text{ m}^2)}{(0.839 \text{ eff})} = 3.3 \text{ m} \cdot 8760 \text{ hr/yr} = \boxed{33,103} \text{ kWh/yr}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation Bldg 168, McPherson

ECO # 1 - Roof Insulation

Foot U-Value - ASHRAE = 22.4

- add R-19 insulation

R = 22.65

U = 0.044

Delta UA

Roof Area = 5000 ft²

original U = 0.27

= Original UA = 1350

Improved UA = 220

Delta UA = 1130

Electric Savings

Total Electric Savings = 3,180 kWh/yr

Electric savings/dUA = 2.8 kWh/yr/dUA

Demand Savings

Peak electric demand savings = 4 kW

Demand savings/dUA = 0.0035 kW/dUA

Gas Savings

Total Gas Savings = 50.6 MBtu/yr

Gas savings/dUA = 0.045 MBtu/yr/dUA

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 168, McPherson

ECO #3 - Weatherstripping + Caulking

- Assume $\Delta T = 10 \text{ dF}$

- upstairs, ft²

presently, $\frac{1}{2} A U = 521 \text{ dftm}$

improved, $521 - 10 = \boxed{511 \text{ dftm}}$

- downward, ft²

present $\frac{1}{2} A U = 130 \text{ dftm}$

improved, $130 - 10 = \boxed{120 \text{ dftm}}$

Delta dftm

improvement = $\boxed{20 \text{ dftm}}$

Electric Savings

Total Electric Savings = 10 kWh/yr

Electric Savings = $\boxed{0.50} \text{ kWh/yr/dftm}$

Demand Savings

Peak Electric Demand Savings = 0 kW

Demand Savings = $\boxed{0} \text{ kW/yr/dftm}$

Gas Savings

Total Gas Savings = 0.69 MBtu/yr

Gas Savings / dftm = $\boxed{0.035} \text{ MBtu/yr/dftm}$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 168, McPherson

ECO #12 - HVAC Controls

First Floor

- change T-stat setpoints: 78°F Cooling + 70°F Heating

Rm 2, basement

- Change T-stat setpoints: 78°F Cooling + 70°F Heating

- Setback thermostat:

- Fan on 06:00 - 13:00 M-F otherwise off

- Turn off pumps between heating + cooling seasons

Volume 4 wh/yr = 672 h/yr

Savings: 3.3 kW * 672 h/yr = 2,218 kWh/yr

Electric Savings

Total Electric Savings = 31,210 kWh/yr

Peak Demand Savings

Peak Demand Savings = 2 kW

Gas Savings

Total Gas Savings = 19 MMBtu/yr

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EEAP
 Location: FT MCPHERSON, BLDG 168
 Program User: R. GERRANS

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month Cooling Simulation	Last Month Cooling Simulation	Peak Cooling Load Hr	1st Month Summer Period	Last Month Summer Period	1st Month Daylight Savings	Last Month Daylight Savings
MAY	OCT					

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG M168, BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	TOP 2 FLOORS	118.67	65.84		2		10			
2	2	BASEMENT	118.67	32.92		2		10			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room Design RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location Flag	T'stat Location	Mass / No. Hrs On Average	Carpet On Floor
1	76			CLG	72		HTG				
2	76			CLG	72		HTG				

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	125	40	.27	37			

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M1	1	32.92	21	.07	76	0			
1	1	32.92				0			
1	2	118.67				90			
1	3	32.92				180			
1	4	118.67				270			
M2	1	32.92	4	.40	64	0			
2	1	32.92				0			
2	2	118.67				90			
2	3	32.92				180			
2	4	118.67				270			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
M1	1				.7	.58					
1	1	5.5	8.5	2							
1	2	10	36.9	1							
1	3	5.5	8.5	2							
1	4	10	36.9	1							

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
1	RESO	RESL	OFF	AVAIL		AVAIL				
2	ADMPPPL	ADMLGTEQ	OFF	AVAIL		AVAIL				

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	--- Daylighting --- Reference Point 1	Reference Point 2
1	13	PEOPLE	250	200	6137	WATTS					
2	18	PEOPLE	250	200	7831	WATTS					


```

-----CARD 28--- Miscellaneous Equipment -----
Room   Misc      Energy   Energy   Energy   Percent  Percent  Percent
Number Equipment Equipm   Consump Consump Schedule Meter   of Load  Misc. Load Misc. Sens Radiant  Optional
      Number  Descrip Value  Units  Code  Code   Sensible to Room  to Ret. Air Fraction Air Path
1       1      APARTMENT EQUIP  8.1  KW  RESE  ELEC
2       1      MISC BASEMENT   4.4  KW  ADMLGTEQ  ELEC

```

```

-----CARD 29--- Room Airflows -----
Room   Ventilation      Infiltration      --Reheat Minimum--
Number  Cooling  Heating  Cooling  Heating  Value  Units  Value  Units  Value  Units
1       Value  Units  Value  Units  .5  ACH-HR  .5  ACH-HR
2       Value  Units  Value  Units  .25 ACH-HR  .25 ACH-HR

```

```

-----CARD 32-- Exposed Floor Parameters-----
Room   Exposed  Slab  Exposed Floor
Number Floor  Perimeter Loss  Floor  Floor  Const Temp  Cooling Heating Adjacent
      Number Length Coefficient Area  U-Value Type  Flag  Temp  Temp  Room No
2       1      3906.6  .022

```

----- System Section Alternative #1 -----

```

-----CARD 39-- System Alternative -----
Number  Description
1       BLDG M168, BASELINE

```

```

-----CARD 40--- System Type -----
System  Ventil  Fan
Set  System  Deck  Cooling Heating Cooling Heating Static
Number Type  Location SADEVh SADEVh Schedule Schedule Pressure
1       FC
2       FC

```

```

-----CARD 41-- Zone Assignment -----
System
Set      Ref #1      Ref #2      Ref #3      Ref #4      Ref #5      Ref #6
Number  Begin  End  Begin  End  Begin  End  Begin  End  Begin  End
1       1      1
2       2      2

```


-----CARD 65-- Heating Load Assignment -----

Load	All Coil	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-
Assignment	Loads To	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
Reference	Heating Ref	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
1	1	1	2							

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld	Cap'y Value	Units	Energy Rate	Units	Seq Order	Switch over	Hot	Misc. Acc.	Demand Limit	
Number	Name	Units	Value	Value	Units	Value	Units	Number	Control	Strg	Acc.	Cogen	Number
1	EQ2002	1	3.8		KW								

-----CARD 69-- Fan Equipment Parameters -----

System Set	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
Number							
1	EQ4371						
2	EQ4371						

Utility Description Reference Table

Schedules:

- ADMLGTEQ ADMIN LIGHTING AND EQUIPMENT
- ADMPEL ADMIN PEOPLE SCHEDULE
- AVAIL AVAILABLE (100%)
- CLG COOLING TSTAT SCHEDULE
- CLGC COOLING COIL SCHEDULE
- HTG HEATING TSTAT SCHEDULE
- HTGC HEATING COIL SCHEDULE
- OFF ALWAYS OFF
- RESE RESIDENCE EQUIPMENT SCHEDULE
- RESL RESIDENCE LIGHTING SCHEDULE
- RESO RESIDENCE OCCUPANCY SCHEDULE

System:

FC FAN COIL

Equipment:

Cooling:

EQ1121S AIR-CLD RECIP 20-35 TONS

Heating:

EQ2002 GAS FIRE TUBE STEAM

Fan:

EQ4371 FAN COIL SUPPLY FAN

Schedule Name: ADMLGTEQ

Project: ADMIN LIGHTING AND EQUIPMENT SC

Location:

Client:

Program User:

Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

Hour	Util Percent
0	5
24	

Schedule Name: ADMPPL
Project: ADMIN PEOPLE SCHEDULE
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: NOV Ending Month: ETG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: ETG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: RESE
Project: RESIDENCE EQUIPMENT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	5	
5	40	
7	5	
16	40	
18	30	
19	100	
20	20	
22	5	
24		

Schedule Name: RESL
Project: RESIDENCE LIGHTING SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util	Percent
0	0	
5	90	
8	10	
16	50	
19	100	
23	0	
24		

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util	Percent
0	0	
7	50	
9	20	
16	50	
19	100	
23	0	
24		

Schedule Name: RESO
Project: RESIDENCE OCCUPANCY SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	40
8	20
16	100
20	60
23	40
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	40
10	30
17	90
20	60
23	40
24	

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

```
*****  
*****  
**  
**          T R A C E    6 0 0    A N A L Y S I S          **  
**  
**          by              **  
**  
*****  
*****
```

FT MCPHERSON & FT GILLEM BEAP
FT MCPHERSON, BLDG 168

R. GERRANS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 8:57:24 4/ 8/92
Dataset Name: M168-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M168, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Main			Auxil. Supply Airflow (Cfm)	Room Exhaust Airflow (Cfm)
				Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)		
1	FC	0	13,122	13,122	13,643	521	0	0
2	FC	0	3,879	3,879	4,009	130	0	0
Totals		0	17,001	17,001	17,652	651	0	0

CAPACITY - ALTERNATIVE 1
 BLDG M168, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating							
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)
1	FC	15.5	0.0	0.0	0.0	15.5	-118,914	0	0	0	0	0	0	-118,914
2	FC	5.6	0.0	0.0	0.0	5.6	-34,149	0	0	0	0	0	0	-34,149
Totals		21.1	0.0	0.0	0.0	21.1	-153,063	0	0	0	0	0	0	-153,063

The building peaked at hour 17 month 6 with a capacity of 20.1 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M168, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	FC	0.00	1.68	844.2	502.6	23.87	1.68	-15.22	7,813
2	Main	FC	0.00	0.99	698.8	703.7	17.05	0.99	-8.74	3,907

System 1 Block FC - FAN COIL

***** COOLING COIL PEAK *****					CLG SPACE PEAK *****		HEATING COIL PEAK *****			
Peaked at Time ==>					Mo/Hr: 6/17	Mo/Hr: 6/17	Mo/Hr: 13/ 1			
Outside Air ==>					OADB/WB/HR: 94/ 70/ 77.0	OADB: 94	OADB: 22			
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	Space Sensible (Btuh)	Perct Of Tot (%)	Space Peak (Btuh)	Coil Peak (Btuh)	Perct Of Tot (%)
Skylite Solr	0	0	0	0	0.00	0	0.00	0	0	0.00
Skylite Cond	0	0	0	0	0.00	0	0.00	0	0	0.00
Roof Cond	0	68,966	0	68,966	36.97	0	0.00	0	-42,686	35.90
Glass Solar	48,100	0	0	48,100	25.79	48,100	27.22	0	0	0.00
Glass Cond	11,849	0	0	11,849	6.35	11,849	6.70	-34,382	-34,382	28.91
Wall Cond	11,963	1,131	0	13,094	7.02	11,963	6.77	-14,589	-17,408	14.64
Partition	0	0	0	0	0.00	0	0.00	0	0	0.00
Exposed Floor	0	0	0	0	0.00	0	0.00	0	0	0.00
Infiltration	12,752	0	0	12,752	6.84	10,225	5.79	-27,937	-27,937	23.49
Sub Total==>	84,664	70,097	0	154,761	82.97	82,138	46.47	-76,909	-122,413	102.94
Internal Loads										
Lights	10,473	0	0	10,473	5.61	10,473	5.93	0	0	0.00
People	5,850	0	0	5,850	3.14	3,250	1.84	0	0	0.00
Misc	10,782	0	0	10,782	5.78	10,782	6.10	0	0	0.00
Sub Total==>	27,104	0	0	27,104	14.53	24,504	13.86	0	0	0.00
Ceiling Load	70,097	-70,097	0	0	0.00	70,097	39.66	-45,505	0	0.00
Outside Air	0	0	0	0	0.00	0	0.00	0	0	0.00
Sup. Fan Heat				3,499	1.88		0.00		3,499	-2.94
Ret. Fan Heat		1,166		1,166	0.63		0.00		0	0.00
Duct Heat Pkup		0		0	0.00		0.00		0	0.00
OV/UNDR Sizing	0			0	0.00	0	0.00	0	0	0.00
Exhaust Heat		0	0	0	0.00		0.00		0	0.00
Terminal Bypass		0	0	0	-0.00		0.00		0	0.00
Grand Total==>	181,865	1,166	0	186,531	100.00	176,739	100.00	-122,413	-118,914	100.00

-----COOLING COIL SELECTION-----									-----AREAS-----				
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total	Glass (sf)	(&)	
				Deg F	Deg F	Grains	Deg F	Deg F	Grains				
Main Clg	15.5	186.5	181.4	13,122	76.1	63.2	69.8	63.3	58.6	69.1	Floor	7,813	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0	
0											Roof	5,000	0
Totals	15.5	186.5									Wall	6,367	925 15

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----				
	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling		Heating		Clg % OA			Type		
						0	521	0	521	Clg Cfm/Sqft	1.68	SADB	63.4	Htg	80.7
Main Htg	-118.9	13,122	72.2	80.7	Vent	0	521	0	521	Clg Cfm/Ton	844.15	Plenum	104.3	53.6	
Aux Htg	0.0	0	0.0	0.0	Infil	13,122	13,122	13,122	13,122	Clg Sqft/Ton	502.65	Return	76.0	72.0	
Preheat	-0.0	13,122	72.2	63.4	Supply	0	0	0	0	Clg Btuh/Sqft	23.87	Ret/OA	76.0	72.0	
Reheat	0.0	0	0.0	0.0	Mincfm	0	0	0	0	No. People	13	Runarnd	76.0	72.0	
Humidif	0.0	0	0.0	0.0	Return	13,122	13,122	13,122	13,122	Htg % OA	0.0	Fn MtrTD	0.1	0.0	
Opt Vent	0.0	0	0.0	0.0	Exhaust	0	0	0	0	Htg Cfm/Sqft	1.68	Fn BldTD	0.1	0.0	
Total	-118.9				Rm Exh	0	0	0	0	Htg Btuh/Sqft	-15.22	Fn Frict	0.2	0.0	
					Auxil	0	0	0	0						

System 2 Block FC - FAN COIL

***** COOLING COIL PEAK *****						CLG SPACE PEAK *****		***** HEATING COIL PEAK *****		
Peaked at Time ==> Mo/Hr: 6/15						Mo/Hr: 6/16		Mo/Hr: 13/ 1		
Outside Air ==> OADB/WB/HR: 96/ 73/ 91.0						OADB: 96		OADB: 22		
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Percnt Of Tot (%)	Space Sensible (Btuh)	Percnt Of Tot (%)	Space Peak (Btuh)	Coil Peak (Btuh)	Percnt Of Tot (%)
Skylite Solr	0	0	0	0	0.00	0	0.00	0	0	0.00
Skylite Cond	0	0	0	0	0.00	0	0.00	0	0	0.00
Roof Cond	0	0	0	0	0.00	0	0.00	0	0	0.00
Glass Solar	0	0	0	0	0.00	0	0.00	0	0	0.00
Glass Cond	0	0	0	0	0.00	0	0.00	0	0	0.00
Wall Cond	8,693	2,015	0	10,708	16.07	9,003	14.99	-19,404	-23,902	69.99
Partition	0	0	0	0	0.00	0	0.00	0	0	0.00
Exposed Floor	0	0	0	0	0.00	0	0.00	-4,297	-4,297	12.58
Infiltration	4,683	0	0	4,683	7.03	2,738	4.56	-6,984	-6,984	20.45
Sub Total==>	13,376	2,015	0	15,391	23.10	11,741	19.54	-30,685	-35,183	103.03
Internal Loads										
Lights	26,727	0	0	26,727	40.12	26,727	44.49	0	0	0.00
People	8,100	0	0	8,100	12.16	4,500	7.49	0	0	0.00
Misc	15,017	0	0	15,017	22.54	15,017	25.00	0	0	0.00
Sub Total==>	49,844	0	0	49,844	74.82	46,244	76.98	0	0	0.00
Ceiling Load	2,015	-2,015	0	0	0.00	2,087	3.47	-4,498	0	0.00
Outside Air	0	0	0	0	0.00	0	0.00	0	0	0.00
Sup. Fan Heat	0	0	0	1,034	1.55	0	0.00	0	1,034	-3.03
Ret. Fan Heat	0	345	0	345	0.52	0	0.00	0	0	0.00
Duct Heat Pkup	0	0	0	0	0.00	0	0.00	0	0	0.00
OV/UNDR Sizing	0	0	0	0	0.00	0	0.00	0	0	0.00
Exhaust Heat	0	0	0	0	0.00	0	0.00	0	0	0.00
Terminal Bypass	0	0	0	0	-0.00	0	0.00	0	0	0.00
Grand Total==>	65,235	345	0	66,615	100.00	60,073	100.00	-35,183	-34,149	103.03

-----COOLING COIL SELECTION-----											-----AREAS-----		
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)	
Main Clg	5.6	66.6	3,879	76.1	63.2	69.8	61.4	57.6	67.7	3,907			
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0			
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0			
Totals	5.6	66.6								3,907	1,213	0	

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----		-----TEMPERATURES (F)-----		
Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg	
Main Htg	-34.1	72.2	80.5	Infil	130	130	Clg Cfm/Sqft	0.99	SADB	61.6	80.5	
Aux Htg	0.0	0.0	0.0	Supply	3,879	3,879	Clg Cfm/Ton	698.75	Plenum	77.6	68.4	
Preheat	-0.0	72.2	61.6	Mincfm	0	0	Clg Sqft/Ton	703.74	Return	76.0	72.0	
Reheat	0.0	0.0	0.0	Return	3,879	3,879	Clg Btuh/Sqft	17.05	Ret/OA	76.0	72.0	
Humidif	0.0	0.0	0.0	Exhaust	0	0	No. People	18	Runarnd	76.0	72.0	
Opt Vent	0.0	0.0	0.0	Rm Exh	0	0	Htg % OA	0.0	Fn MtrTD	0.1	0.0	
Total	-34.1			Auxil	0	0	Htg Cfm/SqFt	0.99	Fn BldTD	0.1	0.0	
							Htg Btuh/SqFt	-8.74	Fn Frict	0.2	0.0	

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M168, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room	1						
		Dry	Wet	Relat.	Humid.		Temp.
		Bulb	Bulb	Humid.	Ratio	Enthalpy	Diff.
		(F)	(F)	(%)	(GR)	(Btu/Lb)	(F)
Space		76.0	63.2	50.0	69.8	29.2	
Main System							
Return Air Heat Pickup							-0.1
Return Fan							0.1
Return Air		76.0	63.2	50.0	69.8	29.2	
Outdoor Air		94.3	70.3	30.6	77.0	34.8	
Return/Outdoor Air Mix		76.0	63.2	50.0	69.8	29.2	
Blow through Fan							0.1
Entering Coil		76.1	63.2	49.9	69.8	29.2	
Leaving Coil		63.3	58.7	77.1	69.6	26.0	
Draw Through Fan							0.0
Duct Frictional Heat							0.2
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		63.4	58.8	76.6	69.6	26.1	
Supply Air		63.4	58.8	76.6	69.6	26.1	
Percent Outside Air				0.00 (%)			
Sensible Heat Ratio (SHR)				0.972			
Percent Supply Air Bypassing Coil				0.00 (%)			
Coil Airflow				13,122 (Cfm)			

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M168, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room 2

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						-0.1
Return Fan						0.1
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	96.2	73.2	34.1	91.0	37.4	
Return/Outdoor Air Mix	76.0	63.2	50.0	69.8	29.2	
Blow through Fan						0.1
Entering Coil	76.1	63.2	49.9	69.8	29.2	
Leaving Coil	61.4	57.7	80.9	68.4	25.4	
Draw Through Fan						0.0
Duct Frictional Heat						0.2
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	61.6	57.8	80.4	68.4	25.4	
Supply Air	61.6	57.8	80.4	68.4	25.4	
Percent Outside Air		0.00	(%)			
Sensible Heat Ratio (SHR)		0.925				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		3,879	(Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M168, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Part.	ExFlr	Room U-Values (Btu/hr/sqft/F)						Room Mass (lb/sqft)	Room Capac. (Btu/sqft/F)	
				Summr Skylt	Wintr Skylt	Summr Roof	Wintr Windo	Summr Windo	Wintr Wall			Cell.
1	TOP 2 FLOORS	0.000	0.000	0.000	0.000	0.270	0.700	0.743	0.070	0.317	38.7	9.11
Zone	1 Total/Ave.	0.000	0.000	0.000	0.000	0.270	0.700	0.743	0.070	0.317	38.7	9.11
System	1 Total/Ave.	0.000	0.000	0.000	0.000	0.270	0.700	0.743	0.070	0.317	38.7	9.11
2	BASEMENT	0.000	0.022	0.000	0.000	0.000	0.000	0.000	0.400	0.317	59.6	11.84
Zone	2 Total/Ave.	0.000	0.022	0.000	0.000	0.000	0.000	0.000	0.400	0.317	59.6	11.84
System	2 Total/Ave.	0.000	0.022	0.000	0.000	0.000	0.000	0.000	0.400	0.317	59.6	11.84
Building		0.000	0.022	0.000	0.000	0.270	0.700	0.743	0.130	0.317	45.7	10.02

BUILDING AREAS - ALTERNATIVE 1
 BLDG M168, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Sk1 /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
		Fir	Rm										
1	TOP 2 FLOORS	1	1	7,813	7,813	0	0	0	0	5,000	925	15	5,442
Zone	1 Total/Ave.				7,813	0	0	0	0	5,000	925	15	5,442
System	1 Total/Ave.				7,813	0	0	0	0	5,000	925	15	5,442
2	BASEMENT	1	1	3,907	3,907	0	3,907	0	0	0	0	0	1,213
Zone	2 Total/Ave.				3,907	0	3,907	0	0	0	0	0	1,213
System	2 Total/Ave.				3,907	0	3,907	0	0	0	0	0	1,213
Building					11,720	0	3,907	0	0	5,000	925	12	6,654

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
BLDG M168, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.270 (Btu/Hr/Sq Ft/F)

Overall Wall U-Value = 0.200 (Btu/Hr/Sq Ft/F)

Overall Building U-Value = 0.228 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTvr) = 20.97 (Btu/Hr/Sq Ft)

Wall Overall Thermal Transfer Value (OTTWw) = 12.03 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M168, BASELINE

Main System 1 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.8	7	194	-5,946	5	75	656.1	0	0	0.0	0	0
5 - 10	1.6	7	193	-11,891	11	183	1,312.2	0	0	0.0	0	0
10 - 15	2.3	2	67	-17,837	8	140	1,968.3	0	0	0.0	0	0
15 - 20	3.1	6	160	-23,783	7	122	2,624.3	0	0	0.0	0	0
20 - 25	3.9	15	433	-29,729	8	138	3,280.4	0	0	0.0	0	0
25 - 30	4.7	11	305	-35,674	10	170	3,936.5	0	0	0.0	0	0
30 - 35	5.4	7	196	-41,620	7	119	4,592.6	0	0	0.0	0	0
35 - 40	6.2	8	221	-47,566	7	118	5,248.7	0	0	0.0	0	0
40 - 45	7.0	8	228	-53,511	4	69	5,904.8	0	0	0.0	0	0
45 - 50	7.8	7	185	-59,457	5	89	6,560.9	0	0	0.0	0	0
50 - 55	8.5	7	192	-65,403	4	67	7,217.0	0	0	0.0	0	0
55 - 60	9.3	3	84	-71,348	13	220	7,873.0	0	0	0.0	0	0
60 - 65	10.1	7	183	-77,294	9	149	8,529.1	0	0	0.0	0	0
65 - 70	10.9	4	123	-83,240	0	0	9,185.2	0	0	0.0	0	0
70 - 75	11.7	1	38	-89,186	0	0	9,841.3	0	0	0.0	0	0
75 - 80	12.4	0	0	-95,131	0	0	10,497.4	0	0	0.0	0	0
80 - 85	13.2	0	0	-101,077	0	0	11,153.5	0	0	0.0	0	0
85 - 90	14.0	0	0	-107,023	0	0	11,809.6	0	0	0.0	0	0
90 - 95	14.8	0	0	-112,968	0	0	12,465.7	0	0	0.0	0	0
95 - 100	15.5	0	0	-118,914	0	0	13,121.7	100	8,760	0.0	0	0
Hours Off	0.0	0	5,958	0	0	7,101	0.0	0	0	0.0	0	8,760

Main System 2 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.3	3	115	-1,707	0	0	193.9	0	0	0.0	0	0
5 - 10	0.6	19	739	-3,415	0	0	387.9	0	0	0.0	0	0
10 - 15	0.8	30	1,165	-5,122	0	0	581.8	0	0	0.0	0	0
15 - 20	1.1	12	481	-6,830	2	5	775.8	0	0	0.0	0	0
20 - 25	1.4	1	39	-8,537	0	0	969.7	0	0	0.0	0	0
25 - 30	1.7	0	0	-10,245	47	113	1,163.7	0	0	0.0	0	0
30 - 35	1.9	1	42	-11,952	37	88	1,357.6	0	0	0.0	0	0
35 - 40	2.2	1	43	-13,660	13	32	1,551.6	0	0	0.0	0	0
40 - 45	2.5	1	44	-15,367	0	0	1,745.5	0	0	0.0	0	0
45 - 50	2.8	1	22	-17,074	0	0	1,939.5	0	0	0.0	0	0
50 - 55	3.1	1	44	-18,782	0	0	2,133.4	0	0	0.0	0	0
55 - 60	3.3	2	97	-20,489	0	0	2,327.4	0	0	0.0	0	0
60 - 65	3.6	4	172	-22,197	0	0	2,521.3	0	0	0.0	0	0
65 - 70	3.9	3	123	-23,904	0	0	2,715.3	0	0	0.0	0	0
70 - 75	4.2	3	126	-25,612	0	0	2,909.2	0	0	0.0	0	0
75 - 80	4.4	4	153	-27,319	0	0	3,103.1	0	0	0.0	0	0
80 - 85	4.7	6	217	-29,027	0	0	3,297.1	0	0	0.0	0	0
85 - 90	5.0	7	282	-30,734	0	0	3,491.0	0	0	0.0	0	0
90 - 95	5.3	0	0	-32,442	0	0	3,685.0	0	0	0.0	0	0
95 - 100	5.6	0	0	-34,149	0	0	3,878.9	100	8,760	0.0	0	0
Hours Off	0.0	0	4,856	0	0	8,522	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M168, BASELINE

----- S Y S T E M L O A D P R O F I L E -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.1	27	1,091	-7,653	7	115	850.0	0	0	0.0	0	0
5 - 10	2.1	6	241	-15,306	15	258	1,700.1	0	0	0.0	0	0
10 - 15	3.2	4	166	-22,959	11	182	2,550.1	0	0	0.0	0	0
15 - 20	4.2	11	455	-30,613	8	145	3,400.1	0	0	0.0	0	0
20 - 25	5.3	7	279	-38,266	13	224	4,250.2	0	0	0.0	0	0
25 - 30	6.3	5	209	-45,919	7	115	5,100.2	0	0	0.0	0	0
30 - 35	7.4	6	236	-53,572	8	140	5,950.2	0	0	0.0	0	0
35 - 40	8.4	8	305	-61,225	6	104	6,800.3	0	0	0.0	0	0
40 - 45	9.5	5	207	-68,878	13	230	7,650.3	0	0	0.0	0	0
45 - 50	10.5	5	212	-76,532	9	153	8,500.3	0	0	0.0	0	0
50 - 55	11.6	7	290	-84,185	3	50	9,350.4	0	0	0.0	0	0
55 - 60	12.7	2	86	-91,838	0	8	10,200.4	0	0	0.0	0	0
60 - 65	13.7	1	23	-99,491	0	0	11,050.4	0	0	0.0	0	0
65 - 70	14.8	3	128	-107,144	0	0	11,900.5	0	0	0.0	0	0
70 - 75	15.8	3	109	-114,797	0	0	12,750.5	0	0	0.0	0	0
75 - 80	16.9	0	0	-122,451	0	0	13,600.5	0	0	0.0	0	0
80 - 85	17.9	0	0	-130,104	0	0	14,450.6	0	0	0.0	0	0
85 - 90	19.0	0	0	-137,757	0	0	15,300.6	0	0	0.0	0	0
90 - 95	20.0	0	0	-145,410	0	0	16,150.6	0	0	0.0	0	0
95 - 100	21.1	0	0	-153,063	0	0	17,000.7	100	8,760	0.0	0	0
Hours Off	0.0	0	4,723	0	0	7,036	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M168, BASELINE

January			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-70,471	0.0	-31,158	0.0	-66,638	0.0	-66,638	0.0	-75,601	0.0
2	32.1	29.3	-73,859	0.0	-69,324	0.0	-69,320	0.0	-69,320	0.0	-78,741	0.0
3	31.7	29.3	-76,675	0.0	-72,433	0.0	-72,433	0.0	-72,433	0.0	-81,943	0.0
4	31.9	29.5	-80,262	0.0	-74,726	0.0	-74,726	0.0	-74,726	0.0	-84,597	0.0
5	32.6	30.3	-81,819	0.0	-76,536	0.0	-76,536	0.0	-76,536	0.0	-86,633	0.0
6	33.6	31.3	-53,923	0.0	-49,318	0.0	-68,170	0.0	-77,673	0.0	-59,993	0.0
7	35.0	32.6	-54,752	0.0	-46,508	0.0	-65,359	0.0	-76,270	0.0	-57,420	0.0
8	36.6	34.4	-22,682	0.0	-40,503	0.0	-48,882	0.0	-60,368	0.0	-40,503	0.0
9	38.5	36.3	-19,873	0.0	-46,510	0.0	-37,482	0.0	-48,941	0.0	-46,510	0.0
10	40.4	37.7	-9,714	0.0	-35,701	0.0	-32,956	0.0	-44,951	0.0	-35,701	0.0
11	42.3	38.7	-4,108	0.0	-30,622	0.0	-28,202	0.0	-40,209	0.0	-30,622	0.0
12	44.2	39.6	0	0.0	-25,288	0.0	-22,868	0.0	-34,819	0.0	-25,288	0.0
13	45.8	40.5	0	0.0	-14,963	0.0	-12,544	0.0	-24,477	0.0	-14,963	0.0
14	47.2	41.1	0	0.0	-4,420	0.0	-2,001	0.0	-13,391	0.0	-4,420	0.0
15	48.2	41.6	0	0.0	0	0.0	0	0.0	-11,399	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	0	0.0	-10,802	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	0	0.0	-10,358	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	0	0.0	-9,673	0.0	0	0.0
19	47.4	41.7	0	0.0	-8,667	0.0	-7,084	0.0	-16,163	0.0	-8,667	0.0
20	45.5	40.5	0	0.0	0	0.0	0	0.0	-8,925	0.0	0	0.0
21	43.1	38.9	0	0.0	-8,592	0.0	-8,908	0.0	-17,638	0.0	-8,592	0.0
22	40.4	36.7	0	0.0	-25,342	0.0	-25,342	0.0	-34,108	0.0	-25,342	0.0
23	37.7	34.3	0	0.0	-34,565	0.0	-34,565	0.0	-43,447	0.0	-34,565	0.0
24	35.3	32.3	0	0.0	-62,397	0.0	-62,397	0.0	-71,452	0.0	-62,397	0.0

February			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	-63,707	0.0	0	0.0	-61,580	0.0	-61,580	0.0	-70,666	0.0
2	36.0	33.0	-66,914	0.0	-11,145	0.0	-66,265	0.0	-66,265	0.0	-76,075	0.0
3	34.7	31.8	-69,098	0.0	-68,452	0.0	-68,446	0.0	-68,446	0.0	-78,111	0.0
4	33.6	30.9	-71,171	0.0	-71,416	0.0	-71,416	0.0	-71,416	0.0	-81,612	0.0
5	32.8	30.1	-72,194	0.0	-73,419	0.0	-73,419	0.0	-73,419	0.0	-83,654	0.0
6	32.2	29.8	-45,348	0.0	-47,160	0.0	-66,011	0.0	-66,011	0.0	-57,977	0.0
7	32.1	29.6	-41,503	0.0	-46,876	0.0	-65,727	0.0	-65,727	0.0	-57,775	0.0
8	32.5	30.3	-8,833	0.0	-34,600	0.0	-42,979	0.0	-42,979	0.0	-34,600	0.0
9	33.9	31.6	-11,444	0.0	-47,937	0.0	-38,909	0.0	-38,909	0.0	-47,937	0.0
10	36.0	33.0	-740	0.0	-42,285	0.0	-39,540	0.0	-45,438	0.0	-42,285	0.0
11	38.5	34.8	0	0.0	-37,487	0.0	-35,067	0.0	-47,775	0.0	-37,487	0.0
12	41.3	36.5	0	0.0	-29,625	0.0	-27,205	0.0	-39,902	0.0	-29,625	0.0
13	43.8	38.1	0	0.0	-18,811	0.0	-16,391	0.0	-28,654	0.0	-18,811	0.0
14	45.9	39.5	0	0.0	-6,976	0.0	-4,556	0.0	-16,578	0.0	-6,976	0.0
15	47.2	40.4	0	0.0	0	0.0	0	0.0	-11,804	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	0	0.0	-11,442	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	0	0.0	-10,693	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	0	0.0	-10,811	0.0	0	0.0
19	46.2	39.9	0	0.0	0	0.0	0	0.0	-9,969	0.0	0	0.0
20	45.1	39.7	0	0.0	0	0.0	0	0.0	-9,399	0.0	0	0.0
21	43.8	39.2	0	0.0	0	0.0	0	0.0	-9,255	0.0	0	0.0
22	42.3	38.3	0	0.0	-21,855	0.0	-20,721	0.0	-29,459	0.0	-21,855	0.0
23	40.7	37.2	0	0.0	-33,138	0.0	-33,138	0.0	-42,127	0.0	-33,138	0.0
24	39.1	35.8	0	0.0	-57,443	0.0	-57,443	0.0	-66,419	0.0	-57,443	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M168, BASELINE

May Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	21.1	0	0.4	0	0.5	0	0.4	0	0.4
2	64.5	60.4	0	21.1	0	0.4	0	0.4	0	0.4	0	0.4
3	62.7	59.1	0	20.4	0	0.4	0	0.4	0	0.4	0	0.4
4	61.2	58.1	0	5.6	0	0.4	0	0.4	0	0.4	0	0.4
5	60.0	57.1	0	5.6	0	0.3	0	0.3	0	0.3	0	0.3
6	59.3	56.6	0	6.5	0	0.3	0	0.3	0	0.3	0	0.3
7	59.0	56.5	0	10.8	0	0.2	0	0.2	0	0.2	0	0.2
8	59.5	56.6	0	11.1	0	3.0	0	0.2	0	0.2	0	3.0
9	60.9	56.6	0	10.8	0	3.8	0	0.1	0	0.1	0	4.1
10	63.0	57.2	0	11.7	0	6.4	0	0.2	0	0.2	0	6.3
11	65.7	58.1	0	12.2	0	7.0	0	3.1	0	3.1	0	7.0
12	68.7	59.8	0	13.0	0	7.5	0	3.9	0	3.9	0	7.5
13	71.7	61.6	0	14.8	0	7.8	0	5.2	0	5.2	0	7.8
14	74.5	63.4	0	16.6	0	10.4	0	6.8	0	6.8	0	10.4
15	76.6	64.8	0	17.6	0	11.6	0	7.9	0	7.9	0	11.6
16	78.0	65.6	0	17.8	0	11.2	0	7.4	0	7.4	0	11.2
17	78.5	65.6	0	18.7	0	11.6	0	8.5	0	8.5	0	11.6
18	78.2	65.8	0	16.3	0	8.7	0	7.4	0	7.4	0	8.7
19	77.5	65.6	0	12.3	0	5.1	0	5.1	0	5.1	0	5.1
20	76.3	66.1	0	10.8	0	6.8	0	6.8	0	6.8	0	6.8
21	74.8	67.2	0	5.8	0	4.1	0	4.1	0	4.1	0	4.1
22	73.0	66.4	0	4.9	0	3.4	0	3.4	0	3.4	0	3.4
23	70.9	65.4	0	3.7	0	2.5	0	2.5	0	2.5	0	2.5
24	68.7	64.0	0	1.2	0	0.5	0	0.5	0	0.5	0	0.5

June Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	2.9	0	1.3	0	1.4	0	1.4	0	1.4
2	71.2	66.1	0	2.5	0	0.8	0	0.8	0	0.9	0	0.9
3	69.7	65.2	0	2.2	0	0.8	0	0.8	0	0.8	0	0.8
4	68.5	64.3	0	1.9	0	0.8	0	0.8	0	0.8	0	0.8
5	67.8	64.2	0	1.7	0	0.7	0	0.7	0	0.8	0	0.8
6	67.6	64.2	0	6.3	0	1.5	0	0.7	0	0.7	0	1.6
7	68.1	64.8	0	8.1	0	4.4	0	2.3	0	2.3	0	4.5
8	69.4	65.7	0	11.7	0	7.4	0	3.8	0	3.8	0	8.1
9	71.6	66.2	0	12.5	0	8.0	0	4.6	0	4.6	0	8.1
10	74.2	67.2	0	13.2	0	9.8	0	6.3	0	6.4	0	10.1
11	77.2	68.5	0	14.0	0	10.2	0	6.7	0	6.7	0	10.5
12	80.2	70.0	0	14.9	0	10.7	0	7.3	0	7.3	0	11.1
13	82.8	70.8	0	15.7	0	11.5	0	9.0	0	9.0	0	11.6
14	85.0	71.6	0	19.0	0	14.7	0	10.8	0	10.8	0	14.7
15	86.3	72.3	0	20.0	0	15.8	0	11.9	0	11.9	0	15.8
16	86.8	72.1	0	20.0	0	14.9	0	11.0	0	11.0	0	14.9
17	86.6	71.7	0	19.9	0	15.1	0	11.8	0	11.8	0	15.1
18	85.8	71.5	0	16.0	0	11.8	0	10.5	0	10.5	0	11.8
19	84.7	71.2	0	10.2	0	7.5	0	7.5	0	7.5	0	7.5
20	83.2	71.5	0	11.4	0	9.5	0	9.5	0	9.5	0	9.5
21	81.4	71.7	0	8.1	0	6.1	0	6.1	0	6.1	0	6.1
22	79.3	71.4	0	7.0	0	5.3	0	5.3	0	5.3	0	5.3
23	77.2	70.5	0	5.8	0	4.3	0	4.4	0	4.4	0	4.3
24	75.1	69.1	0	3.5	0	1.9	0	2.0	0	2.0	0	1.9

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M168, BASELINE

July		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0 69.3	0	2.9	0	0.9	0	1.1	0	1.1	0	1.1
2	70.5 68.0	0	2.3	0	0.8	0	0.8	0	0.8	0	0.8
3	69.4 67.1	0	2.0	0	0.7	0	0.8	0	0.8	0	0.8
4	68.5 66.4	0	1.7	0	0.7	0	0.7	0	0.7	0	0.7
5	67.9 66.0	0	1.6	0	0.7	0	0.7	0	0.7	0	0.7
6	67.7 65.9	0	5.6	0	0.7	0	0.7	0	0.7	0	0.7
7	68.1 66.3	0	8.0	0	4.1	0	1.1	0	1.1	0	4.9
8	69.1 67.3	0	12.0	0	7.8	0	4.1	0	4.1	0	8.5
9	70.8 68.0	0	12.1	0	8.0	0	5.1	0	5.1	0	8.2
10	72.9 69.1	0	13.1	0	9.8	0	6.0	0	6.0	0	9.9
11	75.2 70.5	0	13.9	0	10.3	0	6.4	0	6.4	0	10.3
12	77.5 71.7	0	14.6	0	10.7	0	7.0	0	7.0	0	10.7
13	79.6 72.7	0	15.5	0	11.2	0	8.6	0	8.6	0	11.2
14	81.3 73.5	0	18.5	0	14.2	0	10.3	0	10.3	0	14.2
15	82.3 73.7	0	19.4	0	15.1	0	11.2	0	11.2	0	15.1
16	82.7 73.5	0	19.5	0	14.7	0	10.9	0	10.9	0	14.7
17	82.5 73.1	0	19.5	0	14.7	0	11.3	0	11.3	0	14.7
18	82.0 72.6	0	15.0	0	11.2	0	9.9	0	9.9	0	11.2
19	81.1 73.2	0	9.4	0	6.8	0	6.8	0	6.8	0	6.8
20	79.9 73.8	0	10.8	0	9.2	0	9.2	0	9.2	0	9.2
21	78.5 73.9	0	7.5	0	5.4	0	5.5	0	5.5	0	5.4
22	76.9 73.1	0	6.5	0	4.9	0	5.0	0	5.0	0	4.9
23	75.2 71.9	0	5.4	0	4.0	0	4.1	0	4.1	0	4.0
24	73.5 70.8	0	3.2	0	1.6	0	1.6	0	1.6	0	1.6

August		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7 70.2	0	2.9	0	1.0	0	1.1	0	1.2	0	1.2
2	71.2 69.0	0	2.3	0	0.7	0	0.8	0	0.8	0	0.8
3	69.9 68.0	0	2.0	0	0.7	0	0.7	0	0.7	0	0.7
4	68.8 67.1	0	1.7	0	0.7	0	0.7	0	0.7	0	0.7
5	68.0 66.6	0	1.6	0	0.6	0	0.6	0	0.6	0	0.6
6	67.5 66.2	0	4.4	0	0.6	0	0.6	0	0.6	0	0.6
7	67.3 66.1	0	7.7	0	3.6	0	0.6	0	0.6	0	4.2
8	67.8 66.5	0	12.0	0	7.5	0	3.5	0	3.5	0	8.2
9	69.1 67.0	0	12.1	0	7.5	0	4.7	0	4.7	0	7.7
10	71.2 67.8	0	13.0	0	9.0	0	5.6	0	5.6	0	9.3
11	73.8 68.7	0	13.6	0	9.5	0	5.7	0	5.7	0	9.5
12	76.5 70.0	0	14.3	0	10.0	0	6.3	0	6.3	0	10.0
13	79.1 71.2	0	15.1	0	10.9	0	8.3	0	8.3	0	10.9
14	81.1 72.6	0	18.3	0	14.1	0	10.1	0	10.1	0	14.1
15	82.5 73.6	0	19.3	0	14.9	0	11.0	0	11.0	0	14.9
16	83.0 73.7	0	19.2	0	13.3	0	9.4	0	9.4	0	13.3
17	82.8 73.5	0	19.0	0	14.1	0	10.8	0	10.8	0	14.1
18	82.3 73.5	0	13.5	0	9.8	0	8.5	0	8.5	0	9.8
19	81.5 73.1	0	8.9	0	6.3	0	6.3	0	6.3	0	6.3
20	80.4 73.7	0	10.5	0	8.9	0	8.9	0	8.9	0	8.9
21	79.1 74.9	0	7.2	0	5.2	0	5.3	0	5.3	0	5.2
22	77.6 73.9	0	6.3	0	4.8	0	4.9	0	4.9	0	4.8
23	76.0 72.7	0	5.2	0	4.0	0	4.1	0	4.1	0	4.0
24	74.3 71.3	0	3.1	0	1.6	0	1.7	0	1.7	0	1.6

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M168, BASELINE

September			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----				
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	
1	69.8	66.1	0		1.6		0		0.5		0		0.6		0		0.6		0.6
2	68.0	64.5	0		1.0		0		0.5		0		0.5		0		0.5		0.5
3	66.3	63.0	0		1.0		0		0.5		0		0.5		0		0.5		0.5
4	64.9	61.9	0		0.9		0		0.4		0		0.5		0		0.5		0.5
5	63.9	61.3	0		0.9		0		0.4		0		0.5		0		0.5		0.5
6	63.2	61.0	0		1.7		0		0.4		0		0.4		0		0.4		0.4
7	63.0	60.8	0		5.6		0		0.3		0		0.3		0		0.3		0.3
8	63.4	61.4	0		10.0		0		3.4		0		0.3		0		0.3		3.8
9	64.7	61.8	0		10.4		0		6.0		0		0.3		0		0.3		6.3
10	66.6	62.1	0		11.0		0		6.4		0		1.7		0		1.7		6.4
11	69.1	62.9	0		11.5		0		7.6		0		3.9		0		3.9		7.7
12	71.8	63.7	0		12.4		0		8.1		0		4.4		0		4.4		8.1
13	74.5	65.5	0		13.7		0		8.5		0		5.9		0		5.9		8.5
14	77.0	67.1	0		16.9		0		11.4		0		7.8		0		7.8		11.5
15	78.9	68.2	0		17.3		0		11.6		0		7.9		0		7.9		11.7
16	80.2	68.6	0		17.0		0		11.3		0		7.5		0		7.5		11.3
17	80.6	68.5	0		15.8		0		11.1		0		8.1		0		8.1		11.4
18	80.4	68.9	0		10.2		0		7.2		0		5.8		0		5.8		7.2
19	79.7	70.0	0		7.5		0		4.9		0		4.9		0		4.9		4.9
20	78.7	71.2	0		8.8		0		7.1		0		7.1		0		7.1		7.2
21	77.3	71.6	0		5.8		0		4.2		0		4.2		0		4.2		4.2
22	75.6	70.5	0		5.0		0		3.8		0		3.8		0		3.8		3.8
23	73.7	69.4	0		4.1		0		3.1		0		3.1		0		3.1		3.1
24	71.8	67.7	0		1.8		0		0.6		0		0.6		0		0.6		0.6

October			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----				
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	
1	54.8	51.3	0		0.2		0		0.0		0		0.0		0		0.0		0.0
2	52.9	49.6	0		0.2		0		0.0		0		0.0		0		0.0		0.0
3	51.2	48.2	0		0.1		0		0.0		0		0.0		0		0.0		0.0
4	49.8	47.2	0		0.1		0		0.0		0		0.0		0		0.0		0.0
5	48.8	46.2	0		0.1		0		0.0		0		0.0		0		0.0		0.0
6	48.2	45.7	0		0.0		0		0.0		0		0.0		0		0.0		0.0
7	47.9	45.6	0		0.0		0		0.0		0		0.0		0		0.0		0.0
8	48.5	46.2	0		2.8		0		1.3		0		0.0		0		0.0		0.0
9	50.3	47.3	0		3.7		0		3.3		0		0.0		0		0.0		0.0
10	52.9	48.7	0		3.7		0		3.3		0		0.0		0		0.0		0.8
11	56.2	49.9	0		3.8		0		3.3		0		0.0		0		0.0		3.3
12	59.6	51.5	0		4.9		0		3.3		0		0.0		0		0.0		3.3
13	62.9	53.5	0		8.8		0		2.4		0		0.0		0		0.0		2.4
14	65.5	55.2	0		11.5		0		3.4		0		0.0		0		0.0		3.4
15	67.3	56.3	0		12.4		0		3.6		0		0.0		0		0.0		3.5
16	67.9	56.6	0		11.8		0		3.7		0		0.0		0		0.0		3.7
17	67.7	56.4	0		9.3		0		2.7		0		0.0		0		0.0		2.7
18	67.0	56.6	0		5.8		0		2.6		0		0.2		0		0.2		2.5
19	66.0	57.6	0		3.2		0		1.4		0		1.4		0		1.4		1.4
20	64.6	57.9	0		4.7		0		3.3		0		3.3		0		3.3		3.4
21	62.9	57.3	0		1.9		0		0.9		0		0.9		0		0.9		0.9
22	61.0	56.0	0		1.1		0		0.5		0		0.5		0		0.5		0.5
23	59.0	54.8	0		0.3		0		0.0		0		0.0		0		0.0		0.0
24	56.9	53.0	0		0.3		0		0.0		0		0.0		0		0.0		0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M168, BASELINE

November			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton
1	48.7	45.7	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
2	46.9	44.1	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
3	45.5	42.8	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
4	44.6	41.9	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	-13,390	0.0	0.0	-13,390	0.0	0.0
5	44.4	42.0	0	0.0	0.0	0	0.0	0.0	-20,713	0.0	0.0	-50,031	0.0	0.0	-50,031	0.0	0.0
6	44.8	42.7	0	0.0	0.0	0	0.0	0.0	-42,319	0.0	0.0	-42,315	0.0	0.0	-23,464	0.0	0.0
7	45.9	43.9	0	0.0	0.0	0	0.0	0.0	-39,674	0.0	0.0	-39,673	0.0	0.0	-20,822	0.0	0.0
8	47.8	46.0	0	0.0	0.0	0	0.0	0.0	-15,942	0.0	0.0	-15,942	0.0	0.0	-7,564	0.0	0.0
9	50.2	48.0	0	0.0	0.0	0	0.0	0.0	-7,211	0.0	0.0	-7,211	0.0	0.0	-16,239	0.0	0.0
10	52.9	49.9	0	0.0	0.0	0	0.0	0.0	-6,221	0.0	0.0	-6,221	0.0	0.0	-8,966	0.0	0.0
11	55.8	51.1	0	0.0	0.0	0	0.0	0.0	-2,351	0.0	0.0	-2,351	0.0	0.0	-4,770	0.0	0.0
12	58.5	52.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
13	60.9	52.5	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
14	62.8	53.4	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
15	64.0	53.8	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
16	64.4	53.9	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
17	64.1	53.7	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
18	63.2	53.7	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
19	61.8	54.2	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
20	60.0	53.6	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
21	57.9	52.7	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
22	55.6	51.2	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
23	53.2	49.5	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
24	50.8	47.6	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0

December			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton	Htg Btuh	Clg Ton	Ton
1	37.5	35.3	0	0.0	0.0	0	0.0	0.0	-62,512	0.0	0.0	-62,512	0.0	0.0	-62,512	0.0	0.0
2	37.1	35.1	0	0.0	0.0	-5,725	0.0	0.0	-65,498	0.0	0.0	-65,498	0.0	0.0	-65,498	0.0	0.0
3	37.4	35.5	-13,649	0.0	0.0	-66,473	0.0	0.0	-66,476	0.0	0.0	-66,476	0.0	0.0	-66,476	0.0	0.0
4	38.1	36.2	-59,080	0.0	0.0	-66,562	0.0	0.0	-66,562	0.0	0.0	-66,562	0.0	0.0	-66,562	0.0	0.0
5	39.3	37.6	-60,097	0.0	0.0	-67,346	0.0	0.0	-67,346	0.0	0.0	-67,346	0.0	0.0	-67,346	0.0	0.0
6	40.9	39.2	-32,257	0.0	0.0	-37,294	0.0	0.0	-56,146	0.0	0.0	-56,146	0.0	0.0	-37,294	0.0	0.0
7	42.7	41.2	-31,810	0.0	0.0	-35,642	0.0	0.0	-54,492	0.0	0.0	-54,492	0.0	0.0	-35,642	0.0	0.0
8	44.7	43.1	-10,045	0.0	0.0	-24,420	0.0	0.0	-32,799	0.0	0.0	-32,799	0.0	0.0	-24,420	0.0	0.0
9	46.8	45.3	-8,265	0.0	0.0	-28,521	0.0	0.0	-19,494	0.0	0.0	-19,494	0.0	0.0	-28,521	0.0	0.0
10	48.8	47.0	0	0.0	0.0	-22,054	0.0	0.0	-19,309	0.0	0.0	-19,309	0.0	0.0	-22,054	0.0	0.0
11	50.7	48.1	0	0.0	0.0	-16,735	0.0	0.0	-14,315	0.0	0.0	-14,315	0.0	0.0	-16,735	0.0	0.0
12	52.2	48.8	0	0.0	0.0	-10,697	0.0	0.0	-8,278	0.0	0.0	-8,278	0.0	0.0	-10,697	0.0	0.0
13	53.4	49.2	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
14	54.1	49.2	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
15	54.4	48.9	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
16	54.0	48.2	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
17	53.0	47.3	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
18	51.4	46.3	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
19	49.3	45.4	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
20	47.0	43.5	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
21	44.5	41.5	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
22	42.2	39.3	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0	0	0.0	0.0
23	40.1	37.6	0	0.0	0.0	-16,583	0.0	0.0	-11,782	0.0	0.0	-11,782	0.0	0.0	-16,583	0.0	0.0
24	38.5	36.2	0	0.0	0.0	-57,687	0.0	0.0	-57,687	0.0	0.0	-57,687	0.0	0.0	-57,687	0.0	0.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M168, BASELINE

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	WATER (1000 Gl)	GAS DMND On Peak (Thrm/hr)
Jan	12,245	26	308	0	1
Feb	10,794	26	249	0	1
March	10,099	26	24	0	1
April	9,157	21	0	0	0
May	15,288	46	0	0	0
June	17,323	50	0	0	0
July	17,129	48	0	0	0
Aug	17,344	48	0	0	0
Sept	15,014	42	0	0	0
Oct	11,978	34	0	0	0
Nov	9,598	26	26	0	1
Dec	11,242	26	193	0	1
Total	157,212	50	801	1	1

Building Energy Consumption = 52,621 (Btu/Sq Ft/Year)
 Source Energy Consumption = 144,559 (Btu/Sq Ft/Year)

Floor Area = 11,720 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M168, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 49.8 (kW)
 Yearly Time of Peak 17 (hr) 6 (mo)

Hour 17 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	28.4	56.93
Sub Total			28.4	56.93
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	4.1	8.32
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.2	2.46
Sub Total			5.4	10.78
Sub Total			0.0	0.00
Miscellaneous				
Lights			9.3	18.73
Base Utilities			0.0	0.00
Misc Equipment			6.8	13.56
Sub Total			16.1	32.29
Grand Total			49.8	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M168, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 11,720
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,126.4	80,139.6	1.4	13.6	95,891.8	8.4
Primary Cooling						
Compressor	18,925.8	0.0	0.0	10.5	193,800.3	16.9
Tower/Cond Fans	2,399.9	0.0	0.0	1.3	24,575.5	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,158.3	0.0	0.0	0.6	11,861.0	1.0
Auxiliary						
Supply Fans	47,060.6	0.0	0.0	26.0	481,901.7	42.1
Circulation Pumps	21,154.6	0.0	0.0	11.7	216,623.5	18.9
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	68,215.2	0.0	0.0	37.8	698,525.1	61.1
Lighting	41,081.3	0.0	0.0	22.7	420,673.0	35.9
Receptacle	24,305.2	0.0	0.0	13.5	248,886.3	21.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	157,212.1	80,139.6	1.4	100.0	1,694,213.3	146.7

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M168, ECO#1

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	WATER	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)		On Peak (Thrm/hr)
Jan	12,194	27	140	0	1
Feb	10,921	27	111	0	1
March	9,742	21	0	0	0
April	9,157	21	0	0	0
May	15,986	43	0	0	0
June	17,324	45	0	0	0
July	17,226	44	0	0	0
Aug	17,579	44	0	0	0
Sept	15,696	40	0	0	0
Oct	12,939	33	0	0	0
Nov	9,157	21	0	0	0
Dec	10,311	24	44	0	1
Total	158,233	45	295	1	1

Building Energy Consumption = 48,596 (Btu/Sq Ft/Year) Floor Area = 11,720 (Sq Ft)
 Source Energy Consumption = 140,902 (Btu/Sq Ft/Year)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M168, ECO#1

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 44.9 (kW)
Yearly Time of Peak 17 (hr) 6 (mo)

Hour 17 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	23.4	52.14
Sub Total			23.4	52.14
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	4.1	9.24
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.2	2.73
Sub Total			5.4	11.98
Sub Total			0.0	0.00
Miscellaneous				
	Lights		9.3	20.81
	Base Utilities		0.0	0.00
	Misc Equipment		6.8	15.07
Sub Total			16.1	35.88
Grand Total			44.9	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M168, ECO#1

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 11,720
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	666.2	29,493.0	0.7	5.6	37,867.6	3.3
Primary Cooling						
Compressor	16,499.9	0.0	0.0	9.9	168,958.9	14.8
Tower/Cond Fans	2,053.9	0.0	0.0	1.2	21,032.3	1.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,210.8	0.0	0.0	0.7	12,398.6	1.1
Auxiliary						
Supply Fans	47,061.5	0.0	0.0	28.2	481,910.7	42.1
Circulation Pumps	25,353.9	0.0	0.0	15.2	259,624.4	22.7
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	72,415.4	0.0	0.0	43.4	741,535.1	64.9
Lighting	41,081.3	0.0	0.0	24.6	420,673.0	35.9
Receptacle	24,305.2	0.0	0.0	14.6	248,886.3	21.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	158,232.7	29,493.0	0.7	100.0	1,651,351.9	143.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M168, ECO#3

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	WATER (1000 G1)	GAS DMND On Peak (Thrm/hr)
Jan	12,965	27	306	0	1
Feb	11,373	27	247	0	1
March	10,192	27	24	0	1
April	9,157	21	0	0	0
May	16,056	47	0	0	0
June	18,159	51	0	0	0
July	17,993	50	0	0	0
Aug	18,208	49	0	0	0
Sept	15,792	44	0	0	0
Oct	12,404	35	0	0	0
Nov	9,714	27	26	0	1
Dec	11,730	27	192	0	1
Total	163,744	51	795	1	1

Building Energy Consumption = 54,464 (Btu/Sq Ft/Year)
 Source Energy Consumption = 150,205 (Btu/Sq Ft/Year)

Floor Area = 11,720 (Sq Ft)

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M168, ECO#3

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 50.9 (kW)
Yearly Time of Peak 17 (hr) 6 (mo)

Hour 17 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	29.4	57.84
Sub Total			29.4	57.84
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	4.1	8.14
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.2	2.41
Sub Total			5.4	10.55
Sub Total			0.0	0.00
Miscellaneous				
	Lights		9.3	18.33
	Base Utilities		0.0	0.00
	Misc Equipment		6.8	13.28
Sub Total			16.1	31.61
Grand Total			50.9	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M168, ECO#3

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 11,720
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,124.5	79,451.9	1.3	13.0	95,148.2	8.3
Primary Cooling						
Compressor	18,918.1	0.0	0.0	10.1	193,721.9	16.9
Tower/Cond Fans	2,398.5	0.0	0.0	1.3	24,560.7	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,159.5	0.0	0.0	0.6	11,873.3	1.0
Auxiliary						
Supply Fans	47,061.5	0.0	0.0	25.2	481,910.7	42.1
Circulation Pumps	27,695.4	0.0	0.0	14.8	283,601.4	24.8
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	74,756.9	0.0	0.0	40.0	765,512.2	67.0
Lighting	41,081.3	0.0	0.0	22.0	420,673.0	35.9
Receptacle	24,305.2	0.0	0.0	13.0	248,886.3	21.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	163,744.0	79,451.9	1.3	100.0	1,760,375.6	152.5

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M168, ECO#12

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	WATER	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)		On Peak (Thrm/hr)
Jan	11,033	26	251	0	1
Feb	9,771	26	199	0	1
March	9,400	26	10	0	1
April	8,569	21	0	0	0
May	13,012	43	0	0	0
June	14,984	48	0	0	0
July	14,674	47	0	0	0
Aug	14,909	46	0	0	0
Sept	12,548	41	0	0	0
Oct	9,862	33	0	0	0
Nov	8,782	26	8	0	0
Dec	10,408	26	148	0	1
Total	137,951	48	616	1	1

Building Energy Consumption = 45,432 (Btu/Sq Ft/Year)
 Source Energy Consumption = 126,067 (Btu/Sq Ft/Year)

Floor Area = 11,720 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M168, ECO#12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 48.1 (kW)
 Yearly Time of Peak 17 (hr) 6 (mo)

Hour 17 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	26.7	55.41
Sub Total			26.7	55.41
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	4.1	8.61
2		SUMMATION OF FAN ELECTRICAL DEMAND	1.2	2.55
Sub Total			5.4	11.16
Sub Total			0.0	0.00
Miscellaneous				
	Lights		9.3	19.39
	Base Utilities		0.0	0.00
	Misc Equipment		6.8	14.04
Sub Total			16.1	33.43
Grand Total			48.1	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M168, ECO#12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 11,720
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	874.8	61,627.0	1.0	12.1	73,828.0	6.5
Primary Cooling						
Compressor	14,011.3	0.0	0.0	9.0	143,476.5	12.5
Tower/Cond Fans	1,833.0	0.0	0.0	1.2	18,769.6	1.6
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	785.7	0.0	0.0	0.5	8,045.6	0.7
Auxiliary						
Supply Fans	40,030.5	0.0	0.0	25.7	409,913.2	35.9
Circulation Pumps	15,029.0	0.0	0.0	9.6	153,897.3	13.5
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	55,059.5	0.0	0.0	35.3	563,810.4	49.3
Lighting	41,081.3	0.0	0.0	26.3	420,673.0	35.9
Receptacle	24,305.2	0.0	0.0	15.6	248,886.3	21.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	137,950.7	61,627.0	1.0	100.0	1,477,489.4	127.8

BUILDING 171

EMC ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 15-APR-92
 FILE: M171ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M171 Area: 35,398 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (Mbtu/yr)
Baseline	296,389	1,574	65,183	102,491	79,993	93,656	86,156	429,054	161	296	1,760
ECO#7	46,949	185	65,183	102,491	33,743	93,656	86,156	381,414	161	47	1,348
Savings/(Loss)	249,440	1,389	0	0	46,250	0	0	47,639	0	249	412
ECO#12	34,322	96	14,947	35,381	5,427	93,656	86,156	235,663	135	34	838
Savings/(Loss)	262,068	1,478	50,236	67,111	74,566	0	0	193,390	26	262	922
ECO#13	296,389	1,574	81,478	102,491	79,993	93,656	86,156	445,349	101	296	1,816
Savings/(Loss)	0	0	(16,296)	0	0	0	0	(16,296)	60	0	(56)
ECO#15	319,459	1,644	62,248	102,491	79,993	75,862	86,156	408,395	161	319	1,713
Savings/(Loss)	(23,070)	(69)	2,934	0	0	17,794	0	20,659	0	(23)	47

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105 000
SHEET NO. 1 OF _____
CALCULATED BY RMA DATE 3/5/92
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation - Bldg 171, Ericsson Rcn
Bldg. Type: Brick Hospital Area: 34,114
ECO: 12,13
Take off bldg: 170


Assumptions:

- Heating db = 72°F
- Cooling db = 76°F
- Basement walls framed w/ R-11 Insulation
- Occupancy: 1.5 people/room \Rightarrow 105 people
- Misc Equip: 3.0 W/L/HZ
- No infiltration due to outside air fan coil units

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

Camp S. in - Bldg 171


Wall U-Value - ASHRAE Table F 22.4



Material	R-Value
Outside Surface (15 mph)	0.17
4" Face Brick	1.24
1/2" Gyp	0.45
R-11 Insulation	11.0
1/2" Gyp	0.45
Inside Surface (still air)	<u>0.68</u>
	13.99

$$U = \frac{1}{R} = \frac{1}{13.99} = \boxed{0.071}$$

Roof U-Value ASHRAE Table F. 22.4



Material	R-Value
Outside Surface (15 mph)	0.17
Shingles	0.44
1/2" Plywood	0.62
Air Space	1.24
R-19 Insulation	19.00
1/2" Gyp Board	0.45
Inside Surface (still Air)	<u>0.62</u>
	22.54

$$U = \frac{1}{22.54} = \boxed{0.044}$$

Window U-Value - ASHRAE Table F 27.13

- Double Pane, Al Frame, sliding

$$U = \boxed{0.70}$$

Indoor Shading Coefficient - ASHRAE Table F 27.26

- Light Venetian blinds

$$\Rightarrow \boxed{0.58}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000

SHEET NO. 3 OF _____

CALCULATED BY Rmg DATE 3/5/92

CHECKED BY _____ DATE _____

SCALE _____


Comp Sw - Bldg 171

Slab Heat Loss Coefficient - ASHRAE Table F 25.5

0.62

Basement Walls U-Value - ASHRAE Table F 22.4

- Assumed construction



Material	R-Value
Outside surface (15 mph)	0.17
12" Concrete	1.20
R-11 Insulation	11.0
1/2 Gyp Board	0.45
Inside Surface (still air)	<u>0.68</u>
	13.5

$$U = \frac{1}{13.5} = \boxed{0.074}$$

- Assume 6' height to account for both above + below surface

Basement Floor U-Value - ASHRAE Table F 25.4

- chamber width = 20 ft

- Depth below grade = 5 ft

$$U = \boxed{0.032}$$

Lighting - from ECO #15

33,823 W

People

- Assume 1.5 people / room * 70 rooms = 105 people

Misc Equipment

- Assume 5.0 Btuh / ft²

Inf.

- Assume none due to OA Fan coils

OA Ventilation

- 3950 cfm, from building drawings' mech. equip schedules

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 171, McPherson

Baseline (cont)

Pumps

$$\text{CHW Pump: } \frac{(10 \text{ HP}) \cdot (0.746 \text{ kW/HP}) \cdot (0.95 \text{ load})}{0.865 \text{ efl}} = 7.3 \text{ kW} \cdot 4,380 \text{ hrs} = 32,109 \text{ kWh/yr}$$

$$\text{HW Pump: } \frac{(15 \text{ HP}) \cdot (0.746 \text{ kW/HP}) \cdot (0.95 \text{ load})}{0.87 \text{ efl}} = 10.9 \text{ kW} \cdot 4,380 \text{ hrs} = 47,885 \text{ kWh/yr}$$

79,993 kWh/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

BLDG 171, McPherson

ECO # 7 - Pump Controls

HW Circulation Pump

- Add time clock: on 06:00 - 18:00 M-F, off otherwise

- cycle with load

DHW Pumps

- off as per survey, therefore no savings

Electric Savings

Total Electric Savings = 47,630 kWh/yr

Demand Savings

Peak Demand Savings = 0 kW

Gas Savings

Total Gas Savings = 249 MBtu/yr

RATIO SAVINGS TO BLDG 170

$$47,639 \text{ kWh} \times \frac{30,205 \text{ sq ft}}{34,114} = 42,180 \text{ kWh}$$

$$0 \text{ kW} \times 0 = 0$$

$$249 \text{ MBtu} \times \frac{30,205}{34,114} = 220 \text{ MBtu}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - Bldg 171, McPherson

ECO #12 - HVAC Controls

- Reset T-stat setpoints: 70F - heating 78F - cooling
- Add timerlock + cycle controlled for pump
- Set back thermostats
- Turn off fans at night - assume 5 ACU, all

Electric Savings

Total Electric Savings = 193,390 kWh/yr

Demand Savings

Peak Demand Savings = 26 kW/yr

Gas Savings

Total Gas Savings = 262 MMBtu/yr

Fan + Pump schedule

On 0600 - 18:00 M-F, off otherwise

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - 10/1/77 - J. E. Liberson

ECO #13 - Thermal Storage

Charge Tank: 00:00 - 06:00 M-Sun

Discharge Tank: 12:00 - 18:00 M-Sun

Tank Capacity: 247.5 Ton-Hr - from Trace output for August design

Chiller Capacity: 41.25 Tons = 145 Ton

Demand Savings

Existing chiller kW/ton = 1.064 kW/ton

Peak Capacity (Aug) = 56.1 Tons

Demand Savings = $56.1 \times 1.064 = 597 = \boxed{60} \text{ kW}$

Electric Loss

Additional Electric = $\boxed{16,296} \text{ kWh/yr}$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Compressor 2.1.1.1

Bldg 71, McPherson

Flow #15

32,827 W

5,425 W

27,402 W

Flow #16

30,000 W

Flow #17

2,000 - 200 = 2,800 W

Flow Factor 0.15 (minimum of 0.15)

Gas Factor

2.1.1.1 McPherson

Gas Factor 1.70 (minimum of 1.70)

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EEAP
 Location: FT MCPHERSON, BLDG 171
 Program User: R. GERRANS

-----CARD 08-- Climatic Information-----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month Cooling Simulation	Last Month Cooling Simulation	Peak Cooling Load Hr	1st Month Summer Period	Last Month Summer Period	1st Month Daylight Savings	Last Month Daylight Savings
MAY						OCT

----- Load Section Alternative #1 -----

----- Load Alternative -----

Number	Description
1	BLDG M171, BASELINE

-----CARD 20-- General Room Parameters-----

Room Number	Zone	Reference Room	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1		1	2 FLOORS + BASEM	35398	1		4		12			

-----CARD 21-- Thermostat Parameters-----

Room Number	Cooling Room Design DB	Room RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	T'stat Location Flag	Mass / No. Hrs Average	Carpet On Floor
1	76			CLG	72		HTG			

-----CARD 22-- Roof Parameters -----

Roof									
Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	16760	1	.044	38			

-----CARD 24-- Wall Parameters -----

Wall										Ground
Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Wall Reflectance	Ground Multiplier
M	1		24	.071	76					
1	1	38				180				
1	2	131				90				
1	3	41				0				
1	4	203				0				
1	5	90				90				
1	6	216				180				
1	7	238				270				
M1	1		6	.074	65					
1	8	102				0				
1	9	80				90				
1	10	135				180				
1	11	141				270				

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
M	1			1	.7	.58					
1	1	7	41				3				
1	2	8.5	62.8				4				
1	3	8.5	23.7				4				
1	4	7	157.5								
1	5	7	65.5								
1	6	7	100.7								
1	7	7	152.5								
1	8	2.5	12.9								
1	9	2.5	22.1								
1	10	2.5	9.5								
1	11										

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
1	ADMPPL	ADMLGTEQ	AVAIL	OFF		AVAIL				

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to		--- Daylighting ---	
									Ret. Air	Reference Point 1	Reference Point 2	
1	105	PEOPLE	250	200	33823	WATTS						

-----CARD 28--- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path

-----CARD 29--- Room Airflows -----

Room Number	-----Ventilation-----				-----Infiltration-----				--Reheat Minimum--	
	Cooling		Heating		Cooling		Heating		Value	Units
	Value	Units	Value	Units	Value	Units	Value	Units	Value	Units
1	3950	CFM	3950	CFM						

-----CARD 32-- Exposed Floor Parameters-----

Room Number	Exposed Floor Number	-----Slab-----		Floor Area	-----Exposed Floor-----			Cooling Temp	Heating Temp	Adjacent Room No
		Perimeter Length	Loss Coefficient		Floor U-Value	Const Type	Temp Flag			
1	1	499	.62							
1	2	458	.032							

-----CARD 33-- External Shading -----

Shading Type	Glass Height	-----OVERHANG-----		-----VERTICAL FINS-----					Adjacent Building Flag	
		Above Glass	Projection Out	Glass Width	Projection Left	Projection Out	Projection Right	Projection Out		
3	7	1	10							
4	8.5	1	10							

----- System Section Alternative #1 -----

-----CARD 39-- System Alternative -----

Number	Description
1	BLDG M171, BASELINE

```

-----CARD 40--- System Type -----
-----OPTIONAL VENTILATION SYSTEM-----
System      Ventil      Fan
Set System  Deck      Cooling Heating Cooling Heating Static
Number Type   Location  SADBvh  SADBvh  Schedule Schedule Pressure
1          FC
    
```

```

-----CARD 41-- Zone Assignment -----
System
Set          Ref #1      Ref #2      Ref #3      Ref #4      Ref #5      Ref #6
Number      Begin   End   Begin   End   Begin   End   Begin   End   Begin   End   Begin   End
1           1     1     1     1     1     1     1     1     1     1     1     1
    
```

```

-----CARD 42--- Fan SP and Duct Parameters-----
System Cool Heat Return Mn Exh Aux Rm Exh Cool Return Supply Supply Return
Set Fan Fan Fan Fan Fan Fan Fan Mtr Fan Mtr Duct Duct Air
Number SP SP SP SP SP SP Loc Loc Ht Gn Loc Path
1      2
          RETAIR          OTHER ROOMDK
    
```

```

-----CARD 45--- Equipment Schedules -----
System Main          Direct Indirect Auxiliary Main Main Auxiliary
Set Cooling Heat Return Evap Evap Cooling Heating Preheat Reheat Mech. Heating
Number Coil Economizer Coil Coil Coil Coil Coil Coil Coil Humidity Coil
1      CLGC
          BTGC
    
```

----- Equipment Section Alternative #1 -----

```

-----CARD 59-- Equipment Description / TOD Schedules -----
Alternative Elec Consump Elec Demand Demand
Number      Time of Day Time of Day Limit
1           Schedule   Schedule   Max KW Alternative Description
          BLDG M171, BASELINE
    
```

```

-----CARD 60--- Cooling Load Assignment-----
Load All Coil Cooling
Asgn Loads To Equipment -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
Ref Cool Ref Sizing Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
1      1      BLKPLANT 1 1
    
```

```

-----CARD 62-- Cooling Equipment Parameters -----
Cool Equip Num -----COOLING----- -----HEAT RECOVERY----- Seq Demand
Ref Code Of --Capacity-- --Energy-- --Capacity-- --Energy-- Order Seq Limit
Num Name Units Value Units Value Units Value Units Value Units Num Type Number
1 EQ1122L 1 75 TONS
    
```

-----CARD 63-- Cooling Pumps and References -----

Cool Ref	---CHILLED WATER---	-----CONDENSER-----	---HT REC or AUX---	Switch-over	Cold Storage	Cooling Tower	Misc. Access.
Num	Value	Units	Value	Units	Value	Units	Value
1	7.3	KW					

-----CARD 65-- Heating Load Assignment -----

Load Assignment Reference	All Coil Loads To Heating Ref	-Group 1- Begin End	-Group 2- Begin End	-Group 3- Begin End	-Group 4- Begin End	-Group 5- Begin End	-Group 6- Begin End	-Group 7- Begin End	-Group 8- Begin End	-Group 9- Begin End
1	1	1	1							

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref Number	Equip Code	Number Of Units	HW Pmp Full Ld Value	Cap'y Units	Energy Rate Value	Seq Order Number	Switch over Control	Hot Strg	Misc. Acc.	Cogen	Demand Limit Number
1	EQ2004	1	10.9	KW							

-----CARD 69-- Fan Equipment Parameters -----

System Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	EQ4371						

Utility Description Reference Table

Schedules:

ADMLGTEQ ADMIN LIGHTING AND EQUIPMENT
ADMPEPL ADMIN PEOPLE SCHEDULE
AVAIL AVAILABLE (100%)
CLG COOLING TSTAT SCHEDULE
CLGC COOLING COIL SCHEDULE
HTG HEATING TSTAT SCHEDULE
HTGC HEATING COIL SCHEDULE
OFF ALWAYS OFF

System:

FC FAN COIL

Equipment:

Cooling:
EQ1122L AIR-CLD RECIP >55 TONS
Heating:
EQ2004 GAS WATER TUBE STEAM
Fan:
EQ4371 FAN COIL SUPPLY FAN

Schedule Name: ADMLGTEQ

Project: ADMIN LIGHTING AND EQUIPMENT SC

Location:

Client:

Program User:

Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

0 5
7 80
8 100
12 80
13 100
16 80
17 40
18 5
24

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

0 5
24

Schedule Name: ADMPPL
Project: ADMIN PEOPLE SCHEDULE
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: BTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

**
** T R A C E 6 0 0 A N A L Y S I S **
**
** by **
**

FT MCPHERSON & FT GILLEM EEAP
FT MCPHERSON, BLDG 171

R. GERRANS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 9:33:34 4/ 8/92
Dataset Name: M171-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M171, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil.	Room
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Supply Airflow (Cfm)	Exhaust Airflow (Cfm)
1	FC	3,950	37,025	37,025	37,025	3,950	0	0
Totals		3,950	37,025	37,025	37,025	3,950	0	0

CAPACITY - ALTERNATIVE 1
 BLDG M171, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating							
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)
1	FC	67.6	0.0	0.0	0.0	67.6	-460,338	0	0	0	0	0	0	-460,338
Totals		67.6	0.0	0.0	0.0	67.6	-460,338	0	0	0	0	0	0	-460,338

The building peaked at hour 15 month 8 with a capacity of 67.6 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M171, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	FC	10.67	1.05	547.8	523.7	22.91	1.05	-13.00	35,398

System 1 Block FC - FAN COIL

***** COOLING COIL PEAK *****						***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****					
Peaked at Time ==>						Mo/Hr: 8/15			Mo/Hr: 6/16			Mo/Hr: 13/ 1		
Outside Air ==>						OADB/WB/HR: 92/ 74/105.0			OADB: 96			OADB: 22		
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Percent Of Tot (%)	Space Sensible (Btuh)	Percent Of Tot (%)	Space Peak (Btuh)	Coil Peak (Btuh)	Percent Of Tot (%)	Space Peak (Btuh)	Coil Peak (Btuh)	Percent Of Tot (%)	
Skylite Solr	0	0	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	
Skylite Cond	0	0	0	0	0.00	0	0.00	0	-32,913	7.15	0	0	0.00	
Roof Cond	0	50,364	0	50,364	6.21	0	0.00	0	0	0.00	0	0	0.00	
Glass Solar	183,490	0	0	183,490	22.62	183,490	30.79	183,490	-166,349	36.14	-166,349	-166,349	15.75	
Glass Cond	51,064	0	0	51,064	6.30	61,402	10.30	61,402	-45,209	72.514	-45,209	-72,514	0.00	
Wall Cond	27,035	14,741	0	41,776	5.15	29,928	5.02	29,928	0	0.00	0	0	0.00	
Partition	0	0	0	0	0.00	0	0.00	0	-16,202	3.52	-16,202	-16,202	0.00	
Exposed Floor	0	0	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	
Infiltration	0	0	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	
Sub Total==>	261,588	65,105	0	326,694	40.28	274,820	46.12	274,820	-227,760	62.56	-227,760	-287,978	0.00	
Internal Loads														
Lights	115,438	0	0	115,438	14.23	115,438	19.37	115,438	0	0.00	0	0	0.00	
People	47,250	0	0	47,250	5.83	26,250	4.40	26,250	0	0.00	0	0	0.00	
Misc	106,194	0	0	106,194	13.09	106,194	17.82	106,194	0	0.00	0	0	0.00	
Sub Total==>	268,882	0	0	268,882	33.15	247,882	41.60	247,882	0	0.00	0	0	0.00	
Ceiling Load	65,105	-65,105	0	0	0.00	73,238	12.29	73,238	-60,218	0.00	-60,218	0	0.00	
Outside Air	0	0	0	162,829	20.08	0	0.00	0	-211,854	46.02	0	-211,854	0.00	
Sup. Fan Heat	0	0	0	39,493	4.87	0	0.00	0	39,493	-8.58	0	39,493	0.00	
Ret. Fan Heat	0	13,164	0	13,164	1.62	0	0.00	0	0	0.00	0	0	0.00	
Duct Heat Pkup	0	0	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	
OV/UNDR Sizing	0	0	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	
Exhaust Heat	0	0	0	0	0.00	0	0.00	0	0	0.00	0	0	0.00	
Terminal Bypass	0	0	0	0	-0.00	0	0.00	0	0	0.00	0	0	0.00	
Grand Total==>	595,576	13,164	0	811,063	100.00	595,940	100.00	595,940	-287,978	100.00	-287,978	-460,338	100.00	

-----COOLING COIL SELECTION-----										-----AREAS-----		
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)
Main Clg	67.6	811.1	37,025	78.0	64.6	73.6	60.2	57.5	69.4	35,398	0	0
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	10,126	0
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	16,760	0
Totals	67.6	811.1								Wall	25,716	4,475 17

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA	10.7	Type	Clg	Htg	
Main Htg	-460.3	37,025	67.7	79.3	Vent	3,950	3,950	Clg Cfm/Sqft	1.05	SADB	61.0	79.3	
Aux Htg	0.0	0	0.0	0.0	Infil	0	0	Clg Cfm/Ton	547.80	Plenum	81.8	66.6	
Preheat	-0.0	37,025	67.7	61.0	Supply	37,025	37,025	Clg Sqft/Ton	523.73	Return	76.0	72.0	
Reheat	0.0	0	0.0	0.0	Minclfm	0	0	Clg Btuh/Sqft	22.91	Ret/OA	77.7	66.7	
Humidif	0.0	0	0.0	0.0	Return	37,025	37,025	No. People	105	Runarnd	76.0	72.0	
Opt Vent	0.0	0	0.0	0.0	Exhaust	3,950	3,950	Htg % OA	10.7	Fn MtrTD	0.3	0.0	
Total	-460.3				Rm Exh	0	0	Htg Cfm/Sqft	1.05	Fn BldTD	0.2	0.0	
					Auxil	0	0	Htg Btuh/Sqft	-13.00	Fn Frict	0.7	0.0	

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M171, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room	1						
		Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space		76.0	63.2	50.0	69.8	29.2	
Main System							
Return Air Heat Pickup							-0.3
Return Fan							0.3
Return Air		76.0	63.2	50.0	69.8	29.2	
Outdoor Air		92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix		77.7	64.5	49.7	73.6	30.2	
Blow through Fan							0.2
Entering Coil		78.0	64.6	49.3	73.6	30.2	
Leaving Coil		60.2	57.5	85.5	69.4	25.2	
Draw Through Fan							0.0
Duct Frictional Heat							0.7
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		61.0	57.8	83.2	69.4	25.4	
Supply Air		61.0	57.8	83.2	69.4	25.4	
Percent Outside Air				10.67 (%)			
Sensible Heat Ratio (SHR)				0.966			
Percent Supply Air Bypassing Coil				0.00 (%)			
Coil Airflow				37,025 (Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M171, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)								Room Mass (lb/ sqft)	Room Capac. (Btu/ sqft/F)	
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Roof	Summr Windo	Wintr Windo	Wall			Ceil.
1	2 FLOORS + BASEM	0.000	0.032	0.000	0.000	0.044	0.700	0.743	0.071	0.317	43.8	9.74
Zone	1 Total/Ave.	0.000	0.032	0.000	0.000	0.044	0.700	0.743	0.071	0.317	43.8	9.74
System	1 Total/Ave.	0.000	0.032	0.000	0.000	0.044	0.700	0.743	0.071	0.317	43.8	9.74
Building		0.000	0.032	0.000	0.000	0.044	0.700	0.743	0.071	0.317	43.8	9.74

BUILDING AREAS - ALTERNATIVE 1
 BLDG M171, BASELINE

----- B U I L D I N G A R E A S -----

Room	Number of Duplicate	Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Skl /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
1 2 FLOORS + BASEM	1	1	35,398	0	10,126	0	0	16,760	4,475	17	21,241
Zone 1 Total/Ave.			35,398	0	10,126	0	0	16,760	4,475	17	21,241
System 1 Total/Ave.			35,398	0	10,126	0	0	16,760	4,475	17	21,241
Building			35,398	0	10,126	0	0	16,760	4,475	17	21,241

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
 BLDG M171, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.044 (Btu/Hr/Sq Ft/F)
 Overall Wall U-Value = 0.181 (Btu/Hr/Sq Ft/F)
 Overall Building U-Value = 0.127 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTvr) = 2.25 (Btu/Hr/Sq Ft)
 Wall Overall Thermal Transfer Value (OTTvw) = 16.35 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M171, BASELINE

Main System 1 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	3.4	12	359	-23,017	5	73	1,851.3	0	0	0.0	0	0
5 - 10	6.8	12	363	-46,034	6	79	3,702.5	0	0	0.0	0	0
10 - 15	10.1	11	336	-69,051	11	152	5,553.8	0	0	0.0	0	0
15 - 20	13.5	12	347	-92,068	4	56	7,405.0	0	0	0.0	0	0
20 - 25	16.9	4	123	-115,085	3	39	9,256.3	0	0	0.0	0	0
25 - 30	20.3	4	124	-138,101	5	69	11,107.5	0	0	0.0	0	0
30 - 35	23.7	3	80	-161,118	8	114	12,958.8	0	0	0.0	0	0
35 - 40	27.0	7	212	-184,135	6	81	14,810.1	0	0	0.0	0	0
40 - 45	30.4	6	164	-207,152	8	109	16,661.3	0	0	0.0	0	0
45 - 50	33.8	5	156	-230,169	6	86	18,512.6	0	0	0.0	0	0
50 - 55	37.2	3	82	-253,186	10	137	20,363.8	0	0	0.0	0	0
55 - 60	40.6	6	174	-276,203	6	77	22,215.1	0	0	0.0	0	0
60 - 65	43.9	6	193	-299,220	5	69	24,066.3	0	0	0.0	0	0
65 - 70	47.3	2	62	-322,237	17	231	25,917.6	0	0	0.0	0	0
70 - 75	50.7	1	23	-345,254	0	0	27,768.9	0	0	0.0	0	0
75 - 80	54.1	2	64	-368,271	0	0	29,620.1	0	0	0.0	0	0
80 - 85	57.5	4	108	-391,288	0	0	31,471.4	0	0	0.0	0	0
85 - 90	60.8	0	0	-414,304	0	0	33,322.6	0	0	0.0	0	0
90 - 95	64.2	0	0	-437,321	0	0	35,173.9	0	0	0.0	0	0
95 - 100	67.6	0	0	-460,338	0	0	37,025.1	100	8,760	0.0	0	0
Hours Off	0.0	0	5,790	0	0	7,388	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M171, BASELINE

----- SYSTEM LOAD PROFILE -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	3.4	12	359	-23,017	5	73	1,851.3	0	0	0.0	0	0
5 - 10	6.8	12	363	-46,034	6	79	3,702.5	0	0	0.0	0	0
10 - 15	10.1	11	336	-69,051	11	152	5,553.8	0	0	0.0	0	0
15 - 20	13.5	12	347	-92,068	4	56	7,405.0	0	0	0.0	0	0
20 - 25	16.9	4	123	-115,085	3	39	9,256.3	0	0	0.0	0	0
25 - 30	20.3	4	124	-138,101	5	69	11,107.5	0	0	0.0	0	0
30 - 35	23.7	3	80	-161,118	8	114	12,958.8	0	0	0.0	0	0
35 - 40	27.0	7	212	-184,135	6	81	14,810.1	0	0	0.0	0	0
40 - 45	30.4	6	164	-207,152	8	109	16,661.3	0	0	0.0	0	0
45 - 50	33.8	5	156	-230,169	6	86	18,512.6	0	0	0.0	0	0
50 - 55	37.2	3	82	-253,186	10	137	20,363.8	0	0	0.0	0	0
55 - 60	40.6	6	174	-276,203	6	77	22,215.1	0	0	0.0	0	0
60 - 65	43.9	6	193	-299,220	5	69	24,066.3	0	0	0.0	0	0
65 - 70	47.3	2	62	-322,237	17	231	25,917.6	0	0	0.0	0	0
70 - 75	50.7	1	23	-345,254	0	0	27,768.9	0	0	0.0	0	0
75 - 80	54.1	2	64	-368,271	0	0	29,620.1	0	0	0.0	0	0
80 - 85	57.5	4	108	-391,288	0	0	31,471.4	0	0	0.0	0	0
85 - 90	60.8	0	0	-414,304	0	0	33,322.6	0	0	0.0	0	0
90 - 95	64.2	0	0	-437,321	0	0	35,173.9	0	0	0.0	0	0
95 - 100	67.6	0	0	-460,338	0	0	37,025.1	100	8,760	0.0	0	0
Hours Off	0.0	0	5,790	0	0	7,388	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M171, BASELINE

January			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-212,678	0.0	0	0.0	-291,604	0.0	-291,604	0.0	-291,604	0.0
2	32.1	29.3	-222,936	0.0	0	0.0	-308,798	0.0	-308,798	0.0	-308,798	0.0
3	31.7	29.3	-232,349	0.0	0	0.0	-316,940	0.0	-316,940	0.0	-316,940	0.0
4	31.9	29.5	-239,709	0.0	-157,672	0.0	-318,500	0.0	-318,500	0.0	-318,500	0.0
5	32.6	30.3	-245,795	0.0	-316,773	0.0	-316,739	0.0	-316,739	0.0	-316,739	0.0
6	33.6	31.3	-245,306	0.0	-314,910	0.0	-314,910	0.0	-314,910	0.0	-314,910	0.0
7	35.0	32.6	-239,085	0.0	-304,941	0.0	-304,941	0.0	-304,941	0.0	-304,941	0.0
8	36.6	34.4	0	0.0	-56,485	0.0	-235,833	0.0	-235,833	0.0	-56,485	0.0
9	38.5	36.3	0	0.0	0	0.0	-187,253	0.0	-187,253	0.0	0	0.0
10	40.4	37.7	0	0.0	0	0.0	-145,371	0.0	-145,371	0.0	0	0.0
11	42.3	38.7	0	0.0	0	0.0	-133,276	0.0	-133,276	0.0	0	0.0
12	44.2	39.6	0	0.0	0	0.0	-118,360	0.0	-118,360	0.0	0	0.0
13	45.8	40.5	0	0.0	0	0.0	-88,828	0.0	-88,828	0.0	0	0.0
14	47.2	41.1	0	0.0	0	0.0	-69,486	0.0	-69,486	0.0	0	0.0
15	48.2	41.6	0	0.0	0	0.0	-46,803	0.0	-46,803	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	-34,653	0.0	-34,653	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	-116,658	0.0	-116,658	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	-142,559	0.0	-142,559	0.0	0	0.0
19	47.4	41.7	0	0.0	0	0.0	-156,922	0.0	-156,922	0.0	0	0.0
20	45.5	40.5	0	0.0	0	0.0	-173,827	0.0	-173,827	0.0	0	0.0
21	43.1	38.9	0	0.0	0	0.0	-200,924	0.0	-200,924	0.0	0	0.0
22	40.4	36.7	0	0.0	0	0.0	-228,089	0.0	-228,089	0.0	0	0.0
23	37.7	34.3	-65,534	0.0	-187,785	0.0	-251,215	0.0	-251,215	0.0	-187,785	0.0
24	35.3	32.3	-3,491	0.0	-277,120	0.0	-277,107	0.0	-277,107	0.0	-277,120	0.0

February			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	-211,049	0.0	0	0.0	-264,954	0.0	-264,954	0.0	-264,954	0.0
2	36.0	33.0	-222,089	0.0	0	0.0	-277,756	0.0	-277,756	0.0	-277,756	0.0
3	34.7	31.8	-231,078	0.0	0	0.0	-288,503	0.0	-288,503	0.0	-288,503	0.0
4	33.6	30.9	-238,014	0.0	-55,664	0.0	-303,648	0.0	-303,648	0.0	-303,648	0.0
5	32.8	30.1	-240,064	0.0	-313,534	0.0	-313,484	0.0	-313,484	0.0	-313,484	0.0
6	32.2	29.8	-239,998	0.0	-317,229	0.0	-317,229	0.0	-317,229	0.0	-317,229	0.0
7	32.1	29.6	-229,654	0.0	-314,732	0.0	-314,732	0.0	-314,732	0.0	-314,732	0.0
8	32.5	30.3	0	0.0	-54,024	0.0	-233,372	0.0	-233,372	0.0	-54,024	0.0
9	33.9	31.6	0	0.0	0	0.0	-222,867	0.0	-222,867	0.0	0	0.0
10	36.0	33.0	0	0.0	0	0.0	-203,509	0.0	-203,509	0.0	0	0.0
11	38.5	34.8	0	0.0	0	0.0	-185,598	0.0	-185,598	0.0	0	0.0
12	41.3	36.5	0	0.0	0	0.0	-145,121	0.0	-145,121	0.0	0	0.0
13	43.8	38.1	0	0.0	0	0.0	-109,435	0.0	-109,435	0.0	0	0.0
14	45.9	39.5	0	0.0	0	0.0	-86,801	0.0	-86,801	0.0	0	0.0
15	47.2	40.4	0	0.0	0	0.0	-38,030	0.0	-38,030	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	-37,072	0.0	-37,072	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	-78,522	0.0	-78,522	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	-157,838	0.0	-157,838	0.0	0	0.0
19	46.2	39.9	0	0.0	0	0.0	-164,838	0.0	-164,838	0.0	0	0.0
20	45.1	39.7	0	0.0	0	0.0	-179,558	0.0	-179,558	0.0	0	0.0
21	43.8	39.2	0	0.0	0	0.0	-197,958	0.0	-197,958	0.0	0	0.0
22	42.3	38.3	0	0.0	-59,344	0.0	-211,963	0.0	-211,963	0.0	-59,344	0.0
23	40.7	37.2	0	0.0	-229,259	0.0	-229,225	0.0	-229,225	0.0	-229,259	0.0
24	39.1	35.8	0	0.0	-247,691	0.0	-247,691	0.0	-247,691	0.0	-247,691	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M171, BASELINE

March			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6	-123,335	0.0	0	0.0	0	0.0	-180,695	0.0	-180,695	0.0
2	43.3	39.7	-135,221	0.0	0	0.0	0	0.0	-201,281	0.0	-201,281	0.0
3	41.6	38.6	-145,058	0.0	0	0.0	0	0.0	-218,968	0.0	-218,968	0.0
4	40.6	37.5	-154,468	0.0	0	0.0	0	0.0	-230,852	0.0	-230,852	0.0
5	40.2	37.3	-161,762	0.0	-60,331	0.0	0	0.0	-238,993	0.0	-238,993	0.0
6	40.6	37.8	-161,273	0.0	-2,922	0.0	0	0.0	-239,709	0.0	-239,709	0.0
7	41.6	39.0	-58,627	0.0	0	0.0	-14,641	0.0	-170,063	0.0	-170,063	0.0
8	43.3	40.7	0	0.0	0	0.0	-148,898	0.0	-148,864	0.0	0	0.0
9	45.4	42.5	0	0.0	0	0.0	-124,943	0.0	-124,943	0.0	0	0.0
10	47.9	44.3	0	0.0	0	0.0	-103,207	0.0	-103,207	0.0	0	0.0
11	50.6	45.5	0	0.0	0	0.0	-44,683	0.0	-44,683	0.0	0	0.0
12	53.3	46.8	0	0.0	0	0.0	-5,866	0.0	-5,866	0.0	0	0.0
13	55.8	48.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	58.0	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	59.6	50.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	60.7	50.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	61.0	50.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	60.7	50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	59.6	50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	58.0	50.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	55.8	49.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	53.3	47.8	0	0.0	0	0.0	-29,514	0.0	-29,514	0.0	0	0.0
23	50.6	45.9	0	0.0	0	0.0	-131,269	0.0	-131,269	0.0	0	0.0
24	47.9	43.8	0	0.0	0	0.0	-158,416	0.0	-158,416	0.0	0	0.0

April			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2	51.3	0	0.0	0	0.0	0	0.0	0	0.0	-4,387	0.0
4	52.9	50.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	51.2	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.0	49.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	51.6	49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	53.3	50.6	0	0.0	0	0.0	0	0.0	-17,382	0.0	0	0.0
10	55.9	51.8	0	0.0	0	0.0	0	0.0	-22,785	0.0	0	0.0
11	59.0	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	62.4	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5	57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8	60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2	60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2	59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M171, BASELINE

May Hour	Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	63.1	0	0.0	0	0.0	0	0.0
2	64.5	60.4	0	55.3	0	0.0	0	0.0	0	0.0
3	62.7	59.1	0	10.7	0	0.0	0	0.0	0	0.0
4	61.2	58.1	0	0.0	0	0.0	0	0.0	0	0.0
5	60.0	57.1	0	0.0	0	0.0	0	0.0	0	0.0
6	59.3	56.6	0	3.9	0	0.0	0	0.0	0	0.0
7	59.0	56.5	0	11.3	0	0.0	0	0.0	0	0.0
8	59.5	56.6	0	27.6	0	0.0	0	0.0	0	0.0
9	60.9	56.6	0	33.9	0	9.7	0	0.0	0	9.7
10	63.0	57.2	0	37.2	0	24.5	0	0.0	0	24.5
11	65.7	58.1	0	39.5	0	26.0	0	0.0	0	26.0
12	68.7	59.8	0	41.5	0	27.9	0	0.0	0	27.9
13	71.7	61.6	0	41.1	0	27.1	0	9.1	0	27.1
14	74.5	63.4	0	51.9	0	35.8	0	16.4	0	35.8
15	76.6	64.8	0	55.4	0	40.0	0	19.3	0	40.2
16	78.0	65.6	0	55.2	0	38.8	0	17.8	0	38.8
17	78.5	65.6	0	46.5	0	33.4	0	17.7	0	33.4
18	78.2	65.8	0	31.9	0	21.7	0	14.5	0	21.7
19	77.5	65.6	0	13.6	0	8.4	0	8.4	0	8.4
20	76.3	66.1	0	11.2	0	7.2	0	7.2	0	7.2
21	74.8	67.2	0	8.5	0	5.4	0	5.4	0	5.4
22	73.0	66.4	0	6.4	0	4.1	0	3.9	0	4.1
23	70.9	65.4	0	4.6	0	1.8	0	1.8	0	1.8
24	68.7	64.0	0	3.0	0	0.0	0	0.0	0	0.0

June Hour	Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	8.6	0	3.7	0	4.4	0	4.4
2	71.2	66.1	0	7.6	0	2.1	0	2.3	0	2.3
3	69.7	65.2	0	6.3	0	0.6	0	0.9	0	0.9
4	68.5	64.3	0	6.1	0	0.0	0	0.0	0	0.0
5	67.8	64.2	0	5.5	0	0.0	0	0.0	0	0.0
6	67.6	64.2	0	14.2	0	2.5	0	2.5	0	2.5
7	68.1	64.8	0	18.9	0	6.0	0	6.1	0	6.1
8	69.4	65.7	0	36.9	0	23.9	0	6.9	0	6.9
9	71.6	66.2	0	45.3	0	33.0	0	8.7	0	8.7
10	74.2	67.2	0	47.8	0	39.4	0	14.3	0	14.3
11	77.2	68.5	0	51.6	0	40.4	0	16.4	0	16.4
12	80.2	70.0	0	53.7	0	43.1	0	19.3	0	19.3
13	82.8	70.8	0	51.1	0	40.7	0	23.7	0	23.7
14	85.0	71.6	0	64.1	0	53.7	0	29.4	0	29.4
15	86.3	72.3	0	66.2	0	56.9	0	32.9	0	32.9
16	86.8	72.1	0	65.6	0	53.0	0	29.1	0	29.1
17	86.6	71.7	0	56.6	0	44.1	0	26.5	0	26.5
18	85.8	71.5	0	40.6	0	30.7	0	23.4	0	23.4
19	84.7	71.2	0	20.8	0	15.0	0	15.2	0	15.2
20	83.2	71.5	0	18.0	0	13.3	0	13.4	0	13.4
21	81.4	71.7	0	15.6	0	11.6	0	12.2	0	12.2
22	79.3	71.4	0	13.1	0	10.2	0	10.3	0	10.3
23	77.2	70.5	0	11.2	0	8.3	0	8.4	0	8.4
24	75.1	69.1	0	9.6	0	6.2	0	6.3	0	6.3

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M171, BASELINE

July Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0	69.3	0	8.2	0	2.6	0	3.5	0	3.5	0	3.5
2	70.5	68.0	0	7.2	0	1.6	0	2.0	0	2.0	0	2.0
3	69.4	67.1	0	6.6	0	0.0	0	0.0	0	0.0	0	0.0
4	68.5	66.4	0	6.1	0	0.0	0	0.0	0	0.0	0	0.0
5	67.9	66.0	0	6.0	0	0.0	0	0.0	0	0.0	0	0.0
6	67.7	65.9	0	11.7	0	0.0	0	0.0	0	0.0	0	0.0
7	68.1	66.3	0	17.6	0	5.8	0	6.3	0	6.3	0	6.3
8	69.1	67.3	0	40.5	0	27.4	0	7.7	0	7.7	0	28.0
9	70.8	68.0	0	45.5	0	34.6	0	9.3	0	9.3	0	34.6
10	72.9	69.1	0	49.1	0	39.9	0	15.1	0	15.1	0	39.9
11	75.2	70.5	0	51.2	0	41.3	0	16.8	0	16.8	0	41.3
12	77.5	71.7	0	53.8	0	43.3	0	19.4	0	19.4	0	43.3
13	79.6	72.7	0	51.3	0	40.2	0	23.4	0	23.4	0	40.2
14	81.3	73.5	0	63.9	0	54.4	0	28.9	0	28.9	0	54.4
15	82.3	73.7	0	65.8	0	55.9	0	31.4	0	31.4	0	55.9
16	82.7	73.5	0	65.1	0	53.4	0	29.1	0	29.1	0	53.4
17	82.5	73.1	0	55.0	0	43.8	0	25.8	0	25.8	0	43.8
18	82.0	72.6	0	37.9	0	29.0	0	22.3	0	22.3	0	29.0
19	81.1	73.2	0	18.3	0	12.3	0	13.6	0	13.6	0	12.3
20	79.9	73.8	0	16.1	0	12.9	0	13.5	0	13.5	0	12.9
21	78.5	73.9	0	14.0	0	12.5	0	12.7	0	12.7	0	12.5
22	76.9	73.1	0	12.0	0	10.5	0	10.6	0	10.6	0	10.5
23	75.2	71.9	0	10.3	0	8.2	0	8.2	0	8.2	0	8.2
24	73.5	70.8	0	8.9	0	5.8	0	5.8	0	5.8	0	5.8

August Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7	70.2	0	9.3	0	3.2	0	4.4	0	4.4	0	4.4
2	71.2	69.0	0	7.5	0	2.0	0	2.4	0	2.4	0	2.4
3	69.9	68.0	0	6.4	0	0.9	0	1.1	0	1.1	0	1.1
4	68.8	67.1	0	5.9	0	0.0	0	0.0	0	0.0	0	0.0
5	68.0	66.6	0	5.8	0	0.0	0	0.0	0	0.0	0	0.0
6	67.5	66.2	0	7.4	0	0.0	0	0.0	0	0.0	0	0.0
7	67.3	66.1	0	15.8	0	3.2	0	3.3	0	3.3	0	3.3
8	67.8	66.5	0	40.0	0	26.6	0	6.7	0	6.7	0	27.0
9	69.1	67.0	0	46.5	0	32.3	0	7.7	0	7.7	0	32.2
10	71.2	67.8	0	49.5	0	37.3	0	12.8	0	12.8	0	37.3
11	73.8	68.7	0	52.0	0	39.1	0	14.7	0	14.7	0	39.1
12	76.5	70.0	0	53.6	0	41.6	0	17.7	0	17.7	0	41.6
13	79.1	71.2	0	50.9	0	40.7	0	23.5	0	23.5	0	40.7
14	81.1	72.6	0	65.3	0	54.3	0	29.3	0	29.3	0	54.3
15	82.5	73.6	0	66.7	0	56.1	0	32.2	0	32.2	0	56.1
16	83.0	73.7	0	64.6	0	49.9	0	25.5	0	25.5	0	49.9
17	82.8	73.5	0	54.2	0	42.6	0	24.2	0	24.2	0	42.6
18	82.3	73.5	0	33.2	0	25.3	0	19.0	0	19.0	0	25.3
19	81.5	73.1	0	18.2	0	12.6	0	14.1	0	14.1	0	12.6
20	80.4	73.7	0	15.8	0	12.8	0	13.2	0	13.2	0	12.8
21	79.1	74.9	0	13.8	0	12.5	0	12.6	0	12.6	0	12.5
22	77.6	73.9	0	11.4	0	11.2	0	11.2	0	11.2	0	11.2
23	76.0	72.7	0	10.2	0	8.7	0	8.8	0	8.8	0	8.7
24	74.3	71.3	0	8.7	0	6.1	0	6.1	0	6.1	0	6.1

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M171, BASELINE

September			----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	69.8	66.1		0		5.3		0		0.6		0		0.9		0		0.9		0		0.9
2	68.0	64.5		0		4.3		0		0.0		0		0.0		0		0.0		0		0.0
3	66.3	63.0		0		2.8		0		0.0		0		0.0		0		0.0		0		0.0
4	64.9	61.9		0		2.1		0		0.0		0		0.0		0		0.0		0		0.0
5	63.9	61.3		0		1.6		0		0.0		0		0.0		0		0.0		0		0.0
6	63.2	61.0		0		1.6		0		0.0		0		0.0		0		0.0		0		0.0
7	63.0	60.8		0		11.3		0		0.0		0		0.0		0		0.0		0		0.0
8	63.4	61.4		0		31.7		0		2.6		0		0.0		0		0.0		0		2.6
9	64.7	61.8		0		41.7		0		24.8		0		0.0		0		0.0		0		26.8
10	66.6	62.1		0		44.3		0		26.5		0		0.0		0		0.0		0		26.8
11	69.1	62.9		0		47.3		0		33.2		0		9.4		0		9.4		0		33.3
12	71.8	63.7		0		49.1		0		34.3		0		13.4		0		13.4		0		34.3
13	74.5	65.5		0		47.9		0		33.6		0		17.7		0		17.7		0		33.6
14	77.0	67.1		0		59.6		0		45.8		0		21.7		0		21.7		0		45.8
15	78.9	68.2		0		61.1		0		44.2		0		20.7		0		20.7		0		44.2
16	80.2	68.6		0		57.9		0		43.1		0		19.5		0		19.5		0		43.1
17	80.6	68.5		0		44.3		0		33.9		0		16.7		0		16.7		0		33.9
18	80.4	68.9		0		24.5		0		17.8		0		10.7		0		10.7		0		17.8
19	79.7	70.0		0		15.1		0		9.7		0		9.8		0		9.8		0		9.7
20	78.7	71.2		0		12.8		0		8.6		0		8.6		0		8.6		0		8.6
21	77.3	71.6		0		10.3		0		7.6		0		7.8		0		7.8		0		7.6
22	75.6	70.5		0		8.4		0		6.6		0		6.6		0		6.6		0		6.6
23	73.7	69.4		0		6.9		0		4.8		0		4.9		0		4.9		0		4.8
24	71.8	67.7		0		5.4		0		2.9		0		2.9		0		2.9		0		2.9
October			----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	54.8	51.3		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
2	52.9	49.6		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
3	51.2	48.2		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
4	49.8	47.2		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
5	48.8	46.2		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
6	48.2	45.7		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
7	47.9	45.6		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
8	48.5	46.2		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
9	50.3	47.3		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
10	52.9	48.7		0		25.6		0		0.0		0		0.0		0		0.0		0		0.0
11	56.2	49.9		0		32.0		0		0.0		0		0.0		0		0.0		0		0.0
12	59.6	51.5		0		34.3		0		0.0		0		0.0		0		0.0		0		0.0
13	62.9	53.5		0		34.5		0		0.0		0		0.0		0		0.0		0		0.0
14	65.5	55.2		0		43.0		0		25.1		0		0.0		0		0.0		0		0.0
15	67.3	56.3		0		45.2		0		28.9		0		0.0		0		0.0		0		0.0
16	67.9	56.6		0		42.1		0		27.9		0		0.0		0		0.0		0		8.5
17	67.7	56.4		0		26.3		0		17.5		0		0.0		0		0.0		0		17.5
18	67.0	56.6		0		13.3		0		6.5		0		0.0		0		0.0		0		6.5
19	66.0	57.6		0		3.6		0		0.0		0		0.0		0		0.0		0		0.0
20	64.6	57.9		0		1.0		0		0.0		0		0.0		0		0.0		0		0.0
21	62.9	57.3		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
22	61.0	56.0		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
23	59.0	54.8		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0
24	56.9	53.0		0		0.0		0		0.0		0		0.0		0		0.0		0		0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M171, BASELINE

November			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	Htg Btuh	Clg Ton		
1	48.7	45.7	0	0.0		0	0.0		0	0.0		0	0.0	-153,397	0.0		
2	46.9	44.1	0	0.0		0	0.0		0	0.0		-156,804	0.0	-171,508	0.0		
3	45.5	42.8	0	0.0		0	0.0		0	0.0		-183,889	0.0	-183,887	0.0		
4	44.6	41.9	0	0.0		0	0.0		-49,076	0.0		-194,144	0.0	-194,144	0.0		
5	44.4	42.0	0	0.0		0	0.0		-2,469	0.0		-201,439	0.0	-201,439	0.0		
6	44.8	42.7	0	0.0		0	0.0		0	0.0		-200,946	0.0	-200,946	0.0		
7	45.9	43.9	0	0.0		0	0.0		0	0.0		-182,979	0.0	-182,979	0.0		
8	47.8	46.0	0	0.0		-49,701	0.0		0	0.0		-91,258	0.0	0	0.0		
9	50.2	48.0	0	0.0		0	0.0		0	0.0		-53,364	0.0	0	0.0		
10	52.9	49.9	0	0.0		0	0.0		0	0.0		-32,275	0.0	0	0.0		
11	55.8	51.1	0	0.0		0	0.0		0	0.0		-11,099	0.0	0	0.0		
12	58.5	52.0	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
13	60.9	52.5	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
14	62.8	53.4	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
15	64.0	53.8	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
16	64.4	53.9	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
17	64.1	53.7	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
18	63.2	53.7	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
19	61.8	54.2	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
20	60.0	53.6	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
21	57.9	52.7	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
22	55.6	51.2	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
23	53.2	49.5	0	0.0		0	0.0		0	0.0		-18,151	0.0	0	0.0		
24	50.8	47.6	0	0.0		0	0.0		0	0.0		-128,798	0.0	0	0.0		

December			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	Htg Btuh	Clg Ton		
1	37.5	35.3	0	0.0		0	0.0		-115,580	0.0		-259,712	0.0	-259,712	0.0		
2	37.1	35.1	0	0.0		0	0.0		-267,885	0.0		-267,854	0.0	-267,854	0.0		
3	37.4	35.5	0	0.0		0	0.0		-268,990	0.0		-268,990	0.0	-268,990	0.0		
4	38.1	36.2	0	0.0		0	0.0		-267,229	0.0		-267,229	0.0	-267,229	0.0		
5	39.3	37.6	0	0.0		0	0.0		-259,311	0.0		-259,311	0.0	-259,311	0.0		
6	40.9	39.2	0	0.0		-36,563	0.0		-248,495	0.0		-248,495	0.0	-248,495	0.0		
7	42.7	41.2	-32,479	0.0		-236,879	0.0		-236,832	0.0		-236,832	0.0	-236,832	0.0		
8	44.7	43.1	0	0.0		0	0.0		-152,850	0.0		-152,850	0.0	0	0.0		
9	46.8	45.3	0	0.0		0	0.0		-98,268	0.0		-98,268	0.0	0	0.0		
10	48.8	47.0	0	0.0		0	0.0		-71,701	0.0		-71,701	0.0	0	0.0		
11	50.7	48.1	0	0.0		0	0.0		-58,440	0.0		-58,440	0.0	0	0.0		
12	52.2	48.8	0	0.0		0	0.0		-42,893	0.0		-42,893	0.0	0	0.0		
13	53.4	49.2	0	0.0		0	0.0		-11,492	0.0		-11,492	0.0	0	0.0		
14	54.1	49.2	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
15	54.4	48.9	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
16	54.0	48.2	0	0.0		0	0.0		0	0.0		0	0.0	0	0.0		
17	53.0	47.3	0	0.0		0	0.0		-54,139	0.0		-54,139	0.0	0	0.0		
18	51.4	46.3	0	0.0		0	0.0		-110,165	0.0		-110,165	0.0	0	0.0		
19	49.3	45.4	0	0.0		0	0.0		-133,149	0.0		-133,149	0.0	0	0.0		
20	47.0	43.5	0	0.0		0	0.0		-155,785	0.0		-155,785	0.0	0	0.0		
21	44.5	41.5	0	0.0		0	0.0		-183,305	0.0		-183,305	0.0	0	0.0		
22	42.2	39.3	0	0.0		0	0.0		-208,773	0.0		-208,773	0.0	0	0.0		
23	40.1	37.6	0	0.0		0	0.0		-229,360	0.0		-229,360	0.0	0	0.0		
24	38.5	36.2	0	0.0		0	0.0		-247,825	0.0		-247,825	0.0	0	0.0		

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M171, BASELINE

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	WATER	GAS DMND
	On Peak (kwh)	On Peak (kW)	On Peak (Therm)	(1000 G1)	On Peak (Thrm/hr)
Jan	28,553	77	1,033	1	4
Feb	26,010	77	922	1	4
March	26,566	77	228	0	3
April	22,896	77	2	0	0
May	35,631	146	0	0	0
June	44,205	166	0	0	0
July	42,456	161	0	0	0
Aug	44,419	161	0	0	0
Sept	35,958	153	0	0	0
Oct	27,021	128	0	0	0
Nov	24,357	77	195	0	2
Dec	26,588	77	583	1	3
Total	384,662	166	2,964	3	4

Building Energy Consumption = 45,461 (Btu/Sq Ft/Year)
 Source Energy Consumption = 120,090 (Btu/Sq Ft/Year)

Floor Area = 35,398 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M171, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 165.6 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	88.9	53.71
Sub Total			88.9	53.71
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	11.7	7.07
Sub Total			11.7	7.07
Sub Total			0.0	0.00
Miscellaneous				
	Lights		33.8	20.43
	Base Utilities		0.0	0.00
	Misc Equipment		31.1	18.79
Sub Total			64.9	39.22
Grand Total			165.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M171, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 35,398
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kwh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,574.4	296,389.4	3.2	18.8	328,111.0	9.5
Primary Cooling						
Compressor	57,296.7	0.0	0.0	12.2	586,719.9	17.0
Tower/Cond Fans	7,022.2	0.0	0.0	1.5	71,908.0	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	863.7	0.0	0.0	0.2	8,844.3	0.3
Auxiliary						
Supply Fans	102,491.4	0.0	0.0	21.7	1,049,514.6	30.4
Circulation Pumps	35,600.9	0.0	0.0	7.6	364,554.0	10.6
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	138,092.3	0.0	0.0	29.3	1,414,068.8	40.9
Lighting	93,655.9	0.0	0.0	19.9	959,038.3	27.1
Receptacle	86,156.3	0.0	0.0	18.3	882,242.7	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	384,661.6	296,389.4	3.2	100.0	4,250,933.0	121.8

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M171, ECO#7

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	WATER	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	(1000 Gl)	On Peak (Thrm/hr)
Jan	18,779	89	189	0	6
Feb	16,748	89	144	0	6
March	19,557	77	41	0	5
April	17,159	77	0	0	0
May	27,962	147	0	0	0
June	33,037	165	0	0	0
July	29,976	160	0	0	0
Aug	33,297	161	0	0	0
Sept	26,781	153	0	0	0
Oct	22,494	128	0	0	0
Nov	17,208	77	13	0	3
Dec	17,625	89	83	0	6
Total	280,624	165	469	0	6

Building Energy Consumption = 28,384 (Btu/Sq Ft/Year)
 Source Energy Consumption = 82,576 (Btu/Sq Ft/Year)

Floor Area = 35,398 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M171, ECO#7

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 164.6 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	88.0	53.45
Sub Total			88.0	53.45
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	11.7	7.11
Sub Total			11.7	7.11
Sub Total			0.0	0.00
Miscellaneous				
	Lights		33.8	20.55
	Base Utilities		0.0	0.00
	Misc Equipment		31.1	18.90
Sub Total			64.9	39.45
Grand Total			164.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M171, ECO#7

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 35,398
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	185.2	46,949.3	0.4	4.7	51,316.9	1.5
Primary Cooling						
Compressor	47,041.2	0.0	0.0	16.0	481,702.6	13.9
Tower/Cond Fans	5,717.4	0.0	0.0	1.9	58,546.4	1.7
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	428.4	0.0	0.0	0.1	4,386.8	0.1
Auxiliary						
Supply Fans	35,380.5	0.0	0.0	12.0	362,297.0	10.5
Circulation Pumps	12,059.4	0.0	0.0	4.1	123,488.5	3.6
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	47,439.9	0.0	0.0	16.1	485,785.6	14.1
Lighting	93,655.9	0.0	0.0	31.8	959,038.3	27.1
Receptacle	86,156.3	0.0	0.0	29.3	882,242.7	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	280,624.2	46,949.3	0.4	100.0	2,923,019.2	83.3

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M171, ECO#12

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	WATER (1000 Gl)	GAS DMND On Peak (Thrm/hr)
Jan	18,317	89	148	0	6
Feb	16,516	89	116	0	6
March	19,509	77	18	0	4
April	17,159	77	0	0	0
May	20,389	108	0	0	0
June	24,850	143	0	0	0
July	21,896	135	3	0	0
Aug	24,320	135	0	0	0
Sept	19,446	132	0	0	0
Oct	18,719	115	0	0	0
Nov	17,159	77	0	0	0
Dec	17,382	89	59	0	6
Total	235,663	143	343	0	6

Building Energy Consumption = 23,692 (Btu/Sq Ft/Year) Floor Area = 35,398 (Sq Ft)
 Source Energy Consumption = 69,194 (Btu/Sq Ft/Year)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M171, ECO#12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 142.9 (kW)
Yearly Time of Peak 16 (hr) 6 (mo)

Hour 16 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	66.3	46.38
Sub Total			66.3	46.38
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	11.7	8.19
Sub Total			11.7	8.19
Sub Total			0.0	0.00
Miscellaneous				
	Lights		33.8	23.66
	Base Utilities		0.0	0.00
	Misc Equipment		31.1	21.77
Sub Total			64.9	45.43
Grand Total			142.9	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M171, ECO#12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 35,398
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	96.4	34,321.8	0.2	4.1	37,115.7	1.1
Primary Cooling						
Compressor	13,143.2	0.0	0.0	5.3	134,586.7	3.9
Tower/Cond Fans	1,616.6	0.0	0.0	0.7	16,554.4	0.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	187.2	0.0	0.0	0.1	1,916.9	0.1
Auxiliary						
Supply Fans	35,380.5	0.0	0.0	14.4	362,297.0	10.5
Circulation Pumps	5,427.2	0.0	0.0	2.2	55,574.7	1.6
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	40,807.7	0.0	0.0	16.6	417,871.7	12.1
Lighting	93,655.9	0.0	0.0	38.1	959,038.3	27.1
Receptacle	86,156.3	0.0	0.0	35.1	882,242.7	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	235,663.3	34,321.8	0.2	100.0	2,449,326.5	69.6

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M171, ECO#13

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	WATER (1000 Gl)	GAS DMND On Peak (Thrm/hr)
Jan	30,047	83	1,033	1	4
Feb	27,383	77	922	1	4
March	28,086	77	228	0	3
April	24,367	77	2	0	0
May	37,627	128	0	0	0
June	45,231	147	0	0	0
July	43,657	144	0	0	0
Aug	45,861	144	0	0	0
Sept	37,923	138	0	0	0
Oct	30,088	117	0	0	0
Nov	25,828	77	195	0	2
Dec	28,108	77	583	1	3
Total	404,206	147	2,964	3	4

Building Energy Consumption = 47,346 (Btu/Sq Ft/Year)
 Source Energy Consumption = 125,743 (Btu/Sq Ft/Year)

Floor Area = 35,398 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M171, ECO#13

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	----- Monthly Consumption -----												Total
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	
0	LIGHTS													
	ELEC	7828	7081	8454	7475	8141	8101	7515	8454	7475	8141	7475	7515	93,656
	PK	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8	33.8
1	MISC LD													
	ELEC	7201	6514	7777	6876	7489	7452	6914	7777	6876	7489	6876	6914	86,156
	PK	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1
2	MISC LD													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	MISC LD													
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD													
	P HOTH2O	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ1122L													
	ELEC	0	0	0	0	3907	8419	8021	7998	4767	495	0	0	33,608
	PK	0.0	0.0	0.0	0.0	50.4	60.6	56.1	55.5	47.4	28.9	0.0	0.0	60.6
1	EQ5200													
	ELEC	0	0	0	0	435	1031	995	971	543	46	0	0	4,022
	PK	0.0	0.0	0.0	0.0	6.1	8.7	6.7	6.6	5.9	3.6	0.0	0.0	8.7
1	EQ5001													
	ELEC	0	0	0	0	2226	3723	3621	3621	2628	321	0	0	16,140
	PK	0.0	0.0	0.0	0.0	7.3	7.3	7.3	7.3	7.3	7.3	0.0	0.0	7.3
1	EQ5313													
	ELEC	0	0	0	0	91	153	149	149	108	13	0	0	663
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3
2	EQ1750													
	ELEC	1360	1252	1386	1341	6315	7603	7408	7850	6779	4645	1341	1386	48,666
	PK	20.5	20.5	20.5	20.5	50.5	52.4	52.1	52.0	50.5	50.5	27.0	20.5	52.4

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M171, ECO#13

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 146.7 (kW)
 Yearly Time of Peak 12 (hr) 6 (mo)

Hour 12 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	70.1	47.76
Sub Total			70.1	47.76
Sub Total			0.0	0.00
Air Moving Equipment				
1	SUMMATION OF FAN ELECTRICAL DEMAND		11.7	7.97
Sub Total			11.7	7.97
Sub Total			0.0	0.00
Miscellaneous				
Lights			33.8	23.05
Base Utilities			0.0	0.00
Misc Equipment			31.1	21.21
Sub Total			64.9	44.26
Grand Total			146.7	100.00

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

January

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	42.7	35.4	0.0	0.0	
2	41.8	34.7	0.0	4.9	8.1	247
3	41.1	34.4	0.0	0.0	0.0	245
4	40.6	34.0	0.0	4.9	8.1	247
5	40.4	34.0	0.0	0.0	0.0	245
6	40.8	34.4	0.0	4.9	8.1	247
7	41.6	35.0	0.0	0.0	0.0	245
8	43.2	36.5	0.0	4.9	8.1	247
9	45.5	38.5	0.0	0.0	0.0	247
10	48.1	40.4	0.0	0.0	0.0	247
11	51.0	42.2	0.0	0.0	0.0	247
12	53.8	43.8	0.0	0.0	0.0	247
13	55.9	45.0	0.0	0.0	0.0	245
14	57.3	45.5	0.0	0.0	0.0	243
15	57.8	45.6	0.0	0.0	0.0	240
16	57.3	44.8	0.0	0.0	0.0	238
17	56.1	43.9	0.0	0.0	0.0	238
18	54.2	42.7	0.0	0.0	0.0	238
19	51.9	41.6	0.0	0.0	0.0	238
20	49.6	40.2	0.0	0.0	0.0	238
21	47.7	39.1	0.0	0.0	0.0	238
22	46.0	37.9	0.0	0.0	0.0	238
23	44.6	36.8	0.0	0.0	0.0	238
24	43.6	36.1	0.0	0.0	0.0	238

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	33.4	30.4	0.0	12.1	19.0	247	0.0	14.5	20.5	247
2	32.1	29.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	31.7	29.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	31.9	29.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	32.6	30.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	33.6	31.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	35.0	32.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	36.6	34.4	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	38.5	36.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	40.4	37.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	42.3	38.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	44.2	39.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	45.8	40.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	47.2	41.1	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	48.2	41.6	0.0	0.0	0.0	238	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		Weekday			Saturday				
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	48.9	41.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	49.1	41.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	48.7	41.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	47.4	41.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	45.5	40.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	43.1	38.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	40.4	36.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	37.7	34.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	35.3	32.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235

Hour	Typical		Sunday			Monday				
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	33.4	30.4	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	32.1	29.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	31.7	29.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	31.9	29.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	32.6	30.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	33.6	31.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	35.0	32.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	36.6	34.4	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	38.5	36.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	40.4	37.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	42.3	38.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	44.2	39.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	45.8	40.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	47.2	41.1	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	48.2	41.6	0.0	0.0	0.0	238	0.0	0.0	0.0	238
16	48.9	41.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	49.1	41.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	48.7	41.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	47.4	41.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	45.5	40.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	43.1	38.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	40.4	36.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	37.7	34.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	35.3	32.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

--- B U I L D I N G C O O L I N G D E M A N D S A N D T H E R M A L S T O R A G E ---

February

Hour	----- Design -----					
	Design		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)				
1	42.8	35.6	0.0	14.5	20.5	247
2	42.0	34.9	0.0	0.0	0.0	245
3	41.4	34.5	0.0	4.9	8.1	247
4	41.0	34.2	0.0	0.0	0.0	245
5	40.8	34.0	0.0	4.9	8.1	247
6	41.1	34.4	0.0	0.0	0.0	245
7	41.9	35.0	0.0	4.9	8.1	247
8	43.3	36.5	0.0	0.0	0.0	245
9	45.3	38.2	0.0	0.0	0.0	245
10	47.7	39.5	0.0	0.0	0.0	245
11	50.3	41.3	0.0	0.0	0.0	245
12	52.8	42.5	0.0	0.0	0.0	245
13	54.7	43.4	0.0	0.0	0.0	243
14	55.9	44.0	0.0	0.0	0.0	240
15	56.4	44.2	0.0	0.0	0.0	238
16	55.9	43.6	0.0	0.0	0.0	235
17	54.8	42.6	0.0	0.0	0.0	235
18	53.1	41.4	0.0	0.0	0.0	235
19	51.1	40.4	0.0	0.0	0.0	235
20	49.1	39.4	0.0	0.0	0.0	235
21	47.4	38.5	0.0	0.0	0.0	235
22	45.8	37.6	0.0	0.0	0.0	235
23	44.5	36.9	0.0	0.0	0.0	235
24	43.6	36.1	0.0	0.0	0.0	235

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	37.5	34.5	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	36.0	33.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	34.7	31.8	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	33.6	30.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	32.8	30.1	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	32.2	29.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	32.1	29.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	32.5	30.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	33.9	31.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	36.0	33.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	38.5	34.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	41.3	36.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	43.8	38.1	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	45.9	39.5	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	47.2	40.4	0.0	0.0	0.0	238	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
16	47.7	40.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	47.5	40.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	47.0	39.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	46.2	39.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	45.1	39.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	43.8	39.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	42.3	38.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	40.7	37.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	39.1	35.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235

Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
1	37.5	34.5	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	36.0	33.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	34.7	31.8	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	33.6	30.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	32.8	30.1	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	32.2	29.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	32.1	29.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	32.5	30.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	33.9	31.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	36.0	33.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	38.5	34.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	41.3	36.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	43.8	38.1	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	45.9	39.5	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	47.2	40.4	0.0	0.0	0.0	238	0.0	0.0	0.0	238
16	47.7	40.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	47.5	40.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	47.0	39.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	46.2	39.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	45.1	39.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	43.8	39.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	42.3	38.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	40.7	37.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	39.1	35.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

March

Hour	Design		Design			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	51.8	42.9	0.0	14.5	20.5	247
2	50.8	42.1	0.0	0.0	0.0	245
3	50.0	41.8	0.0	4.9	8.1	247
4	49.3	41.1	0.0	0.0	0.0	245
5	49.1	41.1	0.0	4.9	8.1	247
6	49.5	41.6	0.0	0.0	0.0	245
7	50.6	42.7	0.0	4.9	8.1	247
8	52.5	44.3	0.0	0.0	0.0	245
9	55.2	46.4	0.0	0.0	0.0	245
10	58.3	48.5	0.0	0.0	0.0	245
11	61.8	50.3	0.0	0.0	0.0	245
12	65.1	51.9	0.0	0.0	0.0	245
13	67.6	53.4	0.0	0.0	0.0	243
14	69.3	53.9	0.0	0.0	0.0	240
15	69.9	53.8	0.0	0.0	0.0	238
16	69.3	53.1	0.0	0.0	0.0	235
17	67.8	51.8	0.0	0.0	0.0	235
18	65.6	50.2	0.0	0.0	0.0	235
19	62.9	48.9	0.0	0.0	0.0	235
20	60.2	47.7	0.0	0.0	0.0	235
21	57.9	46.5	0.0	0.0	0.0	235
22	55.8	45.3	0.0	0.0	0.0	235
23	54.1	44.4	0.0	0.0	0.0	235
24	52.9	43.7	0.0	0.0	0.0	235

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	45.4	41.6	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	43.3	39.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	41.6	38.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	40.6	37.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	40.2	37.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	40.6	37.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	41.6	39.0	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	43.3	40.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	45.4	42.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	47.9	44.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	50.6	45.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	53.3	46.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	55.8	48.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	58.0	49.6	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	59.6	50.3	0.0	0.0	0.0	238	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	QAWB (F)								
16	60.7	50.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	61.0	50.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	60.7	50.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	59.6	50.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	58.0	50.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	55.8	49.4	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	53.3	47.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	50.6	45.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	47.9	43.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	QAWB (F)								
1	45.4	41.6	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	43.3	39.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	41.6	38.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	40.6	37.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	40.2	37.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	40.6	37.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	41.6	39.0	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	43.3	40.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	45.4	42.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	47.9	44.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	50.6	45.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	53.3	46.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	55.8	48.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	58.0	49.6	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	59.6	50.3	0.0	0.0	0.0	238	0.0	0.0	0.0	238
16	60.7	50.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	61.0	50.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	60.7	50.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	59.6	50.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	58.0	50.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	55.8	49.4	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	53.3	47.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	50.6	45.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	47.9	43.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

April

Hour	----- Design -----					
	Design		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)				
1	62.6	52.5	0.0	14.5	20.5	247
2	61.6	52.1	0.0	0.0	0.0	245
3	60.9	51.6	0.0	4.9	8.1	247
4	60.3	51.2	0.0	0.0	0.0	245
5	60.1	51.3	0.0	4.9	8.1	247
6	60.5	51.9	0.0	0.0	0.0	245
7	61.4	53.0	0.0	4.9	8.1	247
8	63.2	54.5	0.0	0.0	0.0	245
9	65.7	55.8	0.0	0.0	0.0	245
10	68.6	57.1	0.0	0.0	0.0	245
11	71.9	58.6	0.0	0.0	0.0	245
12	75.0	60.3	0.0	0.0	0.0	245
13	77.4	61.5	0.0	0.0	0.0	243
14	78.9	62.2	0.0	0.0	0.0	240
15	79.5	62.5	0.0	0.0	0.0	238
16	78.9	61.8	0.0	0.0	0.0	235
17	77.5	60.3	0.0	0.0	0.0	235
18	75.4	59.1	0.0	0.0	0.0	235
19	72.9	57.3	0.0	0.0	0.0	235
20	70.4	56.5	0.0	0.0	0.0	235
21	68.2	55.7	0.0	0.0	0.0	235
22	66.3	55.0	0.0	0.0	0.0	235
23	64.7	54.0	0.0	0.0	0.0	235
24	63.6	53.2	0.0	0.0	0.0	235

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	57.7	53.9	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	55.9	52.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	54.2	51.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	52.9	50.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	51.9	49.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	51.2	49.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	51.0	49.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	51.6	49.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	53.3	50.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	55.9	51.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	59.0	53.4	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	62.4	55.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	65.5	57.7	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	68.1	59.4	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	69.8	60.7	0.0	0.0	0.0	238	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	70.4	60.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	70.2	60.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	69.5	60.1	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	68.5	59.4	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	67.2	59.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	65.5	59.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	63.7	58.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	61.7	57.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	59.7	55.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
Hour	Typical		Sunday				Monday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	57.7	53.9	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	55.9	52.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	54.2	51.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	52.9	50.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	51.9	49.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	51.2	49.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	51.0	49.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	51.6	49.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	53.3	50.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	55.9	51.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	59.0	53.4	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	62.4	55.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	65.5	57.7	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	68.1	59.4	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	69.8	60.7	0.0	0.0	0.0	238	0.0	0.0	0.0	238
16	70.4	60.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	70.2	60.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	69.5	60.1	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	68.5	59.4	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	67.2	59.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	65.5	59.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	63.7	58.8	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	61.7	57.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	59.7	55.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

May

Hour	----- Design -----					
	Design		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)				
1	70.8	59.3	0.0	14.5	20.5	247
2	69.8	58.5	0.0	0.0	0.0	245
3	69.0	58.2	0.0	4.9	8.1	247
4	68.4	58.1	0.0	0.0	0.0	245
5	68.2	58.0	0.0	4.9	8.1	247
6	68.6	58.5	0.0	0.0	0.0	245
7	69.6	59.5	0.0	4.9	8.1	247
8	71.3	60.6	0.0	0.0	0.0	245
9	73.9	61.5	0.0	0.0	0.0	245
10	76.8	62.7	0.0	0.0	0.0	245
11	80.1	63.9	0.0	0.0	0.0	245
12	83.2	65.4	0.0	0.0	0.0	245
13	85.6	66.5	41.1	0.0	0.0	201
14	87.1	67.1	51.9	0.0	0.0	148
15	87.7	67.2	55.4	0.0	0.0	91
16	87.1	66.5	55.2	0.0	0.0	35
17	85.8	65.1	0.0	0.0	0.0	35
18	83.6	63.9	0.0	0.0	0.0	35
19	81.1	62.4	0.0	0.0	0.0	35
20	78.6	61.6	0.0	0.0	0.0	35
21	76.4	61.8	0.0	0.0	0.0	35
22	74.5	60.9	0.0	0.0	0.0	35
23	72.9	60.3	0.0	0.0	0.0	35
24	71.7	59.9	0.0	0.0	0.0	35

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	66.6	62.3	0.0	45.0	50.5	79	0.0	45.0	50.5	140
2	64.5	60.4	0.0	45.0	50.5	123	0.0	45.0	50.5	183
3	62.7	59.1	0.0	45.0	50.5	167	0.0	45.0	50.5	226
4	61.2	58.1	0.0	45.0	50.5	211	0.0	23.4	27.4	247
5	60.0	57.1	0.0	39.0	43.2	247	0.0	0.0	0.0	245
6	59.3	56.6	0.0	0.0	0.0	245	0.0	4.9	8.1	247
7	59.0	56.5	0.0	4.9	8.1	247	0.0	0.0	0.0	245
8	59.5	56.6	0.0	0.0	0.0	245	0.0	4.9	8.1	247
9	60.9	56.6	0.0	0.0	0.0	245	0.0	0.0	0.0	247
10	63.0	57.2	0.0	0.0	0.0	245	0.0	0.0	0.0	247
11	65.7	58.1	0.0	0.0	0.0	245	0.0	0.0	0.0	247
12	68.7	59.8	0.0	0.0	0.0	245	0.0	0.0	0.0	247
13	71.7	61.6	27.1	0.0	0.0	215	9.1	0.0	0.0	236
14	74.5	63.4	35.8	0.0	0.0	178	16.4	0.0	0.0	217
15	76.6	64.8	40.0	0.0	0.0	136	19.3	0.0	0.0	196

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	78.0	65.6	38.8	0.0	0.0	96	17.8	0.0	0.0	176
17	78.5	65.6	0.0	0.0	0.0	96	0.0	0.0	0.0	176
18	78.2	65.8	0.0	0.0	0.0	96	0.0	0.0	0.0	176
19	77.5	65.6	0.0	0.0	0.0	96	0.0	0.0	0.0	176
20	76.3	66.1	0.0	0.0	0.0	96	0.0	0.0	0.0	176
21	74.8	67.2	0.0	0.0	0.0	96	0.0	0.0	0.0	176
22	73.0	66.4	0.0	0.0	0.0	96	0.0	0.0	0.0	176
23	70.9	65.4	0.0	0.0	0.0	96	0.0	0.0	0.0	176
24	68.7	64.0	0.0	0.0	0.0	96	0.0	0.0	0.0	176

Hour	Typical		Sunday				Monday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	66.6	62.3	0.0	45.0	50.5	219	0.0	45.0	50.5	219
2	64.5	60.4	0.0	30.5	34.0	247	0.0	30.5	34.0	247
3	62.7	59.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
4	61.2	58.1	0.0	4.9	8.1	247	0.0	4.9	8.1	247
5	60.0	57.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
6	59.3	56.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
7	59.0	56.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
8	59.5	56.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
9	60.9	56.6	0.0	0.0	0.0	247	0.0	0.0	0.0	247
10	63.0	57.2	0.0	0.0	0.0	247	0.0	0.0	0.0	247
11	65.7	58.1	0.0	0.0	0.0	247	0.0	0.0	0.0	247
12	68.7	59.8	0.0	0.0	0.0	247	0.0	0.0	0.0	247
13	71.7	61.6	9.1	0.0	0.0	236	27.1	0.0	0.0	218
14	74.5	63.4	16.4	0.0	0.0	217	35.8	0.0	0.0	180
15	76.6	64.8	19.3	0.0	0.0	196	40.2	0.0	0.0	138
16	78.0	65.6	17.8	0.0	0.0	176	38.8	0.0	0.0	98
17	78.5	65.6	0.0	0.0	0.0	176	0.0	0.0	0.0	98
18	78.2	65.8	0.0	0.0	0.0	176	0.0	0.0	0.0	98
19	77.5	65.6	0.0	0.0	0.0	176	0.0	0.0	0.0	98
20	76.3	66.1	0.0	0.0	0.0	176	0.0	0.0	0.0	98
21	74.8	67.2	0.0	0.0	0.0	176	0.0	0.0	0.0	98
22	73.0	66.4	0.0	0.0	0.0	176	0.0	0.0	0.0	98
23	70.9	65.4	0.0	0.0	0.0	176	0.0	0.0	0.0	98
24	68.7	64.0	0.0	0.0	0.0	176	0.0	0.0	0.0	98

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

June

Hour	----- Design -----					
	Design		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)				
1	79.5	66.2	0.0	45.0	52.4	142
2	78.5	65.3	0.0	45.0	51.9	185
3	77.7	65.1	0.0	45.0	51.6	229
4	77.2	64.8	0.0	21.3	26.1	247
5	77.0	65.1	0.0	0.0	0.0	245
6	77.4	65.6	0.0	4.9	8.2	247
7	78.3	66.5	0.0	0.0	0.0	245
8	80.0	67.7	0.0	4.9	8.4	247
9	82.5	68.3	0.0	0.0	0.0	247
10	85.4	69.5	0.0	0.0	0.0	247
11	88.7	70.8	0.0	0.0	0.0	247
12	91.8	72.2	0.0	0.0	0.0	247
13	94.1	72.6	51.1	0.0	0.0	194
14	95.6	72.9	64.1	0.0	0.0	128
15	96.2	72.9	66.2	0.0	0.0	60
16	95.6	72.0	65.6	0.0	0.0	0
17	94.3	70.8	0.0	0.0	0.0	0
18	92.1	69.7	0.0	0.0	0.0	0
19	89.6	68.3	0.0	0.0	0.0	0
20	87.1	67.7	0.0	0.0	0.0	0
21	85.0	67.5	0.0	0.0	0.0	0
22	83.1	67.3	0.0	0.0	0.0	0
23	81.6	66.8	0.0	0.0	0.0	0
24	80.4	66.3	0.0	0.0	0.0	0

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	73.0	67.9	0.0	45.0	50.5	45	0.0	45.0	50.5	81
2	71.2	66.1	0.0	45.0	50.5	90	0.0	45.0	50.5	125
3	69.7	65.2	0.6	45.0	50.5	133	0.9	45.0	50.5	168
4	68.5	64.3	0.0	45.0	50.5	177	0.0	45.0	50.5	211
5	67.8	64.2	0.0	45.0	50.5	220	0.0	38.3	42.4	247
6	67.6	64.2	0.0	29.8	33.3	247	0.0	0.0	0.0	245
7	68.1	64.8	0.0	0.0	0.0	245	0.0	4.9	8.1	247
8	69.4	65.7	0.0	4.9	8.1	247	0.0	0.0	0.0	245
9	71.6	66.2	0.0	0.0	0.0	247	0.0	0.0	0.0	245
10	74.2	67.2	0.0	0.0	0.0	247	0.0	0.0	0.0	245
11	77.2	68.5	0.0	0.0	0.0	247	0.0	0.0	0.0	245
12	80.2	70.0	0.0	0.0	0.0	247	0.0	0.0	0.0	245
13	82.8	70.8	40.7	0.0	0.0	204	23.7	0.0	0.0	219
14	85.0	71.6	53.7	0.0	0.0	149	29.4	0.0	0.0	187
15	86.3	72.3	56.9	0.0	0.0	90	32.9	0.0	0.0	152

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	86.8	72.1	53.0	0.0	0.0	36	29.1	0.0	0.0	122
17	86.6	71.7	0.0	0.0	0.0	36	0.0	0.0	0.0	122
18	85.8	71.5	0.0	0.0	0.0	36	0.0	0.0	0.0	122
19	84.7	71.2	0.0	0.0	0.0	36	0.0	0.0	0.0	122
20	83.2	71.5	0.0	0.0	0.0	36	0.0	0.0	0.0	122
21	81.4	71.7	0.0	0.0	0.0	36	0.0	0.0	0.0	122
22	79.3	71.4	0.0	0.0	0.0	36	0.0	0.0	0.0	122
23	77.2	70.5	0.0	0.0	0.0	36	0.0	0.0	0.0	122
24	75.1	69.1	0.0	0.0	0.0	36	0.0	0.0	0.0	122

Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	73.0	67.9	0.0	45.0	50.5	166	0.0	45.0	50.5	166
2	71.2	66.1	0.0	45.0	50.5	209	0.0	45.0	50.5	209
3	69.7	65.2	0.9	41.5	46.1	247	0.9	41.5	46.1	247
4	68.5	64.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	67.8	64.2	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	67.6	64.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	68.1	64.8	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	69.4	65.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	71.6	66.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	74.2	67.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	77.2	68.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	80.2	70.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	82.8	70.8	23.7	0.0	0.0	219	40.7	0.0	0.0	202
14	85.0	71.6	29.4	0.0	0.0	187	53.7	0.0	0.0	146
15	86.3	72.3	32.9	0.0	0.0	152	56.9	0.0	0.0	88
16	86.8	72.1	29.1	0.0	0.0	122	53.0	0.0	0.0	34
17	86.6	71.7	0.0	0.0	0.0	122	0.0	0.0	0.0	34
18	85.8	71.5	0.0	0.0	0.0	122	0.0	0.0	0.0	34
19	84.7	71.2	0.0	0.0	0.0	122	0.0	0.0	0.0	34
20	83.2	71.5	0.0	0.0	0.0	122	0.0	0.0	0.0	34
21	81.4	71.7	0.0	0.0	0.0	122	0.0	0.0	0.0	34
22	79.3	71.4	0.0	0.0	0.0	122	0.0	0.0	0.0	34
23	77.2	70.5	0.0	0.0	0.0	122	0.0	0.0	0.0	34
24	75.1	69.1	0.0	0.0	0.0	122	0.0	0.0	0.0	34

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

July

Hour	Design		Design			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	
1	78.9	67.7	0.0	45.0	52.1	79
2	78.2	67.2	0.0	45.0	51.8	123
3	77.6	66.8	0.0	45.0	51.6	167
4	77.1	66.6	0.0	45.0	51.4	210
5	77.0	66.6	0.0	39.7	44.8	247
6	77.3	66.9	0.0	0.0	0.0	245
7	78.0	67.6	0.0	4.9	8.3	247
8	79.4	68.8	0.0	0.0	0.0	245
9	81.3	69.6	0.0	0.0	0.0	245
10	83.6	70.7	0.0	0.0	0.0	245
11	86.1	72.2	0.0	0.0	0.0	245
12	88.5	73.3	0.0	0.0	0.0	245
13	90.3	74.0	51.3	0.0	0.0	191
14	91.5	74.3	63.9	0.0	0.0	126
15	92.0	74.0	65.8	0.0	0.0	58
16	91.5	73.2	65.1	0.0	0.0	0
17	90.5	72.1	0.0	0.0	0.0	0
18	88.8	70.8	0.0	0.0	0.0	0
19	86.9	70.4	0.0	0.0	0.0	0
20	84.9	70.2	0.0	0.0	0.0	0
21	83.3	70.0	0.0	0.0	0.0	0
22	81.8	69.4	0.0	0.0	0.0	0
23	80.6	68.7	0.0	0.0	0.0	0
24	79.7	68.4	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
1	72.0	69.3	0.0	45.0	50.5	45	0.0	45.0	50.5	81
2	70.5	68.0	0.0	45.0	50.5	90	0.0	45.0	50.5	126
3	69.4	67.1	0.0	45.0	50.5	134	0.0	45.0	50.5	169
4	68.5	66.4	0.0	45.0	50.5	177	0.0	45.0	50.5	213
5	67.9	66.0	0.0	45.0	50.5	221	0.0	37.1	40.9	247
6	67.7	65.9	0.0	29.2	32.7	247	0.0	0.0	0.0	245
7	68.1	66.3	0.0	0.0	0.0	245	0.0	4.9	8.1	247
8	69.1	67.3	0.0	4.9	8.1	247	0.0	0.0	0.0	245
9	70.8	68.0	0.0	0.0	0.0	247	0.0	0.0	0.0	245
10	72.9	69.1	0.0	0.0	0.0	247	0.0	0.0	0.0	245
11	75.2	70.5	0.0	0.0	0.0	247	0.0	0.0	0.0	245
12	77.5	71.7	0.0	0.0	0.0	247	0.0	0.0	0.0	245
13	79.6	72.7	40.2	0.0	0.0	205	23.4	0.0	0.0	219
14	81.3	73.5	54.4	0.0	0.0	148	28.9	0.0	0.0	188
15	82.3	73.7	55.9	0.0	0.0	91	31.4	0.0	0.0	155

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)
16	82.7	73.5	53.4	0.0	0.0	37	29.1	0.0	0.0	124
17	82.5	73.1	0.0	0.0	0.0	37	0.0	0.0	0.0	124
18	82.0	72.6	0.0	0.0	0.0	37	0.0	0.0	0.0	124
19	81.1	73.2	0.0	0.0	0.0	37	0.0	0.0	0.0	124
20	79.9	73.8	0.0	0.0	0.0	37	0.0	0.0	0.0	124
21	78.5	73.9	0.0	0.0	0.0	37	0.0	0.0	0.0	124
22	76.9	73.1	0.0	0.0	0.0	37	0.0	0.0	0.0	124
23	75.2	71.9	0.0	0.0	0.0	37	0.0	0.0	0.0	124
24	73.5	70.8	0.0	0.0	0.0	37	0.0	0.0	0.0	124

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)
1	72.0	69.3	0.0	45.0	50.5	168	0.0	45.0	50.5	168
2	70.5	68.0	0.0	45.0	50.5	211	0.0	45.0	50.5	211
3	69.4	67.1	0.0	38.4	42.5	247	0.0	38.4	42.5	247
4	68.5	66.4	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	67.9	66.0	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	67.7	65.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	68.1	66.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	69.1	67.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	70.8	68.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	72.9	69.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	75.2	70.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	77.5	71.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	79.6	72.7	23.4	0.0	0.0	219	40.2	0.0	0.0	202
14	81.3	73.5	28.9	0.0	0.0	188	54.4	0.0	0.0	146
15	82.3	73.7	31.4	0.0	0.0	155	55.9	0.0	0.0	89
16	82.7	73.5	29.1	0.0	0.0	124	53.4	0.0	0.0	34
17	82.5	73.1	0.0	0.0	0.0	124	0.0	0.0	0.0	34
18	82.0	72.6	0.0	0.0	0.0	124	0.0	0.0	0.0	34
19	81.1	73.2	0.0	0.0	0.0	124	0.0	0.0	0.0	34
20	79.9	73.8	0.0	0.0	0.0	124	0.0	0.0	0.0	34
21	78.5	73.9	0.0	0.0	0.0	124	0.0	0.0	0.0	34
22	76.9	73.1	0.0	0.0	0.0	124	0.0	0.0	0.0	34
23	75.2	71.9	0.0	0.0	0.0	124	0.0	0.0	0.0	34
24	73.5	70.8	0.0	0.0	0.0	124	0.0	0.0	0.0	34

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

August

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	
	(F)	(F)	(Ton)	(Ton)	(kW)	
1	78.6	67.6	0.0	45.0	52.0	79
2	77.9	67.2	0.0	45.0	51.7	123
3	77.2	66.9	0.0	45.0	51.4	167
4	76.8	66.6	0.0	45.0	51.2	210
5	76.6	66.7	0.0	39.3	44.1	247
6	76.9	67.1	0.0	0.0	0.0	245
7	77.7	67.8	0.0	4.9	8.2	247
8	79.1	69.0	0.0	0.0	0.0	245
9	81.2	70.0	0.0	0.0	0.0	245
10	83.5	70.9	0.0	0.0	0.0	245
11	86.2	71.8	0.0	0.0	0.0	245
12	88.7	72.7	0.0	0.0	0.0	245
13	90.6	73.2	50.9	0.0	0.0	192
14	91.8	73.8	65.3	0.0	0.0	124
15	92.3	74.0	66.7	0.0	0.0	56
16	91.8	73.3	64.6	0.0	0.0	0
17	90.7	72.4	0.0	0.0	0.0	0
18	89.0	71.4	0.0	0.0	0.0	0
19	87.0	70.1	0.0	0.0	0.0	0
20	84.9	69.8	0.0	0.0	0.0	0
21	83.2	70.3	0.0	0.0	0.0	0
22	81.6	69.3	0.0	0.0	0.0	0
23	80.4	68.5	0.0	0.0	0.0	0
24	79.4	67.9	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	72.7	70.2	0.0	45.0	50.5	45	0.0	45.0	50.5	84
2	71.2	69.0	0.0	45.0	50.5	90	0.0	45.0	50.5	128
3	69.9	68.0	0.9	45.0	50.5	133	1.1	45.0	50.5	171
4	68.8	67.1	0.0	45.0	50.5	176	0.0	45.0	50.5	214
5	68.0	66.6	0.0	45.0	50.5	220	0.0	35.4	39.1	247
6	67.5	66.2	0.0	30.1	33.6	247	0.0	0.0	0.0	245
7	67.3	66.1	0.0	0.0	0.0	245	0.0	4.9	8.1	247
8	67.8	66.5	0.0	4.9	8.1	247	0.0	0.0	0.0	245
9	69.1	67.0	0.0	0.0	0.0	247	0.0	0.0	0.0	245
10	71.2	67.8	0.0	0.0	0.0	247	0.0	0.0	0.0	245
11	73.8	68.7	0.0	0.0	0.0	247	0.0	0.0	0.0	245
12	76.5	70.0	0.0	0.0	0.0	247	0.0	0.0	0.0	245
13	79.1	71.2	40.7	0.0	0.0	204	23.5	0.0	0.0	219
14	81.1	72.6	54.3	0.0	0.0	148	29.3	0.0	0.0	188
15	82.5	73.6	56.1	0.0	0.0	90	32.2	0.0	0.0	153

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	83.0	73.7	49.9	0.0	0.0	40	25.5	0.0	0.0	126
17	82.8	73.5	0.0	0.0	0.0	40	0.0	0.0	0.0	126
18	82.3	73.5	0.0	0.0	0.0	40	0.0	0.0	0.0	126
19	81.5	73.1	0.0	0.0	0.0	40	0.0	0.0	0.0	126
20	80.4	73.7	0.0	0.0	0.0	40	0.0	0.0	0.0	126
21	79.1	74.9	0.0	0.0	0.0	40	0.0	0.0	0.0	126
22	77.6	73.9	0.0	0.0	0.0	40	0.0	0.0	0.0	126
23	76.0	72.7	0.0	0.0	0.0	40	0.0	0.0	0.0	126
24	74.3	71.3	0.0	0.0	0.0	40	0.0	0.0	0.0	126

Hour	Typical		Sunday				Monday			
	OADB	OAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	72.7	70.2	0.0	45.0	50.5	170	0.0	45.0	50.5	170
2	71.2	69.0	0.0	45.0	50.5	213	0.0	45.0	50.5	213
3	69.9	68.0	1.1	37.3	41.2	247	1.1	37.3	41.2	247
4	68.8	67.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	68.0	66.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	67.5	66.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	67.3	66.1	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	67.8	66.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	69.1	67.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	71.2	67.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	73.8	68.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	76.5	70.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	79.1	71.2	23.5	0.0	0.0	219	40.7	0.0	0.0	202
14	81.1	72.6	29.3	0.0	0.0	188	54.3	0.0	0.0	146
15	82.5	73.6	32.2	0.0	0.0	153	56.1	0.0	0.0	88
16	83.0	73.7	25.5	0.0	0.0	126	49.9	0.0	0.0	37
17	82.8	73.5	0.0	0.0	0.0	126	0.0	0.0	0.0	37
18	82.3	73.5	0.0	0.0	0.0	126	0.0	0.0	0.0	37
19	81.5	73.1	0.0	0.0	0.0	126	0.0	0.0	0.0	37
20	80.4	73.7	0.0	0.0	0.0	126	0.0	0.0	0.0	37
21	79.1	74.9	0.0	0.0	0.0	126	0.0	0.0	0.0	37
22	77.6	73.9	0.0	0.0	0.0	126	0.0	0.0	0.0	37
23	76.0	72.7	0.0	0.0	0.0	126	0.0	0.0	0.0	37
24	74.3	71.3	0.0	0.0	0.0	126	0.0	0.0	0.0	37

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

September

Hour	----- Design -----					
	Design		Cooling	Chiller	Chiller	Storage
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)
1	74.6	63.1	0.0	45.0	50.5	82
2	73.7	62.4	0.0	45.0	50.5	126
3	73.0	61.9	0.0	45.0	50.5	170
4	72.4	61.7	0.0	45.0	50.5	213
5	72.3	61.8	0.0	36.6	40.4	247
6	72.6	62.5	0.0	0.0	0.0	245
7	73.5	63.2	0.0	4.9	8.1	247
8	75.1	64.8	0.0	0.0	0.0	245
9	77.4	65.9	0.0	0.0	0.0	245
10	80.0	66.8	0.0	0.0	0.0	245
11	83.0	67.8	0.0	0.0	0.0	245
12	85.8	68.5	0.0	0.0	0.0	245
13	87.9	69.7	47.9	0.0	0.0	195
14	89.3	70.2	59.6	0.0	0.0	133
15	89.9	70.1	61.1	0.0	0.0	71
16	89.3	69.1	57.9	0.0	0.0	12
17	88.1	67.8	0.0	0.0	0.0	12
18	86.2	66.8	0.0	0.0	0.0	12
19	83.9	66.5	0.0	0.0	0.0	12
20	81.6	66.3	0.0	0.0	0.0	12
21	79.7	66.1	0.0	0.0	0.0	12
22	77.9	65.0	0.0	0.0	0.0	12
23	76.5	64.4	0.0	0.0	0.0	12
24	75.4	63.6	0.0	0.0	0.0	12

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage	
	OADB (F)	OAWB (F)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	Load (Ton)	Load (Ton)	Demand (kW)	Capacity (Ton-Hr)	
1	69.8	66.1	0.6	45.0	50.5	56	0.9	45.0	50.5	117	
2	68.0	64.5	0.0	45.0	50.5	101	0.0	45.0	50.5	161	
3	66.3	63.0	0.0	45.0	50.5	145	0.0	45.0	50.5	204	
4	64.9	61.9	0.0	45.0	50.5	188	0.0	45.0	50.5	247	
5	63.9	61.3	0.0	45.0	50.5	231	0.0	3.1	5.0	247	
6	63.2	61.0	0.0	18.4	23.3	247	0.0	0.0	0.0	245	
7	63.0	60.8	0.0	0.0	0.0	245	0.0	4.9	8.1	247	
8	63.4	61.4	0.0	4.9	8.1	247	0.0	0.0	0.0	245	
9	64.7	61.8	0.0	0.0	0.0	247	0.0	0.0	0.0	245	
10	66.6	62.1	0.0	0.0	0.0	247	0.0	0.0	0.0	245	
11	69.1	62.9	0.0	0.0	0.0	247	0.0	0.0	0.0	245	
12	71.8	63.7	0.0	0.0	0.0	247	0.0	0.0	0.0	245	
13	74.5	65.5	33.6	0.0	0.0	211	17.7	0.0	0.0	225	
14	77.0	67.1	45.8	0.0	0.0	163	21.7	0.0	0.0	201	
15	78.9	68.2	44.2	0.0	0.0	118	20.7	0.0	0.0	178	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	80.2	68.6	43.1	0.0	0.0	73	19.5	0.0	0.0	157
17	80.6	68.5	0.0	0.0	0.0	73	0.0	0.0	0.0	157
18	80.4	68.9	0.0	0.0	0.0	73	0.0	0.0	0.0	157
19	79.7	70.0	0.0	0.0	0.0	73	0.0	0.0	0.0	157
20	78.7	71.2	0.0	0.0	0.0	73	0.0	0.0	0.0	157
21	77.3	71.6	0.0	0.0	0.0	73	0.0	0.0	0.0	157
22	75.6	70.5	0.0	0.0	0.0	73	0.0	0.0	0.0	157
23	73.7	69.4	0.0	0.0	0.0	73	0.0	0.0	0.0	157
24	71.8	67.7	0.0	0.0	0.0	73	0.0	0.0	0.0	157

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	69.8	66.1	0.9	45.0	50.5	200	0.9	45.0	50.5	200
2	68.0	64.5	0.0	45.0	50.5	243	0.0	45.0	50.5	243
3	66.3	63.0	0.0	7.4	12.1	247	0.0	7.4	12.1	247
4	64.9	61.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	63.9	61.3	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	63.2	61.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	63.0	60.8	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	63.4	61.4	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	64.7	61.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	66.6	62.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	69.1	62.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	71.8	63.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	74.5	65.5	17.7	0.0	0.0	225	33.6	0.0	0.0	209
14	77.0	67.1	21.7	0.0	0.0	201	45.8	0.0	0.0	161
15	78.9	68.2	20.7	0.0	0.0	178	44.2	0.0	0.0	115
16	80.2	68.6	19.5	0.0	0.0	157	43.1	0.0	0.0	71
17	80.6	68.5	0.0	0.0	0.0	157	0.0	0.0	0.0	71
18	80.4	68.9	0.0	0.0	0.0	157	0.0	0.0	0.0	71
19	79.7	70.0	0.0	0.0	0.0	157	0.0	0.0	0.0	71
20	78.7	71.2	0.0	0.0	0.0	157	0.0	0.0	0.0	71
21	77.3	71.6	0.0	0.0	0.0	157	0.0	0.0	0.0	71
22	75.6	70.5	0.0	0.0	0.0	157	0.0	0.0	0.0	71
23	73.7	69.4	0.0	0.0	0.0	157	0.0	0.0	0.0	71
24	71.8	67.7	0.0	0.0	0.0	157	0.0	0.0	0.0	71

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

October

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	59.5	50.0	0.0	45.0	
2	58.5	49.3	0.0	45.0	50.5	159
3	57.7	48.8	0.0	45.0	50.5	203
4	57.1	48.5	0.0	45.0	50.5	246
5	56.9	48.3	0.0	4.4	7.3	247
6	57.3	48.7	0.0	0.0	0.0	245
7	58.3	49.7	0.0	4.9	8.1	247
8	60.1	51.3	0.0	0.0	0.0	245
9	62.7	52.9	0.0	0.0	0.0	245
10	65.7	54.4	0.0	0.0	0.0	245
11	69.1	55.5	0.0	0.0	0.0	245
12	72.3	56.7	0.0	0.0	0.0	245
13	74.7	57.8	34.5	0.0	0.0	208
14	76.3	58.6	43.0	0.0	0.0	163
15	76.9	58.7	45.2	0.0	0.0	116
16	76.3	58.0	42.1	0.0	0.0	73
17	74.9	57.0	0.0	0.0	0.0	73
18	72.7	56.0	0.0	0.0	0.0	73
19	70.1	55.5	0.0	0.0	0.0	73
20	67.5	54.7	1.0	0.0	0.0	72
21	65.3	53.6	0.0	0.0	0.0	72
22	63.3	52.4	0.0	0.0	0.0	72
23	61.7	51.5	0.0	0.0	0.0	72
24	60.5	50.7	0.0	0.0	0.0	72

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	54.8	51.3	0.0	45.0	50.5	116	0.0	45.0	50.5
2	52.9	49.6	0.0	45.0	50.5	160	0.0	45.0	50.5	241
3	51.2	48.2	0.0	45.0	50.5	203	0.0	9.1	15.0	247
4	49.8	47.2	0.0	45.0	50.5	246	0.0	0.0	0.0	245
5	48.8	46.2	0.0	3.6	5.9	247	0.0	4.9	8.1	247
6	48.2	45.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	47.9	45.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	48.5	46.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	50.3	47.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	52.9	48.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	56.2	49.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	59.6	51.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	62.9	53.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	65.5	55.2	25.1	0.0	0.0	215	0.0	0.0	0.0	240
15	67.3	56.3	28.9	0.0	0.0	184	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
16	67.9	56.6	27.9	0.0	0.0	154	0.0	0.0	0.0	235
17	67.7	56.4	0.0	0.0	0.0	154	0.0	0.0	0.0	235
18	67.0	56.6	0.0	0.0	0.0	154	0.0	0.0	0.0	235
19	66.0	57.6	0.0	0.0	0.0	154	0.0	0.0	0.0	235
20	64.6	57.9	0.0	0.0	0.0	154	0.0	0.0	0.0	235
21	62.9	57.3	0.0	0.0	0.0	154	0.0	0.0	0.0	235
22	61.0	56.0	0.0	0.0	0.0	154	0.0	0.0	0.0	235
23	59.0	54.8	0.0	0.0	0.0	154	0.0	0.0	0.0	235
24	56.9	53.0	0.0	0.0	0.0	154	0.0	0.0	0.0	235

Hour	Typical		Sunday				Monday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
		(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)	
1	54.8	51.3	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	52.9	49.6	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	51.2	48.2	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	49.8	47.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	48.8	46.2	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	48.2	45.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	47.9	45.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	48.5	46.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	50.3	47.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	52.9	48.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	56.2	49.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	59.6	51.5	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	62.9	53.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	65.5	55.2	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	67.3	56.3	0.0	0.0	0.0	238	0.0	0.0	0.0	238
16	67.9	56.6	0.0	0.0	0.0	235	8.5	0.0	0.0	227
17	67.7	56.4	0.0	0.0	0.0	235	0.0	0.0	0.0	227
18	67.0	56.6	0.0	0.0	0.0	235	0.0	0.0	0.0	227
19	66.0	57.6	0.0	0.0	0.0	235	0.0	0.0	0.0	227
20	64.6	57.9	0.0	0.0	0.0	235	0.0	0.0	0.0	227
21	62.9	57.3	0.0	0.0	0.0	235	0.0	0.0	0.0	227
22	61.0	56.0	0.0	0.0	0.0	235	0.0	0.0	0.0	227
23	59.0	54.8	0.0	0.0	0.0	235	0.0	0.0	0.0	227
24	56.9	53.0	0.0	0.0	0.0	235	0.0	0.0	0.0	227

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

November

Hour	Design		Design			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	56.0	47.2	0.0	22.9	27.0	247
2	55.0	46.4	0.0	0.0	0.0	245
3	54.2	45.8	0.0	4.9	8.1	247
4	53.6	45.2	0.0	0.0	0.0	245
5	53.4	45.3	0.0	4.9	8.1	247
6	53.8	45.9	0.0	0.0	0.0	245
7	54.8	46.9	0.0	4.9	8.1	247
8	56.6	48.7	0.0	0.0	0.0	245
9	59.2	50.6	0.0	0.0	0.0	245
10	62.2	52.6	0.0	0.0	0.0	245
11	65.6	54.1	0.0	0.0	0.0	245
12	68.8	55.3	0.0	0.0	0.0	245
13	71.2	55.7	0.0	0.0	0.0	243
14	72.8	56.3	0.0	0.0	0.0	240
15	73.4	56.2	0.0	0.0	0.0	238
16	72.8	55.6	0.0	0.0	0.0	235
17	71.4	54.6	0.0	0.0	0.0	235
18	69.2	53.6	0.0	0.0	0.0	235
19	66.6	53.0	0.0	0.0	0.0	235
20	64.0	51.7	0.0	0.0	0.0	235
21	61.8	50.7	0.0	0.0	0.0	235
22	59.8	49.6	0.0	0.0	0.0	235
23	58.2	48.7	0.0	0.0	0.0	235
24	57.0	48.0	0.0	0.0	0.0	235

Hour	Typical		Weekday				Saturday			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	48.7	45.7	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	46.9	44.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	45.5	42.8	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	44.6	41.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	44.4	42.0	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	44.8	42.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	45.9	43.9	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	47.8	46.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	50.2	48.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	52.9	49.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	55.8	51.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	58.5	52.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	60.9	52.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	62.8	53.4	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	64.0	53.8	0.0	0.0	0.0	238	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	64.4	53.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	64.1	53.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	63.2	53.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	61.8	54.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	60.0	53.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	57.9	52.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	55.6	51.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	53.2	49.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	50.8	47.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235

Hour	Typical		Sunday				Monday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	48.7	45.7	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	46.9	44.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	45.5	42.8	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	44.6	41.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	44.4	42.0	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	44.8	42.7	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	45.9	43.9	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	47.8	46.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	50.2	48.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	52.9	49.9	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	55.8	51.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	58.5	52.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	60.9	52.5	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	62.8	53.4	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	64.0	53.8	0.0	0.0	0.0	238	0.0	0.0	0.0	238
16	64.4	53.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	64.1	53.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	63.2	53.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	61.8	54.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	60.0	53.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	57.9	52.7	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	55.6	51.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	53.2	49.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	50.8	47.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

December

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	48.2	40.8	0.0	14.5	
2	47.3	40.2	0.0	0.0	0.0	245
3	46.6	39.7	0.0	4.9	8.1	247
4	46.1	39.3	0.0	0.0	0.0	245
5	45.9	39.4	0.0	4.9	8.1	247
6	46.3	39.7	0.0	0.0	0.0	245
7	47.1	40.6	0.0	4.9	8.1	247
8	48.7	42.0	0.0	0.0	0.0	245
9	50.9	44.0	0.0	0.0	0.0	245
10	53.5	46.1	0.0	0.0	0.0	245
11	56.5	48.0	0.0	0.0	0.0	245
12	59.2	49.7	0.0	0.0	0.0	245
13	61.3	50.8	0.0	0.0	0.0	243
14	62.7	51.4	0.0	0.0	0.0	240
15	63.2	51.4	0.0	0.0	0.0	238
16	62.7	50.7	0.0	0.0	0.0	235
17	61.5	49.7	0.0	0.0	0.0	235
18	59.6	48.5	0.0	0.0	0.0	235
19	57.3	47.6	0.0	0.0	0.0	235
20	55.1	45.9	0.0	0.0	0.0	235
21	53.2	44.6	0.0	0.0	0.0	235
22	51.5	43.1	0.0	0.0	0.0	235
23	50.1	42.2	0.0	0.0	0.0	235
24	49.0	41.5	0.0	0.0	0.0	235

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	37.5	35.3	0.0	14.5	20.5	247	0.0	14.5	20.5
2	37.1	35.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	37.4	35.5	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	38.1	36.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	39.3	37.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	40.9	39.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	42.7	41.2	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	44.7	43.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	46.8	45.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	48.8	47.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	50.7	48.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	52.2	48.8	0.0	0.0	0.0	245	0.0	0.0	0.0	245
13	53.4	49.2	0.0	0.0	0.0	243	0.0	0.0	0.0	243
14	54.1	49.2	0.0	0.0	0.0	240	0.0	0.0	0.0	240
15	54.4	48.9	0.0	0.0	0.0	238	0.0	0.0	0.0	238

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M171, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	54.0	48.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	53.0	47.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	51.4	46.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	49.3	45.4	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	47.0	43.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	44.5	41.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	42.2	39.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	40.1	37.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	38.5	36.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235

Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB	OAWB	Cooling	Chiller	Chiller	Storage	Cooling	Chiller	Chiller	Storage
	(F)	(F)	Load	Load	Demand	Capacity	Load	Load	Demand	Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	37.5	35.3	0.0	14.5	20.5	247	0.0	14.5	20.5	247
2	37.1	35.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
3	37.4	35.5	0.0	4.9	8.1	247	0.0	4.9	8.1	247
4	38.1	36.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
5	39.3	37.6	0.0	4.9	8.1	247	0.0	4.9	8.1	247
6	40.9	39.2	0.0	0.0	0.0	245	0.0	0.0	0.0	245
7	42.7	41.2	0.0	4.9	8.1	247	0.0	4.9	8.1	247
8	44.7	43.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
9	46.8	45.3	0.0	0.0	0.0	245	0.0	0.0	0.0	245
10	48.8	47.0	0.0	0.0	0.0	245	0.0	0.0	0.0	245
11	50.7	48.1	0.0	0.0	0.0	245	0.0	0.0	0.0	245
12	52.2	48.8	0.0	0.0	0.0	243	0.0	0.0	0.0	243
13	53.4	49.2	0.0	0.0	0.0	240	0.0	0.0	0.0	240
14	54.1	49.2	0.0	0.0	0.0	238	0.0	0.0	0.0	238
15	54.4	48.9	0.0	0.0	0.0	235	0.0	0.0	0.0	235
16	54.0	48.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235
17	53.0	47.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
18	51.4	46.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
19	49.3	45.4	0.0	0.0	0.0	235	0.0	0.0	0.0	235
20	47.0	43.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
21	44.5	41.5	0.0	0.0	0.0	235	0.0	0.0	0.0	235
22	42.2	39.3	0.0	0.0	0.0	235	0.0	0.0	0.0	235
23	40.1	37.6	0.0	0.0	0.0	235	0.0	0.0	0.0	235
24	38.5	36.2	0.0	0.0	0.0	235	0.0	0.0	0.0	235

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M171, ECO#13

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 35,398
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,574.4	296,390.2	3.2	18.0	328,111.8	9.5
Primary Cooling						
Compressor	82,273.7	0.0	0.0	16.8	842,484.9	24.4
Tower/Cond Fans	4,171.3	0.0	0.0	0.8	42,713.9	1.2
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,158.3	0.0	0.0	0.6	32,341.1	0.9
Auxiliary						
Supply Fans	102,491.2	0.0	0.0	20.9	1,049,512.1	30.4
Circulation Pumps	30,724.5	0.0	0.0	6.3	314,619.5	9.1
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	133,215.7	0.0	0.0	27.1	1,364,131.8	39.5
Lighting	93,655.9	0.0	0.0	19.1	959,038.3	27.1
Receptacle	86,156.3	0.0	0.0	17.5	882,242.7	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	404,205.6	296,390.2	3.2	100.0	4,451,064.5	127.6

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M171, ECO#15

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	WATER (1000 G1)	GAS DMND On Peak (Thrm/hr)
Jan	27,525	71	1,124	1	4
Feb	24,665	71	996	1	4
March	25,008	70	235	0	3
April	21,355	70	0	0	0
May	33,621	137	0	0	0
June	42,114	156	0	0	0
July	40,517	151	0	0	0
Aug	42,252	153	0	0	0
Sept	33,953	144	0	0	0
Oct	25,062	120	0	0	0
Nov	23,022	70	207	0	2
Dec	25,401	71	633	1	3
Total	364,492	156	3,195	3	4

Building Energy Consumption = 44,168 (Btu/Sq Ft/Year)
 Source Energy Consumption = 114,941 (Btu/Sq Ft/Year)

Floor Area = 35,398 (Sq Ft)

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M171, ECO#15

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 156.1 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	85.9	55.01
Sub Total			85.9	55.01
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	11.7	7.50
Sub Total			11.7	7.50
Sub Total			0.0	0.00
Miscellaneous				
	Lights		27.4	17.56
	Base Utilities		0.0	0.00
	Misc Equipment		31.1	19.94
Sub Total			58.5	37.49
Grand Total			156.1	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M171, ECO#15

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 35,398
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,643.8	319,459.2	3.3	20.8	353,105.9	10.2
Primary Cooling						
Compressor	54,663.6	0.0	0.0	11.9	559,757.0	16.2
Tower/Cond Fans	6,727.2	0.0	0.0	1.5	68,887.0	2.0
Condenser Pump	0.0	0.0	0.0	0.0	0.0	0.0
Other Accessories	857.4	0.0	0.0	0.2	8,779.8	0.3
Auxiliary						
Supply Fans	102,491.2	0.0	0.0	22.4	1,049,512.1	30.4
Circulation Pumps	36,090.7	0.0	0.0	7.9	369,569.6	10.7
Base Utilities	0.0	0.0	0.0	0.0	0.0	0.0
Subtotal	138,581.9	0.0	0.0	30.3	1,419,081.9	41.1
Lighting	75,862.3	0.0	0.0	16.6	776,831.6	21.9
Receptacle	86,156.3	0.0	0.0	18.8	882,242.7	24.9
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0	0.0
Totals	364,492.6	319,459.2	3.3	100.0	4,068,685.7	116.6

BUILDING 181

EMC ENGINEERS, INC.

PROJECT: FORT MCPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT MCPHERSON
 ECO: Computer Simulation Summary

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

EMC PROJECT: #3105.000
 DATE: 04/22/92
 FILE: M181ECO
 PREPARED BY: DENNIS JONES
 CHECKED BY:

Bldg: M181

Area: 36,158 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Receipt Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	212,180	1,447	86,080	273,717	54,369	174,211	92,112	681,936	198	212	2,540
Wall Insulation	103,893	869	81,817	273,166	54,369	174,211	92,112	676,544	195	104	2,413
Savings (Loss)	108,287	578	4,263	551	0	0	0	5,392	3	108	127
Economizer	212,180	1,447	79,882	273,717	54,369	174,211	92,112	675,738	198	212	2,518
Savings (Loss)	0	0	6,198	0	0	0	0	6,198	0	0	21
HVAC Controls	10,306	199	52,098	94,489	18,843	174,211	92,112	431,952	198	10	1,485
Savings (Loss)	201,874	1,248	33,982	179,228	35,526	0	0	249,984	0	202	1,055
Ice Storage	212,180	1,447	120,006	273,717	54,369	174,211	92,112	715,862	146	212	2,655
Savings (Loss)	0	0	(33,926)	0	0	0	0	(33,926)	52	0	(116)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY DB DATE 7/1/97

CHECKED BY _____ DATE _____

SCALE 1/12"

ECCS

ECONOMIZER

(1) DRY COIL
100' / 2.0

(2) CLG
285 FEET
100 CFM VELOCITY @ 10 CFM/PERSON
6% OF 500 A/C
100 CFM TO 20 CFM/PERSON

INSULATION

NO SCREEN WITH STUDS - ADDS R-10
R = 15.45 [U = 0.065]

HVAC CONTROLS

(2)	CLG PACK	COILS	} OFF 18-6 WEEKDAY 9-24 WEEKENDS
	HTS PACK	HEATING	
(26)	FAN OFF	FAN SPEEDS	
	FAN OFF	VENT "	
(29)	O/S ACH	INTIL	

THERMAL STORAGE - (ALT-4)

(62) <EQ1750>
 (53) STORAGE REF 1
 (73) CLIMICE STORAGE SIZE FOR 190 TON-HRS
 USE 40 TON CHILLER
 CAPACITY
 CONTROL OPTIMIZE
 LOSS FULL CHARGE 0.07%

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE 1/8" = 1'-0"


U-VALUES

WALLS



$$U = 0.169$$

ROOF



$$U = 0.025$$

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

21112

7015

BASE AREA 474.21

1.05

11.1 1.05 11.655

11.1 1.05 11.655

11.1

11.1 1.05 11.655

11.1

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

11.1 1.05 11.655

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE 1/8" = 1'-0"

FRESH AIR FLOW

VENTILATION 2360 cfm (FROM SPECS) → 10.4 CFM/PERSON
FANS 3940 cfm = 1.0 CFM/SF

LIFTER

TRANC CGAA080RD51CC4C4C311CRAR 80 TONS
McQUAY - PERFEX APP-007C-V-99 77.2 kW
0.965 kW/ton

HEATING

STEAM FROM CHP

PUMPS

CWP 1 5 HP
CWP 2 7.5 HP
HWP 1 1.5 HP

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY [Signature] DATE 2/28/92


CHECKED BY _____ DATE _____

SCALE 1/2" = 1'

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

DIMENSIONS



JOB 3105-000
 SHEET NO. _____ OF _____
 CALCULATED BY DS DATE 3/4/92
 CHECKED BY _____ DATE _____
 SCALE 1/181

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

- AREA - 500' x 100'
50000

ENTIRE BUILDING SERVED BY FAN COILS AND
 CONSTANT VOLUME AHUS
 MODEL AS ONE ZONE (NON-MIXING SYSTEM)

FLOOR AREAS

1st	18,400	18,400	ROOF AREA = 18,400
2nd	15,131		
MEZZ	2,618		
	<u>36,149</u>		

WALLS

WEST	5072		
NORTH	3132		
EAST	3862		
SOUTH	3708		
			144 x 24 = 49 x 18 + 49 x 18 + 28 x 9

PEOPLE

228 PEOPLE / 10,000 SF = 1.2 PEOPLE/SF

LIGHTS

62,933 W / 10,000 SF = 1.92 W/SF

EQUIPMENT

PC	99	⊖	200	= 19,800
MINI-MAINFRAMES	8	⊖	400	3,200
PRINTERS	50	⊖	100	5,000
COPY MACHINES	5	⊖	600	3,000
COPY MACHINE	2	⊖	300	600
TYPEWRITERS	9	⊖	30	270
REFRIGERATOR	3	⊖	200	600
COFFEE POTS	3	⊖	260	780

33,250 W

$\frac{33,250}{36,149} = 0.92 \text{ W/SF}$

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

Handwritten notes and diagrams within a large rectangular frame. The text is mostly illegible due to blurriness and handwriting. Some legible fragments include:

- Top left: "1/2" and "1/4"
- Top center: "SUMMER"
- Top right: "1/2"
- Middle left: "20"
- Middle right: "1/2"
- Bottom left: "4 HRS"
- Bottom center: "OFF"
- Bottom right: "OFF"

Card - Job Information

Project: FORT MCPHERSON & GILLEM EEAP #3105.000
 Location: ATLANTA, GA
 Client: COE - DACA21-9-C-0097
 Program User: DENNIS JONES
 Comments: BUILDING 181 - FORT MCPHERSON

-----CARD 08-- Climatic Information -----
 Weather Summer Winter Summer Summer Winter Summer Winter
 Code Clearness Clearness Design Design Design Building Ground Ground
 Number Number Dry Bulb Wet Bulb Dry Bulb Orientation Reflect Reflect
 ATLANTA

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	M181 - BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Description	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	OFFICE	7174	1	1	2		10			
2	2	OFFICE	5341	1	1	2		10			
3	3	OFFICE	23643	1	1	2		10			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Flag	T'stat Location	Mass / No. Hrs Average	Carpet On Floor
M1	76			CLGM181	72		HTGM181				YES

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	YES			0.025	42	0	90	0.45

-----CARD 22-- Roof Parameters -----

Roof									
Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
2	1	YES			0.025	42	0	90	0.45
3	1	NO	5894	1	0.025	42	0	90	0.45

-----CARD 24-- Wall Parameters -----

Wall									
Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M	1			0.169	77	0		.45	
1	1	94	20	0.169	77	0		.45	
1	2	62	24	0.169	77	180		.45	
2	1	109	9			270			
2	2	49	9			180			
2	3	20	9			90			
3	1	50	20			0			
3	2	68	24			270			
3	3	137	9			270			
3	4	77	9			180			
3	5	33	24			180			
3	6	68	24			90			
3	7	137	9			90			

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
M1	PPL1	LGT1	AVAIL	OFF		AVAIL	AVAIL		AVAIL	

-----CARD 27-- People and Lights -----

Lighting											
Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	--- Daylighting --- Reference Point 1	Reference Point 2
M1	159	SF-PERS	250	200	1.74	WATT-SF	ASHRAE2	1			

-----CARD 28--- Miscellaneous Equipment -----

Miscellaneous Equipment												
Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path	
M1	1	GENERAL OFFICE	0.92	WATT-SF	LGT1	ELEC						

```

-----CARD 29--- Room Airflows -----
-----Ventilation-----
Room   ----Cooling----   ----Heating----
Number Value   Units   Value   Units
M1     20     CFM-P   20     CFM-P
-----Cooling----   ----Heating----   ----Infiltration-----
Value   Units   Value   Units   Value   Units
0.5     ACH-HR  0.5     ACH-HR
--Reheat Minimum--
Value   Units

```

```

-----CARD 30- Fan Airflows -----
-----Main-----
Room   ----Cooling----   ----Heating----   ----Auxiliary-----
Number Value   Units   Value   Units   Value   Units
M1     1.09   CFM-SF  1.09   CFM-SF
-----Cooling----   ----Heating----   ----Room Exhaust--
Value   Units   Value   Units   Value   Units

```

```

----- System Section Alternative #1 -----

```

```

-----CARD 39-- System Alternative -----
Number   Description
1

```

```

-----CARD 40--- System Type -----
-----OPTIONAL VENTILATION SYSTEM-----
System   Ventil   Fan
Set      System  Deck   Cooling Heating Cooling Heating Static
Number  Type   Location SADBvh SADBvh Schedule Schedule Pressure
1       MZ
2       FC

```

```

-----CARD 41-- Zone Assignment -----
System
Set      Ref #1      Ref #2      Ref #3      Ref #4      Ref #5      Ref #6
Number   Begin  End   Begin  End   Begin  End   Begin  End   Begin  End   Begin  End
1        1      2
2        3      3

```

```

-----CARD 42--- Fan SP and Duct Parameters-----
System Cool Heat Return Mn Exh Aux Rm Exh Cool Return Supply Supply Return
Set     Fan Fan Fan Fan Fan Fan Fan Mtr Fan Mtr Duct Duct Air
Number SP  SP  SP  SP  SP  SP  Loc  Loc  Ht Gn Loc Path
1       2.50 2.50
2       1.50 1.50
RETAIR DUCTED
RETAIR DUCTED

```


-----CARD 65-- Heating Load Assignment -----
 Load All Coil
 Assignment Loads To -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
 Reference Heating Ref Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
 1 1 1 2

-----CARD 67-- Heating Equipment Parameters -----
 Heat Equip Number HW Pmp Energy Seq Switch Demand
 Ref Code Of Full Ld Cap'y Rate Order over Hot Misc. Limit
 Number Name Units Value Units Value Units Value Units Number Control Strg Acc. Cogen Number
 1 EQ2001 1 1.5 HP

-----CARD 69-- Fan Equipment Parameters -----
 System
 Set Cooling Heating Return Exhaust Auxiliary Room Optional
 Number Fan Fan Fan Fan Supply Exhaust Ventilation
 1 EQ4003 EQ4003
 2 EQ4003 EQ4003

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
CLGM181 COOLING TSTAT SCHEDULE
CLGMAC COOLING SCHEDULE
HTGM181 HEATING TSTAT SCHEDULE
HTGMAC HEATING SCHEDULE
LGT1
OFF ALWAYS OFF
PPL1

System:

FC FAN COIL
MZ MULTIZONE

Equipment:

Cooling:

EQ1121L AIR-CLD RECIP 35-60 TONS

Heating:

EQ2001 GAS FIRE TUBE HOT WATER

Fan:

EQ4003 FC CENTRIF. FAN C.V.

Scenario Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: CLGM181
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments: 70 F SUMMER - BLDG M181

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 70
24

Sample Name: CLGMAC
Project: COOLING SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Schedule Name: HTGM181
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments: 78 F WINTER - BLDG M181

Starting Month: NOV Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	78
24	

Rule Name: HTGMAC
Project: HEATING SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: LGT1

Project:

Location:

Client:

Program User:

Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

Hour	Util Percent
0	5
24	

Rule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Schedule Name: PPL1

Project:

Location:

Client:

Program User: D JONES

Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

Hour	Util Percent
0	0
24	

```
*****  
*****  
**  
**          T R A C E   6 0 0   A N A L Y S I S          **  
**  
**          by                **  
**  
*****  
*****
```

FORT MCPHERSON & GILLEM EEAP #3105.000
ATLANTA, GA
COE - DACA21-9-C-0097
DENNIS JONES
BUILDING 181 - FORT MCPHERSON

Weather File Code: ATLANTA.
Location:
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: June To November
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 2:18: 5 3/20/92
Dataset Name: M181 .TM

AIRFLOW - ALTERNATIVE 1
 M181 - BASELINE

----- SYSTEM SUMMARY -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	MZ	1,574	13,740	13,740	13,740	1,574	0	0
2	FC	2,974	25,771	25,771	25,771	2,974	0	0
Totals		4,548	39,510	39,510	39,510	4,548	0	0

CAPACITY - ALTERNATIVE 1
 M181 - BASELINE

----- SYSTEM SUMMARY -----
 (Design Capacity Quantities)

System Number	System Type	Cooling				Cooling Totals (Tons)	Heating						Heating Totals (Btuh)
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)		Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	
1	MZ	20.6	0.0	0.0	20.6	-121,341	0	0	0	0	0	0	-121,341
2	FC	36.3	0.0	0.0	36.3	-207,660	0	0	0	0	0	0	-207,660
Totals		56.8	0.0	0.0	56.8	-329,001	0	0	0	0	0	0	-329,001

The building peaked at hour 15 month 8 with a capacity of 56.8 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 M181 - BASELINE

----- ENGINEERING CHECKS -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	MZ	11.46	1.10	667.7	608.2	19.73	1.10	-9.70	12,515
2	Main	FC	11.54	1.09	710.8	652.1	18.40	1.09	-8.78	23,643

System 1 Block MZ - MULTIZONE

***** COOLING COIL PEAK *****					***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****				
Peaked at Time ==>	Mo/Hr: 8/15				*	Mo/Hr: 6/16			*	Mo/Hr: 13/ 1		
Outside Air ==>	OADB/WB/HR: 92/ 74/105.0				*	OADB: 96			*	OADB: 22		
	Space	Ret. Air	Ret. Air	Net	Perct	*	Space	Perct	*	Space Peak	Coil Peak	Perct
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Space Sens	Tot Sens	Of Tot
	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%)
Envelope Loads												
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	3,988		3,988	1.62	*	0	0.00	*	0	-14,007	11.47
Glass Solar	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Wall Cond	12,470	2,840		15,310	6.20	*	14,941	9.41	*	-33,597	-41,111	33.66
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	0			0	0.00	*	0	0.00	*	0	0	0.00
Sub Total==>	12,470	6,828		19,298	7.82	*	14,941	9.41	*	-33,597	-55,118	45.13
Internal Loads												
Lights	74,322	0		74,322	30.10	*	74,322	46.83	*	0	0	0.00
People	35,420			35,420	14.34	*	19,678	12.40	*	0	0	0.00
Misc	39,297	0	0	39,297	15.91	*	39,297	24.76	*	0	0	0.00
Sub Total==>	149,038	0	0	149,038	60.36	*	133,296	83.99	*	0	0	0.00
Ceiling Load	6,559	-6,559		0	0.00	*	9,330	5.88	*	-21,443	0	0.00
Outside Air	0	0	0	53,025	21.47	*	0	0.00	*	0	-84,431	69.14
Fan Heat				24,426	9.89	*		0.00	*		24,426	-20.00
Fan Heat		0		0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	1,135			1,135	0.46	*	1,135	0.71	*	-6,999	-6,999	5.73
Exhaust Heat		0	0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0	-0.00	*		0.00	*		0	0.00
Grand Total==>	169,202	269	0	246,922	100.00	*	158,702	100.00	*	-62,040	-122,123	100.00

-----COOLING COIL SELECTION-----											-----AREAS-----		
	Total Capacity		Sens Cap.	Coil Airfl	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total	Glass (sf)	(%)
	(Tons)	(Mbh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor		
Main Clg	20.6	246.9	205.7	13,740	77.9	66.6	83.7	63.6	61.1	80.0	Part	12,515	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	12,515	0 0
Totals	20.6	246.9									Wall	4,970	0 0

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA		Type	Clg	Htg	
	(Mbh)	(cfm)	Deg F	Deg F	Vent	1,574	1,574	Clg Cfm/Sqft	11.5	SADB	65.2	76.2	
Main Htg	-121.3	13,740	68.0	76.2	Infil	0	0	Clg Cfm/Ton	667.72	Plenum	77.7	66.8	
Aux Htg	0.0	0	0.0	0.0	Supply	13,740	13,740	Clg Sqft/Ton	608.21	Return	76.0	72.0	
Preheat	-0.0	13,740	66.3	63.6	Mincfm	0	0	Clg Btuh/Sqft	19.73	Ret/OA	77.9	66.3	
Reheat	0.0	0	0.0	0.0	Return	13,740	13,740	No. People	79	Runarnd	76.0	72.0	
Humidif	0.0	0	0.0	0.0	Exhaust	1,574	1,574	Htg % OA	11.5	Fn MtrTD	0.4	0.4	
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg Cfm/SqFt	1.10	Fn BldTD	0.3	0.3	
Totals	-121.3				Auxil	0	0	Htg Btuh/SqFt	-9.70	Fn Frict	0.9	0.9	

System 2 Block FC - FAN COIL

***** COOLING COIL PEAK ***** CLG SPACE PEAK ***** HEATING COIL PEAK *****

COOLING COIL PEAK						CLG SPACE PEAK			HEATING COIL PEAK		
Peaked at Time ==> Mo/Hr: 8/15						Mo/Hr: 6/16			Mo/Hr: 13/ 1		
Outside Air ==> OADB/WB/HR: 92/ 74/105.0						OADB: 96			OADB: 22		
Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	Space Sensible (Btuh)	Perct Of Tot (%)	Space Peak (Btuh)	Coil Peak (Btuh)	Perct Of Tot (%)		
Envelope Loads											
Skylite Solr	0	0	0	0.00	0	0.00	0	0	0.00		
Skylite Cond	0	0	0	0.00	0	0.00	0	0	0.00		
Roof Cond	0	1,977	1,977	0.45	0	0.00	0	-6,972	3.36		
Glass Solar	0	0	0	0.00	0	0.00	0	0	0.00		
Glass Cond	0	0	0	0.00	0	0.00	0	0	0.00		
Wall Cond	22,658	5,391	28,049	6.45	27,322	9.47	-55,533	-68,671	33.07		
Partition	0	0	0	0.00	0	0.00	0	0	0.00		
Exposed Floor	0	0	0	0.00	0	0.00	0	0	0.00		
Infiltration	0	0	0	0.00	0	0.00	0	0	0.00		
Sub Total==>	22,658	7,368	30,026	6.90	27,322	9.47	-55,533	-75,643	36.43		
Internal Loads											
Lights	140,407	0	140,407	32.27	140,407	48.65	0	0	0.00		
People	66,914	0	66,914	15.38	37,175	12.88	0	0	0.00		
Misc	74,238	0	74,238	17.06	74,238	25.72	0	0	0.00		
Sub Total==>	281,559	0	281,559	64.72	251,819	87.25	0	0	0.00		
Ceiling Load	7,368	-7,368	0	0.00	9,462	3.28	-20,110	0	0.00		
Outside Air	0	0	95,977	22.06	0	0.00	0	-159,505	76.81		
Sup. Fan Heat			27,489	6.32		0.00		27,489	-13.2		
Ret. Fan Heat		0	0	0.00		0.00		0	0.00		
Duct Heat PkUp		0	0	0.00		0.00		0	0.00		
OV/UNDR Sizing	0		0	0.00	0	0.00	0	0	0.00		
Exhaust Heat		0	0	0.00		0.00		0	0.00		
Terminal Bypass		0	0	-0.00		0.00		0	0.00		
Grand Total==>	311,585	0	435,051	100.00	288,604	100.00	-75,643	-207,660	100.00		

-----COOLING COIL SELECTION-----

-----AREAS-----

	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)
Main Clg	36.3	435.1	361.3	78.3	67.0	85.3	65.0	61.9	81.5	23,643		
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Totals	36.3	435.1								5,894	0	0
										8,215	0	0

-----HEATING COIL SELECTION-----

-----AIRFLOWS (cfm)-----

-----ENGINEERING CHECKS-----

-----TEMPERATURES (F)-----

Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA	11.5	Type	Clg	Htg
Main Htg	-207.7	25,771	67.2	74.7	2,974	2,974	Clg Cfm/Sqft	1.09	SADB	65.6	74.7
Aux Htg	0.0	0	0.0	0.0	25,771	25,771	Clg Cfm/Ton	710.84	Plenum	77.0	69.3
Preheat	-0.0	25,771	67.2	65.6	0	0	Clg Sqft/Ton	652.14	Return	76.0	72.0
Reheat	0.0	0	0.0	0.0	0	0	Clg Btuh/Sqft	18.40	Ret/OA	77.9	66.2
Humidif	0.0	0	0.0	0.0	25,771	25,771	No. People	149	Runarnd	76.0	72.0
Opt Vent	0.0	0	0.0	0.0	2,974	2,974	Htg % OA	11.5	Fn MtrTD	0.2	0.2
Total	-207.7				0	0	Htg Cfm/Sqft	1.09	Fn BldTD	0.2	0.2
					0	0	Htg Btuh/Sqft	-8.78	Fn Frict	0.6	0.6

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 M181 - BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room 3

Space	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	65.8	59.1	82.7	31.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	65.8	59.1	82.7	31.2	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	77.9	66.9	57.2	85.3	32.0	
Blow through Fan						0.4
Entering Coil	78.3	67.0	56.4	85.3	32.1	
Leaving Coil	65.0	61.9	84.5	81.4	28.3	
Draw Through Fan						0.0
Duct Frictional Heat						0.6
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	65.6	62.1	82.9	81.4	28.4	
Supply Air	65.6	62.1	82.9	81.4	28.4	
Percent Outside Air		11.54	(%)			
Sensible Heat Ratio (SHR)		0.907				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		25,771	(cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 M181 - BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)								Room Mass (lb/sqft)	Room Capac. (Btu/sqft/F)	
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Roof	Summr Windo	Wintr Windo	Wall			Ceil.
1	OFFICE	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	33.4	13.13
Zone	1 Total/Ave.	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	33.4	13.13
2	OFFICE	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	28.5	12.14
Zone	2 Total/Ave.	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	28.5	12.14
System	1 Total/Ave.	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	31.3	12.71
3	OFFICE	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	19.7	7.40
Zone	3 Total/Ave.	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	19.7	7.40
System	2 Total/Ave.	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	19.7	7.40
Building		0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.169	0.317	23.7	9.24

BUILDING AREAS - ALTERNATIVE 1
 - BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room	Total Floor Area	Partition Area	Exposed Floor Area	Skylight Area	Skl /Rf	Net Roof Area	Window Area	Win /Wl	Net Wall Area
		Flr	Rm	(sqft)	(sqft)	(sqft)	(sqft)	(sqft)	(%)	(sqft)	(sqft)	(%)	(sqft)
1	OFFICE	1	1	7,174	7,174	0	0	0	0	7,174	0	0	3,368
Zone	1 Total/Ave.				7,174	0	0	0	0	7,174	0	0	3,368
2	OFFICE	1	1	5,341	5,341	0	0	0	0	5,341	0	0	1,602
Zone	2 Total/Ave.				5,341	0	0	0	0	5,341	0	0	1,602
System	1 Total/Ave.				12,515	0	0	0	0	12,515	0	0	4,970
3	OFFICE	1	1	23,643	23,643	0	0	0	0	5,894	0	0	8,215
Zone	3 Total/Ave.				23,643	0	0	0	0	5,894	0	0	8,215
System	2 Total/Ave.				23,643	0	0	0	0	5,894	0	0	8,215
Building					36,158	0	0	0	0	18,409	0	0	13,185

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
 M181 - BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.025 (Btu/Hr/Sq Ft/F)
 Overall Wall U-Value = 0.169 (Btu/Hr/Sq Ft/F)
 Overall Building U-Value = 0.085 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 0.47 (Btu/Hr/Sq Ft)
 Wall Overall Thermal Transfer Value (OTTVw) = 6.53 (Btu/Hr/Sq Ft)

‡

SYSTEM LOAD PROFILE - ALTERNATIVE 1

Main System 1 MZ MULTIZONE

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.0	5	196	-6,067	7	102	687.0	0	0	0.0	0	0
5 - 10	2.1	7	273	-12,134	8	126	1,374.0	0	0	0.0	0	0
10 - 15	3.1	4	159	-18,201	7	102	2,060.9	0	0	0.0	0	0
15 - 20	4.1	11	446	-24,268	8	112	2,747.9	0	0	0.0	0	0
20 - 25	5.1	9	369	-30,335	9	138	3,434.9	0	0	0.0	0	0
25 - 30	6.2	4	172	-36,402	11	163	4,121.9	0	0	0.0	0	0
30 - 35	7.2	7	275	-42,469	12	177	4,808.9	0	0	0.0	0	0
35 - 40	8.2	6	268	-48,536	13	191	5,495.8	0	0	0.0	0	0
40 - 45	9.3	9	373	-54,603	7	104	6,182.8	0	0	0.0	0	0
45 - 50	10.3	4	166	-60,670	5	73	6,869.8	0	0	0.0	0	0
50 - 55	11.3	7	270	-66,737	4	55	7,556.8	0	0	0.0	0	0
55 - 60	12.3	6	240	-72,804	4	58	8,243.8	0	0	0.0	0	0
60 - 65	13.4	7	292	-78,871	4	65	8,930.7	0	0	0.0	0	0
65 - 70	14.4	7	300	-84,939	1	18	9,617.7	0	0	0.0	0	0
70 - 75	15.4	4	151	-91,006	0	0	10,304.7	0	0	0.0	0	0
75 - 80	16.5	5	195	-97,073	0	0	10,991.7	0	0	0.0	0	0
80 - 85	17.5	0	0	-103,140	0	0	11,678.7	0	0	0.0	0	0
85 - 90	18.5	0	0	-109,207	0	0	12,365.6	0	0	0.0	0	0
90 - 95	19.5	0	0	-115,274	0	0	13,052.6	0	0	0.0	0	0
95 - 100	20.6	0	0	-121,341	0	0	13,739.6	100	8,760	0.0	0	0
Hours Off	0.0	0	4,615	0	0	7,276	0.0	0	0	0.0	0	8,760

Main System 2 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.8	6	243	-10,383	4	71	1,288.5	0	0	0.0	0	0
5 - 10	3.6	5	181	-20,766	9	149	2,577.1	0	0	0.0	0	0
10 - 15	5.4	14	553	-31,149	8	133	3,865.6	0	0	0.0	0	0
15 - 20	7.3	10	373	-41,532	7	120	5,154.2	0	0	0.0	0	0
20 - 25	9.1	6	227	-51,915	4	74	6,442.7	0	0	0.0	0	0
25 - 30	10.9	5	199	-62,298	9	154	7,731.3	0	0	0.0	0	0
30 - 35	12.7	7	279	-72,681	9	157	9,019.8	0	0	0.0	0	0
35 - 40	14.5	6	241	-83,064	9	161	10,308.3	0	0	0.0	0	0
40 - 45	16.3	3	125	-93,447	13	232	11,596.9	0	0	0.0	0	0
45 - 50	18.1	6	234	-103,830	9	154	12,885.4	0	0	0.0	0	0
50 - 55	19.9	3	127	-114,213	8	134	14,174.0	0	0	0.0	0	0
55 - 60	21.8	3	129	-124,596	4	70	15,462.5	0	0	0.0	0	0
60 - 65	23.6	7	256	-134,979	4	66	16,751.1	0	0	0.0	0	0
65 - 70	25.4	6	235	-145,362	4	68	18,039.6	0	0	0.0	0	0
70 - 75	27.2	5	190	-155,745	0	0	19,328.2	0	0	0.0	0	0
75 - 80	29.0	3	108	-166,128	0	0	20,616.7	0	0	0.0	0	0
80 - 85	30.8	5	195	-176,511	0	0	21,905.2	0	0	0.0	0	0
85 - 90	32.6	0	0	-186,894	0	0	23,193.8	0	0	0.0	0	0
90 - 95	34.4	0	0	-197,277	0	0	24,482.3	0	0	0.0	0	0
95 - 100	36.3	0	0	-207,660	0	0	25,770.9	100	8,760	0.0	0	0
Hours Off	0.0	0	4,865	0	0	7,017	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1

----- SYSTEM LOAD PROFILE -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow -----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	2.8	9	388	-16,450	7	127	1,975.5	0	0	0.0	0	0
5 - 10	5.7	5	187	-32,900	11	200	3,951.0	0	0	0.0	0	0
10 - 15	8.5	10	418	-49,350	7	132	5,926.6	0	0	0.0	0	0
15 - 20	11.4	9	379	-65,800	9	165	7,902.1	0	0	0.0	0	0
20 - 25	14.2	8	313	-82,250	5	86	9,877.6	0	0	0.0	0	0
25 - 30	17.0	5	209	-98,700	8	151	11,853.1	0	0	0.0	0	0
30 - 35	19.9	6	248	-115,150	7	126	13,828.7	0	0	0.0	0	0
35 - 40	22.7	8	324	-131,600	13	231	15,804.2	0	0	0.0	0	0
40 - 45	25.6	5	215	-148,050	11	188	17,779.7	0	0	0.0	0	0
45 - 50	28.4	4	184	-164,500	6	111	19,755.2	0	0	0.0	0	0
50 - 55	31.3	4	172	-180,950	5	96	21,730.8	0	0	0.0	0	0
55 - 60	34.1	4	171	-197,400	2	43	23,706.3	0	0	0.0	0	0
60 - 65	36.9	5	214	-213,850	5	86	25,681.8	0	0	0.0	0	0
65 - 70	39.8	8	320	-230,300	2	37	27,657.3	0	0	0.0	0	0
70 - 75	42.6	4	150	-246,750	0	0	29,632.8	0	0	0.0	0	0
75 - 80	45.5	4	152	-263,200	0	0	31,608.4	0	0	0.0	0	0
80 - 85	48.3	3	106	-279,651	0	0	33,583.9	0	0	0.0	0	0
85 - 90	51.1	0	0	-296,101	0	0	35,559.4	0	0	0.0	0	0
90 - 95	54.0	0	0	-312,551	0	0	37,534.9	0	0	0.0	0	0
95 - 100	56.8	0	0	-329,001	0	0	39,510.5	100	8,760	0.0	0	0
Hours Off	0.0	0	4,610	0	0	6,981	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

January		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-198,780	0.0	-42,916	0.0	-82,043	0.0	-200,606	0.0	-205,828	0.0
2	32.1	29.3	-196,597	0.0	-73,225	0.0	-106,692	0.0	-209,477	0.0	-214,122	0.0
3	31.7	29.3	-194,762	0.0	-95,514	0.0	-123,957	0.0	-213,159	0.0	-217,295	0.0
4	31.9	29.5	-192,941	0.0	-111,813	0.0	-135,995	0.0	-213,492	0.0	-217,177	0.0
5	32.6	30.3	-190,340	0.0	-123,135	0.0	-143,701	0.0	-211,103	0.0	-214,389	0.0
6	33.6	31.3	-185,000	0.0	-130,924	0.0	-148,419	0.0	-207,106	0.0	-210,039	0.0
7	35.0	32.6	-177,971	0.0	-134,721	0.0	-149,610	0.0	-200,766	0.0	-203,386	0.0
8	36.6	34.4	-151,442	0.0	-120,696	0.0	-148,583	0.0	-193,225	0.0	-180,356	0.0
9	38.5	36.3	-102,638	0.0	-85,048	0.0	-144,757	0.0	-183,760	0.0	-136,940	0.0
10	40.4	37.7	-51,666	0.0	-47,494	0.0	-139,889	0.0	-174,003	0.0	-92,680	0.0
11	42.3	38.7	-2,773	0.0	-13,309	0.0	-133,873	0.0	-163,745	0.0	-52,700	0.0
12	44.2	39.6	0	0.0	0	0.0	-126,619	0.0	-152,806	0.0	-16,765	0.0
13	45.8	40.5	0	0.0	0	0.0	-120,073	0.0	-143,057	0.0	-2,270	0.0
14	47.2	41.1	0	0.0	0	0.0	-113,822	0.0	-134,017	0.0	0	0.0
15	48.2	41.6	0	0.0	0	0.0	-109,186	0.0	-126,949	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	-105,705	0.0	-121,349	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	-104,689	0.0	-118,480	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	-106,903	0.0	-119,074	0.0	0	0.0
19	47.4	41.7	0	0.0	0	0.0	-114,438	0.0	-125,190	0.0	0	0.0
20	45.5	40.5	0	0.0	0	0.0	-125,681	0.0	-135,191	0.0	0	0.0
21	43.1	38.9	0	0.0	0	0.0	-140,100	0.0	-148,520	0.0	0	0.0
22	40.4	36.7	0	0.0	0	0.0	-156,547	0.0	-164,007	0.0	-8,775	0.0
23	37.7	34.3	0	0.0	-14,761	0.0	-173,247	0.0	-179,865	0.0	-39,751	0.0
24	35.3	32.3	0	0.0	-51,436	0.0	-188,342	0.0	-194,218	0.0	-73,069	0.0

February		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	-42,920	0.0	-3,550	0.0	-59,217	0.0	-177,219	0.0	-182,557	0.0
2	36.0	33.0	-61,182	0.0	-26,560	0.0	-84,807	0.0	-187,218	0.0	-191,970	0.0
3	34.7	31.8	-76,799	0.0	-57,149	0.0	-107,172	0.0	-196,148	0.0	-200,383	0.0
4	33.6	30.9	-89,943	0.0	-83,584	0.0	-126,579	0.0	-203,967	0.0	-207,744	0.0
5	32.8	30.1	-100,761	0.0	-105,738	0.0	-142,723	0.0	-210,108	0.0	-213,478	0.0
6	32.2	29.8	-107,564	0.0	-124,607	0.0	-156,450	0.0	-215,190	0.0	-218,199	0.0
7	32.1	29.6	-110,385	0.0	-138,651	0.0	-166,091	0.0	-217,353	0.0	-220,043	0.0
8	32.5	30.3	-93,578	0.0	-132,867	0.0	-171,746	0.0	-216,532	0.0	-203,728	0.0
9	33.9	31.6	-53,978	0.0	-101,135	0.0	-170,481	0.0	-209,656	0.0	-162,896	0.0
10	36.0	33.0	-9,944	0.0	-63,323	0.0	-164,178	0.0	-198,483	0.0	-117,215	0.0
11	38.5	34.8	0	0.0	-26,528	0.0	-154,566	0.0	-184,640	0.0	-73,645	0.0
12	41.3	36.5	0	0.0	0	0.0	-142,105	0.0	-168,501	0.0	-32,505	0.0
13	43.8	38.1	0	0.0	0	0.0	-130,534	0.0	-153,728	0.0	-6,680	0.0
14	45.9	39.5	0	0.0	0	0.0	-120,643	0.0	-141,046	0.0	0	0.0
15	47.2	40.4	0	0.0	0	0.0	-114,903	0.0	-132,871	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	-113,278	0.0	-129,119	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	-115,228	0.0	-129,209	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	-118,402	0.0	-130,753	0.0	0	0.0
19	46.2	39.9	0	0.0	0	0.0	-122,971	0.0	-133,895	0.0	0	0.0
20	45.1	39.7	0	0.0	0	0.0	-129,319	0.0	-138,991	0.0	0	0.0
21	43.8	39.2	0	0.0	0	0.0	-137,095	0.0	-145,666	0.0	0	0.0
22	42.3	38.3	0	0.0	0	0.0	-146,359	0.0	-153,963	0.0	-4,444	0.0
23	40.7	37.2	0	0.0	0	0.0	-156,468	0.0	-163,220	0.0	-28,285	0.0
24	39.1	35.8	0	0.0	-30,660	0.0	-166,772	0.0	-172,773	0.0	-56,073	0.0

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1

March			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6	-4,402	0.0	0	0.0	0	0.0	-89,546	0.0	-116,613	0.0
2	43.3	39.7	-15,236	0.0	0	0.0	0	0.0	-105,419	0.0	-129,661	0.0
3	41.6	38.6	-24,744	0.0	0	0.0	0	0.0	-118,925	0.0	-140,653	0.0
4	40.6	37.5	-35,026	0.0	0	0.0	0	0.0	-128,266	0.0	-147,750	0.0
5	40.2	37.3	-44,349	0.0	0	0.0	0	0.0	-134,020	0.0	-151,501	0.0
6	40.6	37.8	-49,338	0.0	0	0.0	0	0.0	-135,005	0.0	-150,697	0.0
7	41.6	39.0	-49,458	0.0	0	0.0	-7,276	0.0	-132,468	0.0	-146,561	0.0
8	43.3	40.7	-30,378	0.0	0	0.0	-17,446	0.0	-125,713	0.0	-123,165	0.0
9	45.4	42.5	0	0.0	0	0.0	-23,932	0.0	-116,342	0.0	-78,812	0.0
10	47.9	44.3	0	0.0	0	0.0	-26,898	0.0	-104,100	0.0	-31,140	0.0
11	50.6	45.5	0	0.0	0	0.0	-27,177	0.0	-90,095	0.0	0	0.0
12	53.3	46.8	0	0.0	0	0.0	-25,625	0.0	-75,477	0.0	0	0.0
13	55.8	48.5	0	0.0	0	0.0	-23,161	0.0	-61,484	0.0	0	0.0
14	58.0	49.6	0	0.0	0	0.0	-20,415	0.0	-48,845	0.0	0	0.0
15	59.6	50.3	0	0.0	0	0.0	-18,535	0.0	-41,565	0.0	0	0.0
16	60.7	50.9	0	0.0	0	0.0	-17,363	0.0	-36,847	0.0	0	0.0
17	61.0	50.9	0	0.0	0	0.0	-17,896	0.0	-34,380	0.0	0	0.0
18	60.7	50.7	0	0.0	0	0.0	-19,624	0.0	-33,571	0.0	0	0.0
19	59.6	50.7	0	0.0	0	0.0	-23,492	0.0	-35,292	0.0	0	0.0
20	58.0	50.5	0	0.0	0	0.0	-28,802	0.0	-43,167	0.0	0	0.0
21	55.8	49.4	0	0.0	0	0.0	-36,065	0.0	-55,355	0.0	0	0.0
22	53.3	47.8	0	0.0	0	0.0	-44,416	0.0	-69,592	0.0	0	0.0
23	50.6	45.9	0	0.0	0	0.0	-53,640	0.0	-85,349	0.0	0	0.0
24	47.9	43.8	0	0.0	0	0.0	-71,203	0.0	-101,441	0.0	0	0.0

April			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2	51.3	0	0.0	0	0.0	0	0.0	0	0.0	-11,904	0.0
4	52.9	50.2	0	0.0	0	0.0	0	0.0	0	0.0	-21,121	0.0
5	51.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	-28,965	0.0
6	51.2	49.2	0	0.0	0	0.0	0	0.0	0	0.0	-35,429	0.0
7	51.0	49.3	0	0.0	0	0.0	0	0.0	0	0.0	-39,940	0.0
8	51.6	49.9	0	0.0	0	0.0	0	0.0	0	0.0	-30,064	0.0
9	53.3	50.6	0	0.0	0	0.0	0	0.0	0	0.0	-2,337	0.0
10	55.9	51.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	59.0	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	62.4	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5	57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8	60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2	60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2	59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

May Hour	OADB OAWB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	56.8	0	11.4	0	6.0	0	6.1	0	6.1
2	64.5	60.4	0	53.8	0	9.8	0	4.7	0	4.7	0	4.7
3	62.7	59.1	0	47.6	0	5.7	0	3.4	0	3.4	0	3.4
4	61.2	58.1	0	42.2	0	2.3	0	2.3	0	2.3	0	2.3
5	60.0	57.1	0	37.7	0	1.4	0	1.4	0	1.4	0	1.4
6	59.3	56.6	0	34.0	0	0.8	0	0.8	0	0.8	0	0.8
7	59.0	56.5	0	31.1	0	0.6	0	0.6	0	0.6	0	0.6
8	59.5	56.6	0	30.1	0	16.5	0	0.6	0	0.6	0	16.5
9	60.9	56.6	0	31.5	0	18.3	0	0.8	0	0.8	0	18.3
10	63.0	57.2	0	33.4	0	20.6	0	1.7	0	1.7	0	20.6
11	65.7	58.1	0	35.6	0	23.2	0	3.2	0	3.2	0	23.4
12	68.7	59.8	0	38.7	0	25.6	0	4.7	0	4.7	0	25.6
13	71.7	61.6	0	39.3	0	27.5	0	6.1	0	6.1	0	27.5
14	74.5	63.4	0	39.8	0	29.4	0	7.6	0	7.6	0	29.4
15	76.6	64.8	0	41.4	0	32.7	0	9.0	0	9.0	0	32.7
16	78.0	65.6	0	42.1	0	35.0	0	10.1	0	10.1	0	35.0
17	78.5	65.6	0	40.7	0	35.4	0	11.0	0	11.0	0	35.4
18	78.2	65.8	0	38.3	0	34.0	0	11.4	0	11.4	0	34.0
19	77.5	65.6	0	35.2	0	31.1	0	11.5	0	11.5	0	31.1
20	76.3	66.1	0	31.8	0	28.5	0	11.4	0	11.4	0	28.5
21	74.8	67.2	0	28.9	0	27.3	0	11.4	0	11.4	0	27.3
22	73.0	66.4	0	26.3	0	21.1	0	11.4	0	11.4	0	21.1
23	70.9	65.4	0	24.0	0	11.5	0	10.2	0	10.2	0	11.5
24	68.7	64.0	0	15.0	0	8.0	0	8.2	0	8.2	0	8.0

June Hour	OADB OAWB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	14.8	0	15.8	0	13.7	0	13.5	0	13.5
2	71.2	66.1	0	13.5	0	14.5	0	11.3	0	11.4	0	11.4
3	69.7	65.2	0	12.6	0	9.7	0	9.7	0	9.8	0	9.8
4	68.5	64.3	0	11.9	0	8.0	0	8.1	0	8.1	0	8.1
5	67.8	64.2	0	11.5	0	6.9	0	6.9	0	6.9	0	6.9
6	67.6	64.2	0	11.3	0	6.8	0	6.8	0	6.8	0	6.8
7	68.1	64.8	0	11.6	0	7.1	0	7.1	0	7.1	0	7.1
8	69.4	65.7	0	28.4	0	27.5	0	7.7	0	7.7	0	27.5
9	71.6	66.2	0	31.5	0	28.3	0	9.0	0	9.0	0	28.3
10	74.2	67.2	0	35.5	0	32.4	0	10.4	0	10.4	0	32.4
11	77.2	68.5	0	39.5	0	34.7	0	12.1	0	12.1	0	34.7
12	80.2	70.0	0	42.3	0	38.1	0	14.5	0	14.5	0	38.1
13	82.8	70.8	0	42.9	0	39.1	0	16.6	0	16.6	0	39.1
14	85.0	71.6	0	44.4	0	40.6	0	18.0	0	18.0	0	40.6
15	86.3	72.3	0	46.9	0	44.7	0	20.0	0	20.0	0	44.7
16	86.8	72.1	0	46.7	0	45.1	0	20.4	0	20.4	0	45.1
17	86.6	71.7	0	44.9	0	44.5	0	20.4	0	20.4	0	44.5
18	85.8	71.5	0	42.5	0	42.5	0	20.7	0	20.7	0	42.5
19	84.7	71.2	0	38.9	0	39.2	0	20.5	0	20.5	0	39.2
20	83.2	71.5	0	35.2	0	37.5	0	20.9	0	20.9	0	37.5
21	81.4	71.7	0	32.5	0	35.4	0	20.4	0	20.4	0	35.4
22	79.3	71.4	0	30.1	0	32.8	0	19.0	0	19.0	0	32.8
23	77.2	70.5	0	28.1	0	25.5	0	17.7	0	17.7	0	25.5
24	75.1	69.1	0	23.4	0	18.8	0	15.4	0	15.4	0	18.8

ING COOL-HEAT DEMAND - ALTERNATIVE 1

July Hour	OADB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
	QAWB		Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0	69.3	0	16.3	0	17.5	0	13.6	0	14.1	0	14.1
2	70.5	68.0	0	13.9	0	13.7	0	12.3	0	12.4	0	12.4
3	69.4	67.1	0	12.8	0	10.4	0	10.7	0	10.7	0	10.7
4	68.5	66.4	0	12.2	0	9.3	0	9.4	0	9.4	0	9.4
5	67.9	66.0	0	11.9	0	8.6	0	8.6	0	8.6	0	8.6
6	67.7	65.9	0	11.8	0	8.1	0	8.1	0	8.1	0	8.1
7	68.1	66.3	0	12.5	0	8.0	0	8.0	0	8.0	0	8.0
8	69.1	67.3	0	30.8	0	30.1	0	8.5	0	8.5	0	30.1
9	70.8	68.0	0	32.5	0	30.7	0	10.2	0	10.2	0	30.7
10	72.9	69.1	0	37.7	0	35.3	0	12.1	0	12.1	0	35.3
11	75.2	70.5	0	40.3	0	37.0	0	13.7	0	13.7	0	37.0
12	77.5	71.7	0	43.6	0	40.3	0	15.9	0	15.9	0	40.3
13	79.6	72.7	0	44.7	0	41.0	0	17.9	0	17.9	0	41.0
14	81.3	73.5	0	45.8	0	43.6	0	19.9	0	19.9	0	43.6
15	82.3	73.7	0	48.3	0	46.6	0	21.4	0	21.4	0	46.6
16	82.7	73.5	0	48.1	0	46.4	0	21.3	0	21.3	0	46.4
17	82.5	73.1	0	46.1	0	45.9	0	21.2	0	21.2	0	45.9
18	82.0	72.6	0	43.4	0	44.2	0	21.3	0	21.3	0	44.2
19	81.1	73.2	0	39.9	0	40.9	0	21.4	0	21.4	0	40.9
20	79.9	73.8	0	36.7	0	39.3	0	21.7	0	21.7	0	39.3
21	78.5	73.9	0	34.2	0	38.6	0	22.0	0	22.0	0	38.6
22	76.9	73.1	0	31.9	0	35.2	0	20.4	0	20.4	0	35.2
23	75.2	71.9	0	30.0	0	25.0	0	18.6	0	18.6	0	25.0
24	73.5	70.8	0	22.4	0	19.0	0	16.5	0	16.5	0	19.0

August Hour	OADB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
	QAWB		Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7	70.2	0	16.8	0	18.7	0	14.7	0	15.1	0	15.1
2	71.2	69.0	0	13.8	0	14.1	0	13.1	0	13.1	0	13.1
3	69.9	68.0	0	12.6	0	11.4	0	11.7	0	11.7	0	11.7
4	68.8	67.1	0	12.0	0	10.0	0	10.0	0	10.0	0	10.0
5	68.0	66.6	0	11.6	0	8.8	0	8.8	0	8.8	0	8.8
6	67.5	66.2	0	12.2	0	8.2	0	8.2	0	8.2	0	8.2
7	67.3	66.1	0	12.9	0	7.7	0	7.7	0	7.7	0	7.7
8	67.8	66.5	0	30.8	0	29.6	0	7.8	0	7.8	0	29.6
9	69.1	67.0	0	33.8	0	28.6	0	8.6	0	8.6	0	28.6
10	71.2	67.8	0	38.0	0	32.8	0	10.0	0	10.0	0	32.8
11	73.8	68.7	0	40.2	0	34.8	0	11.6	0	11.6	0	34.8
12	76.5	70.0	0	42.4	0	38.2	0	13.9	0	13.9	0	38.2
13	79.1	71.2	0	43.0	0	39.1	0	15.9	0	15.9	0	39.1
14	81.1	72.6	0	45.6	0	41.8	0	18.1	0	18.1	0	41.8
15	82.5	73.6	0	48.5	0	44.8	0	19.7	0	19.7	0	44.8
16	83.0	73.7	0	48.1	0	46.1	0	20.7	0	20.7	0	46.1
17	82.8	73.5	0	47.4	0	46.0	0	21.1	0	21.1	0	46.0
18	82.3	73.5	0	43.8	0	44.1	0	21.4	0	21.4	0	44.1
19	81.5	73.1	0	39.9	0	40.9	0	21.3	0	21.3	0	40.9
20	80.4	73.7	0	36.7	0	39.3	0	21.6	0	21.6	0	39.3
21	79.1	74.9	0	35.3	0	38.7	0	22.0	0	22.0	0	38.7
22	77.6	73.9	0	32.2	0	36.7	0	21.4	0	21.4	0	36.7
23	76.0	72.7	0	29.8	0	24.4	0	19.3	0	19.3	0	24.4
24	74.3	71.3	0	22.0	0	18.6	0	16.8	0	16.8	0	18.6

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

September			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	QAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	69.8	66.1	0	12.4	0	11.4	0	9.8	0	9.9	0	9.9
2	68.0	64.5	0	10.1	0	7.4	0	8.3	0	8.3	0	8.3
3	66.3	63.0	0	9.2	0	6.3	0	6.5	0	6.5	0	6.5
4	64.9	61.9	0	8.5	0	4.9	0	5.1	0	5.1	0	5.1
5	63.9	61.3	0	8.1	0	3.8	0	3.8	0	3.8	0	3.8
6	63.2	61.0	0	8.0	0	3.2	0	3.2	0	3.2	0	3.2
7	63.0	60.8	0	8.1	0	2.7	0	2.7	0	2.7	0	2.7
8	63.4	61.4	0	24.3	0	21.7	0	2.6	0	2.6	0	21.7
9	64.7	61.8	0	28.5	0	22.9	0	3.1	0	3.1	0	22.9
10	66.6	62.1	0	32.9	0	25.5	0	4.1	0	4.1	0	25.5
11	69.1	62.9	0	35.5	0	27.8	0	5.4	0	5.4	0	27.8
12	71.8	63.7	0	37.6	0	29.9	0	6.9	0	6.9	0	29.9
13	74.5	65.5	0	38.3	0	31.6	0	8.4	0	8.4	0	31.6
14	77.0	67.1	0	39.5	0	33.5	0	10.2	0	10.2	0	33.5
15	78.9	68.2	0	42.0	0	37.6	0	12.4	0	12.4	0	37.6
16	80.2	68.6	0	41.9	0	39.6	0	14.1	0	14.1	0	39.6
17	80.6	68.5	0	41.4	0	39.7	0	15.0	0	15.0	0	39.7
18	80.4	68.9	0	38.6	0	37.9	0	15.4	0	15.4	0	37.9
19	79.7	70.0	0	34.9	0	36.0	0	16.1	0	16.1	0	36.0
20	78.7	71.2	0	32.0	0	34.8	0	16.9	0	16.9	0	34.8
21	77.3	71.6	0	29.4	0	34.0	0	17.3	0	17.3	0	34.0
22	75.6	70.5	0	27.0	0	28.2	0	16.0	0	16.0	0	28.2
23	73.7	69.4	0	24.1	0	17.4	0	14.3	0	14.3	0	17.4
24	71.8	67.7	0	15.8	0	11.8	0	12.4	0	12.4	0	11.8

October			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	QAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	54.8	51.3	0	1.2	0	0.0	0	0.0	0	0.0	0	0.1
2	52.9	49.6	0	0.6	0	0.0	0	0.0	0	0.0	0	0.0
3	51.2	48.2	0	0.4	0	0.0	0	0.0	0	0.0	0	0.0
4	49.8	47.2	0	0.2	0	0.0	0	0.0	0	0.0	0	0.0
5	48.8	46.2	0	0.2	0	0.0	0	0.0	0	0.0	0	0.0
6	48.2	45.7	0	0.3	0	0.0	0	0.0	0	0.0	0	0.0
7	47.9	45.6	0	0.4	0	0.0	0	0.0	0	0.0	0	0.0
8	48.5	46.2	0	14.7	0	0.0	0	0.0	0	0.0	0	0.0
9	50.3	47.3	0	18.2	0	9.3	0	0.0	0	0.0	0	0.0
10	52.9	48.7	0	20.9	0	14.2	0	0.0	0	0.0	0	5.1
11	56.2	49.9	0	23.6	0	16.8	0	0.2	0	0.4	0	13.7
12	59.6	51.5	0	26.0	0	19.3	0	0.7	0	0.8	0	17.9
13	62.9	53.5	0	27.6	0	21.2	0	1.2	0	1.3	0	20.0
14	65.5	55.2	0	28.8	0	22.7	0	1.6	0	1.7	0	21.7
15	67.3	56.3	0	30.1	0	24.4	0	1.8	0	1.9	0	23.5
16	67.9	56.6	0	30.9	0	25.7	0	1.9	0	2.0	0	24.9
17	67.7	56.4	0	30.9	0	26.1	0	1.9	0	2.0	0	25.4
18	67.0	56.6	0	29.5	0	25.2	0	1.8	0	1.9	0	24.6
19	66.0	57.6	0	26.6	0	22.9	0	1.6	0	1.7	0	22.4
20	64.6	57.9	0	23.4	0	20.2	0	1.4	0	1.5	0	19.7
21	62.9	57.3	0	20.6	0	11.1	0	1.2	0	1.3	0	7.0
22	61.0	56.0	0	14.2	0	1.6	0	0.9	0	1.0	0	1.6
23	59.0	54.8	0	5.2	0	0.6	0	0.6	0	0.7	0	0.6
24	56.9	53.0	0	2.2	0	0.2	0	0.3	0	0.4	0	0.2

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1

November			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	-187,676	0.0	0	0.0	0	0.0	-47,930	0.0	-86,373	0.0
2	46.9	44.1	-174,104	0.0	0	0.0	0	0.0	-56,730	0.0	-98,507	0.0
3	45.5	42.8	-162,591	0.0	0	0.0	0	0.0	-69,361	0.0	-108,442	0.0
4	44.6	41.9	-152,641	0.0	0	0.0	0	0.0	-80,812	0.0	-115,559	0.0
5	44.4	42.0	-142,556	0.0	0	0.0	0	0.0	-87,710	0.0	-118,632	0.0
6	44.8	42.7	-130,723	0.0	0	0.0	0	0.0	-90,761	0.0	-118,302	0.0
7	45.9	43.9	-116,903	0.0	0	0.0	0	0.0	-89,340	0.0	-113,889	0.0
8	47.8	46.0	-84,482	0.0	0	0.0	0	0.0	-82,808	0.0	-89,497	0.0
9	50.2	48.0	-29,902	0.0	0	0.0	0	0.0	-72,984	0.0	-43,622	0.0
10	52.9	49.9	0	0.0	0	0.0	0	0.0	-60,901	0.0	0	0.0
11	55.8	51.1	0	0.0	0	0.0	0	0.0	-49,915	0.0	0	0.0
12	58.5	52.0	0	0.0	0	0.0	0	0.0	-41,723	0.0	0	0.0
13	60.9	52.5	0	0.0	0	0.0	0	0.0	-33,889	0.0	0	0.0
14	62.8	53.4	0	0.0	0	0.0	0	0.0	-27,215	0.0	0	0.0
15	64.0	53.8	0	0.0	0	0.0	0	0.0	-22,381	0.0	0	0.0
16	64.4	53.9	0	0.0	0	0.0	0	0.0	-19,693	0.0	0	0.0
17	64.1	53.7	0	0.0	0	0.0	0	0.0	-18,993	0.0	0	0.0
18	63.2	53.7	0	0.0	0	0.0	0	0.0	-20,142	0.0	0	0.0
19	61.8	54.2	0	0.0	0	0.0	0	0.0	-23,027	0.0	0	0.0
20	60.0	53.6	0	0.0	0	0.0	0	0.0	-27,529	0.0	0	0.0
21	57.9	52.7	0	0.0	0	0.0	-4,464	0.0	-33,348	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	-15,744	0.0	-41,899	0.0	0	0.0
23	53.2	49.5	0	0.0	0	0.0	-27,028	0.0	-57,188	0.0	0	0.0
24	50.8	47.6	0	0.0	0	0.0	-38,047	0.0	-72,609	0.0	0	0.0
December			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	0	0.0	0	0.0	0	0.0	-165,453	0.0	-174,051	0.0
2	37.1	35.1	0	0.0	0	0.0	-9,156	0.0	-169,765	0.0	-177,419	0.0
3	37.4	35.5	0	0.0	0	0.0	-25,665	0.0	-170,064	0.0	-176,884	0.0
4	38.1	36.2	0	0.0	0	0.0	-43,155	0.0	-168,180	0.0	-174,261	0.0
5	39.3	37.6	0	0.0	0	0.0	-54,536	0.0	-163,383	0.0	-168,809	0.0
6	40.9	39.2	0	0.0	-6,966	0.0	-61,358	0.0	-156,224	0.0	-161,070	0.0
7	42.7	41.2	0	0.0	-18,230	0.0	-65,054	0.0	-147,828	0.0	-152,158	0.0
8	44.7	43.1	0	0.0	-14,634	0.0	-65,787	0.0	-138,093	0.0	-126,755	0.0
9	46.8	45.3	0	0.0	0	0.0	-64,313	0.0	-127,546	0.0	-82,098	0.0
10	48.8	47.0	0	0.0	0	0.0	-61,812	0.0	-117,172	0.0	-37,079	0.0
11	50.7	48.1	0	0.0	0	0.0	-58,221	0.0	-106,771	0.0	0	0.0
12	52.2	48.8	0	0.0	0	0.0	-55,326	0.0	-98,049	0.0	0	0.0
13	53.4	49.2	0	0.0	0	0.0	-53,375	0.0	-90,405	0.0	0	0.0
14	54.1	49.2	0	0.0	0	0.0	-52,240	0.0	-85,255	0.0	0	0.0
15	54.4	48.9	0	0.0	0	0.0	-53,131	0.0	-82,116	0.0	0	0.0
16	54.0	48.2	0	0.0	0	0.0	-57,307	0.0	-82,858	0.0	0	0.0
17	53.0	47.3	0	0.0	0	0.0	-64,351	0.0	-86,898	0.0	0	0.0
18	51.4	46.3	0	0.0	0	0.0	-74,477	0.0	-94,395	0.0	0	0.0
19	49.3	45.4	0	0.0	0	0.0	-87,477	0.0	-105,090	0.0	0	0.0
20	47.0	43.5	0	0.0	0	0.0	-101,851	0.0	-117,442	0.0	0	0.0
21	44.5	41.5	0	0.0	0	0.0	-117,704	0.0	-131,519	0.0	0	0.0
22	42.2	39.3	0	0.0	0	0.0	-132,583	0.0	-144,836	0.0	0	0.0
23	40.1	37.6	0	0.0	0	0.0	-146,541	0.0	-157,420	0.0	-5,553	0.0
24	38.5	36.2	0	0.0	0	0.0	-157,720	0.0	-167,387	0.0	-14,546	0.0

BUILDING TEMPERATURE PROFILES - ALTERNATIVE 1

----- B U I L D I N G T E M P E R A T U R E P R O F I L E S -----

Temperature ----- Room Number -----

Range (F)	1	2	3
Max. Temp.	88.3	88.9	93.0
Mo./Hr.	4 18	4 18	4 18
Day Type	2	2	2

----- Number of Hours -----

Above 100	0	0	0
95 - 100	0	0	0
90 - 95	0	0	176
85 - 90	238	291	430
80 - 85	880	945	1,171
75 - 80	2,105	2,092	1,437
70 - 75	3,106	2,976	2,907
65 - 70	2,431	2,456	2,639
60 - 65	0	0	0
55 - 60	0	0	0
50 - 55	0	0	0
Below 50	0	0	0
Min. Temp.	67.7	67.9	66.9
Mo./Hr.	10 7 10	7 10 11	
Day Type	5	5	4

†

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	46,717	130	755	3
Feb	42,147	130	649	3
March	47,770	130	179	2
April	43,809	127	8	0
May	65,779	188	0	0
June	72,879	202	0	0
July	72,592	198	0	0
Aug	76,028	198	0	0
Sept	65,904	189	0	0
Oct	56,362	171	0	0
Nov	44,247	130	149	2
Dec	45,414	130	382	2
Total	679,649	202	2,122	3

Building Energy Consumption = 70,021 (Btu/Sq Ft/Year)
Source Energy Consumption = 198,655 (Btu/Sq Ft/Year)

Floor Area = 36,158 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M181 - BASELINE

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2 EQ4003	FC CENTRIF. FAN C.V.												
ELEC	12309	11118	12309	11912	12309	11912	12309	12309	11912	12309	11912	12309	144,933
PK	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5
2 EQ4003	FC CENTRIF. FAN C.V.												
ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER												
GAS	755	649	179	8	0	0	0	0	0	0	149	382	2,122
PK	2.6	2.6	1.8	0.5	0.0	0.0	0.0	0.0	0.0	0.0	2.3	2.1	2.6
1 EQ5020	HEAT WATER CIRC. PUMP C.V.												
ELEC	777	652	310	36	0	0	0	0	0	0	318	512	2,604
PK	1.5	1.5	1.5	1.5	0.0	0.0	0.0	0.0	0.0	0.0	1.5	1.5	1.5
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	171	144	68	8	0	0	0	0	0	0	70	113	574
PK	0.3	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3
1 EQ5307	BOILER CONTROLS												
ELEC	260	219	104	12	0	0	0	0	0	0	107	172	873
PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BASELINE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 202.2 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	74.8	36.98
Sub Total			74.8	36.98
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			14.7	7.27
SUMMATION OF FAN ELECTRICAL DEMAND			16.5	8.18
Sub Total			31.2	15.45
Sub Total			0.0	0.00
Miscellaneous				
Lights			62.9	31.12
Base Utilities			0.0	0.00
Misc Equipment			33.3	16.45
Sub Total			96.2	47.57
Grand Total			202.2	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M181 - BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 36,158
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,447.4	212,180.3	8.6	238,169.5	6.8
Primary Cooling					
Compressor	75,559.2	0.0	10.2	773,727.6	21.9
Tower/Cond Fans	9,326.4	0.0	1.3	95,502.4	2.7
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,194.3	0.0	0.2	12,229.7	0.3
Auxiliary					
Supply Fans	273,717.4	0.0	36.9	2,802,872.7	79.5
Circulation Pumps	52,081.3	0.0	7.0	533,313.6	15.1
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	325,798.7	0.0	43.9	3,336,186.2	94.6
Lighting	174,211.4	0.0	23.5	1,783,928.9	49.3
Receptacle	92,111.7	0.0	12.4	943,226.3	26.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	679,649.1	212,180.3	100.0	7,182,970.5	201.7

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1

--- BASELINE --- *2000*

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	46,738	130	755	3
Feb	42,164	130	649	3
March	47,769	130	179	2
April	43,810	127	8	0
May	61,548	188	0	0
June	72,624	202	0	0
July	72,280	198	0	0
Aug	75,684	198	0	0
Sept	63,604	189	0	0
Oct	52,263	170	0	0
Nov	44,256	130	151	2
Dec	45,388	130	382	2
Total	668,127	202	2,123	3

Building Energy Consumption = 68,938 (Btu/Sq Ft/Year)
 Source Energy Consumption = 195,396 (Btu/Sq Ft/Year)

Floor Area = 36,158 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M181 - BASELINE

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2 EQ4003													
ELEC	12309	11118	12309	11912	12309	11912	12309	12309	11912	12309	11912	12309	144,933
PK	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5
2 EQ4003													
ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001													
GAS	755	649	179	8	0	0	0	0	0	0	151	382	2,123
PK	2.6	2.6	1.8	0.5	0.0	0.0	0.0	0.0	0.0	0.0	2.5	2.1	2.6
1 EQ5020													
ELEC	777	652	304	36	0	0	0	0	0	0	318	486	2,573
PK	1.5	1.5	1.5	1.5	0.0	0.0	0.0	0.0	0.0	0.0	1.5	1.5	1.5
1 EQ5240													
ELEC	192	161	75	9	0	0	0	0	0	0	79	120	636
PK	0.4	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4
1 EQ5307													
ELEC	260	219	102	12	0	0	0	0	0	0	107	163	863
PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 - BASELINE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 202.2 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	74.8	36.98
Sub Total			74.8	36.98
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			14.7	7.27
SUMMATION OF FAN ELECTRICAL DEMAND			16.5	8.18
Sub Total			31.2	15.45
Sub Total			0.0	0.00
Miscellaneous				
Lights			62.9	31.12
Base Utilities			0.0	0.00
Misc Equipment			33.3	16.45
Sub Total			96.2	47.57
Grand Total			202.2	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M181 --BASELINE *Case No. 911207*

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 36,158
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,498.6	212,332.9	8.7	238,853.9	6.8
Primary Cooling					
Compressor	70,012.3	0.0	9.6	716,927.6	20.3
Tower/Cond Fans	8,804.4	0.0	1.2	90,156.8	2.6
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,065.3	0.0	0.1	10,908.7	0.3
Auxiliary					
Supply Fans	273,717.4	0.0	37.5	2,802,872.7	79.5
Circulation Pumps	46,705.8	0.0	6.4	478,268.2	13.6
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	320,423.2	0.0	43.9	3,281,141.0	93.0
Lighting	174,211.4	0.0	23.9	1,783,928.9	49.3
Receptacle	92,111.7	0.0	12.6	943,226.3	26.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	668,126.9	212,332.9	100.0	7,065,143.5	198.4

‡

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
MONTHLY WALL INSULATION

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	46,388	130	413	2
Feb	41,767	130	337	2
March	47,528	130	72	1
April	43,708	127	0	0
May	65,702	188	0	0
June	71,519	199	0	0
July	71,334	194	0	0
Aug	74,800	195	0	0
Sept	65,170	186	0	0
Oct	56,864	170	0	0
Nov	43,946	130	36	2
Dec	45,024	130	181	2
Total	673,750	199	1,039	2

Building Energy Consumption = 66,469 (Btu/Sq Ft/Year)
Source Energy Consumption = 193,832 (Btu/Sq Ft/Year)

Floor Area = 36,158 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M181 - WALL INSULATION

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
2 EQ4003	FC CENTRIF. FAN C.V.														
ELEC	12309	11118	12309	11912	12309	11912	12309	12309	11912	12309	11912	12309	11912	12309	144,933
PK	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5
2 EQ4003	FC CENTRIF. FAN C.V.														
ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER														
GAS	413	337	72	0	0	0	0	0	0	0	0	36	181	1,039	
PK	2.1	2.1	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.6	1.6	2.1	
1 EQ5020	HEAT WATER CIRC. PUMP C.V.														
ELEC	614	449	191	0	0	0	0	0	0	0	0	158	300	1,712	
PK	1.5	1.5	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.5	1.5	1.5	
1 EQ5240	BOILER FORCED DRAFT FAN														
ELEC	106	77	33	0	0	0	0	0	0	0	0	27	52	295	
PK	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3	
1 EQ5307	BOILER CONTROLS														
ELEC	206	150	64	0	0	0	0	0	0	0	0	53	100	574	
PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 NET - WALL INSULATION

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 198.8 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	71.4	35.93
Sub Total			71.4	35.93
Sub Total			0.0	0.00
Air Moving Equipment				
		SUMMATION OF FAN ELECTRICAL DEMAND	14.6	7.36
2		SUMMATION OF FAN ELECTRICAL DEMAND	16.5	8.32
Sub Total			31.2	15.69
Sub Total			0.0	0.00
Miscellaneous				
		Lights	62.9	31.65
		Base Utilities	0.0	0.00
		Misc Equipment	33.3	16.73
Sub Total			96.2	48.38
Grand Total			198.8	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M181 - WALL INSULATION

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 36,158
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	869.1	103,892.7	4.4	118,260.3	3.4
Primary Cooling					
Compressor	71,747.6	0.0	10.2	734,696.8	20.8
Tower/Cond Fans	8,866.2	0.0	1.3	90,790.2	2.6
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,203.6	0.0	0.2	12,324.9	0.3
Auxiliary					
Supply Fans	273,166.2	0.0	38.8	2,797,228.8	79.3
Circulation Pumps	51,574.7	0.0	7.3	528,126.3	15.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	324,741.0	0.0	46.1	3,325,355.2	94.3
Lighting	174,211.4	0.0	24.7	1,783,928.9	49.3
Receptacle	92,111.7	0.0	13.1	943,226.3	26.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	673,750.6	103,892.7	100.0	7,008,583.0	196.8

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 - HVAC CONTROLS

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	30,401	130	56	4
Feb	27,497	130	43	4
March	32,683	127	2	0
April	28,755	127	0	0
May	41,947	206	0	0
June	45,978	210	0	0
July	42,311	205	0	0
Aug	47,529	206	0	0
Sept	39,346	196	0	0
Oct	37,865	177	0	0
Nov	28,755	127	0	0
Dec	28,885	127	1	0
Total	431,952	210	103	4

Building Energy Consumption = 41,058 (Btu/Sq Ft/Year)
 Source Energy Consumption = 122,630 (Btu/Sq Ft/Year)

Floor Area = 36,158 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 HGT - HVAC CONTROLS

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 209.8 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	82.3	39.25
Sub Total			82.3	39.25
Sub Total			0.0	0.00
Air Moving Equipment				
		SUMMATION OF FAN ELECTRICAL DEMAND	14.7	7.01
2		SUMMATION OF FAN ELECTRICAL DEMAND	16.5	7.89
Sub Total			31.2	14.90
Sub Total			0.0	0.00
Miscellaneous				
Lights			62.9	29.99
Base Utilities			0.0	0.00
Misc Equipment			33.3	15.86
Sub Total			96.2	45.85
Grand Total			209.8	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M181 - HVAC CONTROLS

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 36,158
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	199.1	10,306.4	0.7	12,887.5	0.4
Primary Cooling					
Compressor	46,265.9	0.0	10.6	473,763.9	13.4
Tower/Cond Fans	5,385.4	0.0	1.2	55,146.2	1.6
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	446.7	0.0	0.1	4,574.2	0.1
Auxiliary					
Supply Fans	94,488.7	0.0	21.7	967,566.4	27.4
Circulation Pumps	18,842.9	0.0	4.3	192,951.6	5.5
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	113,331.6	0.0	26.1	1,160,518.0	32.9
Lighting	174,211.4	0.0	40.1	1,783,928.9	49.3
Receptacle	92,111.7	0.0	21.2	943,226.3	26.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	431,951.7	10,306.4	100.0	4,434,045.0	123.8

†

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
WITH ICE STORAGE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	46,717	130	755	3
Feb	42,147	130	649	3
March	47,770	130	179	2
April	43,809	127	8	0
May	71,097	190	0	0
June	78,873	197	0	0
July	78,961	197	0	0
Aug	82,473	195	0	0
Sept	71,817	190	0	0
Oct	59,640	177	0	0
Nov	44,247	133	149	2
Dec	45,414	130	382	2
Total	712,966	197	2,122	3

Building Energy Consumption = 73,166 (Btu/Sq Ft/Year)
Source Energy Consumption = 208,091 (Btu/Sq Ft/Year)

Floor Area = 36,158 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M181 - ICE STORAGE

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2 EQ4003	FC CENTRIF. FAN C.V.												
ELEC	12309	11118	12309	11912	12309	11912	12309	12309	11912	12309	11912	12309	144,933
PK	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5	16.5
2 EQ4003	FC CENTRIF. FAN C.V.												
ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER												
GAS	755	649	179	8	0	0	0	0	0	0	149	382	2,122
PK	2.6	2.6	1.8	0.5	0.0	0.0	0.0	0.0	0.0	0.0	2.3	2.1	2.6
1 EQ5020	HEAT WATER CIRC. PUMP C.V.												
ELEC	777	652	310	36	0	0	0	0	0	0	318	512	2,604
PK	1.5	1.5	1.5	1.5	0.0	0.0	0.0	0.0	0.0	0.0	1.5	1.5	1.5
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	171	144	68	8	0	0	0	0	0	0	70	113	574
PK	0.3	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3
1 EQ5307	BOILER CONTROLS												
ELEC	260	219	104	12	0	0	0	0	0	0	107	172	873
PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 H2O - ICE STORAGE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 196.5 (kW)
 Yearly Time of Peak 12 (hr) 7 (mo)

Hour 12 Month 7

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1750	AIR-CLD CTV ICE-CHILL H2O	69.1	35.17
Sub Total			69.1	35.17
Sub Total			0.0	0.00
Air Moving Equipment				
		SUMMATION OF FAN ELECTRICAL DEMAND	14.7	7.48
2		SUMMATION OF FAN ELECTRICAL DEMAND	16.5	8.42
Sub Total			31.2	15.90
Sub Total			0.0	0.00
Miscellaneous				
Lights			62.9	32.01
Base Utilities			0.0	0.00
Misc Equipment			33.3	16.93
Sub Total			96.2	48.94
Grand Total			196.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M181 - ICE STORAGE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 36,158
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,447.4	212,180.3	8.2	238,169.5	6.8
Primary Cooling					
Compressor	106,413.2	0.0	13.7	1,089,674.0	30.9
Tower/Cond Fans	9,660.4	0.0	1.2	98,923.2	2.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,932.0	0.0	0.5	40,263.8	1.1
Auxiliary					
Supply Fans	273,717.4	0.0	35.3	2,802,872.7	79.5
Circulation Pumps	51,472.3	0.0	6.6	527,077.6	14.9
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	325,189.7	0.0	42.0	3,329,950.0	94.4
Lighting	174,211.4	0.0	22.5	1,783,928.9	49.3
Receptacle	92,111.7	0.0	11.9	943,226.3	26.1
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	712,966.0	212,180.3	100.0	7,524,136.0	211.4

‡

BUILDING 184

EMC ENGINEERS, INC.

PROJECT: FORT MCPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT MCPHERSON
 ECO: Computer Simulation Summary

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

EMC PROJECT: #3105.000
 DATE: 04/21/92
 FILE: M184ECO
 PREPARED BY: DENNIS JONES
 CHECKED BY:

Bldg: M184 Area: 36,158 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Receipt. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	127,447	1,015	61,504	137,786	23,652	158,493	92,865	475,315	180	127	1,750
Insulated Glass	86,309	850	59,744	137,786	23,652	158,493	92,865	473,390	176	86	1,702
Savings (Loss)	41,138	165	1,760	0	0	0	0	1,925	4	41	48
Economizer	127,447	1,015	56,767	137,786	23,652	158,493	92,865	470,578	180	127	1,734
Savings (Loss)	0	0	4,737	0	0	0	0	4,737	0	0	16
HW Pump	7,849	63	61,504	137,786	18,359	158,493	92,865	469,070	180	8	1,609
Savings (Loss)	119,598	952	0	0	5,293	0	0	6,245	0	120	141
HVAC Controls	7,849	63	54,264	47,565	5,788	158,493	92,865	359,038	179	8	1,233
Savings (Loss)	119,598	952	7,240	90,221	17,864	0	0	116,277	1	120	516
Ice Storage	127,447	1,015	81,361	137,786	23,652	158,493	92,865	495,172	114	127	1,817
Savings (Loss)	0	0	(19,857)	0	0	0	0	(19,857)	66	0	(68)
Lighting Control	143,681	1,145	56,256	137,786	23,652	128,716	92,865	440,420	180	144	1,647
Savings (Loss)	(16,234)	(130)	5,248	0	0	29,777	0	34,895	0	(16)	103

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE BUDG - 1/4"

INSULATED GLASS ECO (ALT-2)

SM-HP SAVY ACCOUNTS FOR 100,000 Btuh
OR 640,000 Btuh DESIGN COOLING COA

HISTORICAL BUILDING → USE CLEAR DOUBLE GLASS

ASHRAE F27.26	SC = 0.82	CLEAR GLASS
27.31	SC = 0.58	CLEAR WITH BLINDS
29.16 (25)	U = 0.51	3/8" AIR SPACE

ECONOMIZED CYCLE (ALT-3)

ECONOMIZED CONTROL
ON POINT

MAX 70 OSA

BRY-BUCK

100%

AVAIL

} CAAD (44)

(45)

HVAC CONTROLS (ALT-4)

SETBACK T/STATS

- CLG FANS
HTG " VENTILATION
INFIL

CLG BACK (31)
HTG BACK

FAN OFF (26)
" " INFIL

OFF 6 - 6am WEEKDAYS
0-24 SAT-SUN

THERMAL STORAGE

- (62) EQ1750
 - (63) SR 1
 - (73) CLIMICE
- 200 TON-HRS

30 TONS

OPTIMIZE
FULL CHARGE
1.07% LOSS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Rtdg 131 Main Street

ECO #15

Present Lighting Values 165 w/ft²

1985 Reduction 0.31
133 w/ft²

Lighting Power = 277 w/ft²

Cooling Load

Total Electric Cooling = 5748 - 170 = 5118 w/ft²

Cooling Load 0.17 w/ft²/w/ft²

Gas Load

Total Gas Load = 16.2 MBtu/yr

Gas Load 5.4 x 10⁻⁴ MBtu/ft²/w/ft²

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105-000
SHEET NO. _____ OF _____
CALCULATED BY DJ DATE 2/20/92
CHECKED BY _____ DATE _____
SCALE MIE+

ICE STORAGE <MIE+>

WATER PERFORMANCE - TANK CHARGING (52)
STORE ICE @ 25°F → 145 kWh/TON

STORAGE REFERENCE (53) 1

STORAGE TANK PARAMETERS (73)

STANDARD	COOL STOR TANK	CUMICE
SCHEDULE	7pm → 9am	CHR 7P27A
CAPACITY	62.5 TONS x 5/12	500 TON-HRS
CONTROL		OPTIMIZE
LOSS		FULLCHARGE
		1%

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____




SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE BLOS - 84

FACE 200 MODEL
USE 4 ZONES



ZONE	DIR	AREA (SQ FT)
1	N	7524
2	E	7104
3	S	7424
4	W	12,654
		<u>34,706</u>

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE 3005-782

U-VALUES

ROOF



	R
JOIST	0.65
SHINGLE	0.05
WOOD	0.50
TRUSS	1.20
AIR	2.50
AIR SPACE	1.00
R-19 BATT	19.00
ACROSTIC	1.25
INSIDE FILM	0.75
	<u>29.12</u>

$U = 0.034$

HALLS



1/2\"/>	0.68
1/2\"/>	0.45
5\"/>	1.00
3\"/>	1.48
OUTSIDE FILM	0.25
	<u>13.86</u>

$U = 0.072$

SLAB

SINGLE PANE - WOOD FRAME - CATEGORY C
 $U = 0.98$ (1989 FUNDAMENTALS p 29.16)

INTERNAL SHADING - BLINDS (LIGHT)
 SHADING COEF = 0.67

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE BC 33 - 150

PEOPLE

NO DATA ON OCCUPANCY

AREA 17' x 17' PERSON CLERICAL
1987 HVAC

1.2

OCCUPANCY 140 PEOPLE FROM FIELD NOTES

OFFICE WORK } 250 WATT PER PERSON 0.5 WATT PER SQ FT
ASHRAE FUND } 26.7

ZONE ARE ABOUT THE SAME SIZE

20 35 PEOPLE PER ZONE

LIGHTS

136 4-TUBE FLUORESCENTS ON 1ST FLOOR
4' 30 WATT LAMPS 155 WATTS (SYLVANIA DATA)

12.775 ft² → 94.0 ft² / FIXTURE
→ 1.65 WATTS / FT²

RECESSED FLUORESCENT / NOT VENTED / SA CFM > 0.5 ft³ / SF
BALLAST FACTOR = 1 (BALLAST ENERGY INCLUDED IN FIXTURE WATTS)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3115,000

SHEET NO. _____ OF _____

CALCULATED BY DJ DATE 2/6/83

CHECKED BY _____ DATE _____

SCALE 1/8" = 1'-0"

HVAC SYSTEM

1st and 2nd FLOOR

(10) AHUS IN ATTIC DUCTED TO EACH ZONE
PERIMETER BALANCE CONTROL SYSTEM
BASEMENT

FAN COILS (HEATING) 77°F COOL
68°F HEAT

<u>TERMINAL UNITS</u>				40000	20000
UNIT	CFM	MIN OA CFM	FAN HP	COOL BTU/H	HEAT BTU/H
AHU-1	2190	500	1	40,000	12,500
2	1465	250	3/4	39,000	13,100
3	2950	250	1 1/2	63,400	"
4	3450	250	"	72,000	"
5	1770	250	"	35,000	18,000
6	2300	200	1	50,000	16,000
7	2100	190	1	48,000	10,500
8	2100	190	1	"	"
9	2600	"	1	51,000	17,600
10	3500	310	1	60,800	15,500
FAN COILS (11)	4300	390	—	57,000	123,000

HEAT EXCH 420,000 BTU/H
 CONDENSER 62.5 TONS 43°F CWT 170 gpm
 LOW VOLT 5 HP
 EXHAUST FANS 1100 gpm

BASEMENT DX UNIT (GAS HEAT) SERVES ONE ROOM
 COMPUTER ROOM UNIT ON 1st FLOOR 5 HP

JOB 3105,000

SHEET NO. _____ OF _____

CALCULATED BY [Signature] DATE 5/3/92

CHECKED BY _____ DATE _____

SCALE 1/8" = 1'

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

TRACE - 500 INPUTS

SYSTEM MODEL

CARD 40

50 TON CHILLER = V T C V VARIABLE TEMP / CONSTANT VOLUME
PERM ~~BAD~~ WILL BEHAVE LIKE HEAT COIL IN MODEL
AND WILL SUPPLY HEATING OR COOLING
CONTROL VALVE PROVIDES VARIABLE TEMP
VENTILATION = R O A D K RETURN AIR DECK
4% SENS = ALWAYS AVAILABLE

CARD 42

FAN SP + DUCT PARAMETERS
AND MOTORS AT END OF AIRSTREAM
CHILLER PROVIDES 44°F WATER
COIL PLUMBING 40,400 BTUH SENSITIVE COOLING @ 2170 CFM @ 79.9°F DB
 $SA = 40,400 / 2170 / 1.08 = 21.1 \text{ } ^\circ\text{F} \rightarrow SA \text{ TEMP} = 62.9 \text{ } ^\circ\text{F}$
HEATING 18,500 BTUH $\rightarrow SA = +7.9 \text{ } ^\circ\text{F} + 64.3 = 72.2 \text{ } ^\circ\text{F}$

CARD 62

62.5 TON CHILLER
AIR COOLED 45°F
USE EQ 1121 &
1.129 KW/TON

CARD 69

ASSUME FORWARD CURVE CENTRIFUGAL FAN

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
 SHEET NO. _____ OF _____
 CALCULATED BY _____ DATE _____
 CHECKED BY _____ DATE _____
 SCALE _____

ROOM AIR FLOWS
VENTILATION

OA CFMS FROM HVAC PLANS 2670 CFM (10 AHUS)
 SERVING 1st & 2nd FLOOR OF 25,572 ft²
 0.10 CFM/ft²

EXHAUST FANS 1100 CFM

ASSUMING 4 EQUAL SIZED ZONES → 568 CFM/ZONE

NET FORCED FLOW IN IS 2670 - 1100 = 1570 CFM

INFILTRATION (ASSUME FUND 87 @ 23.17)

$$Q = L(A \cdot \Delta T + B \cdot V^n)$$

Q = 1,662 L WINTER
 1,300 L SUMMER

A = 0.0471 (3 STORY)
 B = 0.0101 (3 STORY, CLASS 3)
 V = 11 mph
 T = 51.7°F AVG WINTER
 80°F
 ΔT = 30°F WINTER
 10°F SUMMER

ELEMENT	DESCRIPTION	TOTAL AREA	LEAK/TOTAL	LEAK AREA
WINDOWS	DOUBLE HUNG	2182	0.043	94
WINDOW FRAMES & DOOR	MASONRY (CALC REQD)	2770	0.030	83
DOORS	NOT WITHSTP	588	0.157	92

269 in²

INFILTRATION
 SUMMER 330 CFM
 WINTER 436 CFM

SINCE FORCED VENTILATION IS 3 TIME INFILTRATION,
 ASSUME INFILTRATION SUPPRESSED = ZERO

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

FAN AIRFLOWS

ALL FANS SPECIFIED FOR 1.25" WC ESP

TOTAL FLOW FOR 10 FANS = 24,500 cfm } 0.96 cfm/ft^2

TOTAL AREA (10 FANS) = 25,512 ft^2 }

2111 FLOW = 100 cfm } 275 cfm

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE 1/8" = 1'-0"

EQUIPMENT HEAT GAIN

Zone 1 (1st Floor)

OFFICE WITH 1 PC & 1 LASER PRINTER EVERY 225 SQ FT
 ASSUME 1 COFFEE MAKER/FLOOR (1ST FLOOR ONLY)
 1 REFRIG/1000
 AREA 2508 FT²/FLOOR

COMPONENT	WATTS	FT ²	W/FT ²
PC	200	225	0.89
LASER PRINT	100	225	0.44
REFRIG	200	2508	0.08
COFFEE	350	2508	0.10
COPYER	300	"	0.24
			<hr/>
			1.75 W/FT ²

OTHER ZONES & FLOORS

PC	1200	3552	
LASER	300	"	
REFRIG	200	"	
COFFEE	250	"	
COPYER	300	"	
	<hr/>		
	2550	3552	→ 0.75 W/FT ²

TOTALS

Zone-1 is AVG 1.25 W/FT²
 OTHER ZONES 0.75 "

01 Card - Job Information

 Project: FORT MCPHERSON & GILLEM EEAP #3105.000
 Location: ATLANTA, GA
 Client: COE - DACA21-9-C-0097
 Program User: DENNIS JONES
 Comments: BUILDING 184 - FORT MCPHERSON - BASECASE

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	M184 - BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
M1	1	NORTH ZONES	75.2	100	1	4		12			
2	2	EAST ZONES	71	100							
3	3	SOUTH ZONES	74.2	100							
4	4	WEST ZONES	126.5	100							

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	T'stat Location Flag	Mass / No. Hrs Average Floor	Carpet On
M	76			CLGSTAT	72		HTGSTAT			YES

-----CARD 22-- Roof Parameters -----

Roof

Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
M1	1	NO	25.08	100	0.034	41	0	60	0.9
2	1		35.52	100			90		
3	1		25.08	100			180		
4	1		42.18	100			270		

-----CARD 24-- Wall Parameters -----

Wall

Ground

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M	1			0.072	77	0		0.68	
1	1	104	28						
1	2	28	24			180			
2	1	150	28			90			
2	2	72	24			270			
3	1	104	28			180			
3	2	28	24			0			
4	1	150	28			270			
4	2	72	24			90			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret.	Visible Transmittance	Inside Visible Reflectance
M1	1	3.33	6.42	17	0.98	0.67					
1	2			4							
2	1			19							
2	2			6							
3	1			14							
3	2			4							
4	1			18			3				
4	2			20			3				

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
M1	PPL1	LGT1	AVAIL	OFF		AVAIL	AVAIL		AVAIL	

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	Daylighting Reference Point 1	Daylighting Reference Point 2
M1	35	PEOPLE	250	200	1.65	WATT-SF	ASHRAE2	1			

-----CARD 28--- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
M1	1	GENERAL OFFICE	1.75	WATT-SF	LGT1	ELEC					
2	1		0.75	WATT-SF							
3	1		0.75								
4	1		0.75								

-----CARD 29--- Room Airflows -----

Room Number	-----Ventilation-----				-----Infiltration-----				--Reheat Minimum--	
	----Cooling----		----Heating----		----Cooling----		----Heating----		Value	Units
	Value	Units	Value	Units	Value	Units	Value	Units		
M1	668	CFM	668	CFM	0.5	ACH-HR	0.5	ACH-HR		

-----CARD 30- Fan Airflows -----

Room Number	-----Main-----				-----Auxiliary-----				--Room Exhaust--	
	----Cooling----		----Heating----		----Cooling----		----Heating----		Value	Units
	Value	Units	Value	Units	Value	Units	Value	Units		
M1	6125	CFM	6125	CFM					275	CFM

-----CARD 33-- External Shading -----

Shading Type	-----OVERHANG-----				-----VERTICAL FINS-----					
	Glass Height	Above Glass	Projection Out	Projection Width	Glass Left	Projection Left	Projection Out	Projection Right	Projection Out	Adjacent Building Flag
3	6.5	4	10							

----- System Section Alternative #1 -----

-----CARD 39-- System Alternative -----

Number	Description
1	M184 - BASELINE

-----CARD 40--- System Type -----

System Set Number	System Type	-----OPTIONAL VENTILATION SYSTEM-----					
		Deck Location	Cooling SADBvh	Heating SADBvh	Cooling Schedule	Heating Schedule	Fan Static Pressure
1	FC						

-----CARD 41-- Zone Assignment -----

System	Ref #1		Ref #2		Ref #3		Ref #4		Ref #5		Ref #6	
Set	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End
1	1	4										

-----CARD 42--- Fan SP and Duct Parameters-----

System	Cool	Heat	Return	Mn Exh	Aux	Rm Exh	Cool	Return	Supply	Supply	Return
Set	Fan	Fan	Fan	Fan	Fan	Fan	Fan Mtr	Fan Mtr	Duct	Duct	Air
Number	SP	SP	SP	SP	SP	SP	Loc	Loc	Ht Gn	Loc	Path
1	1.5	1.5				0.5	OMIT			RETAIR	DUCTED

-----CARD 44-- System Options -----

System	Econ	Econ	Max Pct	Direct	Indirect	1st Stage	----- Exhaust Air Heat Recovery -----				
Set	Type	On	Outside	Evap	Evap	Evap	Fan	--- Effectiveness ---	--- Control Method ---		
Number	Flag	Point	Air	Cooling	Cooling	Cooling	Cycling	System	Room	System	Room
1	NONE										

-----CARD 45--- Equipment Schedules -----

System	Main	Direct	Indirect	Auxiliary	Main	Main	Auxiliary				
Set	Cooling	Evap	Evap	Cooling	Heating	Preheat	Reheat	Mech.	Heating		
Number	Coil	Economizer	Coil	Coil	Coil	Coil	Coil	Humidity	Coil		
1	CLGMAC	OFF	OFF	OFF	OFF	HTGMAC	OFF	OFF	OFF	OFF	OFF

-----CARD 46--- EMS/BAS Schedules -----

System	Discrim	Night	Optimum	Optimum	-----DUTY CYCLING-----			System HR	Room HR
Set	Control	Purge	Start	Stop	On Period	Pattern	Maximum	Exhaust	Exhaust
Number	Schedule	Schedule	Schedule	Schedule	Schedule	Length	Off Time	Schedule	Schedule
1									

----- Equipment Section Alternative #1 -----

-----CARD 59-- Equipment Description / TOD Schedules -----

Alternative	Elec Consump	Elec Demand	Demand	Alternative Description		
Number	Time of Day	Time of Day	Limit	Max KW	Schedule	Schedule
1	Schedule	Schedule	Limit		M184 - BASELINE	

-----CARD 60--- Cooling Load Assignment-----

Load	All Coil	Cooling										
Asgn	Loads To	Equipment	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-	
Ref	Cool Ref	Sizing	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End
1	1		1	1								

-----CARD 62-- Cooling Equipment Parameters -----

Cool Equip	Num	-----COOLING-----				-----HEAT RECOVERY-----				Seq	Demand		
Ref	Code	Of	--Capacity--		----Energy----		--Capacity--		----Energy----	Order	Seq	Limit	
Num	Name	Units	Value	Units	Value	Units	Value	Units	Value	Units	Num	Type	Number
1	EQ1121L	1	62.5	TONS									

-----CARD 63-- Cooling Pumps and References -----

Cool	---CHILLED WATER---	-----CONDENSER-----	---HT REC or AUX---		Switch-							
Ref	Full Load	Full Load	Full Load	Full Load	Full Load	Full Load	over	Cold	Cooling	Misc.		
Num	Value	Units	Value	Units	Value	Units	Control	Storage	Tower	Access.		
1	5	HP										

-----CARD 65-- Heating Load Assignment -----

Load	All Coil										
Assignment	Loads To	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-	
Reference	Heating Ref	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End
1	1	1	1								

-----CARD 67-- Heating Equipment Parameters -----

Heat	Equip	Number	HW Pmp	Energy				Seq	Switch	Demand				
Ref	Code	Of	Full Ld	Cap'y		Rate		Order	over	Hot	Misc.	Limit		
Number	Name	Units	Value	Units	Value	Units	Value	Units	Number	Control	Strg	Acc.	Cogen	Number
1	EQ2001	1	2	HP	420	MBH								

-----CARD 69-- Fan Equipment Parameters -----

System									
Set	Cooling	Heating	Return	Exhaust	Auxiliary	Room	Optional		
Number	Fan	Fan	Fan	Fan	Supply	Exhaust	Ventilation		
1	EQ4003	EQ4003							

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
CLGMAC COOLING SCHEDULE
CLGSTAT COOLING TSTAT SCHEDULE
HTGMAC HEATING SCHEDULE
HTGSTAT HEATING TSTAT SCHEDULE
LGT1
OFF ALWAYS OFF
PPL1

System:

FC FAN COIL

Equipment:

Cooling:

EQ1121L AIR-CLD RECIP 35-60 TONS

Heating:

EQ2001 GAS FIRE TUBE HOT WATER

Fan:

EQ4003 FC CENTRIF. FAN C.V.

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: CLGMAC
Project: COOLING SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour Util Percent

0 0
24

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour Util Percent

0 100
24

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour Util Percent

0 0
24

Schedule Name: CLGSTAT
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

System Name: HTGMAC
Project: HEATING SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: HTGSTAT
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: NOV Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 72
24

Module Name: LGT1
Project:
Location:
Client:
Program User:
Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	5
24	

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Module Name: PPL1
Project:
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGM Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

**
** TRACE 600 ANALYSIS **
**
** by **
**

FORT MCPHERSON & GILLEM EEAP #3105.000
ATLANTA, GA
COE - DACA21-9-C-0097
DENNIS JONES
BUILDING 184 - FORT MCPHERSON - BASECASE

Weather File Code: ATLANTA.
Location:
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: June To November
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 18:46:56 3/11/92
Dataset Name: M184 .TM

LOW - ALTERNATIVE 1
 - BASELINE

----- SYSTEM SUMMARY -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	FC	2,672	24,500	24,500	24,500	2,672	0	1,100
Totals		2,672	24,500	24,500	24,500	2,672	0	1,100

CAPACITY - ALTERNATIVE 1
 M184 - BASELINE

----- SYSTEM SUMMARY -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating							
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)
1	FC	55.4	0.0	0.0	0.0	55.4	-319,002	0	0	0	0	0	0	-319,002
Totals		55.4	0.0	0.0	0.0	55.4	-319,002	0	0	0	0	0	0	-319,002

The building peaked at hour 16 month 8 with a capacity of 55.4 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 M184 - BASELINE

----- ENGINEERING CHECKS -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	FC	10.91	0.71	442.6	626.6	19.15	0.71	-9.20	34,690

System 1 Block FC - FAN COIL

***** COOLING COIL PEAK ***** CLG SPACE PEAK ***** HEATING COIL PEAK *****

Peaked at Time ==>	Mo/Hr: 8/15	*	Mo/Hr: 6/16	*	Mo/Hr: 13/ 1					
Outside Air ==>	OADB/WB/HR: 92/ 74/105.0	*	OADB: 96	*	OADB: 22					
	Space	Ret. Air	Ret. Air	Net	Perct	Space	Perct	Space Peak	Coil Peak	Perct
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	Sensible	Of Tot	Space Sens	Tot Sens	Of Tot
	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	(Btuh)	(%)	(Btuh)	(Btuh)	(%)
Envelope Loads										
Skylite Solr	0	0		0	0.00	0	0.00	0	0	0.00
Skylite Cond	0	0		0	0.00	0	0.00	0	0	0.00
Roof Cond	0	10,414		10,414	1.57	0	0.00	0	-16,074	5.10
Glass Solar	69,267	0		69,267	10.43	160,489	29.41	0	0	0.00
Glass Cond	34,833	0		34,833	5.24	20,165	3.70	-116,253	-116,253	36.92
Wall Cond	19,491	10,556		30,047	4.52	11,593	2.12	-37,807	-58,832	18.68
Partition	0			0	0.00	0	0.00	0	0	0.00
Exposed Floor	0			0	0.00	0	0.00	0	0	0.00
Infiltration	0			0	0.00	0	0.00	0	0	0.00
Sub Total==>	123,591	20,970		144,561	21.76	192,248	35.24	-154,061	-191,159	60.71
Internal Loads										
Lights	195,355	0		195,355	29.41	195,355	35.80	0	0	0.00
People	63,000			63,000	9.48	33,250	6.09	0	0	0.00
Misc	114,463	0	0	114,463	17.23	114,463	20.98	0	0	0.00
Sub Total==>	372,818	0	0	372,818	56.12	343,068	62.88	0	0	0.00
Ceiling Load	26,563	-26,563		0	0.00	10,297	1.89	-37,548	0	0.00
Outside Air	0	0	0	127,341	19.17	0	0.00	0	-143,310	45.51
Sup. Fan Heat				19,600	2.95		0.00		19,600	-6.00
Ret. Fan Heat		0		0	0.00		0.00		0	0.00
Duct Heat PkUp		0		0	0.00		0.00		0	0.00
OV/UNDR Sizing	0			0	0.00	0	0.00	0	0	0.00
Exhaust Heat		0	0	0	0.00		0.00		0	0.00
Terminal Bypass		0	0	0	-0.00		0.00		0	0.00
Grand Total==>	522,972	-5,593	0	664,320	100.00	545,613	100.00	-191,609	-314,869	100.00

-----COOLING COIL SELECTION-----

	Total Capacity	Sens Cap.	Coil Airfl	Entering DB/WB/HR			Leaving DB/WB/HR			AREAS		
	(Tons)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Glass (sf)	(%)
Main Clg	55.4	664.3	24,500	78.0	62.8	64.8	54.7	53.5	61.6	34,690		
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Totals	55.4	664.3								10,278	0	0
										19,024	2,181	11

-----HEATING COIL SELECTION-----

	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	--ENGINEERING CHECKS--		--TEMPERATURES (F)--		
	(Mbh)	(cfm)	Deg F	Deg F	Vent			Clg % OA	10.9	Type	Clg	Htg
Main Htg	-319.0	24,500	67.2	79.3	Infil	2,672	2,672	Clg Cfm/Sqft	0.71	SADB	55.2	79.3
Aux Htg	0.0	0	0.0	0.0	Supply	0	0	Clg Cfm/Ton	442.56	Plenum	78.4	68.2
Preheat	-0.0	24,500	67.3	55.2	Mincfm	24,500	24,500	Clg Sqft/Ton	626.63	Return	76.0	72.0
Reheat	0.0	0	0.0	0.0	Return	0	0	Clg Btuh/Sqft	19.15	Ret/OA	77.8	66.5
Humidif	0.0	0	0.0	0.0	Exhaust	23,400	23,400	No. People	140	Runarnd	76.0	72.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	1,572	1,572	Htg % OA	10.9	Fn MtrTD	0.2	0.2
Total	-319.0				Auxil	1,100	1,100	Htg Cfm/SqFt	0.71	Fn BldTD	0.2	0
						0	0	Htg Btuh/SqFt	-9.20	Fn Frict	0.6	0

COOLING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 M184 - BASELINE

----- AIRFLOW HEAT GAIN AND LOSS -----
 (At time of Coil Peak)

Room Number	Description	Cooling											
		Duct Heat Pickup (Btuh)	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	System Exhaust Total (Btuh)	Room Exhaust (Cfm)	Room Exhaust (Cfm)	Ducted (Cfm)	Plenum (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)
1	NORTH ZONES	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	1 Total/Ave.	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	1 Block	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
2	EAST ZONES	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	2 Total/Ave.	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	2 Block	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
3	SOUTH ZONES	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	3 Total/Ave.	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	3 Block	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
4	WEST ZONES	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	4 Total/Ave.	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	4 Block	0	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
System	1 Total/Ave.	0	19,600	0	0	19,600	1,572	1,100	23,400	0	0	0	23,400
System	1 Block	0	19,600	0	0	19,600	1,572	1,100	23,400	0	0	0	23,400

HEATING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 M184 - BASELINE

----- AIRFLOW HEAT GAIN AND LOSS -----
 (At time of Coil Peak)

Room Number	Description	Heating										
		Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	System Exhaust Total (Btuh)	Room Exhaust (Cfm)	Room Exhaust (Cfm)	Ducted (Cfm)	Plenum (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)
1	NORTH ZONES	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	1 Total/Ave.	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	1 Block	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
2	EAST ZONES	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	2 Total/Ave.	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	2 Block	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
3	SOUTH ZONES	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	3 Total/Ave.	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	3 Block	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
4	WEST ZONES	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	4 Total/Ave.	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
Zone	4 Block	4,900	0	0	4,900	393	275	5,850	0	0	0	5,850
System	1 Total/Ave.	19,600	0	0	19,600	1,572	1,100	23,400	0	0	0	23,400
System	1 Block	19,600	0	0	19,600	1,572	1,100	23,400	0	0	0	23,400

PSYCHROMETRICS - ALTERNATIVE 1
 - BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room 1

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	62.1	46.2	64.4	28.3	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	62.1	46.2	64.4	28.3	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	77.8	63.6	46.5	68.8	29.4	
Blow through Fan						0.2
Entering Coil	78.0	63.7	46.2	68.8	29.5	
Leaving Coil	57.1	54.8	87.2	63.2	23.5	
Draw Through Fan						0.0
Duct Frictional Heat						0.6
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	57.7	55.1	85.5	63.2	23.6	
Supply Air	57.7	55.1	85.5	63.2	23.6	
Percent Outside Air		10.91	(%)			
Sensible Heat Ratio (SHR)		0.945				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		6,125	(Cfm)			

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 M184 - BASELINE

----- PSYCHROMETRIC STATE POINTS -----

Room 2

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	61.6	44.7	62.3	28.0	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	61.6	44.7	62.3	28.0	
Outdoor Air	92.0	74.4	44.6	105.0	38.6	
Return/Outdoor Air Mix	77.7	63.2	45.3	67.0	29.1	
Blow through Fan						0.2
Entering Coil	77.9	63.3	45.0	67.0	29.2	
Leaving Coil	56.0	53.9	88.0	61.1	22.9	
Draw Through Fan						0.0
Duct Frictional Heat						0.6
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	56.5	54.1	86.2	61.1	23.1	
Supply Air	56.5	54.1	86.2	61.1	23.1	
Percent Outside Air	10.91	(%)				
Sensible Heat Ratio (SHR)	0.948					
Percent Supply Air Bypassing Coil	0.00	(%)				
Coil Airflow	6,125	(Cfm)				

PSYCHROMETRICS - ALTERNATIVE 1
 - BASELINE

----- PSYCHROMETRIC STATE POINTS -----

Room 3

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	62.5	47.6	66.3	28.6	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	62.5	47.6	66.3	28.6	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	77.8	64.0	47.6	70.6	29.7	
Blow through Fan						0.2
Entering Coil	78.0	64.0	47.3	70.6	29.8	
Leaving Coil	58.2	55.8	86.7	65.5	24.1	
Draw Through Fan						0.0
Duct Frictional Heat						0.6
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	58.8	56.1	85.0	65.5	24.3	
Supply Air	58.8	56.1	85.0	65.5	24.3	
Percent Outside Air			10.91 (%)			
Sensible Heat Ratio (SHR)			0.953			
Percent Supply Air Bypassing Coil			0.00 (%)			
Coil Airflow			6,125 (Cfm)			

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 M184 - BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room	4					
	Dry	Wet	Relat.	Humid.		Temp.
	Bulb	Bulb	Humid.	Ratio	Enthalpy	Diff.
	(F)	(F)	(%)	(GR)	(Btu/Lb)	(F)
Space	76.0	58.1	33.5	46.5	25.5	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	58.1	33.5	46.5	25.5	
Outdoor Air	91.8	73.2	42.0	98.0	37.5	
Return/Outdoor Air Mix	77.7	60.0	35.4	52.2	26.8	
Blow through Fan						0.2
Entering Coil	77.9	60.1	35.2	52.2	26.9	
Leaving Coil	47.4	45.9	89.9	45.4	18.4	
Draw Through Fan						0.0
Duct Frictional Heat						0.6
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	48.0	46.2	88.1	45.4	18.5	
Supply Air	48.0	46.2	88.1	45.4	18.5	
Percent Outside Air	10.91	(%)				
Sensible Heat Ratio (SHR)	0.963					
Percent Supply Air Bypassing Coil	0.00	(%)				
Coil Airflow	6,125	(Cfm)				

BUILDING U-VALUES - ALTERNATIVE 1
 - BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)									Room Mass (lb/sqft)	Room Capac. (Btu/sqft/F)
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Summr Roof	Wintr Windo	Summr Windo	Wall	Ceil.		
1	NORTH ZONES	0.000	0.000	0.000	0.000	0.000	0.980	1.067	0.072	0.317	18.4	6.14
Zone	1 Total/Ave.	0.000	0.000	0.000	0.000	0.000	0.980	1.067	0.072	0.317	18.4	6.14
2	EAST ZONES	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	35.0	11.45
Zone	2 Total/Ave.	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	35.0	11.45
3	SOUTH ZONES	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	23.2	8.46
Zone	3 Total/Ave.	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	23.2	8.46
4	WEST ZONES	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	22.4	8.27
Zone	4 Total/Ave.	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	22.4	8.27
System	1 Total/Ave.	0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	24.3	8.50
Building		0.000	0.000	0.000	0.000	0.034	0.980	1.067	0.072	0.317	24.3	8.50

BUILDING AREAS - ALTERNATIVE 1
 M184 - BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed			Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
		Flr	Rm				Floor Area (sqft)	Skylight Area (sqft)	Skl /Rf (%)				
1	NORTH ZONES	1	1	7,520	7,520	0	0	0	0	0	449	13	3,135
Zone	1 Total/Ave.				7,520	0	0	0	0	0	449	13	3,135
2	EAST ZONES	1	1	7,100	7,100	0	0	0	0	3,552	534	9	5,394
Zone	2 Total/Ave.				7,100	0	0	0	0	3,552	534	9	5,394
3	SOUTH ZONES	1	1	7,420	7,420	0	0	0	0	2,508	385	11	3,199
Zone	3 Total/Ave.				7,420	0	0	0	0	2,508	385	11	3,199
4	WEST ZONES	1	1	12,650	12,650	0	0	0	0	4,218	812	14	5,116
Zone	4 Total/Ave.				12,650	0	0	0	0	4,218	812	14	5,116
System	1 Total/Ave.				34,690	0	0	0	0	10,278	2,181	11	16,843
Building					34,690	0	0	0	0	10,278	2,181	11	16,843

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
M184 - BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.034 (Btu/Hr/Sq Ft/F)

Overall Wall U-Value = 0.176 (Btu/Hr/Sq Ft/F)

Overall Building U-Value = 0.126 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTvr) = 0.87 (Btu/Hr/Sq Ft)

Wall Overall Thermal Transfer Value (OTTvw) = 13.69 (Btu/Hr/Sq Ft)

†

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 - BASELINE

Main System 1 FC FAN COIL

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	2.8	14	451	-15,950	8	94	1,225.0	0	0	0.0	0	0
5 - 10	5.5	15	492	-31,900	12	136	2,450.0	0	0	0.0	0	0
10 - 15	8.3	17	568	-47,850	7	79	3,675.0	0	0	0.0	0	0
15 - 20	11.1	9	310	-63,800	15	167	4,900.0	0	0	0.0	0	0
20 - 25	13.8	2	51	-79,751	6	64	6,125.0	0	0	0.0	0	0
25 - 30	16.6	4	136	-95,701	4	46	7,350.0	0	0	0.0	0	0
30 - 35	19.4	1	44	-111,651	8	95	8,575.0	0	0	0.0	0	0
35 - 40	22.1	2	82	-127,601	7	75	9,800.0	0	0	0.0	0	0
40 - 45	24.9	1	42	-143,551	8	84	11,025.0	0	0	0.0	0	0
45 - 50	27.7	1	49	-159,501	5	60	12,250.0	0	0	0.0	0	0
50 - 55	30.4	1	39	-175,451	5	52	13,475.0	0	0	0.0	0	0
55 - 60	33.2	5	162	-191,401	5	56	14,700.0	0	0	0.0	0	0
60 - 65	36.0	3	107	-207,351	4	46	15,925.0	0	0	0.0	0	0
65 - 70	38.8	4	143	-223,301	6	64	17,150.0	0	0	0.0	0	0
70 - 75	41.5	4	136	-239,252	0	0	18,375.0	0	0	0.0	0	0
75 - 80	44.3	8	275	-255,202	0	0	19,600.0	0	0	0.0	0	0
80 - 85	47.1	0	0	-271,152	0	0	20,825.0	0	0	0.0	0	0
85 - 90	49.8	6	195	-287,102	0	0	22,050.0	0	0	0.0	0	0
90 - 95	52.6	0	0	-303,052	0	0	23,275.0	0	0	0.0	0	0
95 - 100	55.4	0	0	-319,002	0	0	24,500.0	100	8,760	0.0	0	0
Hours Off	0.0	0	5,478	0	0	7,642	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 M184 - BASELINE

January		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-141,090	0.0	0	0.0	-48,079	0.0	-194,911	0.0	-194,911	0.0
2	32.1	29.3	-148,395	0.0	0	0.0	-55,091	0.0	-205,142	0.0	-205,142	0.0
3	31.7	29.3	-154,944	0.0	0	0.0	-56,619	0.0	-210,831	0.0	-210,831	0.0
4	31.9	29.5	-160,760	0.0	0	0.0	-56,946	0.0	-211,748	0.0	-211,748	0.0
5	32.6	30.3	-163,796	0.0	-19,863	0.0	-57,685	0.0	-212,522	0.0	-212,522	0.0
6	33.6	31.3	-163,553	0.0	-57,210	0.0	-75,809	0.0	-210,828	0.0	-210,828	0.0
7	35.0	32.6	-160,874	0.0	-55,902	0.0	-130,440	0.0	-205,061	0.0	-205,061	0.0
8	36.6	34.4	0	0.0	0	0.0	-154,793	0.0	-154,763	0.0	0	0.0
9	38.5	36.3	0	0.0	0	0.0	-122,564	0.0	-122,564	0.0	0	0.0
10	40.4	37.7	0	0.0	0	0.0	-100,179	0.0	-100,179	0.0	0	0.0
11	42.3	38.7	0	0.0	0	0.0	-99,863	0.0	-99,863	0.0	0	0.0
12	44.2	39.6	0	0.0	0	0.0	-96,146	0.0	-96,146	0.0	0	0.0
13	45.8	40.5	0	0.0	0	0.0	-83,676	0.0	-83,676	0.0	0	0.0
14	47.2	41.1	0	0.0	0	0.0	-75,572	0.0	-75,572	0.0	0	0.0
15	48.2	41.6	0	0.0	0	0.0	-63,285	0.0	-63,285	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	-52,760	0.0	-52,760	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	-93,075	0.0	-93,075	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	-104,322	0.0	-104,322	0.0	0	0.0
19	47.4	41.7	0	0.0	0	0.0	-108,697	0.0	-108,697	0.0	0	0.0
20	45.5	40.5	0	0.0	0	0.0	-119,545	0.0	-119,545	0.0	0	0.0
21	43.1	38.9	0	0.0	0	0.0	-135,084	0.0	-135,084	0.0	0	0.0
22	40.4	36.7	0	0.0	0	0.0	-151,300	0.0	-151,300	0.0	0	0.0
23	37.7	34.3	0	0.0	0	0.0	-168,263	0.0	-168,263	0.0	0	0.0
24	35.3	32.3	0	0.0	0	0.0	-184,121	0.0	-184,121	0.0	0	0.0

February		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	-33,300	0.0	0	0.0	-42,316	0.0	-175,909	0.0	-175,909	0.0
2	36.0	33.0	-39,955	0.0	0	0.0	-50,522	0.0	-186,304	0.0	-186,304	0.0
3	34.7	31.8	-41,625	0.0	0	0.0	-52,693	0.0	-194,330	0.0	-194,330	0.0
4	33.6	30.9	-43,153	0.0	0	0.0	-54,487	0.0	-202,493	0.0	-202,493	0.0
5	32.8	30.1	-43,531	0.0	0	0.0	-56,301	0.0	-208,819	0.0	-208,819	0.0
6	32.2	29.8	-49,046	0.0	-22,085	0.0	-57,736	0.0	-214,686	0.0	-214,686	0.0
7	32.1	29.6	-102,355	0.0	-55,940	0.0	-136,767	0.0	-210,790	0.0	-210,790	0.0
8	32.5	30.3	0	0.0	0	0.0	-145,389	0.0	-145,354	0.0	0	0.0
9	33.9	31.6	0	0.0	0	0.0	-139,813	0.0	-139,814	0.0	0	0.0
10	36.0	33.0	0	0.0	0	0.0	-137,864	0.0	-137,864	0.0	0	0.0
11	38.5	34.8	0	0.0	0	0.0	-133,643	0.0	-133,643	0.0	0	0.0
12	41.3	36.5	0	0.0	0	0.0	-115,082	0.0	-115,082	0.0	0	0.0
13	43.8	38.1	0	0.0	0	0.0	-100,047	0.0	-100,047	0.0	0	0.0
14	45.9	39.5	0	0.0	0	0.0	-90,869	0.0	-90,869	0.0	0	0.0
15	47.2	40.4	0	0.0	0	0.0	-64,705	0.0	-64,705	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	-56,460	0.0	-56,460	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	-76,335	0.0	-76,335	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	-116,229	0.0	-116,229	0.0	0	0.0
19	46.2	39.9	0	0.0	0	0.0	-118,427	0.0	-118,427	0.0	0	0.0
20	45.1	39.7	0	0.0	0	0.0	-124,089	0.0	-124,089	0.0	0	0.0
21	43.8	39.2	0	0.0	0	0.0	-133,315	0.0	-133,315	0.0	0	0.0
22	42.3	38.3	0	0.0	0	0.0	-141,916	0.0	-141,916	0.0	0	0.0
23	40.7	37.2	0	0.0	0	0.0	-154,375	0.0	-154,375	0.0	0	0.0
24	39.1	35.8	0	0.0	0	0.0	-164,048	0.0	-164,048	0.0	0	0.0

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1
 - BASELINE

March		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4 41.6	-15,577	0.0	0	0.0	0	0.0	-12,250	0.0	-117,286	0.0
2	43.3 39.7	-23,894	0.0	0	0.0	0	0.0	-35,539	0.0	-131,764	0.0
3	41.6 38.6	-25,708	0.0	0	0.0	0	0.0	-44,642	0.0	-143,657	0.0
4	40.6 37.5	-27,450	0.0	0	0.0	0	0.0	-72,610	0.0	-151,587	0.0
5	40.2 37.3	-28,835	0.0	0	0.0	0	0.0	-75,155	0.0	-157,117	0.0
6	40.6 37.8	-29,019	0.0	0	0.0	0	0.0	-102,721	0.0	-158,497	0.0
7	41.6 39.0	0	0.0	0	0.0	0	0.0	-78,840	0.0	-99,837	0.0
8	43.3 40.7	0	0.0	0	0.0	0	0.0	-66,328	0.0	0	0.0
9	45.4 42.5	0	0.0	0	0.0	0	0.0	-63,789	0.0	0	0.0
10	47.9 44.3	0	0.0	0	0.0	0	0.0	-72,553	0.0	0	0.0
11	50.6 45.5	0	0.0	0	0.0	0	0.0	-43,209	0.0	0	0.0
12	53.3 46.8	0	0.0	0	0.0	0	0.0	-33,267	0.0	0	0.0
13	55.8 48.5	0	0.0	0	0.0	0	0.0	-20,698	0.0	0	0.0
14	58.0 49.6	0	0.0	0	0.0	0	0.0	-6,983	0.0	0	0.0
15	59.6 50.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	60.7 50.9	0	0.0	0	0.0	0	0.0	-3,252	0.0	0	0.0
17	61.0 50.9	0	0.0	0	0.0	0	0.0	-4,286	0.0	0	0.0
18	60.7 50.7	0	0.0	0	0.0	0	0.0	-10,795	0.0	0	0.0
19	59.6 50.7	0	0.0	0	0.0	0	0.0	-16,573	0.0	0	0.0
20	58.0 50.5	0	0.0	0	0.0	0	0.0	-21,255	0.0	0	0.0
21	55.8 49.4	0	0.0	0	0.0	0	0.0	-41,400	0.0	0	0.0
22	53.3 47.8	0	0.0	0	0.0	0	0.0	-59,433	0.0	0	0.0
23	50.6 45.9	0	0.0	0	0.0	0	0.0	-85,093	0.0	0	0.0
24	47.9 43.8	0	0.0	0	0.0	0	0.0	-101,822	0.0	0	0.0

April		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7 53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9 52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2 51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	52.9 50.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9 49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	51.2 49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.0 49.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	51.6 49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	53.3 50.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	55.9 51.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	59.0 53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	62.4 55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5 57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1 59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8 60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4 60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2 60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5 60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5 59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2 59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5 59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7 58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7 57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7 55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 M184 - BASELINE

May		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6 62.3	0	55.4	0	0.0	0	0.0	0	0.0	0	0.0
2	64.5 60.4	0	55.4	0	0.0	0	0.0	0	0.0	0	0.0
3	62.7 59.1	0	53.0	0	0.0	0	0.0	0	0.0	0	0.0
4	61.2 58.1	0	36.6	0	0.0	0	0.0	0	0.0	0	0.0
5	60.0 57.1	0	16.1	0	0.0	0	0.0	0	0.0	0	0.0
6	59.3 56.6	0	5.3	0	0.0	0	0.0	0	0.0	0	0.0
7	59.0 56.5	0	10.3	0	0.0	0	0.0	0	0.0	0	0.0
8	59.5 56.6	0	31.2	0	10.3	0	0.0	0	0.0	0	10.3
9	60.9 56.6	0	38.4	0	28.3	0	0.8	0	0.8	0	29.2
10	63.0 57.2	0	40.1	0	31.7	0	2.0	0	2.0	0	32.0
11	65.7 58.1	0	41.7	0	32.0	0	1.4	0	1.4	0	32.1
12	68.7 59.8	0	42.2	0	32.0	0	1.4	0	1.4	0	32.0
13	71.7 61.6	0	35.1	0	26.0	0	3.1	0	3.1	0	26.0
14	74.5 63.4	0	45.9	0	36.5	0	4.2	0	4.2	0	36.5
15	76.6 64.8	0	46.3	0	38.7	0	6.9	0	6.9	0	38.7
16	78.0 65.6	0	48.6	0	39.6	0	8.5	0	8.5	0	39.6
17	78.5 65.6	0	40.2	0	32.4	0	9.6	0	9.6	0	32.4
18	78.2 65.8	0	24.3	0	18.0	0	8.1	0	8.1	0	18.0
19	77.5 65.6	0	8.8	0	5.2	0	5.2	0	5.2	0	5.2
20	76.3 66.1	0	7.7	0	4.8	0	4.8	0	4.8	0	4.8
21	74.8 67.2	0	6.3	0	4.0	0	4.0	0	4.0	0	4.0
22	73.0 66.4	0	5.0	0	3.0	0	3.0	0	3.0	0	3.0
23	70.9 65.4	0	3.8	0	2.0	0	2.0	0	2.0	0	2.0
24	68.7 64.0	0	2.7	0	0.6	0	0.7	0	0.7	0	0.6

June		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0 67.9	0	6.7	0	3.1	0	3.4	0	3.5	0	3.5
2	71.2 66.1	0	5.9	0	2.2	0	2.3	0	2.4	0	2.4
3	69.7 65.2	0	5.2	0	1.1	0	1.3	0	1.3	0	1.3
4	68.5 64.3	0	4.6	0	0.0	0	0.3	0	0.3	0	0.3
5	67.8 64.2	0	4.4	0	0.0	0	0.0	0	0.0	0	0.0
6	67.6 64.2	0	10.8	0	3.1	0	3.1	0	3.1	0	3.1
7	68.1 64.8	0	15.6	0	5.8	0	6.0	0	6.1	0	6.1
8	69.4 65.7	0	43.9	0	34.4	0	6.1	0	6.2	0	35.5
9	71.6 66.2	0	47.9	0	40.3	0	6.0	0	6.0	0	40.3
10	74.2 67.2	0	48.7	0	43.0	0	9.4	0	9.4	0	43.0
11	77.2 68.5	0	49.9	0	42.7	0	9.6	0	9.6	0	42.7
12	80.2 70.0	0	50.1	0	43.5	0	10.8	0	10.8	0	43.5
13	82.8 70.8	0	42.1	0	35.6	0	12.4	0	12.4	0	35.6
14	85.0 71.6	0	53.9	0	48.5	0	14.2	0	14.2	0	48.5
15	86.3 72.3	0	53.7	0	49.1	0	15.4	0	15.4	0	49.1
16	86.8 72.1	0	54.6	0	48.8	0	15.6	0	15.6	0	48.8
17	86.6 71.7	0	49.1	0	39.7	0	15.7	0	15.7	0	39.7
18	85.8 71.5	0	29.9	0	23.4	0	14.1	0	14.1	0	23.4
19	84.7 71.2	0	13.5	0	9.6	0	9.8	0	9.8	0	9.6
20	83.2 71.5	0	12.3	0	9.0	0	9.3	0	9.3	0	9.0
21	81.4 71.7	0	11.1	0	8.1	0	8.6	0	8.6	0	8.1
22	79.3 71.4	0	9.7	0	7.1	0	7.4	0	7.4	0	7.1
23	77.2 70.5	0	8.6	0	6.1	0	6.3	0	6.3	0	6.1
24	75.1 69.1	0	7.5	0	4.7	0	4.8	0	4.8	0	4.7

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1
 BASELINE

July Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0	69.3	0	6.3	0	2.7	0	3.3	0	3.3	0	3.3
2	70.5	68.0	0	5.6	0	1.7	0	2.0	0	2.0	0	2.0
3	69.4	67.1	0	5.0	0	0.8	0	1.0	0	1.0	0	1.0
4	68.5	66.4	0	4.6	0	0.0	0	0.0	0	0.0	0	0.0
5	67.9	66.0	0	4.4	0	0.0	0	0.0	0	0.0	0	0.0
6	67.7	65.9	0	8.9	0	1.9	0	2.1	0	2.1	0	2.1
7	68.1	66.3	0	16.3	0	6.2	0	6.6	0	6.6	0	6.6
8	69.1	67.3	0	46.4	0	37.8	0	6.7	0	6.7	0	38.4
9	70.8	68.0	0	48.1	0	41.6	0	6.2	0	6.2	0	41.5
10	72.9	69.1	0	49.5	0	43.4	0	9.2	0	9.2	0	43.4
11	75.2	70.5	0	50.8	0	43.4	0	9.7	0	9.7	0	43.4
12	77.5	71.7	0	50.2	0	43.7	0	10.7	0	10.7	0	43.7
13	79.6	72.7	0	42.2	0	35.6	0	12.5	0	12.5	0	35.6
14	81.3	73.5	0	54.1	0	49.4	0	14.3	0	14.3	0	49.4
15	82.3	73.7	0	53.7	0	48.8	0	15.0	0	15.0	0	48.8
16	82.7	73.5	0	54.6	0	49.0	0	15.3	0	15.3	0	49.0
17	82.5	73.1	0	48.2	0	39.4	0	15.3	0	15.3	0	39.4
18	82.0	72.6	0	28.0	0	22.4	0	13.6	0	13.6	0	22.4
19	81.1	73.2	0	11.9	0	7.9	0	8.9	0	8.9	0	7.9
20	79.9	73.8	0	11.0	0	8.1	0	9.1	0	9.1	0	8.1
21	78.5	73.9	0	9.9	0	8.0	0	8.9	0	8.9	0	8.0
22	76.9	73.1	0	8.8	0	7.4	0	7.8	0	7.8	0	7.4
23	75.2	71.9	0	7.8	0	6.2	0	6.4	0	6.4	0	6.2
24	73.5	70.8	0	6.9	0	4.6	0	4.7	0	4.7	0	4.6

August Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7	70.2	0	7.0	0	2.8	0	3.6	0	3.6	0	3.6
2	71.2	69.0	0	5.6	0	2.0	0	2.4	0	2.4	0	2.4
3	69.9	68.0	0	4.9	0	1.2	0	1.3	0	1.3	0	1.3
4	68.8	67.1	0	4.5	0	0.0	0	0.0	0	0.0	0	0.0
5	68.0	66.6	0	4.2	0	0.0	0	0.0	0	0.0	0	0.0
6	67.5	66.2	0	5.6	0	0.5	0	0.6	0	0.6	0	0.6
7	67.3	66.1	0	15.2	0	5.1	0	5.6	0	5.6	0	5.6
8	67.8	66.5	0	47.2	0	37.4	0	6.0	0	6.0	0	38.1
9	69.1	67.0	0	49.6	0	40.5	0	5.6	0	5.6	0	40.5
10	71.2	67.8	0	49.6	0	41.8	0	8.1	0	8.1	0	41.8
11	73.8	68.7	0	51.5	0	41.8	0	8.4	0	8.4	0	41.8
12	76.5	70.0	0	50.0	0	42.5	0	9.7	0	9.7	0	42.5
13	79.1	71.2	0	42.0	0	35.4	0	12.2	0	12.2	0	35.4
14	81.1	72.6	0	54.0	0	49.0	0	14.2	0	14.2	0	49.0
15	82.5	73.6	0	54.0	0	48.7	0	15.0	0	15.0	0	48.7
16	83.0	73.7	0	55.4	0	47.8	0	14.2	0	14.2	0	47.8
17	82.8	73.5	0	48.5	0	39.1	0	14.8	0	14.8	0	39.1
18	82.3	73.5	0	26.0	0	20.5	0	11.4	0	11.4	0	20.5
19	81.5	73.1	0	11.9	0	7.8	0	8.9	0	8.9	0	7.8
20	80.4	73.7	0	10.9	0	8.1	0	9.1	0	9.1	0	8.1
21	79.1	74.9	0	9.7	0	8.0	0	8.9	0	8.9	0	8.0
22	77.6	73.9	0	8.6	0	7.9	0	8.2	0	8.2	0	7.9
23	76.0	72.7	0	7.5	0	6.6	0	6.7	0	6.7	0	6.6
24	74.3	71.3	0	6.7	0	5.0	0	5.0	0	5.0	0	5.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 M184 - BASELINE

September			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	69.8	66.1	0	4.1	0	0.8	0	1.1	0	1.1	0	1.1
2	68.0	64.5	0	3.2	0	0.0	0	0.0	0	0.0	0	0.0
3	66.3	63.0	0	2.8	0	0.0	0	0.0	0	0.0	0	0.0
4	64.9	61.9	0	2.0	0	0.0	0	0.0	0	0.0	0	0.0
5	63.9	61.3	0	1.6	0	0.0	0	0.0	0	0.0	0	0.0
6	63.2	61.0	0	1.6	0	0.0	0	0.0	0	0.0	0	0.0
7	63.0	60.8	0	9.5	0	0.0	0	0.0	0	0.0	0	0.0
8	63.4	61.4	0	41.2	0	19.6	0	0.8	0	0.8	0	20.8
9	64.7	61.8	0	47.9	0	38.3	0	2.8	0	2.8	0	39.2
10	66.6	62.1	0	45.6	0	35.0	0	1.9	0	1.9	0	35.1
11	69.1	62.9	0	46.8	0	38.2	0	4.9	0	4.9	0	38.2
12	71.8	63.7	0	46.8	0	37.5	0	7.0	0	7.0	0	37.5
13	74.5	65.5	0	39.4	0	30.5	0	8.7	0	8.7	0	30.5
14	77.0	67.1	0	50.6	0	42.5	0	9.9	0	9.9	0	42.5
15	78.9	68.2	0	52.7	0	43.2	0	10.3	0	10.3	0	43.2
16	80.2	68.6	0	51.8	0	43.7	0	10.7	0	10.7	0	43.7
17	80.6	68.5	0	40.2	0	33.1	0	9.6	0	9.6	0	33.1
18	80.4	68.9	0	20.9	0	16.5	0	6.6	0	6.6	0	16.5
19	79.7	70.0	0	10.2	0	6.4	0	6.4	0	6.4	0	6.4
20	78.7	71.2	0	8.8	0	5.9	0	6.0	0	6.0	0	5.9
21	77.3	71.6	0	7.6	0	5.3	0	5.5	0	5.5	0	5.3
22	75.6	70.5	0	6.3	0	4.5	0	4.7	0	4.7	0	4.5
23	73.7	69.4	0	5.2	0	3.5	0	3.6	0	3.6	0	3.5
24	71.8	67.7	0	4.3	0	2.3	0	2.4	0	2.4	0	2.3

October			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	54.8	51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	52.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	51.2	48.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	49.8	47.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	48.8	46.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	48.2	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	47.9	45.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	48.5	46.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	50.3	47.3	0	27.6	0	0.0	0	0.0	0	0.0	0	0.0
10	52.9	48.7	0	33.8	0	4.0	0	0.0	0	0.0	0	0.0
11	56.2	49.9	0	34.0	0	19.3	0	0.0	0	0.0	0	0.0
12	59.6	51.5	0	34.8	0	26.2	0	0.0	0	0.0	0	0.0
13	62.9	53.5	0	30.1	0	21.2	0	0.0	0	0.0	0	3.6
14	65.5	55.2	0	38.9	0	28.7	0	0.0	0	0.0	0	11.5
15	67.3	56.3	0	41.2	0	31.0	0	0.0	0	0.0	0	17.3
16	67.9	56.6	0	40.0	0	31.3	0	0.0	0	0.0	0	25.2
17	67.7	56.4	0	27.2	0	21.6	0	0.0	0	0.0	0	27.0
18	67.0	56.6	0	13.4	0	9.0	0	0.0	0	0.0	0	21.6
19	66.0	57.6	0	2.4	0	0.0	0	0.0	0	0.0	0	9.0
20	64.6	57.9	0	0.9	0	0.0	0	0.0	0	0.0	0	0.0
21	62.9	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	61.0	56.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	59.0	54.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	56.9	53.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BASELINE COOL-HEAT DEMAND - ALTERNATIVE 1
 MONTHLY BASELINE

November			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	0	0.0	0	0.0	0	0.0	0	0.0	-47,795	0.0
2	46.9	44.1	0	0.0	0	0.0	0	0.0	0	0.0	-85,169	0.0
3	45.5	42.8	0	0.0	0	0.0	0	0.0	0	0.0	-95,145	0.0
4	44.6	41.9	0	0.0	0	0.0	0	0.0	-27,678	0.0	-101,392	0.0
5	44.4	42.0	0	0.0	0	0.0	0	0.0	-35,691	0.0	-104,357	0.0
6	44.8	42.7	0	0.0	0	0.0	0	0.0	-36,644	0.0	-107,187	0.0
7	45.9	43.9	0	0.0	0	0.0	0	0.0	-32,875	0.0	-122,784	0.0
8	47.8	46.0	0	0.0	0	0.0	0	0.0	-12,862	0.0	0	0.0
9	50.2	48.0	0	0.0	0	0.0	0	0.0	-19,311	0.0	0	0.0
10	52.9	49.9	0	0.0	0	0.0	0	0.0	-15,677	0.0	0	0.0
11	55.8	51.1	0	0.0	0	0.0	0	0.0	-15,372	0.0	0	0.0
12	58.5	52.0	0	0.0	0	0.0	0	0.0	-10,905	0.0	0	0.0
13	60.9	52.5	0	0.0	0	0.0	0	0.0	-4,249	0.0	0	0.0
14	62.8	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	64.0	53.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	64.4	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	64.1	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	63.2	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	61.8	54.2	0	0.0	0	0.0	0	0.0	-6,505	0.0	0	0.0
20	60.0	53.6	0	0.0	0	0.0	0	0.0	-10,431	0.0	0	0.0
21	57.9	52.7	0	0.0	0	0.0	0	0.0	-20,557	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	0	0.0	-27,638	0.0	0	0.0
23	53.2	49.5	0	0.0	0	0.0	0	0.0	-34,414	0.0	0	0.0
24	50.8	47.6	0	0.0	0	0.0	0	0.0	-41,450	0.0	0	0.0

December			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	0	0.0	0	0.0	0	0.0	-138,102	0.0	-174,603	0.0
2	37.1	35.1	0	0.0	0	0.0	0	0.0	-167,257	0.0	-180,216	0.0
3	37.4	35.5	0	0.0	0	0.0	0	0.0	-180,692	0.0	-180,688	0.0
4	38.1	36.2	0	0.0	0	0.0	-27,898	0.0	-178,568	0.0	-178,568	0.0
5	39.3	37.6	0	0.0	0	0.0	-48,096	0.0	-176,033	0.0	-176,033	0.0
6	40.9	39.2	0	0.0	0	0.0	-46,412	0.0	-169,566	0.0	-169,566	0.0
7	42.7	41.2	0	0.0	0	0.0	-44,588	0.0	-160,887	0.0	-160,887	0.0
8	44.7	43.1	0	0.0	0	0.0	-23,215	0.0	-99,206	0.0	0	0.0
9	46.8	45.3	0	0.0	0	0.0	-14,779	0.0	-62,318	0.0	0	0.0
10	48.8	47.0	0	0.0	0	0.0	-14,978	0.0	-52,074	0.0	0	0.0
11	50.7	48.1	0	0.0	0	0.0	-19,688	0.0	-56,044	0.0	0	0.0
12	52.2	48.8	0	0.0	0	0.0	-22,378	0.0	-56,364	0.0	0	0.0
13	53.4	49.2	0	0.0	0	0.0	-18,033	0.0	-45,267	0.0	0	0.0
14	54.1	49.2	0	0.0	0	0.0	-13,480	0.0	-29,827	0.0	0	0.0
15	54.4	48.9	0	0.0	0	0.0	-11,727	0.0	-20,896	0.0	0	0.0
16	54.0	48.2	0	0.0	0	0.0	-12,971	0.0	-27,657	0.0	0	0.0
17	53.0	47.3	0	0.0	0	0.0	-21,599	0.0	-61,358	0.0	0	0.0
18	51.4	46.3	0	0.0	0	0.0	-23,636	0.0	-66,891	0.0	0	0.0
19	49.3	45.4	0	0.0	0	0.0	-26,146	0.0	-76,274	0.0	0	0.0
20	47.0	43.5	0	0.0	0	0.0	-29,569	0.0	-106,258	0.0	0	0.0
21	44.5	41.5	0	0.0	0	0.0	-50,304	0.0	-122,306	0.0	0	0.0
22	42.2	39.3	0	0.0	0	0.0	-93,216	0.0	-137,878	0.0	0	0.0
23	40.1	37.6	0	0.0	0	0.0	-120,424	0.0	-152,013	0.0	0	0.0
24	38.5	36.2	0	0.0	0	0.0	-130,039	0.0	-164,302	0.0	0	0.0

BUILDING TEMPERATURE PROFILES - ALTERNATIVE 1
 M184 - BASELINE

----- BUILDING TEMPERATURE PROFILES -----

Temperature ----- Room Number -----
 Range 1 2 3 4
 (F)

Max. Temp. 100.8 88.9 91.4 93.1
 Mo./Hr. 4 17 4 18 4 18 4 18
 Day Type 2 2 2 2

----- Number of Hours -----

Above 100 32 0 0 0
 95 - 100 165 0 0 0
 90 - 95 487 0 96 181
 85 - 90 690 255 561 483
 80 - 85 1,069 598 1,196 993
 75 - 80 4,641 5,233 5,402 5,420
 70 - 75 1,561 2,649 1,505 1,683
 65 - 70 115 25 0 0
 60 - 65 0 0 0 0
 55 - 60 0 0 0 0
 50 - 55 0 0 0 0
 Below 50 0 0 0 0

Min. Temp. 67.8 69.3 71.1 70.1
 Mo./Hr. 10 7 10 7 10 7 10 7
 Day Type 5 5 5 5

‡

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	33,640	107	454	3
Feb	30,356	107	388	3
March	34,718	107	98	2
April	31,386	107	0	0
May	44,153	168	0	0
June	49,980	182	0	0
July	48,000	178	0	0
Aug	51,224	179	0	0
Sept	43,318	175	0	0
Oct	38,159	155	0	0
Nov	31,773	107	61	1
Dec	32,658	107	273	2
Total	469,367	182	1,274	3

Building Energy Consumption = 49,853 (Btu/Sq Ft/Year)
Source Energy Consumption = 142,418 (Btu/Sq Ft/Year)

Floor Area = 34,690 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M184 - BASELINE

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER												
GAS	454	388	98	0	0	0	0	0	0	0	61	273	1,274
PK	2.6	2.6	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.5	2.2	2.6
1 EQ5020	HEAT WATER CIRC. PUMP C.V. <i>2/17/84 1.5 kw</i>												
ELEC	634	535	223	0	0	0	0	0	0	0	264	537	2,193
PK	2.0	2.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	2.0	2.0
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	134	113	47	0	0	0	0	0	0	0	56	113	463
PK	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4
1 EQ5307	BOILER CONTROLS												
ELEC	159	134	56	0	0	0	0	0	0	0	67	135	551
PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
- BASELINE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 181.5 (kW)
Yearly Time of Peak 16 (hr) 6 (mo)

Hour 16 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	75.0	41.32
Sub Total			75.0	41.32
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			15.7	8.67
Sub Total			15.7	8.67
Sub Total			0.0	0.00
Miscellaneous				
Lights			57.2	31.53
Base Utilities			0.0	0.00
Misc Equipment			33.5	18.48
Sub Total			90.8	50.01
Grand Total			181.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M184 - BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 34,690
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,014.8	127,447.1	7.6	144,546.0	4.3
Primary Cooling					
Compressor	54,099.9	0.0	10.7	553,984.4	16.4
Tower/Cond Fans	6,467.6	0.0	1.3	66,228.7	2.0
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	936.0	0.0	0.2	9,584.7	0.3
Auxiliary					
Supply Fans	137,786.0	0.0	27.2	1,410,931.6	41.7
Circulation Pumps	17,704.0	0.0	3.5	181,289.1	5.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	155,489.9	0.0	30.7	1,592,220.6	47.0
Lighting	158,493.3	0.0	31.3	1,622,974.9	46.8
Receptacle	92,865.3	0.0	18.3	950,942.9	27.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	469,366.8	127,447.1	100.0	4,940,482.5	144.1

t

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- INSULATED GLASS

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	33,530	107	338	2
Feb	30,240	107	278	2
March	34,659	107	48	2
April	31,386	107	0	0
May	44,009	165	0	0
June	49,490	178	0	0
July	47,736	175	0	0
Aug	50,896	175	0	0
Sept	43,182	171	0	0
Oct	38,449	152	0	0
Nov	31,610	107	22	1
Dec	32,585	107	176	2
Total	467,773	178	863	2

Building Energy Consumption = 48,510 (Btu/Sq Ft/Year)
Source Energy Consumption = 140,699 (Btu/Sq Ft/Year)

Floor Area = 34,690 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M184 - INSULATED GLASS

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER												
GAS	338	278	48	0	0	0	0	0	0	0	22	176	863
PK	2.2	2.2	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	1.8	2.2
1 EQ5020	HEAT WATER CIRC. PUMP C.V.												
ELEC	559	455	183	0	0	0	0	0	0	0	153	487	1,837
PK	2.0	2.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	2.0	2.0
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	118	96	39	0	0	0	0	0	0	0	32	103	388
PK	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4
1 EQ5307	BOILER CONTROLS												
ELEC	141	115	46	0	0	0	0	0	0	0	38	123	462
PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 - INSULATED GLASS

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 178.0 (kW)
 Yearly Time of Peak 16 (hr) 6 (mo)

Hour 16 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	71.5	40.16
Sub Total			71.5	40.16
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			15.7	8.84
Sub Total			15.7	8.84
Sub Total			0.0	0.00
Miscellaneous				
Lights			57.2	32.16
Base Utilities			0.0	0.00
Misc Equipment			33.5	18.84
Sub Total			90.8	51.00
Grand Total			178.0	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M184 - INSULATED GLASS

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 34,690
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	850.1	86,308.5	5.3	99,555.9	2.9
Primary Cooling					
Compressor	52,504.9	0.0	10.6	537,651.1	15.9
Tower/Cond Fans	6,262.0	0.0	1.3	64,123.5	1.9
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	977.4	0.0	0.2	10,008.6	0.3
Auxiliary					
Supply Fans	137,786.0	0.0	27.9	1,410,931.6	41.7
Circulation Pumps	18,034.1	0.0	3.7	184,669.3	5.5
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	155,820.0	0.0	31.6	1,595,600.8	47.1
Lighting	158,493.3	0.0	32.1	1,622,974.9	46.8
Receptacle	92,865.3	0.0	18.8	950,942.9	27.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	467,773.0	86,308.5	100.0	4,880,858.0	142.4

†

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- ECONOMIZER

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	33,640	107	454	3
Feb	30,356	107	388	3
March	34,718	107	98	2
April	31,386	107	0	0
May	42,533	168	0	0
June	48,782	182	0	0
July	46,531	178	0	0
Aug	50,006	179	0	0
Sept	42,278	175	0	0
Oct	36,162	155	0	0
Nov	31,773	107	61	1
Dec	32,658	107	273	2
Total	460,823	182	1,274	3

Building Energy Consumption = 49,012 (Btu/Sq Ft/Year)
Source Energy Consumption = 139,896 (Btu/Sq Ft/Year)

Floor Area = 34,690 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M184 - ECONOMIZER

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER												
GAS	454	388	98	0	0	0	0	0	0	0	61	273	1,274
PK	2.6	2.6	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.5	2.2	2.6
1 EQ5020	HEAT WATER CIRC. PUMP C.V.												
ELEC	634	535	223	0	0	0	0	0	0	0	264	537	2,193
PK	2.0	2.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	2.0	2.0
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	134	113	47	0	0	0	0	0	0	0	56	113	463
PK	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4
1 EQ5307	BOILER CONTROLS												
ELEC	159	134	56	0	0	0	0	0	0	0	67	135	551
PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
- ECONOMIZER

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 181.5 (kW)
Yearly Time of Peak 16 (hr) 6 (mo)

Hour 16 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	75.0	41.32
Sub Total			75.0	41.32
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			15.7	8.67
Sub Total			15.7	8.67
Sub Total			0.0	0.00
Miscellaneous				
Lights			57.2	31.53
Base Utilities			0.0	0.00
Misc Equipment			33.5	18.48
Sub Total			90.8	50.01
Grand Total			181.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M184 - ECONOMIZER

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 34,690
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,014.8	127,447.1	7.7	144,546.0	4.3
Primary Cooling					
Compressor	49,997.3	0.0	10.0	511,973.6	15.1
Tower/Cond Fans	6,064.0	0.0	1.2	62,095.2	1.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	706.2	0.0	0.1	7,231.5	0.2
Auxiliary					
Supply Fans	137,786.0	0.0	27.7	1,410,931.6	41.7
Circulation Pumps	13,895.9	0.0	2.8	142,294.4	4.2
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	151,681.9	0.0	30.4	1,553,226.0	45.9
Lighting	158,493.3	0.0	31.8	1,622,974.9	46.8
Receptacle	92,865.3	0.0	18.6	950,942.9	27.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	460,822.7	127,447.1	100.0	4,852,990.0	141.5

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- HVAC CONTROLS

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	25,067	109	40	2
Feb	22,660	109	30	2
March	27,031	107	0	1
April	23,836	107	0	0
May	35,423	177	0	0
June	39,080	181	0	0
July	35,773	177	0	0
Aug	39,990	177	0	0
Sept	33,126	173	0	0
Oct	30,949	154	0	0
Nov	23,836	107	0	0
Dec	23,980	109	8	1
Total	360,751	181	78	2

Building Energy Consumption = 35,719 (Btu/Sq Ft/Year)
Source Energy Consumption = 106,727 (Btu/Sq Ft/Year)

Floor Area = 34,690 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
- HVAC CONTROLS

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 180.7 (kW)
Yearly Time of Peak 16 (hr) 6 (mo)

Hour 16 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	74.2	41.05
Sub Total			74.2	41.05
Sub Total			0.0	0.00
Air Moving Equipment				
		SUMMATION OF FAN ELECTRICAL DEMAND	15.7	8.71
Sub Total			15.7	8.71
Sub Total			0.0	0.00
Miscellaneous				
		Lights	57.2	31.68
		Base Utilities	0.0	0.00
		Misc Equipment	33.5	18.56
Sub Total			90.8	50.25
Grand Total			180.7	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M184 - HVAC CONTROLS

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 34,690
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	62.6	7,848.9	0.7	8,902.6	0.3
Primary Cooling					
Compressor	48,325.8	0.0	13.3	494,857.1	14.6
Tower/Cond Fans	5,492.9	0.0	1.5	56,247.2	1.7
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	444.6	0.0	0.1	4,552.7	0.1
Auxiliary					
Supply Fans	47,564.5	0.0	13.1	487,061.7	14.4
Circulation Pumps	7,502.8	0.0	2.1	76,828.4	2.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	55,067.3	0.0	15.2	563,890.0	16.7
Lighting	158,493.3	0.0	43.7	1,622,974.9	46.8
Receptacle	92,865.3	0.0	25.6	950,942.9	27.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	360,751.7	7,848.9	100.0	3,702,367.8	107.5

†

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 WITH ICE STORAGE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	33,640	107	454	3
Feb	30,356	107	388	3
March	34,718	107	98	2
April	31,386	107	0	0
May	47,367	162	0	0
June	53,660	175	0	0
July	51,816	174	0	0
Aug	54,935	175	0	0
Sept	46,942	169	0	0
Oct	40,282	152	0	0
Nov	31,773	107	61	1
Dec	32,658	107	273	2
Total	489,533	175	1,274	3

Building Energy Consumption = 51,837 (Btu/Sq Ft/Year)
 Source Energy Consumption = 148,371 (Btu/Sq Ft/Year)

Floor Area = 34,690 (Sq Ft)

1 EQ4003

FC CENTRIF. FAN C.V.

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M184 - ICE STORAGE

ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1 EQ2001	GAS FIRE TUBE HOT WATER												
GAS	454	388	98	0	0	0	0	0	0	0	61	273	1,274
PK	2.6	2.6	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.5	2.2	2.6
1 EQ5020	HEAT WATER CIRC. PUMP C.V.												
ELEC	634	535	223	0	0	0	0	0	0	0	264	537	2,193
PK	2.0	2.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	2.0	2.0
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	134	113	47	0	0	0	0	0	0	0	56	113	463
PK	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4
1 EQ5307	BOILER CONTROLS												
ELEC	159	134	56	0	0	0	0	0	0	0	67	135	551
PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 - ICE STORAGE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 175.2 (kW)
 Yearly Time of Peak 12 (hr) 6 (mo)

Hour 12 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1750	AIR-CLD CTV ICE-CHILL H2O	68.7	39.20
Sub Total			68.7	39.20
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			15.7	8.98
Sub Total			15.7	8.98
Sub Total			0.0	0.00
Miscellaneous				
Lights			57.2	32.67
Base Utilities			0.0	0.00
Misc Equipment			33.5	19.15
Sub Total			90.8	51.82
Grand Total			175.2	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M184 - ICE STORAGE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 34,690
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,014.8	127,447.1	7.3	144,546.0	4.3
Primary Cooling					
Compressor	71,694.0	0.0	13.6	734,148.2	21.7
Tower/Cond Fans	6,485.4	0.0	1.2	66,410.2	2.0
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,182.0	0.0	0.6	32,583.8	1.0
Auxiliary					
Supply Fans	137,786.0	0.0	26.2	1,410,931.6	41.7
Circulation Pumps	18,012.2	0.0	3.4	184,445.3	5.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	155,798.2	0.0	29.6	1,595,376.7	47.1
Lighting	158,493.3	0.0	30.1	1,622,974.9	46.8
Receptacle	92,865.3	0.0	17.6	950,942.9	27.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	489,532.9	127,447.1	100.0	5,146,983.0	150.2

t

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 M184 - ECO#15

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	31,262	96	502	3
Feb	28,262	96	433	3
March	32,053	96	116	2
April	29,010	96	0	0
May	40,652	153	0	0
June	46,389	167	0	0
July	44,740	163	0	0
Aug	47,460	164	0	0
Sept	40,033	160	0	0
Oct	34,750	141	0	0
Nov	29,437	96	81	2
Dec	30,347	96	307	2
Total	434,395	167	1,438	3

Building Energy Consumption = 46,885 (Btu/Sq Ft/Year)
 Source Energy Consumption = 132,592 (Btu/Sq Ft/Year)

Floor Area = 34,690 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M184 - ECO#15

1	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ2001		GAS FIRE TUBE HOT WATER											
	GAS	502	433	116	0	0	0	0	0	0	81	307	1,438	
	PK	2.6	2.6	1.9	0.0	0.0	0.0	0.0	0.0	0.0	1.6	2.2	2.6	
1	EQ5020		HEAT WATER CIRC. PUMP C.V.											
	ELEC	710	642	239	0	0	0	0	0	0	292	591	2,474	
	PK	2.0	2.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	2.0	2.0	
1	EQ5240		BOILER FORCED DRAFT FAN											
	ELEC	150	136	50	0	0	0	0	0	0	62	125	522	
	PK	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4	
1	EQ5307		BOILER CONTROLS											
	ELEC	178	161	60	0	0	0	0	0	0	73	149	622	
	PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
M184 - ECO#15

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 166.6 (kW)
Yearly Time of Peak 16 (hr) 6 (mo)

Hour 16 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121L	AIR-CLD RECIP 35-60 TONS	70.9	42.54
Sub Total			70.9	42.54
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	15.7	9.44
Sub Total			15.7	9.44
Sub Total			0.0	0.00
Miscellaneous				
	Lights		46.5	27.90
	Base Utilities		0.0	0.00
	Misc Equipment		33.5	20.13
Sub Total			80.0	48.02
Grand Total			166.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M184 - ECO#15

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 34,690
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,144.5	143,680.8	9.1	163,132.8	4.8
Primary Cooling					
Compressor	49,375.5	0.0	10.4	505,606.3	14.9
Tower/Cond Fans	5,966.5	0.0	1.3	61,096.9	1.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	914.4	0.0	0.2	9,363.5	0.3
Auxiliary					
Supply Fans	137,786.0	0.0	28.9	1,410,931.6	41.7
Circulation Pumps	17,626.4	0.0	3.7	180,494.9	5.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	155,412.4	0.0	32.6	1,591,426.5	47.0
Lighting	128,715.8	0.0	27.0	1,318,053.0	38.0
Receptacle	92,865.3	0.0	19.5	950,942.9	27.4
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	434,394.4	143,842.6	100.0	4,599,622.0	134.3

BUILDING 200

EMC ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 04/09/92
 FILE: M200ECO
 PREPARED BY: DENNIS JONES
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M200 Area: 274,244 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Receipt Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	0	22,773	3,538,947	3,261,616	716,492	4,140,593	2,952,151	14,632,572	3,188	0	49,941
Reduced Ventilation	0	20,688	3,543,461	3,261,616	717,486	4,140,593	2,952,151	14,635,995	3,188	0	49,953
Savings (Loss)	0	2,085	(4,514)	0	(994)	0	0	(3,423)	0	0	(12)
Ice Storage	0	22,773	3,400,663	3,261,616	716,492	4,140,593	2,952,151	14,494,288	1,710	2,575	49,469
Savings (Loss)	0	0	138,284	0	0	0	0	138,284	1,475	0	472
Lighting Controls	0	28,559	3,451,761	3,205,009	715,523	3,518,059	2,952,151	13,871,062	3,025	0	47,342
Savings (Loss)	0	(5,786)	87,186	56,607	969	622,534	0	761,510	163	0	2,599

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

B-200 ECO2

VENTILATION

DP31 VENTILATION RATE TO 5 MINUTE IN 6 pm, TO 6 am

<u>VENT 200</u>	0	0
	4	2.5
	6	2.0
	18	2.5
	21	0

ALT-3

CHILLER YORK YT-L3L3-E3 CWA 74 TONS
 0.672 FWH/TON BASELINE
 1.315 " ICE STOR
 14000 TON HRS

BUILDING 200 FAN DATA

EMC PROJECT: #3105.000
 DATE: 03/19/92
 FILE: M200.WK3
 PREPARED BY: DENNIS JONES
 CHECKED BY:

COOLING UNIT	SUPPLY FAN			SPECIFIED		MEASURED		RETURN FAN	
	TOTAL CFM	EXTERNAL STATIC	TOTAL STATIC	OSA CFM	OSA CFM	TOTAL CFM	EXTERNAL STATIC	COOLING CAPAC	
FIRST FLOOR									
AHU-1	13,525	5.40	6.40	1,915	2,692	14,780	3.10	477	
4	13,710	6.60	7.60	1,090	0	12,200	3.20	401	
7	16,680	5.90	6.90	2,150	1,417	15,060	3.10	515	
10	18,010	4.90	5.90	2,440	3,435	17,025	2.80	519	
17	1,910	2.80	3.80	125	0	1,590	2.10	47	
	63,835			7,720	7,544	60,655		1,959	
SECOND FLOOR									
AHU-2	13,525	5.40	6.40	1,410	2,692	12,875	2.70	412	
5	19,795	5.30	6.30	1,945	478	18,105	3.00	582	
8	19,750	5.80	6.80	2,200	814	17,920	3.00	599	
11	19,730	5.10	6.10	2,095	3,010	18,670	2.60	595	
	72,800			7,650	6,994	67,570		2,188	
THIRD FLOOR									
AHU-3	18,350	4.90	5.90	2,200	265	17,445	2.80	632	
6	20,590	5.90	6.90	2,575	2,656	18,920	2.70	676	
9	15,370	5.60	6.60	2,220	915	13,690	2.80	520	
12	22,240	6.70	7.70	2,200	2,904	21,215	2.70	730	
	76,550			9,195	6,740	71,270		2,558	
BASEMENT									
AHU-13	2,040	3.40	4.40	2,040	2,040	245	2.10	88	
14	53,465	6.70	7.70	5,570	3,465	29,850	3.40	1,178	
15	24,075	5.50	6.50	3,540	744	23,245	3.20	954	
16	2,040	4.70	5.70	2,040	2,040	1,856	1.70	88	
	81,620			13,190	8,289	55,196		2,308	
BLDG TOTALS									
	294,805			37,755	29,567	254,691		9,013	

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

COOLING EQUIPMENT

SYSTEM TYPE = TABVAV

VENTILATION

1800 PEOPLE

SPECIFIED 37,755 CFM

MEASURED 27,557 CFM (73%) DIRECT LOW

$37,755 / 1800 = 21$ CFM/PERSON USE 20 CFM/PERSON

SUPPLY FANS

$71,050 \text{ cfm} / 68,544 \text{ ft}^2 = 1.04 \text{ cfm/ft}^2$

1000 FLOORS BASE

EXHAUST AHUS $87,520 \text{ cfm} / 34,300 \text{ ft}^2 = 2.55 \text{ cfm/ft}^2$

ACS 533,000 " / $34,300 \text{ ft}^2 = 15.56$ "

FAN SIZES USE TO FAN 200

COMPUTER

CHILLER

(3) CENTRIFUGALS

COOL 1285 GPM FROM 56°F TO 42°F

WITH 85°F CONDENSER ENT

CAPACITY $1285 \times 500 (55-42) = 9,000,000 \text{ Btu/h}$

(1) 750 tons

EQ1001L

CENTRIFUGAL 750 tons

0.748 W/m²/in

PUMPS

CHILLED WATER

(1) 30 HP } OPERATING
(1) 50 HP }

CONDENSER

(1) 75 HP

HEATING

(2) 10 HP

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

JOB 205,000
 SHEET NO. _____ OF _____
 CALCULATED BY [Signature] DATE 2/25/92
 CHECKED BY _____ DATE _____
 SCALE 1/200

ITEMS HEAT LOAD
PEOPLE

TYPICAL 8-5 SCHEDULE $1700 \text{ PEOPLE} / 3 = 567 \text{ PEOPLE/FLOOR}$
 BASEMENT 24 HRS 100 PEOPLE
 USE 1250 Btu/h sensible
250 Btu/h latent
 DENSITY $68,344 \text{ Btu} / 567 = 120 \text{ Btu/PERSON}$

EQUIPMENT PER PERSON

	Q	WATTS	WATTS/PERSON
PC	100	200	200
SERVER	25	100	25
COPIER	5	500	50
COFFEE	5	260	13
SEAT	5	200	10
			<u>78 / 1200 ft² → 2.32 W/SF</u>

PPL 1 ~~2000~~

LIGHTS - OVERHEAD

7 100 W FIXTURES IN $24 \times 24 = 576 \text{ ft}^2$
 $7 \times 100 \text{ WATT/FIXT} \rightarrow 1030 \text{ WATTS}$ } 1.88 W/SF
 $600 \times 6 \text{ AW} / 200 \times 200 \text{ ft}^2 \rightarrow 2.19 \text{ W/SF} \leftarrow$

TASK

(2) $340 \text{ (WITH BALLAST)} = 80 \text{ W} / 120 \text{ ft}^2 \rightarrow 0.67 \text{ W/SF} \leftarrow$

TOTAL LIGHTING

2.86 W/SF

OUTDOOR

5.6 AW TOTAL

SUPPLY 600-2200 200

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____


CHECKED BY _____ DATE _____

SCALE 1/4" = 1'-0"

HEAT LOSS

$$\text{HEAT RECEIVER CAPACITY} = \frac{\text{HEATING CAPACITY}}{\text{TEMP. DIFF.}} = \frac{2800 \text{ MBH}}{22 \text{ °F}} = 127 \text{ TONS}$$

ENERGY LOSS: 127 TONS HEATING LOSS
 FROM MECH. LOSS: 0 TONS HEATING LOSS



$$\text{POWER} = 2800 - 1600 = 1200 \text{ MBH} = 352 \text{ kW}$$

CAP. 63

$$\begin{aligned} \text{HEAT RECEIVER CAPACITY} &= 2800 \text{ MBH} \\ \text{ENERGY LOSS} &= 352 \text{ kW} \end{aligned}$$

2 SURF.)

256 MBH OUT
 39 KW

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany




JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY [Signature] DATE 3/25/92

CHECKED BY _____ DATE _____

SCALE 1/200




TOO COMPLEX TO DRAW AS SHOWN

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

JOB 3195.000
 SHEET NO. _____ OF _____
 CALCULATED BY [Signature] DATE 2/25/92
 CHECKED BY _____ DATE _____
 SCALE 1/200

TRACED WALL
U-VALUES

<u>WALL</u>	OUTER FILM		0.25
	EXT. AIR SPACE	6"	2.00
	FOAM INSUL	2"	10.0 (POLYSTYR)
	AIR SPACE	4"	1.01
	DRY WALL	5/8"	0.56
	INNER FILM		0.68
			<u>13.01</u>
			<u>U = 0.076</u>



UNDER SLAB WALL

	CONC	14"	1.40
	AIR SPACE	7/8"	1.01
	DRY WALL	5/8"	0.56
	INNER FILM		0.68
			<u>3.65</u>
			<u>U = 0.27</u>

ROOF

	OUTER FILM		0.25
	BUILT UP ROOFING		0.33
	INSULATING CONC	1"	0.23
	INSULATION BOARD	4"	16.00 (FG BOARD)
	4" CONC		0.40
	INNER FILM		0.92
			<u>18.13</u>
			<u>U = 0.055</u>

GLASS

	1" INSULATING WITH OUTER TINT		U = 0.59
	THERM-C ALUM FRAME W/THERMAC BEAR.		SC = 0.58

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

THERMAL STORAGE DEMAND SAVINGS

CHILLER	—	598 KW
COND W. PUMP	—	<u>75 KW</u>
		673 KW

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 2/25/92

CHECKED BY _____ DATE _____

SCALE _____

FT. MAC.

BLDG 200 EXTERIOR LIGHTING

<u>QUANTITY</u>	<u>WATTS/FIX</u>	<u>TOTAL WATTS</u>
36	100 (MERC. VAPOR)	3600
8	250 (MET. HALIDE)	1750 2000
	TOTAL	<u><u>5.6 kW</u></u>

BUILDING - M184

TRACE - 600 INPUT DATA

EMC PROJECT:
DATE:
FILE:
PREPARED BY:
CHECKED BY:

#3106.000
02/21/92
DENNIS JONES

DUPLICATE FIGURES

CARD DESCRIPTION

20	ROOM NUMBER	1	2	3	4	5	6	7
	ROOM DESCRIPTION	NORTH	EAST	SOUTH	WEST	CORE	BASEMENT	CLIMATE
	FLOOR LENGTH	216	424	384	288	633		
	FLOOR WIDTH	4	4	4	4	100		
	CONSTRUCTION TYPE	5" CONC						
21	PLENUM HEIGHT	5.5'					3.5	
	FLOOR-TO-FLOOR HEIGHT	9					20	
	DESIGN COOLING DRY BULB	76						
	COOLING THERMOSTAT SCHEDULE	ON						
	DESIGN HEATING DRY BULB	72						
	HEATING THERMOSTAT SCHEDULE	2						
	CARPET?	YES						
22	ROOF NUMBER	1	2	3	4	5		
	ROOF AREA = FLOOR AREA?	YES						
	ROOF LENGTH							
	ROOF WIDTH							
	ROOF U-VALUE	0.055						
	ROOF TYPE/DESCRIPTION	5" CONC						
	ROOF DIRECTION							
	ROOF TILT	90°						
	ROOF ALPHA	135						
24	WALL NUMBER	1	2	1	1	1	1	
	WALL LENGTH	216	288/136				1312	
	WALL WIDTH	15.5					23.5	
	WALL U-VALUE	0.076					0.27	
	WALL TYPE/DESCRIPTION	5" CONC					0.06	
	WALL DIRECTION	C	70/45	180	270			
	WALL ALPHA	MEP						
25	GLASS LENGTH	216	288/136	384	288	633		
	GLASS HEIGHT	5'						
	NUMBER OF WINDOWS	1						
	GLASS U-VALUE	0.59						
	SHADING COEFFICIENT	0.58						
26	SCHEDULES							
	PEOPLE	OFFICE						24 HRS
	LIGHTS	"						"
	VENTILATION	AVAL						"
	INFILTRATION							
	COOLING FAN	ALAS						
	HEATING FAN	"						
27	PEOPLE HEAT GAIN	100 BTU/PERSON					50	50
	PEOPLE SENSIBLE	250						
	PEOPLE LATENT	230						
	LIGHTING HEAT GAIN	20 BTU/30'						
28	EQUIPMENT HEAT GAIN	220						
	EQUIPMENT SCHEDULE	OFFICE						24 HRS
	ENERGY METER CODE	ELECTRIC						
29	VENTILATION COOLING RATE	0.19					0.192	0.192
	VENTILATION HEATING RATE	"					"	"
	INFILTRATION COOLING RATE							
	INFILTRATION HEATING RATE							
30	COOLING AIRFLOW	1.04 CFM/FT ²					2.38	15.56
	HEATING AIRFLOW							
	EXHAUST AIRFLOW	0					0	0
32	PERIMETER LENGTH							
	PERIMETER LOSS COEFFICIENT							
40	SYSTEM SET NUMBER	1						2
	SYSTEM TYPE	TABVAU						FC
	VENTILATION DECK LOCATION	ROOF						DUCT
	COOLING SCHEDULE							
	HEATING SCHEDULE							
42	COOLING FAN STATIC PRESSURE	6.5						10.5
	HEATING FAN STATIC PRESSURE	3.0						
44	ECONOMIZER TYPE	DRY BYP						1/UNE
	ECONOMIZER ON POINT	65						
	MAXIMUM % OUTSIDE AIR	100						
62	COOLING EQUIPMENT CODE NAME	EQ1001L						
	COOLING CAPACITY	2250 TONS						
	ENERGY RATE	0.745 kW/TON						
	CHILLED WATER PUMP CONSUMPTION	535 GPM		90'				
	CONDENSER PUMP CONSUMPTION	4500		100'				
67	HEATING EQUIPMENT CODE NAME							
	HOT WATER PUMP CONSUMPTION	76		75'				
69	COOLING FAN CODE	STCLT						
	HEATING FAN CODE	"						

01 Card - Job Information

 Project: FORT MCPHERSON & GILLEM EEAP #3105.000
 Location: ATLANTA
 Client: COE - DACA21-9-C-0097
 Program User: DENNIS JONES
 Comments: BUILDING 200 - FORT MCPHERSON

-----CARD 08-- Climatic Information -----
 Summer Winter Summer Summer Winter Summer Winter
 Weather Clearness Clearness Design Design Design Building Ground Ground
 Code Number Number Dry Bulb Wet Bulb Dry Bulb Orientation Reflect Reflect
 ATLANTA

----- Load Section Alternative #1 -----

---- Load Alternative ----
 Number Description
 1 BASELINE

-----CARD 20-- General Room Parameters -----
 Zone
 Room Reference Room Floor Floor Const Plenum Acoustic Floor to Duplicate Duplicate Perimeter
 Number Number Descrip Length Width Type Height Resistance Height Floors Rooms per Depth
 1 1 NORTH ZONES 216 4 5 14 3
 2 2 EAST ZONES 424 4 5 14 3
 3 3 SOUTH ZONES 384 4 5 14 3
 4 4 WEST ZONES 288 4 5 14 3
 5 5 CORE ZONES 633 100 5 14 3
 6 6 BASEMENT 34.3 1000 5 14
 7 7 BASEMENT COMPUTE 34.3 1000 5 14

-----CARD 21-- Thermostat Parameters -----
 Cooling Room Cooling Cooling Heating Heating Heating T'stat Mass / Carpet
 Room Room Design T'stat T'stat Room T'stat T'stat Location No. Hrs On
 Number Design DB RH Driftpoint Schedule Design DB Driftpoint Schedule Flag Average Floor
 1 76 CLG76 72 65 HTG72

-----CARD 22-- Roof Parameters -----

Roof

Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	YES			0.055	11			0.45
2	1	YES			0.055	11			0.45
3	1	YES			0.055	11			0.45
4	1	YES			0.055	11			0.45
5	1	YES			0.055	11			0.45

-----CARD 23-- Skylight Parameters-----

Pct Glass

Room Number	Roof Number	Skylight Length	Skylight Width	Pct Glass or No. of Windows	Skylight U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
5	1	24	24	1	0.59	0.58					

-----CARD 24-- Wall Parameters -----

Wall

Ground

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
1	1	216	15.5	0.076	58	0		0.68	
2	1	288	15.5	0.076	58	90		0.68	
2	2	136	15.5	0.076	58	45		0.68	
3	1	384	15.5	0.076	58	180		0.68	
4	1	288	15.5	0.076	58	270		0.68	

-----CARD 25-- Wall/Glass Parameters -----

Pct Glass

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
1	1	216	5	1	0.59	0.58					
2	1	288	5	1	0.59	0.58					
2	2	136	5	1	0.59	0.58					
3	1	384	5	1	0.59	0.58					
4	1	288	5	1	0.59	0.58					

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
M1	PPL1	LGT200	FAN200			FAN200	FAN200		AVAIL	
7	AVAIL	AVAIL	AVAIL			AVAIL	AVAIL		AVAIL	

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting		Ballast Factor	Percent Lights to Ret. Air	--- Daylighting ---	
							Fixture Type				Reference Point 1	Reference Point 2
M1	120	SF-PERS	250	200	2.86	WATT-SF			1			

-----CARD 28--- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
7	1	GENERAL OFFICE	1.40	WATT-SF	AVAIL	ELEC					
7	2	COMPUTERS	180	KW	AVAIL	ELEC	100				
7	3	OUTDOOR LIGHTS	5.6	KW	OUTLITE	ELEC	0				

-----CARD 29--- Room Airflows -----

Room Number	-----Ventilation-----				-----Infiltration-----				--Reheat Minimum--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
M1	20	CFM-P	20	CFM-P						
2	0.119	CFM-SF	0.119	CFM-SF						

-----CARD 30- Fan Airflows -----

Room Number	-----Main-----				-----Auxiliary-----				--Room Exhaust--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
M1										
7	15.56	CFM-SF	15.56	CFM-SF						

-----CARD 31-- Partition Parameters -----

Room Number	Partition Number	Partition Length	Partition Height	Partition U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No
6	1	1312	23.5	0.27	108	SINE-FIT	65	55	

-----CARD 32-- Exposed Floor Parameters-----

Room Number	Exposed Floor Number	-----Slab-----		-----Exposed Floor-----						
		Perimeter Length	Loss Coefficient	Floor Area	Floor U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No
6	1									


```

-----CARD 47-- Fan Overrides -----
Sys Clg Htg Ret Mn Exh Aux Rm Exh Opt Vnt -----MAIN COOLING FAN-----
Set Fan Fan Fan Fan Fan Fan Sys Fan Mech Air Air Size
Num Eff Eff Eff Eff Eff Eff Eff Eff Value Units Meth Config
1 290720 CFM
2 533708 CFM

```

```

----- Equipment Section Alternative #1 -----

```

```

-----CARD 59-- Equipment Description / TOD Schedules -----

```

```

      Elec Consump Elec Demand Demand
Alternative Time of Day Time of Day Limit
Number      Schedule      Schedule      Max KW Alternative Description
1                                     M200 - BASELINE

```

```

-----CARD 60--- Cooling Load Assignment-----

```

```

Load All Coil Cooling
Asgn Loads To Equipment -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
Ref Cool Ref Sizing Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
1 1 BLKPLANT 1 2

```

```

-----CARD 62-- Cooling Equipment Parameters -----

```

```

Cool Equip Num -----COOLING----- -----HEAT RECOVERY----- Seq Demand
Ref Code Of --Capacity-- ----Energy---- --Capacity-- ----Energy---- Order Seq Limit
Num Name Units Value Units Value Units Value Units Value Units Num Type Number
1 EQ1010L 3 2250 TONS 0.672 KW-TON

```

```

-----CARD 63-- Cooling Pumps and References -----

```

```

Cool ---CHILLED WATER---- -----CONDENSER----- ---HT REC or AUX---- Switch-
Ref Full Load Full Load Full Load Full Load Full Load Full Load Full Load over Cold Cooling Misc.
Num Value Units Value Units Value Units Value Units Control Storage Tower Access.
1 80 HP 75 HP

```

```

-----CARD 64-- Cooling Equipment Options -----

```

```

Cool Max Load Free Cond Cond Cond Rej Cond Rej Cond Rej
Ref CW Shed Evap Cooling Heat Entering Min Oper To Ref To Ref @ HW
Num Reset Economizer Precool Type Source Temp Temp Type Number Temp
1 85 HEATING 1 95

```

```

-----CARD 65-- Heating Load Assignment -----

```

```

Load All Coil
Assignment Loads To -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-

```


-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld Value	Units	Cap'y Value	Units	Energy Rate Value	Units	Seq Order	Switch over	Hot Strg	Misc. Acc.	Cogen	Demand Limit
1	HEATPUMP	1							1					
2	EQ2051	1	21	HP	1600	MBH	100	PCTEFF	2					

-----CARD 69-- Fan Equipment Parameters -----

System	Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
	1	CECAFVAR	CECFCFAN	CECAFVAR				
	2	CECFCFAN						

-----CARD 74--- Condenser / Cooling Tower Parameters -----

Tower Ref	Cooling Tower Code	Capacity Value	Capacity Units	Energy Consump Value	Energy Consump Units	Fluid Type	Tower Type	Number Of Cells	Percent Airflow Low Spd	Low Spd Energy Value	Low Spd Energy Units
1	CECTOWER	33750	MBH								

----- Equipment Section Alternative #2 -----

-----CARD 59-- Equipment Description / TOD Schedules -----

Alternative Number	Time of Day Schedule	Elec Consump	Elec Demand	Demand Limit	Alternative Description
2					M200 - ICE STORAGE

-----CARD 60--- Cooling Load Assignment-----

Load Ref	All Cool Ref	Equipment Sizing	-Group 1- Begin End	-Group 2- Begin End	-Group 3- Begin End	-Group 4- Begin End	-Group 5- Begin End	-Group 6- Begin End	-Group 7- Begin End	-Group 8- Begin End	-Group 9- Begin End
1	1	BLKPLANT	1	2							

-----CARD 62-- Cooling Equipment Parameters -----

Cool Ref	Equip Code	Num Of	-----COOLING-----				-----HEAT RECOVERY-----				Seq Order	Demand Limit	
Num	Name	Units	--Capacity-- Value	Units	Value	Units	--Capacity-- Value	Units	Value	Units	Num	Type	Number
1	EQ1010L	3	2250	TONS	0.672	KW-TON							

-----CARD 62-- Cooling Equipment Parameters -----

-----TANK CHARGE-----				-----TANK & HT REC-----			
---Capacity---		---Energy---		---Capacity---		---Energy---	
Value	Units	Value	Units	Value	Units	Value	Units
1600	TONS	0.840	KW-TON				

-----CARD 63-- Cooling Pumps and References -----

Cool Ref	Full Load Value	Full Load Units	CONDENSER Full Load Value	CONDENSER Full Load Units	HT REC or AUX Full Load Value	HT REC or AUX Full Load Units	Switch over Control	Cold Storage	Cooling Tower	Misc. Access.
1	80	HP	75	HP				1		

-----CARD 64-- Cooling Equipment Options -----

Cool Ref	Max CW	Load Shed	Free Evap	Free Cooling Type	Cond Heat Source	Cond Entering Temp	Cond Min Oper Temp	Cond Rej To Ref Type	Cond Rej To Ref Number	Cond Rej @ HW Temp
1						85		HEATING	1	95

-----CARD 65-- Heating Load Assignment -----

Load Assignment Reference	All Coils	Heating Ref	-Group 1- Begin End	-Group 2- Begin End	-Group 3- Begin End	-Group 4- Begin End	-Group 5- Begin End	-Group 6- Begin End	-Group 7- Begin End	-Group 8- Begin End	-Group 9- Begin End
1		1	2								

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld Value	HW Pmp Units	Cap'y Value	Cap'y Units	Energy Rate Value	Energy Units	Seq Order Number	Switch over Control	Hot Strg	Misc. Acc.	Cogen	Demand Limit Number
1	HEATPUMP	1							1					
2	EQ2051	1	21	HP	1600	MBH	100	PCTEFF	2					

-----CARD 69-- Fan Equipment Parameters -----

System Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	CECAFVAR	CECFCFAN	CECAFVAR				
2	CECFCFAN						

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
AVAIL (Utility file not found)
CLG76 COOLING TSTAT SCHEDULE - 76
FAN200
HTG72 HEATING ONLY (T-STAT AT 72)
ICE
LGT1
LGT200
OFF (Utility file not found)
OUTLITE (Utility file not found)
PPL1

System:

COMP COMPUTER ROOM UNIT
FPVAV FAN POWERED VAV

Equipment:

Cooling:

EQ1010L HR CTV >190 TONS 95 F

Heating:

EQ2051 ELECTRIC HOT WATER BOILER
HEATPUMP

Fan:

CECAFVAR AIR FOIL CENTRIFUGAL W\VAR SPEED DRIVE
CECFCFAN FORWARD CURVE CENT. FAN CONSTANT VOLUME

Accessories:

Storage:

CLIMAICE TRANE CALMAC THERMAL STORAGE SYSTEM

Tower:

CECTOWER COOLING TOWER

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: CLG76

Project: COOLING TSTAT SCHEDULE - 76

Location:

Client:

Program User:

Comments: COOLING THERMOSTAT - SET AT 76

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 76
24

Schedule Name: FAN200
Project:
Location:
Client:
Program User:
Comments: BLDG-200 FAN SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
4	100	
21	0	
24		

File Name: HTG72

Project: HEATING ONLY (T-STAT AT 72)

Location:

Client:

Program User:

Comments: HEATING ONLY SCHEDULE - T-STAT

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 72

24

Schedule Name: ICE
Project:
Location:
Client:
Program User:
Comments: ICE STORAGE

Starting Month: APR Ending Month: NOV
Starting Day Type: DSGM Ending Day Type: SUN

Hour	Tank Cntrl
0	CHARGE
6	SATLOAD
12	DISCHARG
16	SATLOAD
24	

Rule Name: LGT1
Project:
Location:
Client:
Program User:
Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	5
24	

Schedule Name: LGT200

Project:

Location:

Client:

Program User:

Comments: BLDG-200 OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

0	5
7	80
8	100
12	80
13	100
16	80
17	60
21	30
23	5
24	

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

0	5
8	30
17	5
24	

Module Name: PPL1
Project:
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

01 Card - Job Information

 Project: FORT MCPHERSON & GILLEM EEAP #3105.000
 Location: ATLANTA
 Client: COE - DACA21-9-C-0097
 Program User: DENNIS JONES
 Comments: BUILDING 200 - FORT MCPHERSON

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	NORTH ZONES	216	4		5		14	3		
2	2	EAST ZONES	424	4		5		14	3		
3	3	SOUTH ZONES	384	4		5		14	3		
4	4	WEST ZONES	288	4		5		14	3		
5	5	CORE ZONES	633	100		5		14	3		
6	6	BASEMENT	34.3	1000		5		14			
7	7	BASEMENT COMPUTE	34.3	1000		5		14			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location Flag	Mass / No. Hrs Average	Carpet On Floor
1	76			CLG76	72	65	HTG72			

-----CARD 22-- Roof Parameters -----

Roof										
Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha	
1	1	YES			0.055	11			0.45	
2	1	YES			0.055	11			0.45	
3	1	YES			0.055	11			0.45	
4	1	YES			0.055	11			0.45	
5	1	YES			0.055	11			0.45	

-----CARD 23-- Skylight Parameters-----

Pct Glass												
Room Number	Roof Number	Skylight Length	Skylight Width	or No. of Windows	Skylight U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret.	Visible Air Transmittance	Percent Visible	Inside Visible Reflectance
5	1	24	24	1	0.59	0.58						

-----CARD 24-- Wall Parameters -----

Wall											Ground
Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Wall Reflectance	Ground Multiplier	
1	1	216	15.5	0.076	58	0		0.68			
2	1	288	15.5	0.076	58	90		0.68			
2	2	136	15.5	0.076	58	45		0.68			
3	1	384	15.5	0.076	58	180		0.68			
4	1	288	15.5	0.076	58	270		0.68			

-----CARD 25-- Wall/Glass Parameters -----

Pct Glass												
Room Number	Wall Number	Glass Length	Glass Width	or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret.	Visible Air Transmittance	Percent Visible	Inside Visible Reflectance
1	1	216	5	1	0.59	0.58						
2	1	288	5	1	0.59	0.58						
2	2	136	5	1	0.59	0.58						
3	1	384	5	1	0.59	0.58						
4	1	288	5	1	0.59	0.58						

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
M1	PPL1	LGT200	FAN200			FAN200	FAN200		AVAIL	
7	AVAIL	AVAIL	AVAIL			AVAIL	AVAIL		AVAIL	

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	--- Daylighting --- Reference Point 1	Reference Point 2
M1	120	SF-PERS	250	200	2.86	WATT-SF		1			

-----CARD 28--- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
M1	1	GENERAL OFFICE	1.40	WATT-SF	LGT1	ELEC					
7	1	GENERAL OFFICE	1.40	WATT-SF	AVAIL	ELEC					
7	2	COMPUTERS	180	KW	AVAIL	ELEC	100				
7	3	OUTDOOR LIGHTS	5.6	KW	OUTLITE	ELEC	0				

-----CARD 29--- Room Airflows -----

Room Number	-----Ventilation-----				-----Infiltration-----				--Reheat Minimum--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
M1	20	CFM-P	20	CFM-P						
2	0.119	CFM-SF	0.119	CFM-SF						

-----CARD 30- Fan Airflows -----

Room Number	-----Main-----				-----Auxiliary-----				--Room Exhaust--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
M1										
7	15.56	CFM-SF	15.56	CFM-SF						

-----CARD 31-- Partition Parameters -----

Room Number	Partition Number	Partition Length	Partition Height	Partition U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No
6	1	1312	23.5	0.27	108	SINE-FIT	65	55	

-----CARD 32-- Exposed Floor Parameters-----

Room Number	Exposed Slab-----				-----Exposed Floor-----						
	Floor Number	Perimeter Length	Loss Coefficient	Floor Area	Floor U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No	
6	1										

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld	Energy Rate	Seq Order	Switch over	Hot Strg	Misc. Acc.	Cogen	Demand Limit
Number	Name	Units	Value Units	Value Units	Number	Control				Number
1	HEATPUMP	1			1					
2	EQ2051	1	21 HP	1600 MBH	100	PCTEFF				2

-----CARD 69-- Fan Equipment Parameters -----

System

Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	CECAFVAR	CECFCFAN	CECAFVAR				
2	CECFCFAN						

-----CARD 74--- Condenser / Cooling Tower Parameters -----

Tower Ref	Cooling Tower Code	Capacity Value	Capacity Units	Energy Consump Value	Energy Consump Units	Fluid Type	Tower Type	Number Of Cells	Percent Airflow Low Spd	Low Spd Energy Value	Low Spd Energy Units
1	CECTOWER	33750	MBH								

----- Equipment Section Alternative #2 -----

-----CARD 59-- Equipment Description / TOD Schedules -----

Alternative Number	Time of Day Schedule	Elec Consump	Elec Demand	Demand Limit	Max KW	Alternative Description
2						M200 - ICE STORAGE

-----CARD 60--- Cooling Load Assignment-----

Asgn Ref	Loads To Cool Ref	Equipment Sizing	-Group 1- Begin End	-Group 2- Begin End	-Group 3- Begin End	-Group 4- Begin End	-Group 5- Begin End	-Group 6- Begin End	-Group 7- Begin End	-Group 8- Begin End	-Group 9- Begin End
1	1	BLKPLANT	1	2							

-----CARD 62-- Cooling Equipment Parameters -----

Cool Ref	Equip Code	Num Of	-----COOLING-----				-----HEAT RECOVERY-----				Seq Order	Demand Limit	
Num	Name	Units	--Capacity-- Value	Units	Value	Units	Value	Units	Value	Units	Num	Type	Number
1	EQ1010L	3	2250	TONS	0.672	KW-TON							

-----CARD 62-- Cooling Equipment Parameters -----

-----TANK CHARGE-----				-----TANK & HT REC-----			
---Capacity---		----Energy----		---Capacity---		----Energy----	
Value	Units	Value	Units	Value	Units	Value	Units
1600	TONS	0.840	KW-TON				

-----CARD 63-- Cooling Pumps and References -----

Cool Ref	Full Load Value	Full Load Units	Full Load Value	Full Load Units	Full Load Value	Full Load Units	Full Load Value	Full Load Units	Switch over Control	Cold Storage	Cooling Tower	Misc. Access.
1	80	HP	75	HP						1		

-----CARD 64-- Cooling Equipment Options -----

Cool Ref	Max CW	Load Shed	Free Evap Precool	Cond Cooling Type	Cond Heat Source	Cond Entering Temp	Cond Min Oper Temp	Cond Rej To Ref Type	Cond Rej To Ref Number	Cond Rej @ HW Temp
1						85		HEATING	1	95

-----CARD 65-- Heating Load Assignment -----

Load	Assignment Reference	All Coil Heating Ref	-Group 1- Begin End	-Group 2- Begin End	-Group 3- Begin End	-Group 4- Begin End	-Group 5- Begin End	-Group 6- Begin End	-Group 7- Begin End	-Group 8- Begin End	-Group 9- Begin End
	1		1	2							

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld Value	Cap'y Units	Energy Rate Value	Seq Order	Switch over Control	Hot Strg	Misc. Acc.	Demand Limit Cogen
1	HEATPUMP	1				1				
2	EQ2051	1	21	HP	1600 MBH	100	PCTEFF			2

-----CARD 69-- Fan Equipment Parameters -----

System Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	CECAFVAR	CECFAN	CECAFVAR				
2	CECFAN						

-----CARD 73-- Storage Tank Parameters -----

Strg	Tank	Size	Sched	Control	Limit		
Ref	Code	Value	Units	Code	Type	Value	Units
1	CLIMAICE	4000	TON-HRS	ICE	OPTIMIZE		

-----CARD 73-- Storage Tank Parameters -----

Charge	Control	Mx Ls	Warning	Loss		
Type	Value	Units	Value	Units	Value	Units
FULLCHG					0.07	PERCENT

-----CARD 74--- Condenser / Cooling Tower Parameters -----

Cooling	Energy	Energy	Number	Percent	Low Spd	Low Spd
Tower	Consump	Consump	Of	Airflow	Energy	Energy
Ref	Code	Value	Cells	Low Spd	Value	Units
1	CECTOWER	33750	MBH			

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
AVAIL (Utility file not found)
CLG76 (Utility file not found)
FAN200
HTG72 (Utility file not found)
ICE
LGT1
LGT200
OFF (Utility file not found)
OUTLITE (Utility file not found)
PPL1

System:

COMP COMPUTER ROOM UNIT
FPVAV FAN POWERED VAV

Equipment:

Cooling:
EQ1010L HR CTV >190 TONS 95 F

Heating:
EQ2051 ELECTRIC HOT WATER BOILER
HEATPUMP

Fan:

CECAFVAR AIR FOIL CENTRIFUGAL W\VAR SPEED DRIVE
CECFCFAN FORWARD CURVE CENT. FAN CONSTANT VOLUME

Accessories:

Storage:
CLIMAICE TRANE CALMAC THERMAL STORAGE SYSTEM

Tower:
CECTOWER COOLING TOWER

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: FAN200

Project:

Location:

Client:

Program User:

Comments: BLDG-200 FAN SCHEDULE

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: SUN

Hour Util Percent

---- -

0	0
4	100
21	0
24	

Schedule Name: ICE
Project:
Location:
Client:
Program User:
Comments: ICE STORAGE

Starting Month: APR Ending Month: NOV
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Tank Cntrl
0	CHARGE
6	SATLOAD
12	DISCHARG
16	SATLOAD
24	

Schedule Name: LGT1
Project:
Location:
Client:
Program User:
Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	5
24	

Schedule Name: LGT200

Project:

Location:

Client:

Program User:

Comments: BLDG-200 OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: SUN

Hour Util Percent

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
21	5
24	

File Name: PPL1
Project:
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util	Percent
0	0	
7	50	
8	100	
11	80	
12	40	
13	80	
14	100	
16	70	
17	30	
18	0	
24		

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

**
** TRACE 600 ANALYSIS **
**
** by **
**

FORT MCPHERSON & GILLEM EEAP #3105.000
ATLANTA
COE - DACA21-9-C-0097
DENNIS JONES
BUILDING 200 - FORT MCPHERSON

Weather File Code: ATLANTA.
Location:
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: June To November
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 15:35: 7 3/13/92
Dataset Name: M200 .TM

LOW - ALTERNATIVE 1
 BASELINE

----- SYSTEM SUMMARY -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	FPVAV	39,748	290,720	15,621	290,720	290,720	0	0
2	COMP	5,717	533,708	533,708	533,708	5,717	0	0
Totals		45,465	824,428	549,329	824,428	296,437	0	0

CAPACITY - ALTERNATIVE 1
 BASELINE

----- SYSTEM SUMMARY -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating							
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)
1	FPVAV	781.7	0.0	0.0	0.0	781.7	-998,255	0	-1,383,473	0	0	0	0	-2,381,728
2	COMP	146.6	0.0	0.0	0.0	146.6	0	0	-2,725,540	0	0	0	0	-2,725,540
Totals		928.3	0.0	0.0	0.0	928.3	-998,255	0	-4,109,012	0	0	0	0	-5,107,268

The building peaked at hour 15 month 8 with a capacity of 928.3 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BASELINE

----- ENGINEERING CHECKS -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	FPVAV	13.67	1.21	371.9	306.9	39.10	0.07	-9.93	239,944
2	Main	COMP	1.07	15.56	3,640.6	234.0	51.29	15.56	-79.46	34,300

System 1 Block FPVAV - FAN POWERED VAV

***** COOLING COIL PEAK ***** CLG SPACE PEAK ***** HEATING COIL PEAK *****

Peaked at Time ==> Mo/Hr: 8/15 * Mo/Hr: 9/15 * Mo/Hr: 13/ 1
 Outside Air ==> OADB/WB/HR: 92/ 74/105.0 * OADB: 90 * OADB: 22

	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	*	Space Sensible (Btuh)	Perct Of Tot (%)	*	Space Peak (Btuh)	Coil Peak (Btuh)	Perct Of Tot (%)
Envelope Loads												
Skylite Solr	58,752	0	0	58,752	0.63	*	47,232	0.93	*	0	0	0.00
Skylite Cond	0	5,695	0	5,695	0.06	*	0	0.00	*	0	-15,512	1.56
Roof Cond	0	156,484	0	156,484	1.67	*	0	0.00	*	0	-161,641	16.27
Glass Solar	814,080	0	0	814,080	8.68	*	915,360	18.04	*	0	0	0.00
Glass Cond	198,962	0	0	198,962	2.12	*	171,095	3.37	*	-570,011	-570,011	57.38
Wall Cond	27,307	29,976	0	57,283	0.61	*	22,365	0.44	*	-69,288	-138,045	13.90
Partition	-89,074	0	0	-89,074	-0.95	*	-104,058	-2.05	*	-108,220	-108,220	10.89
Exposed Floor	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total==>	1,010,027	192,154	0	1,202,181	12.82	*	1,051,994	20.74	*	-747,519	-993,429	100.00
Internal Loads												
Lights	2,342,136	0	0	2,342,136	24.97	*	2,342,136	46.17	*	0	0	0.00
People	899,790	0	0	899,790	9.59	*	499,883	9.85	*	0	0	0.00
Misc	1,146,500	0	0	1,146,500	12.22	*	1,146,500	22.60	*	0	0	0.00
Sub Total==>	4,388,427	0	0	4,388,427	46.78	*	3,988,520	78.62	*	0	0	0.00
Ceiling Load	40,487	-40,487	0	0	0.00	*	32,497	0.64	*	-198,688	0	0.00
Outside Air	0	0	0	1,933,531	20.61	*	0	0.00	*	0	0	0.00
Sup. Fan Heat	0	0	0	1,343,772	14.32	*	0	0.00	*	0	0	0.00
Ret. Fan Heat	0	620,203	0	620,203	6.61	*	0	0.00	*	0	0	0.00
Duct Heat Pkup	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
OV/UNDR Sizing	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat	0	-107,499	0	-107,499	-1.15	*	0	0.00	*	0	0	0.00
Terminal Bypass	0	0	0	0	-0.00	*	0	0.00	*	0	0	0.00
Grand Total==>	5,438,941	664,371	0	9,380,615	100.00	*	5,073,010	100.00	*	-946,207	-993,429	100.00

-----COOLING COIL SELECTION-----

-----AREAS-----

	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)
Main Clg	781.7	9,380.6	7,784.3	290,720	79.6	63.7	66.5	54.4	52.6	58.6	239,944	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	30,832	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0	
Totals	781.7	9,380.6									68,548	576 1
											61,008	19,680 32

-----HEATING COIL SELECTION-----

-----AIRFLOWS (cfm)-----

-----ENGINEERING CHECKS-----

-----TEMPERATURES (F)-----

	Capacity (Mbh)	Coil Airfl (cfm)	Ent (Deg F)	Lvg (Deg F)	Type	Cooling	Heating	Clg % OA	13.7	Type	Clg	Htg
Main Htg	-998.3	15,621	65.4	125.0	Infil	39,748	0	Clg Cfm/Sqft	1.21	SADB	58.8	125.0
Aux Htg	0.0	0	0.0	0.0	Supply	290,720	15,621	Clg Cfm/Ton	371.90	Plenum	75.5	65.6
Preheat	-1,383.5	39,748	22.0	54.4	Mincfm	0	0	Clg Sqft/Ton	306.94	Return	77.5	68.0
Reheat	-0.0	0	0.0	0.0	Return	290,720	0	Clg Btuh/Sqft	39.10	Ret/OA	79.6	22.0
Humidif	0.0	0	0.0	0.0	Exhaust	39,748	0	No. People	2,000	Runarnd	75.5	64.5
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg % OA	0.0	Fn MtrTD	1.1	0.2
Total	-2,381.7				Auxil	0	0	Htg Cfm/SqFt	0.07	Fn BldTD	0.8	0.0
								Htg Btuh/SqFt	-9.93	Fn Frict	2.4	0.0

2 Peak COMP - COMPUTER ROOM UNIT

***** COOLING COIL PEAK ***** CLG SPACE PEAK ***** HEATING COIL PEAK *****

COOLING COIL PEAK						CLG SPACE PEAK			HEATING COIL PEAK		
Peaked at Time ==> Mo/Hr: 8/15						Mo/Hr: 6/ 9			Mo/Hr: 13/ 1		
Outside Air ==> OADB/WB/HR: 92/ 74/105.0						OADB: 83			OADB: 22		
Space	Ret. Air	Ret. Air	Net	Perct		Space	Perct		Space Peak	Coil Peak	Perct
Sens.+Lat.	Sensible	Latent	Total	Of Tot		Sensible	Of Tot		Space Sens	Tot Sens	Of Tot
(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)		(Btuh)	(%)		(Btuh)	(Btuh)	(%)
Envelope Loads											
Skylite Solr	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Glass Solar	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Glass Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Wall Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Partition	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	0	0	0	0.00	*	0	0.00	*	0	0	-0.00
Sub Total==>	0	0	0	0.00	*	0	0.00	*	0	0	-0.00
Internal Loads											
Lights	334,808	0	334,808	19.03	*	334,808	28.27	*	334,808	334,808	26.12
People	128,625	0	128,625	7.31	*	71,458	6.03	*	71,458	71,458	5.57
Misc	778,232	0	778,232	44.24	*	778,232	65.70	*	778,232	778,232	60.71
Sub Total==>	1,241,666	0	1,241,666	70.58	*	1,184,499	100.00	*	1,184,499	1,184,499	92.40
Ceiling Load	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Outside Air	0	0	138,003	7.84	*	0	0.00	*	0	-282,079	-22.00
Fan Heat			379,526	21.57	*		0.00	*		379,526	29.61
Ret. Fan Heat		0	0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0	0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0		0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0.00	*		0.00	*		0	0.00
Grand Total==>	1,241,666	0	1,759,195	100.00	*	1,184,499	100.00	*	1,184,499	1,281,946	100.00

-----COOLING COIL SELECTION-----

	Total Capacity		Sens Cap.	Coil Airfl	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total		Glass (sf) (%)	
	(Tons)	(Mbh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	34,300		
Main Clg	146.6	1,759.2	1,670.1	533,708	75.2	68.1	96.4	72.3	67.2	96.2	Part	0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0	0	0
Totals	146.6	1,759.2									Wall	0	0	0

-----AREAS-----

-----HEATING COIL SELECTION-----

	Capacity		Coil Airfl	Ent	Lvg	Type	AIRFLOWS (cfm)		--ENGINEERING CHECKS--		--TEMPERATURES (F)--		
	(Mbh)	(cfm)	Deg F	Deg F	Vent	Cooling	Heating	Clg % OA	1.1	Type	Clg	Htg	
Main Htg	-0.0	533,708	68.1	68.1	Infil	5,717	5,717	Clg Cfm/Sqft	15.56	SADB	72.9	68.1	
Aux Htg	0.0	0	0.0	0.0	Supply	533,708	533,708	Clg Cfm/Ton	3640.58	Plenum	75.0	68.0	
Preheat	-2,725.5	533,708	67.5	72.3	Mincfm	0	533,708	Clg Sqft/Ton	233.97	Return	75.0	68.0	
Reheat	-0.0	533,708	72.9	68.0	Return	533,708	533,708	Clg Btuh/Sqft	51.29	Ret/OA	75.2	67.5	
Humidif	0.0	0	0.0	0.0	Exhaust	5,717	5,717	No. People	286	Runarnd	75.0	68.0	
Overheat	0.0	0	0.0	0.0	Rm Exh	0	0	Htg % OA	1.1	Fn MtrTD	0.2	0.0	
Totals	-2,725.5				Auxil	0	0	Htg Cfm/SqFt	15.56	Fn BldTD	0.1	0.0	
								Htg Btuh/SqFt	-79.46	Fn Frict	0.4	0.0	

COOLING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BASELINE

----- AIR FLOW HEAT GAIN AND LOSS -----													
(At time of Coil Peak)													
		----- Cooling -----											
Room Number	Description	Duct	Supply	Return	System	Cooling				Run	System		
		Heat Pickup (Btuh)	Fan Heat (Btuh)	Fan Heat (Btuh)	Exhaust Heat Loss (Btuh)	System Exhaust Total (Btuh)	Room Exhaust Airflow (Cfm)	Ducted Airflow (Cfm)	Plenum Airflow (Cfm)	Around Airflow (Cfm)	Corridor Airflow (Cfm)	Return Airflow (Cfm)	
1	NORTH ZONES	0	38,435	17,739	-698	55,477	432	0	0	8,315	0	0	8,315
Zone	1 Total/Ave.	0	38,435	17,739	-698	55,477	432	0	0	8,315	0	0	8,315
Zone	1 Block	0	38,435	17,739	-698	55,477	432	0	0	8,315	0	0	8,315
2	EAST ZONES	0	206,095	95,121	-1,410	299,806	605	0	0	44,588	0	0	44,588
Zone	2 Total/Ave.	0	206,095	95,121	-1,410	299,806	605	0	0	44,588	0	0	44,588
Zone	2 Block	0	206,095	95,121	-1,410	299,806	605	0	0	44,588	0	0	44,588
3	SOUTH ZONES	0	210,827	97,305	-1,586	306,546	768	0	0	45,612	0	0	45,612
Zone	3 Total/Ave.	0	210,827	97,305	-1,586	306,546	768	0	0	45,612	0	0	45,612
Zone	3 Block	0	210,827	97,305	-1,586	306,546	768	0	0	45,612	0	0	45,612
4	WEST ZONES	0	162,279	74,898	-1,404	235,773	576	0	0	35,108	0	0	35,108
Zone	4 Total/Ave.	0	162,279	74,898	-1,404	235,773	576	0	0	35,108	0	0	35,108
Zone	4 Block	0	162,279	74,898	-1,404	235,773	576	0	0	35,108	0	0	35,108
5	CORE ZONES	0	863,699	398,630	-90,299	1,172,029	31,650	0	0	186,858	0	0	186,858
Zone	5 Total/Ave.	0	863,699	398,630	-90,299	1,172,029	31,650	0	0	186,858	0	0	186,858
Zone	5 Block	0	863,699	398,630	-90,299	1,172,029	31,650	0	0	186,858	0	0	186,858
6	BASEMENT	0	129,169	59,617	-12,196	176,590	5,717	0	0	27,945	0	0	27,945
Zone	6 Total/Ave.	0	129,169	59,617	-12,196	176,590	5,717	0	0	27,945	0	0	27,945
Zone	6 Block	0	129,169	59,617	-12,196	176,590	5,717	0	0	27,945	0	0	27,945
System	1 Total/Ave.	0	1,610,505	743,310	-107,593	2,246,222	39,748	0	0	348,426	0	0	348,426
System	1 Block	0	1,343,772	620,203	-107,499	1,856,476	39,748	0	0	290,720	0	0	290,720
7	BASEMENT COMPUTE	0	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
Zone	7 Total/Ave.	0	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
Zone	7 Block	0	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
System	2 Total/Ave.	0	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
System	2 Block	0	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708

HEATING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 LINE

----- AIRFLOW HEAT GAIN AND LOSS -----
 (At time of Coil Peak)

Room Number	Description	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Total (Btuh)	Heating						
						System Exhaust Airflow (Cfm)	Room Exhaust Airflow (Cfm)	Ducted Airflow (Cfm)	Plenum Airflow (Cfm)	Run Around Airflow (Cfm)	Corridr Airflow (Cfm)	System Return Airflow (Cfm)
1	NORTH ZONES	0	0	0	0	0	0	0	2,079	2,079	0	0
Zone	1 Total/Ave.	0	0	0	0	0	0	0	2,079	2,079	0	0
Zone	1 Block	0	0	0	0	0	0	0	2,079	2,079	0	0
2	EAST ZONES	0	0	0	0	0	0	0	3,399	3,399	0	0
Zone	2 Total/Ave.	0	0	0	0	0	0	0	3,399	3,399	0	0
Zone	2 Block	0	0	0	0	0	0	0	3,399	3,399	0	0
3	SOUTH ZONES	0	0	0	0	0	0	0	3,079	3,079	0	0
Zone	3 Total/Ave.	0	0	0	0	0	0	0	3,079	3,079	0	0
Zone	3 Block	0	0	0	0	0	0	0	3,079	3,079	0	0
4	WEST ZONES	0	0	0	0	0	0	0	2,309	2,309	0	0
Zone	4 Total/Ave.	0	0	0	0	0	0	0	2,309	2,309	0	0
Zone	4 Block	0	0	0	0	0	0	0	2,309	2,309	0	0
5	CORE ZONES	0	0	0	0	0	0	0	2,529	2,529	0	0
Zone	5 Total/Ave.	0	0	0	0	0	0	0	2,529	2,529	0	0
Zone	5 Block	0	0	0	0	0	0	0	2,529	2,529	0	0
6	BASEMENT	0	0	0	0	0	0	0	2,227	2,227	0	0
Zone	6 Total/Ave.	0	0	0	0	0	0	0	2,227	2,227	0	0
Zone	6 Block	0	0	0	0	0	0	0	2,227	2,227	0	0
System	1 Total/Ave.	0	0	0	0	0	0	0	15,621	15,621	0	0
System	1 Block	0	0	0	0	0	0	0	15,621	15,621	0	0
7	BASEMENT COMPUTE	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
Zone	7 Total/Ave.	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
Zone	7 Block	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
System	2 Total/Ave.	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708
System	2 Block	379,526	0	0	379,526	5,717	0	0	533,708	0	0	533,708

ROOM PSYCHROMETRICS - ALTERNATIVE 1
 BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Room 7

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	75.0	68.1	70.9	96.3	33.1	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	75.0	68.1	70.9	96.3	33.1	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	75.2	68.1	70.6	96.4	33.1	
Blow through Fan						0.0
Entering Coil	75.2	68.1	70.6	96.4	33.1	
Leaving Coil	72.3	67.2	77.7	96.3	32.4	
Draw Through Fan						0.3
Duct Frictional Heat						0.4
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	72.9	67.4	76.0	96.3	32.5	
Supply Air	72.9	67.4	76.0	96.3	32.5	
Percent Outside Air		1.07	(%)			
Sensible Heat Ratio (SHR)		0.954				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		533,708	(Cfm)			

PSYCHROMETRICS - ALTERNATIVE 1
 BASELINE

----- PSYCHROMETRIC STATE POINTS -----

System 1

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	75.0	60.9	44.8	60.4	27.4	
Main System						
Return Air Heat Pickup						0.4
Return Fan						2.0
Return Air	77.4	61.7	41.3	60.4	28.0	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	79.5	63.7	42.5	66.5	29.5	
Blow through Fan						0.0
Entering Coil	79.5	63.7	42.5	66.5	29.5	
Leaving Coil	54.4	52.6	89.3	58.7	22.2	
Draw Through Fan						1.9
Duct Frictional Heat						2.4
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	58.8	54.4	76.4	58.7	23.2	
Supply Air	58.8	54.4	76.4	58.7	23.2	
Percent Outside Air		13.67	(%)			
Sensible Heat Ratio (SHR)		0.927				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		290,720	(Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	----- Room U-Values ----- (Btu/hr/sqft/F)									Room Mass (lb/ sqft)	Room Capac. (Btu/ sqft/F)
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Roof	Summr Windo	Wintr Windo	Wall	Ceil.		
1	NORTH ZONES	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
Zone	1 Total/Ave.	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
2	EAST ZONES	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
Zone	2 Total/Ave.	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
3	SOUTH ZONES	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
Zone	3 Total/Ave.	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
4	WEST ZONES	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
Zone	4 Total/Ave.	0.000	0.000	0.000	0.000	0.055	0.590	0.620	0.076	0.317	287.9	57.24
5	CORE ZONES	0.000	0.000	0.590	0.620	0.055	0.000	0.000	0.000	0.317	19.2	4.14
Zone	5 Total/Ave.	0.000	0.000	0.590	0.620	0.055	0.000	0.000	0.000	0.317	19.2	4.14
6	BASEMENT	0.270	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	97.2	19.45
Zone	6 Total/Ave.	0.270	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	97.2	19.45
System	1 Total/Ave.	0.270	0.000	0.590	0.620	0.055	0.590	0.620	0.076	0.317	48.0	9.81
7	BASEMENT COMPUTE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	13.3	2.67
Zone	7 Total/Ave.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	13.3	2.67
System	2 Total/Ave.	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.317	13.3	2.67
Building		0.270	0.000	0.590	0.620	0.055	0.590	0.620	0.076	0.317	43.7	8.92

BUILDING AREAS - ALTERNATIVE 1
 BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Skl /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
1	NORTH ZONES	3	1	864	2,592	0	0	0	0	864	3,240	32	6,804
Zone	1 Total/Ave.				2,592	0	0	0	0	864	3,240	32	6,804
2	EAST ZONES	3	1	1,696	5,088	0	0	0	0	1,696	6,360	32	13,356
Zone	2 Total/Ave.				5,088	0	0	0	0	1,696	6,360	32	13,356
3	SOUTH ZONES	3	1	1,536	4,608	0	0	0	0	1,536	5,760	32	12,096
Zone	3 Total/Ave.				4,608	0	0	0	0	1,536	5,760	32	12,096
4	WEST ZONES	3	1	1,152	3,456	0	0	0	0	1,152	4,320	32	9,072
Zone	4 Total/Ave.				3,456	0	0	0	0	1,152	4,320	32	9,072
5	CORE ZONES	3	1	63,300	189,900	0	0	576	1	62,724	0	0	0
Zone	5 Total/Ave.				189,900	0	0	576	1	62,724	0	0	0
6	BASEMENT	1	1	34,300	34,300	30,832	0	0	0	0	0	0	0
Zone	6 Total/Ave.				34,300	30,832	0	0	0	0	0	0	0
System	1 Total/Ave.				239,944	30,832	0	576	1	67,972	19,680	32	41,328
7	BASEMENT COMPUTE	1	1	34,300	34,300	0	0	0	0	0	0	0	0
Zone	7 Total/Ave.				34,300	0	0	0	0	0	0	0	0
System	2 Total/Ave.				34,300	0	0	0	0	0	0	0	0
Building					274,244	30,832	0	576	1	67,972	19,680	32	41,328

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
 BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.059 (Btu/Hr/Sq Ft/F)
 Overall Wall U-Value = 0.242 (Btu/Hr/Sq Ft/F)
 Overall Building U-Value = 0.145 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 3.59 (Btu/Hr/Sq Ft)
 Wall Overall Thermal Transfer Value (OTTVw) = 26.97 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BASELINE

Main System 1 FPVAV FAN POWERED VAV

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	39.1	17	542	-119,086	48	731	14,536.0	15	704	781.1	53	867
5 - 10	78.2	6	182	-238,173	38	577	29,072.0	1	58	1,562.1	6	98
10 - 15	117.3	4	121	-357,259	6	87	43,608.0	4	176	2,343.2	33	548
15 - 20	156.3	3	94	-476,346	4	66	58,144.0	17	826	3,124.2	1	24
20 - 25	195.4	3	111	-595,432	3	44	72,680.0	4	188	3,905.3	1	10
25 - 30	234.5	4	132	-714,518	0	5	87,216.0	1	27	4,686.4	0	4
30 - 35	273.6	4	140	-833,605	0	0	101,752.0	0	0	5,467.4	1	16
35 - 40	312.7	3	105	-952,691	0	0	116,288.0	0	0	6,248.5	2	38
40 - 45	351.8	2	59	-1,071,778	0	0	130,824.0	2	102	7,029.6	0	3
45 - 50	390.9	2	58	-1,190,864	0	0	145,360.0	1	32	7,810.6	2	34
50 - 55	429.9	5	161	-1,309,950	0	0	159,896.0	1	71	8,591.7	0	0
55 - 60	469.0	6	182	-1,429,037	0	0	174,432.0	2	82	9,372.7	0	0
60 - 65	508.1	3	111	-1,548,123	0	0	188,968.0	5	250	10,153.8	0	0
65 - 70	547.2	6	198	-1,667,210	0	0	203,504.0	4	167	10,934.9	0	0
70 - 75	586.3	3	110	-1,786,296	0	0	218,040.0	6	291	11,715.9	0	0
75 - 80	625.4	4	115	-1,905,382	0	0	232,576.0	8	363	12,497.0	0	0
80 - 85	664.5	4	119	-2,024,469	0	0	247,112.0	7	319	13,278.1	0	0
85 - 90	703.5	8	257	-2,143,555	0	0	261,648.0	10	466	14,059.1	0	0
90 - 95	742.6	7	222	-2,262,642	0	0	276,184.1	7	354	14,840.2	0	0
95 - 100	781.7	5	170	-2,381,728	0	0	290,720.0	6	275	15,621.2	0	0
Hours Off	0.0	0	5,571	0	0	7,250	0.0	0	4,009	0.0	0	7,118

Main System 2 COMP COMPUTER ROOM UNIT

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	7.3	0	0	-136,277	100	345	26,685.4	0	0	0.0	0	0
5 - 10	14.7	0	0	-272,554	0	0	53,370.8	0	0	0.0	0	0
10 - 15	22.0	0	0	-408,831	0	0	80,056.2	0	0	0.0	0	0
15 - 20	29.3	0	0	-545,108	0	0	106,741.6	0	0	0.0	0	0
20 - 25	36.6	0	0	-681,385	0	0	133,427.0	0	0	0.0	0	0
25 - 30	44.0	0	0	-817,662	0	0	160,112.4	0	0	0.0	0	0
30 - 35	51.3	0	0	-953,939	0	0	186,797.8	0	0	0.0	0	0
35 - 40	58.6	0	0	-1,090,216	0	0	213,483.2	0	0	0.0	0	0
40 - 45	66.0	0	0	-1,226,493	0	0	240,168.6	0	0	0.0	0	0
45 - 50	73.3	0	21	-1,362,770	0	0	266,854.0	0	0	0.0	0	0
50 - 55	80.6	0	0	-1,499,047	0	0	293,539.4	0	0	0.0	0	0
55 - 60	88.0	0	34	-1,635,324	0	0	320,224.8	0	0	0.0	0	0
60 - 65	95.3	1	46	-1,771,601	0	0	346,910.2	0	0	0.0	0	0
65 - 70	102.6	0	29	-1,907,878	0	0	373,595.7	0	0	0.0	0	0
70 - 75	109.9	1	99	-2,044,155	0	0	400,281.1	0	0	0.0	0	0
75 - 80	117.3	24	2,122	-2,180,432	0	0	426,966.5	0	0	0.0	0	0
80 - 85	124.6	30	2,613	-2,316,709	0	0	453,651.9	0	0	0.0	0	0
85 - 90	131.9	14	1,231	-2,452,987	0	0	480,337.3	0	0	0.0	0	0
90 - 95	139.3	3	287	-2,589,263	0	0	507,022.7	0	0	0.0	0	0
95 - 100	146.6	26	2,278	-2,725,540	0	0	533,708.1	100	8,760	0.0	0	0
Hours Off	0.0	0	0	0	0	8,415	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 LINE

----- SYSTEM LOAD PROFILE -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	46.4	0	0	-255,363	89	1,657	41,221.4	0	0	781.1	53	867
5 - 10	92.8	0	34	-510,727	9	165	82,442.8	0	0	1,562.1	6	98
10 - 15	139.2	55	4,806	-766,090	2	33	123,664.2	0	0	2,343.2	33	548
15 - 20	185.7	16	1,358	-1,021,454	0	0	164,885.6	0	0	3,124.2	1	24
20 - 25	232.1	2	209	-1,276,817	0	0	206,107.0	0	0	3,905.3	1	10
25 - 30	278.5	1	78	-1,532,181	0	0	247,328.4	0	0	4,686.4	0	4
30 - 35	324.9	1	98	-1,787,544	0	0	288,549.8	0	0	5,467.4	1	16
35 - 40	371.3	2	151	-2,042,907	0	0	329,771.2	0	0	6,248.5	2	38
40 - 45	417.7	2	191	-2,298,271	0	0	370,992.6	0	0	7,029.6	0	3
45 - 50	464.2	1	96	-2,553,634	0	0	412,214.1	0	0	7,810.6	2	34
50 - 55	510.6	1	70	-2,808,998	0	0	453,435.4	0	0	8,591.7	0	0
55 - 60	557.0	2	202	-3,064,361	0	0	494,656.9	0	0	9,372.7	0	0
60 - 65	603.4	2	172	-3,319,725	0	0	535,878.2	52	4,553	10,153.8	0	0
65 - 70	649.8	2	185	-3,575,088	0	0	577,099.7	4	359	10,934.9	0	0
70 - 75	696.2	2	161	-3,830,452	0	0	618,321.1	12	1,076	11,715.9	0	0
75 - 80	742.7	2	142	-4,085,815	0	0	659,542.5	1	85	12,497.0	0	0
80 - 85	789.1	2	153	-4,341,178	0	0	700,763.9	2	185	13,278.1	0	0
85 - 90	835.5	2	210	-4,596,542	0	0	741,985.3	5	473	14,059.1	0	0
90 - 95	881.9	3	271	-4,851,905	0	0	783,206.8	12	1,021	14,840.2	0	0
95 - 100	928.3	2	173	-5,107,268	0	0	824,428.1	12	1,008	15,621.2	0	0
Hours Off	0.0	0	0	0	0	6,905	0.0	0	0	0.0	0	7,118

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BASELINE

January		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	0	0.0	0	111.9	0	111.6	0	111.4	0	111.4
2	32.1	29.3	-275	109.3	0	111.4	0	110.8	0	110.7	0	110.6
3	31.7	29.3	0	112.3	0	111.3	0	110.5	0	110.4	0	110.4
4	31.9	29.5	0	112.2	0	111.5	0	110.5	0	110.4	0	110.4
5	32.6	30.3	-125,185	112.1	-129,370	111.9	-130,809	110.8	-130,809	110.7	-130,809	110.7
6	33.6	31.3	-124,615	112.3	-128,938	112.5	-130,334	111.2	-130,334	111.0	-130,334	111.0
7	35.0	32.6	-124,056	112.7	-128,496	113.2	-129,851	111.6	-129,851	111.5	-129,851	111.5
8	36.6	34.4	-791,156	113.6	-348,549	114.0	-128,968	112.4	-541,273	112.3	-513,803	112.3
9	38.5	36.3	-148,248	114.9	-163,765	115.0	-127,837	113.4	-277,956	113.4	-512,479	113.4
10	40.4	37.7	-396,814	116.5	-122,755	115.9	-126,566	114.5	-174,593	114.4	-510,986	114.4
11	42.3	38.7	0	118.1	-8,150	116.8	-125,002	115.5	-125,002	115.4	-480,404	115.4
12	44.2	39.6	0	119.7	0	117.7	-50,825	116.5	-50,825	116.4	-387,820	116.4
13	45.8	40.5	0	401.4	-10,980	118.4	-22,613	117.3	-231,888	117.3	-389,727	117.3
14	47.2	41.1	0	486.0	0	119.0	-18,982	118.0	-18,982	118.0	-374,817	118.0
15	48.2	41.6	0	484.4	0	119.5	-78,377	118.6	-20,053	118.5	-253,511	118.5
16	48.9	41.8	0	460.7	-5,633	119.7	-23,068	118.9	-23,068	118.9	-221,762	118.9
17	49.1	41.9	0	339.9	-22,804	119.8	-121,369	119.0	-119,203	119.0	-155,408	119.0
18	48.7	41.9	0	121.2	-31,834	119.5	-146,241	118.9	-146,251	118.9	-73,267	118.9
19	47.4	41.7	0	120.2	-39,983	118.9	-211,757	118.4	-211,757	118.4	-39,983	118.4
20	45.5	40.5	0	119.3	-44,307	118.0	-302,259	117.6	-302,259	117.6	-44,307	117.6
21	43.1	38.9	0	118.6	-48,627	116.8	-416,636	116.5	-416,636	116.5	-48,627	116.5
22	40.4	36.7	0	117.9	0	115.5	0	115.2	0	115.2	0	115.2
23	37.7	34.3	0	117.4	0	114.1	0	113.8	0	113.8	0	113.8
24	35.3	32.3	0	117.0	0	112.7	0	112.5	0	112.5	0	112.5

February		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	0	116.1	0	112.9	0	113.9	0	113.9	0	113.9
2	36.0	33.0	0	115.6	0	112.3	0	113.1	0	113.1	0	113.1
3	34.7	31.8	0	115.2	0	111.6	0	112.3	0	112.3	0	112.3
4	33.6	30.9	0	114.9	0	111.0	0	111.6	0	111.6	0	111.6
5	32.8	30.1	-128,187	114.7	-128,764	110.5	-130,220	111.1	-130,220	111.1	-130,220	111.1
6	32.2	29.8	-127,324	114.8	-128,356	110.1	-129,769	110.6	-129,769	110.6	-129,769	110.6
7	32.1	29.6	-126,679	114.9	-127,977	109.8	-129,349	110.3	-129,349	110.3	-129,349	110.3
8	32.5	30.3	-500,358	115.4	-337,511	109.9	-128,531	110.3	-697,249	110.3	-513,366	110.3
9	33.9	31.6	-306,435	116.3	-126,109	110.4	-127,674	110.8	-467,838	110.8	-512,316	110.8
10	36.0	33.0	-158,008	117.5	-121,314	111.3	-126,502	111.7	-362,073	111.7	-510,496	111.7
11	38.5	34.8	-45,041	119.0	-17,593	112.7	-125,061	112.9	-235,444	112.9	-486,171	112.9
12	41.3	36.5	0	120.4	-5,820	114.3	-62,331	114.5	-62,331	114.5	-381,833	114.5
13	43.8	38.1	0	523.7	-11,437	115.8	-23,071	115.9	-311,202	115.9	-381,752	115.9
14	45.9	39.5	0	534.8	0	116.9	-20,104	117.1	-20,104	117.1	-235,214	117.1
15	47.2	40.4	0	523.6	0	117.7	-112,401	117.8	-17,246	117.8	-172,625	117.8
16	47.7	40.6	0	502.0	0	118.0	-20,810	118.1	-20,810	118.1	0	118.1
17	47.5	40.2	0	416.5	-20,929	118.0	-183,179	118.0	-181,221	118.0	-25,937	118.0
18	47.0	39.8	0	120.4	-38,597	117.9	-222,894	117.9	-222,894	117.9	-88,510	117.9
19	46.2	39.9	0	119.4	-44,575	117.7	-264,933	117.7	-264,933	117.7	-44,575	117.7
20	45.1	39.7	0	118.4	-46,736	117.3	-321,743	117.3	-321,743	117.3	-46,736	117.3
21	43.8	39.2	0	117.6	-46,736	116.8	-382,320	116.8	-382,320	116.8	-46,736	116.8
22	42.3	38.3	0	116.8	0	116.1	0	116.1	0	116.1	0	116.1
23	40.7	37.2	0	116.2	0	115.4	0	115.4	0	115.4	0	115.4
24	39.1	35.8	0	115.8	0	114.6	0	114.6	0	114.6	0	114.6

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1
 LINE

March			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
	Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6		0	121.1	0	118.4	0	117.4	0	114.8	0	114.7
2	43.3	39.7		0	120.6	0	117.4	0	116.2	0	113.6	0	113.7
3	41.6	38.6		0	120.3	0	116.6	0	115.4	0	112.7	0	112.8
4	40.6	37.5		0	120.0	0	116.0	0	115.0	0	112.2	0	112.3
5	40.2	37.3		-124,402	119.9	0	115.8	-124,289	114.9	-125,583	112.0	-125,583	112.1
6	40.6	37.8		-123,523	120.1	-28,962	116.0	-123,710	115.2	-124,965	112.3	-124,965	112.3
7	41.6	39.0		-122,565	120.5	-58,555	116.5	-123,073	115.8	-124,291	112.9	-124,291	112.8
8	43.3	40.7		-143,516	121.5	-18,953	117.4	-92,632	116.7	-553,964	113.7	-123,310	113.6
9	45.4	42.5		0	444.8	0	118.4	-18,062	117.8	-73,674	114.7	-44,864	114.7
10	47.9	44.3		0	477.6	0	119.7	-9,504	119.0	-9,503	115.8	0	116.0
11	50.6	45.5		0	548.6	0	121.1	0	120.3	0	117.2	0	117.3
12	53.3	46.8		0	589.4	0	122.5	0	121.6	0	118.6	0	118.7
13	55.8	48.5		0	576.6	0	514.5	0	122.7	0	144.0	0	563.1
14	58.0	49.6		0	589.3	0	532.1	0	123.8	0	190.1	0	565.1
15	59.6	50.3		0	597.6	0	520.5	0	149.0	0	195.1	0	566.3
16	60.7	50.9		0	643.5	0	549.2	0	201.0	0	198.6	0	571.1
17	61.0	50.9		0	508.8	0	428.1	0	164.3	0	162.0	0	531.5
18	60.7	50.7		0	350.4	0	317.2	0	161.9	0	159.7	0	464.6
19	59.6	50.7		0	127.4	0	125.4	0	156.5	0	154.6	0	122.0
20	58.0	50.5		0	126.0	0	124.4	0	148.9	0	147.3	0	121.2
21	55.8	49.4		0	124.8	0	123.1	0	139.1	0	137.8	0	120.1
22	53.3	47.8		0	123.7	0	121.7	0	119.6	0	118.7	0	118.8
23	50.6	45.9		0	122.9	0	120.2	0	117.9	0	117.4	0	117.4
24	47.9	43.8		0	122.2	0	118.7	0	116.3	0	116.0	0	116.1

April			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
	Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9		0	123.6	0	121.4	0	121.7	0	121.8	0	121.8
2	55.9	52.7		0	123.1	0	120.5	0	120.8	0	120.8	0	120.9
3	54.2	51.3		0	122.7	0	119.6	0	119.9	0	120.0	0	120.0
4	52.9	50.2		0	122.4	0	119.0	0	119.2	0	119.3	0	119.3
5	51.9	49.6		-98,235	122.3	0	118.5	0	118.7	-16,124	118.8	-16,124	118.8
6	51.2	49.2		-9,265	122.5	0	118.1	0	118.3	0	118.4	0	118.4
7	51.0	49.3		0	123.0	0	118.0	0	118.2	0	118.3	0	118.3
8	51.6	49.9		0	611.4	0	118.3	0	118.5	0	118.5	0	118.6
9	53.3	50.6		0	599.4	0	119.2	0	119.3	0	119.4	0	119.4
10	55.9	51.8		0	654.4	0	544.4	0	120.7	0	179.6	0	736.5
11	59.0	53.4		0	678.0	0	575.6	0	122.2	0	198.5	0	694.0
12	62.4	55.6		0	694.7	0	596.8	0	124.0	0	214.3	0	688.1
13	65.5	57.7		0	688.2	0	599.3	0	125.6	0	200.0	0	688.1
14	68.1	59.4		0	734.1	0	646.5	0	143.9	0	248.8	0	703.7
15	69.8	60.7		0	752.7	0	680.6	0	267.4	0	267.0	0	724.3
16	70.4	60.9		0	731.0	0	659.2	0	267.8	0	267.9	0	697.4
17	70.2	60.2		0	620.9	0	545.8	0	216.7	0	216.7	0	666.2
18	69.5	60.1		0	441.2	0	407.8	0	212.3	0	212.3	0	602.4
19	68.5	59.4		0	129.1	0	127.1	0	207.1	0	207.1	0	127.2
20	67.2	59.7		0	127.8	0	126.4	0	212.5	0	212.5	0	126.6
21	65.5	59.3		0	126.7	0	125.6	0	204.9	0	204.9	0	125.7
22	63.7	58.8		0	125.7	0	124.7	0	124.8	0	124.8	0	124.8
23	61.7	57.3		0	124.9	0	123.7	0	123.8	0	123.8	0	123.8
24	59.7	55.6		0	124.4	0	122.7	0	122.8	0	122.8	0	122.8

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BASELINE

May			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	128.5	0	126.4	0	128.0	0	129.1	0	129.8
2	64.5	60.4	0	128.0	0	125.4	0	126.9	0	126.7	0	124.8
3	62.7	59.1	0	127.6	0	124.5	0	125.9	0	130.0	0	136.5
4	61.2	58.1	0	127.3	0	123.7	0	125.1	0	114.3	0	93.3
5	60.0	57.1	0	127.2	0	123.1	0	124.0	0	160.3	0	160.3
6	59.3	56.6	0	127.4	0	122.7	0	124.6	0	66.3	0	135.6
7	59.0	56.5	0	127.9	0	122.6	0	120.3	0	131.7	0	85.9
8	59.5	56.6	0	679.4	0	617.9	0	133.1	0	144.4	0	928.3
9	60.9	56.6	0	770.2	0	646.5	0	91.5	0	238.1	0	924.8
10	63.0	57.2	0	797.1	0	664.2	0	146.6	0	217.3	0	862.6
11	65.7	58.1	0	790.2	0	663.2	-9	128.9	0	242.8	0	872.3
12	68.7	59.8	0	775.1	0	661.9	0	133.3	-90	272.3	-4,111	826.2
13	71.7	61.6	0	758.7	0	658.1	0	136.8	0	251.1	0	767.3
14	74.5	63.4	0	795.7	0	702.6	0	215.2	0	302.2	0	768.2
15	76.6	64.8	0	813.4	0	739.2	0	323.4	0	322.9	0	794.3
16	78.0	65.6	0	810.5	0	731.6	0	325.4	0	325.4	0	778.5
17	78.5	65.6	0	719.2	0	645.6	0	288.4	0	293.9	0	751.8
18	78.2	65.8	0	531.8	0	501.8	0	285.7	0	302.8	0	699.9
19	77.5	65.6	0	138.2	0	132.1	0	275.1	0	275.1	0	132.4
20	76.3	66.1	0	132.5	0	131.5	0	282.0	0	282.2	0	132.1
21	74.8	67.2	0	131.4	0	130.8	0	289.8	0	289.9	0	131.9
22	73.0	66.4	0	130.4	0	129.9	0	131.3	0	131.4	0	131.4
23	70.9	65.4	0	129.6	0	129.5	0	130.7	0	130.9	0	130.9
24	68.7	64.0	0	129.0	0	128.8	0	129.8	0	129.7	0	129.7

June			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	136.2	0	117.2	0	123.6	0	135.0	0	133.8
2	71.2	66.1	0	131.8	0	146.6	0	146.6	0	134.9	0	135.7
3	69.7	65.2	0	144.1	0	127.1	0	142.9	0	134.6	0	131.1
4	68.5	64.3	0	101.6	0	146.6	0	112.0	0	129.0	0	146.6
5	67.8	64.2	0	151.5	0	94.4	0	146.6	0	193.3	0	149.0
6	67.6	64.2	0	159.6	0	151.4	0	140.9	0	105.9	0	153.7
7	68.1	64.8	0	145.6	0	152.5	0	112.6	0	158.0	0	158.0
8	69.4	65.7	0	892.1	0	850.6	0	154.4	0	291.1	0	900.3
9	71.6	66.2	0	866.5	0	815.2	0	156.3	0	325.8	0	928.3
10	74.2	67.2	0	911.9	0	831.6	0	126.7	0	369.5	0	906.7
11	77.2	68.5	0	923.8	0	778.4	0	165.4	0	394.2	0	928.3
12	80.2	70.0	0	912.5	0	823.4	0	170.6	0	390.2	0	906.9
13	82.8	70.8	0	874.0	0	803.6	0	171.6	0	387.3	0	928.3
14	85.0	71.6	0	888.2	0	843.6	0	369.5	0	449.7	0	928.3
15	86.3	72.3	0	918.9	0	879.9	0	438.2	0	495.7	0	928.3
16	86.8	72.1	0	905.1	0	853.9	0	422.4	0	471.0	0	923.4
17	86.6	71.7	0	844.5	0	772.7	0	381.4	0	420.2	0	928.3
18	85.8	71.5	0	629.0	0	611.2	0	377.1	0	404.5	0	839.0
19	84.7	71.2	0	140.7	0	156.9	0	360.2	0	366.6	0	156.9
20	83.2	71.5	0	156.6	0	152.2	0	370.0	0	359.7	0	153.2
21	81.4	71.7	0	154.1	0	155.1	0	358.0	0	364.9	0	154.4
22	79.3	71.4	0	113.2	0	133.4	0	146.6	0	146.6	0	132.1
23	77.2	70.5	0	146.6	0	146.6	0	132.2	0	146.6	0	146.6
24	75.1	69.1	0	146.6	0	146.6	0	146.6	0	141.3	0	146.6

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1
 BASELINE

July		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0 69.3	0	125.2	0	146.6	-812	146.6	-1,873	146.6	-2,711	146.6
2	70.5 68.0	0	146.6	0	146.6	0	146.6	-723	146.6	0	146.6
3	69.4 67.1	0	141.2	0	146.6	-194	146.6	0	146.6	0	146.6
4	68.5 66.4	0	122.9	0	124.9	0	146.6	0	146.6	0	146.6
5	67.9 66.0	0	158.7	0	146.6	0	146.6	0	202.0	0	202.0
6	67.7 65.9	0	139.1	0	131.1	0	146.6	0	151.3	0	151.3
7	68.1 66.3	0	162.2	0	148.6	0	130.2	0	153.9	0	153.9
8	69.1 67.3	0	890.6	0	847.3	0	154.4	0	303.2	0	928.3
9	70.8 68.0	0	928.3	0	859.7	0	120.4	0	364.9	0	928.3
10	72.9 69.1	0	928.3	0	843.7	0	163.0	0	379.3	0	928.3
11	75.2 70.5	0	928.3	0	813.4	0	165.5	0	391.7	0	928.3
12	77.5 71.7	0	928.3	0	841.2	0	169.4	0	430.0	0	928.3
13	79.6 72.7	0	928.3	0	826.8	0	169.9	-61	400.9	-157	928.3
14	81.3 73.5	0	928.3	0	863.8	0	401.0	0	461.9	0	928.3
15	82.3 73.7	0	928.3	0	885.6	0	452.4	-935	475.4	-1,040	928.3
16	82.7 73.5	0	928.3	0	863.2	-244	435.2	-3,031	480.3	-3,153	928.3
17	82.5 73.1	0	892.4	0	778.5	-130	395.2	-422	430.0	-489	928.3
18	82.0 72.6	0	781.9	0	619.4	0	391.8	0	415.0	0	872.6
19	81.1 73.2	0	157.9	0	155.7	-1,096	380.0	-1,182	381.2	-1,113	155.7
20	79.9 73.8	0	156.4	0	155.6	0	390.2	0	390.5	0	155.6
21	78.5 73.9	0	155.6	0	155.4	-249	399.6	-635	399.6	-677	155.4
22	76.9 73.1	0	146.6	-1,858	146.6	-3,486	146.6	0	146.6	0	146.6
23	75.2 71.9	0	146.6	-610	146.6	-1,840	146.6	0	146.6	0	146.6
24	73.5 70.8	0	146.6	-1,903	146.6	-2,335	146.6	-5,858	146.6	0	146.6

August		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7 70.2	-3,874	146.6	0	146.6	-54	146.6	-879	146.6	-449	146.6
2	71.2 69.0	-1,160	146.6	0	146.6	-542	146.6	-1,193	146.6	0	146.6
3	69.9 68.0	0	146.6	0	146.6	0	146.6	0	146.6	0	146.6
4	68.8 67.1	0	146.6	0	146.6	0	146.6	0	146.6	0	146.6
5	68.0 66.6	0	154.5	0	146.6	0	146.6	0	202.9	0	202.9
6	67.5 66.2	0	146.6	-42	146.6	0	146.6	0	151.1	-121	151.1
7	67.3 66.1	0	155.0	0	146.6	0	135.1	0	151.8	0	151.8
8	67.8 66.5	0	928.3	0	869.4	0	124.6	0	290.7	0	928.3
9	69.1 67.0	0	928.3	0	828.2	0	154.5	0	342.3	0	928.3
10	71.2 67.8	0	928.3	0	786.0	0	142.6	0	356.4	0	902.5
11	73.8 68.7	-33	928.3	0	816.9	0	161.4	0	369.1	0	928.3
12	76.5 70.0	-167	928.3	0	828.7	0	140.5	0	395.8	0	928.3
13	79.1 71.2	-373	928.3	0	821.5	0	168.1	0	371.8	0	908.0
14	81.1 72.6	-66	928.3	0	864.3	0	376.4	0	418.7	0	928.3
15	82.5 73.6	-1,351	928.3	0	873.3	0	436.4	0	464.2	0	928.3
16	83.0 73.7	-3,043	928.3	0	852.4	0	432.9	0	471.8	0	928.3
17	82.8 73.5	-1,183	906.8	0	769.7	0	392.4	0	425.1	0	928.3
18	82.3 73.5	-762	778.7	0	603.6	0	387.5	0	402.6	0	846.6
19	81.5 73.1	-81	157.8	0	155.7	-521	381.0	0	382.1	-276	155.7
20	80.4 73.7	0	156.4	0	155.6	-44	391.5	-4	391.9	-79	155.6
21	79.1 74.9	0	156.4	0	155.4	-509	401.3	-421	401.3	-530	155.4
22	77.6 73.9	0	146.6	0	146.6	-2,561	146.6	-2,488	146.6	-2,566	146.6
23	76.0 72.7	0	146.6	-1,537	146.6	-3,257	146.6	-3,346	146.6	-3,218	146.6
24	74.3 71.3	0	146.6	-1,238	146.6	-2,579	146.6	-2,180	146.6	-2,472	146.6

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BASELINE

September		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	69.8	66.1	-1,397	146.6	0	146.6	0	146.6	0	146.6	0	123.7
2	68.0	64.5	0	146.6	0	146.6	0	118.2	0	121.0	0	146.6
3	66.3	63.0	-695	146.6	0	81.3	0	146.6	0	146.6	0	117.4
4	64.9	61.9	0	146.6	0	135.2	0	124.2	0	114.5	0	146.6
5	63.9	61.3	0	146.6	0	104.5	0	145.0	0	173.4	0	135.6
6	63.2	61.0	0	146.6	0	146.6	0	82.5	0	108.2	0	146.6
7	63.0	60.8	0	105.9	0	119.6	0	133.8	0	146.6	0	111.6
8	63.4	61.4	0	895.5	0	725.7	0	105.0	0	204.1	0	928.3
9	64.7	61.8	0	899.6	0	643.6	0	146.6	0	276.8	0	876.8
10	66.6	62.1	0	869.8	0	718.0	0	120.6	0	253.2	0	928.3
11	69.1	62.9	0	905.9	0	717.8	0	146.6	0	300.9	0	928.3
12	71.8	63.7	0	890.1	0	758.0	0	93.2	0	275.6	0	858.1
13	74.5	65.5	0	875.1	0	753.7	0	150.1	0	334.9	0	913.3
14	77.0	67.1	0	879.7	0	740.2	0	230.1	0	394.1	0	895.7
15	78.9	68.2	0	895.8	0	801.6	0	370.3	0	355.5	0	871.2
16	80.2	68.6	0	846.0	0	789.0	0	372.2	0	384.3	0	810.7
17	80.6	68.5	0	804.4	0	681.0	0	292.8	0	336.3	0	802.0
18	80.4	68.9	0	598.9	0	499.6	0	328.4	0	310.2	0	732.7
19	79.7	70.0	0	135.3	0	152.9	0	340.1	0	340.1	0	138.8
20	78.7	71.2	0	152.9	0	152.9	0	351.3	0	334.2	0	152.9
21	77.3	71.6	0	120.4	0	137.7	0	346.8	0	361.2	0	134.8
22	75.6	70.5	0	146.6	0	146.6	0	146.6	0	146.6	0	146.6
23	73.7	69.4	0	142.0	0	146.5	0	146.6	0	135.8	0	146.6
24	71.8	67.7	0	103.4	0	131.1	0	127.8	0	146.1	0	146.6

October		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	54.8	51.3	0	107.9	0	120.2	0	120.1	0	120.1	0	120.1
2	52.9	49.6	0	136.1	0	119.2	0	119.1	0	119.1	0	119.1
3	51.2	48.2	0	125.4	0	118.3	0	118.2	0	118.2	0	118.2
4	49.8	47.2	0	124.1	0	117.6	0	117.5	0	117.5	0	117.5
5	48.8	46.2	0	117.7	0	117.1	0	117.0	-135,161	117.0	-135,161	117.0
6	48.2	45.7	0	124.8	0	116.8	0	116.7	-63,048	116.6	-63,049	116.6
7	47.9	45.6	0	122.9	0	116.6	-6,965	116.5	-44,782	116.5	-44,782	116.5
8	48.5	46.2	0	654.2	0	116.9	-16,378	116.8	-181,598	116.8	0	116.8
9	50.3	47.3	0	671.1	0	117.8	0	117.7	0	117.7	0	117.7
10	52.9	48.7	0	685.6	0	119.1	0	119.0	0	119.0	0	119.0
11	56.2	49.9	0	695.4	0	554.0	0	120.7	0	179.2	0	646.4
12	59.6	51.5	0	704.1	0	584.5	0	122.4	0	195.4	0	669.3
13	62.9	53.5	0	695.9	0	560.8	0	124.1	0	172.5	0	658.2
14	65.5	55.2	0	725.0	0	580.1	0	125.4	0	219.5	0	654.3
15	67.3	56.3	0	726.0	0	620.4	0	218.8	0	230.0	0	662.4
16	67.9	56.6	0	697.4	0	615.2	0	232.9	0	232.4	0	651.7
17	67.7	56.4	0	545.7	0	449.2	0	189.6	0	189.6	0	583.2
18	67.0	56.6	0	385.5	0	357.9	0	190.1	0	190.0	0	512.2
19	66.0	57.6	0	128.2	0	125.7	0	194.4	0	194.4	0	125.7
20	64.6	57.9	0	126.8	0	125.1	0	188.5	0	188.5	0	125.0
21	62.9	57.3	0	125.7	0	124.2	0	181.1	0	181.1	0	124.1
22	61.0	56.0	0	124.6	0	123.3	0	123.2	0	123.2	0	123.2
23	59.0	54.8	0	123.8	0	122.2	0	122.2	0	122.2	0	122.2
24	56.9	53.0	0	123.1	0	121.2	0	121.1	0	121.1	0	121.1

LOADING COOL-HEAT DEMAND - ALTERNATIVE 1
 BASELINE

November		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	QADB	QAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	0	120.7	0	116.7	0	116.7	0	116.7	0	116.7
2	46.9	44.1	0	120.1	0	115.7	0	115.8	0	115.8	0	115.8
3	45.5	42.8	0	119.7	0	115.0	0	115.1	0	115.1	0	115.1
4	44.6	41.9	0	119.4	0	114.5	0	114.6	0	114.6	0	114.6
5	44.4	42.0	0	119.2	0	114.4	-122,628	114.5	-124,097	114.5	-124,097	114.5
6	44.8	42.7	-28,499	119.4	0	114.6	-121,946	114.7	-123,371	114.7	-123,371	114.7
7	45.9	43.9	-36,730	119.9	-22,907	115.2	-97,988	115.2	-122,653	115.2	-122,653	115.2
8	47.8	46.0	0	464.6	-12,724	116.1	-24,792	116.2	-372,912	116.2	-88,876	116.2
9	50.2	48.0	0	504.8	0	117.4	-8,802	117.4	-8,806	117.4	0	117.4
10	52.9	49.9	0	646.9	0	118.7	0	118.8	0	118.8	0	118.8
11	55.8	51.1	0	658.0	0	545.1	0	120.3	0	175.8	0	632.6
12	58.5	52.0	0	660.0	0	557.0	0	121.6	0	188.0	0	633.5
13	60.9	52.5	0	635.2	0	537.6	0	122.9	0	162.1	0	597.0
14	62.8	53.4	0	678.2	0	549.8	0	123.8	0	206.8	0	595.9
15	64.0	53.8	0	675.5	0	550.8	0	159.4	0	211.2	0	588.5
16	64.4	53.9	0	637.7	0	557.5	0	212.1	0	212.1	0	585.9
17	64.1	53.7	0	452.5	0	411.1	0	173.4	0	173.5	0	524.3
18	63.2	53.7	0	359.0	0	328.0	0	169.4	0	169.4	0	474.0
19	61.8	54.2	0	125.8	0	123.3	0	163.1	0	163.1	0	123.4
20	60.0	53.6	0	124.5	0	122.4	0	159.2	0	159.2	0	122.5
21	57.9	52.7	0	123.4	0	121.4	0	150.6	0	150.6	0	121.4
22	55.6	51.2	0	122.3	0	120.2	0	120.3	0	120.3	0	120.3
23	53.2	49.5	0	121.5	0	119.0	0	119.0	0	119.0	0	119.0
24	50.8	47.6	0	120.9	0	117.8	0	117.8	0	117.8	0	117.8

December		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	QADB	QAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	0	116.5	0	110.7	0	110.7	0	110.7	0	110.7
2	37.1	35.1	0	116.0	0	110.5	0	110.5	0	110.5	0	110.5
3	37.4	35.5	0	115.6	0	110.7	0	110.7	0	110.7	0	110.7
4	38.1	36.2	0	115.3	0	111.0	0	111.0	0	111.0	0	111.0
5	39.3	37.6	-122,860	115.2	-125,917	111.6	-129,068	111.6	-129,068	111.6	-129,068	111.6
6	40.9	39.2	-122,163	115.4	-125,157	112.4	-128,215	112.4	-128,215	112.4	-128,215	112.4
7	42.7	41.2	-98,697	115.8	-124,604	113.3	-127,570	113.3	-127,570	113.3	-127,570	113.3
8	44.7	43.1	-10,264	116.6	-113,464	114.3	-126,522	114.3	-400,818	114.3	-509,719	114.3
9	46.8	45.3	0	117.7	-5,497	115.4	-125,190	115.4	-125,190	115.4	-505,463	115.4
10	48.8	47.0	0	119.0	0	116.4	-118,087	116.5	-118,087	116.5	-446,517	116.5
11	50.7	48.1	0	570.3	0	117.4	-8,270	117.4	-8,270	117.4	-366,329	117.4
12	52.2	48.8	0	580.6	0	118.2	0	118.2	0	118.2	-228,247	118.2
13	53.4	49.2	0	563.6	0	118.8	-5,825	118.8	-5,825	118.8	0	118.8
14	54.1	49.2	0	572.0	0	119.2	0	119.2	0	119.2	0	119.2
15	54.4	48.9	0	597.6	0	119.4	-5,457	119.4	-5,457	119.4	0	119.4
16	54.0	48.2	0	562.8	0	119.2	-12,276	119.2	-12,276	119.2	0	119.2
17	53.0	47.3	0	388.5	0	118.7	-27,595	118.7	-27,595	118.7	0	118.7
18	51.4	46.3	0	306.1	0	117.9	-29,761	117.9	-29,761	117.9	0	117.9
19	49.3	45.4	0	120.9	-12,224	116.8	-114,523	116.8	-114,523	116.8	-15,522	116.8
20	47.0	43.5	0	119.8	-38,391	115.6	-224,654	115.6	-224,654	115.6	-38,392	115.6
21	44.5	41.5	0	118.8	-42,976	114.3	-343,564	114.4	-343,564	114.4	-42,976	114.4
22	42.2	39.3	0	117.9	0	113.2	0	113.2	0	113.2	0	113.2
23	40.1	37.6	0	117.2	0	112.1	0	112.1	0	112.1	0	112.1
24	38.5	36.2	0	116.6	0	111.3	0	111.3	0	111.3	0	111.3

BUILDING TEMPERATURE PROFILES - ALTERNATIVE 1
 BASELINE

----- BUILDING TEMPERATURE PROFILES -----

Temperature Range (F)	Room Number						
	1	2	3	4	5	6	7
Max. Temp.	76.4	90.0	90.0	90.0	90.5	81.8	78.1
Mo./Hr.	6 24	6 11	9 14	5 17	6 4	7 21	7 21
Day Type	1	4	4	4	4	4	5
	----- Number of Hours -----						
Above 100	0	0	0	0	0	0	0
95 - 100	0	0	0	0	0	0	0
90 - 95	0	0	0	0	318	0	0
85 - 90	0	635	519	703	2,308	0	0
80 - 85	0	566	825	414	536	235	0
75 - 80	4,010	1,868	2,357	1,870	4,847	4,397	2,166
70 - 75	4,290	3,865	4,850	4,439	751	4,128	6,594
65 - 70	460	1,290	209	1,049	0	0	0
60 - 65	0	499	0	285	0	0	0
55 - 60	0	37	0	0	0	0	0
50 - 55	0	0	0	0	0	0	0
Below 50	0	0	0	0	0	0	0
Min. Temp.	68.2	58.0	65.5	60.4	68.0	67.1	74.0
Mo./Hr.	1 4	1 7	1 7	1 7	1 1	1 7	5 9
Day Type	3	5	1	5	1	1	5

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	WATER
	On Peak (kWh)	On Peak (kW)	
Jan	1,067,950	2,351	357
Feb	963,976	2,473	319
March	1,154,577	2,788	568
April	1,230,076	2,910	723
May	1,326,991	3,073	952
June	1,352,913	3,152	1,127
July	1,384,404	3,188	1,162
Aug	1,407,292	3,163	1,190
Sept	1,299,865	3,122	981
Oct	1,222,233	2,944	684
Nov	1,149,309	2,879	615
Dec	1,072,982	2,716	357
Total	14,632,569	3,188	9,035

Building Energy Consumption = 182,104 (Btu/Sq Ft/Year)
Source Energy Consumption = 546,367 (Btu/Sq Ft/Year)

Floor Area = 274,244 (Sq Ft)

1 EQ5300

CONTROL PANEL & INTERLOCK

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 - BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 3,187.8 (kW)
 Yearly Time of Peak 14 (hr) 7 (mo)

Hour 14 Month 7

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1010L	HR CTV >190 TONS 95 F	924.5	29.00
Sub Total			924.5	29.00
Heating Equipment				
1	HEATPUMP		7.3	0.23
2	EQ2051	ELECTRIC HOT WATER BOILER	20.9	0.65
Total			28.2	0.88
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	617.2	19.36
2		SUMMATION OF FAN ELECTRICAL DEMAND	269.6	8.46
Sub Total			886.8	27.82
Sub Total			0.0	0.00
Miscellaneous				
	Lights		784.3	24.60
	Base Utilities		0.0	0.00
	Misc Equipment		563.9	17.69
Sub Total			1,348.3	42.30
Grand Total			3,187.8	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M200 - BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 274,244
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	22,772.7	0.0	0.2	233,193.3	0.9
Primary Cooling					
Compressor	1,882,724.4	0.0	12.9	19,279,142.0	72.1
Tower/Cond Fans	994,227.9	9,035.0	6.8	10,180,917.0	38.1
Condenser Pump	653,235.2	0.0	4.5	6,689,144.5	25.0
Other Accessories	8,760.0	0.0	0.1	89,702.6	0.3
Auxiliary					
Supply Fans	3,261,615.8	0.0	22.3	33,399,022.0	124.8
Circulation Pumps	716,491.8	0.0	4.9	7,336,892.5	27.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	3,978,107.5	0.0	27.2	40,735,916.0	152.3
Lighting	4,140,592.8	0.0	28.3	42,399,768.0	154.6
Receptacle	2,952,151.2	0.0	20.2	30,230,098.0	110.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	14,632,572.0	9,035.0	100.0	149837888.0	553.4

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	WATER (1000 GL)
	On Peak (kWh)	On Peak (kW)	
Jan	1,067,578	2,351	357
Feb	963,611	2,473	319
March	1,156,645	2,788	576
April	1,230,951	2,910	729
May	1,327,100	3,071	952
June	1,352,587	3,152	1,124
July	1,383,551	3,188	1,154
Aug	1,406,642	3,163	1,185
Sept	1,299,508	3,122	978
Oct	1,223,519	2,944	691
Nov	1,151,593	2,879	625
Dec	1,072,629	2,716	357
Total	14,635,913	3,188	9,047

Building Energy Consumption = 182,146 (Btu/Sq Ft/Year)
Source Energy Consumption = 546,492 (Btu/Sq Ft/Year)

Floor Area = 274,244 (Sq Ft)

1 EQ5300

CONTROL PANEL & INTERLOCK

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 - BASELINE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 3,187.8 (kW)
 Yearly Time of Peak 14 (hr) 7 (mo)

Hour 14 Month 7

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
----------------------	------------------------	-----------------------	---------------------------	------------------------

Cooling Equipment

1	EQ1010L	HR CTV >190 TONS 95 F	924.5	29.00
Sub Total			924.5	29.00

Heating Equipment

1	HEATPUMP		7.3	0.23
2	EQ2051	ELECTRIC HOT WATER BOILER	20.9	0.65
Total			28.2	0.88

Air Moving Equipment

1	SUMMATION OF FAN ELECTRICAL DEMAND		617.2	19.36
2	SUMMATION OF FAN ELECTRICAL DEMAND		269.6	8.46
Sub Total			886.8	27.82

Sub Total			0.0	0.00
-----------	--	--	-----	------

Miscellaneous

Lights			784.3	24.60
Base Utilities			0.0	0.00
Misc Equipment			563.9	17.69
Sub Total			1,348.3	42.30

Grand Total			3,187.8	100.00
-------------	--	--	---------	--------

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M200 - BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 274,244
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	20,687.8	0.0	0.1	211,844.0	0.8
Primary Cooling					
Compressor	1,887,238.4	0.0	12.9	19,325,366.0	72.2
Tower/Cond Fans	994,227.9	9,046.8	6.8	10,180,917.0	38.1
Condenser Pump	653,235.2	0.0	4.5	6,689,144.5	25.0
Other Accessories	8,760.0	0.0	0.1	89,702.6	0.3
Auxiliary					
Supply Fans	3,261,535.5	0.0	22.3	33,398,200.0	124.8
Circulation Pumps	717,486.3	0.0	4.9	7,347,077.0	27.5
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	3,979,021.8	0.0	27.2	40,745,276.0	152.3
Lighting	4,140,592.8	0.0	28.3	42,399,768.0	154.6
Receptacle	2,952,151.2	0.0	20.2	30,230,098.0	110.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	14,635,915.0	9,046.8	100.0	149872112.0	553.5

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 2
- ICE STORAGE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	WATER (1000 G1)
	On Peak (kWh)	On Peak (kW)	
Jan	1,067,950	2,351	357
Feb	963,976	2,473	319
March	1,154,577	2,788	568
April	1,211,244	2,853	746
May	1,310,015	3,073	974
June	1,336,183	3,140	1,141
July	1,365,903	3,158	1,175
Aug	1,391,788	3,151	1,213
Sept	1,285,354	3,108	1,011
Oct	1,201,578	2,846	704
Nov	1,132,736	2,793	629
Dec	1,072,982	2,716	357
Total	14,494,284	3,158	9,194

Building Energy Consumption = 180,383 (Btu/Sq Ft/Year)
Source Energy Consumption = 541,203 (Btu/Sq Ft/Year)

Floor Area = 274,244 (Sq Ft)

1 EQ5300

CONTROL PANEL & INTERLOCK

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 2
M200 ICE STORAGE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 3,158.3 (kW)
Yearly Time of Peak 12 (hr) 7 (mo)

Hour 12 Month 7

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1010L	HR CTV >190 TONS 95 F	923.2	29.23
Sub Total			923.2	29.23
Sub Total			0.0	*****
Air Moving Equipment				
		SUMMATION OF FAN ELECTRICAL DEMAND	617.2	19.54
2		SUMMATION OF FAN ELECTRICAL DEMAND	269.6	8.53
Sub Total			886.8	28.08
Sub Total			0.0	0.00
Miscellaneous				
		Lights	784.3	24.83
		Base Utilities	0.0	0.00
		Misc Equipment	563.9	17.86
Sub Total			1,348.3	42.69
Grand Total			3,158.3	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 2
 M200 - ICE STORAGE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 274,244
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	22,772.7	0.0	0.2	233,193.3	0.9
Primary Cooling					
Compressor	1,911,567.2	0.0	13.2	19,574,494.0	73.2
Tower/Cond Fans	827,100.8	9,193.6	5.7	8,469,532.0	31.7
Condenser Pump	653,235.2	0.0	4.5	6,689,144.5	25.0
Other Accessories	8,760.0	0.0	0.1	89,702.6	0.3
Auxiliary					
Supply Fans	3,261,615.8	0.0	22.5	33,399,022.0	124.8
Circulation Pumps	716,491.8	0.0	4.9	7,336,892.5	27.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	3,978,107.5	0.0	27.4	40,735,916.0	152.3
Lighting	4,140,592.8	0.0	28.6	42,399,768.0	154.6
Receptacle	2,952,151.2	0.0	20.4	30,230,098.0	110.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	14,494,288.0	9,193.6	100.0	148421856.0	548.1

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
- 5% LIGHTING REDUCTION

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	WATER (1000 G)
	On Peak (kWh)	On Peak (kW)	
Jan	1,008,039	2,215	343
Feb	911,229	2,287	306
March	1,089,625	2,621	532
April	1,165,805	2,768	671
May	1,261,346	2,931	891
June	1,289,094	3,015	1,067
July	1,314,895	3,023	1,089
Aug	1,338,447	3,025	1,119
Sept	1,236,230	2,985	922
Oct	1,155,798	2,807	637
Nov	1,086,303	2,745	572
Dec	1,014,114	2,557	344
Total	13,870,925	3,025	8,493

Building Energy Consumption = 172,625 (Btu/Sq Ft/Year)
Source Energy Consumption = 517,928 (Btu/Sq Ft/Year)

Floor Area = 274,244 (Sq Ft)

1 EQ5300

CONTROL PANEL & INTERLOCK

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M200 - 5% LIGHTING REDUCTION

ELEC	744	672	744	720	744	720	744	744	720	744	720	744	8,760
PK	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
1	CECAFVAR AIR FOIL CENTRIFUGAL W\VAR SPEED DRIVE												
ELEC	27435	25501	36393	43671	58446	73913	67421	75072	60162	44308	34135	29944	576,402
PK	176.2	233.6	284.1	422.3	422.3	422.3	422.3	422.3	422.3	389.4	355.9	255.1	422.3
1	CECFCFAN FORWARD CURVE CENT. FAN CONSTANT VOLUME												
ELEC	447	364	83	0	0	0	0	0	0	27	69	255	1,245
PK	6.6	3.9	1.5	1.0	0.0	0.0	0.0	0.0	0.0	1.0	1.0	3.9	6.6
1	CECAFVAR AIR FOIL CENTRIFUGAL W\VAR SPEED DRIVE												
ELEC	12662	11770	16797	20156	26975	34114	31117	34649	27767	20450	15755	13820	266,032
PK	81.3	107.8	131.1	194.9	194.9	194.9	194.9	194.9	194.9	179.7	164.3	117.8	194.9
2	CECFCFAN FORWARD CURVE CENT. FAN CONSTANT VOLUME												
ELEC	200551	181143	200551	194082	200551	194082	200551	200551	194082	200552	194082	200551	2,361,330
PK	269.6	269.6	269.6	269.6	269.6	269.6	269.6	269.6	269.6	269.6	269.6	269.6	269.6
1	HEATPUMP												
ELEC	8623	7488	1383	100	0	0	0	0	0	450	1139	5486	24,669
PK	64.6	65.6	58.2	20.0	0.0	0.0	0.0	0.0	0.0	35.5	44.8	64.2	65.6
1	EQ5020 HEAT WATER CIRC. PUMP C.V.												
ELEC	2023	1914	881	102	95	0	218	226	0	247	691	1652	8,049
PK	7.3	7.3	7.3	7.3	7.3	0.0	7.3	7.3	0.0	7.3	7.3	7.3	7.3
2	EQ2051 ELECTRIC HOT WATER BOILER												
ELEC	1391	1371	0	0	0	0	0	0	0	184	34	909	3,890
PK	15.1	16.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.2	11.7	13.5	16.2
2	EQ5020 HEAT WATER CIRC. PUMP C.V.												
ELEC	2359	2547	564	188	271	0	626	647	0	480	940	2067	10,690
PK	20.9	20.9	20.9	20.9	20.9	0.0	20.9	20.9	0.0	20.9	20.9	20.9	20.9

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 - 5% LIGHTING REDUCTION

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 3,025.3 (kW)
 Yearly Time of Peak 15 (hr) 8 (mo)

Hour 15 Month 8

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1010L	HR CTV >190 TONS 95 F	908.2	30.02
Sub Total			908.2	30.02
Sub Total			0.0	*****
Air Moving Equipment				
		SUMMATION OF FAN ELECTRICAL DEMAND	617.2	20.40
		SUMMATION OF FAN ELECTRICAL DEMAND	269.6	8.91
Sub Total			886.8	29.31
Sub Total			0.0	0.00
Miscellaneous				
		Lights	666.4	22.03
		Base Utilities	0.0	0.00
		Misc Equipment	563.9	18.64
Sub Total			1,230.4	40.67
Grand Total			3,025.3	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M200 - 5% LIGHTING REDUCTION

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 274,244
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	WATER (1000 gal)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	28,559.0	0.0	0.2	292,445.1	1.1
Primary Cooling					
Compressor	1,795,600.9	0.0	12.9	18,386,996.0	68.7
Tower/Cond Fans	994,033.9	8,493.2	7.2	10,178,930.0	38.0
Condenser Pump	653,235.2	0.0	4.7	6,689,144.5	25.0
Other Accessories	8,760.0	0.0	0.1	89,702.6	0.3
Auxiliary					
Supply Fans	3,205,008.5	0.0	23.1	32,819,362.0	122.7
Circulation Pumps	715,523.3	0.0	5.2	7,326,975.5	27.4
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	3,920,531.7	0.0	28.3	40,146,336.0	150.0
Lighting	3,518,058.5	0.0	25.4	36,025,000.0	131.4
Receptacle	2,952,151.2	0.0	21.3	30,230,098.0	110.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	13,870,931.0	8,493.2	100.0	142038656.0	524.8

BUILDING 246

EMC ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM EEAP STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 03/30/92
 FILE: M246ECO
 PREPARED BY: DENNIS JONES
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-9-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M246 Area: 23,072 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Receipt Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (MBtu/yr)
Baseline	47,364	1,057	53,680	231,647	17,958	105,413	44,082	453,837	139	47	1,596
Economizer	47,364	1,057	52,110	231,647	17,958	105,413	44,082	452,267	139	47	1,591
Savings (Loss)	0	0	1,570	0	0	0	0	1,570	0	0	5
HVAC Controls	5,293	52	37,376	79,966	5,537	105,413	44,082	272,426	139	5	935
Savings (Loss)	42,071	1,005	16,304	151,681	12,421	0	0	181,411	0	42	661
Lighting (15% reduction)	54,491	1,183	50,722	231,647	17,958	89,441	44,082	435,033	130	54	1,539
Savings (Loss)	(7,127)	(126)	(2,958)	0	0	15,972	0	18,804	9	(7)	57
Ice Storage	47,364	1,057	73,527	231,647	17,958	105,413	44,082	473,684	56	47	1,664
Savings (Loss)	0	0	(19,847)	0	0	0	0	(19,847)	83	0	(68)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JS DATE 2/28/92

CHECKED BY _____ DATE _____

SCALE M 246

VENTILATION

20 CFM / PERSON (ASSUMED, NO DATA AVAILABLE)

FAN AIRFLOW

NO DATA — LET DESIGNER CALL

EXPOSED FLARE

LENGTH _____

PIPE SIZE _____ 2.00 8" BLOCK WALL - UNINSULATED

SYSTEM TYPE

MULTI-ZONE (1-Z)

BOILER & CHILLER SHARE COMMON COIL → COIL RECK BYPASS DECK

FANS

15 HP SURGE FAN MOTOR

NO DESIGN FAN

2.0" SP

CHILLER

TRANE CGAC 65E

6 ECONO + MIN VENT
12 SC BANK ON/OFF
3 STOR

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BCDG - 245 ECO

ECONOMIZER & MINIMUM VENTILATION (ACT-2)

o ENABLE DRY-BULB ECONOMIZER

(49) DRY-BULB
65°F ON
100% OSA MAX

(45) ECONO - AVAIL

HVAC CONTROLS (ACT-3)

COOLING THERMOSTAT 0-6 78°F 18-24 95°F <CLG BACK>
HEATING THERMOSTAT 0-6 55°F 18-24 55°F <HTG BACK>
FANS, MIN 0, ECON 100% <FAN OFF>
0-6 OFF 18-24 ON 18-24 OFF (26)
100% ON 18-24 OFF 0-6 ON (46)
DISCRIMINATOR - RESETS FANS TO LOAD (46)

THERMAL STORAGE (ACT-4)

CHILLED TRAFFIC GAC 65E
COULD MAKE ICE 45°F + 25°F
1.20 1.45 KW/TON } ROGER HUBERT
25% DROP IN TONNAGE

(22) CHILLER <EQ1770>

(23) STOR REF - 1

(24) ICE STOR

0-6 CHARGING 6-12 CLG 12-16 DISCHARGE
16-24 CLG

LOSS 1%
CAPACITY 154 TON-HR (JULY 7) - (NOON - 4pm)

USE 190 TON-HR ICE BANK
30 TON CHILLER

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE 1/2" = 1'-0"

PEOPLE

120,000 225 SF / PERSON (LIKE 3000-184)

LIGHTS

$15,888 \text{ WATTS} / 23,072 \text{ SF} = 2.00 \text{ W/SF}$

EQUIPMENT

FLOOR AREAS	ZONE - 1	7,125	} TOTAL	23,072 SF	
	2	9,280		Avg	7,691 SF
	3	10,560			

EQUIP	WATTS	FT ²	W/FT ²
PC	200	450	0.44
PRINTED	100	300	0.11
REFRIG	200	1,691	1.03
COFFEE	60	7,691	1.03
COPYER	800	7,691	0.08

0.69 W/SF

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE 1/2" = 1'-0"

U-VALUES


WALL



OUTER FILM	0.25
BRICK BLOCK	1.50
FRAME WALL (1/2" x 12")	12.00
6" FB	0.45
INNER FILM	0.68
	<hr/>
	13.88

$U = 0.072$

ROOF



OUTER FILM	0.25
BW ROOFING DECK	0.33
AIR SPACE	1.24
6" FB BATTES	18.00
ACOUSTIC CEILING	1.25
INNER FILM	0.75
	<hr/>
	21.8

$U = 0.046$

GLASS

DOUBLE PANE METAL TYPE R
THERMAL BREAK

$U = 0.66$

$SC = 0.88$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY BJ DATE 3/3/92

CHECKED BY _____ DATE _____

SCALE 1/245

HVAC CONTROL

55°F HEAT/COOL CHANGEOVER

THERMOSTAT LOGIC

CALL FOR HEAT → BYPASS FULLY OPEN


CALL FOR COOL → COIL " "

" " NEITHER → COIL/BYPASS MIX

CONTROLS DO NOT MAKE SENSE

MUST BE SOME LOGIC SOMEWHERE TO REVERSE THERMOSTAT
CALLS FOR HEATING/COOLING

MODEL AS NORMAL MULTI ZONE WITH NO
SIMULTANEOUS HEATING & COOLING



⊗ Fire Extinguisher

JOB 3105, 000

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

SHEET NO. _____ OF _____

CALCULATED BY *[Signature]* DATE 2/28/72

CHECKED BY _____ DATE _____

SCALE 1/2" = 1'-0"



EMC ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM EEAP STUDY
 LOCATION:

ECO:15-LIGHTING CONTROL

CLIENT CONTRACT NO: DACA21-9-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

EMC PROJECT: #3105,000
 DATE: 17-Feb-92

FILE: 248LITE.WIG
 PREPARED BY: JW
 CHECKED BY: CEL

BUILDING NUMBER: 246

Sheet 1 of 1

% Switchable lights: 16%
 Cooling Factor (Power): 1.25
 Cooling Factor (Energy): 1.25

Room No.	Total KW Lighting	Hours "On" Per Year	Lighting KW Saved Per Month	Lighting KWH Saved/Yr	Total KW / Month	Total KWH Per Yr	Cost of Switches					
							No. of New Switches	Cost	No. of Wall Switches	Cost	No. of Ceiling Switches	Cost
154	0.62	3393	0.09	312	0.775	2630	0	ERR	45		45	
153	0.31	3393	0.05	156	0.3875	1315	0	ERR				
162	0.31	3393	0.05	156	0.3875	1315	0	ERR				
161	0.47	3393	0.00	0	0.59125	1972	0	ERR				
155	0.62	3393	0.00	0	0.775	2630	0	ERR				
102	0.62	3393	0.00	0	0.775	2630	0	ERR				
103	0.93	3393	0.00	0	1.1625	3944	0	ERR				
108	0.00	3393	0.00	0	0	0	0	ERR				
107	8.99	3393	0.00	0	11.2375	38129	0	ERR				
146	2.46	3393	0.00	0	3.1	10618	0	ERR				
147	0.00	3393	0.00	0	0	0	0	ERR				
149	0.00	3393	0.00	0	0	0	0	ERR				
146	2.46	3393	0.00	0	3.1	10618	0	ERR				
144	1.88	3393	0.00	0	2.325	7889	0	ERR				
143	0.93	3393	0.14	409	1.1625	3944	0	ERR				
142	0.62	3393	0.00	0	0.775	2630	0	ERR				
141	0.36	3393	0.05	179	0.445	1510	0	ERR				
136	0.00	3393	0.00	0	0	0	0	ERR				
139	0.00	3393	0.00	0	0	0	0	ERR				
138	0.00	3393	0.00	0	0	0	0	ERR				
109	4.81	3393	0.00	0	6.00625	20379	0	ERR				
110	0.78	3393	0.12	360	0.98875	3287	0	ERR				
111	2.46	3393	0.00	0	3.1	10618	0	ERR				
115	0.47	3393	0.00	0	0.59125	1972	0	ERR				
113	0.62	3393	0.08	312	0.775	2630	0	ERR				
118	1.24	3393	0.00	0	1.55	5269	0	ERR				
124	5.27	3393	0.00	0	6.5875	22351	0	ERR				
119	0.62	3393	0.08	312	0.775	2630	0	ERR				
120	0.62	3393	0.08	312	0.775	2630	0	ERR				
122	0.00	3393	0.00	0	0	0	0	ERR				
123	0.31	3393	0.05	156	0.3875	1315	0	ERR				
125	0.62	3393	0.00	0	0.775	2630	0	ERR				
126	0.31	3393	0.00	0	0.3875	1315	0	ERR				
134	3.72	3393	0.00	0	4.65	15777	0	ERR				
133	0.18	3393	0.00	0	0.18375	657	0	ERR				
132	0.47	3393	0.07	234	0.59125	1972	0	ERR				
131	0.47	3393	0.07	234	0.59125	1972	0	ERR				
130	0.47	3393	0.00	0	0.59125	1972	0	ERR				
128	0.62	3393	0.00	0	0.775	2630	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
0	0.00	3393	0.00	0	0	0	0	ERR				
Total	45.816		0.960462	8224.692	57.02	193485.9	0					

01 Card - Job Information

Project: FORT MCPHERSON & GILLEM EEAP #3105.000

Location: ATLANTA

Client: COE - DACA21-9-C-0097

Program User: DENNIS JONES

Comments: BUILDING 246 - FORT MCPHERSON

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	ICE STORAGE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Description	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	OFFICE	64	113	0			8			
2	2	OFFICE	60	88	0			8			
3	3	OFFICE	96	110	0			8			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room Design RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location Flag	T'stat Location	Mass / No. Hrs	Carpet On Floor
M1	76			CLG	72		HTG				YES

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	YES			0.046	47			0.45

-----CARD 22-- Roof Parameters -----

Roof									
Room Number	Roof Number	Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
2	1	YES			0.046	47			0.45
3	1	YES			0.046	47			0.45

-----CARD 24-- Wall Parameters -----

Wall										Ground
Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Wall Reflectance	Ground Multiplier
1	1	100	8	0.072	89	90			0.45	
1	2	64	8	0.072	89	0			0.45	
1	3	100	8	0.072	89	270			0.45	
2	1	48	8	0.072	89	0			0.45	
2	2	79	8	0.072	89	270			0.45	
2	3	48	8	0.072	89	180			0.45	
3	1	133	8	0.072	89	270			0.45	
3	2	102	8	0.072	89	180			0.45	
3	3	120	8	0.072	89	180			0.45	

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External	Internal	Percent	Visible Transmittance	Inside
							Shading Type	Shading Type	Solar to Ret. Air		Visible Reflectance
1	1	3.75	4.17	11	0.66	0.88					
1	2	3.75	4.17	5	0.66	0.88					
1	3	3.75	4.17	10	0.66	0.88					
2	1	3.75	4.17	5	0.66	0.88					
2	2	3.75	4.17	8	0.66	0.88					
2	3	3.75	4.17	4	0.66	0.88					
3	1	3.75	4.17	8	0.66	0.88					
3	2	3.75	4.17	4	0.66	0.88					

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
M1	PPL1	LGT1	AVAIL	OFF		AVAIL	AVAIL			

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting		Ballast Factor	Percent Lights to Ret. Air	--- Daylighting ---	
							Fixture Type				Reference Point 1	Reference Point 2
1	225	SF-PERS	250	200	1.65	WATT-SF	ASHRAE2		1			
2	225	SF-PERS	250	200	1.65	WATT-SF	ASHRAE2		1			
3	225	SF-PERS	250	200	1.65	WATT-SF	ASHRAE2		1			

-----CARD 28--- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump		Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
			Value	Units							
1	1	OFFICE EQUIPMENT	0.69	WATT-SF	LGT1	ELEC					
2	1	OFFICE EQUIPMENT	0.69	WATT-SF	LGT1	ELEC					
3	1	OFFICE EQUIPMENT	0.69	WATT-SF	LGT1	ELEC					

-----CARD 29--- Room Airflows -----

Room Number	-----Ventilation-----		-----Heating-----		-----Infiltration-----		-----Heating-----		--Reheat Minimum--	
	Value	Units	Value	Units	Value	Units	Value	Units	Value	Units
M1	20	CFM-P	20	CFM-P	0.5	ACH-HR	0.5	ACH-HR		

-----CARD 30- Fan Airflows -----

Room Number	-----Main-----		-----Heating-----		-----Cooling-----		-----Heating-----		--Room Exhaust--	
	Value	Units	Value	Units	Value	Units	Value	Units	Value	Units
M1	1.0	CFM-SF	1.0	CFM-SF						

-----CARD 32-- Exposed Floor Parameters -----

Room Number	Exposed Floor Number	-----Slab-----		-----Exposed Floor-----						
		Perimeter Length	Loss Coefficient	Floor Area	Floor U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No
1	1	264	0.80							
2	1	175	0.80							
3	1	355	0.80							

----- System Section Alternative #1 -----

-----CARD 39-- System Alternative -----

Number	Description
1	ICE STORAGE

-----CARD 40--- System Type -----

-----OPTIONAL VENTILATION SYSTEM-----

System	Ventil	Fan
Set	System Deck Cooling Heating Cooling Heating Static	
Number	Type Location SADBvh SADBvh Schedule Schedule Pressure	
1	SZ ROADK	

-----CARD 41-- Zone Assignment -----

System	Ref #1	Ref #2	Ref #3	Ref #4	Ref #5	Ref #6
Set	Begin	End	Begin	End	Begin	End
Number	Begin	End	Begin	End	Begin	End
1	1	3				

-----CARD 42--- Fan SP and Duct Parameters-----

System	Cool	Heat	Return	Mn Exh	Aux	Rm Exh	Cool	Return	Supply	Supply	Return
Set	Fan	Fan	Fan	Fan	Fan	Fan	Fan Mtr	Fan Mtr	Duct	Duct	Air
Number	SP	SP	SP	SP	SP	SP	Loc	Loc	Ht Gn	Loc	Path
1	2.5										DUCTED

-----CARD 44-- System Options -----

System	Econ	Econ	Max Pct	Direct	Indirect	1st Stage	Exhaust Air Heat Recovery
Set	Type	On	Outside	Evap	Evap	Evap	Effectiveness
Number	Flag	Point	Air	Cooling	Cooling	Cooling	Control Method
1	NONE						

-----CARD 45--- Equipment Schedules -----

System	Main	Direct	Indirect	Auxiliary	Main	Main	Auxiliary
Set	Cooling	Evap	Evap	Cooling	Heating	Preheat	Reheat
Number	Coil	Economizer	Coil	Coil	Coil	Coil	Coil
1	CLG	OFF	OFF	OFF	HTG	OFF	OFF

-----CARD 46--- EMS/BAS Schedules -----

System	Discrim	Night	Optimum	Optimum	DUTY CYCLING	System HR	Room HR
Set	Control	Purge	Start	Stop	On Period	Pattern	Maximum
Number	Schedule	Schedule	Schedule	Schedule	Schedule	Length	Off Time
1	OFF						

----- Equipment Section Alternative #1 -----

-----CARD 59-- Equipment Description / TOD Schedules -----

Alternative	Elec Consump	Elec Demand	Demand
Time of Day	Time of Day	Limit	

Number	Schedule	Schedule	Max KW	Alternative Description
1				ICE STORAGE

-----CARD 60--- Cooling Load Assignment-----
 Load All Coil Cooling
 Asgn Loads To Equipment -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
 Ref Cool Ref Sizing Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
 1 1 BLKPLANT 1 1

-----CARD 62-- Cooling Equipment Parameters -----
 Cool Equip Num -----COOLING----- -----HEAT RECOVERY----- Seq Demand
 Ref Code Of --Capacity-- ----Energy---- --Capacity-- ----Energy---- Order Seq Limit
 Num Name Units Value Units Value Units Value Units Value Units Value Units Num Type Number
 1 EQ1122L 1 65 TONS 1 PAR
 2 EQ1750 1 30 TONS 2 PAR

-----CARD 63-- Cooling Pumps and References -----
 Cool ---CHILLED WATER--- -----CONDENSER----- ---HT REC or AUX--- Switch-
 Ref Full Load Full Load Full Load Full Load Full Load Full Load Full Load over Cold Cooling Misc.
 Num Value Units Value Units Value Units Value Units Control Storage Tower Access.
 1 5 HP
 2 5 HP 1

-----CARD 65-- Heating Load Assignment -----
 Load All Coil
 Assignment Loads To -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
 Reference Heating Ref Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
 1 1 1 1

-----CARD 67-- Heating Equipment Parameters -----
 Heat Equip Number HW Pmp Energy Seq Switch Demand
 Ref Code Of Full Ld Cap'y Rate Order over Hot Misc. Limit
 Number Name Units Value Units Value Units Value Units Value Units Number Control Strg Acc. Cogen Number
 1 EQ2001 1 0.33 HP 1675 MBH 80 PCTEFF

-----CARD 69-- Fan Equipment Parameters -----
 System
 Set Cooling Heating Return Exhaust Auxiliary Room Optional
 Number Fan Fan Fan Fan Supply Exhaust Ventilation
 1 EQ4003

-----CARD 73-- Storage Tank Parameters -----

Strg	Tank	Size		Sched	Disch	Control	Limit	
Ref	Code	Value	Units	Code	Type	Value	Value	Units
1	CLIMAICE	120	TON-HRS	ICE	OPTIMIZE			

-----CARD 73-- Storage Tank Parameters -----

Charge							
Control	Mx	Ls		Warning		Loss	
Type	Value	Units	Value	Units	Value	Units	Units
FULLCHG					1	PERCENT	

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
CLG COOLING TSTAT SCHEDULE
HTG HEATING ONLY (T-STAT AT 65)
ICE
LGT1
OFF ALWAYS OFF
PPL1

System:

SZ SINGLE ZONE

Equipment:

Cooling:

EQ1122L (Utility file not found)
EQ1750 (Utility file not found)

Heating:

EQ2001 GAS FIRE TUBE HOT WATER

Fan:

EQ4003 FC CENTRIF. FAN C.V.

Accessories:

Storage:

CLIMAICE TRANE CALMAC THERMAL STORAGE SYSTEM

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Rule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments: COOLING THERMOSTAT

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	78
24	

Schedule Name: HTG
Project: HEATING ONLY (T-STAT AT 65)
Location:
Client:
Program User:
Comments: HEATING ONLY SCHEDULE - T-STAT

Starting Month: JAN Ending Month: MAY
Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 65
24

Starting Month: JUN Ending Month: SEP
Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 35
24

Starting Month: OCT Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour Temperature

0 65
24

Module Name: ICE
Project:
Location:
Client:
Program User:
Comments: ICE STORAGE

Starting Month: APR Ending Month: NOV
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Tank Cntrl
0	CHARGE
6	SATLOAD
12	DISCHARG
16	SATLOAD
24	

Schedule Name: LGT1

Project:

Location:

Client:

Program User:

Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

Hour	Util	Percent
0	5	
7	80	
8	100	
12	80	
13	100	
16	80	
17	40	
18	5	
24		

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

Hour	Util	Percent
0	5	
24		

● Rule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Schedule Name: PPL1
Project:
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util	Percent
0	0	
7	50	
8	100	
11	80	
12	40	
13	80	
14	100	
16	70	
17	30	
18	0	
24		

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

**
** TRACE 600 ANALYSIS **
**
** by **
**

FORT MCPHERSON & GILLEM EEAP #3105.000
ATLANTA
COE - DACA21-9-C-0097
DENNIS JONES
BUILDING M246 - BASELINE

Weather File Code: ATLANTA.
Location:
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: June To November
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 18:49:43 3/10/92
Dataset Name: M246 .TM

AIRFLOW - ALTERNATIVE 1

----- SYSTEM SUMMARY -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	SZ	2,051	24,714	24,714	24,714	2,051	0	0
Totals		2,051	24,714	24,714	24,714	2,051	0	0

CAPACITY - ALTERNATIVE 1

----- SYSTEM SUMMARY -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating							
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)
1	SZ	41.6	0.0	0.0	0.0	41.6	-200,684	0	0	0	0	0	0	-200,684
Totals		41.6	0.0	0.0	0.0	41.6	-200,684	0	0	0	0	0	0	-200,684

The building peaked at hour 15 month 8 with a capacity of 41.6 tons

ENGINEERING CHECKS - ALTERNATIVE 1

----- ENGINEERING CHECKS -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/Sq Ft	Cfm/Ton	Sq Ft /Ton	Btuh/Sq Ft	Cfm/Sq Ft	Btuh/Sq Ft	
1	Main	SZ	8.30	1.07	594.3	554.8	21.63	1.07	-8.70	23,072

System 1 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK ***** CLG SPACE PEAK ***** HEATING COIL PEAK *****

Peaked at Time ==>	Mo/Hr: 8/15	Mo/Hr: 6/16	Mo/Hr: 13/ 1							
Outside Air ==>	OADB/WB/HR: 92/ 74/105.0	OADB: 96	OADB: 22							
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Percnt Of Tot (%)	CLG Space Sensible (Btuh)	Percnt Of Tot (%)	Space Peak (Btuh)	Coil Peak Tot Sens (Btuh)	Percnt Of Tot (%)
Skylite Solr	0	0	0	0	0.00	0	0.00	0	0	0.00
Skylite Cond	0	0	0	0	0.00	0	0.00	0	0	0.00
Roof Cond	47,721	0	0	47,721	9.56	48,396	13.47	-53,066	-53,066	26.44
Glass Solar	79,642	0	0	79,642	15.96	82,988	23.10	0	0	0.00
Glass Cond	9,172	0	0	9,172	1.84	11,126	3.10	-30,028	-30,028	14.96
Wall Cond	5,737	0	0	5,737	1.15	6,924	1.93	-19,771	-19,771	9.85
Partition	0	0	0	0	0.00	0	0.00	0	0	0.00
Exposed Floor	0	0	0	0	0.00	0	0.00	-31,760	-31,760	15.83
Infiltration	0	0	0	0	0.00	0	0.00	0	0	0.00
Sub Total==>	142,272	0	0	142,272	28.51	149,434	41.59	-134,625	-134,625	67.08
Internal Loads										
Lights	129,929	0	0	129,929	26.04	129,929	36.16	0	0	0.00
People	46,144	0	0	46,144	9.25	25,636	7.13	0	0	0.00
Misc	54,334	0	0	54,334	10.89	54,334	15.12	0	0	0.00
Sub Total==>	230,407	0	0	230,407	46.17	209,898	58.41	0	0	0.00
Ceiling Load	0	0	0	0	0.00	0	0.00	0	0	0.00
Outside Air	0	0	0	82,420	16.52	0	0.00	0	-109,995	54.81
Fan Heat	0	0	0	43,935	8.80	0	0.00	0	43,935	-21.89
Fan Heat	0	0	0	0	0.00	0	0.00	0	0	0.00
Duct Heat Pkup	0	0	0	0	0.00	0	0.00	0	0	0.00
OV/UNDR Sizing	0	0	0	0	0.00	0	0.00	0	0	0.00
Exhaust Heat	0	0	0	0	0.00	0	0.00	0	0	0.00
Terminal Bypass	0	0	0	0	0.00	0	0.00	0	0	0.00
Grand Total==>	372,678	0	0	499,034	100.00	359,332	100.00	-134,625	-200,684	100.00

-----COOLING COIL SELECTION-----

	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR (Deg F)	Leaving DB/WB/HR (Deg F)	Gross Total Floor	Glass (sf)	(%)
Main Clg	41.6	499.0	24,714	77.3	64.5	23,072		
Aux Clg	0.0	0.0	0	0.0	0.0	0		
Opt Vent	0.0	0.0	0	0.0	0.0	794		
Totals	41.6	499.0				23,072	860	14

-----HEATING COIL SELECTION-----

	Capacity (Mbh)	Coil Airfl (cfm)	Ent (Deg F)	Lvg (Deg F)	Type	Cooling (2,051)	Heating (2,051)	Clg % OA	8.3	Type	Clg	Htg
Main Htg	-200.7	24,714	67.9	75.4	Infil	0	0	Clg Cfm/Sqft	1.07	SADB	62.4	77.1
Aux Htg	0.0	0	0.0	0.0	Supply	24,714	24,714	Clg Cfm/Ton	594.28	Plenum	76.0	72.0
Preheat	-0.0	24,714	67.9	60.8	Mincfm	0	0	Clg Sqft/Ton	554.80	Return	76.0	72.0
Reheat	0.0	0	0.0	0.0	Return	24,714	24,714	Clg Btuh/Sqft	21.63	Ret/OA	77.3	67.9
Humidif	0.0	0	0.0	0.0	Exhaust	2,051	2,051	No. People	103	Runarnd	76.0	72.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg % OA	8.3	Fn MtrTD	0.4	0.0
	-200.7				Auxil	0	0	Htg Cfm/SqFt	1.07	Fn BldTD	0.3	0.0
								Htg Btuh/SqFt	-8.70	Fn Frict	0.9	0.0

ZONE PSYCHROMETRICS - ALTERNATIVE 1

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone 1

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	92.0	74.4	44.6	105.0	38.6	
Return/Outdoor Air Mix	77.3	64.2	49.8	72.6	29.9	
Blow through Fan						0.0
Entering Coil	77.3	64.2	49.8	72.6	29.9	
Leaving Coil	60.4	57.5	84.7	69.1	25.2	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	62.0	58.1	79.8	69.1	25.6	
Supply Air	62.0	58.1	79.8	69.1	25.6	
Percent Outside Air		7.87	(%)			
Sensible Heat Ratio (SHR)		0.950				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		8,164	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1

----- PSYCHROMETRIC STATE POINTS -----

Zone 2

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	77.3	64.2	49.8	72.6	29.9	
Blow through Fan						0.0
Entering Coil	77.3	64.2	49.8	72.6	29.9	
Leaving Coil	60.4	57.5	84.6	69.1	25.2	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	62.0	58.1	79.8	69.1	25.6	
Supply Air	62.0	58.1	79.8	69.1	25.6	
Percent Outside Air		7.84	(%)			
Sensible Heat Ratio (SHR)		0.950				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		5,989	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1

----- PSYCHROMETRIC STATE POINTS -----

Zone 3

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.8	52.1	72.8	29.6	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.8	52.1	72.8	29.6	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	77.4	64.9	51.6	75.7	30.4	
Blow through Fan						0.0
Entering Coil	77.4	64.9	51.6	75.7	30.4	
Leaving Coil	61.3	58.5	85.0	71.8	25.9	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	63.0	59.1	80.2	71.8	26.3	
Supply Air	63.0	59.1	80.2	71.8	26.3	
Percent Outside Air		8.89	(%)			
Sensible Heat Ratio (SHR)		0.940				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		10,560	(Cfm)			

SYSTEM LOAD PROFILE - ALTERNATIVE 1

Main System 1 SZ SINGLE ZONE

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	2.1	8	305	-10,034	10	60	1,235.7	0	0	0.0	0	0
5 - 10	4.2	16	607	-20,068	7	43	2,471.4	0	0	0.0	0	0
10 - 15	6.2	11	411	-30,103	7	42	3,707.1	0	0	0.0	0	0
15 - 20	8.3	11	430	-40,137	11	69	4,942.7	0	0	0.0	0	0
20 - 25	10.4	9	331	-50,171	5	29	6,178.4	0	0	0.0	0	0
25 - 30	12.5	3	126	-60,205	8	46	7,414.1	0	0	0.0	0	0
30 - 35	14.6	3	118	-70,240	9	53	8,649.8	0	0	0.0	0	0
35 - 40	16.6	3	120	-80,274	7	43	9,885.5	0	0	0.0	0	0
40 - 45	18.7	3	110	-90,308	9	58	11,121.2	0	0	0.0	0	0
45 - 50	20.8	3	110	-100,342	10	59	12,356.9	0	0	0.0	0	0
50 - 55	22.9	3	114	-110,376	6	36	13,592.5	0	0	0.0	0	0
55 - 60	25.0	5	169	-120,411	12	74	14,828.2	0	0	0.0	0	0
60 - 65	27.0	3	105	-130,445	0	0	16,063.9	0	0	0.0	0	0
65 - 70	29.1	4	152	-140,479	0	0	17,299.6	0	0	0.0	0	0
70 - 75	31.2	8	281	-150,513	0	0	18,535.3	0	0	0.0	0	0
75 - 80	33.3	2	60	-160,548	0	0	19,771.0	0	0	0.0	0	0
80 - 85	35.3	1	45	-170,582	0	0	21,006.6	0	0	0.0	0	0
85 - 90	37.4	3	108	-180,616	0	0	22,242.3	0	0	0.0	0	0
90 - 95	39.5	1	42	-190,650	0	0	23,478.0	0	0	0.0	0	0
95 - 100	41.6	0	0	-200,684	0	0	24,713.7	100	8,760	0.0	0	0
Hours Off	0.0	0	5,016	0	0	8,148	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

January		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4 30.4	-72,666	0.0	0	0.0	0	0.0	-108,574	0.0	-108,574	0.0
2	32.1 29.3	-76,985	0.0	0	0.0	0	0.0	-114,911	0.0	-114,911	0.0
3	31.7 29.3	-80,550	0.0	0	0.0	0	0.0	-117,738	0.0	-117,738	0.0
4	31.9 29.5	-82,928	0.0	0	0.0	0	0.0	-118,004	0.0	-118,004	0.0
5	32.6 30.3	-85,135	0.0	0	0.0	0	0.0	-117,036	0.0	-117,036	0.0
6	33.6 31.3	-84,570	0.0	0	0.0	-11,080	0.0	-113,776	0.0	-113,776	0.0
7	35.0 32.6	-82,419	0.0	0	0.0	-36,830	0.0	-109,300	0.0	-109,300	0.0
8	36.6 34.4	0	0.0	0	0.0	-34,246	0.0	-88,931	0.0	0	0.0
9	38.5 36.3	0	0.0	0	0.0	-34,048	0.0	-68,383	0.0	0	0.0
10	40.4 37.7	0	0.0	0	0.0	-48,617	0.0	-49,274	0.0	0	0.0
11	42.3 38.7	0	0.0	0	0.0	-39,124	0.0	-39,124	0.0	0	0.0
12	44.2 39.6	0	0.0	0	0.0	-30,952	0.0	-30,952	0.0	0	0.0
13	45.8 40.5	0	0.0	0	0.0	-18,982	0.0	-18,982	0.0	0	0.0
14	47.2 41.1	0	0.0	0	0.0	-10,359	0.0	-10,359	0.0	0	0.0
15	48.2 41.6	0	0.0	0	0.0	-3,978	0.0	-3,978	0.0	0	0.0
16	48.9 41.8	0	0.0	0	0.0	-1,478	0.0	-1,478	0.0	0	0.0
17	49.1 41.9	0	0.0	0	0.0	-26,228	0.0	-26,228	0.0	0	0.0
18	48.7 41.9	0	0.0	0	0.0	-43,598	0.0	-43,598	0.0	0	0.0
19	47.4 41.7	0	0.0	0	0.0	-53,678	0.0	-53,678	0.0	0	0.0
20	45.5 40.5	0	0.0	0	0.0	-60,294	0.0	-60,294	0.0	0	0.0
21	43.1 38.9	0	0.0	0	0.0	-69,623	0.0	-69,623	0.0	0	0.0
22	40.4 36.7	0	0.0	0	0.0	-79,297	0.0	-79,297	0.0	0	0.0
23	37.7 34.3	0	0.0	0	0.0	-90,347	0.0	-90,347	0.0	0	0.0
24	35.3 32.3	0	0.0	0	0.0	-99,675	0.0	-99,675	0.0	0	0.0

February		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5 34.5	0	0.0	0	0.0	0	0.0	-93,698	0.0	-93,698	0.0
2	36.0 33.0	0	0.0	0	0.0	0	0.0	-99,022	0.0	-99,022	0.0
3	34.7 31.8	0	0.0	0	0.0	0	0.0	-105,282	0.0	-105,282	0.0
4	33.6 30.9	0	0.0	0	0.0	0	0.0	-110,118	0.0	-110,118	0.0
5	32.8 30.1	0	0.0	0	0.0	0	0.0	-113,511	0.0	-113,511	0.0
6	32.2 29.8	0	0.0	0	0.0	0	0.0	-116,855	0.0	-116,855	0.0
7	32.1 29.6	-10,920	0.0	0	0.0	-5,134	0.0	-117,086	0.0	-117,086	0.0
8	32.5 30.3	0	0.0	0	0.0	-22,222	0.0	-92,239	0.0	0	0.0
9	33.9 31.6	0	0.0	0	0.0	-29,681	0.0	-80,129	0.0	0	0.0
10	36.0 33.0	0	0.0	0	0.0	-33,377	0.0	-66,191	0.0	0	0.0
11	38.5 34.8	0	0.0	0	0.0	-54,735	0.0	-54,735	0.0	0	0.0
12	41.3 36.5	0	0.0	0	0.0	-40,874	0.0	-40,874	0.0	0	0.0
13	43.8 38.1	0	0.0	0	0.0	-26,383	0.0	-26,383	0.0	0	0.0
14	45.9 39.5	0	0.0	0	0.0	-12,976	0.0	-12,976	0.0	0	0.0
15	47.2 40.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	47.7 40.6	0	0.0	0	0.0	-1,176	0.0	-1,176	0.0	0	0.0
17	47.5 40.2	0	0.0	0	0.0	-8,108	0.0	-8,108	0.0	0	0.0
18	47.0 39.8	0	0.0	0	0.0	-39,782	0.0	-39,782	0.0	0	0.0
19	46.2 39.9	0	0.0	0	0.0	-57,151	0.0	-57,151	0.0	0	0.0
20	45.1 39.7	0	0.0	0	0.0	-62,710	0.0	-62,710	0.0	0	0.0
21	43.8 39.2	0	0.0	0	0.0	-68,398	0.0	-68,398	0.0	0	0.0
22	42.3 38.3	0	0.0	0	0.0	-73,722	0.0	-73,722	0.0	0	0.0
23	40.7 37.2	0	0.0	0	0.0	-80,585	0.0	-80,585	0.0	0	0.0
24	39.1 35.8	0	0.0	0	0.0	-86,521	0.0	-86,521	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

March		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4 41.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	43.3 39.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	41.6 38.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	40.6 37.5	0	0.0	0	0.0	0	0.0	0	0.0	-23,600	0.0
5	40.2 37.3	0	0.0	0	0.0	0	0.0	0	0.0	-73,798	0.0
6	40.6 37.8	0	0.0	0	0.0	0	0.0	0	0.0	-82,280	0.0
7	41.6 39.0	0	0.0	0	0.0	0	0.0	0	0.0	-60,764	0.0
8	43.3 40.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	45.4 42.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	47.9 44.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	50.6 45.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	53.3 46.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	55.8 48.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	58.0 49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	59.6 50.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	60.7 50.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	61.0 50.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	60.7 50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	59.6 50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	58.0 50.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	55.8 49.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	53.3 47.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	50.6 45.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	47.9 43.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

April		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7 53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9 52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2 51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	52.9 50.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9 49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	51.2 49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.0 49.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	51.6 49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	53.3 50.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	55.9 51.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	59.0 53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	62.4 55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5 57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1 59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8 60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4 60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2 60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5 60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5 59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2 59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5 59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7 58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7 57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7 55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

May Hour	OADB OAWB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	41.6	0	1.1	0	1.4	0	1.4	0	1.4
2	64.5	60.4	0	41.6	0	0.4	0	0.5	0	0.5	0	0.5
3	62.7	59.1	0	41.6	0	0.0	0	0.0	0	0.0	0	0.0
4	61.2	58.1	0	39.8	0	0.0	0	0.0	0	0.0	0	0.0
5	60.0	57.1	0	27.1	0	0.0	0	0.0	0	0.0	0	0.0
6	59.3	56.6	0	4.3	0	0.0	0	0.0	0	0.0	0	0.0
7	59.0	56.5	0	5.8	0	0.9	0	1.0	0	1.0	0	1.0
8	59.5	56.6	0	20.1	0	12.7	0	1.8	0	1.8	0	13.3
9	60.9	56.6	0	26.1	0	20.4	0	2.0	0	2.0	0	20.8
10	63.0	57.2	0	27.9	0	22.2	0	3.5	0	3.5	0	22.3
11	65.7	58.1	0	29.5	0	23.0	0	5.4	0	5.4	0	23.0
12	68.7	59.8	0	30.3	0	23.4	0	6.3	0	6.3	0	23.4
13	71.7	61.6	0	27.8	0	21.2	0	8.2	0	8.2	0	21.2
14	74.5	63.4	0	34.1	0	27.7	0	10.4	0	10.4	0	27.7
15	76.6	64.8	0	36.0	0	30.3	0	12.0	0	12.0	0	30.3
16	78.0	65.6	0	36.1	0	29.8	0	11.3	0	11.3	0	29.8
17	78.5	65.6	0	30.1	0	25.2	0	10.8	0	10.8	0	25.2
18	78.2	65.8	0	18.6	0	15.4	0	8.8	0	8.8	0	15.4
19	77.5	65.6	0	6.8	0	5.4	0	5.4	0	5.4	0	5.4
20	76.3	66.1	0	5.5	0	4.9	0	4.9	0	4.9	0	4.9
21	74.8	67.2	0	4.7	0	4.5	0	4.5	0	4.5	0	4.5
22	73.0	66.4	0	4.0	0	4.0	0	4.0	0	4.0	0	4.0
23	70.9	65.4	0	3.4	0	3.3	0	3.3	0	3.3	0	3.3
24	68.7	64.0	0	2.9	0	2.4	0	2.4	0	2.4	0	2.4

June Hour	OADB OAWB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	7.0	0	4.0	0	4.9	0	4.9	0	4.9
2	71.2	66.1	0	6.3	0	3.5	0	3.9	0	3.9	0	3.9
3	69.7	65.2	0	5.6	0	2.9	0	3.1	0	3.1	0	3.1
4	68.5	64.3	0	5.2	0	2.3	0	2.4	0	2.4	0	2.4
5	67.8	64.2	0	5.1	0	1.9	0	1.9	0	1.9	0	1.9
6	67.6	64.2	0	7.7	0	3.7	0	3.8	0	3.8	0	3.8
7	68.1	64.8	0	10.0	0	5.5	0	5.5	0	5.5	0	5.5
8	69.4	65.7	0	26.0	0	22.4	0	6.9	0	6.9	0	22.5
9	71.6	66.2	0	31.8	0	27.1	0	8.4	0	8.4	0	27.1
10	74.2	67.2	0	33.3	0	29.6	0	11.0	0	11.0	0	29.6
11	77.2	68.5	0	34.8	0	30.3	0	11.7	0	11.7	0	30.3
12	80.2	70.0	0	35.4	0	31.0	0	12.7	0	12.7	0	31.0
13	82.8	70.8	0	32.6	0	28.3	0	14.8	0	14.8	0	28.3
14	85.0	71.6	0	39.2	0	35.0	0	17.2	0	17.2	0	35.0
15	86.3	72.3	0	41.1	0	37.6	0	18.9	0	18.9	0	37.6
16	86.8	72.1	0	40.7	0	36.2	0	17.6	0	17.6	0	36.2
17	86.6	71.7	0	34.6	0	30.3	0	15.9	0	15.9	0	30.3
18	85.8	71.5	0	23.6	0	20.5	0	13.9	0	13.9	0	20.5
19	84.7	71.2	0	10.6	0	9.4	0	9.6	0	9.6	0	9.4
20	83.2	71.5	0	9.2	0	8.9	0	9.0	0	9.0	0	8.9
21	81.4	71.7	0	8.3	0	8.5	0	8.6	0	8.6	0	8.5
22	79.3	71.4	0	7.7	0	7.8	0	7.8	0	7.8	0	7.8
23	77.2	70.5	0	7.1	0	7.1	0	7.1	0	7.1	0	7.1
24	75.1	69.1	0	6.5	0	5.9	0	5.9	0	5.9	0	5.9

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

July		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0 69.3	0	7.2	0	3.9	0	4.8	0	4.8	0	4.8
2	70.5 68.0	0	6.4	0	3.6	0	4.0	0	4.0	0	4.0
3	69.4 67.1	0	5.9	0	3.1	0	3.3	0	3.3	0	3.3
4	68.5 66.4	0	5.5	0	2.6	0	2.7	0	2.7	0	2.7
5	67.9 66.0	0	5.4	0	2.2	0	2.3	0	2.3	0	2.3
6	67.7 65.9	0	7.4	0	3.6	0	3.6	0	3.6	0	3.6
7	68.1 66.3	0	10.2	0	5.7	0	5.7	0	5.7	0	5.7
8	69.1 67.3	0	26.7	0	23.9	0	7.3	0	7.3	0	24.0
9	70.8 68.0	0	32.1	0	27.9	0	8.9	0	8.9	0	27.9
10	72.9 69.1	0	34.0	0	30.3	0	11.3	0	11.3	0	30.3
11	75.2 70.5	0	35.0	0	30.9	0	12.0	0	12.0	0	30.9
12	77.5 71.7	0	35.7	0	31.6	0	13.0	0	13.0	0	31.6
13	79.6 72.7	0	32.8	0	28.4	0	14.9	0	14.9	0	28.4
14	81.3 73.5	0	39.4	0	35.6	0	17.2	0	17.2	0	35.6
15	82.3 73.7	0	41.3	0	37.5	0	18.6	0	18.6	0	37.5
16	82.7 73.5	0	40.8	0	36.5	0	17.6	0	17.6	0	36.5
17	82.5 73.1	0	34.5	0	30.3	0	15.7	0	15.7	0	30.3
18	82.0 72.6	0	23.2	0	20.1	0	13.5	0	13.5	0	20.1
19	81.1 73.2	0	10.1	0	8.6	0	9.0	0	9.0	0	8.6
20	79.9 73.8	0	9.2	0	8.6	0	8.7	0	8.7	0	8.6
21	78.5 73.9	0	8.5	0	8.5	0	8.5	0	8.5	0	8.5
22	76.9 73.1	0	7.9	0	7.9	0	7.9	0	7.9	0	7.9
23	75.2 71.9	0	7.4	0	6.9	0	6.9	0	6.9	0	6.9
24	73.5 70.8	0	7.0	0	5.9	0	5.9	0	5.9	0	5.9

August		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7 70.2	0	8.0	0	4.4	0	5.4	0	5.4	0	5.4
2	71.2 69.0	0	6.5	0	4.1	0	4.5	0	4.5	0	4.5
3	69.9 68.0	0	5.8	0	3.4	0	3.6	0	3.6	0	3.6
4	68.8 67.1	0	5.5	0	2.8	0	2.9	0	2.9	0	2.9
5	68.0 66.6	0	5.2	0	2.3	0	2.3	0	2.3	0	2.3
6	67.5 66.2	0	6.1	0	2.8	0	2.8	0	2.8	0	2.8
7	67.3 66.1	0	9.6	0	4.9	0	4.9	0	4.9	0	4.9
8	67.8 66.5	0	26.4	0	23.5	0	6.5	0	6.5	0	23.5
9	69.1 67.0	0	32.4	0	26.7	0	7.8	0	7.8	0	26.7
10	71.2 67.8	0	34.2	0	28.9	0	10.2	0	10.2	0	28.9
11	73.8 68.7	0	35.0	0	29.7	0	10.9	0	10.9	0	29.7
12	76.5 70.0	0	35.2	0	30.3	0	11.9	0	11.9	0	30.3
13	79.1 71.2	0	32.3	0	27.9	0	14.4	0	14.4	0	27.9
14	81.1 72.6	0	39.6	0	35.4	0	17.2	0	17.2	0	35.4
15	82.5 73.6	0	41.5	0	37.4	0	18.7	0	18.7	0	37.4
16	83.0 73.7	0	40.7	0	35.3	0	16.2	0	16.2	0	35.3
17	82.8 73.5	0	34.4	0	29.9	0	15.1	0	15.1	0	29.9
18	82.3 73.5	0	21.3	0	18.7	0	12.0	0	12.0	0	18.7
19	81.5 73.1	0	10.1	0	8.6	0	9.0	0	9.0	0	8.6
20	80.4 73.7	0	9.2	0	8.7	0	8.8	0	8.8	0	8.7
21	79.1 74.9	0	8.7	0	8.6	0	8.7	0	8.7	0	8.6
22	77.6 73.9	0	8.1	0	8.2	0	8.2	0	8.2	0	8.2
23	76.0 72.7	0	7.4	0	7.5	0	7.5	0	7.5	0	7.5
24	74.3 71.3	0	7.0	0	6.4	0	6.4	0	6.4	0	6.4

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

September			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	69.8	66.1	0	5.7	0	2.6	0	3.3	0	3.3	0	3.3
2	68.0	64.5	0	4.7	0	1.9	0	2.3	0	2.3	0	2.3
3	66.3	63.0	0	4.0	0	1.4	0	1.5	0	1.5	0	1.5
4	64.9	61.9	0	3.6	0	0.6	0	0.6	0	0.6	0	0.6
5	63.9	61.3	0	3.3	0	0.0	0	0.0	0	0.0	0	0.0
6	63.2	61.0	0	3.2	0	0.0	0	0.0	0	0.0	0	0.0
7	63.0	60.8	0	6.5	0	1.4	0	1.5	0	1.5	0	1.5
8	63.4	61.4	0	22.9	0	18.9	0	3.5	0	3.5	0	19.2
9	64.7	61.8	0	29.4	0	23.3	0	4.8	0	4.8	0	23.3
10	66.6	62.1	0	31.3	0	24.0	0	5.9	0	5.9	0	24.0
11	69.1	62.9	0	32.2	0	26.1	0	8.0	0	8.0	0	26.1
12	71.8	63.7	0	32.6	0	26.2	0	8.5	0	8.5	0	26.2
13	74.5	65.5	0	30.2	0	24.2	0	10.8	0	10.8	0	24.2
14	77.0	67.1	0	36.6	0	31.0	0	13.4	0	13.4	0	31.0
15	78.9	68.2	0	38.3	0	32.0	0	13.4	0	13.4	0	32.0
16	80.2	68.6	0	37.0	0	31.5	0	12.7	0	12.7	0	31.5
17	80.6	68.5	0	29.5	0	25.6	0	11.0	0	11.0	0	25.6
18	80.4	68.9	0	15.4	0	14.0	0	7.2	0	7.2	0	14.0
19	79.7	70.0	0	7.7	0	6.8	0	7.0	0	7.0	0	6.8
20	78.7	71.2	0	6.9	0	6.9	0	7.0	0	7.0	0	6.9
21	77.3	71.6	0	6.3	0	6.8	0	6.8	0	6.8	0	6.8
22	75.6	70.5	0	5.6	0	6.3	0	6.3	0	6.3	0	6.3
23	73.7	69.4	0	5.1	0	5.4	0	5.4	0	5.4	0	5.4
24	71.8	67.7	0	4.5	0	4.4	0	4.4	0	4.4	0	4.4

October			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	54.8	51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	52.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	51.2	48.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	49.8	47.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	48.8	46.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	48.2	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	47.9	45.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	48.5	46.2	0	2.6	0	0.0	0	0.0	0	0.0	0	0.0
9	50.3	47.3	0	21.0	0	0.0	0	0.0	0	0.0	0	0.0
10	52.9	48.7	0	22.5	0	12.3	0	0.0	0	0.0	0	6.1
11	56.2	49.9	0	23.6	0	17.2	0	0.0	0	0.0	0	17.2
12	59.6	51.5	0	24.3	0	18.7	0	0.0	0	0.0	0	18.7
13	62.9	53.5	0	22.8	0	16.5	0	0.0	0	0.0	0	16.5
14	65.5	55.2	0	28.7	0	21.7	0	0.0	0	0.0	0	21.7
15	67.3	56.3	0	29.7	0	22.9	0	0.0	0	0.0	0	22.9
16	67.9	56.6	0	28.3	0	22.4	0	0.6	0	0.6	0	22.5
17	67.7	56.4	0	19.0	0	15.5	0	0.6	0	0.6	0	15.5
18	67.0	56.6	0	9.4	0	7.0	0	0.2	0	0.2	0	7.0
19	66.0	57.6	0	2.4	0	0.7	0	0.2	0	0.2	0	0.7
20	64.6	57.9	0	1.5	0	0.0	0	0.0	0	0.0	0	0.0
21	62.9	57.3	0	0.7	0	0.0	0	0.0	0	0.0	0	0.0
22	61.0	56.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	59.0	54.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	56.9	53.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1

November		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	46.9	44.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	45.5	42.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	44.6	41.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	44.4	42.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	44.8	42.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	45.9	43.9	0	0.0	0	0.0	0	0.0	0	0.0	-18,531	0.0
8	47.8	46.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	50.2	48.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	52.9	49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	55.8	51.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	58.5	52.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	60.9	52.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	62.8	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	64.0	53.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	64.4	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	64.1	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	63.2	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	61.8	54.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	60.0	53.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	57.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	53.2	49.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	50.8	47.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

December		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	0	0.0	0	0.0	0	0.0	-31,487	0.0	-92,105	0.0
2	37.1	35.1	0	0.0	0	0.0	0	0.0	-36,944	0.0	-95,066	0.0
3	37.4	35.5	0	0.0	0	0.0	0	0.0	-56,371	0.0	-94,979	0.0
4	38.1	36.2	0	0.0	0	0.0	0	0.0	-93,754	0.0	-93,754	0.0
5	39.3	37.6	0	0.0	0	0.0	0	0.0	-89,796	0.0	-89,796	0.0
6	40.9	39.2	0	0.0	0	0.0	0	0.0	-84,823	0.0	-84,823	0.0
7	42.7	41.2	0	0.0	0	0.0	0	0.0	-79,154	0.0	-79,154	0.0
8	44.7	43.1	0	0.0	0	0.0	0	0.0	-53,853	0.0	0	0.0
9	46.8	45.3	0	0.0	0	0.0	0	0.0	-31,237	0.0	0	0.0
10	48.8	47.0	0	0.0	0	0.0	0	0.0	-16,793	0.0	0	0.0
11	50.7	48.1	0	0.0	0	0.0	0	0.0	-8,963	0.0	0	0.0
12	52.2	48.8	0	0.0	0	0.0	0	0.0	-4,141	0.0	0	0.0
13	53.4	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	54.1	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	54.4	48.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	54.0	48.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	53.0	47.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	51.4	46.3	0	0.0	0	0.0	0	0.0	-3,956	0.0	0	0.0
19	49.3	45.4	0	0.0	0	0.0	0	0.0	-29,097	0.0	0	0.0
20	47.0	43.5	0	0.0	0	0.0	0	0.0	-39,787	0.0	0	0.0
21	44.5	41.5	0	0.0	0	0.0	0	0.0	-60,118	0.0	0	0.0
22	42.2	39.3	0	0.0	0	0.0	0	0.0	-70,974	0.0	0	0.0
23	40.1	37.6	0	0.0	0	0.0	0	0.0	-80,312	0.0	0	0.0
24	38.5	36.2	0	0.0	0	0.0	-30,074	0.0	-87,624	0.0	0	0.0

BUILDING TEMPERATURE PROFILES - ALTERNATIVE 1

----- B U I L D I N G T E M P E R A T U R E P R O F I L E S -----

Temperature	----- Room Number -----		
Range	1	2	3
(F)			

Max. Temp.	101.3	101.0	98.4
Mo./Hr.	4 18	4 18	4 18
Day Type	2	2	2

	----- Number of Hours -----		
Above 100	64	48	0
95 - 100	154	154	160
90 - 95	460	530	300
85 - 90	658	701	814
80 - 85	1,043	1,197	1,229
75 - 80	5,083	5,031	5,103
70 - 75	1,298	1,099	1,154
65 - 70	0	0	0
60 - 65	0	0	0
55 - 60	0	0	0
50 - 55	0	0	0
Below 50	0	0	0

Min. Temp.	71.9	71.9	71.9
Mo./Hr.	1 9	3 5	1 5
Day Type	3	5	4

t

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	32,680	80	202	1
Feb	29,486	80	164	1
March	33,199	80	12	1
April	30,971	80	0	0
May	42,860	127	0	0
June	47,273	140	0	0
July	46,686	135	0	0
Aug	48,459	135	0	0
Sept	42,397	130	0	0
Oct	37,099	115	0	0
Nov	30,971	80	0	0
Dec	31,933	80	96	1
Total	454,014	140	474	1

Building Energy Consumption = 69,214 (Btu/Sq Ft/Year)
Source Energy Consumption = 203,665 (Btu/Sq Ft/Year)

Floor Area = 23,072 (Sq Ft)

1 EQ2001

GAS FIRE TUBE HOT WATER

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 139.8 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	59.3	42.46
Sub Total			59.3	42.46
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			26.4	18.92
Sub Total			26.4	18.92
Sub Total			0.0	0.00
Miscellaneous				
Lights			38.1	27.24
Base Utilities			0.0	0.00
Misc Equipment			15.9	11.39
Sub Total			54.0	38.62
Grand Total			139.8	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 23,072
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,057.1	47,364.2	3.2	60,681.2	2.7
Primary Cooling					
Compressor	47,084.4	0.0	10.1	482,145.9	21.4
Tower/Cond Fans	5,511.1	0.0	1.2	56,433.5	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,084.8	0.0	0.2	11,108.4	0.5
Auxiliary					
Supply Fans	231,646.6	0.0	49.5	2,372,067.0	105.4
Circulation Pumps	18,135.9	0.0	3.9	185,711.7	8.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	249,782.5	0.0	53.4	2,557,778.8	113.6
Lighting	105,412.5	0.0	22.5	1,079,426.1	46.8
Receptacle	44,081.6	0.0	9.4	451,396.3	19.6
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	454,013.9	47,364.2	100.0	4,698,970.0	207.1

164

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	32,680	80	202	1
Feb	29,486	80	164	1
March	33,199	80	12	1
April	30,971	80	0	0
May	42,113	127	0	0
June	47,273	140	0	0
July	46,686	135	0	0
Aug	48,459	135	0	0
Sept	42,397	130	0	0
Oct	35,729	115	0	0
Nov	30,971	80	0	0
Dec	31,933	80	96	1
Total	451,897	140	474	1

Building Energy Consumption = 68,901 (Btu/Sq Ft/Year)
Source Energy Consumption = 202,726 (Btu/Sq Ft/Year)

Floor Area = 23,072 (Sq Ft)

1 EQ2001

GAS FIRE TUBE HOT WATER

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 139.8 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	59.3	42.46
Sub Total			59.3	42.46
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			26.4	18.92
Sub Total			26.4	18.92
Sub Total			0.0	0.00
Miscellaneous				
Lights			38.1	27.24
Base Utilities			0.0	0.00
Misc Equipment			15.9	11.39
Sub Total			54.0	38.62
Grand Total			139.8	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 23,072
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,057.1	47,364.2	3.2	60,681.2	2.7
Primary Cooling					
Compressor	45,649.1	0.0	9.8	467,448.3	20.8
Tower/Cond Fans	5,409.4	0.0	1.2	55,392.1	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,051.8	0.0	0.2	10,770.5	0.5
Auxiliary					
Supply Fans	231,646.6	0.0	49.7	2,372,067.0	105.4
Circulation Pumps	17,589.0	0.0	3.8	180,111.9	8.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	249,235.7	0.0	53.5	2,552,179.0	113.4
Lighting	105,412.5	0.0	22.6	1,079,426.1	46.8
Receptacle	44,081.6	0.0	9.5	451,396.3	19.6
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	451,897.0	47,364.2	100.0	4,677,293.5	206.1

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	19,189	83	31	3
Feb	17,354	83	19	3
March	20,793	80	0	0
April	18,278	80	0	0
May	26,703	132	0	0
June	29,372	139	0	0
July	26,742	134	0	0
Aug	30,075	134	0	0
Sept	24,981	129	0	0
Oct	23,929	115	0	0
Nov	18,278	80	0	0
Dec	18,350	80	3	1
Total	274,045	139	53	3

Building Energy Consumption = 40,768 (Btu/Sq Ft/Year)
Source Energy Consumption = 121,871 (Btu/Sq Ft/Year)

Floor Area = 23,072 (Sq Ft)

1 EQ2001

GAS FIRE TUBE HOT WATER

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 139.0 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	58.5	42.12
Sub Total			58.5	42.12
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			26.4	19.03
Sub Total			26.4	19.03
Sub Total			0.0	0.00
Miscellaneous				
Lights			38.1	27.39
Base Utilities			0.0	0.00
Misc Equipment			15.9	11.46
Sub Total			54.0	38.85
Grand Total			139.0	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 23,072
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	52.2	5,292.8	0.6	6,105.9	0.3
Primary Cooling					
Compressor	33,062.0	0.0	12.0	338,555.7	15.0
Tower/Cond Fans	3,883.1	0.0	1.4	39,763.1	1.8
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	431.4	0.0	0.2	4,417.5	0.2
Auxiliary					
Supply Fans	79,965.6	0.0	29.0	818,849.6	36.4
Circulation Pumps	7,156.7	0.0	2.6	73,284.5	3.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	87,122.3	0.0	31.6	892,134.1	39.6
Lighting	105,412.5	0.0	38.2	1,079,426.1	46.8
Receptacle	44,081.6	0.0	16.0	451,396.3	19.6
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	274,045.0	5,292.8	100.0	2,811,798.8	123.3

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
STORAGE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	32,680	80	202	1
Feb	29,486	80	164	1
March	33,199	80	12	1
April	30,971	80	0	0
May	46,169	124	0	0
June	50,872	132	0	0
July	50,566	131	0	0
Aug	52,484	131	0	0
Sept	45,809	127	0	0
Oct	38,766	117	0	0
Nov	30,971	100	0	0
Dec	31,933	80	96	1
Total	473,906	132	474	1

Building Energy Consumption = 72,157 (Btu/Sq Ft/Year)
Source Energy Consumption = 212,494 (Btu/Sq Ft/Year)

Floor Area = 23,072 (Sq Ft)

1 EQ2001

GAS FIRE TUBE HOT WATER

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 STORAGE

----- UTILITY PEAK CHECKSUMS -----

Utility ELECTRIC DEMAND

Peak Value 131.9 (kW)
 Yearly Time of Peak 12 (hr) 6 (mo)

Hour 12 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Perct Of Tot (%)
Cooling Equipment				
1	EQ1750	AIR-CLD CTV ICE-CHILL H2O	51.5	39.04
Sub Total			51.5	39.04
Sub Total			0.0	0.00
Air Moving Equipment				
SUMMATION OF FAN ELECTRICAL DEMAND			26.4	20.04
Sub Total			26.4	20.04
Sub Total			0.0	0.00
Miscellaneous				
Lights			38.1	28.85
Base Utilities			0.0	0.00
Misc Equipment			15.9	12.07
Sub Total			54.0	40.92
Grand Total			131.9	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 ICE STORAGE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 23,072
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,057.1	47,364.2	3.1	60,681.2	2.7
Primary Cooling					
Compressor	64,267.3	0.0	13.2	658,098.9	29.2
Tower/Cond Fans	5,635.4	0.0	1.2	57,706.5	2.6
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,625.0	0.0	0.7	37,120.1	1.6
Auxiliary					
Supply Fans	231,646.6	0.0	47.5	2,372,067.0	105.4
Circulation Pumps	18,180.6	0.0	3.7	186,169.8	8.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	249,827.3	0.0	51.2	2,558,237.0	113.7
Lighting	105,412.5	0.0	21.6	1,079,426.1	46.8
Receptacle	44,081.6	0.0	9.0	451,396.3	19.6
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	473,906.0	47,364.2	100.0	4,902,666.0	216.1

t

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
MONTHLY LIGHTS

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	30,670	74	222	2
Feb	27,690	74	183	1
March	31,081	74	20	1
April	29,023	74	0	0
May	40,125	118	0	0
June	44,695	131	0	0
July	44,209	126	0	0
Aug	45,779	126	0	0
Sept	39,820	121	0	0
Oct	34,529	107	0	0
Nov	29,033	74	3	1
Dec	30,011	74	117	1
Total	426,664	131	545	2

Building Energy Consumption = 65,477 (Btu/Sq Ft/Year)
Source Energy Consumption = 191,852 (Btu/Sq Ft/Year)

Floor Area = 23,072 (Sq Ft)

1 EQ2001

GAS FIRE TUBE HOT WATER

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 M246 - LIGHTS

GAS	222	183	20	0	0	0	0	0	0	0	3	117	545
PK	1.5	1.5	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	1.2	1.5
1 EQ5020	HEAT WATER CIRC. PUMP C.V.												
ELEC	70	59	7	0	0	0	0	0	0	0	1	42	178
PK	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3
1 EQ5240	BOILER FORCED DRAFT FAN												
ELEC	355	303	33	0	0	0	0	0	0	0	7	213	911
PK	1.7	1.7	1.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.7	1.7	1.7
1 EQ5307	BOILER CONTROLS												
ELEC	106	91	10	0	0	0	0	0	0	0	2	63	272
PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 M246 - LIGHTS

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 23,072
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,183.2	54,490.9	3.9	69,474.9	3.1
Primary Cooling					
Compressor	44,462.4	0.0	10.0	455,296.2	20.2
Tower/Cond Fans	5,198.4	0.0	1.2	53,232.1	2.4
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,062.3	0.0	0.2	10,878.0	0.5
Auxiliary					
Supply Fans	223,453.1	0.0	50.5	2,288,165.3	101.7
Circulation Pumps	17,782.0	0.0	4.0	182,088.6	8.1
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	241,235.2	0.0	54.5	2,470,253.8	109.7
Lighting	89,440.9	0.0	20.2	915,876.5	39.7
Receptacle	44,081.6	0.0	10.0	451,396.3	19.6
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	426,663.9	54,490.9	100.0	4,426,408.0	195.2

t

BUILDING 358

E M C ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 13-APR-92
 FILE: M358ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M358 Area: 16,110 ft ^ 2

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (Mbtu/yr)
Baseline	9,738	285	41,175	23,857	17,060	89,217	42,448	214,043	111	10	740
ECO#2	41,052	541	40,715	23,857	17,060	89,217	42,448	213,838	111	41	771
Savings/(Loss)	(31,313)	(255)	460	0	0	0	0	205	0	(31)	(31)
ECO#3	9,741	285	41,179	23,857	17,060	89,217	42,448	214,046	111	10	740
Savings/(Loss)	(2)	0	(4)	0	0	0	0	(4)	0	(0)	(0)
ECO#12	2,938	24	18,998	20,022	2,987	89,217	42,448	173,695	96	3	596
Savings/(Loss)	6,800	262	22,178	3,835	14,073	0	0	40,348	15	7	144

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105000
SHEET NO. 1 OF _____
CALCULATED BY RMM DATE 2/28/62
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation - Bldg 358, Baseline

Bldg Type: Frame Admin

Area: 16,650 ft²

ECC: 3, 12 Take off: 2

Take off Bldg: Gillen 735

Assumptions:

- Heating db = 74°F
- Cooling db = 76°F
- Walls, contain R-11 Insulation
- Lighting: 2 W/ft²
- Misc Recep Loads: 3 Btu/h/ft²
- Infiltration: 1/4 ACH = 0


E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
 SHEET NO. 2 OF _____
 CALCULATED BY Rmp DATE 2/28/77
 CHECKED BY _____ DATE _____
 SCALE _____

Comp. _____ Rtd. 300


Wall U-value - ASHRAE Table F 22.4



Material	R-Value
Outside Surface (15 mph wind)	0.17
1/2" Siding	0.51
1/2" Polystyrene	4.17
1/2" Plywood	1.25
R-19 Insulation	19.0
1/2" Gypsum Board	0.45
Inside Surface (still air)	0.68
Total	18.33

$$U = \frac{1}{R} = \frac{1}{18.33} = \boxed{0.054}$$

Roof U-Value - ASHRAE Table F 22.4



Material	R-Value
Outside Surface (15 mph)	0.17
Shingles	0.44
1/2" Plywood	0.62
Air Space	1.24
R-19 Insulation	19.0
1/2" Gyp Board	0.45
Inside Surface (still air)	0.68
Total	22.60

$$U = \frac{1}{R} = \frac{1}{22.60} = \boxed{0.044}$$

Slab Perimeter Coefficient - ASHRAE Table F.25.5

$$F_2 = \boxed{0.80} \text{ Btu/h } ^\circ\text{F ft}$$

Window U-Value - ASHRAE Table F.27.13

- Single pane wood w/ storm window.
 - use double glass w/ 1/2" air space, type R

$$\boxed{U = 0.43}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000

SHEET NO. 3 OF _____

CALCULATED BY RMD DATE 2/28/92

CHECKED BY _____ DATE _____

SCALE _____

Comp Room - Fig. 278

Steady State - Table 278

- Light Ventilation

0.13

Lighting - Assume 2 W/ft²

Mass load - Assume 2 Btu/h ft² in Rm 7 (comp room) 10 Btu/h ft²

People

<u>Rm</u>	<u>#</u>
1	16
2	12
3	17
4	0
5	7
6	8
<u>total</u> 7	4

Assume 3/4 Area

OA Ventilation

- if no duct sizes assume 10% difference ratio between duct sizes

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • Germany

JOB _____
 SHEET NO. _____ OF _____
 CALCULATED BY _____ DATE _____
 CHECKED BY _____ DATE _____
 SCALE _____

Computer Simulation
Base Case

Bldg 348, Mt. Pleasant

Pumps

$$\text{CHW Pump} = \frac{(3.41) (0.746 \frac{\text{kw}}{\text{hp}}) (1.85 \text{ kw})}{0.812 \text{ eff}} = 2.3 \text{ kw} \times 4,330 \frac{\text{wh}}{\text{kwh}} = 10,261 \text{ kwh/yr}$$

$$\text{HW Pump} = \frac{(2.41) (0.746 \frac{\text{kw}}{\text{hp}}) (1.85 \text{ kw})}{0.817} = 1.6 \text{ kw} \times 4,330 \frac{\text{wh}}{\text{kwh}} = 6,790 \text{ kwh/yr}$$

17,050 kwh/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 358, McPherson

ECO #2 - Insulated glass

- use single pane wood frame - dry for all calculations

Window U-Value - ASHRAE Table F-27.12

$$U = \boxed{0.90}$$

Window shading ASHRAE Table F-27.25

$$\boxed{0.57}$$

Window Area = 595 ft²

note: since kWh negative losses were incurred in the data set, energy losses calculated to savings

Electric Savings

Total Electric Savings = -205 kWh/yr

Electric Savings = $\boxed{-0.13}$ kWh/ft²

Gas Savings

Total Gas Savings = 313 MBtu/yr

Gas Savings = $\boxed{0.020}$ MBtu/ft²

Demand Savings

Peak Demand Savings = $\boxed{0}$ kW

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 35E, McPherson

ECC # 3

$$Q = L (A \Delta T + R V^2)^{1/2}$$

A - stack coefficient: 0.0165 - one story ASHRAE Table F 23.7

B - wind coefficient: 0.024 - heavy shield, ASHRAE Table F 23.8

V - avg wind velocity = 12.65 mph

$$\Delta T = 73^{\circ}F - 50^{\circ}F = 23^{\circ}F$$

L - Effective Area = Area * (C_d)² - ASHRAE Table F 23.3

Ex: 1

Windows: w/c double glaz, wood wall - - 4.8' x 2.5' = 11 ft²

window: 0.026 in²/ft²

frame: 0.004 in²/ft²

Door: w/c, single, wood wall - - 34" x 80" = 18.9 ft²

door: 0.157

frame: 0.022

Improvement - no improvement to windows

Door: w/c, single, wood wall

door: 0.114

frame: 0.004

Room 1

Ex: 1

$$\text{door: } (0.157) (5) (18.9) = 14.8$$

$$\text{frame: } (0.024) (5) (18.9) = 2.3$$

17.1

$$Q = 17.1 (0.951) = 16 \text{ cfm}$$

Improv

$$\text{door: } (0.114) (5) (18.9) = 10.8$$

$$\text{frame: } (0.004) (5) (18.9) = 0.4$$

11.2

$$Q = 11.2 (0.951) = 11 \text{ cfm}$$

$$\Delta Q = 16 - 11 = \boxed{5} \text{ cfm}$$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 358, McPherson

FRO #3 (cont)Room 2 - outside air in no infiltrationRoom 1aext

door: $(0.157) (2) (18.9) = 5.9$

frame: $(0.024) (2) (18.9) = \underline{0.9}$

6.8

$Q = 6.8 (0.95) = 7 \text{ cfm}$

Imp

door: $(0.114) (2) (18.9) = 4.3$

frame: $(0.004) (2) (18.9) = \underline{0.2}$

4.5

$Q = 4.5 (0.95) = 4 \text{ cfm}$

$\Delta Q = 7 - 4 = \boxed{3} \text{ cfm}$

Room 1bext

door: $(0.157) (1) (18.9) = 3.0$

frame: $(0.024) (1) (18.9) = \underline{0.5}$

3.5

$Q = 3.5 (0.95) = 3 \text{ cfm}$

impr

door: $(0.114) (1) (18.9) = 2.2$

frame: $(0.004) (1) (18.9) = \underline{0.1}$

2.3

$Q = 2.3 (0.95) = 1 \text{ cfm}$

$\Delta Q = 3 - 1 = \boxed{2} \text{ cfm}$

Room 3

2 doors \Rightarrow see Rm 3 $\Rightarrow \Delta Q = \boxed{3} \text{ cfm}$

Room 6

- OA in no infil

Room 7

- interior zone in no infil

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 358, McPherson

Energy (cont)

<u>Room</u>	<u>Exist util</u>	<u>ΔQ</u>	<u>Imprv util</u>
1	1055	10	1055
3	128	3	125
-		$\Delta Q = \boxed{13}$ cfm	

Demand Savings

Peak Demand Savings = $\boxed{0}$ kW

Electric Savings

Total Electric Savings = -4 kWh/yr

Electric Savings = $\boxed{-0.31}$ kWh/cfm

Gas Savings

Total Gas Savings = 2.002 MBtu/yr

Gas Savings = $\boxed{-1.5 \times 10^{-4}}$ MBtu/cfm

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

RIJg 358, McPherson

ECO #12

- reset total setpoints: -g = cooling TOE hours
- Nighttime setback of total + fans
- Pump shutoff
- discriminator setback of 240

Electric Savings

Total Electric Savings = 40,348 kWh/yr

Load Savings

Peak Demand Savings = 5 kW

Gas Savings

Total Gas Savings = 6.8 MMBtu/yr

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EEAP
 Location: FT MCPHERSON, BLDG 358
 Program User: R. GERRANS

-----CARD 08-- Climatic Information -----

	Summer	Winter	Summer	Summer	Winter		Summer	Winter
Weather	Clearness	Clearness	Design	Design	Design	Building	Ground	Ground
Code	Number	Number	Dry Bulb	Wet Bulb	Dry Bulb	Orientation	Reflect	Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month	Last Month	Peak	1st Month	Last Month	1st Month	Last Month
Cooling	Cooling	Cooling	Summer	Summer	Daylight	Daylight
Simulation	Simulation	Load Hr	Period	Period	Savings	Savings
MAY	OCT					

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG M358, BASELINE

-----CARD 20-- General Room Parameters -----

Room	Zone	Reference	Room	Floor	Floor	Const	Plenum	Acoustic	Floor to	Duplicate	Duplicate	Perimeter
Number	Number	Descrip		Length	Width	Type	Height	Ceiling	Floor	Floors	Rooms per	Depth
								Resistance	Height	Multiplier	Zone	
M1	1	AHU-1 -CHW		10654	1		2		10			
2	2	AHU-2 -CHW		3610	1							
3	3	AHU-3 -DX		44	29							
4	4	COMPUTER AC		30	19							

-----CARD 21-- Thermostat Parameters -----

Room	Cooling	Room	Cooling	Cooling	Heating	Heating	Heating	T'stat	Mass /	Carpet
Number	Room	Design	T'stat	T'stat	Room	T'stat	T'stat	Location	No. Hrs	On
	Design DB	RH	Driftpoint	Schedule	Design DB	Driftpoint	Schedule	Flag	Average	Floor
M1	76			CLG	74					HTG

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
M1	1	YES			.044	38			
2	1								
3	1								
4	1								

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M	1		10	.054	79				
1	1	208				0			
1	2	176				90			
1	3	264				180			
1	4	104				270			
2	1	74				0			
2	2	18				180			
2	3	72				270			
3	1	44				0			
3	2	29				90			
3	3	44				180			
3	4	29				270			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar to Ret. Air	Visible Transmittance	Inside Visible Reflectance
M	1	4.4	2.5		.43	.58					
1	1			31			3				
1	2			31			3				
1	3			45			3				
1	4			8							
2	1			11			4				
2	2			3			5				
2	3			8			3				
3	1			3			4				
3	2			2			5				
3	3			3			5				


```

-----CARD 33-- External Shading -----
-----OVERHANG-----VERTICAL FINS-----
Shading Glass Above Projection Glass Projection Left Projection Right Projection Adjacent
Type Height Glass Out Width Left Out Right Out Out Building
3 4.4 0 1.5 YES
4 4.4 2 22 YES
5 4.4 2 10 YES

```

```

----- System Section Alternative #1 -----

```

```

-----CARD 39-- System Alternative -----
Number Description
1 BLDG M358, BASELINE

```

```

-----CARD 40-- System Type -----
-----OPTIONAL VENTILATION SYSTEM-----
System Ventil Fan
Set System Deck Cooling Heating Cooling Heating Static
Number Type Location SADBvh SADEVh Schedule Schedule Pressure
1 SZ
2 SZ
3 SZ
4 SZ

```

```

-----CARD 41-- Zone Assignment -----
System
Set Ref #1 Ref #2 Ref #3 Ref #4 Ref #5 Ref #6
Number Begin End Begin End Begin End Begin End Begin End Begin End
1 1 1
2 2 2
3 3 3
4 4 4

```

```

-----CARD 42-- Fan SP and Duct Parameters-----
System Cool Heat Return Mn Exh Aux Rm Exh Cool Return Supply Supply Return
Set Fan Fan Fan Fan Fan Fan Fan Mtr Fan Mtr Duct Duct Air
Number SP SP SP SP SP SP Loc Loc Ht Gn Loc Path
1 2.5 SUPPLY OTHER ROOMDK
2 2.5 SUPPLY OTHER ROOMDK
3 2.5 SUPPLY OTHER ROOMDK
4 .5 SUPPLY OTHER ROOMDK

```


-----CARD 63-- Cooling Pumps and References -----

Cool Ref	---CHILLED WATER---	-----CONDENSER-----	---HT REC or AUX---	Switch-
Num	Value	Units	Value	Units
1	2.3	KW		

-----CARD 65-- Heating Load Assignment -----

Load Assignment Reference	All Coil Loads To Heating Ref	-Group 1- Begin End	-Group 2- Begin End	-Group 3- Begin End	-Group 4- Begin End	-Group 5- Begin End	-Group 6- Begin End	-Group 7- Begin End	-Group 8- Begin End	-Group 9- Begin End
1	1	1	4							

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld	Cap'y Value	Energy Rate	Seq Order	Switch over	Hot Strg	Misc. Acc.	Demand Limit
Number	Name	Units	Value	Units	Value	Units	Number	Control	Cogen	Number
1	EQ2001	1	1.6	KW						

-----CARD 69-- Fan Equipment Parameters -----

System Set Number	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	EQ4003						
2	EQ4003						
3	EQ4003						
4	HIEFF-FC						

Utility Description Reference Table

Schedules:

ADMLGTEQ ADMIN LIGHTING AND EQUIPMENT
 ADMPPPL ADMIN PEOPLE SCHEDULE
 AVAIL AVAILABLE (100%)
 CLG COOLING TSTAT SCHEDULE
 CLGC COOLING COIL SCHEDULE
 HTG HEATING TSTAT SCHEDULE
 HTGC HEATING COIL SCHEDULE
 OFF ALWAYS OFF

System:

SZ SINGLE ZONE

Equipment:

Cooling:

EQ1121S AIR-CLD RECIP 20-35 TONS
 EQ1161 AIR-CLD COND COMP <15 TONS

Heating:

EQ2001 GAS FIRE TUBE HOT WATER

Fan:

EQ4003 FC CENTRIF. FAN C.V.
 HIEFF-FC HIGH EFFICIENCY FAN COIL

Schedule Name: ADMLGTEQ

Project: ADMIN LIGHTING AND EQUIPMENT SC

Location:

Client:

Program User:

Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC

Starting Day Type: DSGN Ending Day Type: WKDY

Hour Util Percent

0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC

Starting Day Type: SAT Ending Day Type: SUN

Hour Util Percent

0	5
24	

Schedule Name: ADMPPL
Project: ADMIN PEOPLE SCHEDULE
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 60
PA0

**
** T R A C E 6 0 0 A N A L Y S I S **
**
** by ** **
**

FT MCPHERSON & FT GILLEM EEAP
FT MCPHERSON, BLDG 358

R. GERRANS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 9:14: 0 4/11/92
Dataset Name: M358-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M358, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	----- Main -----					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	SZ	0	12,863	12,863	13,929	1,065	0	0
2	SZ	449	4,493	4,493	4,493	449	0	0
3	SZ	0	1,782	1,782	1,909	128	0	0
4	SZ	0	842	842	842	0	0	0
Totals		449	19,980	19,980	21,173	1,642	0	0

CAPACITY - ALTERNATIVE 1
 BLDG M358, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	----- Cooling -----				Cooling Totals (Tons)	----- Heating -----								
		Main Sys. Capacity (Tons)	Aux. Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)		Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)	
1	SZ	20.4	0.0	0.0	0.0	20.4	-114,543	0	0	0	0	0	0	0	-114,543
2	SZ	7.9	0.0	0.0	0.0	7.9	-40,463	0	0	0	0	0	0	0	-40,463
3	SZ	2.7	0.0	0.0	0.0	2.7	-18,312	0	0	0	0	0	0	0	-18,312
4	SZ	1.1	0.0	0.0	0.0	1.1	-846	0	0	0	0	0	0	0	-846
Totals		32.2	0.0	0.0	0.0	32.2	-174,164	0	0	0	0	0	0	0	-174,164

The building peaked at hour 15 month 8 with a capacity of 32.1 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	----- Cooling -----				----- Heating -----		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	SZ	0.00	1.21	630.5	522.3	22.98	1.21	-10.75	10,654
2	Main	SZ	10.00	1.24	566.2	454.9	26.38	1.24	-11.21	3,610
3	Main	SZ	0.00	1.40	659.2	472.1	25.42	1.40	-14.35	1,276
4	Main	SZ	0.00	1.48	746.6	505.3	23.75	1.48	-1.48	570

System 1 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK ***** CLG SPACE PEAK ***** HEATING COIL PEAK *****
 Peaked at Time ==> Mo/Hr: 8/15 * Mo/Hr: 6/15 * Mo/Hr: 13/ 1
 Outside Air ==> OADB/WB/HR: 92/ 74/105.0 * OADB: 96 * OADB: 22

	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	*	Space Sensible (Btuh)	Perct Of Tot (%)	*	Space Peak (Btuh)	Coil Peak (Btuh)	Perct Of Tot (%)
Envelope Loads						*			*			
Skylite Solr	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Glass Solar	35,420	0	0	35,420	14.47	*	32,890	17.11	*	0	0	0.00
Glass Cond	8,866	0	0	8,866	3.62	*	10,988	5.72	*	-29,319	-29,319	25.60
Wall Cond	7,748	2,395	0	10,143	4.14	*	7,697	4.00	*	-13,341	-17,465	15.25
Partition	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0	0	0	0	0.00	*	0	0.00	*	-31,200	-31,200	27.24
Infiltration	43,919	0	0	43,919	17.94	*	23,085	12.01	*	-59,427	-59,427	51.88
Sub Total==>	95,953	2,395	0	98,348	40.17	*	74,660	38.84	*	-133,287	-137,411	119.96
Internal Loads						*			*			
Lights	72,724	0	0	72,724	29.71	*	72,724	37.83	*	0	0	0.00
People	18,900	0	0	18,900	7.72	*	10,500	5.46	*	0	0	0.00
Misc	31,962	0	0	31,962	13.06	*	31,962	16.63	*	0	0	0.00
Sub Total==>	123,586	0	0	123,586	50.48	*	115,186	59.92	*	0	0	0.00
Ceiling Load	2,395	-2,395	0	0	0.00	*	2,379	1.24	*	-4,124	0	0.00
Outside Air	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sup. Fan Heat	0	0	0	22,868	9.34	*	0	0.00	*	0	22,868	-19.96
Ret. Fan Heat	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Duct Heat Pkup	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
OV/UNDR Sizing	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Terminal Bypass	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Grand Total==>	221,934	0	0	244,802	100.00	*	192,225	100.00	*	-137,411	-114,543	100.00

-----COOLING COIL SELECTION-----

	Total Capacity			Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total		Glass (sf)	(%)
	(Tons)	(Mbh)	(Mbh)		Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Part		
Main Clg	20.4	244.8	211.1	12,863	76.0	63.2	69.8	60.4	56.9	66.4	10,654	0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	750	0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0	0		
Totals	20.4	244.8									Wall	7,520	1,265 17	

-----AREAS-----

-----HEATING COIL SELECTION-----

	Capacity		Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type		Cooling		Heating		Clg % OA		0.0		Type		
	(Mbh)	(cfm)				Vent		Cooling	Heating	Clg Cfm/Sqft	Clg Cfm/Ton	Clg Btuh/Sqft	No. People	Htg % OA	Htg Cfm/Sqft	Fn MtrTD	Fn BldTD	Fn Frict
Main Htg	-114.5	12,863	74.0	82.3	Infil	1,065	1,065	1.21	630.55	62.1	84.0							
Aux Htg	0.0	0	0.0	0.0	Supply	12,863	12,863	76.7	72.8	76.0	74.0							
Preheat	-0.0	12,863	74.0	60.4	Mincfm	0	0	76.0	74.0	76.0	74.0							
Reheat	0.0	0	0.0	0.0	Return	12,863	12,863	76.0	74.0	76.0	74.0							
Humidif	0.0	0	0.0	0.0	Exhaust	0	0	0.4	0.0	0.4	0.0							
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	0.3	0.0	0.3	0.0							
Total	-114.5				Auxil	0	0	0.9	0.0	0.9	0.0							

-----AIRFLOWS (cfm)-----

-----ENGINEERING CHECKS-----

-----TEMPERATURES (F)-----

System 2 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****						CLG SPACE PEAK *****		***** HEATING COIL PEAK *****			
Peaked at Time ==> Mo/Hr: 8/15 *						Mo/Hr: 6/16 *		Mo/Hr: 13/ 1			
Outside Air ==> OADB/WB/HR: 92/ 74/105.0 *						OADB: 96 *		OADB: 22			
Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	*	Space Sensible (Btuh)	Perct Of Tot (%)	*	Space Peak Space Sens (Btuh)	Coil Peak Tot Sens (Btuh)	Perct Of Tot (%)
Envelope Loads					*			*			
Skylite Solr	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	10,310	10,310	10.83	*	0	0.00	*	0	-7,155	17.68
Glass Solar	9,922	0	9,922	10.42	*	10,890	16.13	*	0	0	0.00
Glass Cond	1,696	0	1,696	1.78	*	2,040	3.02	*	-5,609	-5,609	13.86
Wall Cond	1,208	207	1,415	1.49	*	1,653	2.45	*	-3,005	-3,802	9.40
Partition	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0	0	0	0.00	*	0	0.00	*	-6,822	-6,822	16.86
Infiltration	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total==>	12,826	10,517	23,343	24.51	*	14,582	21.60	*	-15,436	-23,389	57.80
Internal Loads					*			*			
Lights	24,642	0	24,642	25.88	*	24,642	36.49	*	0	0	0.00
People	9,900	0	9,900	10.40	*	5,500	8.15	*	0	0	0.00
Misc	10,830	0	10,830	11.37	*	10,830	16.04	*	0	0	0.00
Sub Total==>	45,372	0	45,372	47.65	*	40,972	60.68	*	0	0	0.00
Ceiling Load	10,517	-10,517	0	0.00	*	11,970	17.73	*	-7,953	0	0.00
Outside Air	0	0	18,521	19.45	*	0	0.00	*	0	-25,061	61.94
Sup. Fan Heat			7,987	8.39	*		0.00	*		7,987	-19.74
Ret. Fan Heat		0	0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0	0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0.00	*		0.00	*		0	0.00
Grand Total==>	68,715	0	95,223	100.00	*	67,524	100.00	*	-23,389	-40,463	100.00

-----COOLING COIL SELECTION-----

	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			AREAS		
				Deg F	Deg F	Grains	Deg F	Deg F	Grains	Gross Total Floor	Glass (sf)	(%)
Main Clg	7.9	95.2	4,493	77.6	64.5	73.3	60.3	57.6	69.5	Part	0	
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	164	
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	3,610	0
Totals	7.9	95.2								Wall	1,640	242 15

-----HEATING COIL SELECTION-----

	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	AIRFLOWS (cfm)		--ENGINEERING CHECKS--			--TEMPERATURES (F)--		
						Cooling	Heating	Clg % OA	10.0	Type	Clg	Htg	
Main Htg	-40.5	4,493	68.8	77.2	Vent	449	449	Clg Cfm/Sqft	1.24	SADB	62.0	78.9	
Aux Htg	0.0	0	0.0	0.0	Supply	4,493	4,493	Clg Cfm/Ton	566.20	Plenum	85.2	67.0	
Preheat	-0.0	4,493	68.8	60.3	Mincfm	0	0	Clg Sqft/Ton	454.93	Return	76.0	74.0	
Reheat	0.0	0	0.0	0.0	Return	4,493	4,493	Clg Btuh/Sqft	26.38	Ret/OA	77.6	68.8	
Humidif	0.0	0	0.0	0.0	Exhaust	449	449	No. People	22	Runarnd	76.0	74.0	
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg % OA	10.0	Fn MtrTD	0.4	0.0	
Total	-40.5				Auxil	0	0	Htg Cfm/SqFt	1.24	Fn BldTD	0.3	0.0	
								Htg Btuh/SqFt	-11.21	Fn Frict	0.9	0.0	

System 3 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****						***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****		
Peaked at Time ==> Mo/Hr: 8/15						Mo/Hr: 6/16			Mo/Hr: 13/ 1		
Outside Air ==> OADB/WB/HR: 92/ 74/105.0						OADB: 96			OADB: 22		
Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Percnt Of Tot (%)	*	Space Sensible (Btuh)	Percnt Of Tot (%)	*	Space Peak Space Sens (Btuh)	Coil Peak Tot Sens (Btuh)	Percnt Of Tot (%)
Envelope Loads					*			*			
Skylite Solr	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	3,616	3,616	11.15	*	0	0.00	*	0	-2,479	13.54
Glass Solar	2,112	0	2,112	6.51	*	1,584	6.19	*	0	0	0.00
Glass Cond	617	0	617	1.90	*	742	2.90	*	-2,040	-2,040	11.14
Wall Cond	1,674	300	1,974	6.08	*	1,866	7.29	*	-3,033	-3,729	20.36
Partition	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0	0	0	0.00	*	0	0.00	*	-6,115	-6,115	33.39
Infiltration	5,260	0	5,260	16.22	*	2,683	10.49	*	-7,117	-7,117	38.87
Sub Total==>	9,663	3,916	13,579	41.87	*	6,875	26.87	*	-18,305	-21,480	117.30
Internal Loads					*			*			
Lights	8,710	0	8,710	26.85	*	8,710	34.04	*	0	0	0.00
People	3,150	0	3,150	9.71	*	1,750	6.84	*	0	0	0.00
Misc	3,828	0	3,828	11.80	*	3,828	14.96	*	0	0	0.00
Sub Total==>	15,688	0	15,688	48.37	*	14,288	55.84	*	0	0	0.00
Ceiling Load	3,916	-3,916	0	0.00	*	4,423	17.29	*	-3,175	0	0.00
Outside Air	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sup. Fan Heat			3,167	9.77	*		0.00	*		3,167	-17.30
Ret. Fan Heat		0	0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0	0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0.00	*		0.00	*		0	0.00
Grand Total==>	29,267	0	0	32,434	100.00	25,585	100.00	*	-21,480	-18,312	100

-----COOLING COIL SELECTION-----

	Total Capacity			Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			AREAS		
	(Tons)	(Mbh)	Sens Cap. (Mbh)		Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Glass (sf)	(%)
Main Clg	2.7	32.4	28.0	1,782	76.0	63.2	69.8	61.0	57.2	66.8	Part	0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	147	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	1,276	0
Totals	2.7	32.4									Wall	1,460	88

-----HEATING COIL SELECTION-----

	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F
Main Htg	-18.3	1,782	74.0	83.6
Aux Htg	0.0	0	0.0	0.0
Preheat	-0.0	1,782	74.0	61.0
Reheat	0.0	0	0.0	0.0
Humidif	0.0	0	0.0	0.0
Opt Vent	0.0	0	0.0	0.0
Total	-18.3			

-----AIRFLOWS (cfm)-----

Type	Cooling	Heating
Vent	0	0
Infil	128	128
Supply	1,782	1,782
Mincfm	0	0
Return	1,782	1,782
Exhaust	0	0
Rm Exh	0	0
Auxil	0	0

-----ENGINEERING CHECKS-----

Clg % OA	0.0
Clg Cfm/Sqft	1.40
Clg Cfm/Ton	659.20
Clg Sqft/Ton	472.09
Clg Btuh/Sqft	25.42
No. People	7
Htg % OA	0.0
Htg Cfm/Sqft	1.40
Htg Btuh/Sqft	-14.35

-----TEMPERATURES (F)-----

Type	Clg	Htg
SADB	62.6	85.2
Plenum	85.7	66.1
Return	76.0	74.0
Ret/OA	76.0	74.0
Runarnd	76.0	74.0
Fn MtrTD	0.4	0.0
Fn BldTD	0.3	0.0
Fn Frict	0.9	0.0

System 4 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****					***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****					
Peaked at Time ==>					Mo/Hr: 6/16			Mo/Hr: 6/16			Mo/Hr: 13/ 1		
Outside Air ==>					OADB/WB/HR: 96/ 72/ 84.0			OADB: 96			OADB: 22		
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Percnt Of Tot (%)	*	Space Sensible (Btuh)	Percnt Of Tot (%)	*	Space Peak Space Sens (Btuh)	Coil Peak Tot Sens (Btuh)	Percnt Of Tot (%)	
Skylite Solr	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Skylite Cond	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Roof Cond	0	1,845	0	1,845	13.63	*	0	0.00	*	0	-1,145	135.40	
Glass Solar	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Glass Cond	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Wall Cond	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Partition	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Exposed Floor	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Infiltration	0	0	0	0	0.00	*	0	0.00	*	0	0	0.01	
Sub Total==>	0	1,845	0	1,845	13.63	*	0	0.00	*	0	-1,145	135.40	
Internal Loads													
Lights	3,891	0	0	3,891	28.74	*	3,891	31.29	*	0	0	0.00	
People	1,800	0	0	1,800	13.30	*	1,000	8.04	*	0	0	0.00	
Misc	5,700	0	0	5,700	42.11	*	5,700	45.83	*	0	0	0.00	
Sub Total==>	11,391	0	0	11,391	84.15	*	10,591	85.16	*	0	0	0.00	
Ceiling Load	1,845	-1,845	0	0	0.00	*	1,845	14.84	*	-1,145	0	0.00	
Outside Air	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Sup. Fan Heat	0	0	0	299	2.21	*	0	0.00	*	0	299	-35.40	
Ret. Fan Heat	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Duct Heat Pkup	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
OV/UNDR Sizing	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Exhaust Heat	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Terminal Bypass	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00	
Grand Total==>	13,236	0	0	13,536	100.00	*	12,436	100.00	*	-1,145	-846	100.00	

-----COOLING COIL SELECTION-----										-----AREAS-----		
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)
Main Clg	1.1	13.5	842	76.0	63.2	69.8	61.9	57.9	68.4	Part	0	
Aux Clg	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0	
Opt Vent	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	570	0
0										Wall	0	0
Totals	1.1	13.5										

-----HEATING COIL SELECTION-----				-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA		Type	Clg	Htg	
Main Htg	-0.8	842	74.0	Infil	0	0	Clg Cfm/Sqft	1.48	SADB	62.2	75.3	
Aux Htg	0.0	0	0.0	Supply	842	842	Clg Cfm/Ton	746.59	Plenum	86.2	67.7	
Preheat	-0.0	842	74.0	Mincfm	0	0	Clg Sqft/Ton	505.33	Return	76.0	74.0	
Reheat	0.0	0	0.0	Return	842	842	Clg Btuh/Sqft	23.75	Ret/OA	76.0	74.0	
Humidif	0.0	0	0.0	Exhaust	0	0	No. People	4	Runarnd	76.0	74.0	
Opt Vent	0.0	0	0.0	Rm Exh	0	0	Htg % OA	0.0	Fn MtrTD	0.1	0.0	
Total	-0.8			Auxil	0	0	Htg Cfm/SqFt	1.48	Fn BldTD	0.1	0.0	
							Htg Btuh/SqFt	-1.48	Fn Frict	0.2	0.0	

MAIN SYSTEM COOLING - ALTERNATIVE 1
 BLDG M358, BASELINE

----- P E A K C O O L I N G L O A D S -----
 (Main System)

Room Number	Description	Peak Time Mo/Hr	Space						Coil								
			OA Cond. (F)	Rm Dry (F)	Supp. Dry (F)	Space Air Flow (Cfm)	Space Sens. Load (Btuh)	Space Lat. Load (Btuh)	Peak Time Mo/Hr	OA Cond. (F)	Rm Dry (F)	Supp. Dry (F)	Coil Air Flow (Cfm)	Coil Sens. Load (Btuh)	Coil Lat. Load (Btuh)		
1	AHU-1 -CHW	6/15	96	73	76	62.1	12,863	192,225	23,629	8/15	92	74	76	62.4	12,863	211,112	33,690
Zone	1 Total/Ave.		96	73	76	62.1	12,863	192,225	23,629		92	74	76	62.4	12,863	211,112	33,690
Zone	1 Block	6/15	96	73	76	62.1	12,863	192,225	23,629	8/15	92	74	76	62.4	12,863	211,112	33,690
System	1 Total/Ave.		96	73	76	62.1	12,863	192,225	23,629		92	74	76	62.4	12,863	211,112	33,690
System	1 Block	6/15	96	73	76	62.1	12,863	192,225	23,629	8/15	92	74	76	62.4	12,863	211,112	33,690
2	AHU-2 -CHW	6/16	96	72	76	62.0	4,493	67,524	4,400	8/15	92	74	76	62.7	4,493	80,158	15,065
Zone	2 Total/Ave.		96	72	76	62.0	4,493	67,524	4,400		92	74	76	62.7	4,493	80,158	15,065
Zone	2 Block	6/16	96	72	76	62.0	4,493	67,524	4,400	8/15	92	74	76	62.7	4,493	80,158	15,065
System	2 Total/Ave.		96	72	76	62.0	4,493	67,524	4,400		92	74	76	62.7	4,493	80,158	15,065
System	2 Block	6/16	96	72	76	62.0	4,493	67,524	4,400	8/15	92	74	76	62.7	4,493	80,158	15,065
3	AHU-3 -DX	6/16	96	72	76	62.6	1,782	25,585	2,621	8/15	92	74	76	63.0	1,782	28,005	4,429
Zone	3 Total/Ave.		96	72	76	62.6	1,782	25,585	2,621		92	74	76	63.0	1,782	28,005	4,429
Zone	3 Block	6/16	96	72	76	62.6	1,782	25,585	2,621	8/15	92	74	76	63.0	1,782	28,005	4,429
System	3 Total/Ave.		96	72	76	62.6	1,782	25,585	2,621		92	74	76	63.0	1,782	28,005	4,429
System	3 Block	6/16	96	72	76	62.6	1,782	25,585	2,621	8/15	92	74	76	63.0	1,782	28,005	4,429
4	COMPUTER AC	6/16	96	72	76	62.2	842	12,436	800	6/16	96	72	76	62.2	842	12,736	800
Zone	4 Total/Ave.		96	72	76	62.2	842	12,436	800		96	72	76	62.2	842	12,736	800
Zone	4 Block	6/16	96	72	76	62.2	842	12,436	800	6/16	96	72	76	62.2	842	12,736	800
System	4 Total/Ave.		96	72	76	62.2	842	12,436	800		96	72	76	62.2	842	12,736	800
System	4 Block	6/16	96	72	76	62.2	842	12,436	800	6/16	96	72	76	62.2	842	12,736	800

MAIN SYSTEM HEATING - ALTERNATIVE 1
 BLDG M358, BASELINE

----- P E A K H E A T I N G L O A D S -----
 (Main System)

Room Number	Description	Floor Area (Sq Ft)	Space					Coil						
			Peak Time Mo/Hr	OA Cond. DB/WB (F)	Rm Dry Blb (F)	Supp. Dry Bulb (F)	Space Air Flow (Cfm)	Space Sens. Load (Btuh)	Peak Time Mo/Hr	OA Cond. DB/WB (F)	Rm Dry Blb (F)	Supp. Dry Bulb (F)	Coil Air Flow (Cfm)	Coil Sens. Load (Btuh)
1	AHU-1 -CHW	10,654	13/ 1	22 18	74	84.0	12,863	-137,411	13/ 1	22 18	74	84.0	12,863	-114,543
Zone	1 Total/Ave.	10,654		22 18	74	84.0	12,863	-137,411		22 18	74	84.0	12,863	-114,543
Zone	1 Block	10,654	13/ 1	22 18	74	84.0	12,863	-137,411	13/ 1	22 18	74	84.0	12,863	-114,543
System	1 Total/Ave.	10,654		22 18	74	84.0	12,863	-137,411		22 18	74	84.0	12,863	-114,543
System	1 Block	10,654	13/ 1	22 18	74	84.0	12,863	-137,411	13/ 1	22 18	74	84.0	12,863	-114,543
2	AHU-2 -CHW	3,610	13/ 1	22 18	74	78.9	4,493	-23,389	13/ 1	22 18	74	78.9	4,493	-40,463
Zone	2 Total/Ave.	3,610		22 18	74	78.9	4,493	-23,389		22 18	74	78.9	4,493	-40,463
Zone	2 Block	3,610	13/ 1	22 18	74	78.9	4,493	-23,389	13/ 1	22 18	74	78.9	4,493	-40,463
System	2 Total/Ave.	3,610		22 18	74	78.9	4,493	-23,389		22 18	74	78.9	4,493	-40,463
System	2 Block	3,610	13/ 1	22 18	74	78.9	4,493	-23,389	13/ 1	22 18	74	78.9	4,493	-40,463
3	AHU-3 -DX	1,276	13/ 1	22 18	74	85.2	1,782	-21,480	13/ 1	22 18	74	85.2	1,782	-18,312
Zone	3 Total/Ave.	1,276		22 18	74	85.2	1,782	-21,480		22 18	74	85.2	1,782	-18,312
Zone	3 Block	1,276	13/ 1	22 18	74	85.2	1,782	-21,480	13/ 1	22 18	74	85.2	1,782	-18,312
System	3 Total/Ave.	1,276		22 18	74	85.2	1,782	-21,480		22 18	74	85.2	1,782	-18,312
System	3 Block	1,276	13/ 1	22 18	74	85.2	1,782	-21,480	13/ 1	22 18	74	85.2	1,782	-18,312
4	COMPUTER AC	570	13/ 1	22 18	74	75.3	842	-1,145	13/ 1	22 18	74	75.3	842	-846
Zone	4 Total/Ave.	570		22 18	74	75.3	842	-1,145		22 18	74	75.3	842	-846
Zone	4 Block	570	13/ 1	22 18	74	75.3	842	-1,145	13/ 1	22 18	74	75.3	842	-846
System	4 Total/Ave.	570		22 18	74	75.3	842	-1,145		22 18	74	75.3	842	-846
System	4 Block	570	13/ 1	22 18	74	75.3	842	-1,145	13/ 1	22 18	74	75.3	842	-846

COOLING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- AIR FLOW HEAT GAIN AND LOSS -----
 (At time of Coil Peak)

Room Number	Description	Duct Heat Pickup (Btuh)	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Cooling							
						System Exhaust (Btuh)	Room Exhaust (Cfm)	Ducted Exhaust (Cfm)	Plenum Exhaust (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)	
1	AHU-1 -CHW	0	22,868	0	0	22,868	0	0	0	0	0	0	12,863
Zone	1 Total/Ave.	0	22,868	0	0	22,868	0	0	0	0	0	0	12,863
Zone	1 Block	0	22,868	0	0	22,868	0	0	0	0	0	0	12,863
System	1 Total/Ave.	0	22,868	0	0	22,868	0	0	0	0	0	0	12,863
System	1 Block	0	22,868	0	0	22,868	0	0	0	0	0	0	12,863
2	AHU-2 -CHW	0	7,987	0	0	7,987	449	0	0	0	0	0	4,493
Zone	2 Total/Ave.	0	7,987	0	0	7,987	449	0	0	0	0	0	4,493
Zone	2 Block	0	7,987	0	0	7,987	449	0	0	0	0	0	4,493
System	2 Total/Ave.	0	7,987	0	0	7,987	449	0	0	0	0	0	4,493
System	2 Block	0	7,987	0	0	7,987	449	0	0	0	0	0	4,493
3	AHU-3 -DX	0	3,167	0	0	3,167	0	0	0	0	0	0	1,782
Zone	3 Total/Ave.	0	3,167	0	0	3,167	0	0	0	0	0	0	1,782
Zone	3 Block	0	3,167	0	0	3,167	0	0	0	0	0	0	1,782
System	3 Total/Ave.	0	3,167	0	0	3,167	0	0	0	0	0	0	1,782
System	3 Block	0	3,167	0	0	3,167	0	0	0	0	0	0	1,782
4	COMPUTER AC	0	299	0	0	299	0	0	0	0	0	0	842
Zone	4 Total/Ave.	0	299	0	0	299	0	0	0	0	0	0	842
Zone	4 Block	0	299	0	0	299	0	0	0	0	0	0	842
System	4 Total/Ave.	0	299	0	0	299	0	0	0	0	0	0	842
System	4 Block	0	299	0	0	299	0	0	0	0	0	0	842

HEATING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- A I R F L O W H E A T G A I N A N D L O S S -----
 (At time of Coil Peak)

Room Number	Description	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Total (Btuh)	Heating						
						System Exhaust Airflow (Cfm)	Room Exhaust Airflow (Cfm)	Ducted Airflow (Cfm)	Plenum Airflow (Cfm)	Run Around Airflow (Cfm)	Corridor Airflow (Cfm)	System Return Airflow (Cfm)
1	AHU-1 -CHW	22,868	0	0	22,868	0	0	0	0	0	0	12,863
Zone	1 Total/Ave.	22,868	0	0	22,868	0	0	0	0	0	0	12,863
Zone	1 Block	22,868	0	0	22,868	0	0	0	0	0	0	12,863
System	1 Total/Ave.	22,868	0	0	22,868	0	0	0	0	0	0	12,863
System	1 Block	22,868	0	0	22,868	0	0	0	0	0	0	12,863
2	AHU-2 -CHW	7,987	0	0	7,987	449	0	0	0	0	0	4,493
Zone	2 Total/Ave.	7,987	0	0	7,987	449	0	0	0	0	0	4,493
Zone	2 Block	7,987	0	0	7,987	449	0	0	0	0	0	4,493
System	2 Total/Ave.	7,987	0	0	7,987	449	0	0	0	0	0	4,493
System	2 Block	7,987	0	0	7,987	449	0	0	0	0	0	4,493
3	AHU-3 -DX	3,167	0	0	3,167	0	0	0	0	0	0	1,782
Zone	3 Total/Ave.	3,167	0	0	3,167	0	0	0	0	0	0	1,782
Zone	3 Block	3,167	0	0	3,167	0	0	0	0	0	0	1,782
System	3 Total/Ave.	3,167	0	0	3,167	0	0	0	0	0	0	1,782
System	3 Block	3,167	0	0	3,167	0	0	0	0	0	0	1,782
4	COMPUTER AC	299	0	0	299	0	0	0	0	0	0	842
Zone	4 Total/Ave.	299	0	0	299	0	0	0	0	0	0	842
Zone	4 Block	299	0	0	299	0	0	0	0	0	0	842
System	4 Total/Ave.	299	0	0	299	0	0	0	0	0	0	842
System	4 Block	299	0	0	299	0	0	0	0	0	0	842

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

V
 PAGE

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone 1

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	76.0	63.2	50.0	69.8	29.2	
Blow through Fan						0.0
Entering Coil	76.0	63.2	50.0	69.8	29.2	
Leaving Coil	60.4	57.2	82.7	67.5	25.0	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	62.1	57.8	78.0	67.5	25.4	
Supply Air	62.1	57.8	78.0	67.5	25.4	
Percent Outside Air		0.00	(%)			
Sensible Heat Ratio (SHR)		0.891				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		12,863	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone 2

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	77.6	64.5	49.7	73.3	30.1	
Blow through Fan						0.0
Entering Coil	77.6	64.5	49.7	73.3	30.1	
Leaving Coil	60.3	57.6	85.2	69.4	25.3	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	62.0	58.2	80.3	69.4	25.7	
Supply Air	62.0	58.2	80.3	69.4	25.7	
Percent Outside Air		10.00	(%)			
Sensible Heat Ratio (SHR)		0.939				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		4,493	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone 3

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix	76.0	63.2	50.0	69.8	29.2	
Blow through Fan						0.0
Entering Coil	76.0	63.2	50.0	69.8	29.2	
Leaving Coil	61.0	57.5	81.7	68.0	25.2	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	62.6	58.1	77.1	68.0	25.6	
Supply Air	62.6	58.1	77.1	68.0	25.6	
Percent Outside Air		0.00	(%)			
Sensible Heat Ratio (SHR)		0.907				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		1,782	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone 4

	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	95.6	71.8	32.1	84.0	36.2	
Return/Outdoor Air Mix	76.0	63.2	50.0	69.8	29.2	
Blow through Fan						0.0
Entering Coil	76.0	63.2	50.0	69.8	29.2	
Leaving Coil	61.9	58.0	79.9	68.8	25.6	
Draw Through Fan						0.1
Duct Frictional Heat						0.2
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	62.2	58.1	79.0	68.8	25.6	
Supply Air	62.2	58.1	79.0	68.8	25.6	
Percent Outside Air		0.00	(%)			
Sensible Heat Ratio (SHR)		0.940				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		842	(Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M358, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Part.	ExFlr	Room U-Values (Btu/hr/sqft/F)							Room Mass (lb/sqft)	Room Capac. (Btu/sqft/F)
				Summr Skylt	Wintr Skylt	Summr Roof	Wintr Windo	Wall	Ceill.			
1	AHU-1 -CHW	0.000	0.800	0.000	0.000	0.000	0.430	0.446	0.054	0.317	30.7	6.14
Zone	1 Total/Ave.	0.000	0.800	0.000	0.000	0.000	0.430	0.446	0.054	0.317	30.7	6.14
System	1 Total/Ave.	0.000	0.800	0.000	0.000	0.000	0.430	0.446	0.054	0.317	30.7	6.14
2	AHU-2 -CHW	0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	33.4	8.80
Zone	2 Total/Ave.	0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	33.4	8.80
System	2 Total/Ave.	0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	33.4	8.80
3	AHU-3 -DX	0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	53.7	12.87
Zone	3 Total/Ave.	0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	53.7	12.87
System	3 Total/Ave.	0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	53.7	12.87
4	COMPUTER AC	0.000	0.000	0.000	0.000	0.044	0.000	0.000	0.000	0.317	21.9	6.51
Zone	4 Total/Ave.	0.000	0.000	0.000	0.000	0.044	0.000	0.000	0.000	0.317	21.9	6.51
System	4 Total/Ave.	0.000	0.000	0.000	0.000	0.044	0.000	0.000	0.000	0.317	21.9	6.51
Building		0.000	0.800	0.000	0.000	0.044	0.430	0.446	0.054	0.317	32.8	7.28

BUILDING AREAS - ALTERNATIVE 1
 BLDG M358, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Sk1 /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
		Flr	Rm										
1	AHU-1 -CHW	1	1	10,654	10,654	0	750	0	0	0	1,265	17	6,255
Zone	1 Total/Ave.				10,654	0	750	0	0	0	1,265	17	6,255
System	1 Total/Ave.				10,654	0	750	0	0	0	1,265	17	6,255
2	AHU-2 -CHW	1	1	3,610	3,610	0	164	0	0	3,610	242	15	1,398
Zone	2 Total/Ave.				3,610	0	164	0	0	3,610	242	15	1,398
System	2 Total/Ave.				3,610	0	164	0	0	3,610	242	15	1,398
3	AHU-3 -DX	1	1	1,276	1,276	0	147	0	0	1,276	88	6	1,372
Zone	3 Total/Ave.				1,276	0	147	0	0	1,276	88	6	1,372
System	3 Total/Ave.				1,276	0	147	0	0	1,276	88	6	1,372
4	COMPUTER AC	1	1	570	570	0	0	0	0	570	0	0	0
0	Zone				570	0	0	0	0	570	0	0	0
0	System				570	0	0	0	0	570	0	0	0
0	Building				16,110	0	1,061	0	0	5,456	1,595	15	9,025

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
BLDG M358, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.044 (Btu/Hr/Sq Ft/F)
Overall Wall U-Value = 0.110 (Btu/Hr/Sq Ft/F)
Overall Building U-Value = 0.088 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 2.25 (Btu/Hr/Sq Ft)
Wall Overall Thermal Transfer Value (OTTWw) = 13.50 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M358, BASELINE

Main System 1 SZ SINGLE ZONE

Percent Design Load	Cooling Load			Heating Load			Cooling Airflow			Heating Airflow		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.0	14	425	-5,727	6	15	643.2	19	634	0.0	0	0
5 - 10	2.0	14	418	-11,454	10	25	1,286.3	14	474	0.0	0	0
10 - 15	3.1	13	384	-17,181	11	27	1,929.5	10	324	0.0	0	0
15 - 20	4.1	7	222	-22,909	14	36	2,572.6	7	247	0.0	0	0
20 - 25	5.1	6	171	-28,636	15	38	3,215.8	6	210	0.0	0	0
25 - 30	6.1	2	75	-34,363	20	49	3,859.0	3	108	0.0	0	0
30 - 35	7.1	3	94	-40,090	24	60	4,502.1	2	65	0.0	0	0
35 - 40	8.2	1	23	-45,817	0	0	5,145.3	1	20	0.0	0	0
40 - 45	9.2	2	64	-51,544	0	0	5,788.5	1	22	0.0	0	0
45 - 50	10.2	1	44	-57,272	0	0	6,431.6	1	22	0.0	0	0
50 - 55	11.2	1	22	-62,999	0	0	7,074.8	1	22	0.0	0	0
55 - 60	12.2	6	196	-68,726	0	0	7,717.9	5	151	0.0	0	0
60 - 65	13.3	3	106	-74,453	0	0	8,361.1	5	173	0.0	0	0
65 - 70	14.3	10	302	-80,180	0	0	9,004.3	6	215	0.0	0	0
70 - 75	15.3	4	128	-85,907	0	0	9,647.4	7	237	0.0	0	0
75 - 80	16.3	6	189	-91,634	0	0	10,290.6	7	232	0.0	0	0
80 - 85	17.3	4	127	-97,362	0	0	10,933.8	4	130	0.0	0	0
85 - 90	18.4	2	68	-103,089	0	0	11,576.9	1	22	0.0	0	0
90 - 95	19.4	0	0	-108,816	0	0	12,220.1	0	0	0.0	0	0
95 - 100	20.4	0	0	-114,543	0	0	12,863.2	0	0	0.0	0	0
Hours Off	0.0	0	5,702	0	0	8,510	0.0	0	5,452	0.0	0	8,760

Main System 2 SZ SINGLE ZONE

Percent Design Load	Cooling Load			Heating Load			Cooling Airflow			Heating Airflow		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.4	17	543	-2,023	100	5	224.6	24	808	0.0	0	0
5 - 10	0.8	9	282	-4,046	0	0	449.3	14	465	0.0	0	0
10 - 15	1.2	8	258	-6,069	0	0	673.9	10	348	0.0	0	0
15 - 20	1.6	7	221	-8,093	0	0	898.6	4	122	0.0	0	0
20 - 25	2.0	9	306	-10,116	0	0	1,123.2	4	141	0.0	0	0
25 - 30	2.4	4	140	-12,139	0	0	1,347.9	2	77	0.0	0	0
30 - 35	2.8	3	107	-14,162	0	0	1,572.5	2	75	0.0	0	0
35 - 40	3.2	5	158	-16,185	0	0	1,797.2	1	22	0.0	0	0
40 - 45	3.6	3	104	-18,208	0	0	2,021.8	2	66	0.0	0	0
45 - 50	4.0	4	114	-20,231	0	0	2,246.5	2	64	0.0	0	0
50 - 55	4.4	5	170	-22,255	0	0	2,471.1	1	44	0.0	0	0
55 - 60	4.8	2	65	-24,278	0	0	2,695.8	3	108	0.0	0	0
60 - 65	5.2	5	172	-26,301	0	0	2,920.4	7	234	0.0	0	0
65 - 70	5.6	3	107	-28,324	0	0	3,145.1	6	196	0.0	0	0
70 - 75	6.0	5	152	-30,347	0	0	3,369.7	7	236	0.0	0	0
75 - 80	6.3	3	102	-32,370	0	0	3,594.4	3	104	0.0	0	0
80 - 85	6.7	2	65	-34,394	0	0	3,819.0	3	110	0.0	0	0
85 - 90	7.1	3	110	-36,417	0	0	4,043.7	3	107	0.0	0	0
90 - 95	7.5	1	20	-38,440	0	0	4,268.3	0	0	0.0	0	0
95 - 100	7.9	2	54	-40,463	0	0	4,493.0	2	54	0.0	0	0
Hours Off	0.0	0	5,510	0	0	8,755	0.0	0	5,379	0.0	0	8,760

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M358, BASELINE

Main System 3 SZ SINGLE ZONE

Percent Design Load	Cooling Load			Heating Load			Cooling Airflow			Heating Airflow		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.1	12	340	-916	3	16	89.1	14	484	0.0	0	0
5 - 10	0.3	8	237	-1,831	11	59	178.2	12	421	0.0	0	0
10 - 15	0.4	11	323	-2,747	22	120	267.3	11	371	0.0	0	0
15 - 20	0.5	9	249	-3,662	13	73	356.3	12	395	0.0	0	0
20 - 25	0.7	9	255	-4,578	12	66	445.4	8	262	0.0	0	0
25 - 30	0.8	3	84	-5,494	18	95	534.5	6	204	0.0	0	0
30 - 35	0.9	3	92	-6,409	18	95	623.6	1	23	0.0	0	0
35 - 40	1.1	1	25	-7,325	3	18	712.7	2	67	0.0	0	0
40 - 45	1.2	4	107	-8,240	0	0	801.8	3	109	0.0	0	0
45 - 50	1.4	4	123	-9,156	0	0	890.9	1	39	0.0	0	0
50 - 55	1.5	4	100	-10,072	0	0	979.9	1	39	0.0	0	0
55 - 60	1.6	3	91	-10,987	0	0	1,069.0	6	210	0.0	0	0
60 - 65	1.8	6	163	-11,903	0	0	1,158.1	5	172	0.0	0	0
65 - 70	1.9	8	241	-12,818	0	0	1,247.2	6	192	0.0	0	0
70 - 75	2.0	7	212	-13,734	0	0	1,336.3	6	213	0.0	0	0
75 - 80	2.2	0	0	-14,650	0	0	1,425.4	4	149	0.0	0	0
80 - 85	2.3	7	195	-15,565	0	0	1,514.5	2	66	0.0	0	0
85 - 90	2.4	0	0	-16,481	0	0	1,603.5	0	0	0.0	0	0
90 - 95	2.6	0	0	-17,397	0	0	1,692.6	0	0	0.0	0	0
95 - 100	2.7	0	0	-18,312	0	0	1,781.7	0	0	0.0	0	0
Hours Off	0.0	0	5,923	0	0	8,218	0.0	0	5,344	0.0	0	8,760

Main System 4 SZ SINGLE ZONE

Percent Design Load	Cooling Load			Heating Load			Cooling Airflow			Heating Airflow		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.1	34	2,575	-42	0	0	42.1	0	0	0.0	0	0
5 - 10	0.1	21	1,582	-85	0	0	84.2	0	0	0.0	0	0
10 - 15	0.2	7	558	-127	0	0	125.3	0	0	0.0	0	0
15 - 20	0.2	0	27	-169	0	0	168.4	0	0	0.0	0	0
20 - 25	0.3	0	0	-211	0	0	210.5	0	0	0.0	0	0
25 - 30	0.3	0	0	-254	0	0	252.6	0	0	0.0	0	0
30 - 35	0.4	1	60	-296	0	0	294.7	0	0	0.0	0	0
35 - 40	0.5	1	85	-338	0	0	336.9	0	0	0.0	0	0
40 - 45	0.5	1	107	-381	0	0	379.0	0	0	0.0	0	0
45 - 50	0.6	1	40	-423	0	0	421.1	0	0	0.0	0	0
50 - 55	0.6	0	20	-465	0	0	463.2	0	0	0.0	0	0
55 - 60	0.7	1	52	-507	0	0	505.3	0	0	0.0	0	0
60 - 65	0.7	3	220	-550	0	0	547.4	0	0	0.0	0	0
65 - 70	0.8	2	165	-592	0	0	589.5	0	0	0.0	0	0
70 - 75	0.8	2	172	-634	0	0	631.6	0	0	0.0	0	0
75 - 80	0.9	3	235	-677	0	0	673.7	0	0	0.0	0	0
80 - 85	1.0	9	664	-719	0	0	715.8	0	0	0.0	0	0
85 - 90	1.0	8	611	-761	0	0	757.9	0	0	0.0	0	0
90 - 95	1.1	4	299	-804	0	0	800.0	0	0	0.0	0	0
95 - 100	1.1	1	42	-846	0	0	842.1	100	8,760	0.0	0	0
Hours Off	0.0	0	1,246	0	0	8,760	0.0	0	0	0.0	0	8,760

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

V 60
 PAC

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M358, BASELINE

----- SYSTEM LOAD PROFILE -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.6	64	4,796	-8,708	57	312	999.0	60	5,219	0.0	0	0
5 - 10	3.2	5	374	-17,416	7	41	1,998.0	9	818	0.0	0	0
10 - 15	4.8	5	401	-26,125	8	44	2,997.0	7	626	0.0	0	0
15 - 20	6.4	4	311	-34,833	8	46	3,996.0	3	291	0.0	0	0
20 - 25	8.0	2	148	-43,541	16	86	4,995.0	3	256	0.0	0	0
25 - 30	9.6	1	102	-52,249	3	18	5,994.0	2	151	0.0	0	0
30 - 35	11.3	2	113	-60,957	0	0	6,993.0	1	72	0.0	0	0
35 - 40	12.9	0	0	-69,666	0	0	7,992.0	1	45	0.0	0	0
40 - 45	14.5	1	65	-78,374	0	0	8,991.0	0	38	0.0	0	0
45 - 50	16.1	1	93	-87,082	0	0	9,990.0	1	44	0.0	0	0
50 - 55	17.7	1	66	-95,790	0	0	10,989.0	1	83	0.0	0	0
55 - 60	19.3	3	214	-104,498	0	0	11,988.0	1	93	0.0	0	0
60 - 65	20.9	1	80	-113,207	0	0	12,987.0	1	106	0.0	0	0
65 - 70	22.5	3	235	-121,915	0	0	13,986.1	4	318	0.0	0	0
70 - 75	24.1	3	219	-130,623	0	0	14,985.1	3	257	0.0	0	0
75 - 80	25.7	1	102	-139,331	0	0	15,984.1	2	151	0.0	0	0
80 - 85	27.3	1	108	-148,039	0	0	16,983.1	2	147	0.0	0	0
85 - 90	28.9	1	87	-156,748	0	0	17,982.1	1	45	0.0	0	0
90 - 95	30.6	0	0	-165,456	0	0	18,981.1	0	0	0.0	0	0
95 - 100	32.2	0	0	-174,164	0	0	19,980.1	0	0	0.0	0	0
Hours Off	0.0	0	1,246	0	0	8,213	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M358, BASELINE

January			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	
1	33.4	30.4		0	0.0	0	0.0		0	0.0		-5,082	0.0		-36,775	0.0	
2	32.1	29.3		0	0.0	0	0.0		0	0.0		-5,393	0.0		-38,465	0.0	
3	31.7	29.3	-27,828	0.0		0	0.0		0	0.0		-5,744	0.0		-40,334	0.0	
4	31.9	29.5	-48,794	0.0		0	0.0		0	0.0		-5,835	0.0		-39,739	0.0	
5	32.6	30.3	-56,058	0.0		0	0.0		0	0.0		-33,655	0.0		-42,536	0.0	
6	33.6	31.3	-56,302	0.0		0	0.0		0	0.0		-43,588	0.0		-43,598	0.0	
7	35.0	32.6	-55,625	0.0		0	0.0		0	0.0		-41,072	0.0		-41,077	0.0	
8	36.6	34.4		0	0.0		0	0.5		0	0.0	-22,900	0.0		0	0.5	
9	38.5	36.3		0	0.9		0	0.9		0	0.0	-9,972	0.0		0	0.9	
10	40.4	37.7		0	0.9		0	0.9		0	0.0	-3,598	0.0		0	0.9	
11	42.3	38.7		0	0.9		0	0.9		0	0.0	-2,464	0.0		0	0.9	
12	44.2	39.6		0	0.9		0	0.9		0	0.0	-1,860	0.0		0	0.9	
13	45.8	40.5		0	0.7		0	0.7		0	0.0	-1,235	0.0		0	0.7	
14	47.2	41.1		0	0.9		0	0.9	-1,003	0.0		-1,246	0.0		0	0.9	
15	48.2	41.6		0	1.0		0	1.0	-1,653	0.0		-1,653	0.0		0	1.0	
16	48.9	41.8		0	1.0		0	1.0	-1,896	0.0		-1,896	0.0		0	1.0	
17	49.1	41.9		0	0.8		0	0.8	-2,184	0.1		-2,184	0.1		0	0.8	
18	48.7	41.9		0	0.4		0	0.4	-2,190	0.0		-14,412	0.0		0	0.4	
19	47.4	41.7		0	0.1		0	0.0	-2,387	0.0		-20,018	0.0		0	0.0	
20	45.5	40.5		0	0.0		0	0.0	-2,692	0.0		-20,759	0.0		0	0.0	
21	43.1	38.9		0	0.0		0	0.0	-3,399	0.0		-25,730	0.0		0	0.0	
22	40.4	36.7		0	0.0		0	0.0	-3,843	0.0		-28,703	0.0		0	0.0	
23	37.7	34.3		0	0.0		0	0.0	-4,272	0.0		-32,231	0.0		0	0.0	
24	35.3	32.3		0	0.0		0	0.0	-4,832	0.0		-35,590	0.0		0	0.0	

February			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	
1	37.5	34.5		0	0.0	0	0.0		0	0.0		-4,996	0.0		-36,173	0.0	
2	36.0	33.0		0	0.0	0	0.0		0	0.0		-23,716	0.0		-39,138	0.0	
3	34.7	31.8		0	0.0	0	0.0		0	0.0		-39,718	0.0		-39,717	0.0	
4	33.6	30.9		0	0.0	0	0.0		0	0.0		-41,227	0.0		-41,236	0.0	
5	32.8	30.1		0	0.0	0	0.0		0	0.0		-42,557	0.0		-42,557	0.0	
6	32.2	29.8		0	0.0	0	0.0		0	0.0		-44,279	0.0		-44,279	0.0	
7	32.1	29.6		0	0.0	0	0.0		0	0.0		-43,495	0.0		-43,495	0.0	
8	32.5	30.3		0	0.6		0	0.6		0	0.0	-19,638	0.0		0	0.6	
9	33.9	31.6		0	0.9		0	0.9		0	0.0	-14,979	0.0		0	0.9	
10	36.0	33.0		0	0.9		0	0.9		0	0.0	-13,435	0.0		0	0.9	
11	38.5	34.8		0	0.9		0	0.9	-285	0.0		-15,623	0.0		0	0.9	
12	41.3	36.5		0	0.9		0	0.9	-2,764	0.0		-10,676	0.0		0	0.9	
13	43.8	38.1		0	0.7		0	0.7	-2,252	0.0		-8,172	0.0		0	0.7	
14	45.9	39.5		0	1.0		0	0.9	-2,064	0.0		-8,080	0.0		0	0.9	
15	47.2	40.4		0	1.0		0	1.0	-1,506	0.0		-1,506	0.0		0	1.0	
16	47.7	40.6		0	1.0		0	1.0	-2,298	0.1		-6,783	0.1		0	1.0	
17	47.5	40.2		0	0.8		0	0.8	-2,501	0.1		-14,772	0.1		0	0.8	
18	47.0	39.8		0	0.4		0	0.4	-2,901	0.1		-27,588	0.1		0	0.4	
19	46.2	39.9		0	0.1		0	0.0	-2,802	0.0		-24,926	0.0		0	0.0	
20	45.1	39.7		0	0.1		0	0.0	-3,128	0.0		-26,054	0.0		0	0.0	
21	43.8	39.2		0	0.0		0	0.0	-3,387	0.0		-26,189	0.0		0	0.0	
22	42.3	38.3		0	0.0		0	0.0	-3,736	0.0		-27,851	0.0		0	0.0	
23	40.7	37.2		0	0.0		0	0.0	-4,362	0.0		-31,756	0.0		0	0.0	
24	39.1	35.8		0	0.0		0	0.0	-4,627	0.0		-33,516	0.0		0	0.0	

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

V
 PAC

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M358, BASELINE

March			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	43.3	39.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	41.6	38.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	40.6	37.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	40.2	37.3	0	0.0	0	0.0	0	0.0	0	0.0	-2,120	0.0
6	40.6	37.8	0	0.0	0	0.0	0	0.0	0	0.0	-4,675	0.0
7	41.6	39.0	0	0.0	0	0.0	0	0.0	0	0.0	-9,805	0.0
8	43.3	40.7	0	0.7	0	0.7	0	0.0	0	0.0	0	0.6
9	45.4	42.5	0	0.9	0	0.9	0	0.0	0	0.0	0	0.9
10	47.9	44.3	0	0.9	0	0.9	0	0.0	0	0.0	0	0.9
11	50.6	45.5	0	1.0	0	0.9	0	0.0	0	0.0	0	0.9
12	53.3	46.8	0	1.0	0	0.9	0	0.1	0	0.0	0	0.9
13	55.8	48.5	0	0.8	0	0.7	0	0.1	0	0.1	0	0.7
14	58.0	49.6	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
15	59.6	50.3	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
16	60.7	50.9	0	1.1	0	1.0	0	0.1	0	0.1	0	1.0
17	61.0	50.9	0	0.9	0	0.8	0	0.1	0	0.1	0	0.8
18	60.7	50.7	0	0.5	0	0.4	0	0.1	0	0.1	0	0.4
19	59.6	50.7	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
20	58.0	50.5	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
21	55.8	49.4	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
22	53.3	47.8	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
23	50.6	45.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	47.9	43.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

April			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2	51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	52.9	50.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	51.2	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.0	49.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	51.6	49.9	0	0.7	0	0.7	0	0.0	0	0.0	0	0.7
9	53.3	50.6	0	0.9	0	0.9	0	0.0	0	0.0	0	0.9
10	55.9	51.8	0	1.0	0	1.0	0	0.0	0	0.0	0	0.9
11	59.0	53.4	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
12	62.4	55.6	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
13	65.5	57.7	0	0.8	0	0.8	0	0.1	0	0.1	0	0.8
14	68.1	59.4	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
15	69.8	60.7	0	1.1	0	1.0	0	0.1	0	0.1	0	1.0
16	70.4	60.9	0	1.1	0	1.0	0	0.1	0	0.1	0	1.0
17	70.2	60.2	0	0.9	0	0.8	0	0.1	0	0.1	0	0.8
18	69.5	60.1	0	0.5	0	0.4	0	0.1	0	0.1	0	0.4
19	68.5	59.4	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
20	67.2	59.7	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
21	65.5	59.3	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
22	63.7	58.8	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
23	61.7	57.3	0	0.1	0	0.1	0	0.1	0	0.1	0	0.1
24	59.7	55.6	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M358, BASELINE

May Hour	OADB OAWB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	31.1	0	8.0	0	0.1	0	0.1	0	0.1
2	64.5	60.4	0	31.1	0	8.0	0	0.0	0	0.0	0	0.0
3	62.7	59.1	0	31.1	0	8.0	0	0.0	0	0.0	0	0.0
4	61.2	58.1	0	31.1	0	0.3	0	0.0	0	0.0	0	0.0
5	60.0	57.1	0	31.1	0	0.0	0	0.0	0	0.0	0	0.0
6	59.3	56.6	0	15.0	0	0.0	0	0.0	0	0.0	0	0.0
7	59.0	56.5	0	13.4	0	0.0	0	0.0	0	0.0	0	0.0
8	59.5	56.6	0	21.9	0	6.9	0	0.0	0	0.0	0	6.4
9	60.9	56.6	0	25.5	0	16.5	0	0.0	0	0.0	0	16.6
10	63.0	57.2	0	25.8	0	18.1	0	0.1	0	0.1	0	18.1
11	65.7	58.1	0	26.0	0	18.4	0	0.1	0	0.1	0	18.4
12	68.7	59.8	0	26.6	0	18.8	0	1.3	0	1.3	0	18.8
13	71.7	61.6	0	24.2	0	15.9	0	3.1	0	3.1	0	15.9
14	74.5	63.4	0	27.9	0	21.2	0	4.3	0	4.3	0	21.2
15	76.6	64.8	0	28.4	0	22.8	0	5.5	0	5.5	0	22.8
16	78.0	65.6	0	28.1	0	22.6	0	5.1	0	5.1	0	22.6
17	78.5	65.6	0	24.5	0	18.7	0	5.2	0	5.2	0	18.7
18	78.2	65.8	0	17.7	0	10.7	0	4.4	0	4.4	0	10.7
19	77.5	65.6	0	10.8	0	2.6	0	2.6	0	2.6	0	2.6
20	76.3	66.1	0	10.3	0	2.3	0	2.3	0	2.3	0	2.3
21	74.8	67.2	0	9.7	0	1.8	0	1.8	0	1.8	0	1.8
22	73.0	66.4	0	9.1	0	1.3	0	1.3	0	1.3	0	1.3
23	70.9	65.4	0	8.7	0	0.6	0	0.6	0	0.6	0	0.6
24	68.7	64.0	0	8.3	0	0.2	0	0.2	0	0.2	0	0.2

June Hour	OADB OAWB		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	2.8	0	1.2	0	1.3	0	1.3	0	1.3
2	71.2	66.1	0	2.4	0	0.6	0	0.7	0	0.7	0	0.7
3	69.7	65.2	0	1.9	0	0.2	0	0.2	0	0.2	0	0.2
4	68.5	64.3	0	1.6	0	0.1	0	0.1	0	0.1	0	0.1
5	67.8	64.2	0	1.5	0	0.0	0	0.0	0	0.0	0	0.0
6	67.6	64.2	0	5.1	0	0.9	0	1.0	0	1.0	0	1.0
7	68.1	64.8	0	7.5	0	3.2	0	3.3	0	3.3	0	3.3
8	69.4	65.7	0	21.6	0	17.6	0	3.4	0	3.4	0	17.7
9	71.6	66.2	0	26.1	0	21.4	0	3.9	0	3.9	0	21.3
10	74.2	67.2	0	26.8	0	23.5	0	6.0	0	6.0	0	23.5
11	77.2	68.5	0	27.6	0	23.8	0	6.3	0	6.3	0	23.8
12	80.2	70.0	0	28.6	0	24.7	0	7.6	0	7.6	0	24.7
13	82.8	70.8	0	25.3	0	21.5	0	8.7	0	8.7	0	21.5
14	85.0	71.6	0	30.4	0	26.8	0	9.8	0	9.8	0	26.8
15	86.3	72.3	0	31.3	0	28.0	0	10.5	0	10.5	0	28.0
16	86.8	72.1	0	31.0	0	27.5	0	9.9	0	9.9	0	27.5
17	86.6	71.7	0	26.2	0	22.8	0	9.1	0	9.1	0	22.8
18	85.8	71.5	0	17.3	0	14.7	0	8.4	0	8.4	0	14.7
19	84.7	71.2	0	7.4	0	5.9	0	6.0	0	6.0	0	5.9
20	83.2	71.5	0	6.5	0	5.7	0	5.8	0	5.8	0	5.7
21	81.4	71.7	0	5.6	0	4.8	0	4.8	0	4.8	0	4.8
22	79.3	71.4	0	4.7	0	4.0	0	4.0	0	4.0	0	4.0
23	77.2	70.5	0	3.9	0	3.1	0	3.1	0	3.1	0	3.1
24	75.1	69.1	0	3.3	0	2.1	0	2.1	0	2.1	0	2.1

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M358, BASELINE

July			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	
1	72.0	69.3	0	3.0		0	0.9		0	1.0		0	1.0		0	1.0	
2	70.5	68.0	0	2.4		0	0.4		0	0.4		0	0.4		0	0.4	
3	69.4	67.1	0	2.0		0	0.1		0	0.1		0	0.1		0	0.1	
4	68.5	66.4	0	1.7		0	0.0		0	0.0		0	0.0		0	0.0	
5	67.9	66.0	0	1.5		0	0.0		0	0.0		0	0.0		0	0.0	
6	67.7	65.9	0	4.4		0	0.0		0	0.0		0	0.0		0	0.0	
7	68.1	66.3	0	7.4		0	3.3		0	3.4		0	3.4		0	3.4	
8	69.1	67.3	0	22.1		0	18.5		0	3.7		0	3.7		0	18.6	
9	70.8	68.0	0	26.3		0	21.7		0	4.2		0	4.2		0	21.7	
10	72.9	69.1	0	27.4		0	23.7		0	6.1		0	6.1		0	23.7	
11	75.2	70.5	0	27.8		0	23.9		0	6.2		0	6.2		0	23.9	
12	77.5	71.7	0	28.6		0	24.3		0	7.2		0	7.2		0	24.3	
13	79.6	72.7	0	25.4		0	21.1		0	8.2		0	8.2		0	21.1	
14	81.3	73.5	0	30.5		0	26.6		0	9.5		0	9.5		0	26.6	
15	82.3	73.7	0	31.5		0	27.7		0	10.1		0	10.1		0	27.7	
16	82.7	73.5	0	31.0		0	27.3		0	9.5		0	9.5		0	27.3	
17	82.5	73.1	0	26.0		0	22.3		0	8.5		0	8.5		0	22.3	
18	82.0	72.6	0	17.0		0	14.1		0	7.8		0	7.8		0	14.1	
19	81.1	73.2	0	7.0		0	5.4		0	5.6		0	5.6		0	5.4	
20	79.9	73.8	0	6.4		0	5.2		0	5.3		0	5.3		0	5.2	
21	78.5	73.9	0	5.6		0	4.7		0	4.7		0	4.7		0	4.7	
22	76.9	73.1	0	4.8		0	3.6		0	3.6		0	3.6		0	3.6	
23	75.2	71.9	0	4.1		0	2.7		0	2.7		0	2.7		0	2.7	
24	73.5	70.8	0	3.5		0	1.8		0	1.8		0	1.8		0	1.8	

August			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	
1	72.7	70.2	0	3.3		0	1.0		0	1.2		0	1.2		0	1.2	
2	71.2	69.0	0	2.5		0	0.4		0	0.5		0	0.5		0	0.5	
3	69.9	68.0	0	1.8		0	0.1		0	0.1		0	0.1		0	0.1	
4	68.8	67.1	0	1.6		0	0.1		0	0.1		0	0.1		0	0.1	
5	68.0	66.6	0	1.4		0	0.0		0	0.0		0	0.0		0	0.0	
6	67.5	66.2	0	2.4		0	0.0		0	0.0		0	0.0		0	0.0	
7	67.3	66.1	0	6.8		0	1.5		0	1.5		0	1.5		0	1.5	
8	67.8	66.5	0	22.0		0	18.6		0	3.5		0	3.5		0	18.8	
9	69.1	67.0	0	26.9		0	21.2		0	3.7		0	3.7		0	21.2	
10	71.2	67.8	0	28.0		0	23.2		0	5.7		0	5.7		0	23.3	
11	73.8	68.7	0	28.3		0	23.5		0	5.9		0	5.9		0	23.5	
12	76.5	70.0	0	28.3		0	24.0		0	6.7		0	6.7		0	24.0	
13	79.1	71.2	0	25.2		0	21.5		0	8.6		0	8.6		0	21.5	
14	81.1	72.6	0	30.8		0	27.2		0	10.1		0	10.1		0	27.2	
15	82.5	73.6	0	31.8		0	28.3		0	10.6		0	10.6		0	28.3	
16	83.0	73.7	0	31.0		0	26.7		0	8.8		0	8.8		0	26.7	
17	82.8	73.5	0	25.8		0	22.2		0	8.3		0	8.3		0	22.2	
18	82.3	73.5	0	15.8		0	13.2		0	6.8		0	6.8		0	13.2	
19	81.5	73.1	0	7.1		0	5.2		0	5.5		0	5.5		0	5.2	
20	80.4	73.7	0	6.3		0	5.1		0	5.2		0	5.2		0	5.1	
21	79.1	74.9	0	5.7		0	4.5		0	4.5		0	4.5		0	4.5	
22	77.6	73.9	0	4.8		0	3.8		0	3.8		0	3.8		0	3.8	
23	76.0	72.7	0	3.9		0	2.8		0	2.8		0	2.8		0	2.8	
24	74.3	71.3	0	3.3		0	2.0		0	2.0		0	2.0		0	2.0	

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M358, BASELINE

September			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	69.8	66.1		0		1.3		0		0.2		0		0.2		0		0.2
2	68.0	64.5		0		0.8		0		0.1		0		0.1		0		0.1
3	66.3	63.0		0		0.3		0		0.0		0		0.0		0		0.0
4	64.9	61.9		0		0.1		0		0.0		0		0.0		0		0.0
5	63.9	61.3		0		0.1		0		0.0		0		0.0		0		0.0
6	63.2	61.0		0		0.0		0		0.0		0		0.0		0		0.0
7	63.0	60.8		0		3.8		0		0.0		0		0.0		0		0.0
8	63.4	61.4		0		19.8		0		9.9		0		0.0		0		10.0
9	64.7	61.8		0		25.6		0		20.4		0		0.0		0		20.4
10	66.6	62.1		0		26.8		0		20.2		0		2.7		0		20.2
11	69.1	62.9		0		27.1		0		22.2		0		4.5		0		22.2
12	71.8	63.7		0		27.4		0		22.2		0		5.1		0		22.2
13	74.5	65.5		0		24.4		0		19.5		0		6.8		0		19.5
14	77.0	67.1		0		29.5		0		24.9		0		8.1		0		24.9
15	78.9	68.2		0		30.1		0		25.0		0		7.5		0		25.0
16	80.2	68.6		0		28.7		0		24.6		0		6.8		0		24.6
17	80.6	68.5		0		22.6		0		19.6		0		5.8		0		19.6
18	80.4	68.9		0		12.1		0		10.5		0		4.0		0		10.5
19	79.7	70.0		0		5.1		0		3.9		0		4.0		0		3.9
20	78.7	71.2		0		4.4		0		3.6		0		3.6		0		3.6
21	77.3	71.6		0		3.6		0		3.0		0		3.0		0		3.0
22	75.6	70.5		0		2.7		0		2.2		0		2.2		0		2.2
23	73.7	69.4		0		2.1		0		1.5		0		1.5		0		1.5
24	71.8	67.7		0		1.5		0		0.7		0		0.7		0		0.7

October			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----			
Hour	OADB	OAWB	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton	Htg	Btuh	Clg	Ton
1	54.8	51.3		0		0.0		0		0.0		0		0.0		0		0.0
2	52.9	49.6		0		0.0		0		0.0		0		0.0		0		0.0
3	51.2	48.2		0		0.0		0		0.0		0		0.0		0		0.0
4	49.8	47.2		0		0.0		0		0.0		0		0.0		0		0.0
5	48.8	46.2		0		0.0		0		0.0		0		0.0		0		0.0
6	48.2	45.7		0		0.0		0		0.0		0		0.0		0		0.0
7	47.9	45.6		0		0.0		0		0.0		0		0.0		0		0.0
8	48.5	46.2		-38		0.7		0		0.7		0		0.0		0		0.7
9	50.3	47.3		0		15.4		0		4.7		0		0.0		-1,642		4.7
10	52.9	48.7		0		20.3		0		15.1		0		0.0		0		15.1
11	56.2	49.9		0		21.3		0		16.6		0		0.0		0		15.3
12	59.6	51.5		0		21.9		0		18.0		0		0.1		0		16.5
13	62.9	53.5		0		19.4		0		14.7		0		0.1		0		14.5
14	65.5	55.2		0		24.0		0		18.6		0		0.1		0		18.6
15	67.3	56.3		0		24.0		0		19.1		0		0.1		0		19.2
16	67.9	56.6		0		22.5		0		18.7		0		0.7		0		18.8
17	67.7	56.4		0		15.5		0		13.2		0		0.2		0		13.2
18	67.0	56.6		0		7.4		0		5.6		0		0.1		0		5.6
19	66.0	57.6		0		0.8		0		0.1		0		0.1		0		0.1
20	64.6	57.9		0		0.3		0		0.1		0		0.1		0		0.1
21	62.9	57.3		0		0.1		0		0.1		0		0.1		0		0.1
22	61.0	56.0		0		0.1		0		0.0		0		0.0		0		0.0
23	59.0	54.8		0		0.0		0		0.0		0		0.0		0		0.0
24	56.9	53.0		0		0.0		0		0.0		0		0.0		0		0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M358, BASELINE

November			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	46.9	44.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	45.5	42.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	44.6	41.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	44.4	42.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	44.8	42.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	45.9	43.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	47.8	46.0	0	0.7	0	0.7	0	0.0	0	0.0	0	0.0
9	50.2	48.0	0	0.9	0	0.9	0	0.0	0	0.0	0	0.7
10	52.9	49.9	0	0.9	0	0.9	0	0.0	0	0.0	0	0.9
11	55.8	51.1	0	1.0	0	0.9	0	0.0	0	0.0	0	0.9
12	58.5	52.0	0	1.0	0	0.9	0	0.0	0	0.0	0	0.9
13	60.9	52.5	0	0.8	0	0.7	0	0.1	0	0.1	0	0.9
14	62.8	53.4	0	1.0	0	0.9	0	0.1	0	0.1	0	0.7
15	64.0	53.8	0	1.0	0	1.0	0	0.1	0	0.1	0	0.9
16	64.4	53.9	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
17	64.1	53.7	0	0.8	0	0.8	0	0.1	0	0.1	0	1.0
18	63.2	53.7	0	0.4	0	0.4	0	0.1	0	0.1	0	0.8
19	61.8	54.2	0	0.1	0	0.1	0	0.1	0	0.1	0	0.4
20	60.0	53.6	0	0.1	0	0.0	0	0.0	0	0.0	0	0.1
21	57.9	52.7	0	0.1	0	0.0	0	0.0	0	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	53.2	49.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	50.8	47.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

December			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	0	0.0	0	0.0	0	0.0	0	0.0	-5,027	0
2	37.1	35.1	0	0.0	0	0.0	0	0.0	0	0.0	-5,351	0
3	37.4	35.5	0	0.0	0	0.0	0	0.0	0	0.0	-28,336	0.0
4	38.1	36.2	0	0.0	0	0.0	0	0.0	0	0.0	-38,360	0.0
5	39.3	37.6	0	0.0	0	0.0	0	0.0	0	0.0	-37,694	0.0
6	40.9	39.2	0	0.0	0	0.0	0	0.0	-2,146	0.0	-36,613	0.0
7	42.7	41.2	0	0.0	0	0.0	0	0.0	-5,461	0.0	-36,297	0.0
8	44.7	43.1	0	0.7	0	0.6	0	0.0	-5,147	0.0	0	0.6
9	46.8	45.3	0	0.9	0	0.9	0	0.0	-3,933	0.0	0	0.9
10	48.8	47.0	0	0.9	0	0.9	0	0.0	-2,409	0.0	0	0.9
11	50.7	48.1	0	0.9	0	0.9	0	0.0	-1,133	0.0	0	0.9
12	52.2	48.8	0	0.9	0	0.9	0	0.0	-384	0.0	0	0.9
13	53.4	49.2	0	0.7	0	0.7	0	0.0	0	0.0	0	0.7
14	54.1	49.2	0	1.0	0	0.9	0	0.1	0	0.1	0	0.9
15	54.4	48.9	0	1.0	0	1.0	0	0.1	0	0.1	0	1.0
16	54.0	48.2	0	1.0	0	1.0	0	0.1	-718	0.1	0	1.0
17	53.0	47.3	0	0.8	0	0.8	0	0.1	-1,133	0.1	0	0.8
18	51.4	46.3	0	0.4	0	0.4	0	0.1	-1,355	0.1	0	0.4
19	49.3	45.4	0	0.1	0	0.0	0	0.0	-1,738	0.0	0	0.0
20	47.0	43.5	0	0.0	0	0.0	0	0.0	-2,262	0.0	0	0.0
21	44.5	41.5	0	0.0	0	0.0	0	0.0	-3,020	0.0	0	0.0
22	42.2	39.3	0	0.0	0	0.0	0	0.0	-3,634	0.0	0	0.0
23	40.1	37.6	0	0.0	0	0.0	0	0.0	-4,114	0.0	0	0.0
24	38.5	36.2	0	0.0	0	0.0	0	0.0	-4,457	0.0	0	0.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	12,176	49	41	1
Feb	11,109	49	45	1
March	12,471	49	1	0
April	11,097	50	0	0
May	21,829	104	0	0
June	25,614	112	0	0
July	23,633	110	0	0
Aug	25,633	111	0	0
Sept	20,978	108	0	0
Oct	17,746	94	0	0
Nov	11,027	49	0	0
Dec	11,271	49	10	0
Total	204,585	112	97	1

Building Energy Consumption = 43,947 (Btu/Sq Ft/Year)
 Source Energy Consumption = 130,677 (Btu/Sq Ft/Year)

Floor Area = 16,110 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, BASELINE

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	Monthly Consumption												Total
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	
0	LIGHTS													
	ELEC	7457	6745	8053	7121	7755	7717	7159	8053	7121	7755	7121	7159	89,217
	PK	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2
1	MISC LD													
	ELEC	3548	3209	3832	3388	3690	3671	3406	3832	3388	3690	3388	3406	42,448
	PK	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3
2	MISC LD													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	MISC LD													
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD													
	P HOTH2O	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ1121S													
			AIR-CLD RECIP 20-35 TONS											
	ELEC	0	0	0	0	3809	5798	5366	5659	4041	2220	0	0	26,893
	PK	0.0	0.0	0.0	0.0	25.7	31.4	30.4	30.5	28.0	18.0	0.0	0.0	31.4
1	EQ5200													
			CONDENSER FANS											
	ELEC	0	0	0	0	449	733	686	715	499	204	0	0	3,285
	PK	0.0	0.0	0.0	0.0	3.1	3.5	3.5	3.5	3.3	2.5	0.0	0.0	3.5
1	EQ5001													
			CHILLED WATER PUMP C.V.											
	ELEC	0	0	0	0	1182	1449	1355	1355	1058	527	0	0	6,925
	PK	0.0	0.0	0.0	0.0	2.3	2.3	2.3	2.3	2.3	2.3	0.0	0.0	2.3
1	EQ5313													
			CONTROLS											
	ELEC	0	0	0	0	154	189	177	177	138	69	0	0	903
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3
2	EQ1161													
			AIR-CLD COND COMP <15 TONS											
	ELEC	0	0	0	0	446	756	692	726	516	242	0	0	3,378
	PK	0.0	0.0	0.0	0.0	3.6	3.9	3.8	3.8	3.7	3.3	0.0	0.0	3.9

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M358, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 112.1 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)
Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	37.5	33.40
2	EQ1161	AIR-CLD COND COMP <15 TONS	4.6	4.09
3	EQ1161	AIR-CLD COND COMP <15 TONS	2.1	1.86
Sub Total			44.1	39.35
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	13.7	12.26
2		SUMMATION OF FAN ELECTRICAL DEMAND	4.6	4.14
3		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	1.69
4		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.14
Sub Total			20.5	18.24
Sub Total			0.0	0.00
Miscellaneous				
Lights			32.2	28.74
Base Utilities			0.0	0.00
Misc Equipment			15.3	13.67
Sub Total			47.5	42.41
Grand Total			112.1	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M358, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 16,110
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	285.2	9,738.3	1.5	13,171.0	0.8
Primary Cooling					
Compressor	33,486.5	0.0	16.1	342,902.2	21.8
Tower/Cond Fans	3,850.6	0.0	1.9	39,430.2	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,838.2	0.0	1.9	39,303.2	2.5
Auxiliary					
Supply Fans	23,857.4	0.0	11.5	244,300.4	15.5
Circulation Pumps	7,602.1	0.0	3.7	77,845.6	5.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	31,459.5	0.0	15.2	322,146.1	20.5
Lighting	89,217.2	0.0	43.0	913,585.9	56.7
Receptacle	42,447.8	0.0	20.5	434,666.1	27.0
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	204,584.9	9,738.3	100.0	2,105,204.5	131.9

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M358, ECO#2

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	12,984	49	152	1
Feb	11,773	49	138	1
March	12,870	49	35	1
April	11,097	50	0	0
May	20,494	107	0	0
June	25,929	113	0	0
July	23,779	111	0	0
Aug	25,723	111	0	0
Sept	20,932	110	0	0
Oct	18,131	96	0	0
Nov	11,151	49	10	1
Dec	11,836	49	75	1
Total	206,699	113	411	1

Building Energy Consumption = 46,339 (Btu/Sq Ft/Year)
Source Energy Consumption = 134,067 (Btu/Sq Ft/Year)

Floor Area = 16,110 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, ECO#2

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	Monthly Consumption												Total	
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec		
0	LIGHTS														
	ELEC	7457	6745	8053	7121	7755	7717	7159	8053	7121	7755	7121	7159	89,217	
	PK	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	
1	MISC LD														
	ELEC	3548	3209	3832	3388	3690	3671	3406	3832	3388	3690	3388	3406	42,448	
	PK	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	
2	MISC LD														
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
3	MISC LD														
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
4	MISC LD														
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
5	MISC LD														
	P HOTH2O	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
6	MISC LD														
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1	EQ1121S														
	ELEC	0	0	0	0	3267	6041	5470	5783	4047	1970	0	0	26,577	
	PK	0.0	0.0	0.0	0.0	27.0	31.6	30.4	30.5	29.6	19.0	0.0	0.0	31.6	
1	EQ5200														
	ELEC	0	0	0	0	404	763	701	732	502	184	0	0	3,285	
	PK	0.0	0.0	0.0	0.0	3.2	3.5	3.5	3.5	3.4	2.6	0.0	0.0	3.5	
1	EQ5001														
	ELEC	0	0	0	0	895	1311	1283	1212	1035	455	0	0	6,192	
	PK	0.0	0.0	0.0	0.0	2.3	2.3	2.3	2.3	2.3	2.3	0.0	0.0	2.3	
1	EQ5313														
	ELEC	0	0	0	0	117	171	167	158	135	59	0	0	808	
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3	
2	EQ1161														
	ELEC	0	0	0	0	433	774	699	733	512	218	0	0	3,368	
	PK	0.0	0.0	0.0	0.0	3.7	4.0	3.9	3.9	3.8	3.3	0.0	0.0	4.0	

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, ECO#2

2	EQ5200		CONDENSER FANS											
	ELEC	0	0	0	0	41	77	71	73	50	16	0	0	327
	PK	0.0	0.0	0.0	0.0	0.3	0.4	0.4	0.4	0.3	0.2	0.0	0.0	0.4
2	EQ5303		CONTROLS											
	ELEC	0	0	0	0	114	163	164	163	123	50	0	0	777
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3
3	EQ1161		AIR-CLD COND COMP <15 TONS											
	ELEC	222	204	269	258	301	332	303	329	277	267	234	219	3,215
	PK	1.3	1.3	1.3	1.4	1.5	1.6	1.6	1.6	1.5	1.4	1.3	1.3	1.6
3	EQ5200		CONDENSER FANS											
	ELEC	10	8	14	18	26	33	30	32	26	17	14	11	240
	PK	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.2
3	EQ5303		CONTROLS											
	ELEC	103	96	160	198	223	216	223	223	216	193	156	110	2,118
	PK	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
1	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	651	683	208	0	2058	3147	2722	2956	2352	2444	62	406	17,690
	PK	5.3	5.2	3.5	0.0	13.8	13.8	13.8	13.8	13.8	13.8	3.0	4.2	13.8
2	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	159	81	0	0	795	999	909	954	754	496	0	10	5,158
	PK	1.9	1.9	0.0	0.0	4.8	4.8	4.8	4.8	4.6	4.1	0.0	1.5	4.8
3	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	100	90	20	0	257	400	352	371	280	198	6	64	2,138
	PK	0.7	0.7	0.5	0.0	1.9	1.9	1.8	1.9	1.8	1.9	0.4	0.5	1.9
4	HIEFF-FC		HIGH EFFICIENCY FAN COIL											
	ELEC	119	107	119	115	119	115	119	119	115	119	115	119	1,397
	PK	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
1	EQ2001		GAS FIRE TUBE HOT WATER											
	GAS	152	138	35	0	0	0	0	0	0	0	10	75	411
	PK	1.2	1.2	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	1.0	1.2
1	EQ5020		HEAT WATER CIRC. PUMP C.V.											
	ELEC	424	379	134	0	0	0	0	0	0	0	38	229	1,205
	PK	1.6	1.6	1.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.6	1.6	1.6
1	EQ5240		BOILER FORCED DRAFT FAN											
	ELEC	58	52	18	0	0	0	0	0	0	0	5	31	164
	PK	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.2
1	EQ5307		BOILER CONTROLS											
	ELEC	133	118	42	0	0	0	0	0	0	0	12	72	376
	PK	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M358, ECO#2

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 112.6 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	37.7	33.47
2	EQ1161	AIR-CLD COND COMP <15 TONS	4.7	4.17
3	EQ1161	AIR-CLD COND COMP <15 TONS	2.1	1.85
Sub Total			44.5	39.49
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	13.8	12.22
2		SUMMATION OF FAN ELECTRICAL DEMAND	4.8	4.23
3		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	1.69
4		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.14
Sub Total			20.6	18.28
Sub Total			0.0	0.00
Miscellaneous				
	Lights		32.2	28.61
	Base Utilities		0.0	0.00
	Misc Equipment		15.3	13.61
Sub Total			47.5	42.23
Grand Total			112.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M358, ECO#2

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 16,110
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	540.6	41,051.7	5.7	48,747.6	3.1
Primary Cooling					
Compressor	33,160.9	0.0	15.2	339,568.5	21.6
Tower/Cond Fans	3,851.9	0.0	1.8	39,444.0	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,702.3	0.0	1.7	37,911.6	2.4
Auxiliary					
Supply Fans	26,382.5	0.0	12.1	270,157.1	17.2
Circulation Pumps	7,396.4	0.0	3.4	75,739.3	4.8
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	33,778.9	0.0	15.4	345,896.4	22.0
Lighting	89,217.2	0.0	40.8	913,585.9	56.7
Receptacle	42,447.8	0.0	19.4	434,666.1	27.0
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	206,699.5	41,051.7	100.0	2,159,820.0	135.3

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, ECO#3

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	12,176	49	41	1
Feb	11,109	49	45	1
March	12,471	49	1	0
April	11,097	50	0	0
May	21,836	104	0	0
June	25,614	112	0	0
July	23,633	110	0	0
Aug	25,633	111	0	0
Sept	20,978	108	0	0
Oct	17,746	94	0	0
Nov	11,027	49	0	0
Dec	11,271	49	10	0
Total	204,591	112	97	1

Building Energy Consumption = 43,949 (Btu/Sq Ft/Year)
 Source Energy Consumption = 130,681 (Btu/Sq Ft/Year)

Floor Area = 16,110 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, ECO#3

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	----- Monthly Consumption -----												Total
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	
0	LIGHTS													
	ELEC	7457	6745	8053	7121	7755	7717	7159	8053	7121	7755	7121	7159	89,217
	PK	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2
1	MISC LD													
	ELEC	3548	3209	3832	3388	3690	3671	3406	3832	3388	3690	3388	3406	42,448
	PK	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3
2	MISC LD													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	MISC LD													
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD													
	P HOH2O	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ1121S													
			AIR-CLD RECIP 20-35 TONS											
	ELEC	0	0	0	0	3812	5798	5365	5659	4041	2221	0	0	26,896
	PK	0.0	0.0	0.0	0.0	25.7	31.4	30.4	30.5	28.0	18.0	0.0	0.0	31.4
1	EQ5200													
			CONDENSER FANS											
	ELEC	0	0	0	0	449	733	686	715	499	204	0	0	3,285
	PK	0.0	0.0	0.0	0.0	3.0	3.5	3.5	3.5	3.3	2.5	0.0	0.0	3.5
1	EQ5001													
			CHILLED WATER PUMP C.V.											
	ELEC	0	0	0	0	1182	1449	1355	1355	1058	527	0	0	6,925
	PK	0.0	0.0	0.0	0.0	2.3	2.3	2.3	2.3	2.3	2.3	0.0	0.0	2.3
1	EQ5313													
			CONTROLS											
	ELEC	0	0	0	0	154	189	177	177	138	69	0	0	903
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3
2	EQ1161													
			AIR-CLD COND COMP <15 TONS											
	ELEC	0	0	0	0	446	756	692	726	516	242	0	0	3,379
	PK	0.0	0.0	0.0	0.0	3.6	3.9	3.8	3.8	3.7	3.3	0.0	0.0	3.9

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M358, ECO#3

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 112.1 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
----------------------	------------------------	-----------------------	---------------------------	--------------------------

Cooling Equipment

1	EQ1121S	AIR-CLD RECIP 20-35 TONS	37.5	33.40
2	EQ1161	AIR-CLD COND COMP <15 TONS	4.6	4.08
3	EQ1161	AIR-CLD COND COMP <15 TONS	2.1	1.86

Sub Total 44.1 39.35

Sub Total 0.0 0.00

Air Moving Equipment

1		SUMMATION OF FAN ELECTRICAL DEMAND	13.7	12.26
2		SUMMATION OF FAN ELECTRICAL DEMAND	4.6	4.14
3		SUMMATION OF FAN ELECTRICAL DEMAND	1.9	1.69
4		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.14

Sub Total 20.5 18.24

Sub Total 0.0 0.00

Miscellaneous

Lights			32.2	28.74
Base Utilities			0.0	0.00
Misc Equipment			15.3	13.67
Sub Total			47.5	42.41

Grand Total 112.1 100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M358, ECO#3

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 16,110
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	285.2	9,740.7	1.5	13,173.5	0.8
Primary Cooling					
Compressor	33,489.8	0.0	16.1	342,936.1	21.8
Tower/Cond Fans	3,850.8	0.0	1.9	39,432.0	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,838.2	0.0	1.9	39,303.2	2.5
Auxiliary					
Supply Fans	23,860.4	0.0	11.5	244,331.1	15.5
Circulation Pumps	7,602.1	0.0	3.7	77,845.6	5.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	31,462.5	0.0	15.2	322,176.7	20.5
Lighting	89,217.2	0.0	43.0	913,585.9	56.7
Receptacle	42,447.8	0.0	20.5	434,666.1	27.0
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	204,591.3	9,740.7	100.0	2,105,273.5	131.9

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M358, ECO#12

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	11,506	56	16	2
Feb	10,386	56	12	2
March	12,279	49	0	0
April	10,875	50	0	0
May	18,537	91	0	0
June	19,544	98	0	0
July	17,676	96	0	0
Aug	19,792	96	0	0
Sept	16,182	95	0	0
Oct	15,214	89	0	0
Nov	10,817	49	0	0
Dec	10,887	49	2	1
Total	173,695	98	29	2

Building Energy Consumption = 36,981 (Btu/Sq Ft/Year)
Source Energy Consumption = 110,598 (Btu/Sq Ft/Year)

Floor Area = 16,110 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M358, ECO#12

----- EQUIPMENT ENERGY CONSUMPTION -----

Ref Num	Equip Code	Monthly Consumption												Total	
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec		
0	LIGHTS														
	ELEC	7457	6745	8053	7121	7755	7717	7159	8053	7121	7755	7121	7159	89,217	
	PK	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	32.2	
1	MISC LD														
	ELEC	3548	3209	3832	3388	3690	3671	3406	3832	3388	3690	3388	3406	42,448	
	PK	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	
2	MISC LD														
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
3	MISC LD														
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
4	MISC LD														
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
5	MISC LD														
	P HOTW20	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
6	MISC LD														
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
1	EQ1121S														
	ELEC	0	0	0	0	2451	2507	2076	2303	1547	875	0	0	11,759	
	PK	0.0	0.0	0.0	0.0	19.4	20.4	18.8	19.2	18.6	13.5	0.0	0.0	20.4	
1	EQ5200														
	ELEC	0	0	0	0	291	338	285	313	208	87	0	0	1,522	
	PK	0.0	0.0	0.0	0.0	2.5	3.5	2.4	2.4	2.4	1.9	0.0	0.0	3.5	
1	EQ5001														
	ELEC	0	0	0	0	607	566	483	538	442	297	0	0	2,933	
	PK	0.0	0.0	0.0	0.0	2.3	2.3	2.3	2.3	2.3	2.3	0.0	0.0	2.3	
1	EQ5313														
	ELEC	0	0	0	0	79	74	63	70	58	39	0	0	382	
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3	
2	EQ1161														
	ELEC	0	0	0	0	110	307	267	261	134	34	0	0	1,113	
	PK	0.0	0.0	0.0	0.0	2.4	2.8	2.7	2.7	2.6	2.3	0.0	0.0	2.8	

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M358, ECO#12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 98.5 (kW)
Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1121S	AIR-CLD RECIP 20-35 TONS	26.4	26.84
2	EQ1161	AIR-CLD COND COMP <15 TONS	3.3	3.40
3	EQ1161	AIR-CLD COND COMP <15 TONS	2.1	2.11
Sub Total			31.9	32.35
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	12.6	12.76
2		SUMMATION OF FAN ELECTRICAL DEMAND	4.5	4.61
3		SUMMATION OF FAN ELECTRICAL DEMAND	1.8	1.84
4		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.16
Sub Total			19.1	19.38
Sub Total			0.0	0.00
Miscellaneous				
	Lights		32.2	32.71
	Base Utilities		0.0	0.00
	Misc Equipment		15.3	15.56
Sub Total			47.5	48.27
Grand Total			98.5	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M358, ECO#12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 16,110
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	23.5	2,938.0	0.5	3,333.7	0.2
Primary Cooling					
Compressor	15,685.0	0.0	9.0	160,614.4	10.2
Tower/Cond Fans	1,841.9	0.0	1.1	18,860.9	1.2
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,470.6	0.0	0.8	15,059.0	1.0
Auxiliary					
Supply Fans	20,022.1	0.0	11.5	205,026.4	13.0
Circulation Pumps	2,986.9	0.0	1.7	30,585.9	1.9
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	23,009.0	0.0	13.2	235,612.4	15.0
Lighting	89,217.2	0.0	51.1	913,585.9	56.7
Receptacle	42,447.8	0.0	24.3	434,666.1	27.0
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	173,694.9	2,938.0	100.0	1,781,732.2	111.3

BUILDING 500

E M C ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 10-APR-92
 FILE: M500ECO.WK3
 PREPARED BY: R. GERRANS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M500 Area: 27,466 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (Mbtu/yr)
Baseline	522,953	2,949	72,756	244,089	33,103	60,842	142,768	556,507	159	523	2,422
ECO#2	542,100	3,015	72,788	244,089	33,103	60,842	142,768	556,606	161	542	2,441
Savings/(Loss)	(19,148)	(66)	(33)	0	0	0	0	(99)	(2)	(19)	(19)
ECO#3	523,838	2,952	72,771	244,089	33,103	60,842	142,768	556,526	161	524	2,423
Savings/(Loss)	(886)	(3)	(16)	0	0	0	0	(19)	(2)	(1)	(1)
ECO#7	144,716	1,073	63,409	244,089	10,647	60,842	142,768	522,828	159	145	1,929
Savings/(Loss)	378,236	1,876	9,347	0	22,456	0	0	33,679	0	378	493
ECO#12	109,736	1,030	52,295	115,273	10,302	60,842	142,768	382,510	155	110	1,415
Savings/(Loss)	413,217	1,919	20,460	128,816	22,801	0	0	173,997	4	413	1,007
ECO#13	522,953	2,949	85,878	244,089	33,103	60,842	142,768	569,629	113	523	2,467
Savings/(Loss)	0	0	(13,122)	0	0	0	0	(13,122)	46	0	(45)

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany

JOB 3105000
SHEET NO. 1 OF _____
CALCULATED BY RMP DATE 3/2/92
CHECKED BY _____ DATE _____
SCALE _____

Computer Simulation Bldg 500 - Baseline
Bldg Type: Frame/Brick Club Area: 22,917 ft²
ECO: 12, 13 For take off: 2, 3
Take off Bldg: 155

Assumptions

- Heating db = 72°F
- Cooling db = 76°F
- Occupancy: 100 people - max normal
- Equipment: 1st floor: 7.5 Btu/h/ft²
2nd floor: 2.5 Btu/h/ft²
- Lights: 100% on during occupancy
- did not include gas for boiler to heat water for domestic hot water loads

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000

SHEET NO. 2

OF _____

CALCULATED BY RMPA

DATE 3/2/92


CHECKED BY _____

DATE _____

SCALE _____

Comp. Sin Bldg - 500


Wall U-Value ASHRAE Table F 22.4



Material	R-Value
Outside Surface (15 mph wind)	0.17
3/4" Stucco	0.15
12" Conc Block	1.23
2" Rigid Insul.	6.0
1/2" Gyp Board	0.45
Inside Surface (still Air)	<u>0.68</u>
	8.68

$$U = \frac{1}{R} = \frac{1}{8.68} = \boxed{0.12}$$

Roof U-Value - ASHRAE Table F 22.4



Material	R-Value
Outside Air (15 mph wind)	0.17
Tin Roof	0.1
Air Space	1.24
R-30 Insulation	30.0
1/2" Gyp. Board	0.45
Inside Surface (still Air)	<u>0.68</u>
	32.64

$$U = \frac{1}{32.64} = \boxed{0.03}$$

Slab Perimeter Coefficient - ASHRAE Table F 25.5

$$F_2 = \boxed{0.62} \text{ Btu/h / F}\cdot\text{ft}$$

Window U-Value ASHRAE Table F 27.13

- Single Pane, fixed, Al	1.10
- Double, sliding, Al	0.70
- Double, fixed, Al	0.65
- Double, fixed, wood	0.55
- Single, sliding, wood	0.90
- Single, fixed, wood	0.90

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105 000

SHEET NO. 3 OF

CALCULATED BY *RMP* DATE 3/2/92

CHECKED BY _____ DATE _____

SCALE _____

Camp Sim Bldg 500

Windows - Internal shading coefficient - ASHRAE Table 27.25, 26

- Double, clear, fixed 0.53
- Double, opaque 0.35
- Double, clear, curtain 0.52
- Single, opaque 0.39
- Single, shutter 0.74

Lighting - Field Survey

- Room 1 : 12,205 W
- Room 2 : 7,664 W
- Assume 100% on during occupancy

People

- Assume: 100 people

Rm 1: 60
Rm 2: 40

Misc Equip

- Rm 1: Assume 7.5 W/ft²
- Rm 2: Assume 2.7 W/ft²

- kitchen + serving area
- minimum office + ball room

Airflows - from marsh schedule

Rm 1

OA : 4,175 cfm

Rm 2

OA : 1,975 cfm

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 500, McPherson

Baseline Control

Pump

$$D+W \text{ Pump} = \frac{(540) + (0.240 \frac{\text{kg}}{\text{m}^3}) (.20 \text{ m}^3)}{0.235 \text{ of}} = 38 \text{ kW} + 8,760 \frac{\text{Wh}}{\text{hr}} = \boxed{23,103} \text{ kWh}$$


E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB 3105.000
 SHEET NO. 4 OF _____
 CALCULATED BY [Signature] DATE 3/2/92
 CHECKED BY _____ DATE _____
 SCALE _____

Comp Sim Bldg 500

People	Employer	M-F	07:30 - 18:00	20 people
	Employer =	M-F	06:00 - 20:00	10
		F	06:00 - 23:00	
	Service	M-F	11:00 - 19:00	50
		SUN	16:00 - 20:00	
	Bar	M-F	18:00 - 20:00	20
		F	16:00 - 23:00	
	Private	SAT	16:00 - 22:00	50-75 Aug. Mon: 200



7:30-11:00	20
11:00-13:00	70
13:00-16:00	20
16:00-17:00	20
17:00-18:00	70
18:00-19:00	20
19:00-21:00	20



16:00-18:00	50
18:00-20:00	100
20:00-22:00	50

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Month	70	Total Meter kW	Total Meter kWh
JAN	36,600	38,040	42,033
FEB	43,320	41,030	38,148
MAR	35,760	34,460	41,532
APR	31,080	29,110	37,192
MAY	40,600	38,340	48,198
JUN	58,280	57,040	58,510
JUL	67,220	66,440	57,735
AUG	64,840	76,840	59,607
SEPT	74,700	58,440	44,761
OCT	51,600	44,760	40,746
NOV	41,160	27,080	37,800
DEC	40,800	31,280	40,855
TOTAL	<u>539,460</u>	<u>540,160</u>	<u>552,117</u>
	<u>Additional Information</u>		
JAN	3,591		1,451
FEB	4,682		1,325
MAR	2,160		529
APR	1,602		59
MAY	1,030		0
JUN	2,400		0
JUL	265		0
AUG	1,707		0
SEP	1,434		0
OCT	1,868		0
NOV	2,114		383
DEC	<u>2,410</u>		<u>1,002</u>
	<u>28,786</u>		<u>4,749</u>

- did not include DHW loads

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation - Bldg 500, McPherson

ECO #2 - Insulated Glass

Window U-Values - ASHRAE F 27.13

- add 0.36 to all window U-Values

- equivalent of changing from double to single pane wood

Window shading coefficient

- add 0.2 to all shading coefficient

- equivalent to changing from double to single pane

Window Area = 640 ft²

- note: AU was negative ∴ losses were incurred. Converting losses to savings for a/c off.

Electric Savings

Total Electric Savings = -99 kWh/yr

Electric Savings / ft² = 0.15 kWh/ft²

Demand Savings

Peak Demand Savings = 2 kW

Demand Savings / ft² = 3.1 × 10⁻³ kW/ft²

Gas Savings

Total Gas Savings = 19.0 MBtu/yr

Gas Savings / ft² = 0.030 MBtu/ft²

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

- Bldg 500, McPherson

ECO #3 - Weatherstripping + Caulking

assume $\Delta Q = 10 \text{ cfm/Rm}$

Rm 1+2

- present, infiltration = 0 cfm

- change, infiltration = 10 cfm

- total

total infiltration increase = 20 cfm

- note: since ΔQ is an increase in cfm, losses were incurred, losses will be treated as savings for takeoff

Electric Savings

Total Electric Savings = 19 kWh/yr

Electric Savings / cfm = 0.95 kWh/cfm

Demand Savings

Peak Demand Savings = 2 kW

Demand Savings / cfm = 0.10 kW/cfm

Gas Savings

Total Gas Savings = 0.89 MBtu/yr

Gas Savings / cfm = 0.044 MBtu/cfm

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation

Bldg 500, McPherson

ECO # 7 - Control Pump

- Circulation Pump - ETA → yr round savings

- Cycle with load

- Install time clock

on: 06:00 - 21:00 M-F, 15:00 - 22:00 Sat; off otherwise

- Usage: 11,257.0 kWh/yr - from Trac 500

- DHW Pump

- 1/2 HP

- Time clock: on 06:00 - 21:00 M-F, 15:00 - 22:00 Sat, off otherwise

⇒ circ. off = 3,434 kWh

- Savings = $\frac{1/2 \text{ HP} \times (0.745 \text{ kW/HP}) \times (0.80) \times (4934 \text{ kWh})}{(0.764 \text{ off})} = \boxed{620} \text{ kWh/yr}$

- Combined Usage = 11,257.0 - 620 = 10,637 kWh/yr

Electrical Savings

Total Electrical Savings = $\boxed{33,579} \text{ kWh/yr}$

Demand Savings

Peak Demand Savings = $\boxed{0} \text{ kW}$

Gas Savings

Total Gas Savings = $\boxed{378} \text{ Mft}^3/\text{yr}$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bids 500, McPherson

ECO #12 - HVAC Control

- setback thermostat, reset setpoints: 70°F - Heating 78°F cooling
- Turn off fans + pumps: on: 06:00-21:00 M-F + 15:00-22:00 s.a., otherwise off
- reset back temperature
- Circle pumps w/ load
- DHW pumps

Electric Savings

Total Electric Savings = 173,997 kWh/yr

Demand Savings

Peak Demand Savings = 4 kW

Gas Savings

Total Gas Savings = 413 MBtu/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg. 500, McPherson

ECC #13 - Thermal Storage

Discharge Tank : 12:00 - 13:00

Charge Tank : 00:00 - 06:00

Tank Capacity : 204.7 Ton H₂O - From TRACE 600 August+March Cooling
Water Capacity : 34.1 Tons H₂O Use 35 Tons

Demand Savings

Chiller kW/Ton = 1.064 kW/Ton

Peak ton (Aug) = 43.5 ton

Demand Savings = 43.5 * 1.064 = 46.3 = 46 kW

Electrical Addition

Electrical Addition = 13,122 kWh/yr

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM BEAP
 Location: FT MCPHERSON, BLDG 500
 Program User: R. GERRANS

-----CARD 08-- Climatic Information -----

Weather Code	Summer Clearness Number	Winter Clearness Number	Summer Design Dry Bulb	Summer Design Wet Bulb	Winter Design Dry Bulb	Building Orientation	Summer Ground Reflect	Winter Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

1st Month Cooling Simulation	Last Month Cooling Simulation	Peak Cooling Load Hr	1st Month Summer Period	Last Month Summer Period	1st Month Daylight Savings	Last Month Daylight Savings
MAY	OCT					

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG M500, BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone Reference Number	Room Descrip	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1	1	1ST FLOOR	113	182		2		10			
2	2	2ND FLOOR	100	69		5		13			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room Design RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Flag	T'stat Location	Mass / No. Hrs	Carpet On Average Floor
1	76		CLG	72			HTG				
2	76		CLG	72			HTG				

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	113	113	.03	39			
2	1	YES			.03	39			

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
M1	1		10	.12	75				
1	1	93				0			
1	2	131	3			0			
1	3	100				270			
1	4	151				180			
1	5	53				90			
1	6	19				90			
1	7	63				180			
1	8	39				90			
M2	1		14						
2	1	11				0			
2	2	11				0			
2	3	23				0			
2	4	11				0			
2	5	11				0			
2	6	40				270			
2	7	19				0			
2	8	59				270			
2	9	82				180			
2	10	99				90			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
M1	1					1.0					
1	1	5.4	4.6	5	.55						
1	2										
1	3	9.8	4.3	2	.98						
1	4										
1	5	25.7	4.8	1	1.1						
1	6	2.75	1.8	2	.7	.46					
1	7	5.4	4.6	4	.55	.62	5				
1	8										
2	1	1.5	3.7	1	.7	.35					
2	2	2.3	5.6	2	.9	1					

-----CARD 25-- Wall/Glass Parameters-----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
2	3	1.7	3.8	2	.9	1	3				
2	4	5.2	5.8	1	.7	.58					
2	5	1.7	4.2	1	.7	.58					
2	6	1.7	5.8	1	.9	.39					
2	7	7.9	3.3	1	.98	.74	4				
2	8	7.9	3.3	2	1.1	.74	4				
2	9	7.9	3.3	1	1.1	.74	4				
2	10	1	3.7	1	.7	.35					

-----CARD 26-- Schedules-----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
1	CLUBO	CLUBL	AVAIL	OFF		AVAIL				
2	CLUBO	CLUBL	AVAIL	OFF		AVAIL				

-----CARD 27-- People and Lights-----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights Ret. Air	--- Daylighting Reference Point 1	--- Daylighting Reference Point 2
1	60	PEOPLE	250	200	12205	WATTS					
2	40	PEOPLE	250	200	3664	WATTS					

-----CARD 28-- Miscellaneous Equipment-----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
1	1	MISC EQUIP	7.5	BTUH-SF	CLUBE	ELEC					
2	1	MISC EQUIP	2.5	BTUH-SF	CLUBE	ELEC					

-----CARD 29-- Room Airflows-----

Room Number	-----Ventilation-----				-----Infiltration-----				--Reheat Minimum--	
	-----Cooling-----		-----Heating-----		-----Cooling-----		-----Heating-----		Value	Units
	Value	Units	Value	Units	Value	Units	Value	Units		
1	4175	CFM	4175	CFM						
2	1975	CFM	1975	CFM						

-----CARD 32-- Exposed Floor Parameters-----

Room Number	Exposed Slab			Exposed Floor						
	Floor Number	Perimeter Length	Loss Coefficient	Floor Area	Floor U-Value	Const Type	Temp Flag	Cooling Temp	Heating Temp	Adjacent Room No
1	1	590	.62							

-----CARD 33-- External Shading-----

Shading Type	Glass Height	OVERHANG		Glass Width	VERTICAL FINES					
		Height Above Glass	Projection Out		Projection Left	Projection Out	Projection Right	Right Projection Out	Adjacent Building Flag	
3	3.75	2	21							
4	3.3	0	2.5							
5	4.6	1	3							

----- System Section Alternative #1 -----

-----CARD 39-- System Alternative-----

Number	Description
1	BLDG M500, BASELINE

-----CARD 40-- System Type-----

System Set Number	System Type	OPTIONAL VENTILATION SYSTEM					
		Ventil Deck Location	Cooling SADBvh	Heating SADBvh	Cooling Schedule	Heating Schedule	Fan Static Pressure
1	SZ						
2	SZ						

-----CARD 41-- Zone Assignment-----

System Set Number	Ref #1		Ref #2		Ref #3		Ref #4		Ref #5		Ref #6	
	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End
1	1	1										
2	2	2										

-----CARD 42-- Fan SP and Duct Parameters-----

System Set Number	Cool Fan	Heat Fan	Return Fan	Mn Exh Fan	Aux Fan	Rm Exh Fan	Cool Fan Mtr Loc	Return Fan Mtr Loc	Supply Duct Ht Gn	Supply Duct Loc	Return Air Path
	SP	SP	SP	SP	SP	SP	Loc	Loc	Ht Gn	Loc	Path
1	2.5	2.5					SUPPLY			OTHER	DUCTED
2	2.5	2.5					SUPPLY			OTHER	DUCTED


```

-----CARD 44-- System Options -----
System Econ      Econ  Max Pct Direct  Indirect 1st Stage ----- Exhaust Air Heat Recovery -----
Set   Type      On   Outside Evap  Evap  Evap  Fan  --- Effectiveness --- --- Control Method ---
Number Flag      Point Air   Cooling Cooling Cooling  Cycling System      Room      System      Room
1     DRY-BULB  65
2     DRY-BULB  65

```

```

-----CARD 45--- Equipment Schedules -----
System Main          Direct  Indirect Auxiliary Main      Main      Reheat  Mech.  Auxiliary
Set   Cooling          Evap  Evap  Cooling Heating Preheat Reheat  Humidity Heating
Number Coil      Economizer Coil    Coil    Coil    Coil    Coil    Coil    Humidity Coil
1     CLGC
2     CLGC

```

```

----- Equipment Section Alternative #1 -----

```

```

-----CARD 59-- Equipment Description / TOD Schedules -----
Elec Consump Elec Demand Demand
Alternative Time of Day Time of Day Limit
Number      Schedule      Schedule      Max KW  Alternative Description
1           Schedule      Schedule      BLDG M500, BASELINE

```

```

-----CARD 60--- Cooling Load Assignment-----
Load All Coil Cooling
Asgn Loads To Equipment -Group 1- -Group 2- -Group 3- -Group 4- -Group 5- -Group 6- -Group 7- -Group 8- -Group 9-
Ref Cool Ref Sizing Begin End Begin End Begin End Begin End Begin End Begin End Begin End Begin End
1     1     BLKPLANT  1     2

```

```

-----CARD 62-- Cooling Equipment Parameters -----
Cool Equip Num -----COOLING----- -----HEAT RECOVERY----- Seq Demand
Ref Code Of --Capacity-- --Energy-- --Capacity-- --Energy-- Order Seq Limit
Num Name Units Value Units Value Units Value Units Value Units Num Type Number
1     EQ1122L 1     90.6 TONS

```

```

-----CARD 63-- Cooling Pumps and References -----
Cool ---CHILLED WATER--- ---CONDENSER--- ---HT REC or AUX--- Switch-
Ref Full Load Full Load Full Load Full Load Full Load Full Load over Cold Cooling Misc.
Num Value Units Value Units Value Units Control Storage Tower Access.
1     3.8 KW

```

-----CARD 65-- Heating Load Assignment -----

Load	All Coil										
Assignment	Loads To	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-	
Reference	Heating Ref	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End	Begin End
1	1	1	2								

-----CARD 67-- Heating Equipment Parameters -----

Heat Ref	Equip Code	Number Of	HW Pmp Full Ld	Cap'y Value	Units	Energy Rate	Seq Order	Switch over	Hot Strg	Misc. Acc.	Demand Limit	
Number	Name	Units	Value	Units	Value	Units	Number	Control	Strg	Acc.	Cogen	Number
1	EQ2001	1	3.8	KW								

-----CARD 69-- Fan Equipment Parameters -----

System Set	Cooling Fan	Heating Fan	Return Fan	Exhaust Fan	Auxiliary Supply	Room Exhaust	Optional Ventilation
1	EQ4003						
2	EQ4003						

Utility Description Reference Table

Schedules:

AVAIL AVAILABLE (100%)
CLG COOLING TSTAT SCHEDULE
CLGC COOLING COIL SCHEDULE
CLUBE O CLUB EQUIPMENT SCHEDULE
CLUBL O CLUB LIGHTING SCHEDULE
CLUBO O CLUB OCCUPANCY SCHEDULE
HTG HEATING TSTAT SCHEDULE
HTGC HEATING COIL SCHEDULE
OFF ALWAYS OFF

System:

SZ SINGLE ZONE

Equipment:

Cooling:
EQ1122L AIR-CLD RECIP >55 TONS
Heating:
EQ2001 GAS FIRE TUBE HOT WATER
Fan:
EQ4003 FC CENTRIF. FAN C.V.

Schedule Name: AVAIL

Project: AVAILABLE (100)

Location:

Client:

Program User:

Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: CLUBE
Project: O CLUB EQUIPMENT SCHEDULE
Location: FT MCPHERSON & FT GILLEM
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	10
7	25
9	50
10	90
13	50
16	80
17	100
19	50
21	10
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SAT

Hour	Util Percent
0	10
16	75
22	10
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SUN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: CLUBL
Project: 0 CLUB LIGHTING SCHEDULE
Location: FT MCPHERSON & FT GILLEM
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	100
21	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SAT

Hour	Util Percent
0	0
16	100
22	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SUN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: CLUBO
Project: O CLUB OCCUPANCY SCHEDULE
Location: FT MCPHERSON & FT GILLEM
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	20
11	70
13	30
16	70
17	90
18	75
19	30
21	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SAT

Hour	Util Percent
0	0
16	50
18	100
20	50
22	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SUN Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	0	
24		


```
*****  
*****  
**  
**          T R A C E    6 0 0    A N A L Y S I S          **  
**  
**          by              **  
**  
*****  
*****
```

FT MCPHERSON & FT GILLEM BEAP
FT MCPHERSON, BLDG 500

R. GERRANS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 10:11:35 4/ 8/92
Dataset Name: M500-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M500, BASELINE

 SYSTEM SUMMARY
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	SZ	4,175	17,226	17,226	17,226	17,226	0	0
2	SZ	1,975	8,815	8,815	8,815	8,815	0	0
Totals		6,150	26,041	26,041	26,041	26,041	0	0

CAPACITY - ALTERNATIVE 1
 BLDG M500, BASELINE

 SYSTEM SUMMARY
 (Design Capacity Quantities)

System Number	System Type	Cooling				Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Heating				Heating Totals (Btuh)
		Main Capacity (Tons)	Sys. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)				Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	
1	SZ	37.5	0.0	0.0	37.5	-278,400	0	0	0	0	0	0	-278,400
2	SZ	18.5	0.0	0.0	18.5	-201,015	0	0	0	0	0	0	-201,015
Totals		56.1	0.0	0.0	56.1	-479,415	0	0	0	0	0	0	-479,415

The building peaked at hour 13 month 7 with a capacity of 55.2 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M500, BASELINE

 ENGINEERING CHECKS

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/Sq Ft	Cfm/Ton	Sq Ft/Ton	Btuh/Sq Ft	Cfm/Sq Ft	Btuh/Sq Ft	
1	Main	SZ	24.24	0.84	458.8	547.8	21.91	0.84	-13.54	20,566
2	Main	SZ	22.41	1.28	475.8	372.4	32.22	1.28	-29.13	6,900

System 1 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****						CLG SPACE PEAK *****			HEATING COIL PEAK *****			
Peaked at Time ==>						Mo/Hr: 7/13	*	Mo/Hr: 6/18	*	Mo/Hr: 13/ 1		
Outside Air ==>						OADB/WB/HR: 90/ 74/105.0	*	OADB: 92	*	OADB: 22		
Envelope Loads	Space Sens.+Lat. (Btuh)	Ret. Air Sensible (Btuh)	Ret. Air Latent (Btuh)	Net Total (Btuh)	Perct Of Tot (%)	*	Space Sensible (Btuh)	Perct Of Tot (%)	*	Space Peak Space Sens (Btuh)	Coil Peak Tot Sens (Btuh)	Perct Of Tot (%)
Skylite Solr	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Roof Cond	0	19,084	0	19,084	4.24	*	0	0.00	*	0	-17,746	6.37
Glass Solar	18,085	0	0	18,085	4.01	*	18,967	6.65	*	0	0	0.00
Glass Cond	4,979	0	0	4,979	1.11	*	5,606	1.97	*	-18,767	-18,767	6.74
Wall Cond	12,293	2,958	0	15,251	3.39	*	18,753	6.58	*	-24,104	-30,300	10.88
Partition	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0	0	0	0	0.00	*	0	0.00	*	-18,290	-18,290	6.57
Infiltration	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total==>	35,357	22,042	0	57,399	12.74	*	43,326	15.19	*	-61,161	-85,103	30.57
Internal Loads						*			*			
Lights	41,656	0	0	41,656	9.25	*	41,656	14.61	*	0	0	0.00
People	18,900	0	0	18,900	4.19	*	13,500	4.73	*	0	0	0.00
Misc	138,820	0	0	138,820	30.81	*	154,245	54.08	*	0	0	0.00
Sub Total==>	199,376	0	0	199,376	44.25	*	209,401	73.42	*	0	0	0.00
Ceiling Load	22,042	-22,042	0	0	0.00	*	32,469	11.38	*	-23,942	0	0.00
Outside Air	0	0	0	163,147	36.21	*	0	0.00	*	0	-223,922	80.43
Sup. Fan Heat				30,625	6.80	*		0.00	*		30,625	-11.00
Ret. Fan Heat		0	0	0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0	0	0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
Grand Total==>	256,775	0	0	450,547	100.00	*	285,195	100.00	*	-85,103	-278,400	1

-----COOLING COIL SELECTION-----										-----AREAS-----			
	Total Capacity (Tons)	Sens Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total Floor	Glass (sf)	(%)	
Main Clg	37.5	450.5	343.0	17,226	79.5	66.0	78.3	58.9	57.7	72.4	20,566		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	590		
Totals	37.5	450.5									12,769	0	
											Wall	5,573	441

-----HEATING COIL SELECTION-----					-----AIRFLOWS (cfm)-----			-----ENGINEERING CHECKS-----			-----TEMPERATURES (F)-----		
	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type	Cooling	Heating	Clg % OA	24.2	Type	Clg	Htg	
Main Htg	-278.4	17,226	59.9	74.9	Vent	4,175	4,175	Clg Cfm/Sqft	0.84	SADB	60.6	76.6	
Aux Htg	0.0	0	0.0	0.0	Infil	0	0	Clg Cfm/Ton	458.82	Plenum	79.4	68.3	
Preheat	-0.0	17,226	59.9	58.9	Supply	17,226	17,226	Clg Sqft/Ton	547.76	Return	76.0	72.0	
Reheat	0.0	0	0.0	0.0	Mincfm	0	0	Clg Btuh/Sqft	21.91	Ret/OA	79.5	59.9	
Humidif	0.0	0	0.0	0.0	Return	17,226	17,226	No. People	60	Runarnd	76.0	72.0	
Opt Vent	0.0	0	0.0	0.0	Exhaust	4,175	4,175	Htg % OA	24.2	Fn MtrTD	0.4	0.4	
Total	-278.4				Rm Exh	0	0	Htg Cfm/Sqft	0.84	Fn BldTD	0.3	0.3	
					Auxil	0	0	Htg Btuh/Sqft	-13.54	Fn Frict	0.9	0.9	

System 2 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****					CLG SPACE PEAK *****		***** HEATING COIL PEAK *****			
Peaked at Time ==>	Mo/Hr: 8/15				*	Mo/Hr: 6/17	*	Mo/Hr: 13/ 1		
Outside Air ==>	OADB/WB/HR: 92/ 74/105.0				*	OADB: 94	*	OADB: 22		
	Space	Ret. Air	Ret. Air	Net	Perct	Space	Perct	Space Peak	Coil Peak	Perct
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	Sensible	Of Tot	Space Sens	Tot Sens	Of Tot
	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	(Btuh)	(%)	(Btuh)	(Btuh)	(%)
Envelope Loads										
Skylite Solr	0	0		0	0.00	0	0.00	0	0	0.00
Skylite Cond	0	0		0	0.00	0	0.00	0	0	0.00
Roof Cond	0	11,191		11,191	5.03	0	0.00	0	-6,950	3.46
Glass Solar	6,779	0		6,779	3.05	9,570	6.63	0	0	0.00
Glass Cond	3,062	0		3,062	1.38	3,438	2.38	-10,219	-10,219	5.08
Wall Cond	54,679	22,995		77,674	34.94	59,849	41.45	-64,632	-93,589	46.56
Partition	0	0		0	0.00	0	0.00	0	0	0.00
Exposed Floor	0	0		0	0.00	0	0.00	0	0	0.00
Infiltration	0	0		0	0.00	0	0.00	0	0	0.00
Sub Total==>	64,519	34,186		98,706	44.40	72,857	50.46	-74,851	-110,758	55.10
Internal Loads										
Lights	12,505	0		12,505	5.62	12,505	8.66	0	0	0.00
People	5,400			5,400	2.43	7,000	4.85	0	0	0.00
Misc	8,625	0	0	8,625	3.88	13,800	9.56	0	0	0.00
Sub Total==>	26,530	0	0	26,530	11.93	33,305	23.07	0	0	0.00
Ceiling Load	34,186	-34,186		0	0.00	38,213	26.47	-35,907	0	0.00
Outside Air	0	0	0	81,415	36.62	0	0.00	0	-105,927	52.70
Sup. Fan Heat				15,671	7.05		0.00		15,671	-7.80
Ret. Fan Heat		0		0	0.00		0.00		0	0.00
Duct Heat Pkup		0		0	0.00		0.00		0	0.00
OV/UNDR Sizing	0			0	0.00	0	0.00	0	0	0.00
Exhaust Heat		0	0	0	0.00		0.00		0	0.00
Terminal Bypass		0	0	0	0.00		0.00		0	0.00
Grand Total==>	125,236	0	0	222,321	100.00	144,375	100.00	-110,758	-201,015	100.00

-----COOLING COIL SELECTION-----

	Total Capacity (Tons)	Sens. Cap. (Mbh)	Coil Airfl (cfm)	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total		Glass (sf)	(%)
				Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Part		
Main Clg	18.5	222.3	173.0	8,815	79.7	66.0	77.7	59.1	58.0	73.1	6,900		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	0		
Totals	18.5	222.3									6,900		
											0		
											0		
											6,900		0
											5,124		199

-----AREAS-----

-----HEATING COIL SELECTION-----

	Capacity (Mbh)	Coil Airfl (cfm)	Ent Deg F	Lvg Deg F	Type		AIRFLOWS (cfm)		--ENGINEERING CHECKS--			--TEMPERATURES (F)--		
					Cooling	Heating	Cooling	Heating	Clg % OA	22.4	Type	Clg	Htg	
Main Htg	-201.0	8,815	60.8	82.1	Vent	1,975	1,975	Clg Cfm/Sqft	1.28	SADE	60.7	83.7		
Aux Htg	0.0	0	0.0	0.0	Infil	0	0	Clg Cfm/Ton	475.78	Plenum	91.6	55.6		
Preheat	-0.0	8,815	60.8	59.1	Supply	8,815	8,815	Clg Sqft/Ton	372.43	Return	76.0	72.0		
Reheat	0.0	0	0.0	0.0	Return	8,815	8,815	Clg Btuh/Sqft	32.22	Ret/OA	79.7	60.8		
Humidif	0.0	0	0.0	0.0	Mincfm	0	0	No. People	40	Runarnd	76.0	72.0		
Opt Vent	0.0	0	0.0	0.0	Exhaust	1,975	1,975	Htg % OA	22.4	Fn MtrTD	0.4	0.4		
Total	-201.0				Rm Exh	0	0	Htg Cfm/SqFt	1.28	Fn BldTD	0.3	0.3		
					Auxil	0	0	Htg Btuh/SqFt	-29.13	Fn Frict	0.9	0.9		

COOLING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M500, BASELINE

----- AIRFLOW HEAT GAIN AND LOSS -----
 (At time of Coil Peak)

Room Number	Description	Duct Heat Pickup (Btuh)	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Cooling							
						Total (Btuh)	System Exhaust (Cfm)	Room Exhaust (Cfm)	Ducted (Cfm)	Plenum (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)
1	1ST FLOOR	0	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
Zone	1 Total/Ave.	0	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
Zone	1 Block	0	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
System	1 Total/Ave.	0	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
System	1 Block	0	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
2	2ND FLOOR	0	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
Zone	2 Total/Ave.	0	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
Zone	2 Block	0	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
System	2 Total/Ave.	0	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
System	2 Block	0	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815

HEATING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M500, BASELINE

----- AIRFLOW HEAT GAIN AND LOSS -----
 (At time of Coil Peak)

Room Number	Description	Supply Fan Heat (Btuh)	Return Fan Heat (Btuh)	System Exhaust Heat Loss (Btuh)	Total (Btuh)	Heating						
						System Exhaust (Cfm)	Room Exhaust (Cfm)	Ducted (Cfm)	Plenum (Cfm)	Run Around (Cfm)	Corridor (Cfm)	System Return (Cfm)
1	1ST FLOOR	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
Zone	1 Total/Ave.	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
Zone	1 Block	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
System	1 Total/Ave.	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
System	1 Block	30,625	0	0	30,625	4,175	0	17,226	0	0	0	17,226
2	2ND FLOOR	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
Zone	2 Total/Ave.	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
Zone	2 Block	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
System	2 Total/Ave.	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815
System	2 Block	15,671	0	0	15,671	1,975	0	8,815	0	0	0	8,815

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M500, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone	1					
	Dry	Wet	Relat.	Humid.	Enthalpy	Temp.
	Bulb	Bulb	Humid.	Ratio	(Btu/Lb)	Diff.
	(F)	(F)	(%)	(GR)		(F)
Space	76.0	63.2	50.0	69.8	29.2	
Main System						
Return Air Heat Pickup						0.0
Return Fan						0.0
Return Air	76.0	63.2	50.0	69.8	29.2	
Outdoor Air	90.3	73.9	47.0	105.0	38.2	
Return/Outdoor Air Mix	79.5	66.0	49.9	78.3	31.3	
Blow through Fan						0.0
Entering Coil	79.5	66.0	49.9	78.3	31.3	
Leaving Coil	58.9	57.0	89.5	69.3	24.9	
Draw Through Fan						0.7
Duct Frictional Heat						0.9
Supply Duct Heat Gain						0.0
Cold Deck Supply Air	60.6	57.6	84.4	69.3	25.3	
Supply Air	60.6	57.6	84.4	69.3	25.3	
Percent Outside Air		24.24	(%)			
Sensible Heat Ratio (SHR)		0.964				
Percent Supply Air Bypassing Coil		0.00	(%)			
Coil Airflow		17,226	(Cfm)			

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M500, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone	2						
		Dry	Wet	Relat.	Humid.		Temp.
		Bulb	Bulb	Humid.	Ratio	Enthalpy	Diff.
		(F)	(F)	(%)	(GR)	(Btu/Lb)	(F)
Space		76.0	63.2	50.0	69.8	29.2	
Main System							0.0
Return Air Heat Pickup							0.0
Return Fan							
Return Air		76.0	63.2	50.0	69.8	29.2	
Outdoor Air		92.3	74.4	44.2	105.0	38.7	
Return/Outdoor Air Mix		79.7	66.0	49.2	77.7	31.3	
Blow through Fan							0.0
Entering Coil		79.7	66.0	49.2	77.7	31.3	
Leaving Coil		59.1	57.1	89.0	69.3	24.9	
Draw Through Fan							0.7
Duct Frictional Heat							0.9
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		60.7	57.7	83.9	69.3	25.4	
Supply Air		60.7	57.7	83.9	69.3	25.4	
Percent Outside Air			22.41	(%)			
Sensible Heat Ratio (SHR)			0.963				
Percent Supply Air Bypassing Coil			0.00	(%)			
Coil Airflow			8,815	(Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M500, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)									Room Mass (lb/sqft)	Room Capac. (Btu/sqft/F)
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Summr Roof	Wintr Windo	Summr Windo	Wall	Ceil.		
1	1ST FLOOR	0.000	0.620	0.000	0.000	0.030	0.789	0.851	0.120	0.317	26.1	6.54
Zone	1 Total/Ave.	0.000	0.620	0.000	0.000	0.030	0.789	0.851	0.120	0.317	26.1	6.54
System	1 Total/Ave.	0.000	0.620	0.000	0.000	0.030	0.789	0.851	0.120	0.317	26.1	6.54
2	2ND FLOOR	0.000	0.000	0.000	0.000	0.030	0.942	1.025	0.438	0.317	33.6	8.85
Zone	2 Total/Ave.	0.000	0.000	0.000	0.000	0.030	0.942	1.025	0.438	0.317	33.6	8.85
System	2 Total/Ave.	0.000	0.000	0.000	0.000	0.030	0.942	1.025	0.438	0.317	33.6	8.85
Building		0.000	0.620	0.000	0.000	0.030	0.837	0.905	0.276	0.317	28.0	7.12

BUILDING AREAS - ALTERNATIVE 1
 BLDG M500, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate		Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Sk1 /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
		Flr	Rm										
1	1ST FLOOR	1	1	20,566	20,566	0	590	0	0	12,769	441	8	5,152
Zone	1 Total/Ave.				20,566	0	590	0	0	12,769	441	8	5,152
System	1 Total/Ave.				20,566	0	590	0	0	12,769	441	8	5,152
2	2ND FLOOR	1	1	6,900	6,900	0	0	0	0	6,900	199	4	4,925
Zone	2 Total/Ave.				6,900	0	0	0	0	6,900	199	4	4,925
System	2 Total/Ave.				6,900	0	0	0	0	6,900	199	4	4,925
Building					27,466	0	590	0	0	19,669	640	6	10,057

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE 12

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
BLDG M500, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.030 (Btu/Hr/Sq Ft/F)
Overall Wall U-Value = 0.309 (Btu/Hr/Sq Ft/F)
Overall Building U-Value = 0.128 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 1.15 (Btu/Hr/Sq Ft)
Wall Overall Thermal Transfer Value (OTTVw) = 17.91 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M500, BASELINE

Main System 1 SZ SINGLE ZONE

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	1.9	11	337	-13,920	8	136	861.3	0	0	0.0	0	0
5 - 10	3.8	12	373	-27,840	6	110	1,722.7	0	0	0.0	0	0
10 - 15	5.6	7	215	-41,760	8	148	2,584.0	0	0	0.0	0	0
15 - 20	7.5	6	182	-55,680	3	51	3,445.3	0	0	0.0	0	0
20 - 25	9.4	4	130	-69,600	6	100	4,306.6	0	0	0.0	0	0
25 - 30	11.3	5	171	-83,520	6	111	5,168.0	0	0	0.0	0	0
30 - 35	13.1	6	188	-97,440	7	118	6,029.3	0	0	0.0	0	0
35 - 40	15.0	3	92	-111,360	8	147	6,890.6	0	0	0.0	0	0
40 - 45	16.9	4	122	-125,280	6	103	7,751.9	0	0	0.0	0	0
45 - 50	18.8	4	141	-139,200	10	181	8,613.3	0	0	0.0	0	0
50 - 55	20.7	4	129	-153,120	8	139	9,474.6	0	0	0.0	0	0
55 - 60	22.5	4	120	-167,040	6	105	10,335.9	0	0	0.0	0	0
60 - 65	24.4	2	68	-180,960	8	141	11,197.2	0	0	0.0	0	0
65 - 70	26.3	4	140	-194,880	9	160	12,058.6	0	0	0.0	0	0
70 - 75	28.2	6	198	-208,800	2	28	12,919.9	0	0	0.0	0	0
75 - 80	30.0	7	226	-222,720	0	0	13,781.2	0	0	0.0	0	0
80 - 85	31.9	4	133	-236,640	0	0	14,642.5	0	0	0.0	0	0
85 - 90	33.8	2	68	-250,560	0	0	15,503.9	0	0	0.0	0	0
90 - 95	35.7	4	117	-264,480	0	0	16,365.2	0	0	0.0	0	0
95 - 100	37.5	1	43	-278,400	0	0	17,226.5	100	8,760	0.0	0	0
Hours Off	0.0	0	5,567	0	0	6,982	0.0	0	0	0.0	0	8,760

Main System 2 SZ SINGLE ZONE

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.9	7	154	-10,051	3	81	440.7	0	0	0.0	0	0
5 - 10	1.9	7	167	-20,101	6	173	881.5	0	0	0.0	0	0
10 - 15	2.8	4	104	-30,152	8	230	1,322.2	0	0	0.0	0	0
15 - 20	3.7	4	96	-40,203	7	224	1,762.9	0	0	0.0	0	0
20 - 25	4.6	5	111	-50,254	7	217	2,203.7	0	0	0.0	0	0
25 - 30	5.6	4	98	-60,304	4	132	2,644.4	0	0	0.0	0	0
30 - 35	6.5	3	80	-70,355	8	254	3,085.1	0	0	0.0	0	0
35 - 40	7.4	5	118	-80,406	5	163	3,525.9	0	0	0.0	0	0
40 - 45	8.3	7	171	-90,457	4	134	3,966.6	0	0	0.0	0	0
45 - 50	9.3	10	235	-100,507	6	176	4,407.3	0	0	0.0	0	0
50 - 55	10.2	9	206	-110,558	6	195	4,848.1	0	0	0.0	0	0
55 - 60	11.1	6	129	-120,609	9	268	5,288.8	0	0	0.0	0	0
60 - 65	12.0	6	147	-130,660	8	247	5,729.5	0	0	0.0	0	0
65 - 70	13.0	6	151	-140,710	5	162	6,170.3	0	0	0.0	0	0
70 - 75	13.9	5	118	-150,761	5	152	6,611.0	0	0	0.0	0	0
75 - 80	14.8	6	139	-160,812	7	214	7,051.7	0	0	0.0	0	0
80 - 85	15.7	5	120	-170,863	0	0	7,492.5	0	0	0.0	0	0
85 - 90	16.7	0	0	-180,913	0	0	7,933.2	0	0	0.0	0	0
90 - 95	17.6	0	0	-190,964	0	0	8,373.9	0	0	0.0	0	0
95 - 100	18.5	0	0	-201,015	0	0	8,814.7	100	8,760	0.0	0	0
Hours Off	0.0	0	6,416	0	0	5,738	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M500, BASELINE

----- SYSTEM LOAD PROFILE -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	2.8	16	513	-23,971	11	349	1,302.1	0	0	0.0	0	0
5 - 10	5.6	9	303	-47,941	16	483	2,604.1	0	0	0.0	0	0
10 - 15	8.4	4	137	-71,912	7	225	3,906.2	0	0	0.0	0	0
15 - 20	11.2	6	177	-95,883	9	295	5,208.2	0	0	0.0	0	0
20 - 25	14.0	6	186	-119,854	9	269	6,510.3	0	0	0.0	0	0
25 - 30	16.8	7	240	-143,824	9	278	7,812.3	0	0	0.0	0	0
30 - 35	19.6	3	107	-167,795	4	121	9,114.4	0	0	0.0	0	0
35 - 40	22.4	4	130	-191,766	3	94	10,416.5	0	0	0.0	0	0
40 - 45	25.2	3	91	-215,737	5	167	11,718.5	0	0	0.0	0	0
45 - 50	28.0	5	148	-239,707	3	108	13,020.6	0	0	0.0	0	0
50 - 55	30.8	5	154	-263,678	6	177	14,322.6	0	0	0.0	0	0
55 - 60	33.6	2	75	-287,649	5	144	15,624.7	0	0	0.0	0	0
60 - 65	36.4	8	241	-311,620	3	80	16,926.8	0	0	0.0	0	0
65 - 70	39.3	3	82	-335,590	5	145	18,228.8	0	0	0.0	0	0
70 - 75	42.1	5	157	-359,561	6	177	19,530.9	0	0	0.0	0	0
75 - 80	44.9	7	225	-383,532	0	0	20,832.9	0	0	0.0	0	0
80 - 85	47.7	2	74	-407,503	0	0	22,135.0	0	0	0.0	0	0
85 - 90	50.5	3	98	-431,473	0	0	23,437.1	0	0	0.0	0	0
90 - 95	53.3	2	65	-455,444	0	0	24,739.1	0	0	0.0	0	0
95 - 100	56.1	0	0	-479,415	0	0	26,041.2	100	8,760	0.0	0	0
Hours Off	0.0	0	5,557	0	0	5,648	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M500, BASELINE

January		----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton			
1	33.4	30.4	-225,264	0.0	-143,531	0.0	-271,935	0.0	-329,390	0.0	-312,241	0.0									
2	32.1	29.3	-237,216	0.0	-316,492	0.0	-328,273	0.0	-345,384	0.0	-328,311	0.0									
3	31.7	29.3	-246,651	0.0	-335,695	0.0	-335,747	0.0	-352,916	0.0	-335,767	0.0									
4	31.9	29.5	-251,976	0.0	-338,428	0.0	-338,434	0.0	-355,583	0.0	-338,434	0.0									
5	32.6	30.3	-256,564	0.0	-336,321	0.0	-336,321	0.0	-353,472	0.0	-336,321	0.0									
6	33.6	31.3	-255,123	0.0	-330,204	0.0	-330,204	0.0	-347,354	0.0	-330,204	0.0									
7	35.0	32.6	-249,846	0.0	-319,249	0.0	-319,249	0.0	-336,397	0.0	-319,249	0.0									
8	36.6	34.4	-124,367	0.0	-203,673	0.0	-288,558	0.0	-305,708	0.0	-203,673	0.0									
9	38.5	36.3	-70,248	0.0	-164,088	0.0	-248,972	0.0	-266,121	0.0	-164,088	0.0									
10	40.4	37.7	-22,402	0.0	-83,342	0.0	-211,102	0.0	-228,251	0.0	-83,342	0.0									
11	42.3	38.7	0	0.0	-44,218	0.0	-184,201	0.0	-201,351	0.0	-44,218	0.0									
12	44.2	39.6	0	0.0	-30,756	0.0	-163,469	0.0	-180,619	0.0	-30,756	0.0									
13	45.8	40.5	0	0.0	-25,639	0.0	-144,203	0.0	-161,352	0.0	-25,639	0.0									
14	47.2	41.1	0	0.0	-28,265	0.0	-123,248	0.0	-140,397	0.0	-28,265	0.0									
15	48.2	41.6	-2,370	0.0	-20,378	0.0	-105,384	0.0	-122,533	0.0	-20,378	0.0									
16	48.9	41.8	0	0.0	-15,965	0.0	-94,366	0.0	-111,515	0.0	-15,965	0.0									
17	49.1	41.9	0	0.0	-15,980	0.0	-18,842	0.0	-129,803	0.0	-15,980	0.0									
18	48.7	41.9	0	0.0	-27,960	0.0	-36,273	0.0	-152,795	0.0	-27,960	0.0									
19	47.4	41.7	0	0.0	-43,926	0.0	-45,738	0.0	-177,967	0.0	-43,926	0.0									
20	45.5	40.5	0	0.0	-67,671	0.0	-56,359	0.0	-201,152	0.0	-67,671	0.0									
21	43.1	38.9	0	0.0	-79,353	0.0	-73,039	0.0	-228,818	0.0	-79,353	0.0									
22	40.4	36.7	-64,385	0.0	-112,592	0.0	-83,875	0.0	-256,150	0.0	-112,592	0.0									
23	37.7	34.3	-97,098	0.0	-122,710	0.0	-122,710	0.0	-282,287	0.0	-122,710	0.0									
24	35.3	32.3	-103,611	0.0	-134,390	0.0	-134,390	0.0	-308,644	0.0	-134,390	0.0									

February		----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton			
1	37.5	34.5	-184,299	0.0	-128,249	0.0	-217,028	0.0	-267,384	0.0	-275,979	0.0									
2	36.0	33.0	-235,379	0.0	-259,039	0.0	-292,639	0.0	-309,758	0.0	-292,650	0.0									
3	34.7	31.8	-242,692	0.0	-305,891	0.0	-305,902	0.0	-323,069	0.0	-305,931	0.0									
4	33.6	30.9	-248,619	0.0	-319,707	0.0	-319,724	0.0	-336,875	0.0	-319,724	0.0									
5	32.8	30.1	-251,136	0.0	-328,988	0.0	-328,988	0.0	-346,138	0.0	-328,988	0.0									
6	32.2	29.8	-250,466	0.0	-336,455	0.0	-336,455	0.0	-353,604	0.0	-336,455	0.0									
7	32.1	29.6	-244,014	0.0	-337,249	0.0	-337,249	0.0	-354,397	0.0	-337,249	0.0									
8	32.5	30.3	-110,894	0.0	-227,464	0.0	-312,349	0.0	-329,500	0.0	-227,464	0.0									
9	33.9	31.6	-61,057	0.0	-198,421	0.0	-283,305	0.0	-300,454	0.0	-198,421	0.0									
10	36.0	33.0	-18,973	0.0	-123,099	0.0	-250,859	0.0	-268,009	0.0	-123,099	0.0									
11	38.5	34.8	0	0.0	-61,704	0.0	-223,788	0.0	-240,938	0.0	-61,704	0.0									
12	41.3	36.5	0	0.0	-46,699	0.0	-196,575	0.0	-213,726	0.0	-46,699	0.0									
13	43.8	38.1	0	0.0	-39,751	0.0	-170,696	0.0	-187,844	0.0	-39,751	0.0									
14	45.9	39.5	0	0.0	-40,900	0.0	-145,349	0.0	-162,498	0.0	-40,900	0.0									
15	47.2	40.4	-2,045	0.0	-29,925	0.0	-120,155	0.0	-137,304	0.0	-29,925	0.0									
16	47.7	40.6	0	0.0	-23,270	0.0	-108,453	0.0	-125,604	0.0	-23,270	0.0									
17	47.5	40.2	0	0.0	-18,004	0.0	-20,867	0.0	-134,702	0.0	-18,004	0.0									
18	47.0	39.8	0	0.0	-28,645	0.0	-36,957	0.0	-163,935	0.0	-28,645	0.0									
19	46.2	39.9	0	0.0	-45,749	0.0	-47,562	0.0	-185,869	0.0	-45,749	0.0									
20	45.1	39.7	0	0.0	-69,999	0.0	-58,687	0.0	-205,974	0.0	-69,999	0.0									
21	43.8	39.2	0	0.0	-77,869	0.0	-71,557	0.0	-223,721	0.0	-77,869	0.0									
22	42.3	38.3	-58,480	0.0	-106,369	0.0	-77,651	0.0	-240,938	0.0	-106,369	0.0									
23	40.7	37.2	-97,311	0.0	-114,156	0.0	-114,156	0.0	-258,989	0.0	-114,156	0.0									
24	39.1	35.8	-103,610	0.0	-121,943	0.0	-121,943	0.0	-277,039	0.0	-121,943	0.0									

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M500, BASELINE

March		----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton					
1	45.4	41.6	-70,146	0.0	-44,400	0.0	-91,003	0.0	-92,729	0.0	-189,308	0.0									
2	43.3	39.7	-142,388	0.0	-102,056	0.0	-102,052	0.0	-103,776	0.0	-212,855	0.0									
3	41.6	38.6	-152,352	0.0	-110,044	0.0	-176,026	0.0	-162,260	0.0	-232,394	0.0									
4	40.6	37.5	-162,534	0.0	-152,302	0.0	-244,174	0.0	-261,348	0.0	-244,174	0.0									
5	40.2	37.3	-167,122	0.0	-253,140	0.0	-253,082	0.0	-270,217	0.0	-253,111	0.0									
6	40.6	37.8	-165,680	0.0	-252,933	0.0	-252,979	0.0	-270,128	0.0	-252,979	0.0									
7	41.6	39.0	-132,454	0.0	-229,258	0.0	-229,258	0.0	-246,409	0.0	-229,258	0.0									
8	43.3	40.7	-29,479	0.0	-113,056	0.0	-197,942	0.0	-215,091	0.0	-113,056	0.0									
9	45.4	42.5	0	0.0	-77,255	0.0	-162,139	0.0	-179,288	0.0	-77,255	0.0									
10	47.9	44.3	0	0.0	-31,209	0.0	-131,384	0.0	-148,533	0.0	-31,209	0.0									
11	50.6	45.5	0	0.0	-12,653	0.0	-100,607	0.0	-117,756	0.0	-12,653	0.0									
12	53.3	46.8	0	0.0	0	0.0	-75,313	0.0	-92,463	0.0	0	0.0									
13	55.8	48.5	0	0.0	0	0.0	-45,563	0.0	-62,713	0.0	0	0.0									
14	58.0	49.6	0	0.0	0	0.0	-13,744	0.0	-30,894	0.0	0	0.0									
15	59.6	50.3	0	0.0	0	0.0	0	0.0	-9,886	0.0	0	0.0									
16	60.7	50.9	0	0.0	0	0.0	0	0.0	-4,932	0.0	0	0.0									
17	61.0	50.9	0	0.0	0	0.0	0	0.0	-4,936	0.0	0	0.0									
18	60.7	50.7	0	0.0	0	0.0	0	0.0	-15,577	0.0	0	0.0									
19	59.6	50.7	0	0.0	0	0.0	0	0.0	-35,906	0.0	0	0.0									
20	58.0	50.5	0	0.0	0	0.0	0	0.0	-71,641	0.0	0	0.0									
21	55.8	49.4	0	0.0	0	0.0	0	0.0	-97,631	0.0	0	0.0									
22	53.3	47.8	0	0.0	0	0.0	0	0.0	-125,606	0.0	0	0.0									
23	50.6	45.9	0	0.0	-40,825	0.0	-49,140	0.0	-152,939	0.0	-40,825	0.0									
24	47.9	43.8	0	0.0	-80,594	0.0	-80,596	0.0	-180,922	0.0	-80,594	0.0									

April		----- Design -----				----- Weekday -----				----- Saturday-----				----- Sunday -----				----- Monday -----			
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton					
1	57.7	53.9	-21,585	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0					
2	55.9	52.7	-25,905	0.0	0	0.0	0	0.0	0	0.0	-18,109	0.0									
3	54.2	51.3	-30,305	0.0	0	0.0	0	0.0	-5,314	0.0	-55,496	0.0									
4	52.9	50.2	-32,294	0.0	0	0.0	0	0.0	-64,376	0.0	-95,341	0.0									
5	51.9	49.6	-34,199	0.0	-21,475	0.0	-66,957	0.0	-68,679	0.0	-132,354	0.0									
6	51.2	49.2	-31,046	0.0	-69,904	0.0	-69,898	0.0	-71,625	0.0	-134,470	0.0									
7	51.0	49.3	-16,477	0.0	-61,486	0.0	-61,493	0.0	-80,311	0.0	-118,141	0.0									
8	51.6	49.9	0	0.0	-29,295	0.0	-46,388	0.0	-114,025	0.0	-29,295	0.0									
9	53.3	50.6	0	0.0	-12,442	0.0	-29,535	0.0	-90,520	0.0	-12,442	0.0									
10	55.9	51.8	0	0.0	0	0.0	-22,993	0.0	-56,174	0.0	0	0.0									
11	59.0	53.4	0	0.0	0	0.0	-10,755	0.0	-27,910	0.0	0	0.0									
12	62.4	55.6	0	0.0	-1,971	0.0	0	0.0	-4,921	0.0	0	0.0									
13	65.5	57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
14	68.1	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
15	69.8	60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
16	70.4	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
17	70.2	60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
18	69.5	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
19	68.5	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
20	67.2	59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
21	65.5	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
22	63.7	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
23	61.7	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									
24	59.7	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0									

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M500, BASELINE

May			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	
1	66.6	62.3	0	17.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
2	64.5	60.4	0	1.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
3	62.7	59.1	0	0.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
4	61.2	58.1	0	0.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
5	60.0	57.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
6	59.3	56.6	0	1.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
7	59.0	56.5	0	3.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
8	59.5	56.6	0	10.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
9	60.9	56.6	0	16.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	
10	63.0	57.2	0	24.1	0	1.5	0	0.0	0	0.0	0	0.0	0	0.0	0	1.4	
11	65.7	58.1	0	33.3	0	15.7	0	0.0	0	0.0	0	0.0	0	0.0	0	15.7	
12	68.7	59.8	0	37.5	0	17.5	0	0.0	0	0.0	0	0.0	0	0.0	0	17.5	
13	71.7	61.6	0	40.3	0	23.0	0	0.0	0	0.0	0	0.0	0	0.0	0	22.6	
14	74.5	63.4	0	35.9	0	22.4	0	0.0	0	0.0	0	0.0	0	0.0	0	22.4	
15	76.6	64.8	0	37.5	0	26.1	0	9.3	0	0.0	0	0.0	0	0.0	0	26.1	
16	78.0	65.6	0	38.0	0	27.8	0	15.8	0	5.7	0	5.7	0	27.8	0	27.8	
17	78.5	65.6	0	41.5	0	34.4	0	33.5	0	14.5	0	14.5	0	34.4	0	34.4	
18	78.2	65.8	0	41.7	0	37.0	0	31.8	0	13.7	0	13.7	0	37.0	0	37.0	
19	77.5	65.6	0	34.9	0	33.8	0	30.5	0	10.8	0	10.8	0	33.8	0	33.8	
20	76.3	66.1	0	22.6	0	23.1	0	29.5	0	8.6	0	8.6	0	23.1	0	23.1	
21	74.8	67.2	0	19.6	0	22.4	0	27.4	0	6.7	0	6.7	0	22.4	0	22.4	
22	73.0	66.4	0	6.5	0	6.0	0	25.5	0	4.3	0	4.3	0	6.0	0	6.0	
23	70.9	65.4	0	4.6	0	3.6	0	3.3	0	1.5	0	1.5	0	3.6	0	3.6	
24	68.7	64.0	0	3.0	0	1.6	0	1.5	0	0.0	0	0.0	0	1.6	0	1.6	

June			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	
1	73.0	67.9	0	11.5	0	5.8	0	6.8	0	4.3	0	4.3	0	6.8	0	6.8	
2	71.2	66.1	0	10.3	0	3.7	0	3.9	0	1.6	0	1.6	0	3.9	0	3.9	
3	69.7	65.2	0	8.8	0	2.3	0	2.3	0	0.0	0	0.0	0	2.3	0	2.3	
4	68.5	64.3	0	8.0	0	1.1	0	1.1	0	0.0	0	0.0	0	1.1	0	1.1	
5	67.8	64.2	0	7.6	0	0.4	0	0.4	0	0.0	0	0.0	0	0.4	0	0.4	
6	67.6	64.2	0	10.6	0	1.7	0	1.7	0	0.0	0	0.0	0	1.7	0	1.7	
7	68.1	64.8	0	14.9	0	2.9	0	2.9	0	0.0	0	0.0	0	2.9	0	2.9	
8	69.4	65.7	0	27.3	0	14.1	0	4.1	0	0.0	0	0.0	0	14.1	0	14.1	
9	71.6	66.2	0	29.7	0	20.1	0	9.8	0	6.6	0	6.6	0	20.1	0	20.1	
10	74.2	67.2	0	36.5	0	27.8	0	14.7	0	13.0	0	13.0	0	27.8	0	27.8	
11	77.2	68.5	0	46.8	0	36.3	0	16.7	0	15.0	0	15.0	0	36.3	0	36.3	
12	80.2	70.0	0	50.8	0	41.1	0	20.2	0	18.4	0	18.4	0	41.1	0	41.1	
13	82.8	70.8	0	53.5	0	44.4	0	23.6	0	21.8	0	21.8	0	44.4	0	44.4	
14	85.0	71.6	0	48.4	0	39.0	0	26.6	0	24.9	0	24.9	0	39.0	0	39.0	
15	86.3	72.3	0	50.4	0	43.1	0	30.0	0	28.2	0	28.2	0	43.1	0	43.1	
16	86.8	72.1	0	49.3	0	42.5	0	29.8	0	28.1	0	28.1	0	42.5	0	42.5	
17	86.6	71.7	0	52.5	0	48.3	0	47.8	0	27.5	0	27.5	0	48.3	0	48.3	
18	85.8	71.5	0	53.4	0	50.9	0	45.3	0	26.3	0	26.3	0	50.9	0	50.9	
19	84.7	71.2	0	47.3	0	46.6	0	43.3	0	22.1	0	22.1	0	46.6	0	46.6	
20	83.2	71.5	0	33.9	0	35.1	0	42.2	0	19.9	0	19.9	0	35.1	0	35.1	
21	81.4	71.7	0	30.6	0	33.3	0	38.2	0	17.2	0	17.2	0	33.3	0	33.3	
22	79.3	71.4	0	15.8	0	15.3	0	35.4	0	14.1	0	14.1	0	15.3	0	15.3	
23	77.2	70.5	0	13.7	0	13.3	0	12.3	0	11.2	0	11.2	0	13.3	0	13.3	
24	75.1	69.1	0	12.2	0	9.9	0	9.8	0	7.7	0	7.7	0	9.9	0	9.9	

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M500, BASELINE

July		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.0	69.3	0	12.9	0	4.7	0	5.6	0	2.7	0	5.8
2	70.5	68.0	0	10.6	0	3.3	0	3.4	0	0.8	0	3.4
3	69.4	67.1	0	9.4	0	2.2	0	2.2	0	0.0	0	2.2
4	68.5	66.4	0	8.5	0	1.0	0	1.0	0	0.0	0	1.0
5	67.9	66.0	0	8.3	0	0.3	0	0.3	0	0.0	0	0.3
6	67.7	65.9	0	10.5	0	1.4	0	1.4	0	0.0	0	1.4
7	68.1	66.3	0	15.2	0	3.1	0	3.1	0	0.0	0	3.1
8	69.1	67.3	0	28.3	0	13.9	0	4.2	0	0.0	0	13.9
9	70.8	68.0	0	30.4	0	22.2	0	8.8	0	2.7	0	22.2
10	72.9	69.1	0	38.5	0	30.6	0	16.1	0	14.4	0	30.6
11	75.2	70.5	0	47.6	0	38.9	0	17.7	0	15.6	0	38.9
12	77.5	71.7	0	52.2	0	43.5	0	21.0	0	18.9	0	43.5
13	79.6	72.7	0	54.9	0	46.4	0	24.1	0	22.1	0	46.4
14	81.3	73.5	0	49.0	0	41.6	0	28.0	0	26.0	0	41.6
15	82.3	73.7	0	51.2	0	44.7	0	30.6	0	28.6	0	44.7
16	82.7	73.5	0	49.9	0	43.3	0	29.9	0	28.1	0	43.3
17	82.5	73.1	0	53.2	0	49.4	0	49.5	0	27.1	0	49.4
18	82.0	72.6	0	54.2	0	52.0	0	45.8	0	25.7	0	52.0
19	81.1	73.2	0	48.5	0	47.8	0	44.6	0	21.6	0	47.8
20	79.9	73.8	0	34.9	0	35.3	0	43.0	0	18.7	0	35.3
21	78.5	73.9	0	32.2	0	35.5	0	40.9	0	16.9	0	35.5
22	76.9	73.1	0	16.2	0	14.4	0	37.2	0	13.4	0	14.4
23	75.2	71.9	0	14.8	0	12.4	0	10.9	0	9.9	0	12.4
24	73.5	70.8	0	13.3	0	8.9	0	8.8	0	6.2	0	8.9

August		----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	72.7	70.2	0	14.4	0	6.0	0	7.0	0	4.1	0	7.3
2	71.2	69.0	0	11.6	0	4.1	0	4.3	0	1.6	0	4.3
3	69.9	68.0	0	9.5	0	2.7	0	2.7	0	0.0	0	2.7
4	68.8	67.1	0	8.4	0	1.5	0	1.5	0	0.0	0	1.5
5	68.0	66.6	0	7.8	0	0.5	0	0.5	0	0.0	0	0.5
6	67.5	66.2	0	9.2	0	0.5	0	0.5	0	0.0	0	0.5
7	67.3	66.1	0	13.8	0	2.0	0	2.0	0	0.0	0	2.0
8	67.8	66.5	0	27.1	0	13.1	0	3.1	0	0.0	0	13.1
9	69.1	67.0	0	31.0	0	16.4	0	4.4	0	0.0	0	16.4
10	71.2	67.8	0	38.9	0	27.3	0	11.6	0	6.0	0	27.3
11	73.8	68.7	0	47.6	0	35.4	0	15.0	0	13.4	0	35.4
12	76.5	70.0	0	50.5	0	40.1	0	18.0	0	16.0	0	40.1
13	79.1	71.2	0	53.1	0	43.5	0	21.9	0	19.9	0	43.5
14	81.1	72.6	0	49.3	0	39.4	0	26.1	0	24.2	0	39.4
15	82.5	73.6	0	51.8	0	42.8	0	29.2	0	27.3	0	42.8
16	83.0	73.7	0	50.4	0	42.5	0	28.9	0	26.9	0	42.5
17	82.8	73.5	0	54.9	0	49.1	0	49.2	0	26.7	0	49.1
18	82.3	73.5	0	53.3	0	50.8	0	44.6	0	24.4	0	50.8
19	81.5	73.1	0	47.6	0	47.1	0	43.9	0	20.9	0	47.1
20	80.4	73.7	0	34.2	0	35.1	0	42.8	0	18.4	0	35.1
21	79.1	74.9	0	33.0	0	35.7	0	41.0	0	17.1	0	35.7
22	77.6	73.9	0	16.0	0	15.4	0	39.0	0	14.3	0	15.4
23	76.0	72.7	0	14.5	0	13.5	0	11.8	0	11.0	0	13.5
24	74.3	71.3	0	12.9	0	10.1	0	9.9	0	7.4	0	10.1

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M500, BASELINE

November			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	48.7	45.7	-88,569	0.0	0	0.0	-77,424	0.0	-79,139	0.0	-157,973	0.0
2	46.9	44.1	-53,781	0.0	-37,184	0.0	-86,342	0.0	-88,072	0.0	-178,059	0.0
3	45.5	42.8	-58,415	0.0	-93,714	0.0	-93,711	0.0	-95,437	0.0	-194,310	0.0
4	44.6	41.9	-61,879	0.0	-97,810	0.0	-183,029	0.0	-193,889	0.0	-205,544	0.0
5	44.4	42.0	-63,783	0.0	-112,014	0.0	-210,822	0.0	-227,970	0.0	-210,849	0.0
6	44.8	42.7	-63,654	0.0	-211,762	0.0	-211,708	0.0	-228,854	0.0	-211,719	0.0
7	45.9	43.9	-82,078	0.0	-201,162	0.0	-201,211	0.0	-218,360	0.0	-201,211	0.0
8	47.8	46.0	-25,104	0.0	-79,762	0.0	-164,647	0.0	-181,797	0.0	-79,761	0.0
9	50.2	48.0	0	0.0	-37,602	0.0	-119,941	0.0	-137,090	0.0	-37,602	0.0
10	52.9	49.9	0	0.0	-9,639	0.0	-82,101	0.0	-99,252	0.0	-9,639	0.0
11	55.8	51.1	0	0.0	0	0.0	-50,164	0.0	-67,312	0.0	0	0.0
12	58.5	52.0	0	0.0	0	0.0	-23,431	0.0	-40,581	0.0	0	0.0
13	60.9	52.5	0	0.0	0	0.0	0	0.0	-12,804	0.0	0	0.0
14	62.8	53.4	0	0.0	-1,610	0.0	0	0.0	0	0.0	-1,610	0.0
15	64.0	53.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	64.4	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	64.1	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	63.2	53.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	61.8	54.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	60.0	53.6	0	0.0	0	0.0	-2,454	0.0	-25,582	0.0	0	0.0
21	57.9	52.7	0	0.0	0	0.0	0	0.0	-81,077	0.0	0	0.0
22	55.6	51.2	0	0.0	0	0.0	0	0.0	-104,561	0.0	0	0.0
23	53.2	49.5	0	0.0	0	0.0	0	0.0	-128,615	0.0	0	0.0
24	50.8	47.6	0	0.0	-20,988	0.0	-58,405	0.0	-154,253	0.0	-20,988	0.0

December			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	35.3	-83,599	0.0	-128,240	0.0	-178,981	0.0	-198,014	0.0	-275,149	0.0
2	37.1	35.1	-87,693	0.0	-169,511	0.0	-282,629	0.0	-299,777	0.0	-282,603	0.0
3	37.4	35.5	-91,381	0.0	-284,650	0.0	-284,564	0.0	-301,715	0.0	-284,613	0.0
4	38.1	36.2	-178,299	0.0	-280,896	0.0	-280,951	0.0	-298,101	0.0	-280,951	0.0
5	39.3	37.6	-199,922	0.0	-272,864	0.0	-272,864	0.0	-290,013	0.0	-272,864	0.0
6	40.9	39.2	-198,614	0.0	-259,279	0.0	-259,279	0.0	-276,428	0.0	-259,279	0.0
7	42.7	41.2	-193,825	0.0	-245,206	0.0	-245,206	0.0	-262,356	0.0	-245,206	0.0
8	44.7	43.1	-66,932	0.0	-124,694	0.0	-209,580	0.0	-226,730	0.0	-124,694	0.0
9	46.8	45.3	-32,495	0.0	-82,303	0.0	-167,188	0.0	-184,337	0.0	-82,303	0.0
10	48.8	47.0	0	0.0	-31,583	0.0	-129,123	0.0	-146,272	0.0	-31,583	0.0
11	50.7	48.1	0	0.0	-9,518	0.0	-102,962	0.0	-120,112	0.0	-9,518	0.0
12	52.2	48.8	0	0.0	0	0.0	-85,447	0.0	-102,596	0.0	0	0.0
13	53.4	49.2	0	0.0	0	0.0	-65,662	0.0	-82,810	0.0	0	0.0
14	54.1	49.2	0	0.0	0	0.0	-47,391	0.0	-64,540	0.0	0	0.0
15	54.4	48.9	0	0.0	0	0.0	-36,166	0.0	-53,316	0.0	0	0.0
16	54.0	48.2	0	0.0	0	0.0	-42,721	0.0	-59,870	0.0	0	0.0
17	53.0	47.3	0	0.0	0	0.0	-5,104	0.0	-93,876	0.0	0	0.0
18	51.4	46.3	0	0.0	0	0.0	-26,155	0.0	-125,350	0.0	0	0.0
19	49.3	45.4	0	0.0	-30,742	0.0	-37,315	0.0	-155,800	0.0	-30,742	0.0
20	47.0	43.5	0	0.0	-60,095	0.0	-48,784	0.0	-183,763	0.0	-60,095	0.0
21	44.5	41.5	0	0.0	-71,988	0.0	-65,676	0.0	-211,257	0.0	-71,988	0.0
22	42.2	39.3	0	0.0	-104,382	0.0	-75,664	0.0	-236,781	0.0	-104,382	0.0
23	40.1	37.6	-11,158	0.0	-115,427	0.0	-115,427	0.0	-261,638	0.0	-115,427	0.0
24	38.5	36.2	-79,709	0.0	-123,214	0.0	-123,214	0.0	-279,687	0.0	-123,214	0.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, BASELINE

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	41,151	99	1,485	4
Feb	37,352	99	1,353	4
March	41,219	94	684	3
April	37,531	94	122	2
May	47,780	144	0	0
June	57,692	162	0	0
July	56,957	160	0	0
Aug	58,819	159	0	0
Sept	49,215	147	0	0
Oct	40,716	125	0	0
Nov	37,554	94	484	3
Dec	40,050	99	1,101	4
Total	546,037	162	5,230	4

Building Energy Consumption = 86,892 (Btu/Sq Ft/Year)
 Source Energy Consumption = 223,619 (Btu/Sq Ft/Year)

Floor Area = 27,466 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, BASELINE

2	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	7017	6338	7017	6791	7017	6791	7017	7017	6791	7017	6791	7017	82,621
	PK	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4
1	EQ2001		GAS FIRE TUBE HOT WATER											
	GAS	1485	1353	684	122	0	0	0	0	0	0	484	1101	5,230
	PK	4.3	4.3	3.2	1.6	0.0	0.0	0.0	0.0	0.0	0.0	2.7	3.6	4.3
1	EQ5020		HEAT WATER CIRC. PUMP C.V.											
	ELEC	2827	2554	1729	730	0	0	0	0	0	0	1402	2200	11,442
	PK	3.8	3.8	3.8	3.8	0.0	0.0	0.0	0.0	0.0	0.0	3.8	3.8	3.8
1	EQ5240		BOILER FORCED DRAFT FAN											
	ELEC	357	322	218	92	0	0	0	0	0	0	177	278	1,444
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5
1	EQ5307		BOILER CONTROLS											
	ELEC	372	336	228	96	0	0	0	0	0	0	184	290	1,505
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M500, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 161.7 (kW)
 Yearly Time of Peak 18 (hr) 6 (mo)

Hour 18 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	67.7	41.88
Sub Total			67.7	41.88
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	18.4	11.40
2		SUMMATION OF FAN ELECTRICAL DEMAND	9.4	5.83
Sub Total			27.9	17.23
Sub Total			0.0	0.00
Miscellaneous				
Lights			15.9	9.81
Base Utilities			0.0	0.00
Misc Equipment			50.2	31.07
Sub Total			66.1	40.89
Grand Total			161.7	100.00

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#2

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	42,033	100	1,530	4
Feb	38,148	100	1,397	4
March	41,758	95	716	3
April	37,789	94	131	2
May	48,198	145	0	0
June	58,510	163	0	0
July	57,735	162	0	0
Aug	59,607	161	0	0
Sept	49,761	148	0	0
Oct	40,746	126	0	0
Nov	37,991	94	506	3
Dec	40,855	100	1,140	4
Total	553,131	163	5,421	4

Building Energy Consumption = 88,471 (Btu/Sq Ft/Year)
 Source Energy Consumption = 226,997 (Btu/Sq Ft/Year)

Floor Area = 27,466 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#2

EQ#	Category	7017	6338	7017	6791	7017	6791	7017	6791	7017	6791	7017	Total	
2	EQ4003			FC CENTRIF. FAN C.V.										
	ELEC	7017	6338	7017	6791	7017	6791	7017	6791	7017	6791	7017	82,625	
	PK	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	
1	EQ2001			GAS FIRE TUBE HOT WATER										
	GAS	1530	1397	716	131	0	0	0	0	0	0	506	1140	5,421
	PK	4.4	4.4	3.3	1.7	0.0	0.0	0.0	0.0	0.0	0.0	2.8	3.7	4.4
1	EQ5020			HEAT WATER CIRC. PUMP C.V.										
	ELEC	3699	3341	2262	979	0	0	0	0	0	0	1834	2978	15,093
	PK	5.0	5.0	5.0	5.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0	5.0	5.0
1	EQ5240			BOILER FORCED DRAFT FAN										
	ELEC	367	331	224	97	0	0	0	0	0	0	182	295	1,497
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5
1	EQ5307			BOILER CONTROLS										
	ELEC	372	336	228	98	0	0	0	0	0	0	184	299	1,518
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M500, ECO#2

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 163.0 (kW)
 Yearly Time of Peak 18 (hr) 6 (mo)

Hour 18 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	69.1	42.36
Sub Total			69.1	42.36
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	18.4	11.31
2		SUMMATION OF FAN ELECTRICAL DEMAND	9.4	5.79
Sub Total			27.9	17.09
Sub Total			0.0	0.00
Miscellaneous				
	Lights		15.9	9.73
	Base Utilities		0.0	0.00
	Misc Equipment		50.2	30.82
Sub Total			66.1	40.55
Grand Total			163.0	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M500, ECO#2

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 27,466
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	3,015.4	542,100.2	22.7	601,509.4	22.4
Primary Cooling					
Compressor	64,014.1	0.0	9.0	655,505.7	24.5
Tower/Cond Fans	7,897.0	0.0	1.1	80,865.1	3.0
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	877.2	0.0	0.1	8,982.5	0.3
Auxiliary					
Supply Fans	244,087.6	0.0	34.3	2,499,462.5	93.3
Circulation Pumps	29,629.2	0.0	4.2	303,404.1	11.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	273,716.8	0.0	38.4	2,802,866.5	104.6
Lighting	60,841.8	0.0	8.5	623,021.1	22.7
Receptacle	142,768.4	0.0	20.1	1,461,952.1	53.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	553,130.6	542,100.2	100.0	6,234,702.5	230.8

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M500, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 27,466
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	2,949.0	522,952.5	22.3	580,674.3	21.7
Primary Cooling					
Compressor	63,988.1	0.0	9.2	655,239.4	24.5
Tower/Cond Fans	7,884.2	0.0	1.1	80,734.8	3.0
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	883.5	0.0	0.1	9,047.1	0.3
Auxiliary					
Supply Fans	244,088.9	0.0	34.9	2,499,476.5	93.3
Circulation Pumps	22,632.8	0.0	3.2	231,760.2	8.6
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	266,721.7	0.0	38.1	2,731,236.8	101.9
Lighting	60,841.8	0.0	8.7	623,021.1	22.7
Receptacle	142,768.4	0.0	20.4	1,461,952.1	53.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	546,036.8	522,952.5	100.0	6,141,905.5	227.3

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#3

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	42,023	100	1,487	4
Feb	38,139	100	1,355	4
March	41,753	95	686	3
April	37,756	94	123	2
May	48,196	145	0	0
June	58,450	163	0	0
July	57,726	161	0	0
Aug	59,595	161	0	0
Sept	49,760	148	0	0
Oct	40,916	126	0	0
Nov	37,986	94	485	3
Dec	40,729	100	1,103	4
Total	553,031	163	5,238	4

Building Energy Consumption = 87,793 (Btu/Sq Ft/Year)
 Source Energy Consumption = 226,260 (Btu/Sq Ft/Year)

Floor Area = 27,466 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#3

2	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	7017	6338	7017	6791	7017	6791	7017	7017	6791	7017	6791	7017	82,625
	PK	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4
1	EQ2001		GAS FIRE TUBE HOT WATER											
	GAS	1487	1355	686	123	0	0	0	0	0	0	485	1103	5,238
	PK	4.3	4.3	3.2	1.6	0.0	0.0	0.0	0.0	0.0	0.0	2.7	3.6	4.3
1	EQ5020		HEAT WATER CIRC. PUMP C.V.											
	ELEC	3699	3341	2262	954	0	0	0	0	0	0	1834	2878	14,969
	PK	5.0	5.0	5.0	5.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0	5.0	5.0
1	EQ5240		BOILER FORCED DRAFT FAN											
	ELEC	357	323	219	92	0	0	0	0	0	0	177	278	1,447
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5
1	EQ5307		BOILER CONTROLS											
	ELEC	372	336	228	96	0	0	0	0	0	0	184	290	1,505
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M500, ECO#3

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 162.9 (kW)
 Yearly Time of Peak 18 (hr) 6 (mo)

Hour 18 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	68.9	42.32
Sub Total			68.9	42.32
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	18.4	11.31
2		SUMMATION OF FAN ELECTRICAL DEMAND	9.4	5.79
Sub Total			27.9	17.10
Sub Total			0.0	0.00
Miscellaneous				
	Lights		15.9	9.74
	Base Utilities		0.0	0.00
	Misc Equipment		50.2	30.84
Sub Total			66.1	40.58
Grand Total			162.9	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M500, ECO#3

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 27,466
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	2,952.2	523,838.3	22.1	581,639.9	21.7
Primary Cooling					
Compressor	64,001.2	0.0	9.1	655,373.6	24.5
Tower/Cond Fans	7,886.7	0.0	1.1	80,759.6	3.0
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	883.5	0.0	0.1	9,047.1	0.3
Auxiliary					
Supply Fans	244,087.6	0.0	34.5	2,499,462.5	93.3
Circulation Pumps	29,609.4	0.0	4.2	303,200.5	11.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	273,696.9	0.0	38.7	2,802,662.8	104.6
Lighting	60,841.8	0.0	8.6	623,021.1	22.7
Receptacle	142,768.4	0.0	20.2	1,461,952.1	53.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	553,030.7	523,838.3	100.0	6,214,456.5	230.0

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#7

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kwh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	28,077	99	448	6
Feb	25,647	99	438	6
March	29,320	94	176	3
April	25,944	94	12	2
May	36,404	144	0	0
June	43,878	162	0	0
July	41,144	160	0	0
Aug	44,847	159	0	0
Sept	36,813	147	0	0
Oct	30,788	125	0	0
Nov	25,010	94	102	3
Dec	26,760	99	271	5
Total	394,632	162	1,447	6

Building Energy Consumption = 54,307 (Btu/Sq Ft/Year)
 Source Energy Consumption = 152,675 (Btu/Sq Ft/Year)

Floor Area = 27,466 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#7

2	EQ4003		FC CENTRIF. FAN C.V.												
	ELEC	3235	2952	3518	3160	3377	3377	3160	3518	3160	3377	3028	3160	39,020	
	PK	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	
1	EQ2001		GAS FIRE TUBE HOT WATER												
	GAS	448	438	176	12	0	0	0	0	0	0	102	271	1,447	
	PK	5.8	6.0	3.5	1.8	0.0	0.0	0.0	0.0	0.0	0.0	2.6	5.1	6.0	
1	EQ5020		HEAT WATER CIRC. PUMP C.V.												
	ELEC	1303	1189	483	46	0	0	0	0	0	0	266	688	3,975	
	PK	3.8	3.8	3.8	3.8	0.0	0.0	0.0	0.0	0.0	0.0	3.8	3.8	3.8	
1	EQ5240		BOILER FORCED DRAFT FAN												
	ELEC	180	165	67	6	0	0	0	0	0	0	37	95	550	
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	
1	EQ5307		BOILER CONTROLS												
	ELEC	172	157	63	6	0	0	0	0	0	0	35	91	523	
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M500, ECO#7

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 161.7 (kW)
Yearly Time of Peak 18 (hr) 6 (mo)

Hour 18 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	67.7	41.88
Sub Total			67.7	41.88
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	18.4	11.40
2		SUMMATION OF FAN ELECTRICAL DEMAND	9.4	5.83
Sub Total			27.9	17.23
Sub Total			0.0	0.00
Miscellaneous				
	Lights		15.9	9.81
	Base Utilities		0.0	0.00
	Misc Equipment		50.2	31.07
Sub Total			66.1	40.89
Grand Total			161.7	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M500, ECO#7

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 27,466
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,072.9	144,716.2	9.9	163,319.3	6.1
Primary Cooling					
Compressor	55,952.8	0.0	12.8	572,957.7	21.4
Tower/Cond Fans	6,880.5	0.0	1.6	70,456.5	2.6
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	575.7	0.0	0.1	5,895.2	0.2
Auxiliary					
Supply Fans	115,272.8	0.0	26.4	1,180,396.1	44.1
Circulation Pumps	11,267.0	0.0	2.6	115,374.3	4.3
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	126,539.8	0.0	29.0	1,295,770.5	48.4
Lighting	60,841.8	0.0	13.9	623,021.1	22.7
Receptacle	142,768.4	0.0	32.7	1,461,952.1	53.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	394,631.9	144,716.2	100.0	4,193,372.7	154.6

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M500, ECO#12

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	27,992	99	364	5
Feb	25,571	99	356	5
March	29,214	94	115	3
April	25,925	94	4	1
May	34,840	141	0	0
June	41,458	158	0	0
July	38,994	156	0	0
Aug	42,393	155	0	0
Sept	34,462	142	0	0
Oct	29,990	124	0	0
Nov	24,999	94	57	2
Dec	26,671	94	202	3
Total	382,510	158	1,097	5

Building Energy Consumption = 51,527 (Btu/Sq Ft/Year)
Source Energy Consumption = 146,815 (Btu/Sq Ft/Year)

Floor Area = 27,466 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#12

2	EQ4003		FC CENTRIF. FAN C.V.											
	ELEC	3235	2952	3518	3160	3377	3377	3160	3518	3160	3377	3028	3160	39,020
	PK	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4
1	EQ2001		GAS FIRE TUBE HOT WATER											
	GAS	364	356	115	4	0	0	0	0	0	0	57	202	1,097
	PK	5.2	5.4	2.6	0.9	0.0	0.0	0.0	0.0	0.0	0.0	2.3	2.5	5.4
1	EQ5020		HEAT WATER CIRC. PUMP C.V.											
	ELEC	1224	1117	395	30	0	0	0	0	0	0	255	612	3,633
	PK	3.8	3.8	3.8	3.8	0.0	0.0	0.0	0.0	0.0	0.0	3.8	3.8	3.8
1	EQ5240		BOILER FORCED DRAFT FAN											
	ELEC	186	170	60	5	0	0	0	0	0	0	39	93	552
	PK	0.6	0.6	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.6	0.6
1	EQ5307		BOILER CONTROLS											
	ELEC	161	147	52	4	0	0	0	0	0	0	33	81	478
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M500, ECO#12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 158.3 (kW)
 Yearly Time of Peak 18 (hr) 6 (mo)

Hour 18 Month 6

Eq. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	64.3	40.63
Sub Total			64.3	40.63
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	18.4	11.64
2		SUMMATION OF FAN ELECTRICAL DEMAND	9.4	5.96
Sub Total			27.9	17.60
Sub Total			0.0	0.00
Miscellaneous				
	Lights		15.9	10.02
	Base Utilities		0.0	0.00
	Misc Equipment		50.2	31.74
Sub Total			66.1	41.77
Grand Total			158.3	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M500, ECO#12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 27,466
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,030.0	109,735.9	8.0	126,059.1	4.7
Primary Cooling					
Compressor	46,149.9	0.0	11.1	472,576.1	17.6
Tower/Cond Fans	5,619.0	0.0	1.4	57,538.5	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	526.5	0.0	0.1	5,391.4	0.2
Auxiliary					
Supply Fans	115,272.8	0.0	27.8	1,180,396.1	44.1
Circulation Pumps	10,301.8	0.0	2.5	105,490.7	3.9
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	125,574.6	0.0	30.3	1,285,886.7	48.0
Lighting	60,841.8	0.0	14.7	623,021.1	22.7
Receptacle	142,768.4	0.0	34.4	1,461,952.1	53.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	382,510.2	109,735.9	100.0	4,032,425.2	148.6

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M500, ECO#13

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	42,393	99	1,485	4
Feb	38,494	99	1,353	4
March	42,484	94	684	3
April	38,755	94	122	2
May	49,747	144	0	0
June	58,648	162	0	0
July	57,998	160	0	0
Aug	60,097	159	0	0
Sept	50,993	146	0	0
Oct	43,384	125	0	0
Nov	38,777	94	484	3
Dec	41,314	99	1,101	4
Total	563,084	162	5,230	4

Building Energy Consumption = 89,010 (Btu/Sq Ft/Year)
Source Energy Consumption = 229,974 (Btu/Sq Ft/Year)

Floor Area = 27,466 (Sq Ft)

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#13

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	Monthly Consumption												Total
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	
0	LIGHTS													
	ELEC	5046	4602	5491	4919	5269	5269	4919	5491	4919	5269	4729	4919	60,842
	PK	15.9	15.9	15.9	15.9	15.9	15.9	15.9	15.9	15.9	15.9	15.9	15.9	15.9
1	MISC LD													
	ELEC	11818	10813	12823	11632	12321	12321	11632	12823	11632	12321	10999	11632	142,768
	PK	50.2	50.2	50.2	50.2	50.2	50.2	50.2	50.2	50.2	50.2	50.2	50.2	50.2
2	MISC LD													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	MISC LD													
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD													
	P HOTH2O	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ1122L													
			AIR-CLD RECIP >55 TONS											
	ELEC	0	0	0	0	4909	10820	10530	10635	6553	1129	0	0	44,575
	PK	0.0	0.0	0.0	0.0	41.8	57.9	55.7	57.4	47.0	25.0	0.0	0.0	57.9
1	EQ5200													
			CONDENSER FANS											
	ELEC	0	0	0	0	604	1326	1324	1322	804	101	0	0	5,482
	PK	0.0	0.0	0.0	0.0	5.1	11.2	6.6	6.8	5.6	3.3	0.0	0.0	11.2
1	EQ5001													
			CHILLED WATER PUMP C.V.											
	ELEC	0	0	0	0	973	1877	1911	1927	1330	464	0	0	8,482
	PK	0.0	0.0	0.0	0.0	3.8	3.8	3.8	3.8	3.8	3.8	0.0	0.0	3.8
1	EQ5313													
			CONTROLS											
	ELEC	0	0	0	0	77	148	151	152	105	37	0	0	670
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3
2	EQ1750													
			AIR-CLD CTV ICE-CHILL H2O											
	ELEC	1108	1021	1130	1094	4523	6482	6448	6663	5266	3107	1094	1130	39,067
	PK	16.5	16.5	16.5	16.5	39.3	40.7	40.5	40.4	39.3	39.3	16.5	16.5	40.7

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M500, ECO#13

2	EQ5205		CONDENSER FANS												
	ELEC	10	9	10	10	14	17	17	17	15	13	10	10	153	
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	
2	EQ5001		CHILLED WATER PUMP C.V.												
	ELEC	0	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
2	EQ5309		CONTROLS												
	ELEC	124	112	124	120	327	326	335	337	307	213	120	124	2,569	
	PK	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	
1	EQ4003		FC CENTRIF. FAN C.V.												
	ELEC	13713	12386	13713	13271	13713	13271	13713	13271	13713	13271	13713	13713	161,463	
	PK	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	
2	EQ4003		FC CENTRIF. FAN C.V.												
	ELEC	7017	6338	7017	6791	7017	6791	7017	6791	7017	6791	7017	6791	7017	82,625
	PK	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	9.4	
1	EQ2001		GAS FIRE TUBE HOT WATER												
	GAS	1485	1353	684	122	0	0	0	0	0	0	484	1101	5,230	
	PK	4.3	4.3	3.2	1.6	0.0	0.0	0.0	0.0	0.0	0.0	2.7	3.6	4.3	
1	EQ5020		HEAT WATER CIRC. PUMP C.V.												
	ELEC	2827	2554	1729	730	0	0	0	0	0	0	1402	2200	11,442	
	PK	3.8	3.8	3.8	3.8	0.0	0.0	0.0	0.0	0.0	0.0	3.8	3.8	3.8	
1	EQ5240		BOILER FORCED DRAFT FAN												
	ELEC	357	322	218	92	0	0	0	0	0	0	177	278	1,444	
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	
1	EQ5307		BOILER CONTROLS												
	ELEC	372	336	228	96	0	0	0	0	0	0	184	290	1,505	
	PK	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M500, ECO#13

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 161.7 (kW)
Yearly Time of Peak 18 (hr) 6 (mo)

Hour 18 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1122L	AIR-CLD RECIP >55 TONS	67.7	41.88
Sub Total			67.7	41.88
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	18.4	11.40
2		SUMMATION OF FAN ELECTRICAL DEMAND	9.4	5.83
Sub Total			27.9	17.23
Sub Total			0.0	0.00
Miscellaneous				
	Lights		15.9	9.81
	Base Utilities		0.0	0.00
	Misc Equipment		50.2	31.07
Sub Total			66.1	40.89
Grand Total			161.7	100.00

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

January

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	42.7	35.4	0.0	0.0	0.0	203
2	41.8	34.7	0.0	4.1	6.7	205
3	41.1	34.4	0.0	0.0	0.0	203
4	40.6	34.0	0.0	4.1	6.7	205
5	40.4	34.0	0.0	0.0	0.0	203
6	40.8	34.4	0.0	4.1	6.7	205
7	41.6	35.0	0.0	0.0	0.0	203
8	43.2	36.5	0.0	4.1	6.7	205
9	45.5	38.5	0.0	0.0	0.0	205
10	48.1	40.4	0.0	0.0	0.0	205
11	51.0	42.2	0.0	0.0	0.0	205
12	53.8	43.8	0.0	0.0	0.0	205
13	55.9	45.0	0.0	0.0	0.0	203
14	57.3	45.5	0.0	0.0	0.0	201
15	57.8	45.6	0.0	0.0	0.0	199
16	57.3	44.8	0.0	0.0	0.0	197
17	56.1	43.9	0.0	0.0	0.0	197
18	54.2	42.7	0.0	0.0	0.0	197
19	51.9	41.6	0.0	0.0	0.0	197
20	49.6	40.2	0.0	0.0	0.0	197
21	47.7	39.1	0.0	0.0	0.0	197
22	46.0	37.9	0.0	0.0	0.0	197
23	44.6	36.8	0.0	0.0	0.0	197
24	43.6	36.1	0.0	0.0	0.0	197

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	33.4	30.4	0.0	10.0	15.1	205	0.0	12.0	16.5	205
2	32.1	29.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	31.7	29.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	31.9	29.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	32.6	30.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	33.6	31.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	35.0	32.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	36.6	34.4	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	38.5	36.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	40.4	37.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	42.3	38.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	44.2	39.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	45.8	40.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	47.2	41.1	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	48.2	41.6	0.0	0.0	0.0	197	0.0	0.0	0.0	197

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
16	48.9	41.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
17	49.1	41.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
18	48.7	41.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
19	47.4	41.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
20	45.5	40.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
21	43.1	38.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
22	40.4	36.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
23	37.7	34.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
24	35.3	32.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
Hour	----- Sunday -----						----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
1	33.4	30.4	0.0	12.0	16.5	205	0.0	12.0	16.5	205	
2	32.1	29.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
3	31.7	29.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205	
4	31.9	29.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
5	32.6	30.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205	
6	33.6	31.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
7	35.0	32.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205	
8	36.6	34.4	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
9	38.5	36.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
10	40.4	37.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
11	42.3	38.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
12	44.2	39.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
13	45.8	40.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201	
14	47.2	41.1	0.0	0.0	0.0	199	0.0	0.0	0.0	199	
15	48.2	41.6	0.0	0.0	0.0	197	0.0	0.0	0.0	197	
16	48.9	41.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
17	49.1	41.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
18	48.7	41.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
19	47.4	41.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
20	45.5	40.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
21	43.1	38.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
22	40.4	36.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
23	37.7	34.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
24	35.3	32.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

February

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	42.8	35.6	0.0	12.0	16.5	205
2	42.0	34.9	0.0	0.0	0.0	203
3	41.4	34.5	0.0	4.1	6.7	205
4	41.0	34.2	0.0	0.0	0.0	203
5	40.8	34.0	0.0	4.1	6.7	205
6	41.1	34.4	0.0	0.0	0.0	203
7	41.9	35.0	0.0	4.1	6.7	205
8	43.3	36.5	0.0	0.0	0.0	203
9	45.3	38.2	0.0	0.0	0.0	203
10	47.7	39.5	0.0	0.0	0.0	203
11	50.3	41.3	0.0	0.0	0.0	203
12	52.8	42.5	0.0	0.0	0.0	203
13	54.7	43.4	0.0	0.0	0.0	201
14	55.9	44.0	0.0	0.0	0.0	199
15	56.4	44.2	0.0	0.0	0.0	197
16	55.9	43.6	0.0	0.0	0.0	195
17	54.8	42.6	0.0	0.0	0.0	195
18	53.1	41.4	0.0	0.0	0.0	195
19	51.1	40.4	0.0	0.0	0.0	195
20	49.1	39.4	0.0	0.0	0.0	195
21	47.4	38.5	0.0	0.0	0.0	195
22	45.8	37.6	0.0	0.0	0.0	195
23	44.5	36.9	0.0	0.0	0.0	195
24	43.6	36.1	0.0	0.0	0.0	195

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	37.5	34.5	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	36.0	33.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	34.7	31.8	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	33.6	30.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	32.8	30.1	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	32.2	29.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	32.1	29.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	32.5	30.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	33.9	31.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	36.0	33.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	38.5	34.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	41.3	36.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	43.8	38.1	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	45.9	39.5	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	47.2	40.4	0.0	0.0	0.0	197	0.0	0.0	0.0	197

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	47.7	40.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	47.5	40.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	47.0	39.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	46.2	39.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	45.1	39.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	43.8	39.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	42.3	38.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	40.7	37.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	39.1	35.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	37.5	34.5	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	36.0	33.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	34.7	31.8	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	33.6	30.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	32.8	30.1	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	32.2	29.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	32.1	29.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	32.5	30.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	33.9	31.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	36.0	33.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	38.5	34.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	41.3	36.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	43.8	38.1	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	45.9	39.5	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	47.2	40.4	0.0	0.0	0.0	197	0.0	0.0	0.0	197
16	47.7	40.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	47.5	40.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	47.0	39.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	46.2	39.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	45.1	39.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	43.8	39.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	42.3	38.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	40.7	37.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	39.1	35.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

March

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	51.8	42.9	0.0	12.0	16.5	205
2	50.8	42.1	0.0	0.0	0.0	203
3	50.0	41.8	0.0	4.1	6.7	205
4	49.3	41.1	0.0	0.0	0.0	203
5	49.1	41.1	0.0	4.1	6.7	205
6	49.5	41.6	0.0	0.0	0.0	203
7	50.6	42.7	0.0	4.1	6.7	205
8	52.5	44.3	0.0	0.0	0.0	203
9	55.2	46.4	0.0	0.0	0.0	203
10	58.3	48.5	0.0	0.0	0.0	203
11	61.8	50.3	0.0	0.0	0.0	203
12	65.1	51.9	0.0	0.0	0.0	203
13	67.6	53.4	0.0	0.0	0.0	201
14	69.3	53.9	0.0	0.0	0.0	199
15	69.9	53.8	0.0	0.0	0.0	197
16	69.3	53.1	0.0	0.0	0.0	195
17	67.8	51.8	0.0	0.0	0.0	195
18	65.6	50.2	0.0	0.0	0.0	195
19	62.9	48.9	0.0	0.0	0.0	195
20	60.2	47.7	0.0	0.0	0.0	195
21	57.9	46.5	0.0	0.0	0.0	195
22	55.8	45.3	0.0	0.0	0.0	195
23	54.1	44.4	0.0	0.0	0.0	195
24	52.9	43.7	0.0	0.0	0.0	195

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	45.4	41.6	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	43.3	39.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	41.6	38.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	40.6	37.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	40.2	37.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	40.6	37.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	41.6	39.0	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	43.3	40.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	45.4	42.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	47.9	44.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	50.6	45.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	53.3	46.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	55.8	48.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	58.0	49.6	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	59.6	50.3	0.0	0.0	0.0	197	0.0	0.0	0.0	197

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	60.7	50.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	61.0	50.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	60.7	50.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	59.6	50.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	58.0	50.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	55.8	49.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	53.3	47.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	50.6	45.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	47.9	43.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195

Hour	Typical		Sunday				Monday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	45.4	41.6	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	43.3	39.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	41.6	38.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	40.6	37.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	40.2	37.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	40.6	37.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	41.6	39.0	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	43.3	40.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	45.4	42.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	47.9	44.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	50.6	45.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	53.3	46.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	55.8	48.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	58.0	49.6	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	59.6	50.3	0.0	0.0	0.0	197	0.0	0.0	0.0	197
16	60.7	50.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	61.0	50.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	60.7	50.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	59.6	50.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	58.0	50.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	55.8	49.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	53.3	47.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	50.6	45.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	47.9	43.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

April

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	62.6	52.5	0.0	12.0	
2	61.6	52.1	0.0	0.0	0.0	203
3	60.9	51.6	0.0	4.1	6.7	205
4	60.3	51.2	0.0	0.0	0.0	203
5	60.1	51.3	0.0	4.1	6.7	205
6	60.5	51.9	0.0	0.0	0.0	203
7	61.4	53.0	0.0	4.1	6.7	205
8	63.2	54.5	0.0	0.0	0.0	203
9	65.7	55.8	0.0	0.0	0.0	203
10	68.6	57.1	0.0	0.0	0.0	203
11	71.9	58.6	0.0	0.0	0.0	203
12	75.0	60.3	0.0	0.0	0.0	203
13	77.4	61.5	0.0	0.0	0.0	201
14	78.9	62.2	0.0	0.0	0.0	199
15	79.5	62.5	0.0	0.0	0.0	197
16	78.9	61.8	0.0	0.0	0.0	195
17	77.5	60.3	0.0	0.0	0.0	195
18	75.4	59.1	0.0	0.0	0.0	195
19	72.9	57.3	0.0	0.0	0.0	195
20	70.4	56.5	0.0	0.0	0.0	195
21	68.2	55.7	0.0	0.0	0.0	195
22	66.3	55.0	0.0	0.0	0.0	195
23	64.7	54.0	0.0	0.0	0.0	195
24	63.6	53.2	0.0	0.0	0.0	195

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	57.7	53.9	0.0	12.0	16.5	205	0.0	12.0	16.5
2	55.9	52.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	54.2	51.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	52.9	50.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	51.9	49.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	51.2	49.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	51.0	49.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	51.6	49.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	53.3	50.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	55.9	51.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	59.0	53.4	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	62.4	55.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	65.5	57.7	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	68.1	59.4	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	69.8	60.7	0.0	0.0	0.0	197	0.0	0.0	0.0	197

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB	CAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
16	70.4	60.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	70.2	60.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	69.5	60.1	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	68.5	59.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	67.2	59.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	65.5	59.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	63.7	58.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	61.7	57.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	59.7	55.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195

Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB	CAWB	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity	Cooling Load	Chiller Load	Chiller Demand	Storage Capacity
	(F)	(F)	(Ton)	(Ton)	(kW)	(Ton-Hr)	(Ton)	(Ton)	(kW)	(Ton-Hr)
1	57.7	53.9	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	55.9	52.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	54.2	51.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	52.9	50.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	51.9	49.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	51.2	49.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	51.0	49.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	51.6	49.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	53.3	50.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	55.9	51.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	59.0	53.4	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	62.4	55.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	65.5	57.7	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	68.1	59.4	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	69.8	60.7	0.0	0.0	0.0	197	0.0	0.0	0.0	197
16	70.4	60.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	70.2	60.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	69.5	60.1	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	68.5	59.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	67.2	59.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	65.5	59.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	63.7	58.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	61.7	57.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	59.7	55.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

May

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	70.8	59.3	0.0	12.0	16.5	205
2	69.8	58.5	1.2	0.0	0.0	201
3	69.0	58.2	0.9	6.2	10.1	205
4	68.4	58.1	0.4	0.0	0.0	202
5	68.2	58.0	0.0	4.4	7.3	205
6	68.6	58.5	0.0	0.0	0.0	203
7	69.6	59.5	0.0	4.1	6.7	205
8	71.3	60.6	0.0	0.0	0.0	203
9	73.9	61.5	0.0	0.0	0.0	203
10	76.8	62.7	0.0	0.0	0.0	203
11	80.1	63.9	0.0	0.0	0.0	203
12	83.2	65.4	0.0	0.0	0.0	203
13	85.6	66.5	40.3	0.0	0.0	160
14	87.1	67.1	35.9	0.0	0.0	123
15	87.7	67.2	37.5	0.0	0.0	84
16	87.1	66.5	38.0	0.0	0.0	45
17	85.8	65.1	0.0	0.0	0.0	45
18	83.6	63.9	0.0	0.0	0.0	45
19	81.1	62.4	0.0	0.0	0.0	45
20	78.6	61.6	0.0	0.0	0.0	45
21	76.4	61.8	0.0	0.0	0.0	45
22	74.5	60.9	0.0	0.0	0.0	45
23	72.9	60.3	0.0	0.0	0.0	45
24	71.7	59.9	0.0	0.0	0.0	45

Hour	Typical		Weekday				Saturday			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	66.6	62.3	0.0	35.0	39.3	80	0.0	35.0	39.3	128
2	64.5	60.4	0.0	35.0	39.3	114	0.0	35.0	39.3	162
3	62.7	59.1	0.0	35.0	39.3	148	0.0	35.0	39.3	195
4	61.2	58.1	0.0	35.0	39.3	181	0.0	11.7	16.3	205
5	60.0	57.1	0.0	25.1	27.8	205	0.0	0.0	0.0	203
6	59.3	56.6	0.0	0.0	0.0	203	0.0	4.1	6.7	205
7	59.0	56.5	0.0	4.1	6.7	205	0.0	0.0	0.0	203
8	59.5	56.6	0.0	0.0	0.0	203	0.0	4.1	6.7	205
9	60.9	56.6	0.0	0.0	0.0	203	0.0	0.0	0.0	205
10	63.0	57.2	1.5	0.0	0.0	201	0.0	0.0	0.0	205
11	65.7	58.1	0.0	0.0	0.0	201	0.0	0.0	0.0	205
12	68.7	59.8	0.0	0.0	0.0	201	0.0	0.0	0.0	205
13	71.7	61.6	23.0	0.0	0.0	176	0.0	0.0	0.0	203
14	74.5	63.4	22.4	0.0	0.0	152	0.0	0.0	0.0	201
15	76.6	64.8	26.1	0.0	0.0	124	9.3	0.0	0.0	189

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	78.0	65.6	27.8	0.0	0.0	95	15.8	0.0	0.0	172
17	78.5	65.6	0.0	0.0	0.0	95	0.0	0.0	0.0	172
18	78.2	65.8	0.0	0.0	0.0	95	0.0	0.0	0.0	172
19	77.5	65.6	0.0	0.0	0.0	95	0.0	0.0	0.0	172
20	76.3	66.1	0.0	0.0	0.0	95	0.0	0.0	0.0	172
21	74.8	67.2	0.0	0.0	0.0	95	0.0	0.0	0.0	172
22	73.0	66.4	0.0	0.0	0.0	95	0.0	0.0	0.0	172
23	70.9	65.4	0.0	0.0	0.0	95	0.0	0.0	0.0	172
24	68.7	64.0	1.6	0.0	0.0	94	1.5	0.0	0.0	170
Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	66.6	62.3	0.0	35.0	39.3	203	0.0	17.2	20.5	205
2	64.5	60.4	0.0	3.4	5.5	205	0.0	0.0	0.0	203
3	62.7	59.1	0.0	0.0	0.0	203	0.0	4.1	6.7	205
4	61.2	58.1	0.0	4.1	6.7	205	0.0	0.0	0.0	203
5	60.0	57.1	0.0	0.0	0.0	203	0.0	4.1	6.7	205
6	59.3	56.6	0.0	4.1	6.7	205	0.0	0.0	0.0	203
7	59.0	56.5	0.0	0.0	0.0	203	0.0	4.1	6.7	205
8	59.5	56.6	0.0	4.1	6.7	205	0.0	0.0	0.0	203
9	60.9	56.6	0.0	0.0	0.0	205	0.0	0.0	0.0	203
10	63.0	57.2	0.0	0.0	0.0	205	1.4	0.0	0.0	201
11	65.7	58.1	0.0	0.0	0.0	205	0.0	0.0	0.0	201
12	68.7	59.8	0.0	0.0	0.0	205	0.0	0.0	0.0	201
13	71.7	61.6	0.0	0.0	0.0	203	22.6	0.0	0.0	177
14	74.5	63.4	0.0	0.0	0.0	201	22.4	0.0	0.0	152
15	76.6	64.8	0.0	0.0	0.0	199	26.1	0.0	0.0	125
16	78.0	65.6	5.7	0.0	0.0	191	27.8	0.0	0.0	96
17	78.5	65.6	0.0	0.0	0.0	191	0.0	0.0	0.0	96
18	78.2	65.8	0.0	0.0	0.0	191	0.0	0.0	0.0	96
19	77.5	65.6	0.0	0.0	0.0	191	0.0	0.0	0.0	96
20	76.3	66.1	0.0	0.0	0.0	191	0.0	0.0	0.0	96
21	74.8	67.2	0.0	0.0	0.0	191	0.0	0.0	0.0	96
22	73.0	66.4	0.0	0.0	0.0	191	0.0	0.0	0.0	96
23	70.9	65.4	1.5	0.0	0.0	189	0.0	0.0	0.0	96
24	68.7	64.0	0.0	0.0	0.0	189	1.6	0.0	0.0	94

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

June

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	79.5	66.2	0.0	35.0	40.7	128
2	78.5	65.3	0.0	35.0	40.4	162
3	77.7	65.1	0.0	35.0	40.1	195
4	77.2	64.8	0.0	11.3	16.3	205
5	77.0	65.1	0.0	0.0	0.0	203
6	77.4	65.6	0.0	4.1	6.8	205
7	78.3	66.5	0.0	0.0	0.0	203
8	80.0	67.7	0.0	4.1	6.9	205
9	82.5	68.3	0.0	0.0	0.0	205
10	85.4	69.5	0.0	0.0	0.0	205
11	88.7	70.8	0.0	0.0	0.0	205
12	91.8	72.2	0.0	0.0	0.0	205
13	94.1	72.6	53.5	0.0	0.0	149
14	95.6	72.9	48.4	0.0	0.0	99
15	96.2	72.9	50.4	0.0	0.0	48
16	95.6	72.0	49.3	0.0	0.0	0
17	94.3	70.8	0.0	0.0	0.0	0
18	92.1	69.7	0.0	0.0	0.0	0
19	89.6	68.3	0.0	0.0	0.0	0
20	87.1	67.7	0.0	0.0	0.0	0
21	85.0	67.5	0.0	0.0	0.0	0
22	83.1	67.3	0.0	0.0	0.0	0
23	81.6	66.8	0.0	0.0	0.0	0
24	80.4	66.3	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	73.0	67.9	0.0	35.0	39.3	35	0.0	35.0	39.3	63
2	71.2	66.1	0.0	35.0	39.3	70	0.0	35.0	39.3	97
3	69.7	65.2	0.0	35.0	39.3	104	0.0	35.0	39.3	131
4	68.5	64.3	1.1	35.0	39.3	137	1.1	35.0	39.3	164
5	67.8	64.2	0.4	35.0	39.3	170	0.4	35.0	39.3	197
6	67.6	64.2	1.7	35.0	39.3	202	1.7	11.6	16.2	205
7	68.1	64.8	0.0	5.1	8.4	205	0.0	0.0	0.0	203
8	69.4	65.7	0.0	0.0	0.0	203	0.0	4.1	6.7	205
9	71.6	66.2	0.0	0.0	0.0	203	0.0	0.0	0.0	205
10	74.2	67.2	0.0	0.0	0.0	203	0.0	0.0	0.0	205
11	77.2	68.5	0.0	0.0	0.0	203	0.0	0.0	0.0	205
12	80.2	70.0	0.0	0.0	0.0	203	0.0	0.0	0.0	205
13	82.8	70.8	44.4	0.0	0.0	156	23.6	0.0	0.0	179
14	85.0	71.6	39.0	0.0	0.0	116	26.6	0.0	0.0	151
15	86.3	72.3	43.1	0.0	0.0	71	30.0	0.0	0.0	119

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	Typical		----- Weekday -----			----- Saturday -----				
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	86.8	72.1	42.5	0.0	0.0	28	29.8	0.0	0.0	88
17	86.6	71.7	0.0	0.0	0.0	28	0.0	0.0	0.0	88
18	85.8	71.5	0.0	0.0	0.0	28	0.0	0.0	0.0	88
19	84.7	71.2	0.0	0.0	0.0	28	0.0	0.0	0.0	88
20	83.2	71.5	0.0	0.0	0.0	28	0.0	0.0	0.0	88
21	81.4	71.7	0.0	0.0	0.0	28	0.0	0.0	0.0	88
22	79.3	71.4	0.0	0.0	0.0	28	0.0	0.0	0.0	88
23	77.2	70.5	0.0	0.0	0.0	28	0.0	0.0	0.0	88
24	75.1	69.1	0.0	0.0	0.0	28	0.0	0.0	0.0	88

Hour	Typical		----- Sunday -----			----- Monday -----				
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	73.0	67.9	0.0	35.0	39.3	122	0.0	35.0	39.3	129
2	71.2	66.1	1.6	35.0	39.3	154	0.0	35.0	39.3	163
3	69.7	65.2	0.0	35.0	39.3	188	0.0	35.0	39.3	196
4	68.5	64.3	0.0	18.7	21.7	205	1.1	11.6	16.2	205
5	67.8	64.2	0.0	0.0	0.0	203	0.4	0.0	0.0	202
6	67.6	64.2	0.0	4.1	6.7	205	1.7	6.2	10.2	205
7	68.1	64.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
8	69.4	65.7	0.0	4.1	6.7	205	0.0	4.1	6.7	205
9	71.6	66.2	0.0	0.0	0.0	205	0.0	0.0	0.0	205
10	74.2	67.2	0.0	0.0	0.0	205	0.0	0.0	0.0	205
11	77.2	68.5	0.0	0.0	0.0	205	0.0	0.0	0.0	205
12	80.2	70.0	0.0	0.0	0.0	205	0.0	0.0	0.0	205
13	82.8	70.8	21.8	0.0	0.0	181	44.4	0.0	0.0	158
14	85.0	71.6	24.9	0.0	0.0	154	39.0	0.0	0.0	118
15	86.3	72.3	28.2	0.0	0.0	124	43.1	0.0	0.0	73
16	86.8	72.1	28.1	0.0	0.0	95	42.5	0.0	0.0	30
17	86.6	71.7	0.0	0.0	0.0	95	0.0	0.0	0.0	30
18	85.8	71.5	0.0	0.0	0.0	95	0.0	0.0	0.0	30
19	84.7	71.2	0.0	0.0	0.0	95	0.0	0.0	0.0	30
20	83.2	71.5	0.0	0.0	0.0	95	0.0	0.0	0.0	30
21	81.4	71.7	0.0	0.0	0.0	95	0.0	0.0	0.0	30
22	79.3	71.4	0.0	0.0	0.0	95	0.0	0.0	0.0	30
23	77.2	70.5	0.0	0.0	0.0	95	0.0	0.0	0.0	30
24	75.1	69.1	0.0	0.0	0.0	95	0.0	0.0	0.0	30

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

July

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	78.9	67.7	0.0	35.0	
2	78.2	67.2	0.0	35.0	40.3	99
3	77.6	66.8	0.0	35.0	40.1	133
4	77.1	66.6	0.0	35.0	39.9	167
5	77.0	66.6	0.0	35.0	39.9	200
6	77.3	66.9	0.0	6.5	10.8	205
7	78.0	67.6	0.0	0.0	0.0	203
8	79.4	68.8	0.0	4.1	6.9	205
9	81.3	69.6	0.0	0.0	0.0	205
10	83.6	70.7	0.0	0.0	0.0	205
11	86.1	72.2	0.0	0.0	0.0	205
12	88.5	73.3	0.0	0.0	0.0	205
13	90.3	74.0	54.9	0.0	0.0	148
14	91.5	74.3	49.0	0.0	0.0	97
15	92.0	74.0	51.2	0.0	0.0	45
16	91.5	73.2	49.9	0.0	0.0	0
17	90.5	72.1	0.0	0.0	0.0	0
18	88.8	70.8	0.0	0.0	0.0	0
19	86.9	70.4	0.0	0.0	0.0	0
20	84.9	70.2	0.0	0.0	0.0	0
21	83.3	70.0	0.0	0.0	0.0	0
22	81.8	69.4	0.0	0.0	0.0	0
23	80.6	68.7	0.0	0.0	0.0	0
24	79.7	68.4	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	72.0	69.3	0.0	35.0	39.3	35	0.0	35.0	39.3
2	70.5	68.0	0.0	35.0	39.3	70	0.0	35.0	39.3	91
3	69.4	67.1	0.0	35.0	39.3	104	0.0	35.0	39.3	125
4	68.5	66.4	1.0	35.0	39.3	137	1.0	35.0	39.3	157
5	67.9	66.0	0.3	35.0	39.3	170	0.3	35.0	39.3	191
6	67.7	65.9	1.4	35.0	39.3	202	1.4	17.5	20.7	205
7	68.1	66.3	0.0	4.6	7.5	205	0.0	0.0	0.0	203
8	69.1	67.3	0.0	0.0	0.0	203	0.0	4.1	6.7	205
9	70.8	68.0	0.0	0.0	0.0	203	0.0	0.0	0.0	205
10	72.9	69.1	0.0	0.0	0.0	203	0.0	0.0	0.0	205
11	75.2	70.5	0.0	0.0	0.0	203	0.0	0.0	0.0	205
12	77.5	71.7	0.0	0.0	0.0	203	0.0	0.0	0.0	205
13	79.6	72.7	46.4	0.0	0.0	154	24.1	0.0	0.0	179
14	81.3	73.5	41.6	0.0	0.0	111	28.0	0.0	0.0	149
15	82.3	73.7	44.7	0.0	0.0	65	30.6	0.0	0.0	117

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	82.7	73.5	43.3	0.0	0.0	21	29.9	0.0	0.0	86
17	82.5	73.1	0.0	0.0	0.0	21	0.0	0.0	0.0	86
18	82.0	72.6	0.0	0.0	0.0	21	0.0	0.0	0.0	86
19	81.1	73.2	0.0	0.0	0.0	21	0.0	0.0	0.0	86
20	79.9	73.8	0.0	0.0	0.0	21	0.0	0.0	0.0	86
21	78.5	73.9	0.0	0.0	0.0	21	0.0	0.0	0.0	86
22	76.9	73.1	0.0	0.0	0.0	21	0.0	0.0	0.0	86
23	75.2	71.9	0.0	0.0	0.0	21	0.0	0.0	0.0	86
24	73.5	70.8	0.0	0.0	0.0	21	0.0	0.0	0.0	86

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	72.0	69.3	0.0	35.0	39.3	120	0.0	35.0	39.3	127
2	70.5	68.0	0.8	35.0	39.3	153	0.0	35.0	39.3	161
3	69.4	67.1	0.0	35.0	39.3	186	0.0	35.0	39.3	195
4	68.5	66.4	0.0	20.4	23.3	205	1.0	13.2	17.3	205
5	67.9	66.0	0.0	0.0	0.0	203	0.3	0.0	0.0	202
6	67.7	65.9	0.0	4.1	6.7	205	1.4	5.8	9.4	205
7	68.1	66.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
8	69.1	67.3	0.0	4.1	6.7	205	0.0	4.1	6.7	205
9	70.8	68.0	0.0	0.0	0.0	205	0.0	0.0	0.0	205
10	72.9	69.1	0.0	0.0	0.0	205	0.0	0.0	0.0	205
11	75.2	70.5	0.0	0.0	0.0	205	0.0	0.0	0.0	205
12	77.5	71.7	0.0	0.0	0.0	205	0.0	0.0	0.0	205
13	79.6	72.7	22.1	0.0	0.0	181	46.4	0.0	0.0	156
14	81.3	73.5	26.0	0.0	0.0	153	41.6	0.0	0.0	113
15	82.3	73.7	28.6	0.0	0.0	123	44.7	0.0	0.0	67
16	82.7	73.5	28.1	0.0	0.0	93	43.3	0.0	0.0	23
17	82.5	73.1	0.0	0.0	0.0	93	0.0	0.0	0.0	23
18	82.0	72.6	0.0	0.0	0.0	93	0.0	0.0	0.0	23
19	81.1	73.2	0.0	0.0	0.0	93	0.0	0.0	0.0	23
20	79.9	73.8	0.0	0.0	0.0	93	0.0	0.0	0.0	23
21	78.5	73.9	0.0	0.0	0.0	93	0.0	0.0	0.0	23
22	76.9	73.1	0.0	0.0	0.0	93	0.0	0.0	0.0	23
23	75.2	71.9	0.0	0.0	0.0	93	0.0	0.0	0.0	23
24	73.5	70.8	0.0	0.0	0.0	93	0.0	0.0	0.0	23

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

August

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	78.6	67.6	0.0	35.0	
2	77.9	67.2	0.0	35.0	40.2	93
3	77.2	66.9	0.0	35.0	40.0	127
4	76.8	66.6	0.0	35.0	39.9	160
5	76.6	66.7	0.0	35.0	39.8	194
6	76.9	67.1	0.0	12.9	17.4	205
7	77.7	67.8	0.0	0.0	0.0	203
8	79.1	69.0	0.0	4.1	6.9	205
9	81.2	70.0	0.0	0.0	0.0	205
10	83.5	70.9	0.0	0.0	0.0	205
11	86.2	71.8	0.0	0.0	0.0	205
12	88.7	72.7	0.0	0.0	0.0	205
13	90.6	73.2	53.1	0.0	0.0	150
14	91.8	73.8	49.3	0.0	0.0	99
15	92.3	74.0	51.8	0.0	0.0	46
16	91.8	73.3	50.4	0.0	0.0	0
17	90.7	72.4	0.0	0.0	0.0	0
18	89.0	71.4	0.0	0.0	0.0	0
19	87.0	70.1	0.0	0.0	0.0	0
20	84.9	69.8	0.0	0.0	0.0	0
21	83.2	70.3	0.0	0.0	0.0	0
22	81.6	69.3	0.0	0.0	0.0	0
23	80.4	68.5	0.0	0.0	0.0	0
24	79.4	67.9	0.0	0.0	0.0	0

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	72.7	70.2	0.0	35.0	39.3	35	0.0	35.0	39.3
2	71.2	69.0	0.0	35.0	39.3	70	0.0	35.0	39.3	98
3	69.9	68.0	0.0	35.0	39.3	104	0.0	35.0	39.3	132
4	68.8	67.1	1.5	35.0	39.3	136	1.5	35.0	39.3	164
5	68.0	66.6	0.5	35.0	39.3	170	0.5	35.0	39.3	197
6	67.5	66.2	0.5	35.0	39.3	202	0.5	10.1	15.2	205
7	67.3	66.1	0.0	4.3	7.1	205	0.0	0.0	0.0	203
8	67.8	66.5	0.0	0.0	0.0	203	0.0	4.1	6.7	205
9	69.1	67.0	0.0	0.0	0.0	203	0.0	0.0	0.0	205
10	71.2	67.8	0.0	0.0	0.0	203	0.0	0.0	0.0	205
11	73.8	68.7	0.0	0.0	0.0	203	0.0	0.0	0.0	205
12	76.5	70.0	0.0	0.0	0.0	203	0.0	0.0	0.0	205
13	79.1	71.2	43.5	0.0	0.0	157	21.9	0.0	0.0	181
14	81.1	72.6	39.4	0.0	0.0	116	26.1	0.0	0.0	153
15	82.5	73.6	42.8	0.0	0.0	72	29.2	0.0	0.0	122

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	83.0	73.7	42.5	0.0	0.0	29	28.9	0.0	0.0	92
17	82.8	73.5	0.0	0.0	0.0	29	0.0	0.0	0.0	92
18	82.3	73.5	0.0	0.0	0.0	29	0.0	0.0	0.0	92
19	81.5	73.1	0.0	0.0	0.0	29	0.0	0.0	0.0	92
20	80.4	73.7	0.0	0.0	0.0	29	0.0	0.0	0.0	92
21	79.1	74.9	0.0	0.0	0.0	29	0.0	0.0	0.0	92
22	77.6	73.9	0.0	0.0	0.0	29	0.0	0.0	0.0	92
23	76.0	72.7	0.0	0.0	0.0	29	0.0	0.0	0.0	92
24	74.3	71.3	0.0	0.0	0.0	29	0.0	0.0	0.0	92

Hour	Typical		Sunday				Monday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	72.7	70.2	0.0	35.0	39.3	126	0.0	35.0	39.3	134
2	71.2	69.0	1.6	35.0	39.3	158	0.0	35.0	39.3	167
3	69.9	68.0	0.0	35.0	39.3	192	0.0	35.0	39.3	201
4	68.8	67.1	0.0	14.9	18.6	205	1.5	7.5	12.3	205
5	68.0	66.6	0.0	0.0	0.0	203	0.5	0.0	0.0	202
6	67.5	66.2	0.0	4.1	6.7	205	0.5	5.0	8.3	205
7	67.3	66.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
8	67.8	66.5	0.0	4.1	6.7	205	0.0	4.1	6.7	205
9	69.1	67.0	0.0	0.0	0.0	205	0.0	0.0	0.0	205
10	71.2	67.8	0.0	0.0	0.0	205	0.0	0.0	0.0	205
11	73.8	68.7	0.0	0.0	0.0	205	0.0	0.0	0.0	205
12	76.5	70.0	0.0	0.0	0.0	205	0.0	0.0	0.0	205
13	79.1	71.2	19.9	0.0	0.0	183	43.5	0.0	0.0	159
14	81.1	72.6	24.2	0.0	0.0	157	39.4	0.0	0.0	118
15	82.5	73.6	27.3	0.0	0.0	128	42.8	0.0	0.0	74
16	83.0	73.7	26.9	0.0	0.0	100	42.5	0.0	0.0	31
17	82.8	73.5	0.0	0.0	0.0	100	0.0	0.0	0.0	31
18	82.3	73.5	0.0	0.0	0.0	100	0.0	0.0	0.0	31
19	81.5	73.1	0.0	0.0	0.0	100	0.0	0.0	0.0	31
20	80.4	73.7	0.0	0.0	0.0	100	0.0	0.0	0.0	31
21	79.1	74.9	0.0	0.0	0.0	100	0.0	0.0	0.0	31
22	77.6	73.9	0.0	0.0	0.0	100	0.0	0.0	0.0	31
23	76.0	72.7	0.0	0.0	0.0	100	0.0	0.0	0.0	31
24	74.3	71.3	0.0	0.0	0.0	100	0.0	0.0	0.0	31

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

September

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	74.6	63.1	0.0	35.0	39.3	66
2	73.7	62.4	0.0	35.0	39.3	100
3	73.0	61.9	0.0	35.0	39.3	134
4	72.4	61.7	0.0	35.0	39.3	168
5	72.3	61.8	0.0	35.0	39.3	201
6	72.6	62.5	0.0	5.8	9.5	205
7	73.5	63.2	0.0	0.0	0.0	203
8	75.1	64.8	0.0	4.1	6.7	205
9	77.4	65.9	0.0	0.0	0.0	205
10	80.0	66.8	0.0	0.0	0.0	205
11	83.0	67.8	0.0	0.0	0.0	205
12	85.8	68.5	0.0	0.0	0.0	205
13	87.9	69.7	46.8	0.0	0.0	156
14	89.3	70.2	42.1	0.0	0.0	112
15	89.9	70.1	44.0	0.0	0.0	67
16	89.3	69.1	42.5	0.0	0.0	24
17	88.1	67.8	0.0	0.0	0.0	24
18	86.2	66.8	0.0	0.0	0.0	24
19	83.9	66.5	0.0	0.0	0.0	24
20	81.6	66.3	0.0	0.0	0.0	24
21	79.7	66.1	0.0	0.0	0.0	24
22	77.9	65.0	0.0	0.0	0.0	24
23	76.5	64.4	0.0	0.0	0.0	24
24	75.4	63.6	0.0	0.0	0.0	24

Hour	Typical		Weekday				Saturday			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	69.8	66.1	0.0	35.0	39.3	59	0.0	35.0	39.3	105
2	68.0	64.5	0.8	35.0	39.3	92	0.8	35.0	39.3	138
3	66.3	63.0	0.0	35.0	39.3	126	0.0	35.0	39.3	172
4	64.9	61.9	0.0	35.0	39.3	160	0.0	34.6	38.8	205
5	63.9	61.3	0.0	35.0	39.3	194	0.0	0.0	0.0	203
6	63.2	61.0	0.0	13.0	17.2	205	0.0	4.1	6.7	205
7	63.0	60.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
8	63.4	61.4	0.0	4.1	6.7	205	0.0	4.1	6.7	205
9	64.7	61.8	0.0	0.0	0.0	205	0.0	0.0	0.0	205
10	66.6	62.1	0.0	0.0	0.0	205	0.0	0.0	0.0	205
11	69.1	62.9	0.0	0.0	0.0	205	0.0	0.0	0.0	205
12	71.8	63.7	0.0	0.0	0.0	205	0.0	0.0	0.0	205
13	74.5	65.5	32.8	0.0	0.0	170	10.7	0.0	0.0	192
14	77.0	67.1	28.8	0.0	0.0	139	16.7	0.0	0.0	173
15	78.9	68.2	32.3	0.0	0.0	106	19.4	0.0	0.0	152

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	Typical		----- Weekday -----				----- Saturday -----			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
16	80.2	68.6	33.8	0.0	0.0	71	20.9	0.0	0.0	130
17	80.6	68.5	0.0	0.0	0.0	71	0.0	0.0	0.0	130
18	80.4	68.9	0.0	0.0	0.0	71	0.0	0.0	0.0	130
19	79.7	70.0	0.0	0.0	0.0	71	0.0	0.0	0.0	130
20	78.7	71.2	0.0	0.0	0.0	71	0.0	0.0	0.0	130
21	77.3	71.6	0.0	0.0	0.0	71	0.0	0.0	0.0	130
22	75.6	70.5	0.0	0.0	0.0	71	0.0	0.0	0.0	130
23	73.7	69.4	0.0	0.0	0.0	71	0.0	0.0	0.0	130
24	71.8	67.7	0.0	0.0	0.0	71	0.0	0.0	0.0	130

Hour	Typical		----- Sunday -----				----- Monday -----			
	OADB (F)	QAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	69.8	66.1	0.2	35.0	39.3	163	0.0	35.0	39.3	180
2	68.0	64.5	0.0	35.0	39.3	197	0.9	27.4	30.3	205
3	66.3	63.0	0.0	10.0	15.1	205	0.0	0.0	0.0	203
4	64.9	61.9	0.0	0.0	0.0	203	0.0	4.1	6.7	205
5	63.9	61.3	0.0	4.1	6.7	205	0.0	0.0	0.0	203
6	63.2	61.0	0.0	0.0	0.0	203	0.0	4.1	6.7	205
7	63.0	60.8	0.0	4.1	6.7	205	0.0	0.0	0.0	203
8	63.4	61.4	0.0	0.0	0.0	203	0.0	4.1	6.7	205
9	64.7	61.8	0.0	0.0	0.0	203	0.0	0.0	0.0	205
10	66.6	62.1	0.0	0.0	0.0	203	0.0	0.0	0.0	205
11	69.1	62.9	0.0	0.0	0.0	203	0.0	0.0	0.0	205
12	71.8	63.7	0.0	0.0	0.0	203	0.0	0.0	0.0	205
13	74.5	65.5	1.3	0.0	0.0	199	32.8	0.0	0.0	170
14	77.0	67.1	10.1	0.0	0.0	187	28.8	0.0	0.0	139
15	78.9	68.2	18.1	0.0	0.0	167	32.3	0.0	0.0	106
16	80.2	68.6	19.2	0.0	0.0	146	33.8	0.0	0.0	71
17	80.6	68.5	0.0	0.0	0.0	146	0.0	0.0	0.0	71
18	80.4	68.9	0.0	0.0	0.0	146	0.0	0.0	0.0	71
19	79.7	70.0	0.0	0.0	0.0	146	0.0	0.0	0.0	71
20	78.7	71.2	0.0	0.0	0.0	146	0.0	0.0	0.0	71
21	77.3	71.6	0.0	0.0	0.0	146	0.0	0.0	0.0	71
22	75.6	70.5	0.0	0.0	0.0	146	0.0	0.0	0.0	71
23	73.7	69.4	0.0	0.0	0.0	146	0.0	0.0	0.0	71
24	71.8	67.7	0.0	0.0	0.0	146	0.0	0.0	0.0	71

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

--- BUILDING COOLING DEMANDS AND THERMAL STORAGE ---

October

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	59.5	50.0	0.0	35.0	39.3	105
2	58.5	49.3	0.0	35.0	39.3	139
3	57.7	48.8	0.0	35.0	39.3	173
4	57.1	48.5	0.0	33.8	37.7	205
5	56.9	48.3	0.0	0.0	0.0	203
6	57.3	48.7	0.0	4.1	6.7	205
7	58.3	49.7	0.0	0.0	0.0	203
8	60.1	51.3	0.0	4.1	6.7	205
9	62.7	52.9	0.0	0.0	0.0	205
10	65.7	54.4	0.0	0.0	0.0	205
11	69.1	55.5	0.0	0.0	0.0	205
12	72.3	56.7	0.0	0.0	0.0	205
13	74.7	57.8	25.0	0.0	0.0	178
14	76.3	58.6	25.2	0.0	0.0	151
15	76.9	58.7	26.8	0.0	0.0	122
16	76.3	58.0	26.3	0.0	0.0	95
17	74.9	57.0	0.0	0.0	0.0	95
18	72.7	56.0	0.0	0.0	0.0	95
19	70.1	55.5	0.0	0.0	0.0	95
20	67.5	54.7	0.0	0.0	0.0	95
21	65.3	53.6	0.0	0.0	0.0	95
22	63.3	52.4	0.0	0.0	0.0	95
23	61.7	51.5	0.0	0.0	0.0	95
24	60.5	50.7	0.0	0.0	0.0	95

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	54.8	51.3	0.0	35.0	39.3	129	0.0	35.0	39.3	204
2	52.9	49.6	0.0	35.0	39.3	163	0.0	2.8	4.6	205
3	51.2	48.2	0.0	35.0	39.3	196	0.0	0.0	0.0	203
4	49.8	47.2	0.0	10.7	15.6	205	0.0	4.1	6.7	205
5	48.8	46.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
6	48.2	45.7	0.0	4.1	6.7	205	0.0	4.1	6.7	205
7	47.9	45.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203
8	48.5	46.2	0.0	4.1	6.7	205	0.0	4.1	6.7	205
9	50.3	47.3	0.0	0.0	0.0	205	0.0	0.0	0.0	205
10	52.9	48.7	0.0	0.0	0.0	205	0.0	0.0	0.0	205
11	56.2	49.9	0.0	0.0	0.0	205	0.0	0.0	0.0	205
12	59.6	51.5	0.0	0.0	0.0	205	0.0	0.0	0.0	205
13	62.9	53.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203
14	65.5	55.2	3.7	0.0	0.0	197	0.0	0.0	0.0	201
15	67.3	56.3	11.1	0.0	0.0	184	0.0	0.0	0.0	199

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	----- Weekday -----						----- Saturday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
16	67.9	56.6	11.4	0.0	0.0	171	0.0	0.0	0.0	197	
17	67.7	56.4	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
18	67.0	56.6	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
19	66.0	57.6	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
20	64.6	57.9	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
21	62.9	57.3	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
22	61.0	56.0	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
23	59.0	54.8	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
24	56.9	53.0	0.0	0.0	0.0	171	0.0	0.0	0.0	197	
Hour	----- Sunday -----						----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	
	OADB (F)	OAWB (F)									
1	54.8	51.3	0.0	10.0	15.1	205	0.0	12.0	16.5	205	
2	52.9	49.6	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
3	51.2	48.2	0.0	4.1	6.7	205	0.0	4.1	6.7	205	
4	49.8	47.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
5	48.8	46.2	0.0	4.1	6.7	205	0.0	4.1	6.7	205	
6	48.2	45.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
7	47.9	45.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205	
8	48.5	46.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
9	50.3	47.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
10	52.9	48.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
11	56.2	49.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
12	59.6	51.5	0.0	0.0	0.0	203	0.0	0.0	0.0	203	
13	62.9	53.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201	
14	65.5	55.2	0.0	0.0	0.0	199	0.0	0.0	0.0	199	
15	67.3	56.3	0.0	0.0	0.0	197	0.0	0.0	0.0	197	
16	67.9	56.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
17	67.7	56.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
18	67.0	56.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
19	66.0	57.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
20	64.6	57.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
21	62.9	57.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
22	61.0	56.0	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
23	59.0	54.8	0.0	0.0	0.0	195	0.0	0.0	0.0	195	
24	56.9	53.0	0.0	0.0	0.0	195	0.0	0.0	0.0	195	

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

----- BUILDING COOLING DEMANDS AND THERMAL STORAGE -----

November

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
1	56.0	47.2	0.0	12.0	16.5	205
2	55.0	46.4	0.0	0.0	0.0	203
3	54.2	45.8	0.0	4.1	6.7	205
4	53.6	45.2	0.0	0.0	0.0	203
5	53.4	45.3	0.0	4.1	6.7	205
6	53.8	45.9	0.0	0.0	0.0	203
7	54.8	46.9	0.0	4.1	6.7	205
8	56.6	48.7	0.0	0.0	0.0	203
9	59.2	50.6	0.0	0.0	0.0	203
10	62.2	52.6	0.0	0.0	0.0	203
11	65.6	54.1	0.0	0.0	0.0	203
12	68.8	55.3	0.0	0.0	0.0	203
13	71.2	55.7	0.0	0.0	0.0	201
14	72.8	56.3	0.0	0.0	0.0	199
15	73.4	56.2	0.0	0.0	0.0	197
16	72.8	55.6	0.0	0.0	0.0	195
17	71.4	54.6	0.0	0.0	0.0	195
18	69.2	53.6	0.0	0.0	0.0	195
19	66.6	53.0	0.0	0.0	0.0	195
20	64.0	51.7	0.0	0.0	0.0	195
21	61.8	50.7	0.0	0.0	0.0	195
22	59.8	49.6	0.0	0.0	0.0	195
23	58.2	48.7	0.0	0.0	0.0	195
24	57.0	48.0	0.0	0.0	0.0	195

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
1	48.7	45.7	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	46.9	44.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	45.5	42.8	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	44.6	41.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	44.4	42.0	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	44.8	42.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	45.9	43.9	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	47.8	46.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	50.2	48.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	52.9	49.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	55.8	51.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	58.5	52.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	60.9	52.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	62.8	53.4	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	64.0	53.8	0.0	0.0	0.0	197	0.0	0.0	0.0	197

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	64.4	53.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	64.1	53.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	63.2	53.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	61.8	54.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	60.0	53.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	57.9	52.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	55.6	51.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	53.2	49.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	50.8	47.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195

Hour	----- Sunday -----						----- Monday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	48.7	45.7	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	46.9	44.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	45.5	42.8	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	44.6	41.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	44.4	42.0	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	44.8	42.7	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	45.9	43.9	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	47.8	46.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	50.2	48.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	52.9	49.9	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	55.8	51.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	58.5	52.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	60.9	52.5	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	62.8	53.4	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	64.0	53.8	0.0	0.0	0.0	197	0.0	0.0	0.0	197
16	64.4	53.9	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	64.1	53.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	63.2	53.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	61.8	54.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	60.0	53.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	57.9	52.7	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	55.6	51.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	53.2	49.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	50.8	47.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

---- BUILDING COOLING DEMANDS AND THERMAL STORAGE ----

December

Hour	Design		Design			Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	
	1	48.2	40.8	0.0	12.0	
2	47.3	40.2	0.0	0.0	0.0	203
3	46.6	39.7	0.0	4.1	6.7	205
4	46.1	39.3	0.0	0.0	0.0	203
5	45.9	39.4	0.0	4.1	6.7	205
6	46.3	39.7	0.0	0.0	0.0	203
7	47.1	40.6	0.0	4.1	6.7	205
8	48.7	42.0	0.0	0.0	0.0	203
9	50.9	44.0	0.0	0.0	0.0	203
10	53.5	46.1	0.0	0.0	0.0	203
11	56.5	48.0	0.0	0.0	0.0	203
12	59.2	49.7	0.0	0.0	0.0	203
13	61.3	50.8	0.0	0.0	0.0	201
14	62.7	51.4	0.0	0.0	0.0	199
15	63.2	51.4	0.0	0.0	0.0	197
16	62.7	50.7	0.0	0.0	0.0	195
17	61.5	49.7	0.0	0.0	0.0	195
18	59.6	48.5	0.0	0.0	0.0	195
19	57.3	47.6	0.0	0.0	0.0	195
20	55.1	45.9	0.0	0.0	0.0	195
21	53.2	44.6	0.0	0.0	0.0	195
22	51.5	43.1	0.0	0.0	0.0	195
23	50.1	42.2	0.0	0.0	0.0	195
24	49.0	41.5	0.0	0.0	0.0	195

Hour	Typical		Weekday				Saturday			
	OADB (F)	OAWB (F)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	1	37.5	35.3	0.0	12.0	16.5	205	0.0	12.0	16.5
2	37.1	35.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	37.4	35.5	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	38.1	36.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	39.3	37.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	40.9	39.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	42.7	41.2	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	44.7	43.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	46.8	45.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	48.8	47.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	50.7	48.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	52.2	48.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	53.4	49.2	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	54.1	49.2	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	54.4	48.9	0.0	0.0	0.0	197	0.0	0.0	0.0	197

COLD THERMAL STORAGE - ALTERNATIVE 1
 BLDG M500, ECO#13

Hour	----- Weekday -----						----- Saturday -----			
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
16	54.0	48.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	53.0	47.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	51.4	46.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	49.3	45.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	47.0	43.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	44.5	41.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	42.2	39.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	40.1	37.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	38.5	36.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195

Hour	----- Sunday -----					----- Monday -----				
	Typical		Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)	Cooling Load (Ton)	Chiller Load (Ton)	Chiller Demand (kW)	Storage Capacity (Ton-Hr)
	OADB (F)	OAWB (F)								
1	37.5	35.3	0.0	12.0	16.5	205	0.0	12.0	16.5	205
2	37.1	35.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
3	37.4	35.5	0.0	4.1	6.7	205	0.0	4.1	6.7	205
4	38.1	36.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
5	39.3	37.6	0.0	4.1	6.7	205	0.0	4.1	6.7	205
6	40.9	39.2	0.0	0.0	0.0	203	0.0	0.0	0.0	203
7	42.7	41.2	0.0	4.1	6.7	205	0.0	4.1	6.7	205
8	44.7	43.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
9	46.8	45.3	0.0	0.0	0.0	203	0.0	0.0	0.0	203
10	48.8	47.0	0.0	0.0	0.0	203	0.0	0.0	0.0	203
11	50.7	48.1	0.0	0.0	0.0	203	0.0	0.0	0.0	203
12	52.2	48.8	0.0	0.0	0.0	203	0.0	0.0	0.0	203
13	53.4	49.2	0.0	0.0	0.0	201	0.0	0.0	0.0	201
14	54.1	49.2	0.0	0.0	0.0	199	0.0	0.0	0.0	199
15	54.4	48.9	0.0	0.0	0.0	197	0.0	0.0	0.0	197
16	54.0	48.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195
17	53.0	47.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
18	51.4	46.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
19	49.3	45.4	0.0	0.0	0.0	195	0.0	0.0	0.0	195
20	47.0	43.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
21	44.5	41.5	0.0	0.0	0.0	195	0.0	0.0	0.0	195
22	42.2	39.3	0.0	0.0	0.0	195	0.0	0.0	0.0	195
23	40.1	37.6	0.0	0.0	0.0	195	0.0	0.0	0.0	195
24	38.5	36.2	0.0	0.0	0.0	195	0.0	0.0	0.0	195

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M500, ECO#13

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 27,466
 ACM Multiplier 1.025

----- ENERGY USE SUMMARY -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	2,949.0	522,952.4	21.8	580,674.2	21.7
Primary Cooling					
Compressor	83,641.3	0.0	11.7	856,488.9	32.0
Tower/Cond Fans	5,634.1	0.0	0.8	57,693.5	2.2
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	3,238.6	0.0	0.5	33,163.3	1.2
Auxiliary					
Supply Fans	244,087.6	0.0	34.1	2,499,462.5	93.3
Circulation Pumps	19,923.4	0.0	2.8	204,016.0	7.6
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	264,010.9	0.0	36.9	2,703,478.3	100.9
Lighting	60,841.8	0.0	8.5	623,021.1	22.7
Receptacle	142,768.4	0.0	19.9	1,461,952.1	53.2
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	563,084.2	522,952.4	100.0	6,316,471.5	233.8

BUILDING 514

EMC ENGINEERS, INC.

PROJECT: FORT McPHERSON & FORT GILLEM ESOS STUDY
 LOCATION: FORT McPHERSON
 ECO: Computer Simulation Summary

EMC PROJECT: #3105.000
 DATE: 10-APR-92
 FILE: M514ECO.WK3
 PREPARED BY: JIM WATTERS
 CHECKED BY:

CLIENT CONTRACT NO: DACA21-91-C-0097
 CLIENT PROJECT ENG: TERRY SEABROOK

Bldg: M514 Area: 9,744 ft²

Run Description	Heating Gas Use (kBtu/yr)	Heating Electric Use (kWh/yr)	Cooling Electric Use (kWh/yr)	Fan Electric Use (kWh/yr)	Pump Electric Use (kWh/yr)	Lighting Electric Use (kWh/yr)	Recept. Electric Use (kWh/yr)	Total Electric Use (kWh/yr)	Peak Electric Demand (kW)	Total Gas Use (MBtu/yr)	Total Energy Use (Mbtu/yr)
Baseline	23,160	1,165	22,984	68,724	0	52,797	5,400	151,070	46	23	539
ECO#6	23,160	1,165	21,783	68,724	0	52,797	5,400	149,868	46	23	535
Savings/(Loss)	0	0	1,202	0	0	0	0	1,202	0	0	4
ECO#12	5,964	142	3,721	23,725	0	52,797	5,400	85,784	41	6	299
Savings/(Loss)	17,196	1,023	19,263	44,999	0	0	0	65,286	5	17	240

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
SHEET NO. _____ OF _____
CALCULATED BY JW DATE 3/3/92
CHECKED BY _____ DATE _____
SCALE _____

COMPUTER SIMULATION BLDG 514 BASE RUN

BLDG. TYPE : ~~GAUL BLOCK W/ STUCCO~~ LRU Admin
AREA = ~~8704 ft²~~
9744 ft²
ECO : 12

ASSUMPTIONS

- ~~- OCCUPANCY : 25 people~~
- ~~- INFILTRATION : $\frac{1}{2}$ ACH~~
- ~~- WINDOW U VALUE : 0.8~~
- ~~- LIGHTS : 2.2 WATTS/ft²~~
- HEATING db : 72°F
- COOLING db : 76°F
- ~~- MISC. LOAD : 4.1 kW~~
- ~~- SLAB METHOD : $F_s = 0.62$~~

JOB 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY JW DATE 2/24/92
 CHECKED BY _____ DATE _____
 SCALE _____

E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

BLOG 514


TRACE 600 ENERGY SIMULATION BASE RUN

~~BUILDING ORIENTATION: 270~~

~~WALL TYPE BLOG TYPE: 8" CONC. BLOCK WALL w/ TEXTURED
 EXTERIOR MASONRY COATING.
 STYROFOAM BETWEEN FURRING STRIPS
 5/8" GYP BOARD ON 1" FURRING STRIPS~~

~~BLDG TYPE: CHILD CARE CENTER
 SQUARE FT: ~~7616~~ 8704 ft²~~

WALL U VALUE




OA ⇒
 8" CONC. BLOCK ⇒
 5/8 GYP BOARD ⇒
 STYROFOAM ⇒
 INSIDE AIR ⇒

R-VALUE

0.17
 0.20
~~1.7~~
 0.56
 2.5
 + 0.68
 5.81

$U = \frac{1}{5.61} = \boxed{0.17}$

ROOF U-VALUE



OA ⇒
 SHINGLES ⇒
 3/4" PLYWOOD ⇒
 AIR SPACE ⇒
 PLYWOOD CEILING ⇒
 INSIDE ⇒
 R-19 ⇒

R-VALUE

0.17
 0.44
 0.93
 1.24
 0.62
 0.62
 19.0
 23.02

$U = \frac{1}{R} = \boxed{0.043}$

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 2/24/92

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 514

WINDOW U-VALUE - ASHRAE TABLE F 27.13

Double Pane, Aluminum Frame, Sliding

$U = \boxed{0.70}$

Shading Coefficient - ASHRAE Table F 27.26

- light Venetian blinds

$\Rightarrow \boxed{0.58}$

PEOPLE

60 people - Account for 30 Adults + 60 children (1/2 adult)

SENSIBLE: $250 \frac{\text{BTU}}{\text{hr} \cdot \text{Per}}$

LATENT: $250 \frac{\text{BTU}}{\text{hr} \cdot \text{Per}}$

ASHRAE TABLE 26.3

LIGHTS

FROM LIGHTING PLANS :

TOTAL WATTS

ADDITION TO 514 \Rightarrow

7577

NAW BLDG

11470

$\boxed{19,067}$ Watts

MISC LOADS

HEAT GAIN
(WATTS)

For Peak

- MICROWAVE
- FULL SIZE REFRIGERATOR
- STOVE
- DISHWASHER
- WASHER
- DRYER
- TV
- COFFEE MAKER
- COKE MACHINE

- 65
- 200
- 1250
- 700
- 375
- 750
- 200
- 260
- 300

- 200
- 1250
-
-
-
-
- 200
-
-
- 300

$\boxed{1,950}$ Watts

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Computer Simulation Bldg 514, McPherson

ECO # 12 - HVAC Controls

- Set back thermostats with new setpoints: 78°F cooling & 70°F heating
- Thermostat on fan: on 06:00 - 18:00 M-F, otherwise off
- Reset AHU Back temperature for demand

Electric Savings

Total Electric Savings = 65,286 kWh/yr

Demand Savings

Peak Demand Savings = 5 kW

Gas Savings

Total Gas Savings = 17 MBtu/yr

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

COMPUTER SIMULATION

BLDG 514, McPHERSON

ECO # 6

- DRY BULB ECONOMISER

ELECTRIC SAVINGS

1,202
~~305~~

TOTAL ELECTRIC SAVINGS = 0 KWH/YR

DEMAND SAVINGS

PEAK DEMAND SAVINGS = 0 KW

GAS SAVINGS

TOTAL GAS SAVINGS = 0 MBTU/YR

01 Card - Job Information

 Project: FT MCPHERSON & FT GILLEM EEAP
 Location: FT MCPHERSON, BLDG. 514
 Program User: J. WATTERS

-----CARD 08-- Climatic Information -----

	Summer	Winter	Summer	Summer	Winter		Summer	Winter
Weather Code	Clearness Number	Clearness Number	Design Dry Bulb	Design Wet Bulb	Design Dry Bulb	Building Orientation	Ground Reflect	Ground Reflect
ATLANTA								

-----CARD 09-- Load Simulation Periods-----

	1st Month	Last Month	Peak	1st Month	Last Month	1st Month	Last Month
Cooling Simulation	Cooling Simulation	Cooling Load Hr	Summer Period	Summer Period	Daylight Savings	Daylight Savings	
MAY							OCT

----- Load Section Alternative #1 -----

---- Load Alternative ----

Number	Description
1	BLDG M514, BASELINE

-----CARD 20-- General Room Parameters -----

Room Number	Zone	Reference Room	Room Description	Floor Length	Floor Width	Const Type	Plenum Height	Acoustic Ceiling Resistance	Floor to Ceiling Height	Duplicate Floors Multiplier	Duplicate Rooms per Zone	Perimeter Depth
1		1	WHOLE BUILDING	174	56		1		9			

-----CARD 21-- Thermostat Parameters -----

Room Number	Cooling Room Design DB	Room Design RH	Cooling T'stat Driftpoint	Cooling T'stat Schedule	Heating Room Design DB	Heating T'stat Driftpoint	Heating T'stat Schedule	Heating T'stat Location	T'stat Flag	Mass / No. Hrs Average	Carpet On Floor
1	76			CLG	72		HTG				

-----CARD 22-- Roof Parameters -----

Room Number	Roof Number	Roof Equal to Floor?	Roof Length	Roof Width	Roof U-Value	Const Type	Roof Direction	Roof Tilt	Roof Alpha
1	1	NO	174	80	.043	34	90	65	

-----CARD 24-- Wall Parameters -----

Room Number	Wall Number	Wall Length	Wall Height	Wall U-Value	Wall Constuc Type	Wall Direction	Wall Tilt	Wall Alpha	Ground Reflectance Multiplier
1	1	174	10	.17	95	270			
1	2	56	10	.17	95	0			
1	3	174	10	.17	95	90			
1	4	56	10	.17	95	180			

-----CARD 25-- Wall/Glass Parameters -----

Room Number	Wall Number	Glass Length	Glass Width	Pct Glass or No. of Windows	Glass U-Value	Shading Coefficient	External Shading Type	Internal Shading Type	Percent Solar Ret. Air	Visible Transmittance	Inside Visible Reflectance
1	1	4	2.5	10	.7	.58					
1	2	4	2.5	6	.7	.58					
1	3	4	2.5	7	.7	.58					
1	4	4	2.5	6	.7	.58					

-----CARD 26-- Schedules -----

Room Number	People	Lights	Ventilation	Infiltration	Reheat Minimum	Cooling Fans	Heating Fan	Auxiliary Fan	Room Exhaust	Daylighting Controls
1	ADMPPL	ADMLGTEQ	AVAIL	OFF		AVAIL				

-----CARD 27-- People and Lights -----

Room Number	People Value	People Units	People Sensible	People Latent	Lighting Value	Lighting Units	Lighting Fixture Type	Ballast Factor	Percent Lights to Ret. Air	--- Daylighting --- Reference Point 1	Reference Point 2
1	60	PEOPLE	250	250	19067	WATTS					

-----CARD 28-- Miscellaneous Equipment -----

Room Number	Misc Equipment Number	Equipment Descrip	Energy Consump Value	Energy Consump Units	Schedule Code	Energy Meter Code	Percent of Load Sensible	Percent Misc. Load to Room	Percent Misc. Sens to Ret. Air	Radiant Fraction	Optional Air Path
1	1	ENTIRE FACILITY	1.95	KW	ADMLGTEQ	ELEC					

```

-----CARD 29--- Room Airflows -----
-----Ventilation-----Infiltration-----
Room  ---Cooling---    ---Heating---    ---Cooling---    ---Heating---    --Reheat Minimum--
Number Value      Units      Value      Units      Value      Units      Value      Units
1      650        CFM        650        CFM

```

```

-----CARD 30- Fan Airflows -----
-----Main-----Auxiliary-----
Room  ---Cooling---    ---Heating---    ---Cooling---    ---Heating---    --Room Exhaust--
Number Value      Units      Value      Units      Value      Units      Value      Units
1      340        CFM

```

```

-----CARD 32-- Exposed Floor Parameters-----
Exposed  ---Slab-----Exposed Floor-----
Room  Floor  Perimeter  Loss      Floor  Floor  Const  Temp  Cooling  Heating  Adjacent
Number Number  Length      Coefficient Area  U-Value Type  Flag  Temp  Temp  Room No
1      1      460        .8

```

```

----- System Section Alternative #1 -----

```

```

-----CARD 39-- System Alternative -----
Number  Description
1      BLDG M514, BASELINE

```

```

-----CARD 40--- System Type -----
-----OPTIONAL VENTILATION SYSTEM-----
System  Ventil  Fan
Set  System  Deck  Cooling  Heating  Cooling  Heating  Static
Number Type  Location  SADBvh  SADBvh  Schedule  Schedule  Pressure
1      SZ

```

```

-----CARD 41-- Zone Assignment -----
System  Ref #1      Ref #2      Ref #3      Ref #4      Ref #5      Ref #6
Set      Begin  End  Begin  End  Begin  End  Begin  End  Begin  End  Begin  End
Number  Begin  End  Begin  End  Begin  End  Begin  End  Begin  End  Begin  End
1      1      1

```

```

-----CARD 42--- Fan SP and Duct Parameters-----
System  Cool  Heat  Return  Mn Exh  Aux  Rm Exh  Cool  Return  Supply  Supply  Return
Set  Fan  Fan  Fan  Fan  Fan  Fan  Fan Mtr  Fan Mtr  Duct  Duct  Air
Number SP  SP  SP  SP  SP  SP  Loc  Loc  Ht Gn  Loc  Path
1      2.5  1
          SUPPLY
          RETAIR PLENUM

```


-----CARD 62-- Cooling Equipment Parameters -----

Cool Equip	Num	-----COOLING-----				-----HEAT RECOVERY-----				Seq	Demand	
Ref Code	Of	--Capacity--		----Energy----		--Capacity--		----Energy----		Order	Seq	Limit
Num Name	Units	Value	Units	Value	Units	Value	Units	Value	Units	Num	Type	Number
1 EQ1170S	1	28.6	TONS									

-----CARD 65-- Heating Load Assignment -----

Load	All Coil										
Assignment	Loads To	-Group 1-	-Group 2-	-Group 3-	-Group 4-	-Group 5-	-Group 6-	-Group 7-	-Group 8-	-Group 9-	
Reference	Heating Ref	Begin	End	Begin	End	Begin	End	Begin	End	Begin	End
1	1	1	1								

-----CARD 67-- Heating Equipment Parameters -----

Heat Equip	Number	HW Pmp	Energy				Seq	Switch	Demand					
Ref Code	Of	Full Ld	Cap'y		Rate		Order	over	Hot	Misc.	Limit			
Number	Name	Units	Value	Units	Value	Units	Value	Units	Number	Control	Strg	Acc.	Cogen	Number
1	EQ2454	1												

-----CARD 69-- Fan Equipment Parameters -----

System	Cooling	Heating	Return	Exhaust	Auxiliary	Room	Optional
Set	Fan	Fan	Fan	Fan	Supply	Exhaust	Ventilation
Number	EQ4003		EQ4003				
1	EQ4003			EQ4003			

Utility Description Reference Table

Schedules:

ADMLGTEQ ADMIN LIGHTING AND EQUIPMENT
 ADMPPPL ADMIN PEOPLE SCHEDULE
 AVAIL AVAILABLE (100%)
 CLG COOLING TSTAT SCHEDULE
 CLGC COOLING COIL SCHEDULE
 HTG HEATING TSTAT SCHEDULE
 HTGC HEATING COIL SCHEDULE
 OFF ALWAYS OFF

System:

SZ SINGLE ZONE

Equipment:

Cooling:
 EQ1170S AIR-CLD COND COMP <20 TONS
 Heating:
 EQ2454 RESIDENT GAS FURNACE W-FAN
 Fan:
 EQ4003 FC CENTRIF. FAN C.V.

Schedule Name: ADMLGTEQ
 Project: ADMIN LIGHTING AND EQUIPMENT SC
 Location:
 Client:
 Program User:
 Comments: OFFICE LIGHTING

Starting Month: JAN Ending Month: DEC
 Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	5
7	80
8	100
12	80
13	100
16	80
17	40
18	5
24	

Starting Month: JAN Ending Month: DEC
 Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	5
24	

Schedule Name: ADMPEPL
Project: ADMIN PEOPLE SCHEDULE
Location:
Client:
Program User: D JONES
Comments: OFFICE PEOPLE SCHEDULE

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: WKDY

Hour	Util Percent
0	0
7	50
8	100
11	80
12	40
13	80
14	100
16	70
17	30
18	0
24	

Starting Month: JAN Ending Month: DEC
Starting Day Type: SAT Ending Day Type: SUN

Hour	Util Percent
0	0
24	

Schedule Name: AVAIL
Project: AVAILABLE (100)
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util Percent
0	100
24	

Schedule Name: CLG
Project: COOLING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	76
24	

Schedule Name: CLGC
Project: COOLING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0	100	
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Schedule Name: HTG
Project: HEATING TSTAT SCHEDULE
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: DEC
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Temperature
0	72
24	

Schedule Name: HTGC
Project: HEATING COIL SCHEDULE
Location:
Client:
Program User: R. GERRANS
Comments:

Starting Month: JAN Ending Month: APR
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Starting Month: MAY Ending Month: OCT
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

Starting Month: NOV Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		100
24		

Schedule Name: OFF
Project: ALWAYS OFF
Location:
Client:
Program User:
Comments:

Starting Month: JAN Ending Month: HTG
Starting Day Type: DSGN Ending Day Type: SUN

Hour	Util	Percent
0		0
24		

**
** T R A C E 6 0 0 A N A L Y S I S **
**
** by ** **
**

FT MCPHERSON & FT GILLEM EEAP
FT MCPHERSON, BLDG. 514

J. WATTERS

Weather File Code: ATLANTA.
Location: ATLANTA, GEORGIA
Latitude: 33.0 (deg)
Longitude: 84.0 (deg)
Time Zone: 6
Elevation: 1,005 (ft)
Barometric Pressure: 28.8 (in. Hg)

Summer Clearness Number: 0.90
Winter Clearness Number: 0.90
Summer Design Dry Bulb: 92 (F)
Summer Design Wet Bulb: 74 (F)
Winter Design Dry Bulb: 22 (F)
Summer Ground Relectance: 0.20
Winter Ground Relectance: 0.20

Air Density: 0.0731 (Lbm/cuft)
Air Specific Heat: 0.2444 (Btu/lbm/F)
Density-Specific Heat Prod: 1.0727 (Btu-min./hr/cuft/F)
Latent Heat Factor: 4,721.8 (Btu-min./hr/cuft)
Enthalpy Factor: 4.3883 (Lb-min./hr/cuft)

Design Simulation Period: May To October
System Simulation Period: January To December
Cooling Load Methodology: TETD/Time Averaging

Time/Date Program was Run: 10:57:33 4/10/92
Dataset Name: M514-B .TM

AIRFLOW - ALTERNATIVE 1
 BLDG M514, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Airflow Quantities)

System Number	System Type	Main					Auxil. Supply	Room Exhaust
		Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Airflow (Cfm)	Airflow (Cfm)
1	SZ	650	7,881	7,881	7,881	650	0	340
Totals		650	7,881	7,881	7,881	650	0	340

CAPACITY - ALTERNATIVE 1
 BLDG M514, BASELINE

----- S Y S T E M S U M M A R Y -----
 (Design Capacity Quantities)

System Number	System Type	Cooling					Heating										
		Main Capacity (Tons)	Sys. Capacity (Tons)	Aux. Capacity (Tons)	Opt. Capacity (Tons)	Vent Capacity (Tons)	Cooling Totals (Tons)	Main Capacity (Btuh)	Sys. Capacity (Btuh)	Aux. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Capacity (Btuh)	Vent Capacity (Btuh)	Heating Totals (Btuh)	
1	SZ	16.0	0.0	0.0	0.0	0.0	16.0	-113,914	0	0	0	0	0	0	0	0	-113,914
Totals		16.0	0.0	0.0	0.0	0.0	16.0	-113,914	0	0	0	0	0	0	0	0	-113,914

The building peaked at hour 15 month 6 with a capacity of 16.0 tons

ENGINEERING CHECKS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- E N G I N E E R I N G C H E C K S -----

System Number	Main/Auxiliary	System Type	Percent Outside Air	Cooling				Heating		Floor Area Sq Ft
				Cfm/ Sq Ft	Cfm/ Ton	Sq Ft /Ton	Btuh/ Sq Ft	Cfm/ Sq Ft	Btuh/ Sq Ft	
1	Main	SZ	8.25	0.81	493.8	610.6	19.65	0.81	-11.69	9,744

System 1 Peak SZ - SINGLE ZONE

***** COOLING COIL PEAK *****					***** CLG SPACE PEAK *****			***** HEATING COIL PEAK *****			
Peaked at Time ==>	Mo/Hr: 7/15				*	Mo/Hr: 6/16		*	Mo/Hr: 13/ 1		
Outside Air ==>	OADB/WB/HR: 92/ 74/105.0				*	OADB: 96		*	OADB: 22		
	Space	Ret. Air	Ret. Air	Net	Perct		Space	Perct	Space Peak	Coil Peak	Perct
	Sens.+Lat.	Sensible	Latent	Total	Of Tot		Sensible	Of Tot	Space Sens	Tot Sens	Of Tot
	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)		(Btuh)	(%)	(Btuh)	(Btuh)	(%)
Envelope Loads											
Skylite Solr	0	0		0	0.00	*	0	0.00	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	0	0	0.00
Roof Cond	0	15,177		15,177	7.92	*	0	0.00	0	-28,250	24.80
Glass Solar	13,920	0		13,920	7.27	*	14,790	11.38	0	0	0.00
Glass Cond	3,248	0		3,248	1.70	*	3,979	3.06	-10,779	-10,779	9.46
Wall Cond	16,468	2,082		18,550	9.69	*	18,987	14.61	-32,291	-36,391	31.95
Partition	0	0		0	0.00	*	0	0.00	0	0	0.00
Exposed Floor	0	0		0	0.00	*	0	0.00	-18,400	-18,400	16.15
Infiltration	0	0		0	0.00	*	0	0.00	0	0	0.00
Sub Total==>	33,636	17,259		50,895	26.58	*	37,756	29.04	-61,470	-93,821	82.36
Internal Loads						*					
Lights	65,076	0		65,076	33.98	*	65,076	50.06	0	0	0.00
People	30,000			30,000	15.66	*	15,000	11.54	0	0	0.00
Misc	6,655	0	0	6,655	3.48	*	6,655	5.12	0	0	0.00
Sub Total==>	101,731	0	0	101,731	53.12	*	86,731	66.72	0	0	0.00
Ceiling Load	4,767	-4,767		0	0.00	*	5,510	4.24	-8,655	0	0.00
Outside Air	0	0		26,586	13.88	*	0	0.00	0	-34,862	30.60
Sup. Fan Heat				12,814	6.69	*		0.00		12,814	-11.25
Ret. Fan Heat		0		0	0.00	*		0.00		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	0	0	0.00
Exhaust Heat		-513	0	-513	-0.27	*		0.00		1,954	-1.72
Terminal Bypass		0	0	0	0.00	*		0.00		0	0.00
Grand Total==>	140,134	11,978	0	191,512	100.00	*	129,996	100.00	-70,125	-113,914	100.00

-----COOLING COIL SELECTION-----

	Total Capacity		Sens Cap.	Coil Airfl	Entering DB/WB/HR			Leaving DB/WB/HR			Gross Total		Glass (sf)	(%)
	(Tons)	(Mbh)			Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	Part		
Main Clg	16.0	191.5	161.1	7,881	78.7	64.7	72.7	59.1	56.8	68.0	9,744	0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	460	0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	13,920	0		
Totals	16.0	191.5									4,600	290		

-----HEATING COIL SELECTION-----

	Capacity	Coil Airfl	Ent	Lvg	Type	AIRFLOWS (cfm)		--ENGINEERING CHECKS--			--TEMPERATURES (F)--		
						Cooling	Heating	Clg % OA	8.2	Type	Clg	Htg	
Main Htg	-113.9	7,881	65.3	78.8	Vent	650	650	Clg Cfm/Sqft	0.81	SADB	60.6	80.3	
Aux Htg	0.0	0	0.0	0.0	Infil	0	0	Clg Cfm/Ton	493.80	Plenum	77.5	69.2	
Preheat	-0.0	7,881	65.3	59.1	Supply	7,881	7,881	Clg Sqft/Ton	610.55	Return	77.5	69.2	
Reheat	0.0	0	0.0	0.0	Mincfm	0	0	Clg Btuh/Sqft	19.65	Ret/OA	78.7	65.3	
Humidif	0.0	0	0.0	0.0	Return	7,541	7,881	No. People	60	Runarnd	76.0	72.0	
Opt Vent	0.0	0	0.0	0.0	Exhaust	310	650	Htg % OA	8.2	Fn MtrTD	0.3	0.0	
Total	-113.9				Rm Exh	340	0	Htg Cfm/SqFt	0.81	Fn BldTD	0.3	0.0	
					Auxil	0	0	Htg Btuh/SqFt	-11.69	Fn Frict	0.9	0.0	

COOLING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- A I R F L O W H E A T G A I N A N D L O S S -----
 (At time of Coil Peak)

		Cooling											
Room Number	Description	Duct	Supply	Return	System	System		Room	Run			System	
		Heat Pickup (Btuh)	Fan Heat (Btuh)	Fan Heat (Btuh)	Exhaust Heat Loss (Btuh)	Exhaust	Total	Exhaust	Exhaust	Ducted	Plenum	Around	Corridr
		(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)
1	WHOLE BUILDING	0	12,814	0	-513	12,301	310	340	0	7,541	0	0	7,541
Zone	1 Total/Ave.	0	12,814	0	-513	12,301	310	340	0	7,541	0	0	7,541
Zone	1 Block	0	12,814	0	-513	12,301	310	340	0	7,541	0	0	7,541
System	1 Total/Ave.	0	12,814	0	-513	12,301	310	340	0	7,541	0	0	7,541
System	1 Block	0	12,814	0	-513	12,301	310	340	0	7,541	0	0	7,541

HEATING AIRFLOW HEAT GAIN/LOSS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- A I R F L O W H E A T G A I N A N D L O S S -----
 (At time of Coil Peak)

		Heating										
Room Number	Description	Supply	Return	System	System		Room	Run			System	
		Fan Heat (Btuh)	Fan Heat (Btuh)	Exhaust Heat Loss (Btuh)	Total	Exhaust	Exhaust	Ducted	Plenum	Around	Corridr	Return
		(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)
1	WHOLE BUILDING	12,814	0	1,954	14,769	650	0	0	7,881	0	0	7,881
Zone	1 Total/Ave.	12,814	0	1,954	14,769	650	0	0	7,881	0	0	7,881
Zone	1 Block	12,814	0	1,954	14,769	650	0	0	7,881	0	0	7,881
System	1 Total/Ave.	12,814	0	1,954	14,769	650	0	0	7,881	0	0	7,881
System	1 Block	12,814	0	1,954	14,769	650	0	0	7,881	0	0	7,881

ZONE PSYCHROMETRICS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- P S Y C H R O M E T R I C S T A T E P O I N T S -----

Zone	1	Dry Bulb (F)	Wet Bulb (F)	Relat. Humid. (%)	Humid. Ratio (GR)	Enthalpy (Btu/Lb)	Temp. Diff. (F)
Space		76.0	63.2	50.0	69.8	29.2	
Main System							
Return Air Heat Pickup							1.8
Return Fan							0.0
Return Air		77.8	63.8	47.1	69.8	29.6	
Outdoor Air		92.0	74.4	44.6	105.0	38.6	
Return/Outdoor Air Mix		79.0	64.8	47.2	72.7	30.3	
Blow through Fan							0.0
Entering Coil		79.0	64.8	47.2	72.7	30.3	
Leaving Coil		59.1	56.7	86.6	67.5	24.7	
Draw Through Fan							0.6
Duct Frictional Heat							0.9
Supply Duct Heat Gain							0.0
Cold Deck Supply Air		60.6	57.2	82.0	67.5	25.0	
Supply Air		60.6	57.2	82.0	67.5	25.0	
Percent Outside Air			8.25	(%)			
Sensible Heat Ratio (SHR)			0.897				
Percent Supply Air Bypassing Coil			0.00	(%)			
Coil Airflow			7,881	(Cfm)			

BUILDING U-VALUES - ALTERNATIVE 1
 BLDG M514, BASELINE

----- B U I L D I N G U - V A L U E S -----

Room Number	Description	Room U-Values (Btu/hr/sqft/F)								Room Mass (lb/ sqft)	Room Capac. (Btu/ sqft/F)	
		Part.	ExFlr	Summr Skylt	Wintr Skylt	Roof	Summr Windo	Wintr Windo	Wall			Ceill.
1	WHOLE BUILDING	0.000	0.800	0.000	0.000	0.043	0.700	0.743	0.170	0.317	246.3	50.53
Zone	1 Total/Ave.	0.000	0.800	0.000	0.000	0.043	0.700	0.743	0.170	0.317	246.3	50.53
System	1 Total/Ave.	0.000	0.800	0.000	0.000	0.043	0.700	0.743	0.170	0.317	246.3	50.53
Building		0.000	0.800	0.000	0.000	0.043	0.700	0.743	0.170	0.317	246.3	50.53

BUILDING AREAS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- B U I L D I N G A R E A S -----

Room Number	Description	Number of Duplicate Flr	Rm	Floor Area/Dupl Room (sqft)	Total Floor Area (sqft)	Partition Area (sqft)	Exposed Floor Area (sqft)	Skylight Area (sqft)	Skl /Rf (%)	Net Roof Area (sqft)	Window Area (sqft)	Win /Wl (%)	Net Wall Area (sqft)
1	WHOLE BUILDING	1	1	9,744	9,744	0	460	0	0	13,920	290	6	4,310
Zone	1 Total/Ave.				9,744	0	460	0	0	13,920	290	6	4,310
System	1 Total/Ave.				9,744	0	460	0	0	13,920	290	6	4,310
Building					9,744	0	460	0	0	13,920	290	6	4,310

ASHRAE 90 ANALYSIS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- A S H R A E 9 0 A N A L Y S I S -----

Overall Roof U-Value = 0.043 (Btu/Hr/Sq Ft/F)
 Overall Wall U-Value = 0.203 (Btu/Hr/Sq Ft/F)
 Overall Building U-Value = 0.083 (Btu/Hr/Sq Ft/F)

Roof Overall Thermal Transfer Value (OTTVr) = 0.31 (Btu/Hr/Sq Ft)
 Wall Overall Thermal Transfer Value (OTTVw) = 9.95 (Btu/Hr/Sq Ft)

SYSTEM LOAD PROFILE - ALTERNATIVE 1
 BLDG M514, BASELINE

Main System 1 SZ SINGLE ZONE

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.8	3	129	-5,696	0	0	394.0	0	0	0.0	0	0
5 - 10	1.6	7	260	-11,391	1	4	788.1	0	0	0.0	0	0
10 - 15	2.4	6	231	-17,087	0	0	1,182.1	0	0	0.0	0	0
15 - 20	3.2	20	784	-22,783	0	0	1,576.1	0	0	0.0	0	0
20 - 25	4.0	11	413	-28,479	4	19	1,970.2	0	0	0.0	0	0
25 - 30	4.8	6	222	-34,174	27	127	2,364.2	0	0	0.0	0	0
30 - 35	5.6	12	455	-39,870	14	67	2,758.2	0	0	0.0	0	0
35 - 40	6.4	5	187	-45,566	16	75	3,152.3	0	0	0.0	0	0
40 - 45	7.2	1	34	-51,261	16	73	3,546.3	0	0	0.0	0	0
45 - 50	8.0	2	59	-56,957	22	100	3,940.4	0	0	0.0	0	0
50 - 55	8.8	3	129	-62,653	0	0	4,334.4	0	0	0.0	0	0
55 - 60	9.6	3	131	-68,349	0	0	4,728.4	0	0	0.0	0	0
60 - 65	10.4	4	167	-74,044	0	0	5,122.5	0	0	0.0	0	0
65 - 70	11.2	2	65	-79,740	0	0	5,516.5	0	0	0.0	0	0
70 - 75	12.0	6	240	-85,436	0	0	5,910.5	0	0	0.0	0	0
75 - 80	12.8	4	166	-91,132	0	0	6,304.6	0	0	0.0	0	0
80 - 85	13.6	2	65	-96,827	0	0	6,698.6	0	0	0.0	0	0
85 - 90	14.4	3	130	-102,523	0	0	7,092.6	0	0	0.0	0	0
90 - 95	15.2	0	0	-108,219	0	0	7,486.7	0	0	0.0	0	0
95 - 100	16.0	0	0	-113,914	0	0	7,880.7	100	8,760	0.0	0	0
Hours Off	0.0	0	4,893	0	0	8,295	0.0	0	0	0.0	0	8,760

SYSTEM TOTALS LOAD PROFILE - ALTERNATIVE 1
 BLDG M514, BASELINE

----- S Y S T E M L O A D P R O F I L E -----

System Totals

Percent Design Load	---- Cooling Load ----			----- Heating Load -----			---- Cooling Airflow ----			---- Heating Airflow ----		
	Cap. (Ton)	Hours (%)	Hours	Capacity (Btuh)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours	Cap. (Cfm)	Hours (%)	Hours
0 - 5	0.8	3	129	-5,696	0	0	394.0	0	0	0.0	0	0
5 - 10	1.6	7	260	-11,391	1	4	788.1	0	0	0.0	0	0
10 - 15	2.4	6	231	-17,087	0	0	1,182.1	0	0	0.0	0	0
15 - 20	3.2	20	784	-22,783	0	0	1,576.1	0	0	0.0	0	0
20 - 25	4.0	11	413	-28,479	4	19	1,970.2	0	0	0.0	0	0
25 - 30	4.8	6	222	-34,174	27	127	2,364.2	0	0	0.0	0	0
30 - 35	5.6	12	455	-39,870	14	67	2,758.2	0	0	0.0	0	0
35 - 40	6.4	5	187	-45,566	16	75	3,152.3	0	0	0.0	0	0
40 - 45	7.2	1	34	-51,261	16	73	3,546.3	0	0	0.0	0	0
45 - 50	8.0	2	59	-56,957	22	100	3,940.4	0	0	0.0	0	0
50 - 55	8.8	3	129	-62,653	0	0	4,334.4	0	0	0.0	0	0
55 - 60	9.6	3	131	-68,349	0	0	4,728.4	0	0	0.0	0	0
60 - 65	10.4	4	167	-74,044	0	0	5,122.5	0	0	0.0	0	0
65 - 70	11.2	2	65	-79,740	0	0	5,516.5	0	0	0.0	0	0
70 - 75	12.0	6	240	-85,436	0	0	5,910.5	0	0	0.0	0	0
75 - 80	12.8	4	166	-91,132	0	0	6,304.6	0	0	0.0	0	0
80 - 85	13.6	2	65	-96,827	0	0	6,698.6	0	0	0.0	0	0
85 - 90	14.4	3	130	-102,523	0	0	7,092.6	0	0	0.0	0	0
90 - 95	15.2	0	0	-108,219	0	0	7,486.7	0	0	0.0	0	0
95 - 100	16.0	0	0	-113,914	0	0	7,880.7	100	8,760	0.0	0	0
Hours Off	0.0	0	4,893	0	0	8,295	0.0	0	0	0.0	0	8,760

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M514, BASELINE

January			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	33.4	30.4	-27,858	0.0	0	0.0	0	0.0	-48,246	0.0	-48,246	0.0
2	32.1	29.3	-30,187	0.0	0	0.0	0	0.0	-50,851	0.0	-50,851	0.0
3	31.7	29.3	-32,991	0.0	0	0.0	0	0.0	-52,607	0.0	-52,607	0.0
4	31.9	29.5	-34,817	0.0	0	0.0	0	0.0	-54,166	0.0	-54,166	0.0
5	32.6	30.3	-37,287	0.0	0	0.0	-8,124	0.0	-55,151	0.0	-55,151	0.0
6	33.6	31.3	-37,853	0.0	0	0.0	-55,932	0.0	-55,932	0.0	-55,932	0.0
7	35.0	32.6	-38,769	0.0	0	0.0	-55,797	0.0	-55,797	0.0	-55,797	0.0
8	36.6	34.4	0	0.0	0	0.0	-51,482	0.0	-51,482	0.0	0	0.0
9	38.5	36.3	0	0.0	0	0.0	-47,685	0.0	-47,685	0.0	0	0.0
10	40.4	37.7	0	0.0	0	0.0	-44,250	0.0	-44,250	0.0	0	0.0
11	42.3	38.7	0	0.0	0	0.0	-41,862	0.0	-41,862	0.0	0	0.0
12	44.2	39.6	0	0.0	0	0.0	-39,726	0.0	-39,726	0.0	0	0.0
13	45.8	40.5	0	0.0	0	0.0	-35,728	0.0	-35,728	0.0	0	0.0
14	47.2	41.1	0	0.0	0	0.0	-32,900	0.0	-32,900	0.0	0	0.0
15	48.2	41.6	0	0.0	0	0.0	-29,339	0.0	-29,339	0.0	0	0.0
16	48.9	41.8	0	0.0	0	0.0	-26,209	0.0	-26,209	0.0	0	0.0
17	49.1	41.9	0	0.0	0	0.0	-31,072	0.0	-31,072	0.0	0	0.0
18	48.7	41.9	0	0.0	0	0.0	-30,794	0.0	-30,794	0.0	0	0.0
19	47.4	41.7	0	0.0	0	0.0	-31,068	0.0	-31,068	0.0	0	0.0
20	45.5	40.5	0	0.0	0	0.0	-33,246	0.0	-33,246	0.0	0	0.0
21	43.1	38.9	0	0.0	0	0.0	-35,760	0.0	-35,760	0.0	0	0.0
22	40.4	36.7	0	0.0	0	0.0	-38,496	0.0	-38,496	0.0	0	0.0
23	37.7	34.3	0	0.0	0	0.0	-42,080	0.0	-42,080	0.0	0	0.0
24	35.3	32.3	0	0.0	0	0.0	-45,444	0.0	-45,444	0.0	0	0.0

February			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	37.5	34.5	0	0.0	0	0.0	0	0.0	-43,285	0.0	-43,285	0.0
2	36.0	33.0	0	0.0	0	0.0	0	0.0	-46,661	0.0	-46,661	0.0
3	34.7	31.8	0	0.0	0	0.0	0	0.0	-48,409	0.0	-48,409	0.0
4	33.6	30.9	0	0.0	0	0.0	0	0.0	-51,503	0.0	-51,503	0.0
5	32.8	30.1	-12,531	0.0	0	0.0	0	0.0	-52,910	0.0	-52,910	0.0
6	32.2	29.8	-34,917	0.0	0	0.0	0	0.0	-54,805	0.0	-54,805	0.0
7	32.1	29.6	-35,296	0.0	0	0.0	-33,445	0.0	-55,812	0.0	-55,812	0.0
8	32.5	30.3	0	0.0	0	0.0	-50,754	0.0	-50,754	0.0	0	0.0
9	33.9	31.6	0	0.0	0	0.0	-49,839	0.0	-49,839	0.0	0	0.0
10	36.0	33.0	0	0.0	0	0.0	-48,116	0.0	-48,116	0.0	0	0.0
11	38.5	34.8	0	0.0	0	0.0	-45,317	0.0	-45,317	0.0	0	0.0
12	41.3	36.5	0	0.0	0	0.0	-41,476	0.0	-41,476	0.0	0	0.0
13	43.8	38.1	0	0.0	0	0.0	-37,505	0.0	-37,505	0.0	0	0.0
14	45.9	39.5	0	0.0	0	0.0	-33,346	0.0	-33,346	0.0	0	0.0
15	47.2	40.4	0	0.0	0	0.0	-29,077	0.0	-29,077	0.0	0	0.0
16	47.7	40.6	0	0.0	0	0.0	-26,917	0.0	-26,917	0.0	0	0.0
17	47.5	40.2	0	0.0	0	0.0	-28,817	0.0	-28,817	0.0	0	0.0
18	47.0	39.8	0	0.0	0	0.0	-33,045	0.0	-33,045	0.0	0	0.0
19	46.2	39.9	0	0.0	0	0.0	-32,129	0.0	-32,129	0.0	0	0.0
20	45.1	39.7	0	0.0	0	0.0	-32,267	0.0	-32,267	0.0	0	0.0
21	43.8	39.2	0	0.0	0	0.0	-34,023	0.0	-34,023	0.0	0	0.0
22	42.3	38.3	0	0.0	0	0.0	-35,918	0.0	-35,918	0.0	0	0.0
23	40.7	37.2	0	0.0	0	0.0	-39,356	0.0	-39,356	0.0	0	0.0
24	39.1	35.8	0	0.0	0	0.0	-41,321	0.0	-41,321	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M514, BASELINE

March			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	45.4	41.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	43.3	39.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	41.6	38.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	40.6	37.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	40.2	37.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	40.6	37.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	41.6	39.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	43.3	40.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	45.4	42.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	47.9	44.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	50.6	45.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	53.3	46.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	55.8	48.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	58.0	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	59.6	50.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	60.7	50.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	61.0	50.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	60.7	50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	59.6	50.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	58.0	50.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	55.8	49.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	53.3	47.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	50.6	45.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	47.9	43.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

April			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	57.7	53.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	55.9	52.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	54.2	51.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	52.9	50.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	51.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	51.2	49.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	51.0	49.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	51.6	49.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
9	53.3	50.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
10	55.9	51.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
11	59.0	53.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
12	62.4	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
13	65.5	57.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
14	68.1	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
15	69.8	60.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
16	70.4	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
17	70.2	60.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
18	69.5	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
19	68.5	59.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
20	67.2	59.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
21	65.5	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
22	63.7	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
23	61.7	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	59.7	55.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M514, BASELINE

May Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	66.6	62.3	0	16.0	0	1.7	0	2.0	0	2.0	0	2.0
2	64.5	60.4	0	14.6	0	1.4	0	1.5	0	1.5	0	1.5
3	62.7	59.1	0	14.0	0	1.1	0	1.2	0	1.2	0	1.2
4	61.2	58.1	0	13.6	0	0.8	0	0.8	0	0.8	0	0.8
5	60.0	57.1	0	13.3	0	0.5	0	0.5	0	0.5	0	0.5
6	59.3	56.6	0	13.2	0	0.7	0	0.7	0	0.7	0	0.7
7	59.0	56.5	0	13.1	0	0.8	0	0.8	0	0.8	0	0.8
8	59.5	56.6	0	13.2	0	6.3	0	0.8	0	0.8	0	6.3
9	60.9	56.6	0	13.7	0	8.5	0	0.9	0	0.9	0	8.5
10	63.0	57.2	0	14.3	0	9.1	0	1.2	0	1.2	0	9.1
11	65.7	58.1	0	14.6	0	9.3	0	1.4	0	1.4	0	9.3
12	68.7	59.8	0	14.7	0	9.2	0	1.6	0	1.6	0	9.2
13	71.7	61.6	0	14.5	0	7.7	0	2.1	0	2.1	0	7.7
14	74.5	63.4	0	14.6	0	10.1	0	2.7	0	2.7	0	10.1
15	76.6	64.8	0	15.0	0	11.2	0	3.2	0	3.2	0	11.2
16	78.0	65.6	0	15.1	0	11.4	0	3.2	0	3.2	0	11.4
17	78.5	65.6	0	14.7	0	9.7	0	3.4	0	3.4	0	9.7
18	78.2	65.8	0	14.2	0	6.1	0	3.3	0	3.3	0	6.1
19	77.5	65.6	0	13.6	0	3.0	0	3.0	0	3.0	0	3.0
20	76.3	66.1	0	13.1	0	3.0	0	3.0	0	3.0	0	3.0
21	74.8	67.2	0	6.1	0	3.0	0	3.0	0	3.0	0	3.0
22	73.0	66.4	0	4.1	0	2.9	0	2.9	0	2.9	0	2.9
23	70.9	65.4	0	3.7	0	2.7	0	2.7	0	2.7	0	2.7
24	68.7	64.0	0	3.4	0	2.3	0	2.3	0	2.3	0	2.3

June Hour	OADB	OAWB	----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
			Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	73.0	67.9	0	5.5	0	3.6	0	3.9	0	3.9	0	3.9
2	71.2	66.1	0	4.9	0	3.4	0	3.5	0	3.5	0	3.5
3	69.7	65.2	0	4.5	0	3.1	0	3.1	0	3.1	0	3.1
4	68.5	64.3	0	4.3	0	2.7	0	2.7	0	2.7	0	2.7
5	67.8	64.2	0	4.1	0	2.4	0	2.4	0	2.4	0	2.4
6	67.6	64.2	0	4.5	0	2.7	0	2.7	0	2.7	0	2.7
7	68.1	64.8	0	4.9	0	2.8	0	2.8	0	2.8	0	2.8
8	69.4	65.7	0	10.8	0	9.1	0	2.9	0	2.9	0	9.1
9	71.6	66.2	0	13.3	0	11.3	0	3.2	0	3.2	0	11.3
10	74.2	67.2	0	13.7	0	11.9	0	3.7	0	3.7	0	11.9
11	77.2	68.5	0	14.1	0	12.2	0	4.0	0	4.0	0	12.2
12	80.2	70.0	0	14.2	0	12.2	0	4.3	0	4.3	0	12.2
13	82.8	70.8	0	12.5	0	10.5	0	4.8	0	4.8	0	10.5
14	85.0	71.6	0	14.9	0	13.0	0	5.4	0	5.4	0	13.0
15	86.3	72.3	0	15.9	0	14.1	0	5.9	0	5.9	0	14.1
16	86.8	72.1	0	16.0	0	14.0	0	5.9	0	5.9	0	14.0
17	86.6	71.7	0	14.1	0	12.1	0	5.8	0	5.8	0	12.1
18	85.8	71.5	0	10.4	0	8.5	0	5.7	0	5.7	0	8.5
19	84.7	71.2	0	6.7	0	5.3	0	5.3	0	5.3	0	5.3
20	83.2	71.5	0	6.5	0	5.3	0	5.3	0	5.3	0	5.3
21	81.4	71.7	0	6.3	0	5.2	0	5.3	0	5.3	0	5.2
22	79.3	71.4	0	6.0	0	5.1	0	5.1	0	5.1	0	5.1
23	77.2	70.5	0	5.7	0	4.7	0	4.7	0	4.7	0	4.7
24	75.1	69.1	0	5.4	0	4.3	0	4.3	0	4.3	0	4.3

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M514, BASELINE

July			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	
1	72.0	69.3	0	5.4	0	3.4	0	3.8	0	3.8	0	3.8	
2	70.5	68.0	0	4.8	0	3.3	0	3.4	0	3.4	0	3.4	
3	69.4	67.1	0	4.4	0	3.0	0	3.0	0	3.0	0	3.0	
4	68.5	66.4	0	4.2	0	2.7	0	2.7	0	2.7	0	2.7	
5	67.9	66.0	0	4.0	0	2.5	0	2.5	0	2.5	0	2.5	
6	67.7	65.9	0	4.3	0	2.6	0	2.6	0	2.6	0	2.6	
7	68.1	66.3	0	4.8	0	2.8	0	2.8	0	2.8	0	2.8	
8	69.1	67.3	0	10.9	0	9.5	0	3.0	0	3.0	0	9.5	
9	70.8	68.0	0	13.2	0	11.5	0	3.2	0	3.2	0	11.5	
10	72.9	69.1	0	13.9	0	12.2	0	3.8	0	3.8	0	12.2	
11	75.2	70.5	0	14.2	0	12.4	0	4.0	0	4.0	0	12.4	
12	77.5	71.7	0	14.2	0	12.3	0	4.3	0	4.3	0	12.3	
13	79.6	72.7	0	12.5	0	10.6	0	4.8	0	4.8	0	10.6	
14	81.3	73.5	0	15.0	0	13.3	0	5.4	0	5.4	0	13.3	
15	82.3	73.7	0	15.9	0	14.1	0	5.8	0	5.8	0	14.1	
16	82.7	73.5	0	16.0	0	14.2	0	5.9	0	5.9	0	14.2	
17	82.5	73.1	0	13.9	0	12.1	0	5.8	0	5.8	0	12.1	
18	82.0	72.6	0	10.1	0	8.5	0	5.7	0	5.7	0	8.5	
19	81.1	73.2	0	6.5	0	5.0	0	5.2	0	5.2	0	5.0	
20	79.9	73.8	0	6.4	0	5.2	0	5.3	0	5.3	0	5.2	
21	78.5	73.9	0	6.3	0	5.3	0	5.3	0	5.3	0	5.3	
22	76.9	73.1	0	6.0	0	5.1	0	5.1	0	5.1	0	5.1	
23	75.2	71.9	0	5.7	0	4.8	0	4.8	0	4.8	0	4.8	
24	73.5	70.8	0	5.4	0	4.3	0	4.3	0	4.3	0	4.3	

August			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	
1	72.7	70.2	0	5.4	0	3.3	0	3.7	0	3.7	0	3.7	
2	71.2	69.0	0	4.7	0	3.1	0	3.3	0	3.3	0	3.3	
3	69.9	68.0	0	4.3	0	3.0	0	3.1	0	3.1	0	3.1	
4	68.8	67.1	0	4.0	0	2.6	0	2.7	0	2.7	0	2.7	
5	68.0	66.6	0	3.9	0	2.4	0	2.4	0	2.4	0	2.4	
6	67.5	66.2	0	3.9	0	2.3	0	2.3	0	2.3	0	2.3	
7	67.3	66.1	0	4.6	0	2.5	0	2.5	0	2.5	0	2.5	
8	67.8	66.5	0	10.8	0	9.2	0	2.6	0	2.6	0	9.2	
9	69.1	67.0	0	13.3	0	11.1	0	2.8	0	2.8	0	11.1	
10	71.2	67.8	0	13.8	0	11.6	0	3.3	0	3.3	0	11.6	
11	73.8	68.7	0	14.0	0	11.8	0	3.5	0	3.5	0	11.8	
12	76.5	70.0	0	13.8	0	11.8	0	3.9	0	3.9	0	11.8	
13	79.1	71.2	0	12.2	0	10.2	0	4.5	0	4.5	0	10.2	
14	81.1	72.6	0	14.9	0	13.0	0	5.2	0	5.2	0	13.0	
15	82.5	73.6	0	15.8	0	13.8	0	5.6	0	5.6	0	13.8	
16	83.0	73.7	0	15.9	0	13.7	0	5.3	0	5.3	0	13.7	
17	82.8	73.5	0	13.9	0	11.8	0	5.4	0	5.4	0	11.8	
18	82.3	73.5	0	9.8	0	8.0	0	5.1	0	5.1	0	8.0	
19	81.5	73.1	0	6.3	0	4.8	0	5.0	0	5.0	0	4.8	
20	80.4	73.7	0	6.3	0	5.0	0	5.1	0	5.1	0	5.0	
21	79.1	74.9	0	6.1	0	5.1	0	5.1	0	5.1	0	5.1	
22	77.6	73.9	0	5.8	0	5.0	0	5.0	0	5.0	0	5.0	
23	76.0	72.7	0	5.5	0	4.6	0	4.6	0	4.6	0	4.6	
24	74.3	71.3	0	5.2	0	4.1	0	4.1	0	4.1	0	4.1	

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M514, BASELINE

September			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	69.8	66.1	0	4.1	0	2.0	0	2.4	0	2.4	0	2.4
2	68.0	64.5	0	3.6	0	1.9	0	2.1	0	2.1	0	2.1
3	66.3	63.0	0	3.2	0	1.6	0	1.7	0	1.7	0	1.7
4	64.9	61.9	0	2.9	0	1.3	0	1.3	0	1.3	0	1.3
5	63.9	61.3	0	2.6	0	1.1	0	1.1	0	1.1	0	1.1
6	63.2	61.0	0	2.5	0	0.9	0	0.9	0	0.9	0	0.9
7	63.0	60.8	0	3.1	0	1.1	0	1.1	0	1.1	0	1.1
8	63.4	61.4	0	9.2	0	7.5	0	1.3	0	1.3	0	7.5
9	64.7	61.8	0	12.0	0	9.6	0	1.5	0	1.5	0	9.6
10	66.6	62.1	0	12.5	0	9.8	0	1.6	0	1.6	0	9.8
11	69.1	62.9	0	12.7	0	10.3	0	2.2	0	2.2	0	10.3
12	71.8	63.7	0	12.7	0	10.1	0	2.4	0	2.4	0	10.1
13	74.5	65.5	0	11.1	0	8.7	0	3.0	0	3.0	0	8.7
14	77.0	67.1	0	13.6	0	11.2	0	3.6	0	3.6	0	11.2
15	78.9	68.2	0	14.3	0	11.9	0	3.7	0	3.7	0	11.9
16	80.2	68.6	0	14.3	0	12.2	0	3.9	0	3.9	0	12.2
17	80.6	68.5	0	12.2	0	10.2	0	3.9	0	3.9	0	10.2
18	80.4	68.9	0	7.9	0	6.3	0	3.4	0	3.4	0	6.3
19	79.7	70.0	0	5.0	0	3.6	0	3.6	0	3.6	0	3.6
20	78.7	71.2	0	4.9	0	3.7	0	3.7	0	3.7	0	3.7
21	77.3	71.6	0	4.7	0	3.7	0	3.7	0	3.7	0	3.7
22	75.6	70.5	0	4.4	0	3.5	0	3.5	0	3.5	0	3.5
23	73.7	69.4	0	4.1	0	3.2	0	3.2	0	3.2	0	3.2
24	71.8	67.7	0	3.7	0	2.8	0	2.8	0	2.8	0	2.8

October			----- Design -----		----- Weekday -----		----- Saturday-----		----- Sunday -----		----- Monday -----	
Hour	OADB	OAWB	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton	Htg Btuh	Clg Ton
1	54.8	51.3	0	0.4	0	0.0	0	0.0	0	0.0	0	0.0
2	52.9	49.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	51.2	48.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	49.8	47.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	48.8	46.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	48.2	45.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	47.9	45.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
8	48.5	46.2	0	3.6	0	0.0	0	0.0	0	0.0	0	0.0
9	50.3	47.3	0	7.6	0	0.0	0	0.0	0	0.0	0	0.0
10	52.9	48.7	0	8.1	0	2.7	0	0.0	0	0.0	0	0.0
11	56.2	49.9	0	8.6	0	6.0	0	0.0	0	0.0	0	0.0
12	59.6	51.5	0	8.7	0	6.4	0	0.0	0	0.0	0	0.0
13	62.9	53.5	0	7.4	0	5.0	0	0.0	0	0.0	0	0.0
14	65.5	55.2	0	9.6	0	7.1	0	0.0	0	0.0	0	0.0
15	67.3	56.3	0	10.4	0	7.9	0	0.0	0	0.0	0	1.2
16	67.9	56.6	0	10.5	0	8.2	0	0.0	0	0.0	0	8.7
17	67.7	56.4	0	7.9	0	5.9	0	0.0	0	0.0	0	6.0
18	67.0	56.6	0	4.5	0	2.8	0	0.0	0	0.0	0	2.8
19	66.0	57.6	0	1.9	0	0.1	0	0.0	0	0.0	0	0.1
20	64.6	57.9	0	1.7	0	0.0	0	0.0	0	0.0	0	0.0
21	62.9	57.3	0	1.4	0	0.0	0	0.0	0	0.0	0	0.0
22	61.0	56.0	0	1.0	0	0.0	0	0.0	0	0.0	0	0.0
23	59.0	54.8	0	0.8	0	0.0	0	0.0	0	0.0	0	0.0
24	56.9	53.0	0	0.5	0	0.0	0	0.0	0	0.0	0	0.0

BUILDING COOL-HEAT DEMAND - ALTERNATIVE 1
 BLDG M514, BASELINE

November			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	
1	48.7	45.7	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
2	46.9	44.1	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
3	45.5	42.8	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
4	44.6	41.9	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
5	44.4	42.0	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
6	44.8	42.7	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
7	45.9	43.9	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
8	47.8	46.0	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
9	50.2	48.0	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
10	52.9	49.9	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
11	55.8	51.1	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
12	58.5	52.0	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
13	60.9	52.5	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
14	62.8	53.4	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
15	64.0	53.8	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
16	64.4	53.9	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
17	64.1	53.7	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
18	63.2	53.7	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
19	61.8	54.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
20	60.0	53.6	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
21	57.9	52.7	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
22	55.6	51.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
23	53.2	49.5	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
24	50.8	47.6	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	

December			----- Design -----			----- Weekday -----			----- Saturday-----			----- Sunday -----			----- Monday -----		
Hour	OADB	OAWB	Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton		Htg Btuh	Clg Ton	
1	37.5	35.3	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
2	37.1	35.1	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
3	37.4	35.5	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
4	38.1	36.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
5	39.3	37.6	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
6	40.9	39.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
7	42.7	41.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
8	44.7	43.1	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
9	46.8	45.3	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
10	48.8	47.0	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
11	50.7	48.1	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
12	52.2	48.8	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
13	53.4	49.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
14	54.1	49.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
15	54.4	48.9	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
16	54.0	48.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
17	53.0	47.3	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
18	51.4	46.3	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
19	49.3	45.4	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
20	47.0	43.5	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
21	44.5	41.5	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
22	42.2	39.3	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
23	40.1	37.6	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	
24	38.5	36.2	0	0.0		0	0.0		0	0.0		0	0.0		0	0.0	

BUILDING TEMPERATURE PROFILES - ALTERNATIVE 1
BLDG M514, BASELINE

----- B U I L D I N G T E M P E R A T U R E P R O F I L E S -----

Temperature	Room Number
Range	1
(F)	
Max. Temp.	79.3
Mo./Hr.	4 19
Day Type	5
 Number of Hours
Above 100	0
95 - 100	0
90 - 95	0
85 - 90	0
80 - 85	0
75 - 80	6,324
70 - 75	2,436
65 - 70	0
60 - 65	0
55 - 60	0
50 - 55	0
Below 50	0
Min. Temp.	71.9
Mo./Hr.	1 4
Day Type	1

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M514, BASELINE

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	11,333	29	127	1
Feb	10,206	29	105	1
March	11,090	29	0	0
April	10,293	29	0	0
May	14,195	45	0	0
June	15,798	49	0	0
July	15,494	46	0	0
Aug	16,105	46	0	0
Sept	13,869	45	0	0
Oct	11,887	40	0	0
Nov	10,293	29	0	0
Dec	10,507	29	0	0
Total	151,070	49	232	1

Building Energy Consumption = 55,292 (Btu/Sq Ft/Year)
Source Energy Consumption = 161,262 (Btu/Sq Ft/Year)

Floor Area = 9,744 (Sq Ft)

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M514, BASELINE

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 48.6 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)

Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1170S	AIR-CLD COND COMP <20 TONS	19.8	40.65
Sub Total			19.8	40.65
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.8	16.13
Sub Total			7.8	16.13
Sub Total			0.0	0.00
Miscellaneous				
	Lights		19.1	39.21
	Base Utilities		0.0	0.00
	Misc Equipment		2.0	4.01
Sub Total			21.0	43.22
Grand Total			48.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M514, BASELINE

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 9,744
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,165.3	23,159.9	5.0	36,312.0	3.8
Primary Cooling					
Compressor	19,486.8	0.0	12.3	199,545.5	21.0
Tower/Cond Fans	2,353.4	0.0	1.5	24,098.4	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,144.2	0.0	0.7	11,716.6	1.2
Auxiliary					
Supply Fans	68,723.9	0.0	43.5	703,734.8	74.0
Circulation Pumps	0.0	0.0	0.0	0.0	0.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	68,723.9	0.0	43.5	703,734.8	74.0
Lighting	52,796.6	0.0	33.4	540,638.2	55.5
Receptacle	5,399.6	0.0	3.4	55,291.5	5.7
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	151,069.8	23,159.9	100.0	1,571,337.0	163.8

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
BLDG M514, ECO#6

----- M O N T H L Y E N E R G Y C O N S U M P T I O N -----

Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	GAS On Peak (Therm)	GAS DMND On Peak (Thrm/hr)
Jan	11,333	29	127	1
Feb	10,206	29	105	1
March	11,090	29	0	0
April	10,293	29	0	0
May	14,257	45	0	0
June	15,799	49	0	0
July	15,494	46	0	0
Aug	16,105	46	0	0
Sept	13,869	45	0	0
Oct	11,799	40	0	0
Nov	10,294	29	0	0
Dec	10,507	29	0	0
Total	151,046	49	232	1

Building Energy Consumption = 55,283 (Btu/Sq Ft/Year)
Source Energy Consumption = 161,237 (Btu/Sq Ft/Year)

Floor Area = 9,744 (Sq Ft)

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

V 6
 PAC

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M514, ECO#6

----- E Q U I P M E N T E N E R G Y C O N S U M P T I O N -----

Ref Num	Equip Code	----- Monthly Consumption -----												Total
		Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	
0	LIGHTS													
	ELEC	4413	3992	4766	4214	4589	4567	4237	4766	4214	4589	4214	4237	52,797
	PK	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1
1	MISC LD													
	ELEC	451	408	487	431	469	467	433	487	431	469	431	433	5,400
	PK	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
2	MISC LD													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4	MISC LD													
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD													
	P HOTW20	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ1170S													
			AIR-CLD COND COMP <20 TONS											
	ELEC	0	0	0	0	2750	4356	4231	4261	3004	714	0	0	19,317
	PK	0.0	0.0	0.0	0.0	14.0	16.0	15.3	15.3	13.7	9.2	0.0	0.0	16.0
1	EQ5200													
			CONDENSER FANS											
	ELEC	0	0	0	0	311	544	533	531	356	66	0	0	2,341
	PK	0.0	0.0	0.0	0.0	1.8	3.5	1.9	1.9	1.7	1.2	0.0	0.0	3.5
1	EQ5313													
			CONTROLS											
	ELEC	0	0	0	0	205	216	223	223	216	42	0	0	1,125
	PK	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.3
1	EQ4003													
			FC CENTRIF. FAN C.V.											
	ELEC	5738	5183	5738	5553	5738	5553	5738	5738	5553	5738	5553	5738	67,564
	PK	7.7	7.7	7.7	7.7	7.7	7.7	7.7	7.7	7.7	7.7	7.7	7.7	7.7
1	EQ4003													
			FC CENTRIF. FAN C.V.											
	ELEC	99	89	99	96	194	96	99	99	96	179	96	99	1,338
	PK	0.1	0.1	0.1	0.1	3.2	0.1	0.1	0.1	0.1	3.1	0.1	0.1	3.2

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
 BLDG M514, ECO#6

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 48.6 (kW)
 Yearly Time of Peak 15 (hr) 6 (mo)
 Hour 15 Month 6

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percent Of Tot (%)
Cooling Equipment				
1	EQ1170S	AIR-CLD COND COMP <20 TONS	19.8	40.65
Sub Total			19.8	40.65
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.8	16.13
Sub Total			7.8	16.13
Sub Total			0.0	0.00
Miscellaneous				
	Lights		19.1	39.21
	Base Utilities		0.0	0.00
	Misc Equipment		2.0	4.01
Sub Total			21.0	43.22
Grand Total			48.6	100.00

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M514, ECO#6

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 9,744
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	1,165.3	23,159.5	5.0	36,311.6	3.8
Primary Cooling					
Compressor	19,316.7	0.0	12.2	197,803.5	20.8
Tower/Cond Fans	2,341.4	0.0	1.5	23,975.6	2.5
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	1,124.7	0.0	0.7	11,516.9	1.2
Auxiliary					
Supply Fans	68,902.2	0.0	43.7	705,560.2	74.2
Circulation Pumps	0.0	0.0	0.0	0.0	0.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	68,902.2	0.0	43.7	705,560.2	74.2
Lighting	52,796.6	0.0	33.5	540,638.2	55.5
Receptacle	5,399.6	0.0	3.4	55,291.5	5.7
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	151,046.4	23,159.5	100.0	1,571,097.6	163.7

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 1
 BLDG M514, ECO#12

----- MONTHLY ENERGY CONSUMPTION -----

Month	ELEC	DEMAND	GAS	GAS DMND
	On Peak (kWh)	On Peak (kW)	On Peak (Therm)	On Peak (Thrm/hr)
Jan	6,927	32	35	1
Feb	6,245	32	24	1
March	7,419	29	0	0
April	6,528	29	0	0
May	7,130	29	0	0
June	7,105	29	0	0
July	7,979	41	0	0
Aug	8,928	41	0	0
Sept	7,314	40	0	0
Oct	7,130	38	0	0
Nov	6,528	29	0	0
Dec	6,553	29	0	0
Total	85,784	41	60	1

Building Energy Consumption = 30,659 (Btu/Sq Ft/Year)
 Source Energy Consumption = 90,795 (Btu/Sq Ft/Year)

Floor Area = 9,744 (Sq Ft)

Trane Air Conditioning Economics
By: Trane Customer Direct Service Network

V 600
PAGE 4

UTILITY PEAK CHECKSUMS - ALTERNATIVE 1
BLDG M514, ECO#12

----- U T I L I T Y P E A K C H E C K S U M S -----

Utility ELECTRIC DEMAND

Peak Value 41.0 (KW)
Yearly Time of Peak 16 (hr) 7 (mo)

Hour 16 Month 7

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	Percnt Of Tot (%)
Cooling Equipment				
1	EQ1170S	AIR-CLD COND COMP <20 TONS	12.1	29.62
Sub Total			12.1	29.62
Sub Total			0.0	0.00
Air Moving Equipment				
1		SUMMATION OF FAN ELECTRICAL DEMAND	7.8	19.13
Sub Total			7.8	19.13
Sub Total			0.0	0.00
Miscellaneous				
	Lights		19.1	46.49
	Base Utilities		0.0	0.00
	Misc Equipment		2.0	4.75
Sub Total			21.0	51.25
Grand Total			41.0	100.00

Trane Air Conditioning Economics
 By: Trane Customer Direct Service Network

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 1
 BLDG M514, ECO#12

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT -----

Weather Name ATLANTA.
 Gross Conditioned Floor Area (sqft)..... 9,744
 ACM Multiplier 1.025

----- E N E R G Y U S E S U M M A R Y -----

	ELEC (kWh/yr)	GAS (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	141.9	5,964.3	2.2	7,730.9	0.8
Primary Cooling					
Compressor	3,149.9	0.0	3.6	32,254.7	3.4
Tower/Cond Fans	391.0	0.0	0.4	4,004.3	0.4
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	180.3	0.0	0.2	1,846.3	0.2
Auxiliary					
Supply Fans	23,724.8	0.0	27.1	242,942.1	25.6
Circulation Pumps	0.0	0.0	0.0	0.0	0.0
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	23,724.8	0.0	27.1	242,942.1	25.6
Lighting	52,796.6	0.0	60.3	540,638.2	55.5
Receptacle	5,399.6	0.0	6.2	55,291.5	5.7
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	85,784.0	5,964.3	100.0	884,708.1	91.5

APPENDIX F
FIELD SURVEY DATA



C E R T I F I C A T E O F C A L I B R A T I O N

f o r

EMC ENGINEERS
1950 SPECTRUM CIRCLE
SUITE 312
MARIETTA, GA 30067

Cust PO# 62584
Omega WO# 202992981

Model# HH-23
Serial# T-54474

C A L - 3

OMEGA Process Controls Inc certifies that the above instrumentation has been calibrated to meet or exceed the published specifications. This calibration was performed using instrumentation and standards that are traceable to the United States National Institute of Standards and Technology, and is in compliance with MIL-STD-45662A.

Readings Observed in: Fahrenheit

STANDARD	AS RECEIVED	FINAL CAL
32	32.5	32.0
900	900.8	900.4
1800	1800.4	1800.0

TEST EQUIPMENT

Fluke 8860A Digit Multimeter, S/N 3335023
Analogic AN-3100 DC Standard, S/N 7904379
Gen Res RDS63-A Dec Resistor, S/N 591
Omega TRC-III Ice Point Cell, S/N 003


NIST (NBS)

245516
245516
241457
241457

TEST CONDITIONS

Temp: 23C Rel Hum: 26%

CERTIFIED BY
John L. Howard


Instrumentation Supervisor

BUILDING 022

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO. _____ OF _____

CALCULATED BY: _____
CHECKED BY: _____
DATE: 12-17-91

BLDG.# 22
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. RM	1 1/2"	150'	HW	180°	70	RUBBER	1/2"	GOOD
↓	1 1/2"	150'	CW	NA		↓	↓	↓

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. 22
CALCULATED BY:
CHECKED BY:
DATE

OF

KC

12-17-91

BLDG.# 22
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
FAN ROOM	24 X 24		72	60	FIBERGLASS FOL	1"	GOOD

COMMENTS: ONLY ONE AHU. OTHERS ARE FAN COIL.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO. _____ OF _____

CALCULATED BY: JW
CHECKED BY:
DATE: 12/17/91

BLDG.# 22
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
15	DOUBLE	CASEMENT	(ALUM) METAL	W	NO	BLINDS	38x47 38x47
24	"	"	"	S	"	"	"
8	"	"	"	E	"	"	"
17	"	"	"	N	"	"	"

COMMENTS: ALL WINDOWS ARE FAIRLY NEW METAL CASEMENT W/ NO INFILTRATION.

BLDG.# 22
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
① D	W.S. ON BOTTOM LEFT MISSING	HIGH	W	60x80	1
W	EXCEL.	NONE	W	34x47	15
"	"	"	NSE	"	Ref to WINDOWS
⊙ D	GOOD	LOW	N ¹ / ₄ E ¹ / ₄ TENDS	35x80	2
D	"	"	N ¹ / ₄ E ¹ / ₄ BACKS	"	2
① D	W.S. ON BOTTOM LEFT MISSING	HIGH	E	60x80	1

COMMENTS: ① FRONT DOOR HAS 1/2" AIR GAP ON BOTTOM W/ HIGH INFILTRATION. WEATHER STRIP ACROSS BOTTOM IS MISSING.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY:
CHECKED BY:
DATE:

BLDG.# 72
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Rm. 107 sink	138°F
Rm. 104 sink	134°F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-17-91

BLDG.# 22
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>2</u>	PH		RPM	<u>3450</u>
MODEL #	<u>JMM355T</u>	VOLTS	<u>208</u>	AMPS	<u>5.7</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BALDOR</u>	REQUIRED HR.		TO			
FRAME	<u>145JM</u>	EFF.	<u>79%</u>				
DESCRIPTION	<u>CWP</u>	COMMENTS	<u>OPERATE DURING SUMMER</u>				
	<u>NO PUMP INFO</u>						
MOTOR #	<u>2</u>	HP	<u>1/4</u>	PH		RPM	
MODEL #		VOLTS	<u>115V</u>	AMPS	<u>?</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BELL & GOSSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>HW PUMP</u>	COMMENTS	<u>OPERATE DURING WINTER</u>				
MOTOR #	<u>3</u>	HP		PH		RPM	<u>1725</u>
MODEL #	<u>M7479Z</u>	VOLTS	<u>115</u>	AMPS	<u>4.2 7</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BELL GOSSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>DHW PUMP MOTOR</u>	COMMENTS	<u> </u>				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KU
 CHECKED BY: _____
 DATE: 12-17-91

BLDG.# 22
 ECO 5 _____

MOTORS

MOTOR #	<u>4</u>	HP	<u>1/2</u>	PH	<u>1φ</u>	RPM	<u>1725</u>
MODEL #	<u>S-104633-23</u>	VOLTS	<u>115</u>	AMPS	<u>7.2</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>GOULD</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU</u>	COMMENTS					
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					

EMD

12-3-77

BLDG.#
ECO 8

22

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW- FLOW (QTS/SEC)	LOCATION
			4 1/2 / 45 1.5	5 / 45	Room


FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION
		40 / 10	40 / 35	107

COMMENTS:

Flow rate measured from a low-flow
faucet was not as low as expected.



The faucet RESTRICTOR is very weak & not very practical

Page 22



1001


1002




201
 100-52-53-54-55-56
 100-52-53-54-55-56
 100-52-53-54-55-56

- A. PANEL: Pre-rinsed enclosure, Nomal, 200 x 100 x 100 surface mounted, vinyl finish.
- B. TIME CLOCK: 7008-00 Paragon 7-day clock.
- C. ACTUATOR: 59644, See List for details. Motor. T. Also, timing, +10' shaft.
- D. SWITCH: Heat-0001 4 pole double throw, 20 amp, 115V, 1 phase, 1/2" x 1/2" x 1/2" inside panel.
- E. MOTOR: 70033, 1/2 HP, 115V, 1 phase, 1/2" x 1/2" x 1/2" inside panel.
- F. VALVE: 1975A 1209, trial set 2777, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- G. VALVE: 16,700 1033 clamp gear control, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- H. VALVE: Air handling unit control valve, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- I. ELEMENT: 2 poles, 2 poles, return control, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- J. ELEMENT: 1193 Valve box 7/8" x 1/2" x 1/2" in return air.
- K. ELEMENT: 16029E 1237, 125 F. motor, 1/2" x 1/2" x 1/2" in return air.
- L. CONTACTOR: 88232B 3094, 30 amp, 2-pole with 138522B enclosure.
- M. VALVE: Boiler water temperature control valve, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- N. ELEMENT: 15013A 1211 valve box 7/8" x 1/2" x 1/2" in return air.
- O. ELEMENT: 17083A 1023 with immersion well.
- P. ELEMENT: 77053B 1015.
- Q. VALVE: 7078C 1005 DPDT high comp. limit, 2 inch, 1/2" x 1/2" x 1/2" with 13137A well 1/2" x 1/2" x 1/2" in return air.
- R. VALVE: System diverting valve, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- S. VALVE: AT-396, 11/16" x 1/2" x 1/2" in return air.
- T. VALVE: System mixing valve control, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- U. VALVE: AT-794, 11/16" x 1/2" x 1/2" in return air.
- V. VALVE: VS-9213 mixing valve, 2 inch, 1/2" x 1/2" x 1/2" in return air.
- W. VALVE: 7001A 1029 set 6" x 2" x 1/2" in return air.
- X. VALVE: 7001A 1029 set 6" x 2" x 1/2" in return air.
- Y. VALVE: 7001A 1029 set 6" x 2" x 1/2" in return air.
- Z. VALVE: 7001A 1029 set 6" x 2" x 1/2" in return air.

Page 2



3PHASE MOTOR - 3
 DIVERTIVE WAKE - 5
 SON ST - 2
 Ground - 1



Control circuit check flow switch by 1-1-67
 100 (motor supply) 100V 50/60 Hz
 100V 50/60 Hz 200V 50/60 Hz
 100V 50/60 Hz 200V 50/60 Hz

WIRE WOUND DIAGRAM
 MADE BY (23)
 EDWIN W. PHELPS, JR., GE.
 CONTRACTOR - NEWARK, N.J.

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CND
 CHECKED BY: _____
 DATE: 12-17-50

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 22 BLDG NAME: _____ JOB: 3105.000
 PRIMARY FUNCTION: Housing GROSS SQ FT _____ NO OF FLRS 1
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: Room 105 (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 72.5 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: NEW LOBBY (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 73.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 3 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: HALL (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 71.3 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

Rooms are occupied 24 hrs/day

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____



CWRUMP MOTOR

BALDOR JMM355ST
 FM 145JM 79% eff.
 2HP 208V 5.7A 3Ø 3450
 NO PUMP INFO

DHW

HW PUMP

BELL & GOSSETT	BELL & GOSSETT
3/4 HP 1725 RPM	60 PUMP
115V 7.0A.	SER 165 1468
M7479Z	IDEN# 172542
	SER# 1376498

BOILER

BRADFORD WHITE WATER HEATERS, INC
 MOD. M-I-805-500-3NA
 80 GAL
 50,000 BTUH IN POT 454.5 GAL/HR

HW BOILER

THE H B SMITH CO. INC.
 6300 S/W-8 INT 525 BTUH IN
 NAT GAS. 420 BTUH OUT

HW PUMP 1/4" HP 115V.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY KC DATE 12-17-91

CHECKED BY _____ DATE _____


SCALE _____

BLDG 22

ROOM 107
2-PIPE FAN COIL



FAN { 0.35A
115V.



- 1 HEATER.
- TV (70W)
- 1 TABLE LAMP [60W]
- 1 FRG. (1-2A 120V)
- 1 OVERHEAD (2 LAMP)[60W]
- 1 NIGHT LAMP. (2-60W)
- 1 RADIO ALAM CLOCK (10W)
- 1 LAMP OVER SINK 18" FLOR.
- 1 BATHROOM 60W
- 1 BATHROOM FAN HOMESTYLE

(SOME ROOM MAY HAVE (ADDITIONAL FLOOR LAMP)

TRANE CHILLER

200V 3φ

MODEL CGABC256AD00F3

SER J83L81208

- 1 COMP MOTOR 200V 3φ 86 RLA
- 3 FAN " " 200V 3φ 4.1 FLA each.

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • Germany

JOB 3105
SHEET NO. _____ OF _____
CALCULATED BY PRB DATE 12/17/71
CHECKED BY _____ DATE _____
SCALE _____

E 1/2 02

RASE LOADS

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

4. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

1. max. allowed

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____


SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

HALLWAY BLDG 22 LIGHTING LAYOUT

- 435F
- 60W INC.
- ⊠ 13 W FLOOR.



THIS DOOR IS WEATHERSTRIPT
TIGHT

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____



SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____

SCALE _____

HEATING LOAD OF OFFICES BEHIND RECEPTION DESK



BUILDING 027


EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: _____

BLDG.# 27
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>Al. Sp. 1/16</u> 3. <u>1/2" POLYSTYRENE</u> 4. <u>1x6 PLANKS</u> 5. <u>FRAME</u> 6. <u>GYP. CEILING</u> 7. INSIDE AIR FILM <u>4" BATT INSUL</u>
	0.17 .61 4.17 1.25 R-11 .45 1.68 <hr/> 18.33

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>Shingles</u> 3. <u>FR. BOARD</u> 4. <u>SPACE</u> 5. <u>6" BATT INSUL</u> 6. <u>GYP. CEILING</u> 7. INSIDE AIR FILM
	.17 .44 1.25 1.24 R-19 .45 1.68 <hr/> 23.23

PERSONNEL DOOR TYPE _____	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB []
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: JW

CHECKED BY: _____

DATE 12/17/91

BLDG.# 27
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
BASEMENT	2"	200'	HOT & COLD WATER			1" FIBERGLASS	1"	GOOD

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

← opposite for 28

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO. OF

BLDG.# 27 & 28
ECO 2

CALCULATED BY: JW
CHECKED BY:
DATE: 12/17/91

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
28	DOUBLE	SLIDING	METAL	W	NONE	BLINDS	40X54
21	"	"	WOOD	E	"	"	"
4	"	"	"	N	"	"	"
5	"	"	"	S	"	"	"

COMMENTS: WINDOWS ARE IN GOOD CONDITION

BLDG.# 27 APPT.#2
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	EXCEL	NONE	W	40x54	
D	GOOD	LOW	S	33x80	1
D	POOR	LOW	E	33x80	1

whole Bldg =>
Appt-2 ①
Appt-2 ②

COMMENTS: THIS BUILDING IS FULLER IN SUMMER THAN WINTER. ① THIS DOOR OPENS TO HALLWAY. ② THIS DOOR OPENS TO BACK PARKING LOT. IT HAS LARGE AIR GAP BUT ALSO HAS STORM DOOR WITH MED/LOW INFILTRATION.

TOTAL DOORS OPENING OUT / BLDG = 5

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE: 12-18-91

BLDG.# 27
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Apt 2. Kitchen	128
Apt 2 Bathroom	127
Apt 1 Kitchen	130
Apt 1 Bathroom	129
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: _____

BLDG.# 27
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	<u>1745</u>
MODEL #	<u>8-332730-02</u>	VOLTS	<u>115/230</u>	AMPS	<u>18/9</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>CENTURY</u>	REQUIRED HR.				TO	
FRAME	<u>P145JM</u>	EFF.					
DESCRIPTION	<u>DTW</u>	COMMENTS	<u>MAKE LOUD NOISE</u>				
MOTOR #	<u>2</u>	HP	<u>1/4</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>M95171</u>	VOLTS	<u>115</u>	AMPS	<u>4.9</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>BELL GOSSETT</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>BOILER HW CIR. PUMP</u>	COMMENTS	<u>RUN WHEN BOILER FIRED</u>				
MOTOR #	<u>3</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>M091814-90</u>	VOLTS	<u>115V</u>	AMPS	<u>1.75</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>BELL GOSSETT</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>DHW CIR.</u>	COMMENTS	<u>DHW BOILER UNIT.</u>				

BLDG.# 27
ECO 8

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW-FLOW (QTS/SEC)	LOCATION
1	1	5 or 6	5 - 30	3 / 30	Bathroom Apt 2

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION
2	5 or 6	24 / 5	12 / 5	Bathroom & kitchen, Apt. 2

COMMENTS: Total of 6 unit in this building. Stay about 60% occupied.

- 5 - The unit is 3-bed room. 1 shower 2 faucets
- 1 - " " 2 " " 1 shower 2 faucets

BUILDING 028

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KK
CHECKED BY: _____
DATE: 12-18-91

BLDG.# 28
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Apt 1 Kitchen	148
Apt 1 Bathroom	149

PROBLEMS:

COMMENTS:

BLDG.# 28
 ECO 8

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW-FLOW (QTS/SEC)	LOCATION
1		5	6-30	3-30	Apt 1

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION
		20-5	6-5	Apt 1

COMMENTS:

- There are 6 units in this building
- 5 are 3 bedrooms, 1 is 2 bedrooms
- all rooms has 2 faucets & 1 shower.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 28

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____

SCALE _____

THERE ARE 6 APARTMENTS / BLDG.
APPT #1 HAS EAST MAIN DOOR OPENING TO OUTSIDE
WITH NO STORM DOOR.

THE ~~CAUSE~~ WEATHER STRIP IS PRESENT BUT
DOOR DOES NOT CLOSE TOUCHING WEATHER STRIP,
CAUSING ~~ME~~ / HIGH INFILTRATION.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-17-91

CHECKED BY _____ DATE _____

SCALE _____

Bldg 28

- HW and CW PROVIDED FROM BLDG. 27.
- MECH. ROOM HAS ONLY DOMESTIC HW & HW TANK & CIR. PUMP.
- PIPE INSULATION IN SAME CONDITION AS BLDG 27

GENERAL

- BLDG. IS IDENTICAL TO 27.

HOURS = 0-2400 (APARTMENTS)

BUILDING 040

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/16/91

BLDG.# 40
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS																
<p>BRICK GYP BOARD</p>	<table border="0"> <tr><td>1. OUTSIDE AIR FILM</td><td>.17</td></tr> <tr><td>2. BRICK</td><td>1.24</td></tr> <tr><td>3. R-11</td><td>11</td></tr> <tr><td>4. GYP BOARD</td><td>0.45</td></tr> <tr><td>5.</td><td></td></tr> <tr><td>6.</td><td></td></tr> <tr><td>7. INSIDE AIR FILM</td><td>.68</td></tr> <tr><td></td><td><u>13.54</u></td></tr> </table>	1. OUTSIDE AIR FILM	.17	2. BRICK	1.24	3. R-11	11	4. GYP BOARD	0.45	5.		6.		7. INSIDE AIR FILM	.68		<u>13.54</u>
1. OUTSIDE AIR FILM	.17																
2. BRICK	1.24																
3. R-11	11																
4. GYP BOARD	0.45																
5.																	
6.																	
7. INSIDE AIR FILM	.68																
	<u>13.54</u>																

SKETCH ROOF CROSS-SECTION	COMPONENTS																
	<table border="0"> <tr><td>1. OUTSIDE AIR FILM</td><td>.17</td></tr> <tr><td>2. SHINGLES</td><td>.44</td></tr> <tr><td>3. 1/2" PLYWOOD</td><td>.62</td></tr> <tr><td>4. AIR SPACE</td><td>1.24</td></tr> <tr><td>5. R-11</td><td>11</td></tr> <tr><td>6. DROP CEILING</td><td>.45</td></tr> <tr><td>7. INSIDE AIR FILM</td><td>.68</td></tr> <tr><td></td><td><u>14.6</u></td></tr> </table>	1. OUTSIDE AIR FILM	.17	2. SHINGLES	.44	3. 1/2" PLYWOOD	.62	4. AIR SPACE	1.24	5. R-11	11	6. DROP CEILING	.45	7. INSIDE AIR FILM	.68		<u>14.6</u>
1. OUTSIDE AIR FILM	.17																
2. SHINGLES	.44																
3. 1/2" PLYWOOD	.62																
4. AIR SPACE	1.24																
5. R-11	11																
6. DROP CEILING	.45																
7. INSIDE AIR FILM	.68																
	<u>14.6</u>																

PERSONNEL DOOR TYPE _____	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB []
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ. #
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

OF

EC

12-16-91

BLDG.# 40
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
		NO DUCT - 2-PIPE FANCOIL					

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY:
 CHECKED BY:
 DATE: 12-16-71

BLDG.# 40
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
Mech. Rm ↓	4"	50'	H/W		55°	Rubber	1/2"	FAIR
	1.5"	200'	H/W		55°	Fiberglas	.75"	FAIR
	5"	35'	STM		"	Fiberglas	1"	
	1"	20'	STM		"		1"	
	4.5"	75'	CW		"		1/2"	
	3"	39'	CW		"	SOLID FOAM	2"	

COMMENTS: BASEMENT - ~~Pop~~ Pump housing, joint, coupling need insulation

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: JW

CHECKED BY:

DATE: 12/16/91

BLDG.# 40

ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
1-13	SINGLE	SLIDE	WOOD	S	GLASS NONE	CURTAINS	50 x 73
1-22	"	"	"	E	"	"	"
13 18	"	"	"	N	"	"	"
	"	"	"	W	"	"	64 x 80

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/16/91

BLDG.# 40
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	NONE	LOW	S	40x73	13
D	NONE	MED	S	72x30	1
W	NONE	LOW	E	40x73	22
D	NONE	HIGH	N	72x30	1
W	NONE	LOW	N	40x73	13
W	NONE	LOW	W	64x80	18
D	"	"	W	60x84	3
D	"	"	W	60 34x84	2

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO.: _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-16-01

BLDG.# 40
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
2 ND FLOOR KITCHEN	131°F
BASEMENT RESTROOM	129°F
PROBLEMS:	

COMMENTS:

BLDG.# 40
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1740</u>
MODEL #	<u>F-4542-00-471</u>	VOLTS	<u>230</u>	AMPS	<u>9.2</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>UNICLOSED MOTOR</u>	REQUIRED HR.		TO			
FRAME	<u>182T</u>	EFF.					
DESCRIPTION	<u>DTW PUMP</u>		COMMENTS				
	<u>MANUAL CHANGEOVER</u>						
MOTOR #	<u>2</u>	HP	<u>1/5 ?</u>	PH	<u>1</u>	RPM	
MODEL #		VOLTS	<u>115V</u>	AMPS	<u>?</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BELL GOSSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>HW CIRCULATOR</u>		COMMENTS <u>NOT RUNNING - OLD.</u>				
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					

JOB
 PROJ.#
 SHEET NO.
 CALCULATED BY:
 CHECKED BY:
 DATE:

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000
 _____ OF _____
EMD

12-13-01

BLDG.# 40
 ECO 8

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW-FLOW (QTS/SEC)	LOCATION
<u>8/6</u>	<u>2</u>	<u>30 30</u>	<u>3.25</u>	<u>1.25</u>	

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ.\SEC.	GPM w/ LOW FLOW RESTR.	LOCATION
<u>3</u>		<u>48 7</u>	<u>20/15</u>	<u>1st Floor KITCHEN</u>

COMMENTS:

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: C.M.V.
 CHECKED BY: _____
 DATE: 12-16-92

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 40 BLDG NAME: _____ JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
 SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 1st Floor (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 66.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 2nd Floor (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 66.4 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 041

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: SCV
 CHECKED BY: _____
 DATE: 12-1-91

BLDG.# 41
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS	0	0	0	0
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Brick 3. Cement 4. 5. 6. 7. INSIDE AIR FILM

.17
 1.24
 1.60
 .68

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Sheathing 3. Plywood 4. Air Space 5. R-10 insulation 6. Drop ceiling 7. INSIDE AIR FILM

.17
 .44
 .62
 1.24
 1.40
 .45
 .68
 22.60

PERSONNEL DOOR TYPE <u>wood</u>	BASEMENT []
OVERHEAD DOOR TYPE <u> </u>	SLAB []
	CRAWL SPACE <input checked="" type="checkbox"/>

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000
KC
12-16-91

BLDG.#
ECO 1

41

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. RM	1/2 ACCU REFR LINE.	75'	DX	NOT DR.	55' F	NONE	NONE	
BOILER RM	3"	150'	HW			RUBBER	1/2"	
↓	2"	50'	HW			RUBBER	1/2"	

COMMENTS: GOOD CONDITION INSULATION

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY


Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000

JOB
 PROJ.#
 SHEET NO. RC
 CALCULATED BY:
 CHECKED BY:
 DATE 12-18-91

BLDG.#
 ECO 1

41

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH RM	24" X 24"		65°F	55°F	FIBERGLASS	3/4"	GOOD

COMMENTS:

AHU HAS OA DAMPER SET TO OPEN IF OA 60°F

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE:

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000
OF

BLDG.# 41
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
	Double	Sliding	Al	E	None	Burbs	81 x 32
	Typ of 8						
	"	"	"	S	"	"	"
	Typ of 9						
	"	"	"	N	"	"	"
	Typ of 10						
	"	"	"	W	"	"	"
	Typ of 16						

COMMENTS:

BLDG.# 41
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	No.
W	Good	Low	E	81 X 32	8
W			S		9
W			N		10
W			W		16
① D	FAIR	LOW & MED HIGH	E & W	78 X 58	② 2
② D	POOR Good	HIGH	W	87 X 34	2
D	Good		W	83 X 36	1
D	Good	MED HIGH	N	81 X 35	1
D	Good	LOW	E	82 X 35	1

COMMENTS:

① West D, 1/4" Gap at bottom of door ② HIGH INFILTRATION GAP DUE TO WARPED DOOR.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMB
CHECKED BY: _____
DATE: 12-15-91

BLDG.# 41
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
1 st Floor Restroom	154 °F
2 nd Floor Restroom	148 °F
PROBLEMS:	

COMMENTS:

BLDG.# 4
ECO 5

MOTORS

MOTOR #	<u>4</u>	HP	<u>1/2</u>	PH	<u>12∅</u>	RPM	<u>1725</u>
MODEL #	<u>M80067</u>	VOLTS	<u>115</u>	AMPS	<u>5.2</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BELL GROSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>HWP</u>	COMMENTS					
MOTOR #	<u>5</u>	HP	<u>0.5</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>CJL1304A</u>	VOLTS	<u>115V</u>	AMPS	<u>8.4</u>		
SERIAL #	<u>W2-91</u>	PRESENT HR.		TO			
MFG	<u>BALDOR</u>	REQUIRED HR.		TO			
FRAME	<u>56J</u>	EFF.			<u>.62 PF</u>		
DESCRIPTION	<u>CWS</u>	COMMENTS					
MOTOR #	<u>6</u>	HP	<u>0.5</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>CJL1304A</u>	VOLTS	<u>115</u>	AMPS	<u>8.4</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BAL</u>	REQUIRED HR.		TO			
FRAME	<u>56J</u>	EFF.			<u>.62 PF</u>		
DESCRIPTION	<u>CWR</u>	COMMENTS	<u>NOT RUNNING.</u>				

BLDG.# 41
ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1/3</u>	PH	<u>1</u>	RPM	
MODEL #		VOLTS	<u>200</u>	AMPS	<u>3.7</u>		
SERIAL #		PRESENT HR.		T'STAT	<u>0</u>	TO	<u>2400</u>
MFG	<u>TRANE PACKAGE</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>AHU FAN MOTOR</u>		COMMENTS				
	<u>MECH ROOM</u>						
MOTOR #	<u>2, 3</u>	HP	<u>1</u>	PH	<u>3</u>	RPM	
MODEL #		VOLTS	<u>200V</u>	AMPS	<u>3.5</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>EDPAC UNIT</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>AHU FOR LIBRARY BOOKS</u>		COMMENTS				
	<u>AND SMALL OFFICE</u>						
MOTOR #	<u>7</u>	HP	<u>1/2</u>	PH	<u>3</u>	RPM	<u>1750</u>
MODEL #	<u>M80037-DA88</u>	VOLTS	<u>200</u>	AMPS	<u>1.8</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>BELL GOSSETT</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>CWP CIRCULATION</u>		COMMENTS <u>NEXT TO CHILLER</u>				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KCC
CHECKED BY: _____
DATE: 12-16-91

BLDG.# 41
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1	2	4	34	FLOR	OFF	Y	Y	2	NO
2	2	4	34	FLOR	ON	Y	Y	1	NO
3	4	4	34	FLOR	ON	Y	N	1	NO
4	3	4	34	FLOR	ON	Y	Y	1	NO
5	4	4	34	FLOR	ON	Y	Y	2	NO
6	5	1	60	INC.	ON	Y	N	2	-
7	2	4	34	FLOR	ON	Y	N	1	NO
8	6	4	34	FLOR	OFF	Y	N	1	NO
9	2	4	34	↓	ON	Y	Y	1	NO
10	2	4	34	↓	ON	Y	Y	1	NO
11	1	4	34	↓	ON	Y	N	2	-
12	20	4	34	↓	OFF	Y	N	2	NO
13	3	4	34	FLOR	ON	Y	Y	1	NO
14	3	4	34	↓	ON	Y	Y	1	
15	1	1	60	INC	ON	Y	Y	1	
16	1	1	60	↓	ON	Y	Y	1	
17	1	1	60	↓	OFF	Y	Y	1	
18	4	4	34	FLOR	OFF	Y	N	1	↓

OF EXIT SIGNS - 3

COMMENTS: FIRST FLOOR

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-16-91

BLDG.# 41
 EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
19	2	4	34	FLOR.	ON	Y	Y	1	NO
20	4	4	34	FLOR.	ON	Y	N	1	NO
21	6	4	34	↓	ON	Y	N	1	NO
22	3	1	60	INC.	ON	Y	N	1	1
23	5	4	34	FLOR.	ON	Y	N	2	1
24	2	4	34	↓	ON	Y	Y	1	NO
25	2	4	34	↓	OFF	Y	Y	1	NO

OF EXIT SIGNS - 1

COMMENTS: SECOND FLOOR

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: cmo
 CHECKED BY: _____
 DATE: 12-13-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 41 BLDG NAME: A. J. ... JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 2
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 1st Floor (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1630, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 80.9 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 2nd Floor (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1630, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 74.4 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-16-91

CHECKED BY _____ DATE _____


SCALE _____

FIRST FLOOR



- 11, 6 ARE HALLWAY
- 12 IS A COURT ROOM

SECOND FLOOR



BUILDING 042

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: _____

BLDG.# 42
 ECO 1 _____

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS	
	1. OUTSIDE AIR FILM	.17
	2. BRICK 2 1/2"	1.25
	3. PLASTER	
	4. GYP BOARD	.45
	5. 4" BATT INSUL	1.1
	6. INSULATION	
	7. INSIDE AIR FILM	.68
		<u>13.55</u>

SKETCH ROOF CROSS-SECTION	COMPONENTS	
	1. OUTSIDE AIR FILM	.17
	2. SHINGLES	.44
	3. PLYWOOD	.62
	4. 8" R-19 FIBERGLASS	1.9
	5. GYP BOARD	.45
	6. AIR SPACE	1.25
	7. INSIDE AIR FILM	.68
		<u>22.61</u>

PERSONNEL DOOR TYPE _____	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB [<input checked="" type="checkbox"/>]
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB
 PROJ.#
 SHEET NO. 12 OF
 CALCULATED BY:
 CHECKED BY:
 DATE: 12-6-91

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000

42

BLDG.#
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
2ND FLOOR	1 1/2 DTW TO COIL	40'	WATER		68	FIBERGLASS	1"	FAIR

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: KC OF
 CALCULATED BY:
 CHECKED BY:
 DATE: 12-16-91

BLDG.#: 42
 ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
2ND FL	18" X 12" SUPPLY BRANCH	□	85	68	NONE		
	24" X 24" SUPPLY 10'	□	85	68	NONE		
					NONE		

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000

SHEET NO. OF

CALCULATED BY: JW

CHECKED BY:

DATE: 12/16/91

BLDG.# 42
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MATT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
1-6	Star glass w/ plyra glass	SLIDE	WOOD	E	STAIN	1/8" PLEXI	84x36
1-22	SINGLE/STORM WINDOW	SLIDE	WOOD	W	BUNDS	ST. WIN.	27x60

COMMENTS:

BLDG.# 42
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
D	NONE	LOW	N	7' X 5' = 84 X 60	1
① W	GOOD		E	84 X 36	6
D	NONE	LOW	E	84 X 60	1
D	NONE	LOW	E	84 X 36	1
① W			S	72 X 48	1
D	Good	NONE	S	84 X 30	1
② W	Good	NONE	W	27 X 60	22
D	NONE	MED	N	84 X 30	1
③ D	NONE	HEAVY	W	84 X 60	1

① Permanent closed →

COMMENTS: ① 1/8" Plexiglas panels over all stain glass windows
NOTE: WEST SIDE IS NEW ADDITION (WOOD WALLS, NOT BRICK)
② STORM WINDOWS ③ DOORS are broken and are not operable

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE: 12-16-91

BLDG.# 42 CHAPEL
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
KITCHEN	140°F
MEN'S ROOM	142°F
PROBLEMS: NO	

COMMENTS:

BLDG.# 42
ECO 5

MOTORS

MOTOR #	HP	PH	RPM	
	1.5		3	1725
MODEL #	VOLTS	AMPS		
	208	5.3		
SERIAL #	PRESENT HR.	TO		
F1085	#			
MFG	REQUIRED HR.	TO		
BALDOR				
FRAME	EFF.			
56C	78			
DESCRIPTION	CHILLER CIRC. PUMP	COMMENTS	OFF when suspended	
MOTOR #	HP	PH	RPM	
MODEL #	VOLTS	AMPS		
SERIAL #	PRESENT HR.	TO		
MFG	REQUIRED HR.	TO		
FRAME	EFF.			
DESCRIPTION		COMMENTS		
MOTOR #	HP	PH	RPM	
MODEL #	VOLTS	AMPS		
SERIAL #	PRESENT HR.	TO		
MFG	REQUIRED HR.	TO		
FRAME	EFF.			
DESCRIPTION		COMMENTS		

BLDG.# 42
ECO 5

MOTORS

MOTOR #	<u>AHV FAN</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1755</u>
MODEL #	<u>LINCOLN</u>	VOLTS	<u>230/460</u>	AMPS	<u>83/4.1</u>		
SERIAL #	<u>FRAME: 182T</u>	PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>LINCOLN</u>	REQUIRED HR.		TO			
FRAME	<u>182T</u>	EFF.					
DESCRIPTION	COMMENTS <u>NAME PLATE MISSING FROM OPERATING MOTOR.</u> ← <u>REPLACEMENT MOTOR</u>						
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	COMMENTS _____						
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	COMMENTS _____						

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMJ
 CHECKED BY: _____
 DATE: 17-10-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 42 BLDG NAME: Chapel JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: SANCTUARY (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 72.3 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 2nd Floor (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 70.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 056

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY cmd DATE 12-18-71

CHECKED BY _____ DATE _____

SCALE _____

Bldg 56

DOORS, WINDOWS, INSUL. ETC,

SAME AS 58

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY:
CHECKED BY: _____
DATE: 12-18-91

BLDG.# 56
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
1 st FLOOR LAIR NE West Wing	140 °F
1 st FLOOR LAIR NE East Wing	138 °F
PROBLEMS:	

COMMENTS:

JOB
 PROJ.#
 SHEET NO.
 CALCULATED BY:
 CHECKED BY:
 DATE:

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000
 _____ OF _____
crb

12-18-91

BLDG.#
 ECO 8

56

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW- FLOW (QTS/SEC)	LOCATION
			-		

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION

COMMENTS:

SEE BIDg 58

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEC DATE 12/18

CHECKED BY _____ DATE _____

SCALE _____

56

CONTROLS & EQUIPMENT SAME
AS 58

WEST WING

1ST FLR ROOM FAN COILS 2 (ON)

" " HALL " " 1 (ON)

2ND FLR ROOM " " 1 (ON) 1 (OFF)

EAST WING

same

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CRD
CHECKED BY: _____
DATE: 12-18-91

BLDG.# 56
EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON

OF EXIT SIGNS - _____

COMMENTS: SEE Bldg 58

BUILDING 058

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CEL
CHECKED BY: _____
DATE: 12/18/91

BLDG.# 58
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
1ST FLOOR BATH	136°F
PROBLEMS: <u>NONE</u>	

COMMENTS:

BLDG.# 5B
ECO 5

MOTORS

MOTOR #	<u>NAMEPLATE</u>	HP	<u>est. 1/8</u>	PH	<u>1</u>	RPM	<u>3 speed</u>
MODEL #	<u>NOT</u>	VOLTS	<u>115</u>	AMPS	<u>NA</u>		
SERIAL #	<u>ACCESSIBLE</u>	PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG		REQUIRED HR.	<u>0</u>	TO	<u>2400</u>		
FRAME		EFF.					
DESCRIPTION	<u>FAN COIL FANS</u>		COMMENTS <u>TYPICAL OF (5)</u>				
	<u>WEST WING</u>						

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____		COMMENTS _____				

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____		COMMENTS _____				

BLDG.#
ECO 8

58
WEST WING FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW-FLOW (QTS/SEC)	LOCATION
WEST 1ST FLOOR 2	1 per person		5-15	3-30	
2ND FLOOR 4	1 "	"			

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION
WEST 1ST FLOOR 4		29/5	*	
2ND FLOOR 8				

COMMENTS:

-WATER PRESSURE IS A PROBLEM, TEMP. VARIES
DEPENDING ON SINKS & TOILETS
* RESISTECTOR WOULD NOT FIT

BLDG.# 58
 ECO 15

LIGHTING

EAST

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
121-128	1	2	34	4th Floor	OFF	Yes	NO	1	
121-128 HALL	4	1	34	4th Floor	ON	Yes	NO	1	
M.E.N. 1st	2	2	34	4th Floor	ON	Yes	NO	2	
EAST 1st HALL	4	1	34	4th Floor	ON	Yes	NO	1	
1st FLOOR RESTROOM	3	2	34	4th Floor	ON	Yes	NO	1	
131-139	1	2	34	4th Floor	OFF	Yes	NO	1	
121-129	1	1	34	4th Floor	OFF	Yes	NO	1	
131-139	1	1	34	4th Floor	OFF	Yes	NO	1	
200 2nd	2	2	34	4th Floor	ON	NO	NO	2	
200	4	1	34	4th Floor	ON	Yes	NO	1	
200-227	1	2	34	4th Floor	OFF	Yes	NO	1	
200	1	1	34	4th Floor	OFF	Yes	NO	1	
200 2nd HALL	4	1	34	4th Floor	OFF	Yes	NO	1	
231-237	1	2	34	4th Floor	OFF	Yes	NO	1	
231-237	1	1	34	4th Floor	OFF	Yes	NO	1	
231-237	13	1	54	INCAN	ON	Yes	NO	5	

A

OF EXIT SIGNS - 7

COMMENTS:

~~NOTE~~ NOTE: MULT TOTAL LIGHTING WEST SIDE ALSO
 X Z TO INCLUDE WEST SIDE ALSO

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 12/18

CHECKED BY _____ DATE _____

SCALE _____

58

EAST WING

1ST FLR FAN COILS OFF (2)
HALL " " ON (1)

2ND FLR FAN COILS ON (2)

~~3~~

WEST WING

1ST FLR FAN COIL OFF L 7
HALL " " ON (1)
2ND FLR " " ON (2)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

EAST

— 1ST FLOOR HALLWAY

2 PIPE FAN COIL 1/8 HP, 115V, NO NAMEPLATE
3 SPEED FAN, NO ~~VALVE~~ VALVE ON COIL

— ROOMS

2 PIPE FAN COILS SEE CONTROL DIAGRAM

ROBERTSHAW ^{DWG. NO.} 206578020

2 DOWNSTAIRS

2 UPSTAIRS

— HW BASEBOARDS, NO CONTROLS

WATER TEMP 136°F

SHOWER 5 Q / ~~15~~ 5 SEC
3 Q / 30 SEC

FAUCETS 29 Q / 5 SEC

> CHILLED WATER FROM BLDG 60 AIR COOLED CHILLER

> HEATING FROM CENTRAL PLANT

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY DATE 12-18-91


CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 58
West 100
Denver
East



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY CMD DATE 12-18-91
CHECKED BY _____ DATE _____
SCALE _____

WINDOWS 79 X 34 4 WEST
WOOD FRAME, SLIDING 56 NORTH
WINDOWS ARE LEAKY 4 EAST
56 SOUTH

WALL SEC. SEE Bldg 60.

DOORS 5' X 7' (DOUBLE) WOOD

Typ OF 4

LARGE AIR GAPS

SEE Bldg 60 FOR TYP. ROOM EQUIPMENT
(TVS STEREOS ETC.)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY CMD DATE _____

CHECKED BY _____ DATE _____

SCALE _____

2 WASHERS 1200
2 ELECTRIC DRYERS 220V
2 WATER COOLERS



Bldg 58
West Wing
West 2nd
Floor

3105

18-91

BY: CMD

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY CMP DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany



Building 58
West Wing
East 2nd Floor

STAIRS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-15-91

CHECKED BY _____ DATE _____

SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CNU DATE 12-18-9

CHECKED BY _____ DATE _____

SCALE _____



BUILDING 060

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY CR DATE 11/26

CHECKED BY _____ DATE _____

SCALE _____


BLDG 60

WALL SECTION:




WINDOW:

SLIDING



6'-6"

- 78" x 33"
- WOOD FRAME
- SINGLE PANE
- LEAKING FRAME



DOOR:

WOOD 30" x 84"

WEATHERSTRIP 'POOR'

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY EMD DATE 11-26

CHECKED BY _____ DATE _____

SCALE _____

Bldg 60



72 windows each NORTH + SOUTH SIDES OF Bldg.

4 WINDOWS EACH EAST + WEST SIDE OF Bldg.

3 DOUBLE DOORS NORTH SIDE OF Bldg

6 DOUBLE DOORS SOUTH SIDE OF Bldg

NO DOORS EAST OR WEST SIDE

BLDG.# 60
 ECO 15

167

LIGHTING

X2
 ↓

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOLI OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
12	↓								
13	↓								
17	↓								
18	↓								
19	↓								
20	↓								
14	↓								
15	↓								
16	↓								
21	2	2	34	F	ON	N	N	0	N
22	$\frac{5}{4}$	$\frac{2}{1}$	$\frac{52}{52}$	I	ON	Y	Y	5	N
214	1	$\frac{2}{1}$	$\frac{34}{34}$	F	OFF	Y	N	1	N
216	↓								
217	↓								
219	↓								
220	↓								
218	↓								
215	↓	↓							

OF EXIT SIGNS - _____

COMMENTS: _____

BLDG.# 60
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SUIVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1	<u>NA</u>								
2	<u>2</u>	<u>2</u>	<u>34</u>	<u>F</u>	<u>ON</u>	<u>N</u>	<u>N</u>	<u>0</u>	<u>N</u>
3	<u>3</u>	<u>1</u>	<u>34</u>	<u>F</u>	<u>ON</u>	<u>Y</u>	<u>N</u>	<u>1</u>	<u>N</u>
4	<u>3</u>	<u>1</u>	<u>34</u>	<u>F</u>	<u>ON</u>	<u>Y</u>	<u>N</u>	<u>1</u>	<u>N</u>
116	<u>1</u>	<u>2</u>	<u>34</u>	<u>F</u>	<u>OFF</u>	<u>Y</u>	<u>N</u>	<u>1</u>	<u>N</u>
118									
117									
120									
122									
121									
119	<u>√</u>								
5	<u>1</u>	<u>2</u>	<u>34</u>	<u>F</u>	<u>OFF</u>	<u>Y</u>	<u>N</u>	<u>2</u>	<u>N</u>
6									
7									
8									
9									
10									
11	<u>√</u>								

x2
 ↓

OF EXIT SIGNS - _____

COMMENTS: _____

BLDG.# 60
 ECO 15

LIGHTING

X2
 ↓
 ↓
 ↓
 ↓
 X2
 X2
 X2
 X2

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
23	1	2/1	34	F	OFF	Y	N	2	N
24	1								
25	1								
26	1								
27	1								
28	1								
29	1								
30	1	2/1	34	F	OFF	Y	N	2	N
31	1								
32	2/2								
33	2/2								
34	1								
35	1								
36	5/8	2/1	54/54	I	ON	Y	Y	5	Y
37	4/3	1/2	40/40	F/F	ON	Y	N	2	N
38	4/1	1/1	40	F	ON OFF	Y	N	2	N
CORR. #1	8	2	40	F	ON	Y	N	2	N

OF EXIT SIGNS - _____

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

EAST WING Blog 60

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 11/26

CHECKED BY _____ DATE _____

SCALE _____

Room	# OF Fix.	# OF Lamps Per Fix.	WATTS / Bulbs	BULB TYPE	ON/OFF	SWITCH YES/NO	OCC. SENS. or	# OF CIRCUITS
MAIN CORR. 1ST FLOOR	2 2	2 2-3	40	4FT. FLUORESCENT EXIT INCAND.	ON ON	NO NO		
WING 1 HALL 1ST FLOOR	4 1	1 2-3	40	4FT. FLUORESCENT EXIT INCAND.	ON ON	Yes		
WING 2 HALL 1ST FLOOR	4 1	1 2-3	40	4FT. FI. EXIT INCAND.	ON ON	Yes NO		
WING 2 ROOMS 1ST FLOOR	9 9	2 1	34 34	4FT. FI. OVERHEAD 4FT FI BED	OFF OFF	Yes Yes	NO NO	
WING 2 ROOMS 1ST FLOOR	9 9	2 1	34 34	4FT OVERHEAD 4FT BED	OFF OFF	YES YES	NO NO	
MAIN CORR. 2ND FLOOR	2	2	40	4FT FI.	ON	NO		
WING 1 HALL 2ND FLOOR	4 1	1 2-3	40	4FT FI EXIT INCAN.	ON ON	Yes		
2ND FLOOR LATRINE	5 8	2 1	54 54	INCAN. INCAN	ON ON	Yes Yes	Yes Yes	5
WING 2 HALL 2ND FLOOR	4 1	1 2-3	40	4FT FI EXIT INCAN.	ON OFF	Yes		
WING 2 ROOMS 2ND FLOOR	7 7	2 1	34 34	4FT FI. OVERHEAD 4FT FI BED	OFF OFF	Yes Yes	NO NO	
1ST FLOOR LATRINE	3	2	34	4FT FI.	ON	YES	YES	1
WING 1 2ND FL. ROOMS	9 9	2 1	34 34	4FT FI 4FT FI	OFF OFF	YES YES	NO NO	

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

WEST END

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY OB DATE 11/26

CHECKED BY _____ DATE _____

SCALE _____

60 |

LIGHTING SAME
AS EAST END

BJ-60

DIFFERENCES

LAVRINE 2ND FLOOR
11 SWITCHES

LIGHTS 2ND FLOOR CENTER

ROOM	NO. OF	# OF LAMPS PER FIX.	WATTS PER BULB	BULB TYPE	ON/OFF	SWITCH YES/NO	GOOD FOR O.C.C. SENS. AND, OF SW I TEST
LATRINE	5	2	52W SUPERSAVER	IND.	ON	YES	Y
"	4	1	52W	I	ON	Y	Y
"	1	1	52W	I	"	Y	Z
HALLWAY	3	1	34W	4'-F	"	Y	Z
CORRIDOR	2	2	34W	4'-F	ON	NO	Z
EXIT SIGNS	4	2		I	ON	NO	

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 11/26

CHECKED BY _____ DATE _____

SCALE _____

LIGHTS

- LATRINE 1ST FLOOR, [SWITCH YES]
- 2 TWO LAMP OVER SINKS (34W & 40W)
- 4' FLOOR,
- 1 - TWO LAMP, 4' FLOOR, IN MIDDLE OF ROOM
- (34W & ?)

LIGHTS ON

- CORRIDOR - 1 (ON) [NO SWITCH]
- 2 - 2 LAMP, 4', FLOOR, 34W ~~ON~~
- 2 - 2 LAMP, INC, EXIT SIGNS
- HALL - 1 (ON), [YES SWITCH]
- 3 - 1 LAMP, 4', " , 34W
- 1 - 2 " , INC. EXIT SIGN
- HALL - 2 (ON) [YES SWITCH]
- 3 - 1 LAMP, 4', " , 34W
- TYPICAL ROOM HAS [YES SWITCH]
- 1 - 2 LAMP, 4', FLOOR, OVERHEAD
- 1 - 1 " , 4', " , BED SIDE LAMP

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CRU DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

60



1ST FLOOR - EAST
WING 1

WING 2

FAN
COIL

CORRIDOR

LATRINE

14

15

16

17

18

19

20

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY CEB DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

60



SECOND FLOOR (EAST)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CIBL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

BLDG 60


WEST
WING 2

WEST
WING 1

CENTER

EAST
WING 1

EAST
WING 2



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CRJ DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY OSL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____



60

FC-3 ON FLOOR
IN CORRIDOR

N

FC-1 IN CEILING SERVES
116, 117, 118

FC-2 IN CEILING SERVES
119, 121, 122, 120

HW RADIATION IN LATRINE
AND ALL OTHER ROOMS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY UB DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

601



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 11/25

CHECKED BY _____ DATE _____

SCALE _____

60

CHILLER

CARRIER ^{MODEL} 306B-150-650 ^{SERIAL} T29544

6 ^{RECIP} COMPRESSORS 4600 3ph 52.1 Amps 60Hz

6 FANS 4600 3ph 60Hz 3.0 Amps 1.75 HP

≈ 150 TONS EST.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 11/25/91

CHECKED BY _____ DATE _____

SCALE _____

BLDG 60



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CBL DATE 11/26

CHECKED BY _____ DATE _____

SCALE _____

BLDG 60
BARRACKS

- OCCUPIED 0-2400 SUN - SAT
- MOST OF BLDG UNOCCUPIED DURING WEEKDAY
0700 - 1600

- TYPICAL BARRACK ROOM

- STEREO
- TV
- REFRIG
- COFFEE
- MICROWAVE (SOME)

- COMPLAINTS ABOUT HOT & COLD ROOMS
- TROUBLE MAINTAINING CONSTANT
TEMPERATURE ~~IN~~ IN SHOWER

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEU DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

60

BLDG 60

LIST OF EQUIPMENT (CENTER)

- FAN COIL FC-1 1ST FLOOR, RM 116, NO NAME PLATE
- * FC-2 " " RM 119, " "

- HW RAD. BASEBOARDS, NO CONTROLS
- NOT RUNNING
- SEE CONTROL DWG

- FAN COIL FC-3, 1ST FLOOR, RUNNING
- * 2 PIPE FANS DURING SURVEY BUT NO COOL/NO HEAT
- NO NAME PLATE NO CONTROL VALVE

- MOTOR 3 SPEED
- 1/8 HP
- NO CFM LISTED
- NO O.A.

- ASSUMPTION -

- FAN COILS USED FOR COOLING ONLY
- HW BASEBOARDS USED FOR HEATING

- FAN COIL FC-3, 2ND FLR, RM, NO NAME PLATE
- " " FC-4, " " , RM, " "
- NOT RUNNING

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CBL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

60

EAST WING

FAN COIL FC-1, 1ST FLOOR, RM , RUNNING

FC-2, 1ST FLOOR, RM , RUNNING

FC-3, 1ST FLOOR COORDR, RUNNING
HEAT COMING OUT

FC-4, 2ND FLOOR, RM 228, RUNNING

FC-5, 2ND FLOOR, RM 221, RUNNING
~~HW RADIATION ON~~

CONTROLS

- SEE DWG
- SINGLE SETPOINT PNEUMATIC

~~HAND VALVES~~

TEMPERATURE - 67°F

E. WING

WEST WING

FAN COIL FC-1 OFF

FC-2 OFF

FC-3 OFF

FC-4 ON

FC-5 OFF

HW RADIATION H

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY ORL DATE 11/25

CHECKED BY _____ DATE _____

SCALE _____

O, A, TEMP
BUILDING 60, SPACE TEMP 68°F

> 1ST FLOOR LATRINE E1 → 150.° F HW TEMP
2 → 145 " "

> 2ND FLOOR LATRINE E1 → 101° F HW TEMP
2 → 120° F " "

48 PEOPLE IN BLDG AS OF 11/22/91

NO COMPLAINTS ABOUT COLD SHOWERS

TEST 1 > 10 QUARTS IN 40 SECONDS }
TEST 2 > 11 QUARTS IN 40 SECONDS } EXISTING SHOWER HEAD

TEST 1 > 9.5 QUARTS 1 MIN 25 SECONDS }
TEST 2 > 6.5 QUARTS 1 MIN 0 SECONDS } LOW FLOW RATED @ 2.5 GPM

1ST FLOOR CENTER, 2 SHWR HEADS, 4 SINKS
2ND " " , 4 " " , 4 "
1ST FLOOR EAST, 2 " " , 4 "
2ND " " , 4 " " , 4 "
1ST FLOOR WEST,
2ND FLOOR WEST, D ITTO

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY CEL DATE 11/25
CHECKED BY _____ DATE _____
SCALE _____

EQUIPMENT

1ST FLOOR LATRINE (CENTER)

- WASHER (1)
- DRYER (1), 5400 W

WATER
COOLER

1/5 HP
120 VAC

2ND FLOOR (CENTER) LATRINE

- WASHER (1)
- DRYER (1) 5400 W

WATER
COOLER

1/5 HP
120 VAC

1ST FLOOR LATRINE (EAST)

- 1 WASHER
- 1 DRYER

WATER
COOLER

2ND FLOOR " (~~WEST~~)
DITD EAST

WATER
COOLER

WEST WING DITD

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY APL DATE 11/26

CHECKED BY _____ DATE _____

SCALE _____

BLDG 60

SINK FLOW

- 27 OZ (2.75 CUPS) IN 5 SECONDS

- 24 OZ (3 CUPS) IN 5 SECONDS

- TEST AREA TOR WONT FIT

- LOW FLOW

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
 SHEET NO. _____ OF _____
 CALCULATED BY CBE DATE 11/26/91
 CHECKED BY _____ DATE _____
 SCALE _____

Bldg 60 CRAWLSPACE


CHILLED WATER PUMPS

MOTORS

	HP	PH	Hz	I	FRAME	VOLTS	AMPS	MFG.
1	5	3	60		145 JP	230	5.9	US ELECTRIC motor
2	10/17.5	3	60		215 JP	208	29	MARATHON ELECTRIC
3	10	3	60		215 JP	230	27	US ELECTRIC
4	3	3	60		182 JP	230	9	US ELECTRIC

PUMPS

	MFG	MODEL	NUMBER	GPM	FT HEAD	RPM
1	WEINMAN	261-4	735945	160	25	1750
2	WEINMAN	2K 5-4	726319-2	300	70	1750
4	WEINMAN	363-4	735944	300	23	1750



BLDG 60

BUILDING: 60-50-50		FLOOR: 50	
FURNISHING: 50		DATE: 10/15/50	
DESIGNER: R. W. BROWN		CHECKED: J. W. BROWN	
DRAWN: J. W. BROWN		SCALE: AS SHOWN	
PROJECT: 60-50-50		SHEET: 1 OF 1	

SEQUENCE OPERATION

FAN COIL UNITS:
 TYPE "A" FAN COIL UNITS ARE STARTED AND STOPPED BY SWITCHES 5-5, 5-6, 5-7, AND 5-8 IN THE CEILING.
 TYPE "C" FAN COIL UNIT IS STARTED AND STOPPED BY SWITCH 5-4 IN THE CONTROL PANEL.
 RECEIVER CONTROLLER RC-1 THROUGH RC-5, WITH THEIR SENSING ELEMENTS, MODULATE THEIR RESPECTIVE VALVES.
 TOILET EXHAUST FANS, TYPE "A" AND "B", THE SPEED OF THE 100-50 SENSING ELEMENT IS SELECTED BY SWITCHES 5-4, 5-7, OR 5-8 IN THE CONTROL PANEL.

THREE SETS
 LIKE THIS

NOTES:

- 1 POWER WIRING NOT BY REC.
- 2 CONTROL WIRING BY REC.
- 3 SEE VALVE SCHEDULE SHEET #12.
- 4 3 SPEED FAN SPEED SWITCH, NOT BY REC, MOUNT ABOVE CEILING NEAR UNIT.
- 5 WIRING NOT BY REC.
- 6 100-50 SENSING ELEMENT, RELOCATED FROM RC-1 THROUGH RC-5.

PLAN REFERENCE:
 M-12, M-14, M-15, M-16, AND M-17

BUILDINGS 56-58-60 FORT MONROE, VA


REVISED-LEE-SIMPSON SPECIALTY PIPING SERVICE INC.

DATE	BY	REVISION
		1. FAN COIL
		2. EXHAUST FANS

REVISIONS: 1. FAN COIL 2. EXHAUST FANS

REVISIONS: 1. FAN COIL 2. EXHAUST FANS

BLDG 60




SEQUENCE OF OPERATION

CHILLED WATER PUMP:

LOOP PUMP P-1 OR P-2 RUNS CONTINUOUSLY.
 WHEN OUTSIDE AIR TEMPERATURE, SENSED BY TT-1, RISES ABOVE THE
 SETTING OF S-1, VALVES V-1 AND V-2 OPEN AND V-3 CLOSING
 RETURNING THE SYSTEM TO "WINTER" MODE. WHEN TEMPERATURE SETTING
 OF S-1, AND S-1 IS IN THE AUTO POSITION, IS BELOW THE SETTING
 OF S-2, AND S-2 IS IN THE AUTO POSITION, VALVES V-1 AND V-2
 CLOSE AND V-3 OPENS, RETURNING THE SYSTEM TO "SUMMER" MODE.

S-3 CAN ALSO MANUALLY SELECT THE SUMMER OR WINTER MODE.
 IN THE COOLING MODE THE NORMALLY CLOSED VALVES V-1 AND V-2 ARE POSITIONED
 TO ALLOW CHILLED WATER TO FLOW FROM THE CHILLER THROUGH
 TO ALSO IS CLOSED. AFTER VALVES V-1 AND V-2 ARE OPENED THE LEAD WIRE P-1
 ON P-1 IS CLOSED. THE LEAD CHILLER IS STARTED AND THE DELAY TIME SETTING
 ON P-1 IS STARTED. WHEN THE DELAY TIME SETTING IS COMPLETE THE DELAY IF THE
 CHILLED WATER SUPPLY TO THE BUILDING LOOP IS ABOVE 40°.



NOT LIKE
 THIS
 EXACTLY

BLDG 60

CHILLED WATER SYSTEM	
BUILDING 62 FORT WASHINGTON, GA	YORK YORK
TOLSON-LEC-SIMPSON C. E. W. HIG. & ASS. CO.	YORK YORK

BUILDING 061

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CRL DATE 11/25

CHECKED BY _____ DATE _____

SCALE _____


61

E C O I INSULATION

WALLS:


HISTORICAL, CANNOT CHANGE WALLS

0.17
1.24
1.24
11
1.24
0.45
0.68
16.02



ROOF:

0.17
0.22
0.62
1.25
0.15
1.24
19.0
1.79
0.68
25.12



DUCT:

SOME PARTS NO CEILING INSULATION, SEE

- COOLING DUCT IN CEILING SPACE

- 3" FIBERGLASS INSULATED DUCTS

PIPE:

STEAM -

HW -

REFRIGERANT -

DHW -

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY CMC DATE 1/76
CHECKED BY _____ DATE _____
SCALE _____

Boiler Room

61

PIPE INSULATION

- ✓ 2" STM 40 FT
- 1.5" COND. RET 40.
- 1" INSULATION ON DOMESTIC HOT WTR. LINES
- 3/4" Dom. Hot WTR 40 FT
- 3" HOT WTR MISC. LINES + STOP PIPE
- 4" " " " "
- ✓ 2" STEAM 10' FT UNINS.
- 1" COND 10' FT UNINS.

HOT WATER Pump #1

MOTOR - 2 HP Frame-1451P 1735 RPM 6.8 Amps 200V
Pump = M# 1.5 K2-4 WEINMAN 70 GPM 45 FT. HD. 1735 RPM


HOT WATER Pump #2

MOTOR - MAGNATER 1740 RPM 200V 9.2 A 3 HP 3PH 60 Hz
pump - N/A

CONTINUOUS OPERATION
Pumps ON WHEN SURVEYED

LAG

1" FIBERGLASS ON HOT WATER LINES



~~ACM~~ ONE ELBOWS

1" HW NO INSULATION UP TO RADIATOR
DOWN TO " "
est. 4' of pipe per radiator

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CLM DATE 11-26

CHECKED BY _____ DATE _____

SCALE _____

PIPE INSULATION

Bldg 61

TYPE	INSULATION	PIPE DIAMETER
✓ COND.	1" Fiberglass	2"
✓ HOT WATER	2" Foam	4"
✓ LOW PRESS. STM	1.5" F.G.	4" ✓
✓ LOW PRESS. STM	1" FG	3" ✓
✓ HOT WATER	1"	3" ✓
HI PRESS. STM	1.5"	2"
Dom. HOT WATER TANK	2"	
Dom. HOT WATER	1"	2"

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY EMC DATE 1.76

CHECKED BY _____ DATE _____

SCALE _____

DUCT INSULATION 3" Fiber Glass w/ OUTSIDE METAL FOIL

CEILING 6½" Fiber Glass R-19 UNFACED ON TOP OF CEILING TILE

61

JOB _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

SHEET NO. _____ OF _____

CALCULATED BY PMD DATE 11-26

CHECKED BY _____ DATE _____

SCALE _____

Bldg 61

Insulation / Window Sills

Door / Window	No.	N/S/E/W ORIENTATION	Dim	MATERIAL	FRAME	Window Cover	Condition
D	1	N	2030 x 84	S.P. GLASS	METAL		FAIR
W	1,2,3,4	N	4 @ 40" x 85"	S.P. GLASS	WOOD	DRAPES	FAIR
W	13-17	S	5 @ 40" x 85"	S.P. GLASS	WOOD	DRAPES	FAIR
D	2	N			WOOD	* SEALED	
W	18	S	39" x 63"	S.P. GLASS	METAL	DRAPES	FAIR
D	4	S	36" x 80"	WOOD w/SP GLASS	WOOD	—	BAD
W	19,20	S	39" x 63"	SP GLASS	METAL	DRAPES	FAIR
W	21, 22	W	44" x 53"	S.P. GLASS	WOOD	DRAPES	BAD
W	22	E	"	"	"	"	"
D	5	N	2 @ 30" x 80"	METAL	WOOD		FAIR
D	6	N	2 @ 30" x 80"	WOOD	WOOD		BAD
W	23,24	S	39" x 63"	S.P. GLASS	METAL	—	FAIR
W	25-27	N	31" x 63 W/C in 25	S.P. GLASS	WOOD	DRAPES	BAD
W	28-30 * 22 " " " " " " " " " " " "	N	36" x 36"	SP GLASS	WOOD	—	FAIR
W	31-33	S	39" x 63"	SP GLASS	METAL	—	FAIR
D	8	W	36" x 80"	WOOD/SP GLASS	WOOD	—	BAD
P	3	N	2 @ 30" x 84"	GLASS (S.P.)	METAL	CURTAINS	BAD
W	5,6	N	40" x 85"	SP GLASS	WOOD	DRAPES	FAIR
W	7,8	E	"	"	"	"	"
W	9,10	S	"	"	"	"	"

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEB DATE 11/25

CHECKED BY _____ DATE _____

SCALE _____

611

MOTORS

> AC UNIT - 3 SERVES CONF. ROOM

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CHL DATE _____

CHECKED BY _____ DATE _____

SCALE _____

61

MOTORS:

EXH FAN - 1, ON ROOF, EST. 2 HP
- KITCHEN HOOD FROM PLANS
- ON

EXH FAN - 2, ON ROOF
- SERVING LINE HOOD, EST 1 HP FROM PLANS
- ON

MUAV - 1, ON GROUND
- SERVES KITCHEN
- OFF

MAIL ROOM
UNIT HEATER - ~~at~~ 1/10 HP - NOT RUNNING
2 W.A.C. FOR MAIL ROOM

11 W.A.C. UNITS FOR LAB IN BASEMENT

RUN YEAR ROUND TO COOL & DEHUMIDIFY

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY ORL DATE 11/25

CHECKED BY _____ DATE _____

SCALE _____

611

MOTORS:

> AC-UNIT-1 SERVES DINING AREA
CARRIER MODEL 40RR-016-540
SERIAL T 792 255

EVAP FAN 230/400 V
6.2/3.1 A
2 HP
1.49 KW OUT

- > COOLING ONLY
- > UNIT OFF DURING SURVEY
- > RUNS 24 HRS/DAY IN SUMMER

AC-UNIT-2 SERVES KITCHEN

> YORK 1 1/2 HP (PER DESIGN DRAWINGS)

> COOLING & HEATING

> UNIT OFF DURING SURVEY

> RUNS 24 HRS/DAY IN SUMMER

> CONDENSER

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 11-26

CHECKED BY _____ DATE _____

SCALE _____

Bldg 61

ACCU-1

CARRIER 38 AE 016 600

1 COMP. 460V 3ph 60 Hz 29 Amps

2 FANS 460 V 1 phase 60 Hz 1.9A FAN 2.3A FAN

ACCU-2

YORK CA91 15E ³ FM1199 44

440/480 V 3 ph 60 Hz 23.5A

1 comp.

1 FAN 1/2 HP 3ph 60 Hz 440/480 V 4.4 A

NOT RUNNING
WHEN SURVEYED

NOT RUNNING when surveyed

MAKE UP AIR

Rupp Temp Air No Plate

NOT RUNNING when surveyed

EST SHP FROM plans

ACCU-3

CARRIER Small

1 comp. 1-FAN

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CFM DATE 11/25

CHECKED BY _____ DATE _____

SCALE _____

61

COOLING SOURCE DX-AC UNIT
HEATING " CENTRAL PLANT STEAM

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 11-27

CHECKED BY _____ DATE _____

SCALE _____

Bldg 61

Occupied Hours

M-F	BREAKFAST	0600 - 0730
	LUNCH	1130 - 1300
	DINNER	1630 - 1800
SAT-SUN	B'FAST	0800 - 0930
	LUNCH	1200 - 1300
	DINNER	1700 - 1800

BUILDING 062

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CAD
CHECKED BY: _____
DATE: 12-18-91

BLDG.# 62
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
1st Floor (AIRLINE EAST WING)	127 °F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB
 PROJ.#
 SHEET NO.
 CALCULATED BY:
 CHECKED BY:
 DATE:

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000
 _____ OF _____

 12-13-...

BLDG.# 62
 ECO 8

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW- FLOW (QTS/SEC)	LOCATION
			-		

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION

COMMENTS:

SEE Bldg 58

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CBL DATE 12/18/91

CHECKED BY _____ DATE _____

SCALE _____

62

CONTROLS & EQUIPMENT SAME
AS 58

2-PIPE FAN COILS
HW BASEBOARDS
FAN COILS-ON

127°F HW


SEQUENCE OF OPERATION

CHILLED WATER PUMP

LOOP PUMP P-1 OR P-2 RUNS CONTINUOUSLY. WHEN OUTSIDE AIR TEMPERATURE, SENSED BY TT-1, RISES ABOVE THE SET POINT, PUMP P-1 OR P-2 WILL STOP. WHEN OUTSIDE AIR TEMPERATURE SENSED BY TT-2, IS BELOW THE SETTING OF R-2, AND S-1 IS IN THE AUTO POSITION, P-1 OR P-2 WILL START.

S-1 CAN ALSO MANUALLY SELECT THE NUMBER ON WATER FLOW. TO MAKE THE LOOP WATER FLOW, THE VALVE IS OPENED. WHEN THE VALVE IS OPENED, THE CHILLER PIPES WILL BE OPENED. THE CHILLER PUMP IS STARTED AFTER A PRESET DELAY IF THE CHILLED WATER SUPPLY TO THE BUILDING LOOP IS ABOVE 40°.

NOTES:
 ① POWER WIRING NOT BY REC.
 ② FLOW SWITCH FURNISHED WITH CHILLER.



BUILDING 62	PORT WASHINGTON, GA
DESIGNED BY	ROBERTSON & COMPANY
DATE	1952
PROJECT NO.	100-021
CLIENT	CHILLED WATER SYSTEM
ENGINEER	C. H. WIGGINS & CO.
ARCHITECT	W. H. WIGGINS & CO.
MECHANICAL	W. H. WIGGINS & CO.
ELECTRICAL	W. H. WIGGINS & CO.
PLUMBING	W. H. WIGGINS & CO.
HEATING	W. H. WIGGINS & CO.
Cooling	W. H. WIGGINS & CO.
Lighting	W. H. WIGGINS & CO.
Power	W. H. WIGGINS & CO.
Other	W. H. WIGGINS & CO.

Building 62

BUILDING 100


EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: C.M.V.
 CHECKED BY: _____
 DATE: 12.17.78

BLDG.# 122
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	416	416	1495	1495
WINDOWS				
OVERHEAD DOORS	0	0	0	0
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. BRICK 3. FRAME 4. GYP BOARD 5. 6. 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Shingles 3. PLY 4. SPA 5. 6 1/2" R-19 Fiberglass 6. SPACE 7. INSIDE AIR FILM CEILING TILE


PERSONNEL DOOR TYPE <u>WOOD</u>	BASEMENT [] SLAB [] CRAWL SPACE <input checked="" type="checkbox"/>
OVERHEAD DOOR TYPE _____	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY:
 CHECKED BY:
 DATE: 12-17-97

BLDG.# 100
ECO 1



DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH ROOM	2-24" X 24"	□	72 F	68 F	FIBERGLASS & FOAM	1 1/2"	FAIR
DOWN MECH ROOM	12" X 12"	□			↓	1/2"	GOOD

COMMENTS: THE ROOM IS USED AS RETURN AIR PLENUM, AHU IS COOLED BY DX COIL AND HEATING THROUGH HW COIL. MANUAL SUM/WINTER CHANGEOVER SWITCH. THE ROOM HAS A GRILL FOR MIN OA REQUIREMENT, TOO HOT IN WINTER AND TOO COLD IN SUMMER. NEED CONTROL REPAIR. TC HAS NO FINS.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: JW

CHECKED BY: _____

DATE: 12/17/91

BLDG.# 100
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
	DOUBLE	NEW METAL CASEMENT	METAL	W	NONE	BLINDS	30 X 60
	"	"	"	S	"	"	"
	"	"	"	E	"	"	"
	"	"	"	N	"	"	"

COMMENTS: All windows are new w/ caulk w/ no infiltration

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/17/91

BLDG.# 100
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	EXC,	NONE	W	30 X 60	10
W	"	"	S	"	4
W	"	"	E	"	9
W	"	"	N	"	4
D	NONE	HIGH	S	80 X 36	1

COMMENTS: ~~ONLY~~ ENTRANCE AT FRONT DOOR HAS 2 DOOR AIR SPACE W/ VERY LITTLE INFILTRATION. BUILDING IS VERY TIGHT.
SOUTH END DOOR DOES NOT COMPLETELY SHUT
∴ A 1/2" AIR GAP.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CA D
CHECKED BY: _____
DATE: 12-17-91

BLDG.# 100
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
<u>Miss Room</u>	<u>143 °F</u>

PROBLEMS:

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: cmo
CHECKED BY: _____
DATE: 12-17-91

BLDG.# 100
ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	
MODEL #		VOLTS	<u>200</u>	AMPS	<u>7.1</u>		
SERIAL #		PRESENT HR.	<u>✓</u>			TO	
MFG	<u>⊙</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>S.F. on AHU-1</u>		COMMENTS <u>* AHU OPERATED BY MANUAL SWITCH.</u>				

MOTOR #	<u>2</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	
MODEL #		VOLTS	<u>230</u>	AMPS	<u>4.2</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>?</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>SF ON AHU-2</u>		COMMENTS <u>TRANE AHU #TWH046-14080</u>				

MOTOR #	<u>3</u>	HP	<u>1/3</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>UVA56C17F5312A</u>	VOLTS	<u>115-</u>	AMPS	<u>6.6</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>MARATHON ELECTRIC</u>	REQUIRED HR.				TO	
FRAME	<u>56C-65</u>	EFF.					
DESCRIPTION	<u>HW PUM MOTOR</u>		COMMENTS				

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: _____ OF _____
 CALCULATED BY: CAP
 CHECKED BY: _____
 DATE: 12-17-9

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 100 BLDG NAME: DENTAL CLINIC JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS / _____
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: RECEPTION AREA (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1615, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 73.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: MAIN HALL BY T-STAT (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 71.9 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 101

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: END
 CHECKED BY: _____
 DATE: 12-17-90

BLDG.# 101
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	640	640	3000	3000
WINDOWS				
OVERHEAD DOORS	0	0	0	0
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. BRICK
	3. FRAME
	4. GYP BOARD
	5.
	6.
	7. INSIDE AIR FILM

.17
 1.24
 .45
 .68
 2.54

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. SHINGLES
	3. PLYWOOD
	4. SPACE
	5. 2" BOWA Fiberglass
	6. CEILING TILE
	7. INSIDE AIR FILM

.17
 .44
 .62
 1.0
 1.9
 1.79
 .68
 23.7

PERSONNEL DOOR TYPE _____	BASEMENT <input checked="" type="checkbox"/>
OVERHEAD DOOR TYPE _____	SLAB <input type="checkbox"/>
	CRAWL SPACE <input type="checkbox"/>

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. OF
CALCULATED BY:
CHECKED BY:
DATE: 12-17-91

BLDG.# 101
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
OUTSIDE NORTHEND	4"	80'	CW	NA	65'	FIBERGLASS ALUMINUM	1 1/2"	*
↓	4"	25'	HW	.	50'	FIBERGLASS	1 1/2"	**

COMMENTS: * GOOD FOR STRAIGHT RUN - NEED REPAIR OVERBOWS (8) ON STREET LEVEL.
** NEED INSULATION AROUND COUPLING & VALVE.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE

OF

KL

12-17-91

BLDG.# 101
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
	NO DUCT - 2-PIPE FAN COIL.						

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: JW

CHECKED BY: _____

DATE: 12/17/91

BLDG.# 101
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
23	SINGLE	SLIDING	WOOD	E	NONE	SHADES	34 X 80
25	"	"	"	W	"	"	"
3	"	"	"	N	"	"	"
2	"	"	"	S	"	"	"

COMMENTS:

IT IS COMMON IN THIS BUILDING TO OPEN WINDOWS WITH
FAN COIL UNITS REMAINING ON TO REACH DESIRED OFFICE TEMP.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/17/91

BLDG.# 101
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	BAD	MED	E	80 34x80	23
D	NONE	MED	N	80x34	1
D	GOOD	HIGH	W	80x34	1
W	BAD	MED/LOW	W	34x80	25
D	NONE	HIGH	W	80x34	1
W	BAD	MED	N	80x34	3
"	"	"	S	"	3

MAIN DOOR

ADMIN OFFICES

COMMENTS: ~~BUILDING IS AT POS. PRESSURE AT TIME~~
~~OF SURVEY.~~ ^{LOW} ~~INFILTRATION~~ ^(MAIN) FRONT DOOR IS
WARPED CAUSING AIR GAP.

NOTE: THIS BUILDING ONLY HAS A FEW OPERATIONAL
WINDOWS - MOST ARE NAILED OR PAINTED SHUT. HOWEVER
MANY OF THE PERMANENTLY CLOSED WINDOWS HAVE NO
CAULK. THIS SHOULD BE IMPLEMENTED.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: cmd
CHECKED BY: _____
DATE: 12-12-91

BLDG.# 101
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Men's Room	124 °F
Men's Room - Outside Rest	128 °F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-17-91

BLDG.# 101
 ECO 5



MOTORS

MOTOR #	<u>1</u>	HP	<u>6</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>JMM 3218T</u>	VOLTS	<u>208</u>	AMPS	<u>14.8</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>BALDOR</u>	REQUIRED HR.		TO			
FRAME	<u>18AJM</u>	EFF.					
DESCRIPTION	<u>DTW PUMP MOTOR</u> <u>BASEMENT</u>	COMMENTS	<u>CONTROLS TC HAS NO PINS.</u> <u>BUILDING OR 7:30 - 1630 M-F</u>				
MOTOR #	<u>2</u>	HP	<u>1</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>VL3510</u>	VOLTS	<u>115</u>	AMPS	<u>12.4</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BALDOR</u>	REQUIRED HR.		TO			
FRAME	<u>56C</u>	EFF.	<u>67%</u>				
DESCRIPTION	<u>SUMP PUMP</u>	COMMENTS	<u>FAIRLY NEW</u>				
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 101
 ECO 5

10+ HP MOTORS
 MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
<u>HW Pump</u>				
DESCRIPTION	VOLTS	<u>203</u>	<u>203</u>	
MFG	AMPS	<u>90.6</u>	<u>93.6</u>	
MODEL #	KVAR	<u>17.8</u>		
SERIAL #	KVA	<u>32.4</u>		
FRAME	KW	<u>27</u>		
HP <u>30</u> RPM _____	PF	<u>83.6</u>		
VOLT				
AMPS		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS	_____			

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION	VOLTS			
MFG	AMPS			
MODEL #	KVAR			
SERIAL #	KVA			
FRAME	KW			
HP _____ RPM _____	PF			
VOLT				
AMPS		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS	_____			

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study

PROJ.# _____

EMC # 3105.000

SHEET NO. _____

OF _____

CALCULATED BY: _____

CHECKED BY: _____

DATE: _____

Ft. Gillem

BLDG.# 101

ECO 7

HW PUMPS

CIRCULATION PUMPS

RPM	FT HD	GPM	MODEL #	SERIAL #	MFG.	HOURS		PUMP #
						REQUIRED	PRESENT	
1750	130	625	77-10137-2	SIZE 4-15	AURORA PUMP		0-2400	HWP1
1750	130	625	77-10137-1	↓	AURORA PUMP			HWP2
1750	10	72	2809-318BF		BELL & GOSSETT			CWP 1 & 2

PUMP MOTORS

VOLTS	AMPS	PHASE	MODEL #	SERIAL #	MFG.	HOURS		FRAME	MOTOR #
						REQUIRED	PRESENT		

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

101.

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

HW PUMP 30HP.

V
203
90.6 V 203
93.6 A
27 KW
17.8 KVAR
32.4 KVA
83.6 PF

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
 SHEET NO. _____ OF _____
 CALCULATED BY KCC DATE 12-17-91
 CHECKED BY _____ DATE _____
 SCALE _____


ECO-12

BLDG 101 CHILLER MODEL 30GB040510

COMP 1	208/230	3φ	60HZ	76RLA	345LRA	R-22
COMP 1	208/230	3φ	60HZ	76RLA	345LRA	
FAN 2		1φ		4.6 PLA	0.43HP	
2	↓	1φ	↓	4.6	↓	

PUMP THROUGH BF120
 NO OTHER INFO.

BOILER AMERICANS STANDARD



- HW OA RESET CONTROL
- TC NO TIME-CLOCK PINS
- ELEC. ACTUATOR POOR COND.
- 1 AC WINDOW UNIT

T1 T2 T-3
 □ □ □

36 GQ-400-5 8236
 □ □ □

HAS 2 EXT ROOF FORM.

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMJ
 CHECKED BY: _____
 DATE: 12-17-81

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 1 BLDG NAME: MPS JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 2
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 1st FLOOR HALL (BIT-STAT) (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1630, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 74.3 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 2nd FLOOR HALL (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 74.5 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 3 FUNCTION: Office SPECIAL REQ. YES [] NO []
 LOCATION: OFFICE (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1615, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 76.8 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 4 FUNCTION: DENTAL SPECIAL REQ. YES [] NO []
 LOCATION: DENTAL AREA (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1615, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 78.3 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG. 101

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____



SCALE _____

FIRST FLOOR

2ND FLOOR



- ⊗ ROOM NO.
- ⊠ 4-18" F34
- 4-4' F34
- ▤ 2-4' F34
- ▥ 1-4' F34
- ▨ 2-8' F34
- FAN COIL
- X OFF



← SAME FAN COIL LOCATION AS 2nd floor

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/11/92

BLDG.# M-101
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1	3	4	34	F	OFF	Y	Y	1	N
2	2	4			ON	Y	Y	1	N
3	2	4			ON	Y	Y	1	Y
4	2	4			ON	Y	Y	1	Y
5	2	4			ON	Y	Y	1	Y
6	2	4			ON	Y	Y	1	N
7	2	4			ON	Y	Y	1	N
8	2	4			ON	Y	Y	1	N
9	2	4			ON	Y	Y	1	Y
10	4	4			ON	Y	N	1	N
11	2	4			ON	Y	Y	1	Y
12	4	4			ON	Y	Y	1	N
13	4	4			ON	Y	Y	1	N
14	3	4			ON	Y	Y	1	Y
15	6	4			ON	Y	Y	1	N
16	6	4			ON	Y	N	1	N
17	1	4			ON	Y	Y	1	Y
18	3	4			ON	Y	Y	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 2/11/92

BLDG.# M-101
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
19	4	4			ON	Y	Y	1	N
20	4	4			ON	Y	N	1	N
21	3	4			ON	Y	Y	1	Y
22	9	4			ON	Y	N	2	N
23	3	4			OFF	Y	N	1	N
24	1	4			OFF	Y	N	1	N
25	4	4			ON	Y	N	1	N
26	4	4			ON	Y	Y	1	Y
27	7	8'			ON	Y	N	2	N
28	3	8'			ON	Y	N	1	N
29	4	2	34	F	ON	Y	N	1	N
30	4	2	34	F	ON	Y	N	1	N
31	7	2	34	F	ON	Y	N	1	Y
32	1	2			ON	Y	N	1	N
34	2	4	34	F	ON	Y	Y	1	Y
35	2	4			ON	Y	Y	1	Y
36	2	4			ON	Y	Y	1	N
37	3	4			ON	Y	N	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/11/92

BLDG.# M-101
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
38	1	4	34	F	OFF	Y	Y	1	N
39	2	4			ON	Y	Y	1	N
40	2	4			ON	Y	Y	1	Y
41	2	4			ON	Y	Y	1	Y
42	2	4			ON	Y	Y	1	N
43	2	4			ON	Y	Y	1	Y
44	2	4			ON	Y	Y	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

BUILDING 102

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: MD
 CHECKED BY:
 DATE: 12-16-19

BLDG.# 102
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	372	372	732	732
WINDOWS				
OVERHEAD DOORS	0	0	0	0
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. BRICK 3. 2" 1/2 SHEETROCK 4. GYP BOARD 5. 6. 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Shingles 3. Plywood 4. SPACE 5. 8" Blown Fiberglass 6. PLASTER 7. INSIDE AIR FILM SPACE CRACK EILING

PERSONNEL DOOR TYPE	GLASS	BASEMENT []
OVERHEAD DOOR TYPE	-	SLAB [✓]
		CRAWL SPACE []

COMMENTS:



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE:

BLDG.# 102
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
Above drop ceiling	12 x 16				Fiberglass	3/4"	Good
	10 x 10				Fiberglass	3/4"	Good

COMMENTS: 12x16 runs length of bldg.
10x10 ≈ 50ft, diffuser plenums

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/16/91

BLDG.# 102
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	NONE	NONE	N	78x33	2
W	"	"	S	32x54	3
W	"	"	E	"	2
W	"	"	W	"	4
D	NONE	LOW	W	82x36	2

*Cased
METAL*

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-16-77

BLDG.# 102
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Restroom	119 °F

COMMENTS:

BLDG.# 102
ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>.75</u>	PH	<u>1</u>	RPM	<u>1000</u>
MODEL #	<u>5KCP39RG</u>	VOLTS		AMPS	<u>12.5</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>G.E.</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>Down on Gd. Furnace</u>						
COMMENTS							
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION							
COMMENTS							
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION							
COMMENTS							

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-16-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 102 BLDG NAME: MP JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
 SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: HALLWAY (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 67.1 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 00 TO 2400, SAT 0 TO 2400, SUN 0 TO 2400
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 105

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12/17/00

BLDG.# 105
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	540	540	576	576
WINDOWS				
OVERHEAD DOORS	0	0	0	0
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. BRICK
	3. FRAME
	4. GYP BOARD
	5.
	6.
	7. INSIDE AIR FILM

.17
 1.24
 .45
 .68
 2.54

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. Shingles
	3. PLY WOOD
	4. SPACE
	5. 6" Fiberglass (R-19)
	6. CEILING TILES
	7. INSIDE AIR FILM

.17
 .44
 .62
 1.0
 19
 1.79
 .68
 23.7

PERSONNEL DOOR TYPE	WOOD	BASEMENT [] SLAB [<input checked="" type="checkbox"/>] CRAWL SPACE []
OVERHEAD DOOR TYPE		

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000

JOB
 PROJ.#
 SHEET NO. C-2-D OF
 CALCULATED BY:
 CHECKED BY:
 DATE 12.16.91

BLDG.# 105
 ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
Outside Bldg	20 x 25	RECT					INTERNAL

COMMENTS:

All bus 4ft+ is internally insulated.
 Duct in bldg runs above drip ceiling.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO. OF

BLDG.# 105
ECO 2

CALCULATED BY: JW
CHECKED BY:
DATE: 12/16/91

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
-2	Double	SLIDING	wood	S	NO	BLINDS	48x56
-5	11	11	11	W	11	4	11

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/16/91

BLDG.# 105
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	FAIR	FAIR	W	48x56	6
D	↓	↓	W	38x84	1
W			N	48x56	2
D			E	38x84	2
W			E	28x40	2
W			S	28x40	2

COMMENTS:
 WINDOWS FIXED SHUT, DRAFTY

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO.: _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-17-91

BLDG.# 105
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Common Restroom	137°F
LTA Room	137°F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: SND
 CHECKED BY: _____
 DATE: 12-16-91

BLDG.# 105
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1.5</u>	PH	<u>3</u>	RPM	<u>1125</u>
MODEL #	_____	VOLTS	<u>273</u>	AMPS	<u>5.2</u>	_____	_____
SERIAL #	<u>3277488</u>	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>A.O. Smith</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>F 66</u>	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	_____	COMMENTS	<u>M14-1 Supply Fan</u>				
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	_____	COMMENTS	_____				
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	_____	COMMENTS	_____				

*M14-1
Supply Fan*

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-17-9

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 105 BLDG NAME: VETERINARIAN JOB: 3105.000
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 1
BUILDING MANAGER NAME: _____
PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: WAITING ROOM (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 830 TO 1500, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC 70.1 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: CONFERENCE ROOM (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC 71.3 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

When cleaning crew DUSTS BUILDING THEY OFTEN
ACCIDENTALLY change the SETPOINT ON THE T-STAT

BUILDING 109



EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CPD
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 109
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. VINYL SIDING 3. POURED CONCRETE 8" 4. FRAME 5. GYP BOARD 6. 7. INSIDE AIR FILM
SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. SHINGLES 3. PLYWOOD 4. R-30 ? 5. GYP BOARD 6. 7. INSIDE AIR FILM
PERSONNEL DOOR TYPE <u>METAL / GLASS</u>	BASEMENT [] SLAB [] CRAWL SPACE [✓]
OVERHEAD DOOR TYPE _____	

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

109


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-13-90

CHECKED BY _____ DATE _____

SCALE NTS



EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000

SHEET NO. OF

CALCULATED BY: KC

CHECKED BY:

DATE: 12-13-91

BLDG.# 109
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. RM	2 1/2"	50'	CW	NA	66'	FIBERGLASS	1"	GOOD
MECH. RM	2 1/2"	50'	HW		66'	FIBERGLASS	1"	GOOD

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CAD
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 109
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
W	FAIR	Fair		53x43
	TOP OF 29			
D ₁	GOOD	Low	N	79x31
D ₂	BAD	HIGH	E	83x60
D ₃	FAIR	FAIR	S	79x31

COMMENTS:

WINDOWS DO NOT SEAL TIGHTLY WHERE 2 SECTIONS MEET.

D₂ - 2 GLASS DOORS, SPACE WHERE DOORS MEET IN MIDDLE.

D₃ - SPACE UNDER DOOR

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMW
CHECKED BY: _____
DATE: 12-13-91

BLDG.# 109
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Sink, Room 1	131 °F
KITCHEN	129 °F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE: 12-13-91

BLDG.# 109T
ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1/2</u>	PH	<u>31</u>	RPM	<u>3450</u>
MODEL #	<u>3K954</u>	VOLTS	<u>115</u> <u>230</u>	AMPS	<u>8.6</u> <u>4.3</u>		
SERIAL #	<u>C55CXDBR-1950</u>	PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>DAYTON</u>	REQUIRED HR.		TO			
FRAME	<u>56C</u>	EFF.					
DESCRIPTION	<u>HOT WATER PUMP</u>	COMMENTS	<u>RUN IN WINTER</u>				
	<u>IN MECH. ROOM</u>						
MOTOR #	<u>2</u>	HP	<u>3/4</u>	PH	<u>1</u>	RPM	<u>3450</u>
MODEL #	<u>BKC39NH50X</u>	VOLTS	<u>115V</u>	AMPS	<u>11.2</u>		
SERIAL #		PRESENT HR.		TO	<u>NOT RUNNING.</u>		
MFG	<u>GENERAL ELECTRIC</u>	REQUIRED HR.		TO			
FRAME	<u>56G</u>	EFF.					
DESCRIPTION	<u>CW PUMP.</u>	COMMENTS	<u>RUNS IN SUMMER</u>				
	<u>IN MECH ROOM</u>						
MOTOR #	<u>3</u>	HP		PH	<u>3</u>	RPM	
MODEL #		VOLTS		AMPS	<u>20.8 A</u>		
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AIR COOLED CHILLER</u>	COMMENTS	<u>2-COMP. MOTOR; 2 FAN</u>				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 109
 ECO 8

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM (QTS/SEC)	GPM w/ LOW-FLOW (QTS/SEC)	LOCATION
4	1	16	3.5	3.5/30 sec	Bathrooms

FAUCETS	NO. OF PEOPLE	PRESENT GPM OZ./SEC.	GPM w/ LOW FLOW RESTR.	LOCATION
5		32	16	one in each bathroom & 1 in kitchen -

COMMENTS:

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-13-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 109 BLDG NAME: VOC JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. ROOM 1 FUNCTION: V&R ROOM SPECIAL REQ. YES [] NO []
 LOCATION: NORTH END (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 0 TO 2400, SAT 0 TO 2400, SUN 0 TO 2400
 PRESENT TEMP: WINTER OCC 65.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: ALL ROOMS HAVE 2-PIPE FAN COIL FOR HVAC

ZONE NO. ROOM 2 FUNCTION: V&R ROOM SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 0 TO 2400, SAT 0 TO 2400, SUN 0 TO 2400
 PRESENT TEMP: WINTER OCC 67.5 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: 2-PIPE FAN COIL

ZONE NO. HALL FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 72.8 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

- 1 SIM/HW CONVERTER
 - 1 DHW UNIT N. GAS
 - 1 ~~BEU~~ AIR COOLED CHILLER
 - 1 CHWP
 - 1 BHP
- HAS TG AND PINS
 - SUM/WIN CHANGE OVER
 - BHP ON RESET

BUILDING 111

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 111
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS	—	—	—	—
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>CMU</u> 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

.17
 1.23
 .68
 2.08

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>SHEATHING</u> 3. <u>PLYWOOD</u> 4. <u>SPACE</u> 5. _____ 6. <u>CEILING TILE</u> 7. INSIDE AIR FILM

.17
 .44
 .62
 1.0
 1.79
 .68
 4.7

PERSONNEL DOOR TYPE <u>WOOD</u>	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB <input checked="" type="checkbox"/>
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000

SHEET NO. 82 OF

CALCULATED BY:

CHECKED BY:

DATE

12-13-91

111

BLDG.#
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. RM	2"	15'	CW	NA	63°F	RUBBER	1/2"	BAD
4-4	2"	15'	HW	120°F	63°F	NONE	-	-

COMMENTS: NEED TO INSULATE HW PIPE.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000

JOB
 PROJ.#
 SHEET NO. FC OF
 CALCULATED BY:
 CHECKED BY:
 DATE: 12-13-91

BLDG.# 111
 ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
*	NO DUCT WORK						

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE _____


CHECKED BY _____ DATE _____

SCALE NTS

111

← 20' →

14' x 24'



EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: ~~_____~~ CMJ
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 111
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
W	BAD	HIGH		52x33
	TYP OF 24			
D-1	FAIR	FAIR		80x31
* D-2	BAD	VERY HIGH		80x35
D-3	FAIR	FAIR		70x60

COMMENTS:

D-2 DOOR DOES NOT CLOSE TIGHTLY.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KL
CHECKED BY: _____
DATE: 12-13-91

BLDG.# 111
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
MEN'S ROOM	114 ^s F
WOMAN'S ROOM	114 F

PROBLEMS:

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 111
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>3/4</u>	PH	<u>1</u>	RPM	<u>3450</u>
MODEL #	<u>5K661C</u>	VOLTS	<u>115</u>	AMPS	<u>9.6</u>		
SERIAL #	<u>CASSQPD-2749</u>	PRESENT HR.	<u>0</u>	TO	<u>200</u>		
MFG	<u>DAYTON</u>	REQUIRED HR.		TO			
FRAME	<u>56J</u>	EFF.					
DESCRIPTION	<u>DTW PUMP</u>	COMMENTS	<u>PUMP IS ON TL; NO PINS.</u>				
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	_____				
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	_____				

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-3-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 111 BLDG NAME: Admin JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 1
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. Rm 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: Rm 2 (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1600, SAT 0 TO 0, SUN 0 TO 0
 PRESENT TEMP: WINTER OCC 72.4 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. Rm 5 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: Rm 5 (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 72.2 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 112


EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-13-91


BLDG.# 112
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS	<u>Ø</u>	<u>Ø</u>	<u>Ø</u>	<u>Ø</u>
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>CON</u> 3. FRAME 4. <u>WOOD PANELING</u> 5. 6. 7. INSIDE AIR FILM

R noe R
 .17
 1.2
 1.25
 .68
 3.3
 + R-10
 13.3

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>SYNIGIPS</u> 3. <u>PLYWOOD</u> 4. <u>SPACE</u> 5. 6. <u>CEILING TILE</u> 7. INSIDE AIR FILM

.17
 0.44
 0.62
 1.24
 1.79
 1.68
 4.94
 +R-19
 23.94

PERSONNEL DOOR TYPE	<u>WOOD</u>	BASEMENT []
OVERHEAD DOOR TYPE	<u>Ø</u>	SLAB []
		CRAWL SPACE <u>✓</u>

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. OF
CALCULATED BY:
CHECKED BY:
DATE

112

KC

BLDG.#
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. Rm.	4"	25'	STM	NOT RUNNING	88°F	FIBERGLASS	3/4"	FAIR
	3"	6'	STM		"	-	0	
	3.5"	38'	STM		"	Fiberglass	1"	
	2"	185'	STM		"	Fiberglass	1"	
	1.5"	185'	STM		"	Fiberglass	1"	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. _____ OF _____
CALCULATED BY:
CHECKED BY:
DATE:

BLDG.# 112
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
	NO DUCT WORK						

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____

CALCULATED BY: JLD

CHECKED BY:

DATE: 12-13-91

BLDG.# 112

ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE -- SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
	SINGLE	SLIDING	WOOD		NO	WINDOW COVER	53 x 43

COMMENTS: TYP, 8F 2D

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-1-91

BLDG.# 112
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
W	FAIR	FAIR		53x43
	TYP. OF 20			
D1	BAD	HIGH	N	80x32
D-2	"	"	S	"

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMO
CHECKED BY: _____
DATE: 12-15-99

BLDG.# 112
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
<i>Master Room</i>	134 °F
<i>Slave Room</i>	136 °F
PROBLEMS:	

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

BLDG. 112

- 1 STM GENERATOR
- 1 DHW UNIT
- 9 AC WINDOW UNITS
- HEATING THROUGH BASEBOARD RADIATION.

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-3-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 112 BLDG NAME: _____ JOB: 3105.000
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 1
BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: ADMIN SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 730 TO 1630, SAT 0 TO 0, SUN 0 TO 0
PRESENT TEMP: WINTER OCC 77.6 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ # EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CND
 CHECKED BY: _____
 DATE: 12-13-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 112 BLDG NAME: _____ JOB: 3105.000
 PRIMARY FUNCTION: ADMIN GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: MAIL ROOM (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 730 TO 1830, SAT 0 TO 0, SUN 0 TO 0
 PRESENT TEMP: WINTER OCC 77.8 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 114

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY KC DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

BLDG 114

- WINDOW CONSTRUCTION , INSULATION , WALL , DOOR - SAME AS 111
- 1 AHU DX FURNACE
- 1 ACCU
-



EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000

JOB
 PROJ.#
 SHEET NO.
 CALCULATED BY:
 CHECKED BY:
 DATE

OF

KC

12-13-91

BLDG.# 114
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
*	NO PIPE							

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. _____ OF _____
CALCULATED BY:
CHECKED BY:
DATE:

BLDG.# 114
ECO 1

DUCT INSULATION



LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. RM	2' x 2'		NOT RUNNING	NOT RUNNING	FIBERGLASS	1"	GOOD
	10"				FIBERGLASS	1"	"

COMMENTS: INSULATION IS FIBERGLASS WITH FOIL

2x2' runs length of bldg. 1 10" round feeds diffusers ≈ 40 +

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 1/27/92

CHECKED BY _____ DATE _____

SCALE _____

BLDG 117 HAS NO RUNNING ~~W~~ DOM. WATER.

BLDG 114 DOM. HW. TEMP \Rightarrow 101°F

BLDG.# 114
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1 1/2</u>	PH	<u>1</u>	RPM	<u>3450</u>
MODEL #	<u>XUF56C34D5317A L</u>	VOLTS	<u>115</u>	AMPS	<u>18</u>	<u>T' STAT CONTROL</u>	
SERIAL #		PRESENT HR.		TO			
MFG	<u>MARATHON</u> <u>LAFFERTY</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU</u>		COMMENTS				
	<u>- N. GAS FURNACE</u>						
	<u>- DX COOLING.</u>						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION			COMMENTS				
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION			COMMENTS				

BUILDING 116

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY cmj DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

Bldg 116 windows, insul.,
CONSTRUCTION SAME AS 111.

GLASS DOORS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

116


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE NTS



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. 100 OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE 12-13-91

BLDG.# 116
ECO 1 _____

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
	<i>* NO PIPE EXPOSED</i>							

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. C-00 OF
CALCULATED BY:
CHECKED BY:
DATE: 12/13/91

BLDG.# 116
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
outside	12x14	□			—	0	—
ATTIC	20 x 20	□			—	0	—
ATTIC	12"	○			—	0	—

11 Ft
90 Ft
40 Ft

COMMENTS: * Feeds diffusers

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: C. J.
CHECKED BY: _____
DATE: 11-3-91

BLDG.# 116
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
<u>Master Bath</u>	<u>113° F *</u>

COMMENTS: * Both restrooms served by 1. & 5 gal water HTR.
TEMP. REACHED 113 briefly + began dropping

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY KEC DATE 12-13-91

CHECKED BY KE DATE _____

SCALE _____

BUILDING 116



FAN MOTOR 8.6A 208V 3Ø 3HP CENTURY
 SER: U012 RPM: 17
 FM: N56H2

TRANE AHU PACKAGE UNIT

MODEL SFCA-1003-LD

TYPE NO. 268-515-1-B

INPUT 200,000 BTUH

CAP. 150,000 BTUH

208V 24A 3Ø

1 COMP. 3Ø 208V 24A.

1 COMP 3Ø 208 24A

3 COND FAN 1Ø ~~208~~ 230V 4.1A

NAT GAS HEATING.

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CND
 CHECKED BY: _____
 DATE: 12-17-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 116 BLDG NAME: CREDIT UNION JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 1
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 800 TO 1530, SAT 0 TO 0, SUN 0 TO 0
 PRESENT TEMP: WINTER OCC 75.2 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: EO OPPORTUNITY SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 700 TO 1800, SAT 0 TO 0, SUN 0 TO 0
 PRESENT TEMP: WINTER OCC 74.0 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 117

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CND DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE 1

Bldg 117

Windows, Doors, Insulation, Construction,
DIMENSIONS - SAME AS Bldg 111

Unoccupied DURING SURVEY.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: RC
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 117
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH RA	2"	15'	HW	116°F	63	RUBBER	1/2"	FAIR
↓	2"	25'	CW	NA	63	RUBBER	1/2"	GOOD
	2"	10'	HW	NA	63	RUBBER	1.25"	
	2"	4'	HW	NA	63	-	0"	

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 1/27/97

CHECKED BY _____ DATE _____

SCALE _____

BLDG 117 HAS NO RUNNING ~~W~~ DOM. WATER.

BLDG 114 DOM. HW. TEMP \Rightarrow 101°F

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KL
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 117
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1</u>	PH	<u>1</u>	RPM	<u>3450</u>
MODEL #	<u>8718</u>	VOLTS	<u>115V</u>	AMPS			
SERIAL #	<u>TYP CS</u>	PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>Century Magnetelek</u>	REQUIRED HR.		TO			
FRAME	<u>G56L</u>	EFF.					
DESCRIPTION	<u>DTW PUMP</u>	COMMENTS	<u>ON TC; NO PINS. LOOKS NEW</u>				

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	_____				

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	_____				

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ # EMC # 3105.000
 STREET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: 12-13-41

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 117 BLDG NAME: ADMIN JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
 SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: BUILDING UNOCCUPIED.

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 118

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CAID DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

Bldg 118 -

Windows, Insul., Doors

CONSTRUCTION, DIMENSIONS,

SAME AS 111.

1 BROKEN WINDOW

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: 12-3-4

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

BLDG.#
ECO 1

118

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION

COMMENTS: No PIPING IN Bldg.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: _____
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 118
 ECO 1 _____

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
EAST	2' X 2'		NOT RUNNING	65 F	FIBERGLASS	1/2"	FAIR,

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

BLDG 118



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: 12-13-91

BLDG.# 118
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
NO HW IN THE FACILITY; NO BATHROOM	NA
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KL
 CHECKED BY: _____
 DATE: 12-13-91

BLDG.# 118
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>?</u>	PH	<u>1</u>	RPM	
MODEL #		VOLTS	<u>115V</u>	AMPS	<u>960W</u>		
SERIAL #	<u>SINGER</u>	PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	COMMENTS						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	COMMENTS						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	COMMENTS						

BUILDING 120

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

BUILDING WAS LOCKED

- BUILDING SAME AS #111

- SEE NOTES ON BLDG 111

BUILDING 121

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY DATE 12-13-91
CHECKED BY _____ DATE _____
SCALE _____

Bldg 121
SAME AS Bldg 111

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

121


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE N.T.S.



O-DOOR
9' x 7'

WINDOWS
53 x 33

DROP CEILING
BLOCK CONSTRUCTION
SLAB

INSULATION
VERY BAD

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-13-91

CHECKED BY _____ DATE _____

SCALE _____

BLOG 121

- USE AS SMALL OFFICE
- 2 UNIT HEATERS (NAT. GAS)
- 1 AC WINDOW UNIT.
- 7: - 4:00 PM.

BUILDING 122

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY E. J. D. DATE 12-12-81

CHECKED BY _____ DATE _____

SCALE _____

Bldg. 122

CONSTRUCTION, WINDOWS, DIMENSIONS,
INSULATION - SAME AS 111.

SPACE TEMP - 75.5 °F

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB

Ft. McPherson/Ft. Gillem Energy Study

PROJ.#

EMC # 3105.000

SHEET NO.

OF

CALCULATED BY:

CMD

CHECKED BY:

DATE:

2-1-9

BLDG.#

122

ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
<i>COMMON 3rd floor</i>	<i>113 °F</i>
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: 12-73-91

BLDG.# 120122
 ECO 5

MOTORS

MOTOR #	<u>?</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	
MODEL #	<u>?</u>	VOLTS	<u>208</u>	AMPS	<u>NOT ACCESSIBLE</u>		
SERIAL #	<u>?</u>	PRESENT HR.		TO			
MFG	<u>?</u>	REQUIRED HR.		TO			
FRAME	<u>?</u>	EFF.					
DESCRIPTION	COMMENTS <u>OLD ORIGINAL UNIT</u>						
	<u>- DX</u>						
	<u>- ELECTRIC DUCT HEATERS (2)</u>						
	<u>45.2A 240V 3Ø 19.2KW</u>						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KL
 CHECKED BY: _____
 DATE: 12-13-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 1202 BLDG NAME: ADMIN JOB: 3105.000
 PRIMARY FUNCTION: ADMIN GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
 SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 75.5 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: 7:00 - 1800 M-F SOMETIME WEEKEND

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 124


EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12-12-91


BLDG.# 124

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	900	900	180	180
WINDOWS	140	117	23	23
OVERHEAD DOORS	—	—	—	—
PERSONNEL DOORS	0	0	40	40

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Block 3. 2x4 STUD 4. GYP BOARD 5. R-11 INSUL 6. 7. INSIDE AIR FILM

.17
 1.23
 0.
 0.45
 11.0
 .69
 13.54

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. 2x6 PLANKS 3. 3" Fiberglass Insulation R-11 4. GYP BOARD 5. Shingles 6. AIR SPACE 7. INSIDE AIR FILM

.17
 R-11
 .45
 .44
 1.0
 13.06

PERSONNEL DOOR TYPE <u>Glass/METAL</u>	BASEMENT []
OVERHEAD DOOR TYPE <u>—</u>	SLAB [<u>✓</u>]
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE 12-12-91

BLDG.# 124

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
NE	1/2"	30'	REFRIGERIN	-	-	RUBBER	3/8"	GOOD

COMMENTS: DX. LINE FROM COMPRESSOR OUTSIDE

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

OF

KEC

12-12-91

BLDG.# 124

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SUPPLY AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION

COMMENTS: NO DUCT INSULATION, EXPOSED TO AIR ZONE INTERIOR

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg. 124 Doors & Windows


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-12-91

CHECKED BY _____ DATE _____

SCALE NTS



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: _____ OF _____
 CALCULATED BY: cmd
 CHECKED BY: _____
 DATE: 12-12-91

BLDG.# 124

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
1	Single	Sliding	wood	S	none	Blinds	51 x 33
23	"	"	"	E	Painted	—	"
24	"	"	"	"	"	"	"

COMMENTS: * Typ of 22

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMO
CHECKED BY: _____
DATE: 12-12-91

BLDG.# 124

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
<u>W</u>	<u>FAIR</u>	<u>FAIR</u>	<u>S</u>	<u>51 x 33</u>
<u>*</u>	<u>Typ. of 22</u>			

COMMENTS: Most windows Fixed shut.
All windows in approximately the same condition

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB

Ft. McPherson/Ft. Gillem Energy Study

PROJ.#

EMC # 3105.000

SHEET NO.

OF

CALCULATED BY:

KC

CHECKED BY:

12-12-98

DATE:

BLDG.# 124

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
PROB COMMON BATHROOM	121 °F

COMMENTS:

~~ONLY~~ ONLY Faucet Available

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KE
CHECKED BY: _____
DATE: 12-12-91

BLDG.# 124

MOTORS

MOTOR #	<u>1</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	_____
MODEL #	_____	VOLTS	<u>115V</u>	AMPS	<u>8 Amp (MAX)</u>	_____	_____
SERIAL #	_____	PRESENT HR.	<u>0700</u>	TO	<u>1600</u>	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	COMMENTS <u>T'STAT CONTROL</u>						
<u>CARRIER UNIT MODEL 58SSB120-CC SERIES 120</u>							
<u>INPUT 143,000 BTUH 5 TONS COOLING. UNIT IS NEW, INSTALLED IN FALL 89.</u>							
MOTOR #	<u>2</u>	HP	<u>1/2 ?</u>	PH	<u>1</u>	RPM	_____
MODEL #	_____	VOLTS	<u>230V</u>	AMPS	<u>26</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	COMMENTS <u>COMP MOTOR</u>						
MOTOR #	<u>3</u>	HP	<u>1/3</u>	PH	<u>1</u>	RPM	_____
MODEL #	_____	VOLTS	<u>230V</u>	AMPS	<u>1.9</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	COMMENTS <u>COMP. FAN</u>						

DATE: 12-12-91
BY: KC

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 124 BLDG NAME: ADMIN JOB: 3105.000
PRIMARY FUNCTION: OFFICES GROSS SQ FT _____ NO OF FLRS _____
BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: OFFICE SPECIAL REQ. YES [] NO []
LOCATION: HALLWAY (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 07:15 TO 16:00, SAT - TO -, SUN - TO -
PRESENT TEMP: WINTER OCC 66.4 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: SYSTEM IS NEW - T'STAT

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING IS SCHEDULED TO BE CONDEMN BY THE POST.
IT IS OCCUPIED BY THE AIRFORCE - AIRFORCE PAID FOR
ELECTRICITY & NAT. GAS.

BUILDING 126

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-12-91

CHECKED BY _____ DATE _____

SCALE _____

Bldg 126 SAME AS Bldg 124

Exceptions

1. window AC UNITS
2. DEEP CEILING
3. Different AHU, probably older
DIFFUSERS ONLY IN CENTER OF Bldg.

Bldg. ~~126~~ Unoccupied during survey.
SOME WINDOW UNITS ON.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 126



JOB 3105

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-12-91

CHECKED BY _____ DATE _____

SCALE NTS



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KL
CHECKED BY: _____
DATE: 12-12-91

BLDG.# 126

MOTORS *BUILDING IS UNOCCUPIED*

MOTOR #	<u>1</u>	HP	<u>1/12</u>	PH	<u>1</u>	RPM	_____
MODEL #	_____	VOLTS	<u>115V</u>	AMPS	<u>0.7</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>CARRIER</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>WINDOW UNIT</u>		COMMENTS _____				
	<u>TYP. OF 6.</u>						
MOTOR #	<u>2</u>	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	_____		COMMENTS _____				
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	_____		COMMENTS _____				

BUILDING 131

BLDG.# 131

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
UPSTAIRS Common Bathroom 2 nd Floor	124 °F
1 st Floor Men's Room	124 °F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. OF
CALCULATED BY: KC
CHECKED BY:
DATE: 12-12-91

BLDG.# 131

MOTORS

MOTOR #	1	HP	5	PH	3	RPM	1740
MODEL #	RVE 1847 TDR 7026DF L	VOLTS	208	AMPS	13.8		
SERIAL #	4124	PRESENT HR.		TO			
MFG	MARATHON	REQUIRED HR.		TO			
FRAME	184T	EFF.	85.5				
DESCRIPTION	HWP 1	COMMENTS	MANUAL ON/OFF LOCATED IN BASEMENT * HAS O A RESET CONTROL.				
MOTOR #	2	HP	5	PH	3	RPM	1740
MODEL #	RVE 1847 TDR 7026DF L	VOLTS	208	AMPS	13.8		
SERIAL #		PRESENT HR.		TO			
MFG	MARATHON	REQUIRED HR.		TO			
FRAME	184T	EFF.	85.5				
DESCRIPTION	HWP 2	COMMENTS	MANUAL ON/OFF * HAS O A RESET CONTROL				
MOTOR #	3	HP	1/12	PH	1	RPM	1725
MODEL #	58JV	VOLTS	115	AMPS	1.71		
SERIAL #		PRESENT HR.		TO			
MFG	BELL & GOSSETT B & G	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	H/W CIR. PUMP	COMMENTS					

DATE: 12-12-91
BY: CMB

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 131 BLDG NAME: _____ JOB: 3105.000
PRIMARY FUNCTION: Admin GROSS SQ FT _____ NO OF FLRS 3
BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: 2ND Floor (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 730 TO 1730, SAT 0 TO 0, SUN 0 TO 0
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: Admin SPECIAL REQ. YES [] NO []
LOCATION: 1st Floor (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0730 TO 1600, SAT 0 TO 0, SUN 0 TO 0
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 155

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/18/91

BLDG.# 155
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. R-11 6"
	3. BRICK
	4. 1/2" PLYWOOD
	5.
	6.
	7. INSIDE AIR FILM
	.17 6.0 1.24 0.62 .68 <u>8.71</u>

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. WOOD 1/2"
	3. AIR GAP 12"
	4. R 19 6"
	5. DROP CEILING
	6.
	7. INSIDE AIR FILM
	.17 1.00 1.24 1.9 1.24 1.79 .68 <u>25.12</u>

PERSONNEL DOOR TYPE _____	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB []
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: KCC
 CHECKED BY:
 DATE: 12-18-91

BLDG.# 155
 ECO 1



PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
1 * CRAND SP	3 1/2 STEAM	200'	STM SPI		55°F	NONE	NONE	
	1"	200'	CONDENSATE					

COMMENTS: * There is insulation where steam & condensate pipes enter building - throughout the building
 no insulation on in load condition.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJECT #
SHEET NO. 155
CALCULATED BY:
CHECKED BY:
DATE: 12-18-91

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000
KC
12-18-91

BLDG.# 155
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
LOW LEVEL AHU 1	15" X 30"	□	NOT OP.	60°F	NONE	NONE	-
AHU 2	24" X 24"	□	↓		FIBERGLASS FOIL	1 1/2"	FAIR
AHU 3,4	18" X 18"	□	32	RM 72	↓	1"	GOOD
AHU 5	30" X 30"	□	-	-	FIBERGLASS CANVAS	1 1/2"	GOOD

COMMENTS: AHU-1 HAS NO HEATING COIL (REMOVED) D + COILING.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____

CALCULATED BY: JW
 CHECKED BY:
 DATE: 12/18/91

BLDG.# 155
 ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
3	SINGLE	SLIDING	OLD WOOD	S	NONE	NONE	30x40
1	"	"	"	S DINING ROOM	"	BLINDS	30x60
5	"	"	"	N	"	NONE	30x60
1	"	"	"	W	"	"	"
5	"	"	"	E	"	BLACKED OUT FOR BAR	30x60

COMMENTS: NO CAUCUS @ ALL EAST WINDOWS PANELED OVER ON

INSIDE

BLDG.# 155
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	NONE	MED	S	30 X 40	1
① W	NONE	VERY HIGH	SOUTH DINING ROOM	30 X 60	1
② D	METAL GLASS DOUBLE DOOR UNIT	HIGH	N	60 X 80	1

COMMENTS:
 ① WINDOW HAS 1/2" AIR GAP W/NO CAULK.
 THIS WINDOW SHOULD BE REPLACED OR NAILED SHUT & CAULKED.
 ② ~~DOORS~~ MAIN FRONT DOORS HAVE 1/2" AIR GAP ON BOTTOM &
 SOME INFILTRATION IN BETWEEN.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/18/91

BLDG.# 155
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
NE BATHROOM	180°F
DOWNSTAIRS BAR	170°F

PROBLEMS:

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KL
 CHECKED BY: _____
 DATE: 12-18-91

BLDG # 155
 ECO 5

MOTORS

MOTOR #	<u>1 (AHU-1)</u>	HP	<u>1</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>5K43MG8047X</u>	VOLTS	<u>200</u>	AMPS	<u>3.8</u>		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	<u>GE</u>	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	<u>SUMMER COOLING ONLY</u> <u>NOT RUNNING @ SURVEY</u>				
MOTOR #	<u>2 (AHU-2)</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>M3157T</u>	VOLTS	<u>208</u>	AMPS	<u>6.8</u>		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	<u>BALDOR</u>	REQUIRED HR.	_____	TO	_____		
FRAME	<u>145T</u>	EFF.	<u>78.5</u>				
DESCRIPTION	_____	COMMENTS	<u>NOT RUNNING @ SURVEY.</u>				
MOTOR #	<u>AHU-3</u>	HP	<u>1/4</u>	PH	<u>1</u>	RPM	_____
MODEL #	_____	VOLTS	<u>115V</u>	AMPS	<u>1.3</u>		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	<u>TRANE PACKAGE</u>	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	<u>BY THE FRONT OFFICE, ABOVE</u> <u>CEILING TOWER.</u>				

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

AHU-4 ABOVE CEILING TOWER SAME AS AHU-3

AHU-5 BALDOR 3 ϕ
CAF. M3311T FM 213T F688 1725 RPM.
7 $\frac{1}{2}$ HP 3 ϕ 208V 23A 85.5% eff.

LOCATE IN BASEMENT (LOWER LEVEL)
SERVE MAIN ROOM UPSTAIR.

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 155 BLDG NAME: NCO CLUB JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 7:00 TO 2400, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 168

EMC ENGINEERS, INC.

DENVER * ATLANTA * GERMANY

BLDG.# _____

JOB

PROJ.#

SHEET NO.

CALCULATED BY

CHECKED BY

DATE

Ft. Macpherson Energy Study EMC#3105.000

OF _____

WALL & ROOF INSULATION

AREAS	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION

COMPONENTS

1. OUTSIDE AIR FILM
- 2.
- 3.
- 4.
- 5.
- 6.
7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION

COMPONENTS

1. OUTSIDE AIR FILM
- 2.
- 3.
- 4.
- 5.
- 6.
7. INSIDE AIR FILM

PERSONNEL DOOR TYPE

OVERHEAD DOOR TYPE

BASEMENT

SLAB

CRAWL SPACE

COMMENTS:

[Handwritten notes and signatures are present in the comments section, including "M/A" and various illegible scribbles.]

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY Kc DATE 12-9-91


CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BASEMENT



FRONT

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

Ft. Macpherson Energy Study EMC# 3105.000

JOB _____
 PROJ.# _____
 SHEET NO. _____ OF _____
 CALCULATED BY _____
 CHECKED BY _____
 DATE _____

BLDG.# _____

WINDOWS

WINDOW#	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MAT'L.	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS
1	1	1	1				
2	1	1	1				
3	1	1	1				
4	1	1	1				
5	1	1	1				
6	1	1	1				
7	1	1	1				
8	1	1	1				
9	1	1	1				
10	1	1	1				
11	1	1	1				
12	1	1	1				
13	1	1	1				
14	1	1	1				
15	1	1	1				
16	1	1	1				
17	1	1	1				
18	1	1	1				
19	1	1	1				
20	1	1	1				
21	1	1	1				
22	1	1	1				
23	1	1	1				
24	1	1	1				
25	1	1	1				
26	1	1	1				
27	1	1	1				
28	1	1	1				
29	1	1	1				
30	1	1	1				
31	1	1	1				
32	1	1	1				
33	1	1	1				
34	1	1	1				
35	1	1	1				
36	1	1	1				
37	1	1	1				
38	1	1	1				
39	1	1	1				
40	1	1	1				
41	1	1	1				
42	1	1	1				
43	1	1	1				
44	1	1	1				
45	1	1	1				
46	1	1	1				
47	1	1	1				
48	1	1	1				
49	1	1	1				
50	1	1	1				
51	1	1	1				
52	1	1	1				
53	1	1	1				
54	1	1	1				
55	1	1	1				
56	1	1	1				
57	1	1	1				
58	1	1	1				
59	1	1	1				
60	1	1	1				
61	1	1	1				
62	1	1	1				
63	1	1	1				
64	1	1	1				
65	1	1	1				
66	1	1	1				
67	1	1	1				
68	1	1	1				
69	1	1	1				
70	1	1	1				
71	1	1	1				
72	1	1	1				
73	1	1	1				
74	1	1	1				
75	1	1	1				
76	1	1	1				
77	1	1	1				
78	1	1	1				
79	1	1	1				
80	1	1	1				
81	1	1	1				
82	1	1	1				
83	1	1	1				
84	1	1	1				
85	1	1	1				
86	1	1	1				
87	1	1	1				
88	1	1	1				
89	1	1	1				
90	1	1	1				
91	1	1	1				
92	1	1	1				
93	1	1	1				
94	1	1	1				
95	1	1	1				
96	1	1	1				
97	1	1	1				
98	1	1	1				
99	1	1	1				
100	1	1	1				

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. 11 135 OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. Macpherson Energy Study EMC# 3105.000
PROJ.# _____
SHEET NO. _____ OF _____
CALCULATED BY KC
CHECKED BY _____
DATE 12-9-91

BLDG.# 168

DOMESTIC HOT WATER

FAUCET LOCATION

WATER TEMPERATURE

Rm 209
Rm 103

127 °F
125 °F

PROBLEMS:

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. Macpherson Energy Study EMC# 3105.000

PROJ.#

SHEET NO. _____ OF _____

CALCULATED BY KC

CHECKED BY

DATE 12-9-91

BLDG.# 168

*10-12-91
 DESIGNED
 R. P. IOR*

REMOVED

EFF.

MOTORS

MOTOR #	LOCATION	MFG.	MODEL #	SERIAL #	FRAME	HP	VOLTS	AMPS	PH	RPM	PRESENT OPERATION HOURS
1	BTW PUMP MECH ROOM	GOULD CENTURY	6-338055-03		S184TCB	5	208	16	3		0-2400

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY
CHECKED BY
DATE

Ft. Macpherson Energy Study EMC# 3105.000

OF

KC

BLDG.# 168

12-9-91

FLOW RESTRICTIONS

SHOWERHEADS	SHOWERS/DAY	NO. OF PEOPLE	PRESENT GPM	GPM W/FLOW RESTRICTOR
17	1	*	Rm 209 10 SQUARE FEET Rm 107 6 SQUARE 30 SEC	5 1/2 QUARTS 1 MIN.
1	1	1	10 SQUARE 45 SEC	5 1/2 QUARTS 1 MIN.

FAUCETS	PEOPLE	PRESENT GPM	GPM W/FLOW RESTRICTOR
17	*	40 OR 10 SEC	22 OR 10 SEC
1		"	"
3	ADMIN. RESTROOMS	"	"

COMMENTS: * CHECK W/BLDG 22 FOR BOB OCCUPATION

DATE: 12/9/91
BY: CRJ

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 168 BLDG NAME: VDQ & WEATHER SERVICES JOB: _____
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 2 + BASEMENT
BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: HOTEL VDQ SPECIAL REQ. YES [] NO []
LOCATION: 1ST & 2ND FLOOR (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0 TO 2400 SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC 74 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC 68 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: EMPTY DURING THE DAY, 0700 - 1630

ZONE NO. 2 FUNCTION: ADMIN/WEATHER SERVICE SPECIAL REQ. YES [] NO []
LOCATION: BASEMENT (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0700 TO 1700, SAT 0 TO 0, SUN 0 TO 0
PRESENT TEMP: WINTER OCC 77 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC 68 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: HOT IN SUMMER PER OCCUPANTS

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

- OTHER ECD'S , PIPE INSULATION, SECTIONS
-) GAS DRYERS IN PLACE OF ELECTRICAL DRYERS
-) DIS. LITE IN ~~VENT~~ COKE MACHINE
-) DELAMP ADMIN. BASEMENT

JOB 3105.000

SHEET NO. _____ OF _____


CALCULATED BY KC DATE 12-10-91

CHECKED BY _____ DATE _____


SCALE _____

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany
584-4797



- ⊙ - 2 - FAN COLLS
- 1 - TV
- 1 - FRIG.
- 1 - CLOCK RADIATOR
- ⊙ - 1 - FC
- 1 - RADIATOR
- 1 - TV
- 1 - FRIG.
- 1 - CLOCK
- 1 - BATH VENT



ROOM DOWNSTAIR



KITCHEN.

- 1 COKE MACHINE
- 1 ICE MAKER SCOTSMAN
- 1 BIG REFRIGERATOR 115V B.S.A.
- 1 MICROWAVE (FULL SIZE)
- 1 STOVE/OVEN (GAS)
- 1 DISHWASHER

WATER COOLER

- SUNROC CORP. GLEN RIDDLE, PA.
- NSF-20W MODEL
- 115V 7.2A HP 1/3


LAUNDRY ROOM

- 2 - WASHERS. → 8 LOADS/DAY + OTHERS.
- 2 - DRYERS (ELEC)
- 1 - 4 TUBE 4' FLORESCENT W/SW.
- 1 - VENT FAN (HOME STYLE).
- WASH TOWERS EVERY DAY
- 1 - RADIATOR (LIKE BATH ROOM)


JOB 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY KC DATE 12-10-91
 CHECKED BY _____ DATE _____
 SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany



- ① HONEYWELL ELEC. ACTUATOR.
- ② COND. PUMP 2-1/2 HP 115V PUMPS



GOULD CENTURY
 PART 6-333055-03
 FRAME S184TCZ
 TYPE SC
 HP 5 CODE J
 VOLT 200-208
 AMPS 16
 CAT 0242

PUMP MODEL
 LOCKWOOD PRODUCT
 - 2WS5-4YX MODEL
 - 178P985 SERIAL

- NOTES:**
- DTW PUMP CONNECT TO ~~PC~~ ^{EEP}, BUT NOT OA RESET NOR TC
 - OA RESET DOES NOT WORK
 - TC HAS NO PINS.
 - HONEYWELL VALVE LOOKS NEW.
 - OA & TC COULD BE FOR STM VALVE.

CHILLER LOCATE ON PAD BEHIND BLDG.

TRAVE
 MODEL # CGAA-1506-JB
 COMP. MOTOR/S 2 - 3Ø 60HZ 37.8 RLA each 17.9 LRA each
 COND FAN 3 - 1Ø 60 HZ 2.3 FLA each 1/3 HP. each
 SERIAL # L78E13306
 TYPE # 561-0049-1B
 VOLT 208/240
 R-22.

- SHOULD INSULATE COND. RET PIPE.

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-10-91

CHECKED BY _____ DATE _____



SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

TYP. FOR ROOM (209)

- ALARM CLOCK 5W
- REFRIGERATOR 120V 1.65A SMALL.
- TV. 120V 1A.
- 1 LIGHT IN BEDROOM (OVERHEAD) 2-
- 1 LAMP 52W



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE 2/2

CHECKED BY _____ DATE _____

SCALE _____



BLDG.# 168

BASEMENT

LIGHTING

ROOM #	NO. OF FIXTURES	LAMPS/FIXTURE	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES
1	4	4	F 34	ON	Y	Y	1
2	4	4	F 34	OFF	Y	Y	1
3	2	4	F 34	F	Y	Y	1
4	6	4	F 34	ON	Y	Y	1
WOMEN'S RM	1	4	F 34	OFF	Y	Y	1
	1	1	I 52	OFF	Y	Y	
5 DOR	6	4	F 34	0	Y	Y	1
6	4	4	F 34	0	Y	Y Y	1
7	4	4	F 34	F	Y	Y	1
8	2	4	F 34	0	Y	Y	1
EXIT SIGNS	111	2					

MENS COMMENTS: 1 4 F 34 0 Y Y 1
2 1 I 52

9	2	4	F 34	0	Y (6)	Y	1
10	2	4	F 34	0	Y	Y	1
11	4	4	F 34	0	Y	Y	1
12	2	1	I 100w	0	N	N	1
13	4	4	F 34w	0	Y	Y	1
14	2	4	F "	0	Y	Y	1

BLDG.# 168

PER BULB

LIGHTING

1ST FLOOR
2ND FLOOR

ROOM #	NO. OF FIXTURES	LAMPS/FIXTURE	WATTS	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES
TYP ROOM	1	2	52	INC	OFF	Y	N	1
209	1	1	52	INC	OFF	TABLE LAMP	N	1
BATH	1	1	52	INC	OFF	Y	N	1
2ND FLOOR	1	5	52	INC	OFF	Y	Y	1
"	5	3	52	INC	ON	Y	Y	1
"	1	5	52	INC	OFF	Y	Y	1
LAUNDRY	1	4	34	FLOOR	ON	Y	Y (G)	1
106	2	2	52	INC	ON	Y	N	1
106 Bath	1	1	52	INC	OFF	Y	N	1
106	1	5	52	INC	OFF	Y	Y	1
EXIT SIGN	1	2	45	I	O			

1ST FLOOR - ALL COMMENTS:

106	4	5	52	INC	ON	Y	Y	1
	1	5	52	INC	OFF	Y	Y	1
106	3	1	52	INC	OFF	TABLE LAMP	N	3
102	1	5	52	INC	OFF	Y	Y	1
102	1	5	52	"	"	"	"	"
102	4	1	52	"	OFF	TABLE LAMP	N	4
102 BATH	1	1	52	"	"	Y	N	1
103	2	2	52	"	OFF	Y	N	1
103 BATH	1	1	52	"	OFF	Y	N	1
103	2	1	52	"	"	TABLE LAMP	N	2
KITCHEN	1	4	34	FLOOR	ON (G)	Y	Y	1

BUILDING 170

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/31/91

BLDG.# 170
ECO 5

10+ HP MOTORS
MEASURED

MOTOR#	<u>HW Pump</u>		PHASE A	PHASE B	PHASE C
LOCATION	<u>MECH ROOM</u>	KVAR	<u>7.5</u>		
MFG	<u>BAKDOR</u>	KVA	<u>13.5</u>		
MODEL #	<u>M2333T</u>	KW	<u>11.3</u>		
SERIAL #	<u>10784G</u>	PF	<u>83</u>		
FRAME	<u>254T</u>	HP			
HP	<u>15</u>	VOLTS	<u>208</u>	<u>208</u>	
RPM	<u>1760</u>	AMPS	<u>38</u>	<u>38</u>	
PRESENT	<u>0</u> TO <u>2400</u>	PH			
REQ HR.	_____ TO _____	<u>230V 38A 87% PF 86%</u>			

MOTOR #	_____		PHASE A	PHASE B	PHASE C
LOCATION	_____	KVAR			
MFG	_____	KVA			
MODEL #	_____	KW			
SERIAL #	_____	PF			
FRAME	_____	HP			
HP	_____	VOLTS			
RPM	_____	AMPS			
PRESENT	_____ TO _____	PH			
REQ HR.	_____ TO _____				
COMMENTS	_____ _____ _____				

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CBA DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

170

HW PUMP

MANUFACTURER: BALDOR

MODEL M2333T

SPEC. 09A51Z36

FRAME 254T

HP 15

VOLTS 230 60 HZ

AMPS 38 3 ϕ

RPM 1760

EFF 87% PF 86%

PEERLESS PUMP

NO NAME RATE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY ES DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

170



DHWP-1, RECIRC WATER IN BUILDING

- B & G PUMP, NO NAME PLATE, EST 1/10 HP
- OFF DURING SURVEY

DHWP-2, HW CIRC

- NO NAME PLATE
- OFF DURING SURVEY

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CBL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

170

CHW PUMP

MOTOR:

MANUFACTURER	DAYTON
MODEL	3N662A
HP	15
RPM	1750
NEMA DESIGN	B
FRAME	254T
PHASE	3
HZ	60
NEMA NOMINAL EFF,	88.5
POWER FACTOR	81.5
VOLTS	208
AMPS	42.0

PUMP:

MANUFACTURER	PEERLESS PUMP		
SIZE/MODEL	Z.5AD13	TYPE	5300
RPM	1750	SER. NO.	431238
GPM	250	FT HD	98

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

170

TRANE CHILLER (OFF @ SURVEY)

MODEL NO. CG AA12 06R J51 CA4C 4C36 1AER
COMP. 2 @ 236A ea 3 ϕ 60H
200V

COND FANS 3 25.4A ea 7.5 HP

CARRIER HEAT PUMP (RUNNING @ SURVEY)

MODEL 38B Q 00 8530

SER. NO. 1289 934 108

COMP 1 208V
38.5A

FAN 1 208V
3.6A

- COMPUTER A/C UNIT

- IGNORE, SPECIAL PURPOSE

- LARKIN, PFG-8
2.6A, 208V, 3 ϕ ,
COND. FAN UNIT ONLY

- DATEC FAN & COMP. NO NAMEPLATE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

170

HOURS MON - FRI 0730 - 1615

> BLDG HAS TWO PIPE FAN COILS

> 34 W ECONO-WATT FLUORS. LIGHTS
SPOT CHECK (3)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

170

{ - CONDENSATE RECEIVER OVERFLOWING
{ - PUMPS OFF
 { - CN RETURN

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG-120


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____


CHECKED BY _____ DATE _____

SCALE _____

170 |

PER CONTROLS DWG

- TIMECLOCK HAS NO PINS
- HEAT/AUTO/COOL SW IN HEAT POSITION



IN AUTO, TRIPS TO HEAT
@ OR BELOW 65°F

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

HOSPITAL

AHU 9 zone 3 says "Temp. Never Correct"
AHU 15 zone 1 works 24hrs 7days/wk "Temp. Never Correct"
adj. to blood bank
AHU-16 zone 2 T-STAT Not Responding well
AHU-17 H-3 Not working
H-4 Not working
H-2 Not working

ANNEX

NO T-STAT FORMS

FT. MAL ENERGY
STUDY
E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB EMC # 3105,000

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 11-27

CHECKED BY _____ DATE _____

SCALE NTS

BLDG @ 170

ROOM NO.	N.O.F. FIXTURES	NO. LAMP FIXTURES	WATTS PER BULB	T-TYPE BULB	NO. ON/OFF SWITCHES	NO. ON/OFF SWITCHES	NO. ON/OFF SWITCHES	NO. ON/OFF SWITCHES
111	2	2	40	1	1	1	1	1
112	1	1	40	1	1	1	1	1
113	1	1	40	1	1	1	1	1
114	1	1	40	1	1	1	1	1
115	2	2	40	1	1	1	1	1

PT. MAC ENERGY
STUDY
E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB EMC # 3105,000

SHEET NO. _____ OF _____

CALCULATED BY EMD DATE 11-27

CHECKED BY _____ DATE _____

SCALE NTS

BLDG # 173

NO.	NO. OF FIXTURES	NO. OF LAMP FIXTURES PER BULB	WATTS	BULB TYPE	ON/OFF	SM/TX	NO. OF GOOD LAMP NO.
101	2	4	34	F	ON (G)	Y	1
102	1	1	52	F	OFF	Y	1
103	1	4	34	F	OFF	Y	1
104	1	4	34	F	ON	Y	1
105	1	4	34	F	ON	Y	1
106	1	4	34	F	ON	Y	1
107	1	4	34	F	ON (G)	Y	1
108	1	2	34	F	ON (G)	Y	1
109	1	2	34	F	ON (G)	Y	1
110	3	2	34	F	OFF	Y	2
111	1	2	34	F	ON	Y	1
112	1	4	34	F	ON	Y	1
113	1	4	34	F	ON	Y	1
114	1	4	34	F	ON	Y	1
115	1	4	34	F	ON	Y	1
116	1	2	34	F	ON	Y	1
117	1	4	34	F	ON (G)	Y	1
118	1	1	150	I	ON	Y	1
119	6	4	34	F	ON	Y	1
120	1	4	34	F	OFF	Y	1
121	1	4	34	F	ON (G)	Y	1
122	1	2	34	F	ON (G)	Y	1
119A	2	1	52	F	ON (G)	Y	1
123	1	1	52	F	ON (G)	Y	1

NO. 2ND FLOOR
100

123 OF
(all "A" rooms)

PT. MAC ENERGY
STUDY
E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB EMC # 3105,000

SHEET NO. _____ OF _____

CALCULATED BY EMC DATE 11-87

CHECKED BY _____ DATE _____

SCALE NTS

BLDG # 71

NO. OF TIMES
NO. OF
SERIES
NO. OF
SERIES

ON/OFF
SWITCH
YES/NO

ON/OFF
DRINKING
FURNACE

TYPE
BULB

NO. OF
WATT
BULBS

NO. OF
PER
FIXTURE

NO. OF
FIXTURES

NO. OF
ROOM

ROOM	NO. OF FIXTURES	NO. OF PER FIXTURE	NO. OF WATT BULBS	TYPE BULB	ON/OFF DRINKING FURNACE	ON/OFF SWITCH YES/NO	NO. OF TIMES NO. OF SERIES
79	1	4		F1 (18')	ON	N	
42	1	4		F1	ON	Y	
52	2	4		F1	ON	Y	
43	1	4		F1	OFF	Y	
44	1	4		F1	ON	Y	
45	"	"		"	"	"	
46	"	"		"	"	"	
47	"	"		"	"	"	

PT. MAC ENERGY
STUDY
E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY CMC- DATE 11-27

CHECKED BY _____ DATE _____

SCALE NTS

BLDG # 170

ROOM NO.	N.O. FIXTURES	NO. LAMP PER FIXTURE	WATT BULB	T-TYPE BULB	ON/OFF SWITCHING	YES/NO SWITCH	NISES POSITIVE FOR	SWITCHES
40	1	4	34	FI	ON	N	Y	1
55	6	4		FI	ON	Y		1
54	2	4		FI	ON	Y		1
58	4	2		FI	ON	Y		1
53	7	4		FI	ON	Y		1
59	3	2		FI	ON	Y		3
61	2	2		FI	ON	N/A		
71	3	4		FI	ON	Y		1
70	8	4		FI	ON	Y		1
69	3	4		FI	ON			1
68	3	4		FI	ON	Y		1
60	3	4		FI	ON	Y		1
65	2	4		FI	ON	Y		1
66	1	4		FI	ON	N		
67		4		FI	ON	N		
68	1	4		FI	ON	N		
64	1	4		FI	ON	Y		1
100	1	2		FI	ON	Y	N	1
81	2	4		FI	ON	Y		1
80	1	2		FI	ON	Y	Y	1
72	1	4		FI	ON	Y		1
73	1	4		FI	ON	Y	Y	1
74	1	4		FI	ON	Y		1
	2	4		FI (18')	ON	Y		1

PT. MAC ENERGY
STUDY
E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB EMC # 31051000

SHEET NO. _____ OF _____

CALCULATED BY EMC DATE 11/23

CHECKED BY _____ DATE _____

SCALE NTS

BLDG # 170

ROOM NO.	N.O. FIXTURES	NO. OF FIXTURES	LAMP PER FIXTURE	WATTAGE	BULB TYPE	ON/OFF SCHEDULE	SWITCH	GOOD FOR DUPLICATION	SWITCHES
1	1	1	2		FI 41	OFF	Y	N	1
2	1	1	1	150	INCAN.	OFF	Y	N	1
28	4	2			FI	ON	Y	N	1
5	1	4			FI	ON	Y	N	1
6	"	"		"	"	"	"	"	"
9	6	4			FI	ON	Y	N	1
9	15	1		25	INCAN	ON	Y	N	1
29	6	2		24	FI	ON	Y	N	1
17	1	4		1	FI 18	ON	Y	N	1
21	7	2			FI	ON	Y	N	1
27	1	1		52	INCAN	ON	Y	N	1
25	1	2		1	FI	ON	Y	N	1
24	4	2			FI	ON	Y	N	1
23	2	2			FI	ON	N	N	1
22	4	2			FI	ON	Y	N	1
18	4	4			FI	OFF	Y	N	1
15	7	2			FI 41T	ON	N/A	N	1
14	25	2			FI 41T	ON	N/A	N	1
3	6	2			FI	ON	Y	N	1
30	7	4			FI	ON	Y	N	1
31	3	4			FI	ON	Y	N	1
34	2	4			FI	ON	Y	N	1
37	2	4			FI	ON	Y	N	1
38	1	4			FI	ON	Y	N	1
41	1	4			FI	ON	Y	N	1

BUILDING 171

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 1-27

CHECKED BY _____ DATE _____

SCALE _____

Bldg. 171

1st FLOOR All Fixture are 4 Bulbs excep-
HALLWAY FIXTURES WHICH ARE 2 Bulbs

2nd Floor

Unoccupied offices - lights ON

10

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY C&L DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

171

2 Showers in Bldg.

1/28/92 DMW TEMP. 104°F

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/12/92

BLDG.# 171
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1	8	4	34	F	ON	Y	N	2	N
1	13	2-U			ON	Y	N	1	N
2	2	4	34	F	ON	Y	N	1	N
3	15	8'			ON	Y	N	2	N
4	2	8'			ON	Y	N	1	N
5	2	8'			ON	Y	N	1	N
103	10	4			ON	Y	N	2	N
108	5	4			N/A	Y	N/A	2	N/A
109	2	4				Y		1	
101	2	4				Y		1	
107	5	4				Y		1	
125	3	4				Y		1	
128	4	4				Y		1	
127	4	2				Y		1	
126	4	2				Y		1	
111	8	2				Y		2	
106	2	4				Y		1	
102	2	4				Y		2	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/12/92

BLDG.# 171
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
120	3	4				Y		1	
201	2	4				Y		1	
203	8	4				Y		3	
202	2	4				Y		1	
205	2	2 2				Y		1	
206	1	4				Y		1	
207	1	4				Y		1	
208	2	2				Y		1	
209	2	4				Y		1	
212	3	2				Y		1	
210	1	4				Y		1	
213	1	4				Y		1	
214	1	4				Y		1	
215	1	2				Y		1	
217	1	2				Y		1	
218	4	2				Y		1	
219	4	2				Y		1	
220	4	4				Y		1	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/12/92

BLDG.# 171
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
243	2	4			Y	Y		1	
242	2	4			.	Y		1	
244	1	4				Y		1	
238	3	4				Y		1	
240	6	2				Y		2	
222	1	4				Y		1	
223	3	4				Y		1	
225	3	4				Y		1	
239	2	4				Y		2	
228	2	4				Y		1	
229	2	4				Y		1	
230	2	4				Y		1	
231	2	4				Y		1	
227	30	2				Y		4	
238	2	4				Y		1	
232	40	2				Y		1	
234	1	4				Y		1	
233	4	2				Y		1	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 2/12/92

BLDG.# 171
EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
235	2	2				Y		1	
237	1	4				Y		1	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/12/92

BLDG.# 171
 EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
104	10	4				Y		2	
105	4	4				Y		1	
144	1	2				Y		1	
143	1	4				Y		1	
112	4	2				Y		1	
113	4	2				Y		1	
114	4	2				Y		1	
115	1	4				Y		1	
116	2	2				Y		1	
123	1	2				Y		1	
124	1	4				Y		1	
122	1	4				Y		1	
121	12	2				Y		1	
135	2	4				Y		1	
117	10	2				Y		4	
118	1	4				Y		1	
136	1	2				Y		1	
119	1	4				Y		1	

OF EXIT SIGNS - _____

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY CEL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

171



(2) OA TEMP SENSOR
HIGH LIMIT CONTROL

SET @ 60° & 90°

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CEA DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

171

AHW -

MARATHON ELECTRIC

MODEL EVR 184TTD 87627AC WF1

5 HP

FRAME 184 T

TYPE TDR-BE

3 ϕ

60 Hz

1740 RPM

200 ~~V~~ V

16.2 A

> OFF

> NOT USED ANY MORE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CE DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

171

AHU-2

GOULD CENTURY

PART-6-322467-01

FRAME S-184T

HP. 5.0

RPM 1740

3 ϕ

200 V 16 AMPS

- OFF DURING SURVEY
 - SERVES ^{OLD} OR AREA
 - 100% O.A., DUCT RA ON OUTSIDE OF BLDG?
 - SEE CONTROL DWG
-

- NOT USED ANY MORE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CPJL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

YORK AHU-3

MODEL EB V24Z-A

~~#~~ MOTOR EST. 5HP


SER NO. ES 042576

✓ STEAM

✓ DX

— EASY TO RETROFIT FOR 100% OA

— NO DAMPERS




— SERVES PHYSICAL THERAPY

— RUNS IN SUMMER ONLY

— OFF DURING SURVEY

— EST. 5 PEOPLE MAX



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY CFE DATE 11/26/91
CHECKED BY _____ DATE _____
SCALE _____

171

CONDENSING UNIT WHICH SERVES

AHU-4

YORK

MODEL CA181-25A

SER. NO. ~~FM~~ FM -084766

V - 208

A - 69.7

3 ϕ
60 Hz

COND

3 FANS

1/2 HP ea

208V 3.4A

MAIN CHILLER AIR COOLED

TRANE

MODEL CGAA0756ED 51 CC5C 4C 361

AJFE

SER. NO. L83D11356

COMP. 1 - 3 ϕ , 60 Hz, 264 A, 200V

COND FAN 2 @ 7.5 HP ea

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CBL DATE 11/26/91

CHECKED BY _____ DATE _____

SCALE _____

171

M - F - 0700 - 1500

SAT - CLOSED

SUN -

ECO -

- DISCONNECT LIGHTS ON VENDING MACHINES
- LOW FLOW SHOWER HEADS

-

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY (MD) DATE 11/27

CHECKED BY _____ DATE _____

SCALE _____

Bldg 17.1

BOILER Rm

CHILL WATER Pump - 1

US MOTOR M# F-5882-00-542

10 HP FPM-215JP

200V 1755 RPM

31.2 A

60 Hz

3ph

OFF

HW pump - 1

GOULD MOTOR M# 8-338519-01

15 ~~15~~ HP FRAME N145JM

200V 1745 RPM

4.7 A

60 Hz

3ph

Bell & GOSSETT Pump
M# 1-114 AC 6-3/8 Bf

69 GPM 1750 RPM 33 FT HD.

ON

Direct HW Pump - 1


Bell & GOSSETT pump

3000 RPM pump


ON

SEQUENCE OF OPERATION

START/STOP
 THE UNIT FAN WILL BE STARTED BY A 7-DAY PROGRAM THE CLOCK. HECO'S
 STOP FAN IF THEIR SET POINT IS EXCEEDED. WHEN THE UNIT FAN STARTS,
 THE FAN MOTOR WILL BE ENERGIZED, AND THE O.A. DAMPER WILL OPEN.
 SPACE TEMPERATURE CONTROL
 WHEN THE SPACE TEMPERATURE CONTROL IS PROVIDED AND WILL ALLOW THE MANUAL SELECTION OF
 MANUAL OR AUTOMATIC.
 WHEN THE UNIT IS IN THE HEAT POSITION THE SPACE THERMOSTAT WILL
 MODULATE THE N.C. STEAM VALVE AS REQUIRED TO MAINTAIN SPACE
 TEMPERATURE.
 WHEN THE SWITCH IS IN THE COOL POSITION THE SPACE THERMOSTAT WILL
 CYCLE THE CONDENSING UNIT AS REQUIRED TO MAINTAIN SPACE TEMPERATURE.



**DAMPERS
 SET UP FOR
 ECONOMIZERS**



NOTE: SEE WAVE SCHEDULE
 SHEET #2

171

DWG. REF.
 ANU-1 - SHEET 1
 AIR COMP - SHEET 1

ASB-01 - 0
 N-8-40 - 0
 (TYPICAL)

NO.	REV.	DATE	BY	CHKD.	DESCRIPTION
1	1				ASB-01 - 0
2	2				N-8-40 - 0

BUILDING 171
 FORT ALPHERSON

COMBINATION CONTROL SYSTEM
 FOR THE
 HEATING AND COOLING UNIT (S-1)
 HONOLULU, HAWAII, U.S.A. 1951

ANU-1 CONTROLS

DESIGNED BY S. D. STONE
 DRAWN BY J. W. GIBSON
 CHECKED BY J. W. GIBSON

DWG NO. 206577400

SEQUENCE OF OPERATION

START/STOP

A SYSTEM ON/OFF SWITCH IS PROVIDED FOR MANUAL STARTING AND STOPPING OF THE UNIT. WHEN PLACED IN THE ON POSITION, THE O.L.A. JUMPER WILL BE ENERGIZED AND THE UNIT WILL START. THE UNIT WILL STOP WHEN THE O.L.A. JUMPER IS PLACED IN THE OFF POSITION. THE UNIT WILL START AND CONTROL SYSTEM WILL BE ENERGIZED. THE SPRAY PUMP AND EXHAUST FANS ARE INTERLOCKED TO OPERATE WITH THE UNIT FAN. A HICO AND HECO ARE PROVIDED IN THE SUPPLY AIR AND THE PREHEAT COIL IF AN UNSAFE CONDITION EXISTS. EXHAUST FAN, HICO'S WILL ALSO STOP FAN IF AN UNSAFE CONDITION EXISTS.



DISCHARGE AIR CONTROL

A SENSOR LOCATED IN THE FAN DISCHARGE WILL OPERATE THROUGH ITS RECEIVER CONTROLLER (RC-1) TO MODULATE THE N.C. STEAM COIL VALVE AS REQUIRED FOR HEAT IN SEQUENCE WITH CYCLING THE CONDENSING UNIT AS REQUIRED. A HUMIDISTAT WILL OPERATE THROUGH ITS RECEIVER CONTROLLER (RC-2) AND WILL OVERRIDE RC-1 TO MODULATE THE STEAM VALVE OPEN IF TEMPERATURE FALLS BELOW ITS SETPOINT.

SPACE TEMPERATURE AND HUMIDITY CONTROL

A SPACE THERMOSTAT WILL MODULATE ITS REHEAT COIL VALVE AS REQUIRED TO MAINTAIN SPACE TEMPERATURE.

A SPACE HUMIDISTAT WILL MODULATE ITS N.C. HUMIDIFIER VALVE AS REQUIRED TO MAINTAIN SPACE HUMIDITY. A HUMIDIFIER HIGH LIMIT CONTROL LOCATED DOWNSTREAM OF THE HUMIDIFIER WILL OVERCALL SPACE HUMIDISTAT AND CLOSE THE HUMIDIFIER VALVE IF ITS SETPOINT IS EXCEEDED.



171

- NOTES:
- SEE VALVE SCHEDULE THIS SHEET
 - NORMALLY CLOSED, 8-13" HUMIDIFIER STEAM VALVE FURNISHED WITH HUMIDIFIER.

DWG. REF.

AHU-2 --- SHEET 1
EF-1,2,3 --- SHEET 1

NO.	COMPLETE MODEL NO.	LOCATION	DATE	REV.	BY	CHKD.	APPROVED	REVISIONS
1	V-1 V6700-163012	AHU-1 STEAM COIL	3/4	2-MAX	N.C.	1	194	15 5.7 6.0 (8-13)
2	V-2 V6700-163012	AHU-2 STEAM COIL	3/4	2-MAX	N.C.	1	152	15 5.7 3.4 (8-13)
3	V-3 V6700-033012	AHU-2 COLL. #3	1/2	2-MAX	N.C.	1	41	15 1.2 5.6 (8-13)
4	V-4 V6700-033012	AHU-2 COLL. #4	1/2	2-MAX	N.C.	1	41	15 1.2 5.6 (8-13)
5	V-5 V6700-033012	AHU-2 COLL. #5	1/2	2-MAX	N.C.	1	41	15 1.2 5.6 (8-13)

BUILDING 171
FORT McPHERSON

ROSENTHAL CONTROLS COMPANY
5952 ROCKWELL BLVD.
NORCROSS, GEORGIA 30070

AW-40 - 0
(TYPICAL)

ACE CONTRACTING CO.
DIRECTORATE OF FACILITIES ENGINEERING

MINOLETT S.D. BYES
NOV 3 1957
NO 2023 77000

SEQUENCE OF OPERATION

START/STOP

A SYSTEM ON/OFF SWITCH IS PROVIDED FOR MANUAL STARTING AND STOPPING OF THE UNIT. WHEN PLACED IN THE ON POSITION THE O.A. DAMPER WILL WILL START AND CONTROL SYSTEM WILL BE ENERGIZED. THE SPRAY PUMP, A HEAT AND COOL ARE PROVIDED IN THE SUPPLY AIR AND THE PREHEAT COIL DISCHARGE RESPECTIVELY AND WILL STOP FAN AND CLOSE THE O.A. DAMPER FAN AND AN UNLAMP CONDENSATE TRAP.


DISCHARGE AIR CONTROL

A SENSOR LOCATED IN THE FAN DISCHARGE WILL OPERATE THROUGH ITS RECEIVER FOR HEAT IN SEQUENCE WITH CYCLING THE CONDENSING UNIT AS REQUIRED FOR COOLING TO MAINTAIN SET POINT. A HUMIDIFIER HIGH LIMIT CONTROL LOCATED AND WILL OPERATE RC-1 TO MODULATE THE STEAM VALVE OPEN IF TEMPERATURE FALLS BELOW ITS SETPOINT.


SPACE TEMPERATURE AND HUMIDITY CONTROL

A SPACE THERMOSTAT WILL MODULATE THE REHEAT COIL VALVE AS REQUIRED TO MAINTAIN SPACE TEMPERATURE.

A SPACE HUMIDISTAT WILL MODULATE ITS M.C. HUMIDIFIER VALVE AS REQUIRED TO MAINTAIN SPACE HUMIDITY. A HUMIDIFIER HIGH LIMIT CONTROL LOCATED TO MAINTAIN HUMIDITY. A HUMIDIFIER HIGH LIMIT CONTROL LOCATED AND THE HUMIDIFIER VALVE IF ITS SET POINT IS EXCEEDED.



CP-2
(20-25-10)
N100-9901
(LOCATE ADJACENT TO RHU-2 MOTOR STARTER)



NOTES
1. SEE VALVE SCHEDULE THIS SHEET
2. NORMALLY CLOSED
STEAM VALVE E
OPERATES WITH HUMIDIFIER.

171

DWG. REF
RHU-2 --- SHEET 1
EP-1,2,3 --- SHEET 1

NO.	DESCRIPTION	SIZE	TYPE	LOCATION	REMARKS
1	W/116700-1A10012	3/4"	2-WAY	M.C. 1	B-13
2	W/116700-1A10012	3/4"	2-WAY	M.C. 1	B-13
3	W/116700-1A10012	1/2"	2-WAY	M.C. 1	B-13
4	W/116700-1A10012	1/2"	2-WAY	M.C. 1	B-13
5	W/116700-1A10012	1/2"	2-WAY	M.C. 1	B-13

9201-01 - 0
94-00 - 0
(TYPICAL)

FORWARDING TO
FORT McPHERSON
SHEET NO. 50-315
NO. 202277000

BUILDING 178

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-12-91

BLDG.# 178

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	68 608	608	1456	1456
WINDOWS	68	0	221	0
OVERHEAD DOORS	—	—	—	—
PERSONNEL DOORS	70	35	0	35

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. CMU
	3. 2x4
	4. GYI Board
	5. _____
	6. _____
	7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. Shingles
	3. Plywood
	4. space
	5. 3" ≈ R-11 Fiberglas
	6. Ceiling tile
	7. INSIDE AIR FILM

PERSONNEL DOOR TYPE _____	BASEMENT [] SLAB [] CRAWL SPACE []
OVERHEAD DOOR TYPE _____	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO. 42 OF
CALCULATED BY:
CHECKED BY:
DATE: 12-12-91

BLDG.# 178

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
ACU-1	1 1/2" COPPER	25'	REFRIG.	-	-	RUBBER	3/8"	GOOD
ACU-2	1 1/4" COPPER	50'	↓	-	-	↓	↓	↓
ACU-3	1" COPPER	25'	↓	-	-			

COMMENTS:






EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000
EC OF
12-12-91

BLDG.# 178

DUCT INSULATION
SURE.

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SUPPLY AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
ACU-1	24" X 24"		NOT RUNNING	NOT RUNNING	FIBERG.	1/2"	GOOD
ACU-2	15" X 16"		↓	↓	FIBERG GLASS	1/2"	GOOD
ACU-3	8.4" X 24"		↓	↓	↓	1/2"	GOOD
	50" X 8"				Fiberglass	1.5"	
	60" X 8"				Fiberglass	1.5"	

COMMENTS: FIBERGLASS WITH WHITE PAINT

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study

PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: C.M.P.

CHECKED BY: _____

DATE: 12-12-91

178

BLDG.# _____

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
<u># 1</u>	<u>Double</u>	<u>Sliding</u>	<u>AL</u>	<u>N</u>	<u>NONE</u>	<u>NONE</u>	<u>53x46</u>

COMMENTS: TYP. OF 17

BLDG.# 178

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
* 1	Good	—	N	53x46

COMMENTS: Windows ~~are~~ look new, tight, good insul., caulk.

* Typ. of 17

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMJ
 CHECKED BY: _____
 DATE: 12-12-91

BLDG.# 178

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
<i>1st Floor Men's Room</i>	<i>126 °F</i>
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: kw
CHECKED BY: _____
DATE: 12-12-91

BLDG.# 178

MOTORS GAS WATER HEATER

MOTOR #	<u>1</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	_____
MODEL #	_____	VOLTS	<u>208</u>	AMPS	<u>6.6</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>TRANE</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>NOT ACCESSIBLE</u>	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>ACU-1</u> <u>T'STAT CONTROL</u>	COMMENTS	<u>TRANE PACKAGE '87</u> <u>BWE120C4006A</u> <u>DX - FURNACE (N. GAS)</u>				
MOTOR #	<u>2</u>	HP	_____	PH	<u>1</u>	RPM	_____
MODEL #	<u>BLU162F960B2</u>	VOLTS	<u>115</u>	AMPS	<u>12</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>TRANE</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>NOT ACCESSIBLE</u>	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>ACU-2</u> <u>N GAS. T'STAT CONTROL</u>	COMMENTS	<u>SMALL UNIT</u> <u>INPUT 162,000 BTUH.</u>				
MOTOR #	<u>3</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	_____
MODEL #	_____	VOLTS	<u>208</u>	AMPS	<u>6.6</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>TRANE</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>NOT ACCESSIBLE</u>	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>ACU-3</u> <u>UPSTAIR</u>	COMMENTS	_____				

DATE: 12-12-91
BY: (MD)

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 178 BLDG NAME: Music JOB: 3105.000
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 2
BUILDING MANAGER NAME: _____
PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: 1st Floor (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0730 TO 1615, SAT 0 TO 0, SUN 0 TO 0
PRESENT TEMP: WINTER OCC 68.9 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: 1st Floor (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0730 TO 1615, SAT 0 TO 0, SUN 0 TO 0
PRESENT TEMP: WINTER OCC 70.8 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 3 FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: 2nd Floor (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 730 TO 1615, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 179


EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12-12-91

BLDG.# 179

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	516	516	1575	1575
WINDOWS	73	0	175	204
OVERHEAD DOORS	—	—	—	—
PERSONNEL DOORS	0	0	24.5	24.5

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. STUCCO 3. 2" POLYSTYRENE 4. CMU 5. 2 1/2" STEEL STUDS 6. GYP BOARD 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. SHINGLES 3. PLYWOOD 4. SPACE 5. BLOW IN INSULATION, R-30 6. SPAC 7. INSIDE AIR FILM 8. CEILING CEILING TILE

PERSONNEL DOOR TYPE <u>METAL</u>	BASEMENT [] SLAB [] CRAWL SPACE [✓]
OVERHEAD DOOR TYPE <u>—</u>	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE

g
Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000
KC
12-12-91

BLDG.# 179

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH. RM	* 3"	40'	DTW			Rubber	1"	GOOD
"	2"	25'	"			Rubber	1"	"
CRAWL SPACE	3"	2x Bldg length	"			"	"	"

COMMENTS: * ALL PIPES (HW & CW) HAVE GOOD RUBBER INSULATION.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: cmD
 CHECKED BY: _____
 DATE: 12-12-91

BLDG.# 179

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
<i>W</i>	<i>Good</i>	<i>—</i>	<i>⊗ ⊙</i>	<i>44 x 48</i>
<i>D-1</i>	<i>Good</i>	<i>Low</i>	<i>W</i>	<i>42 x 84</i>
<i>D-2</i>	<i>Good</i>	<i>Low</i>	<i>E</i>	<i>42 x 84</i>

COMMENTS: *# Typ. of 31*

BLDG.# 179

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
1 st Floor Men's Room	149° F
PROBLEMS:	

COMMENTS: Temp. seems high - only HW use is in
 sinks in Bathrooms (2).

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. OF
CALCULATED BY: lec
CHECKED BY:
DATE: 12-12-91

BLDG.# 179

MOTORS MANUAL CHANGE OVER (SUM-WIN)

MOTOR #	<u>2</u>	HP	<u>3/4</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>TVH 56T17D5540A L</u>	VOLTS	<u>208</u>	AMPS	<u>2.9</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>MARATHON</u>	REQUIRED HR.		TO			
FRAME	<u>56C-65</u>	EFF.					
DESCRIPTION	<u>DTW PUMP FOR BLDG.</u>		<u>COMMENTS RUNNING</u>				
MOTOR #	<u>1</u>	HP	<u>1/2</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>TVL56T17D5539A L</u>	VOLTS	<u>208</u>	AMPS	<u>2.3</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO			
MFG	<u>MARATHON</u>	REQUIRED HR.		TO			
FRAME	<u>56C-65</u>	EFF.					
DESCRIPTION	<u>CWP PUMP THROUGH CHILLER</u>		<u>COMMENTS OFF</u>				
MOTOR #	<u>3</u>	HP	<u>1/6</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #		VOLTS	<u>115V</u>	AMPS	<u>2.4A</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>BELLGDSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>DOMESTIC HW PUMP</u>		<u>COMMENTS</u>				

TRANE CHILLER CGACC 208KLN BB20G
1-COMP MOTOR 200V 3Ø 2.2-2.4
2-FAN MOTOR 200V 3Ø 4.1A 1HP. each

DATE: 12-12-91
BY: CMD

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 179 BLDG NAME: Army Ed. JOB: 3105.000
PRIMARY FUNCTION: Education GROSS SQ FT _____ NO OF FLRS 2
BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] _____ - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: Admin SPECIAL REQ. YES [] NO []

LOCATION: 1st Floor (IDENTIFIED ON FLOOR PLAN [])

OCCUPANCY HOURS: M-F 700 TO 1615, SAT 0 TO 0, SUN 0 TO 0

PRESENT TEMP: WINTER OCC 78.1 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: Education SPECIAL REQ. YES [] NO []

LOCATION: 2nd Floor (IDENTIFIED ON FLOOR PLAN [])

OCCUPANCY HOURS: M-F 700 TO 1615, SAT _____ TO _____, SUN _____ TO _____

PRESENT TEMP: WINTER OCC 78.3 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []

LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])

OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []

LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])

OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 181

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/19/91

BLDG.# 181
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
<p>BRICK GYPSUM BOARD</p>	1. OUTSIDE AIR FILM 2. _____ 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
<p>SHINGLES PLYWOOD AIRSPACE 4" Fiberglass Filler HARDWOOD CEILING AIRSPACE R-19 6 1/4" DROP CEILING</p>	1. OUTSIDE AIR FILM 2. _____ 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

PERSONNEL DOOR TYPE _____	BASEMENT [] SLAB [] CRAWL SPACE []
OVERHEAD DOOR TYPE _____	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO.

CALCULATED BY:

CHECKED BY:

DATE:

BLDG.# 181
ECO 2

OF

JW

12/18/91

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
	SEE SEE NOTE						

COMMENTS: ALL WINDOWS HAVE BEEN BOARDED & SEALED.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-8-97

BLDG.# 181
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Mens Room, 1 st Floor	168 °F
PROBLEMS:	

COMMENTS:

BLDG.# 181
ECO 5

MOTORS

MOTOR #	AHV #1	HP	10	PH	3/60Hz	RPM	1720
MODEL #	3N386-A	VOLTS	200 230 460	AMPS	27 13.5		29.4
SERIAL #	H5609406	PRESENT HR.	0	TO			2400
MFG	LEROY-SOMER (EXTRA DUTY)	REQUIRED HR.	0700	TO			1630
FRAME		EFF.	86%		PF=81%		
DESCRIPTION	BA? : TE 215T COMMENTS: INSULATION ON DUCTS (2'x2') 25' L NEED REPAIR, PIPE INSUL. OK. ECONOMIZER WAS "OFF" AT TIME OF SURVEY, WITH OA DAMPER "CLOSED." IT IS NOW "ON" WITH OA DAMPER FUNCTIONING PROPERLY.						

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____		_____
MFG	_____	REQUIRED HR.	_____	TO	_____		_____
FRAME	_____	EFF.	_____		_____		_____
DESCRIPTION	_____						

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____		_____
MFG	_____	REQUIRED HR.	_____	TO	_____		_____
FRAME	_____	EFF.	_____		_____		_____
DESCRIPTION	_____						

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: UC
CHECKED BY: _____
DATE: 12-31-91

BLDG.# 181
ECO 5

10+ HP MOTORS
MEASURED

MOTOR#	<u>AHV # 1</u>		PHASE A	PHASE B	PHASE C
LOCATION		KVAR	<u>4.7</u>		
MFG	<u>LEROY SOMER</u>	KVA	<u>7.4</u>		
MODEL #	<u>3N386-8</u>	KW	<u>5.8</u>		
SERIAL #	<u>85609406</u>	PF	<u>78.7</u>		
FRAME		HP	<u>10</u>		
HP	<u>10</u>	VOLTS	<u>204</u>	<u>204</u>	<u>Ø</u>
RPM	<u>1720</u>	AMPS	<u>21</u>	<u>21</u>	
PRESENT	<u>0</u> TO <u>2400</u>	PH			
REQ HR.		<u>200V</u>	<u>29.4 A . 3Ø 86% eff.</u>		

MOTOR #			PHASE A	PHASE B	PHASE C
LOCATION		KVAR			
MFG		KVA			
MODEL #		KW			
SERIAL #		PF			
FRAME		HP			
HP		VOLTS			
RPM		AMPS			
PRESENT		PH			
REQ HR.					
COMMENTS					

Silver Spoon

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 2/11/92

BLDG.# 181
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
105	2	4	34	F	ON	Y	N	1	N
101	6	4			ON	Y	N	1	N
107	20	4			ON	Y	N	4	N
108	20	4	34		ON	Y	N	4	N
110	24	4			ON	Y	N	4	N
117	80	4			ON	Y	N	10	N
212	7	4			ON	Y	N	1	N
211	2	4			ON	Y	N	1	N
201	6	4			ON	Y	N	1	N
202	6	4			ON	Y	N	1	N
209	1	4			ON	Y	N	1	N
103	8	4			ON	Y	N	1	N
104	2	4			ON	Y	N	1	N
102	3	2			ON	Y	N	1	N
121	3	4			ON	Y	N	1	N
106	12	4			ON	Y	N	1	N
107	5	4			ON	Y	N	1	N
111	14	4			ON	Y	N	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 2/19/92

BLDG.# 181
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
PAY AREA	15	4	34	F	ON	Y	N	3	N
LOBBY	20	4			ON	Y	N	4	N
ENTRY	2	2			ON	Y	N	1	N
TRAVEL AREA	25	4			ON	Y	N	4	N
JUMP RESERVE	25	4			ON	Y	N	4	N

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/11/92

BLDG.# 181
 EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
109	4	4			ON	Y	N	1	N
122	2	4			ON OFF	Y	N	1	N
123	2	4			OFF	Y N	N	0	N
120	2	4			ON	Y	N	1	N
119	4	4			ON	Y	N	1	N
118	20	4			ON	Y	N	2	N
113B	9	4			ON	Y	N	2	N
113A	6	4			ON	Y	N	1	N
114	9	4			ON	Y	N	2	N
116	8	4			ON	Y	N	2	N
117	12	4			ON	Y	N	2	N
115	9	4			ON	Y	N	2	N
307	2	4			ON	Y	N	1	N
305	4	4			ON	Y	Y	1	Y
304	2	4			ON	Y	Y	1	Y
303	2	4			ON	Y	Y	1	N
302	2	2			ON	Y	Y	1	Y
301	6	4			ON	Y	N	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

JOB Fl. McPherson/Fl. Gillem Energy Study
 PROJ # EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-18-91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 181 BLDG NAME: Union JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS 2
 BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
 SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. 1 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: 222 Floor Main AREA (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 0 TO 2400, SAT 0 TO 0, SUN 0 TO 0
 PRESENT TEMP: WINTER OCC 78.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 2 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: BASEMENT ROOM 6 (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 82.7 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 3 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: Room 7 (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. 4 FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: Room 2 (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 8 TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC 75 °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

228 people

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 181

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____


SCALE _____



RAY M. REESE
BASEMENT

□ = 4-34W

■ = ~~4~~ ELECTRIC HEATERS



NOTE: ROOM #6 IS UNBEARABLY HOT IN THE WINTER & TOO COLD IN THE SUMMER. THERE IS A CONSENSUS FEELING OF BEING TEMPERATURE UNCOMFORTABLE.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 181

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____

SCALE _____

LIGHT COUNT \Rightarrow ALL LIGHTS 4 BULB 34W FL.
200 + 50 \approx 250 + 90 MISSED \approx 300 lights

~~1 Refrig~~

~~1 Coffee Pot~~

~~4 PC~~

~~4 Printers~~

~~10 Radiators~~

UPPER LEVEL ~~NORTH WEST~~
NORTH WEST

80°F

PC'S = ~~TTTTT~~ TTTT TTT TTT TTT TTT |

PRINTERS = TTT | | | |

MAIN FRAMES = 11

DUMB STATIONS = 11

REFRIGERATORS = 1

TYPEWRITERS = TTT |

COPY MACHINE = 1

JAM BOXES = ∞

UPPER
N-E 79°F

UPPER
~~N~~ SOUTH
78°F

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 181

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 12/20/91

CHECKED BY _____ DATE _____

SCALE _____

~~BLDG 101~~ ~~ECCO~~ 12 DUCT SIZES

AHU #1 ⇒ 18" X 24" ZONE # 1
30" X 60" ZONE # 2
18" X 24" ZONE # 3

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 181


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 181

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____

SOME ROOMS ARE HOT.

SOME ROOMS ARE COLD

NO WINDOWS - NOT ENOUGH OUTSIDE AIR.

ROOM 6 SEVERAL COMPUTERS, HAS COMP. AC
UNIT, BUT NOT FUNCTIONING.

JOB 3105.000

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany


SHEET NO. _____ OF _____

CALCULATED BY [Signature] DATE 2/28/92

CHECKED BY _____ DATE _____

SCALE 1/8" = 1'-0"

HVAC
LOWER FLOOR



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY [Signature]


DATE 2/28/92

CHECKED BY _____

DATE _____

SCALE 1/8" = 1'-0"

HVAC
UPPER FLOOR



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 181

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____

SCALE _____

THE OUTSIDE AIR DUCTS FOR THE AHU'S IN THIS BUILDING WERE CLOSED AT TIME OF SURVEY RESULTING IN "STUFFY" OFFICE CONDITIONS AND EMPLOYEE IRRITABILITY AND DISCOMFORT FROM EXCESSIVE HEAT.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____

SPACE HEATERS

DAYTON ELECTRIC

MOD. 2E439

SER. 134624

208V

3000WATTS

10240 BTU

Room 1

- 8 DUMB TERMINALS
- 1 PC
- 1 ELEC. TYPEWRITER

Room 2

- 1 DUMB TERMINALS
- 3 PC'S
- 1 PRINTER
- 1 ELECTRIC TYPEWRITER
- 1 COFFEE POT

Room 3

- 3 PC'S
- 1 COPY MACHINE
- 2 PRINTERS
- 1 MINI MAIN-FRAME

Room 4

- 1 MINI MAIN-FRAME
- 12 DUMB TERM.
- 2 PC'S
- 1 LASER PRINTER
- 1 COFFEE POT

Room 5

- 8 PC'S
- 2 ELECTRIC T-WRITERS
- 1 DOT MATRIX

Room 6

- 3 MINI MAINFRAMES
- 4 PC'S
- 15 DUMB TERM.
- 2 ELECTRIC T-WRITERS
- 10 PRINTERS
- 1 COMPUTER AC UNIT - DOES NOT FUNCTION, SET UP TO SERVE ROOM 5.
- 1 FULL SIZE REFRIG.

Room 7


- 11 DUMB TERM
- 2 PRINTERS
- 2 PC'S
- 1 ELEC T-WRITERS
- 1 COFFEE POT
- 1 COPY MACHINE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

181




MCQUARY+PERFEX INC.
ACCU AIRCON-AIR-CONDENSER
SER # 4-PD00164-04
MOD # APD-007C-V-99
208/230V 3φ
0.33 HP. 2A
REF LINE NEEDED TO INSULATE ^{1/2"}~~3/4"~~
30' LONG.

CHILLER

TRAME
MOD # CGAA0806RD61CC4C4C311CKAR
SER # L82L07755

COMP. MOTOR 2-3φ 168A
COND MOTOR 2-3φ 25.4A 7.5HP. } 200-208V

4" w/ 2" BLK FOAM INSULATION. BAD 15' ON ELBOWS VALVE



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY Kc DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____



CWP1 MARATHON GENERAL ELECTRIC
 MOD # JN184TTDR7026BFW
 FM 184T SHP
 TYPE TDR-B 3Ø 230V 13.2A 1740RPM
 PUMP - FEDERAL PUMP
 RECORD # B68296-P1 UNIT # ZCKB-5-4

CWP2 MARATHON ELEC. 7.5HP 3Ø 3450RPM
 MOD # SN184TTDR7001BCN 230V 18.8A
 FM 184T
 TYPE TDR-BE
 PUMP FEDERAL PUMP
 REC # B68296-P2 UNIT # ZCGB-71/2-2

HWP3 MARATHON ELEC. 3Ø 1745RPM 1.5HP
 MOD # NVM1ASTTDR7663CH 208V 1.15A
 FM 145JM
 TYPE TDR 78.5% eff.
 PUMP FEDERAL PUMP
 REC # B68296-P3 UNIT # 11/2CG-11/2

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 181

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____

SCALE _____

FAN COILS
 CEILING HEIGHTS ⇒ 18' UPPER LEVEL 10' UC BACK (SOUTH)
 WALL CONSTRUCTIONS L 8' LOWER " DROP
 LIGHTING CONTROL 3rd floor X
 ROOF Construction (P/E New) X
 DUCT SIZE L
 Chilled Cooling ONLY; Nameplate L X

DUCT SIZE FOR MAIN AHU

20x20 RETURN

12x24 OUTSIDE AIR

10x17 SUPPLY (ZONE #1)

12x12 " (ZONE #3)

~~12x12~~ 16x24 " (ZONE #2)

SMALL AHU (RM 11)

16x24 SUPPLY

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KCC DATE 12-18-91


CHECKED BY _____ DATE _____

SCALE _____

BLDG 181

- HEATING THROUGH STM FROM CENTRAL HEATING PLANT 160
- COOLING. CHILLER (AIR COOLED)
- 1 AHUS ON NORTH-WEST CORNER.

AHU-1



THIS A MULTIZONE SYSTEM 2 ZONES (OPP?)

EXH. FAN US ELECTRIC 2HP 230V 6.6A
 145T 80% 1725 RPM
 F-88803-05-259

DUCT IN 18X8 BAD 1" FG. FOIL TEMP 60' CRAW SPACE
 OVER HALF OF DUCT INSL. MISSING 60'.

FAN MOTOR BALDOR.
 CAT # 143218T 5HP 1725RPM 3Ø
 FRM. 124T 81.5% 14.2A 208V

CONTROL DOES NOT WORK - TOO COLD IN SUMMER
 - TOO HOT IN WINTER

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

181



CHILLER

TRANE

CGAA086RDS1CC4C311 CLEAR

LOT'S OF PCR

2' PLENUM ON 2nd FLOOR

NO WINDOWS

FANS EVERYWHERE

HOT

GETS VERY UNCOMFORTABLE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CND DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____

BASEMENT


- 1 MICROWAVE
- 1 CANDY MACHINE
- 2 COFFEE MACHINES

- 1 FISH SINK
- 2 THERMOPOTS
- 19 PCs
- 12 PRINTERS
- 1 COPY MACHINE


- 10 PCs
- 9 PRINTERS
- 1 TV
- 1 COPY
- 2 MINI MAINFRAMES
- 1 LARGE ENVELOPE MACHINE
- 1 REFRIG (FRIG)
- 1 COFFEE POT
- 10 DUMB TERMINALS

- ELEC. TW
- 7 PC
- COPY
- MINI
- 11 PC
- 17 DT

UPPER LEVEL N.E.



7 PLAN



2 PIPING DIAGRAM
NO SCALE


Value Tag Assembly


LEGEND


- ① CUM. PUMP - FEDERAL COAR MODEL ECK8-5-4
200 GPM STEAM - 5HP - 4175D RPM
- ② CUM. PUMP - FEDERAL COAR MODEL ECG-8-71E-2
823 GPM @ 725 RPM - 7 1/2 HP - 4 1/2" DIA
- ③ CUM. PUMP - FEDERAL COAR MODEL 11E CG-11E-4
213 GPM @ 600 RPM - 1 1/2 HP - 1750 RPM
- ④ H.C. TRACO MODEL G4608 - 4935 45 GPM - 170 W - 1/2" OUT
COLD WATER PUMP - FEDERAL VAC-820-2 90 RPM @ 20 FT HD
1/2" DIA
- ⑤ AIR SEPARATOR TRACO MODEL NCK-125FAC - BTR50 200 GPM
AIR SEPARATOR TRACO MODEL NCK-125FAC - 40 GALS.
- ⑥ EXR TANK - TRACO MODEL SD-400-V-3 125FAC - 40 GALS.
- ⑦ EXR TANK - TRACO MODEL SD-400-V-3 125FAC - 15 GALS.
- ⑧ 5TH. CONTROL VA. HANETWELL VSD1192.456-2
- ⑨ AIR SEPARATOR - TRACO AIR-SEPAR 2" ID 100-12
- ⑩ INVERTED BUCKET TRAP w/HEAT WASHING & SPRAY CO.
- ⑪ GATE VALVE
- ⑫ CHECK VALVE
- ⑬ PRESSURE GAUGE w/ COCK

Tag Number	Size	System	Position for season
①	4"	C. H. V. 3. From chiller	Close for heat - Open for Cool
②	4"	C. H. V. 3. to chiller	Close for heat - Open for Cool
③	4"	Dual temperature	Open for heat and Cool
④	4"	Dual temperature	Open for heat and Cool
⑤	2"	Hot water supply to building	Open for heat - Close for Cool
⑥	2"	Temperature Apply from condenser to pump thru building	Open for heat - Close for Cool
⑦	2"	Temperature return from building	Open for heat - Close for Cool
⑧	2"	Modulating steam control valve	Modulates during heating
⑨	2"	Steam supply shut off	Open for heat - Close for Cool
⑩	3/4"	Make up water for system from expansion tank	Open at all times

BUDS 181








1 MECHANICAL ROOM PLAN
SCALE 1/2" = 1'-0"

BLDG 181




2 PIPING DIAGRAM
NO SCALE

VALVE TAG SCHEDULE

Tag Number	Size	System	Position for SHUTDOWN
1	4"	C. H. W. S. from chiller	Close for heat - Open for cool
2	4"	C. H. W. S. to chiller	Close for heat - Open for cool
3	4"	Dual temperature	Open for heat and cool
4	4"	Dual temperature	Open for heat and cool
5	2"	Hot water supply to building	Open for heat - Close for cool
6	2"	Temperature supply from sensor to pump thru building	Open for heat - Close for cool
7	2"	Temperature return from building	Open for heat - Close for cool
8	2"	Modulating steam control valve	Modulates during heating
9	2"	Steam supply shut off	Open for heat - Close for cool
10	5/4"	Make up water for system from expansion tank	Open at all times

GENERAL NOTE: ALL VALVES RETED FOR 150# STEAM PRESSURE

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100



BLDG 181

① MECHANICAL ROOM PLAN
 M-1 SCALE 1/2" = 1'-0"

Tag Num

- ①
- ②
- ③
- ④
- ⑤
- ⑥
- ⑦
- ⑧
- ⑨
- ⑩

GENE

BUILDING 184

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/19/91

BLDG.# 184
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. _____ 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. _____ 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

PERSONNEL DOOR TYPE _____	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB []
	CRAWL SPACE []

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____
CALCULATED BY: KCL
CHECKED BY: _____
DATE 12-19-21

BLDG.# 184
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
EAST MECH. ↓	3 1/2"	100'	HW	NA	50°	FG. W/F	1"	GOOD
	3 1/2"	150'	CW	NA	50	↓	↓	GOOD

COMMENTS: UPPER LEVEL PIPE INSULATION IN GOOD CONDITION - ALL AHC ARE GOOD COND.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
 EMC # 3105.000

JOB
 PROJ.#
 SHEET NO.
 CALCULATED BY:
 CHECKED BY:
 DATE

BLDG.# 184
 ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
ATC ATU 5	24 X 12	□	NA	65	FG W/F	1 1/2" R.3.8	GOOD
AHU-10	*						

COMMENTS: ALL IN GOOD CONDITION UNLESS SPECIFIED IN NOTE

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. OF
CALCULATED BY: JW
CHECKED BY:
DATE: 12/19/91

BLDG.# 184
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
140	SINGLE	SLIDING	WOOD	S	NONE	BLINDS	40 X 77
19	"	"	"	E	"	"	"
17				N	"		
18				W	"		
INSIDE AREA							
40	"	"	"	N	"	"	"
40				S	"		
20				E	"		
6				W	"		

ZONE

3
2
1
4

3
1
4
2

COMMENTS: WINDOWS ARE OLD & WOODEN BUT INFILTRATION IS LOW TO MEDIUM

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/19/91

BLDG.# 184
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	FAIR (OK)	LOW	N SEW	40 x 77	174
D	BAD	VERY HIGH	N (STAIRS)		1
D	BAD	VERY HIGH	E (PORCH) ADDITION		1

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

BLDG.# 184
ECO 4

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/19/91

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
1 ST FLOOR EAST WING MEN'S	122°F
2 ND FLOOR WEST WING MEN'S	134°F

PROBLEMS:

COMMENTS:

BLDG.# 184
 ECO 5 _____

MOTORS

MOTOR #	<u>1</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>178101</u>	VOLTS	<u>200</u>	AMPS	<u>15.8</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>BELL & GOSSETT</u>	REQUIRED HR.	<u>7:30</u>	TO	<u>4:30</u>		
FRAME	<u>184JM</u>	EFF.					
DESCRIPTION	<u>DTW MOTOR</u>	COMMENTS					
MOTOR #	<u>2</u>	HP	<u>1/3</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>M90062</u>	VOLTS	<u>115</u>	AMPS	<u>6</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>BELL & GOSSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>BOILER HW CIR. PUMP MTR.</u>	COMMENTS					
MOTOR #	<u>AHU-2</u>	HP	<u>1</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>M3116T</u>	VOLTS	<u>208</u>	AMPS	<u>3.6</u>		
SERIAL #	<u>35801-87</u>	PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>BALDOR</u>	REQUIRED HR.		TO			
FRAME	<u>145T</u>	EFF.					
DESCRIPTION		COMMENTS	<u>GOOD COND.</u> <u>1ST FL CLASS ROOM</u>				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE: 12/19/91

BLDG.# 184
ECO 5

MOTORS

MOTOR #	AHU 1	HP	1	PH	3	RPM	1740
MODEL #	3N244B	VOLTS	200	AMPS	4.2		
SERIAL #		PRESENT HR.	0	TO	2400		
MFG	DOERR ELEC.	REQUIRED HR.		TO			
FRAME	143T	EFF.					
DESCRIPTION		COMMENTS	1ST FL SEMINAR RM				
MOTOR #	AHU 6	HP	1.5	PH	3	RPM	1745
MODEL #	KVL145TTDR7926ACW	VOLTS	200	AMPS	5.5		
SERIAL #		PRESENT HR.	0	TO	2400		
MFG	MARATHON	REQUIRED HR.		TO			
FRAME	145T	EFF.	78.5				
DESCRIPTION		COMMENTS	2ND R.N.E.				
MOTOR #	AHU-3	HP	2	PH	3	RPM	1740
MODEL #	WVA145TTDR5831AA	VOLTS	208	AMPS	6.2		
SERIAL #		PRESENT HR.	0	TO	2400		
MFG	MARATHON	REQUIRED HR.		TO			
FRAME	145T-80	EFF.	81.5				
DESCRIPTION		COMMENTS					

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study

PROJ. # EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: KC

CHECKED BY: _____

DATE: 12-18-91

BLDG. # 184

ECO 7

HW PUMPS

CIRCULATION PUMPS

RPM	FT HD	GPM	MODEL #	SERIAL #	MFG.	HOURS		PUMP #
						REQUIRED	PRESENT	
1725	60	16.8	ZBBBF		BELL & GOSSETT	20-4:30	0-2400	1 DTW
1750	15	42	11/2AAAS/88F		"	7:30-4:30	0-24	2 HW BLR CIR.

PUMP MOTORS

VOLTS	AMPS	PHASE	MODEL #	SERIAL #	MFG.	HOURS		FRAME	MOTOR #
						REQUIRED	PRESENT		
200	15.8	3	178101-	S HP	BELL & GOSSETT	1725	SAME AS ABOVE	184JM	1
115	6	1	M60062	1/3 HP	"	1725	"	"	2

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 2/12/92

BLDG.# 184
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
TOTAL BASEMENT	100	2	34	F	ON	N	N	20	N
1	2	4	34	F	ON	Y	N	1	N
2	3	4			ON	Y	ON	1	Y
3	4	4			ON	Y	N	2	Y
4	4	4			ON	Y	N	1	N
5	2	4			ON	Y	N	1	N
6	2	4			ON	Y	Y	1	N
7	10	4			ON	Y	N	2	Y
8	4	4			OFF	Y	N	1	N
9	1	4			OFF	Y	Y	1	N
10	24	4			ON	Y	N	4	N
11	12	4			ON	Y	N	3	N
12	$\frac{3}{1}$	$\frac{4}{1}$	$\frac{34}{200}$	$\frac{F}{I}$	ON	Y	N	3	N
13	3	1	200	I	ON	Y	N	3	N
14	3	4	34	F	ON	Y	N	1	N
15	2	4			ON	Y	Y	1	Y
16	2	4			ON	Y	N	1	N
17	3	4			ON	Y	Y	1	N

OF EXIT SIGNS - _____

COMMENTS: FROM LIGHTING PLANS & SURVEY

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 2/12/92

BLDG.# 184
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
18	2	4	34	F	ON	Y	Y	1	Y
19	3	4	34	F	ON	Y	Y	1	N
20	3	4			ON	Y	N	1	N
21	2	4			ON	Y	Y	1	Y
22	$\frac{3}{1}$	4 200	$\frac{34}{200}$	$\frac{F}{I}$	ON	Y	N	3	N
23	3	1	200	I	ON OFF	Y	N	3	N
24	36	4	34	F	ON	Y	N	4	N
25	15	4			ON	Y	N	3	N
26	14	4			ON	Y	N	2	N
27	$\frac{3}{1}$	$\frac{4}{1}$	$\frac{34}{200}$	$\frac{F}{I}$	ON	Y	N	3	Y
28	2			F	ON	Y			
A	40	34		F	ON	Y	N		
B	40	34			ON	Y			
C	26	34			ON	Y			
D	3	200		I	OFF	Y			
E	42	34		F	ON	Y			
ATTIC	30	100		I	ON	Y			

2nd floor

~~ATTIC~~

OF EXIT SIGNS - _____

COMMENTS: FROM LIGHTING PLANS & SURVEY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ # EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/19/91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 184 BLDG NAME: _____ JOB: 3105.000
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
BUILDING MANAGER NAME: _____
PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] - ZONE NO'S. _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0700 TO 1630, SAT CLOSED, SUN CLOSED
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 184

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____



SCALE _____

N →

2nd FLOOR



BASEMENT



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 184

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____


CHECKED BY _____ DATE _____

SCALE _____

LIGHTS



- 4-34WF
- FAN COIL



① APPLIANCE HEAT 1 COMPUTER & PRINTER / EVERY 15ft²

② THIS ROOM STAYS 70° DUE TO A COMPUTER ROOM AIR CONDITIONER

③ HALLWAY - BOTH EAST & WEST DOORS HAVE VERY LARGE AIR GAPS

Ⓐ NORTH & SOUTH EXIT DOORS HAVE A STAIRWELL (OPEN AREA)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 184

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____


CHECKED BY _____ DATE _____

SCALE _____

LIGHTS



- 4-34WF
- FAN COIL



① APPLIANCE HEAT 1 COMPUTER & PRINTER / EVERY 15ft²

② THIS ROOM STAYS 70° DUE TO A COMPUTER ROOM AIR CONDITIONER

③ HALLWAY - BOTH EAST & WEST DOORS HAVE VERY LARGE AIR GAPS

Ⓐ NORTH & SOUTH EXIT DOORS HAVE A STAIRWELL (OPEN AREA)

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 184

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____



SCALE _____

N →

2nd FLOOR



BASEMENT




E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105 - 200
SHEET NO. _____ OF _____
CALCULATED BY DG DATE 2/6/02
CHECKED BY _____ DATE _____
SCALE BC DS - 1/8"

2nd FLOOR



JOB 3105,000

SHEET NO. _____ OF _____

CALCULATED BY DG DATE 2/6/92



CHECKED BY _____ DATE _____

SCALE BCDG - 184

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

1st FLOOR



4

2

3

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY JG DATE 2/6/92


CHECKED BY _____ DATE _____

SCALE BC DS - 1/8"

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BASMENT




E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____



WINDOWS



FLOOR TO FLOOR 12"

FEW PC 2

SOME WINDOW AC 2



GET PICTURES

BLDG.# 181
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
D	2 METAL DOOR UNITS	VERY HIGH	N	60 x 83	2
D	NONE	HIGH	E	34 x 80	1

FRONT 2
DOORS ①
②

COMMENTS: ① 1/2" AIR GAPS BETWEEN AND UNDER MAIN FRONT
DOORS. WEATHER STRIPPING NEEDS REPLACING. THIS AREA WOULD
SEEM TO BE A GOOD PLACE FOR AN AIR LOCK (FOURIER.)
② THIS DOOR LEADS TO EAST SIDE PATIO AREA. IT
HAS 1/2" AIR GAP AT BOTTOM.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY RC DATE 12-19-71

CHECKED BY _____ DATE _____


SCALE _____

ECO-6 BLDG 1824


AHU-1



AHU-5




AHU-2




AHU-6



AHU-8 MARATHON, KVK1A5TDR79 (SAME AS 9 OR 10)



AHU-4 CENTURY



8-331262-03

FM N145 30 200V 1745 2HP
6.6A

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE _____

AHU-3

20"x18"

NEED INSL. REPAIR @ OA DAMPER, DAMPER REMOVED!




AHU-9

MARATHON

KVK 145TTDR7926ACW

3φ 200V 1745; 1.5HP 5.5A
78.5%



AHU-10

24"x18"

MARATHON KVK 145TTDR7926ACW

3φ 200V 1745 RPM 1.5HP 5.5A

SAME DUCT SIZE AS 9 78.5%

AHU-7

OA DUCT 18"x18"

MARATHON

SAME AS 10

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KU DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE _____

ANU-5 BALDOR CAT 3197T SPEC 35B01-754
FM. 145T 2HP 208V 6.8A 3Ø 1725
78.5% eff. 2ND FL. N.W.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY KC DATE 12-19-91
CHECKED BY _____ DATE _____
SCALE _____

BLDG 184



BELL & COSSETT 5 HP

DUAL TEMP PUMP SEE BARBER COLMAN CONTROL DWG.

ACTUATOR_{FOR}V-1 IS NOT CONNECTED. (LINKAGE)
" — " V-2 " — " — " — "

EQUIPMENT IN THIS MECH

- 1- DTW P
- 1- HW BOILER

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____


CALCULATED BY KC DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE _____

BLDS 184

LISKEY-AIR
SERVE COMPUTER ROOM
5 HP 21.4A 208V 3Ø



AWU PACKAGE GAS HEAT DX COIL.
CARRIER, FOR BASEMENT
NEED INSL 20"X20-15"
ACCU LARKIN FOR LISKEY AIR

- PERIMETER RADIATION ON EXTERIOR ZONES
- 2 PIPE FAN COIL AT ENTRANCE
-

BUILDING 187

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/18/91

BLDG.# 187
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
W WASHROOM (NE CORNER)	133°F

PROBLEMS:

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 187

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE _____

CHECKED BY _____ DATE _____

SCALE 12/18/91

SOUTH EAST CORNER HEATER (GAS BLOW-THROUGH)

JANITROL UNIT HEATER - GAS FIRED (NATURAL)

MODEL SIZE UCS100-55

S# 055960979

INPUT - 100,000 BTU/HR

OUTPUT - 80,000 BTU/HR

AIR HANDLER FOR OFFICE & BREAKROOM

NORDYNE

10.3 ~~10~~ AMP

1φ

140,000 BTU/HR INPUT

(HEATING ONLY SYSTEM)

NAT. GAS

MANUFACTURERS

~~AS~~ # 3175208806

MOD # MFYHX140A21

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY K C DATE 12-18-91

CHECKED BY _____ DATE _____

SCALE _____



BLDG 187

N

EXIT FAN . 115V 1/2 HP.

BATHROOM

UNIT HEATER

DHW

TINT ROOF NO. INSL

WINDOW AC

FEDDERS

115V . 1Ø 7.5A 850W
SER.# LV439500 3204

FRONT

AC WINDOW
SAME AS OTHER

BUILDING 200


EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 1/13/92

BLDG.# 200
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
<p>FROM PLATE A-28</p> 	<ol style="list-style-type: none"> 1. OUTSIDE AIR FILM 2. ● 3. G.W.B. WALL 4. R- 5. 6. WHITE OAK VENEER 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
<p>FROM PLATE A-43</p> 	<ol style="list-style-type: none"> 1. OUTSIDE AIR FILM 2. GRAVEL 3. BUILT UP ROOF 4. INSULATING CONCRETE 5. INSULATING BOARD 6. CONC. ROOF DECK STRUCTURE 7. INSIDE AIR FILM

PERSONNEL DOOR TYPE _____	BASEMENT [] SLAB [] CRAWL SPACE []
OVERHEAD DOOR TYPE _____	

COMMENTS: ROOF AVERAGES $U = .05$, $R \approx 20$

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 200


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 1/13/92

CHECKED BY _____ DATE _____

SCALE _____



APPROX SQ. FOOT

LOCATE
ANYTHING
MISSING

<u>SECTION</u>	<u>FLOOR</u>	<u>SQ.FT. (APPROX)</u>
2	BASEMENT	15,516 ft ²
1	BASEMENT	19,044 ft ²
3	BASEMENT	19,044 ft ²

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Bldg 200

- > CHECK CONTROL ON HW BOILER, HW SETPOINTS
- > HOW MUCH IS HW BOILER OPERATING
- > TAKE TEMPS IN & OUT @ CHILLERS, BOILERS & HEAT PUMP
- >
- > TRY & GET IDEA IF AHU'S & PUMPS VARY w/ PRESSURE
- > MEASURE CA CFM DOES MIN & MAX CFM WORK, HOW ARE THEY CONTROLLING?
- > DISCHARGE TEMPS OFF OF COILS
- > CHW SETPOINTS
- > CNW SETPOINTS
- > S.O.P. ON CHILLERS
- > FLOW METERS ON CHILLERS? CHW & HW?
- > BLDG KW? TWO METERS?
- = LOG KW HOURLY (30 MINUTE) BLDG
- > LOG KW " (") CHILLERS
- >

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

multiple domestic hot water heaters
MCC
- 13+16 100% OA

Additional ECO's Bldg 200

- Chiller optimization
- Run most efficient chillers

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF 1/2/92
CALCULATED BY: JW
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Basement (south) Men's Room	110°F
2 nd Floor West Ctrl. Rm.: Men's	113°F
1 st Flr. N. Janitors	140°F
Basement N.	135°F
2 nd Flr. N.	102°F
3 rd Flr. N. Rm 313	104°F
3 rd Flr. W. Rm 321	107.7°F
PROBLEMS:	

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Blus Zoo

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

BACCAST

TYPICAL —


ADVANCE

CAT NO. VQM 2540-2-TP

277 VOLT

. 35 AMPS Standard Lamps

. 31 AMPS energy saving lamps



LEGEND

- ⊗ - Dial type light switch
- ⌊ - Flip type light switch
- - - - - Partition
- ∧ - Door

DIAL TYPE LIGHT SWITCH

OPERATING INSTRUCTIONS

ON: Full Section - Turn on dial to 1; Press in; hold while turning to 12

Single Section - Turn on dial to desired light bank; Press in

OFF: Follow directions as above using OFF dial

- Bank 1 - Director
- Bank 1 - Director
- Bank 2 - FA
- Bank 2 - FA/HRD
- Bank 3 - PE/HRD
- Bank 4 - PB
- Bank 5 - PB
- Bank 6 - FA
- Bank 7 - HRD
- Bank 8 -
- Bank 9 -
- Bank 10 -

SAMPLE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

BLDG-200

VAV STOPS AT 74°F INTERIOR
EXTERIOR HAS HEATING COILS ALSO

AHU 14&15 REG AIR HANDLERS
13&16 FRESH AIR

40W TASK LIGHT 1 LAMP 2 PER CUBICAL

VAV (AS EXPLAINED BY DEH)

MAX COOL SA ONLY
SA + PLENUM
FAN + PLENUM
FAN + HEATING COIL } PERIMETER ONLY

T/STAT IS ASPIRATOR TYPE PNEUMATIC

VAV

TEMPMASTER CORP.
1222 OZARK ST.
N. KANSAS CITY, MO 64116
816/421-0723

FAN TERMS TYRES HFB, HFBE, HFBW
INTER TERMS AV, S, HSE, HSW, CO

BLDG #200

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

W # of CUBICALS

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 1/30/92

CHECKED BY _____ DATE _____

SCALE _____

BASEMENT MEZZANIE	40	
1 ST FLOOR SEG. 1	120 120	} 505
1 ST FLOOR SEG. 2	110 110	
1 ST FLOOR SEG. 3	275	
2 ND FLOOR SEG. 1	200	
2 ND FLOOR SEG 2	175	} 375
2 ND FLOOR SEG 3	260	

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Bldg 200

<u>Section</u>		<u>Cubicle count</u>
BSMT	SEG 1	110
BSMT	SEG 2	103
BSMT	SEG 3	170
3rd	SEG 1	195
3rd	SEG 2	104
3rd	SEG 3	244

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

CH - 1

Chiller

YORK

~~Chiller Model # ~~YT~~ YT L3 L3 E3 CW A~~

0.65 kW/ton

~~Compressor Model YTH126~~

Serial Y

Control 115/1 ϕ /60 15 A

oil pump 3/4 HP 460/3/60 1.68 FLA

oil heater 115/1/60 8 FLA

BLDG.# 200
ECO 5

MOTORS

MOTOR #	<u>HWP-1 + 2</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1740</u>
MODEL #	<u>6-350324-11</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>9.2-8.6/4.3</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>S182JM</u>	EFF.	_____				
DESCRIPTION	_____	COMMENTS	<u>#2 operating inlet 10 psig outlet 27 psig</u>				

MOTOR #	<u>1, 2, 3</u>	HP	<u>15</u>	PH	<u>3</u>	RPM	<u>3490</u>
MODEL #	<u>6-350390-42</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>42-38/19</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>S215JM</u>	EFF.	_____				
DESCRIPTION	<u>Domestic Cold water</u>	COMMENTS	<u>inlet 40 psd outlet 50 psig > for all 3 pumps in parallel #1 operational</u>				

MOTOR #	<u>HWP-34</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>3480</u>
MODEL #	<u>6-350381-10</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>15-13/6.5</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>S182JM</u>	EFF.	_____				
DESCRIPTION	_____	COMMENTS	<u>in parallel w/ HWP-3 operating</u>				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5

MOTORS

MOTOR #	<u>HWP-3</u>	HP	<u>1.5</u>	PH	<u>3</u>	RPM	<u>1745</u>
MODEL #	<u>8-350320-01</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>5.0-5.2/2.8</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>? JM</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>not running</u>						
MOTOR #	<u>HWP-5</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>3400</u>
MODEL #	<u>6-350381-10</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>15-13/6.5</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>S182 JM</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>operating / parallel</u>						
MOTOR #	<u>HWP-6</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1730</u>
MODEL #	<u>6-350324-10</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>10-9/4.5</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>S182 JM</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>off</u>						

BLDG.# 200
 ECO 5

MOTORS

MOTOR #	<u>HWP-7</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>3480</u>
MODEL #	<u>6-350381-10</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>15-13/6.5</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>5182 JM</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>operating</u>						
MOTOR #	<u>8-35 HWP-8</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>3450</u>
MODEL #	<u>8-350378-01</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>9-8.6/4.3</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>N145 JM</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>off</u>						
MOTOR #	<u>HWP-9</u>	HP	<u>7.5</u>	PH	<u>3</u>	RPM	<u>3460</u>
MODEL #	<u>6-350384-45</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>21-18.6/9.3</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	<u>Century</u>	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	<u>5184 JM</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>operating / same Run as 6</u>						

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5 _____

MOTORS

MOTOR #	<u>HWP-10</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>3480</u>
MODEL #	<u>6-350381-10</u>	VOLTS	<u>200-230/460</u>		AMPS	<u>15-13/6.5</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Contorx</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>S182JN</u>	EFF.	_____				
DESCRIPTION	COMMENTS <u>off / same Run as #9</u>						
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	
FRAME	_____	EFF.	_____				
DESCRIPTION	COMMENTS _____						
MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	
FRAME	_____	EFF.	_____				
DESCRIPTION	COMMENTS _____						

BLDG.# 700
 ECO 5

MOTORS

MOTOR #	<u>CP-4</u>	HP	<u>7.5</u>	PH	<u>3</u>	RPM	<u>1740</u>
MODEL #	<u>6-350330-01</u>	VOLTS	<u>200-230/460</u>	AMPS	<u>22-21/10.5</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>Century</u>	REQUIRED HR.		TO			
FRAME	<u>S213 JM</u>	EFF.	<u>—</u>				
DESCRIPTION	COMMENTS						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 5

10+ HP MOTORS
MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>1</u>			
DESCRIPTION	<u>AHU #1 SUPPLY</u>	<u>472</u>	<u>470</u>	
MFG	<u>West.</u>	<u>17.8</u>	<u>18.2</u>	
MODEL #	<u>TBEC</u>	<u>6.3</u>	<u>38.3 Hz</u>	
SERIAL #	<u>PE JH008</u>	<u>8.9</u>		
FRAME	<u>286T</u>	<u>10.9</u>		
HP	<u>30</u> RPM _____	<u>58.7</u>		
VOLT	<u>208</u>	% MOTOR SPEED _____ %		
AMPS	<u>25</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS _____				
MOTOR#	<u>2</u>			
DESCRIPTION	<u>AHU #1 RETURN</u>	<u>469</u>	<u>473</u>	
MFG	<u>G.E.</u>	<u>7.4</u>	<u>7.6</u>	
MODEL #	<u>SK215BC205</u>	<u>2.0</u>	<u>33.8 Hz</u>	
SERIAL #	<u>PE JH013 ("6-pack")</u>	<u>3.40</u>		
FRAME	<u>215T</u>	<u>3.9</u>		
HP	<u>10</u> RPM _____	<u>50</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>—</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS _____				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY:
 CHECKED BY:
 DATE:

BLDG.# 200
 ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>3</u>			
DESCRIPTION	<u>AHU # 2 SUPPLY</u> VOLTS	<u>225</u>	<u>225</u>	
MFG	<u>Reliance</u> AMPS	<u>14.4</u>	<u>14.3</u>	
MODEL #	<u>P28G03117-G10-UM/NO2836</u> KW	<u>2.5</u>		
SERIAL #	_____ KVAR	<u>2.6</u>		
FRAME	<u>284T</u> KVA	<u>3.6</u>		
HP	<u>25</u> RPM <u>1765</u> PF	<u>69</u>		
VOLT	<u>230/460</u>	% MOTOR SPEED _____ %		
AMPS	<u>64/32</u>	PRESENT _____	TO _____	
EFF.	<u>87.5</u>	REQ HR. _____	TO _____	
COMMENTS	_____			
MOTOR#	<u>4</u>			
DESCRIPTION	<u>AHU # 2 RETURN</u> VOLTS	<u>470</u>	<u>473</u>	
MFG	<u>General Electric</u> AMPS	<u>14</u>	<u>13.8</u>	
MODEL #	<u>5K 215 BC 205</u> KW	<u>7.2</u>		
SERIAL #	_____ KVAR	<u>4.8</u>		
FRAME	<u>215T</u> KVA	<u>8.8</u>		
HP	<u>10</u> RPM <u>1740</u> PF	<u>82.8</u>		
VOLT	<u>230/460</u>	% MOTOR SPEED _____ %		
AMPS	<u>24/12</u>	PRESENT _____	TO _____	
EFF.	<u>85.5</u>	REQ HR. _____	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CEL
CHECKED BY: _____
DATE: 1/21/92

BLDG.# 200
ECC 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>5</u>			
DESCRIPTION	<u>AHU # 3 SUPPLY</u>	<u>468</u>	<u>471</u>	
MFG	<u>Westinghouse</u>	<u>16</u>	<u>20</u>	
MODEL #	<u>TBFC</u>	<u>5.5</u>		
SERIAL #	<u>PE KA003</u>	<u>9.6</u>		
FRAME	<u>286 T</u>	<u>11.2</u>		
HP	<u>30</u> RPM _____	<u>48</u>		
VOLT	<u>208</u>	% MOTOR SPEED <u>35 #2</u>		
AMPS	<u>30</u>	PRESENT _____	TO _____	
EFF.	_____	REQ HR. _____	TO _____	
COMMENTS	<u>MAX OA ACTUATOR BROKEN</u>			
MOTOR#	<u>6</u>			
DESCRIPTION	<u>AHU # 3 RETURN</u>	<u>468</u>	<u>471</u>	
MFG	<u>G.E.</u>	<u>8.8</u>	<u>9.1</u>	
MODEL #	<u>5K254B1205D2</u>	<u>2.6</u>		
SERIAL #	<u>PE AK012A</u>	<u>4.4</u>		
FRAME	<u>254T</u>	<u>5.2</u>		
HP	<u>15</u> RPM _____	<u>51.8</u>		
VOLT	<u>230</u>	% MOTOR SPEED <u>33.50 #2</u>		
AMPS	<u>15</u>	PRESENT _____	TO _____	
EFF.	_____	REQ HR. _____	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.

DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 1/21/91

BLDG.# 200
 ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
7				
DESCRIPTION	AHU #4 SUPPLY	VOLTS	460	472
MFG	West	AMPS	17	16.4
MODEL #	TBFC	KW	4.3	32.3 Hz
SERIAL #	PE KBO0514	KVAR	8.5	
FRAME	286T	KVA	9.4	
HP	30 RPM	PF	46	
VOLT	208	% MOTOR SPEED		
AMPS	30	PRESENT		TO
EFF.		REQ HR.		TO
COMMENTS				

MOTOR#		PHASE A	PHASE B	PHASE C
8				
DESCRIPTION	AHU #4 RETURN	VOLTS	468	470
MFG	G.E.	AMPS	12	12
MODEL #	SK215BC205	KW	3.8	44.4 Hz
SERIAL #	PEJ4001A ("6-pk.")	KVAR	5.2	
FRAME	215T	KVA	6.4	
HP	10 RPM	PF	57	
VOLT	230	% MOTOR SPEED		
AMPS	10 A.	PRESENT		TO
EFF.		REQ HR.		TO
COMMENTS				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CEL
CHECKED BY: _____
DATE: 1/21/92

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>9</u>			
DESCRIPTION	<u>AHU # 5 SUPPLY</u>	<u>471</u>	<u>468</u>	
MFG	<u>Westing.</u>	<u>22.6</u>	<u>23.2</u>	
MODEL #	<u>TBFC</u>	<u>7.6</u>		
SERIAL #	<u>PEJH006</u>	<u>12.3</u>		
FRAME	<u>324 T</u>	<u>14.4</u>		
HP	<u>40</u> RPM _____	<u>51.7</u>		
VOLT	<u>230</u>	% MOTOR SPEED <u>34.7</u> %		
AMPS	<u>30</u>	PRESENT _____	TO _____	
EFF.	_____	REQ HR. _____	TO _____	
COMMENTS	_____			
MOTOR#	<u>10</u>	PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>AHU # 5 RETURN</u>	<u>466</u>	<u>470</u>	
MFG	<u>G.E.</u>	<u>10</u>	<u>10</u>	
MODEL #	<u>SK254 BC 206</u>	<u>2.8</u>		
SERIAL #	<u>PE KA005 A</u>	<u>4.9</u>		
FRAME	<u>254 T</u>	<u>5.9</u>		
HP	<u>15</u> RPM _____	<u>50</u>		
VOLT	<u>230</u>	% MOTOR SPEED <u>36</u> %		
AMPS	<u>15</u>	PRESENT _____	TO _____	
EFF.	_____	REQ HR. _____	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. OF
CALCULATED BY: CEL
CHECKED BY:
DATE: 1/21/92

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>11</u>			
DESCRIPTION	<u>AHU # 6 Supply</u>	<u>469</u>	<u>472</u>	
MFG	<u>Westinghouse</u>	<u>19.8</u>	<u>19.3</u>	
MODEL #	<u>TBFC</u>	<u>14.8</u>		
SERIAL #	<u>PE KBO07m</u>	<u>2.4</u>		
FRAME	<u>324T</u>	<u>15.1</u>		
HP	<u>40</u> RPM _____	<u>98.7</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>40</u>	PRESENT _____	TO _____	
EFF.	_____	REQ HR. _____	TO _____	
COMMENTS	_____			
MOTOR#	<u>12</u>			
DESCRIPTION	<u>AHU # 6 RETURN</u>	<u>468</u>	<u>470</u>	
MFG	<u>G.E.</u>	<u>11.5</u>	<u>13.1</u>	
MODEL #	<u>SK254BC205</u>	<u>1.8</u>		
SERIAL #	<u>PE KA009A</u>	<u>2.3</u>		
FRAME	<u>254T</u>	<u>3.0</u>		
HP	<u>15</u> RPM _____	<u>64.3</u>		
VOLT	<u>230</u>	% MOTOR SPEED <u>45.5</u> %		
AMPS	<u>15</u>	PRESENT _____	TO _____	
EFF.	_____	REQ HR. _____	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>13</u>			
DESCRIPTION	<u>AHU # 7 SUPPLY</u>	<u>473</u>	<u>476</u>	
MFG	<u>West.</u>	<u>18.4</u>	<u>18.7</u>	
MODEL #	<u>TBFC</u>	<u>5.7</u>	<u>35.33 Hz</u>	
SERIAL #	<u>PE KBO06M</u>	<u>9.7</u>		
FRAME	<u>286</u>	<u>11.2</u>		
HP	<u>30</u> RPM _____	<u>50.5</u>		
VOLT	<u>208</u>	% MOTOR SPEED _____ %		
AMPS	<u>30</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			
MOTOR#	<u>14</u>			
DESCRIPTION	<u>AHU # 7 RETURN</u>	<u>473</u>	<u>475</u>	
MFG	<u>G.E.</u>	<u>7.5</u>	<u>8.9</u>	
MODEL #	<u>SK215 BC205</u>	<u>2.0</u>	<u>32.7 Hz</u>	
SERIAL #	<u>PE JH013 ("6-pack")</u>	<u>4.4</u>		
FRAME	<u>215 t</u>	<u>4.7</u>		
HP	<u>10</u> RPM _____	<u>47.9</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>-</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 1/21/92

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR# <u>15</u>				
DESCRIPTION <u>AHU # 8 SUPPLY</u>	VOLTS	<u>472</u>	<u>474</u>	
MFG <u>Westing.</u>	AMPS	<u>11</u>	<u>11.2</u>	
MODEL # <u>TBFC</u>	KW	<u>7.6</u>	<u>38.5 Hz</u>	
SERIAL # <u>PE KBO06K</u>	KVAR	<u>2.0</u>		
FRAME <u>324T</u>	KVA	<u>8.0</u>		
HP <u>40</u> RPM _____	PF	<u>97.1</u>		
VOLT <u>230</u>				
AMPS <u>40</u>		% MOTOR SPEED _____ %		
EFF. _____		PRESENT _____ TO _____		
COMMENTS _____		REQ HR. _____ TO _____		
MOTOR# <u>16</u>				
DESCRIPTION <u>AHU # 8 RETURN</u>	VOLTS	<u>472</u>	<u>474</u>	
MFG <u>G.E.</u>	AMPS	<u>10.7</u>	<u>10.4</u>	
MODEL # <u>SK254BC205</u>	KW	<u>3.0</u>	<u>38.5 Hz</u>	
SERIAL # <u>PE KA006A</u>	KVAR	<u>5.0</u>		
FRAME <u>215T</u>	KVA	<u>6.2</u>		
HP <u>10</u> RPM _____	PF	<u>52.4</u>		
VOLT <u>230</u>				
AMPS <u>10</u>		% MOTOR SPEED _____ %		
EFF. _____		PRESENT _____ TO _____		
COMMENTS _____		REQ HR. _____ TO _____		

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5

10+ HP MOTORS

MEASURED

MOTOR# <u>17</u>		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>AHU #9 SUPPLY</u>	VOLTS	<u>473</u>	<u>476</u>
MFG	<u>Westinghouse</u>	AMPS	<u>21</u>	<u>21.6</u>
MODEL #	<u>TBFC</u>	KW	<u>7.9</u>	
SERIAL #	<u>PE JL007</u>	KVAR	<u>10.3</u>	
FRAME	<u>286 T</u>	KVA	<u>13.2</u>	
HP	<u>30</u> RPM _____	PF	<u>60</u>	
VOLT	<u>208</u>	% MOTOR SPEED	<u>41.5</u> Hz	
AMPS	<u>25</u>	PRESENT	_____ TO _____	
EFF.	_____	REQ HR.	_____ TO _____	
COMMENTS _____				

MOTOR# <u>18</u>		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>AHU #9 RETURN</u>	VOLTS	<u>472</u>	<u>474</u>
MFG	<u>G.E.</u>	AMPS	<u>9.5</u>	<u>9.3</u>
MODEL #	<u>5K215BC205</u>	KW	<u>3.1</u>	
SERIAL #	<u>PE JL007</u>	KVAR	<u>4.2</u>	
FRAME	<u>215 T</u>	KVA	<u>5.2</u>	
HP	<u>10</u> RPM _____	PF	<u>56.5</u>	
VOLT	<u>230</u>	% MOTOR SPEED	<u>41</u> %	
AMPS	<u>10</u>	PRESENT	_____ TO _____	
EFF.	_____	REQ HR.	_____ TO _____	
COMMENTS _____				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 1/21/91

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>19</u>			
DESCRIPTION	<u>AHU #10 SUPPLY</u>	<u>473</u>	<u>475</u>	
MFG	<u>West.</u>	<u>26</u>	<u>28</u>	
MODEL #	<u>TBFC</u>	<u>12.8</u>	<u>44.2 Hz</u>	
SERIAL #	<u>PEKA004</u>	<u>3</u>		
FRAME	<u>324</u>	<u>13</u>		
HP	<u>40</u> RPM _____	<u>97</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>30</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	<u>HAS A NEW YORK MODULATOR ON IT :: GOOD PF</u>			

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>20</u>			
DESCRIPTION	<u>AHU #10 RETURN</u>	<u>474</u>	<u>474</u>	
MFG	<u>G.E.</u>	<u>9.2</u>	<u>9.6</u>	
MODEL #	<u>JK 254BC205</u>	<u>2.7</u>	<u>37.6 Hz</u>	
SERIAL #	<u>PE KA007A</u>	<u>4.7</u>		
FRAME	<u>254T</u>	<u>5.4</u>		
HP	<u>15</u> RPM _____	<u>46</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>15A</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CBL
CHECKED BY: _____
DATE: 1/21/92

BLDG.# 200
ECC 5

10+ HP MOTORS
MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>21</u>			
DESCRIPTION	<u>AHU #11 SUPPLY</u>	<u>473</u>	<u>470</u>	
MFG	<u>Westing.</u>	<u>22.2</u>	<u>22.6</u>	
MODEL #	<u>TBFC</u>	<u>8.6</u>		
SERIAL #	<u>PE K8001M</u>	<u>11.1</u>		
FRAME	<u>286T</u>	<u>14.1</u>		
HP	<u>30</u> RPM _____	<u>61.3</u>		
VOLT	<u>208</u>	% MOTOR SPEED <u>43.25%</u>		
AMPS	<u>30</u>	PRESENT _____ TO _____		
EFF.	_____	REQ HR. _____ TO _____		
COMMENTS _____				
MOTOR#	<u>22</u>	PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>AHU #11 RETURN</u>	<u>473</u>	<u>471</u>	
MFG	<u>G.E.</u>	<u>8.0</u>	<u>9.6</u>	
MODEL #	<u>SK254BC205</u>	<u>2.6</u>		
SERIAL #	<u>PE KA013A</u>	<u>4.5</u>		
FRAME	<u>254T</u>	<u>5.2</u>		
HP	<u>15</u> RPM _____	<u>50.0</u>		
VOLT	<u>230</u>	% MOTOR SPEED <u>35.56%</u>		
AMPS	<u>15</u>	PRESENT _____ TO _____		
EFF.	_____	REQ HR. _____ TO _____		
COMMENTS _____				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. GF
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5

10+ HP MOTORS
 MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>23</u>			
DESCRIPTION	<u>AHU # 12 SUPPLY</u>	<u>472</u>	<u>474</u>	
MFG	<u>Westinghouse</u>	<u>25.8</u>	<u>23</u>	
MODEL #	<u>631-60798-000</u> TBFC	<u>18</u>		
SERIAL #	<u>KC 001 U</u>	<u>3</u>		
FRAME	<u>324T</u>	<u>18</u>		
HP	<u>40</u> RPM _____	<u>98.7</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>40</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			
MOTOR#	<u>24</u>			
DESCRIPTION	<u>AHU # 12 RETURN</u>	<u>472</u>	<u>476</u>	
MFG	<u>G.E.</u>	<u>12.6</u>	<u>12.1</u>	
MODEL #	<u>5K2548C205</u> <u>031-00794-000</u>	<u>4.5</u>		
SERIAL #	<u>PE KAO14 A</u>	<u>6.0</u>		
FRAME	<u>254T</u>	<u>8.0</u>		
HP	<u>15</u> RPM _____	<u>65.2</u>		
VOLT	<u>230</u>	% MOTOR SPEED <u>44.5 #2</u>		
AMPS	<u>15</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 1/21/92

BLDG.# 200
ECC 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>25</u>			
DESCRIPTION	<u>AHU # 14 SUPPLY</u>	<u>467</u>	<u>472</u>	
MFG	<u>West.</u>	<u>12.6</u>	<u>12.5</u>	
MODEL #	<u>TBPC</u>	<u>9.0</u>		
SERIAL #	<u>PEK B004</u>	<u>2.0</u>		
FRAME	<u>364T</u>	<u>9.2</u>		
HP	<u>60</u> RPM _____	<u>97.8</u>		
VOLT	<u>460</u>	% MOTOR SPEED _____ %		
AMPS	<u>50</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			
MOTOR#	<u>26</u>	PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>AHU # 14 RETURN</u>	<u>467</u>	<u>471</u>	
MFG	<u>G.E.</u>	<u>30.3</u>	<u>31.3</u>	
MODEL #	<u>SK284BL205D</u>	13.0		
SERIAL #	<u>PE J6006</u>	13.8	<u>50.6 Hz</u>	
FRAME	<u>284T</u>	<u>18.5</u>		
HP	<u>25</u> RPM _____	<u>66.5</u>		
VOLT	<u>230</u>	% MOTOR SPEED _____ %		
AMPS	<u>25</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 1/21/92

BLDG.# 200
 ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
<u>33</u>				
DESCRIPTION	<u>AHU # 15 SUPPLY</u>	<u>476</u>	<u>470</u>	
MFG		<u>17.5</u>	<u>17.8</u>	
MODEL #		<u>13.4</u>		
SERIAL #		<u>2.2</u>		
FRAME		<u>13.7</u>		
HP		<u>98</u>		
VOLT		% MOTOR SPEED		%
AMPS		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS				

MOTOR#		PHASE A	PHASE B	PHASE C
<u>34</u>				
DESCRIPTION	<u>AHU # 15 RETURN</u>	<u>473</u>	<u>478</u>	
MFG		<u>19.0</u>	<u>19.8</u>	
MODEL #		<u>7.0</u>	<u>48.6Hz</u>	
SERIAL #		<u>8.0</u>		
FRAME		<u>10.9</u>		
HP		<u>63</u>		
VOLT		% MOTOR SPEED		%
AMPS		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. OF
CALCULATED BY:
CHECKED BY:
DATE:

BLDG.# 200
ECO 5

MOTORS

MOTOR #	<u>27</u>	HP	<u>5</u>	PH		RPM	
MODEL #		VOLTS		AMPS		<u>7.6</u>	
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU #13 SUPPLY</u>		COMMENTS				
MOTOR #	<u>28</u>	HP	<u>1</u>	PH		RPM	
MODEL #		VOLTS		AMPS		<u>1.8</u>	
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU #13 RETURN</u>		COMMENTS				
MOTOR #	<u>29</u>	HP	<u>5</u>	PH		RPM	
MODEL #		VOLTS		AMPS		<u>7.6</u>	
SERIAL #	<u>OK</u>	PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU #16 SUPPLY</u>		COMMENTS				

BLDG.# 200
 ECO 5 _____

MOTORS

MOTOR #	<u>30</u>	HP	<u>1</u>	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	<u>1.8</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>AHU # 16 RETURN</u>		COMMENTS _____				

MOTOR #	<u>31</u>	HP	<u>3</u>	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	<u>4.8</u>	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>AHU # 17 SUPPLY</u>		COMMENTS <u>470V 2.6A</u> <u>473V 2.5A</u> <u>0.6kWh 1.2kVAR</u> <u>1.3kVA</u> <u>26.3Hz</u> <u>41.3PF</u>				

MOTOR #	<u>32</u>	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____	_____	_____
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	_____
MFG	_____	REQUIRED HR.	_____	TO	_____	_____	_____
FRAME	_____	EFF.	_____	_____	_____	_____	_____
DESCRIPTION	<u>AHU # 17 RETURN</u>		COMMENTS _____				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5

10+ HP MOTORS
 MEASURED

MOTOR# <u>35</u>		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>CONDENSER PUMP#1</u> VOLTS			
MFG	<u>Century</u> AMPS			
MODEL #	<u>6-321179-07</u> KVAR			
SERIAL #	_____ KVA			
FRAME	<u>365 TS</u> KW			
HP	100 <u>75</u> RPM <u>1770</u> PF			
VOLT	<u>480</u> - 3W 230/460			
AMPS	124 _____ <u>174/87</u> PRESENT _____ TO _____			
EFF.	<u>88.7</u> REQ HR. _____ TO _____			
COMMENTS <u>off</u>				

MOTOR# <u>36</u>		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>CONDENSER PUMP#2</u> VOLTS			
MFG	<u>Century</u> AMPS			
MODEL #	<u>6-321179-07</u> KVAR			
SERIAL #	_____ KVA			
FRAME	<u>365 TS</u> KW			
HP	100 <u>75</u> RPM <u>1770</u> PF			
VOLT	<u>480</u> - 3W 230/460			
AMPS	124 _____ <u>174/87</u> PRESENT _____ TO _____			
EFF.	<u>88.7</u> REQ HR. _____ TO _____			
COMMENTS <u>off</u>				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 5

10+ HP MOTORS
MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>37</u>			
DESCRIPTION	<u>CONDENSER PUM #3</u> VOLTS	<u>472</u>	<u>469</u>	
MFG	<u>Century</u> AMPS	<u>77.3</u>	<u>76.0</u>	
MODEL #	<u>6-321179-07</u> KVAR	<u>33.2</u>		
SERIAL #	_____ KVA	<u>62.8</u>		
FRAME	<u>365TS</u> KW	<u>53.3</u>		
HP	<u>100</u> 75 RPM <u>1770</u> PF	<u>85.1</u>		
VOLT	<u>480 -3W</u> 230/460			
AMPS	<u>124</u> 174/87	PRESENT	TO	
EFF.	<u>88.7</u>	REQ HR.	TO	
COMMENTS	<u>inlet 10 psig outlet 53 psig</u>			

MOTOR#		PHASE A	PHASE B	PHASE C
MOTOR#	<u>38</u>			
DESCRIPTION	<u>CONST. PRESS.</u> VOLTS			
MFG	_____ AMPS			
MODEL #	_____ KVAR			
SERIAL #	_____ KVA			
FRAME	_____ KW			
HP	<u>25</u> RPM _____ PF			
VOLT	<u>480 -3W</u>			
AMPS	<u>34</u>	PRESENT	TO	
EFF.	_____	REQ HR.	TO	
COMMENTS	_____			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: ROMA
CHECKED BY: _____
DATE: 1/21/92

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#	PHASE A	PHASE B	PHASE C
<u>39</u>			
DESCRIPTION <u>CHWP #1</u> VOLTS			
MFG <u>Century</u> AMPS			
MODEL # <u>6-312794-01</u> KVAR			
SERIAL # _____ KVA			
FRAME <u>286T</u> KW			
HP <u>30</u> RPM <u>1750</u> PF			
VOLT <u>480 -3W / 230/460</u>			
AMPS <u>40</u> / <u>74/37</u> PRESENT _____ TO _____			
EFF. <u>88.3</u> REQ. HR. _____ TO _____			
COMMENTS <u>Not Operating</u>			

MOTOR#	PHASE A	PHASE B	PHASE C
<u>40</u>			
DESCRIPTION <u>CHWP #2</u> VOLTS			
MFG <u>Century</u> AMPS			
MODEL # <u>6-312794-01</u> KVAR			
SERIAL # _____ KVA			
FRAME <u>286T</u> KW			
HP <u>30</u> RPM <u>1750</u> PF			
VOLT <u>480 -3W / 230/460</u>			
AMPS <u>40</u> / <u>74/37</u> PRESENT _____ TO _____			
EFF. <u>88.3</u> REQ. HR. _____ TO _____			
COMMENTS <u>Not operating</u>			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
41				
DESCRIPTION	CHWP#3	472	475	
MFG	Century	27.3	26.2	
MODEL #	6-312794-01	12.4		
SERIAL #		22.3		
FRAME	286T	18.5		
HP	30 RPM 1750	83.1		
VOLT	480 -3W / 230/460			
AMPS	40 74/37	PRESENT	TO	
EFF.	88.3	REQ HR.	TO	
COMMENTS	inlet 27 psig outlet 59 psig			

MOTOR#		PHASE A	PHASE B	PHASE C
42				
DESCRIPTION	CHWP#4			
MFG	CENTURY			
PART MODEL #	6-321180-07			
SERIAL #	BB1Z			
FRAME	364T			
HP	30 60 RPM 1770			
VOLT	480-3W			
AMPS	40 70 70	PRESENT	TO	
EFF.	1	REQ HR.	TO	
COMMENTS	off / 4A operating			

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 5

10+ HP MOTORS
MEASURED

MOTOR#	PHASE A	PHASE B	PHASE C
MOTOR# <u>43</u>			
DESCRIPTION <u>CHWP # 5</u>			
MFG <u>Century</u>			
MODEL # <u>6-320318</u>			
SERIAL # <u>326F</u>			
FRAME <u>326TS</u>			
HP <u>60 50</u> RPM <u>1765</u>			
VOLT <u>480 -3W 230/460</u>			
AMPS <u>77</u> <u>120/60</u>	PRESENT	TO	
EFF. _____	REQ HR.	TO	
COMMENTS <u>not op of #6 operating in parallel</u>			
MOTOR# <u>44</u>	PHASE A	PHASE B	PHASE C
DESCRIPTION <u>CHWP # 6</u>	<u>456</u>	<u>453</u>	
MFG <u>Century</u>	<u>46</u>	<u>46</u>	
MODEL # <u>6-320318-01</u>	<u>29</u>		
SERIAL # _____	<u>37</u>		
FRAME <u>326TS</u>	<u>24.3</u>		
HP <u>60 50</u> RPM <u>1765</u>	<u>64</u>		
VOLT <u>480 -3W 230/460</u>			
AMPS <u>77</u> <u>120/60</u>	PRESENT	TO	
EFF. <u>90.3</u>	REQ HR.	TO	
COMMENTS <u>inlet 25 psig outlet 52 psig</u>			

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5

10+ HP MOTORS
 MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
<u>45</u>				
DESCRIPTION	<u>C. TOWER # 1</u>	<u>472</u>	<u>471</u>	
MFG		<u>36</u>	<u>34</u>	
MODEL #		<u>17.3</u>		
SERIAL #		<u>29.5</u>		
FRAME		<u>23.6</u>		
HP	<u>50</u> RPM _____	<u>82%</u>		
VOLT	<u>480 - 3W</u>			
AMPS	<u>65</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			

MOTOR#		PHASE A	PHASE B	PHASE C
<u>46</u>				
DESCRIPTION	<u>C. TOWER # 2</u>			
MFG				
MODEL #				
SERIAL #				
FRAME				
HP	<u>50</u> RPM _____			
VOLT	<u>480 - 3W</u>			
AMPS	<u>65</u>	PRESENT	TO _____	
EFF.	_____	REQ HR.	TO _____	
COMMENTS	_____			

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 5

10+ HP MOTORS

MEASURED

		PHASE A	PHASE B	PHASE C
MOTOR#	<u>47</u>			
DESCRIPTION	<u>C. TOWER #3</u>			
MFG				
MODEL #				
SERIAL #				
FRAME				
HP	<u>50</u> RPM _____			
VOLT	<u>480-3W</u>			
AMPS	<u>65</u>	PRESENT	<u>TO</u>	
EFF.	_____	REQ HR.	<u>TO</u>	
COMMENTS _____				

		PHASE A	PHASE B	PHASE C
MOTOR#	<u>48</u>			
DESCRIPTION	<u>AIR COMP. #2</u>	<u>471</u>	<u>474</u>	
MFG	<u>US Electrical Motors</u>	<u>22</u>	<u>22</u>	
MODEL #	<u>256FL014R044</u>	<u>11.6</u>		
SERIAL #		<u>18.1</u>		
FRAME	<u>256T</u>	<u>13.9</u>		
HP	<u>1520</u> RPM <u>1760</u>	<u>76.5</u>		
VOLT	<u>480-3W</u> <u>230/460</u>			
AMPS	<u>21</u> <u>54/27</u>	PRESENT	<u>TO</u>	
EFF.	<u>87.5</u>	REQ HR.	<u>TO</u>	
COMMENTS <u>#2 Model# E 660/R09R2000316F US Electrical Motors</u>				

(over)

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. 06
CALCULATED BY:
CHECKED BY:
DATE:

BLDG.# 200
ECO 5

10+ HP MOTORS

MEASURED

MOTOR# <u>49</u>		PHASE A	PHASE B	PHASE C
DESCRIPTION <u>AIR COMP. # 2</u>	VOLTS			
MFG	AMPS			
MODEL #	KW			
SERIAL #	KVAR			
FRAME	KVA			
HP <u>15</u>	RPM			
	PF			
VOLT <u>480-3W</u>		% MOTOR SPEED		%
AMPS <u>21</u>		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS				

MOTOR# <u>50</u>		PHASE A	PHASE B	PHASE C
DESCRIPTION <u>HWP #10</u> <u>1ST FLOOR</u>	VOLTS			
MFG	AMPS			
MODEL #	KW			
SERIAL #	KVAR			
FRAME	KVA			
HP <u>10</u>	RPM			
	PF			
VOLT <u>480-3W</u>		% MOTOR SPEED		%
AMPS <u>14</u>		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 202
 ECO 5

10+ HP MOTORS
 MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>Heat Pump</u>	<u>470</u>	<u>475</u>	
MFG		<u>130</u>	<u>137</u>	
MODEL #		<u>99</u>		
SERIAL #		<u>49</u>		
FRAME		<u>109</u>		
HP		<u>90</u>		
VOLT		% MOTOR SPEED _____ %		
AMPS		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS	<u>HWR 121° HWS 133°</u>			

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION				
MFG				
MODEL #				
SERIAL #				
FRAME				
HP				
VOLT		% MOTOR SPEED _____ %		
AMPS		PRESENT	TO	
EFF.		REQ HR.	TO	
COMMENTS				

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Elevator - Freight

Volts	475	478
Amps	40	42
Kw	32	
KVAR	11	
KVA	26 35	
PF	94%	

- Personnel

4 Total

Volts	476	470
Amps	45	45.2
Kw	27	
KVAR	23	
KVA	31	
PF		

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

208

474 V 475 V

148 A 151 A

111 kW

54 kVAR

124 kVA

90% PF

HEAT
PUMP

CONDENSER OFF CHILLERS

74°F RET

73°F SUP

HWR 116°F

HWS 133°F

AHV# 1

472 V 470 V

17.8 A 18.2 A

6.3 kW

8.9 kVAR

10.9 kVA

58.3 PF

38.3 Hz

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 200

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

CHWP46-A
MAGNATEK
PART # 6-358659-02
FRAME # 5364T
HP - 60 60 Hz 3 ϕ
RPM 1765 460V 70A

MEASURED
332V 321V
25.5A 23.5A
4.7kW
3.9kVAR
6.2kVA
63.7%PF
AT 32Hz

Operating

Inlet 29 PSIG
outlet 49 PSIG

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Electric ~~Water~~ Boiler

CAM Industries Mod: 24CW B-2

BHP 48.6

Serial #: H22104

KW 48.6

Volt 480

3 Ph

setpoint 110°F

Amps 585

HTWTR RET 122°F - False

HTWTR supply from Heat Pump

134°F

into Heat Pump

122°F

JOB UPS CAPACITIES (INTERNAL LOADS)

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

200

UPS ~~BANK~~ "A" 500A
TOTAL 380kW
480V

UPS BANK "B" 480V
150A

BANK "D" 480V

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 200

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

AHU-NUMBER	Economizer	Minimum OA.	Minimum Comments
AHU 1	<input checked="" type="checkbox"/> Y	No Dimensions 760 fpm (5x34)3 2692 cfm	One value is open & the other is closed 100% OPEN - MIN OA closed - MAX OA
AHU-2	<input checked="" type="checkbox"/> Y	760 fpm (5x34)3 2692 cfm	100% OPEN - MIN OA closed - MAX OA
AHU 3	Y	(5x34)3 75 fpm 265 cfm	One value is 50% OPEN - MAX OA 100% OPEN - MIN OA
AHU 4	Y	No Dimensions Air circulating in + out through OA louvers	EXHAUST PRESSURIZING INTAKE PLENUM - Air flowing out MIN OA
AHU 6	Y	(34x5)3 730 fpm 2656 cfm	One value is 75% OPEN - MAX OA 100% OPEN - MIN OA
AHU 5	Y	(34x5)3 135 fpm 478 cfm	One value is 50% OPEN - MAX OA 100% OPEN - MIN OA
AHU 7	<input checked="" type="checkbox"/> Y	(34x5)3 400 fpm 1418.8 cfm	100% OPEN - MIN OA closed - MAX OA
AHU 8	Y	(34x5)3 230 fpm 814.8 cfm	One value is 50% OPEN - MAX OA 100% OPEN - MIN OA
AHU 9	Y	(34x5) 2 1/2 310 fpm 915.8 cfm	"
AHU 10	Y	970 fpm (24x5)3 3435 cfm	SUBSTANTIAL OA NEGATIVE PRESSURE PLENUM One 50-75% OPEN - MAX OA 100% OPEN - MIN OA
AHU 11	Y	850 fpm (5x34)3 3010 cfm	One value is 50% OPEN - MAX OA 100% OPEN - MIN OA
AHU 12	Y	820 fpm (5x34)3 2904 cfm	100% OPEN - MIN OA 50% OPEN - MAX OA
AHU 13	100% OA		100% OA OPEN
AHU 14	Y	(2x42)3 330 fpm 3465 cfm	← MIN OA → - Plenum being pressurized → ECON by too much exhaust air
AHU 15	Y	170 fpm (42x5)3 744 cfm	One value is 50-75% OPEN - MAX OA 100% OPEN - MIN OA
AHU 16	100% OA		100% OA OPEN

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

CONTROL SEQUENCE

AHU 2-12, 14, 15, 17

CHW COIL CONTROLLED BY OA AT 57°F

AHU 13 & 16 ARE 100% OA UNITS

AIR HANDLING UNITS/~~RETURN~~^{Supply} AIR FANS

UNIT#	UNIT DESCRIPTION	BELTS/FILTERS	MOTOR/AIR MODULATOR
AHU1	York CS336FO 15,510 CFM S/N P3-816656AH1	B100 (4 EA) 24 x 24 x 2 (10 EA) 24 x 24 x 14 (10 EA)	Westinghouse TBFC 30 HP, 1755 RPM, 208-230/ 460 VAC, 3-Ph, Fr 286T, Air Mod Mdl: AM 25-46 P/N 031-00796-000 S/N PE JH008
AHU2	York CS270FO 13,525 CFM S/N 83816657AH1	B93 (4 EA) 24 x 24 x 2 (8 EA) 24 x 24 x 14 (8 EA)	Reliance 25 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 284T, Air Mod Mdl: AM 25-46 P/N 031-00-796-000 S/N PE JH012
AHU3	York CS336FO 18,350 CFM S/N 83-816657BH2	B99 (4 EA) 24 x 24 x 2 (10 EA) 24 x 24 x 14 (10 EA)	Westinghouse TBFC 30 HP, 1755 RPM, 208-230/ 460 VAC, 3-Ph, Fr 286T, Air Mod Mdl: AM 30-46 P/N 031-0797-000 S/N PE KA003
AHU4	York CS270FO 13,710 CFM S/N 83816656BH2	B93 (4 EA) 24 x 24 x 2 (8 EA) 24 x 24 x 14 (8 EA)	Westinghouse TBFC 30 HP, 1755 RPM, 208-230/ 460 VAC, 3-Ph, Fr 286T Air Mod Mdl: AM 30-46 P/N 031-0797-000 S/N PE KB005 H
AHU5	York CS402FO 19,795 CFM S/N 83816657CH3	C105 (4 EA) 24 x 24 x 2 (10 EA) 12 x 24 x 2 (5 EA) 24 x 24 x 14 (10 EA) 12 x 24 x 14 (5 EA)	Westinghouse TBFC 40 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 324T Air Mod Mdl: AM 30-46 P/N 031-0797-000 S/N PE JH006
AHU6	York CS402FO 20,590 CFM S/N 83816657C1B	C105 (4 EA) 24 x 24 x 2 (10 EA) 12 x 24 x 2 (5 EA) 24 x 24 x 14 (10 EA) 12 x 24 x 14 (5 EA)	Westinghouse TBFC 40 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 324T Air Mod Mdl: AM 40-46 P/N 031-00798-000 S/N PE KB007 M
AHU7	York CS336FO 16,680 CFM S/N 83816659AH1	B99 (4 EA) 24 x 24 x 2 (10 EA) 24 x 24 x 14 (10 EA)	Westinghouse TBFC 30 HP, 1755 RPM, 208-230/ 460 VAC, 3-Ph, Fr 286T Air Mod Mdl: AM 30-46 P/N 031-0797-000 S/N PE KB006 M
AHU8	York CS402FO 19,750 CFM S/N 83816656CH3	C105 (4 EA) 24 x 24 x 2 (10 EA) 12 x 24 x 2 (5 EA) 24 x 24 x 14 (10 EA) 12 x 24 x 14 (5 EA)	Westinghouse TBFC 40 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 324T Air Mod Mdl: AM 40-46 P/N 031-00798-000 S/N PE KB006K

AIR HANDLING UNITS/^{Supply}~~Supply~~ AIR FANS

UNIT#	UNIT DESCRIPTION	BELTS/FILTERS	MOTOR/AIR MODULATOR
AHU9	York CS336FO 15,370 CFM S/N 83816656AH1	B100 (4 EA) 24 x 24 x 2 (10 EA) 24 x 24 x 14 (10 EA)	Westinghouse TBFC 30 HP, 1755 RPM, 208-230/ 460 VAC, 3-Ph, Fr 286T Air Mod Mdl: AM 25-46 P/N 031-00796-000 S/N PE JL007
AHU10	York CS336FO 18,010 CFM S/N 83816659BH2	C105 (4 EA) 24 x 24 x 2 (10 EA) 24 x 24 x 14 (10 EA)	Westinghouse TBFC 40 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 324T Air Mod Mdl: AM 30-46 P/N 031-0797-000 S/N PE KA004
AHU11	York CS490FO 19,730 CFM S/N 83816656DNY	B112 (4 EA) 24 x 24 x 2 (15 EA) 24 x 24 x 14 (15 EA)	Westinghouse TBFC 30 HP, 1755 RPM, 208-230/ 460 VAC, 3-Ph, Fr 286T Air Mod Mdl: AM 30-46 P/N 031-0797-000 S/N PE KB001 M
AHU12	York CS490FO 22,240 CFM S/N 83816657DH4	C120 (4 EA) 24 x 24 x 2 (15 EA) 24 x 24 x 14 (15 EA)	Westinghouse TBFC 40 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 324T Air Mod Mdl: AM 40-46 P/N 031-00798-000 S/N KC 001 U
AHU13	York CS50FO 2,040 CFM S/N 83816655AH1	B48 (2 EA) 24 x 24 x 2 (2 EA) 24 x 24 x 14 (2 EA)	Westinghouse 5BFC 5 HP, 1740 RPM, 230/460 VAC, 3-Ph, Fr 184T Air Mod Mdl: N/A (MCC)
AHU14	York CS666FO 33,465 CFM S/N 83816655CH3	C136 (4 EA) 24 x 24 x 2 (20 EA) 24 x 24 x 14 (20 EA)	Westinghouse TBFC 60 HP, 1775 RPM, 460 VAC 3-Ph, Fr 364T Air Mod Mdl: AM 50-46 P/N 031-00799-000 S/N PE KB004
AHU15	York CS490FO 24,075 CFM S/N 83816659DH4	C120 (4 EA) 24 x 24 x 2 (15 EA) 24 x 24 x 14 (15 EA)	Westinghouse TBFC 40 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 324T Air Mod Mdl: AM 40-46 P/N 031-00798-000 S/N KC008 U
AHU16	York CS50FO 2,040 CFM S/N 838166558HO	B48 (2 EA) 24 x 24 x 2 (2 EA) 24 x 24 x 14 (2 EA)	Westinghouse 5BFC 5 HP, 1740 RPM, 230/460 VAC, 3-Ph, Fr 184T Air Mod Mdl: N/A (MCC)

AIR HANDLING UNITS/~~RETURN~~^{Supply} AIR FANS

UNIT#	UNIT DESCRIPTION	BELTS/FILTERS	MOTOR/AIR MODULATOR
AH017	York CS50FO 1,910 CFM S/N ?	B46 (2 EA) <i>J</i> 12 x 24 x 2 (2 EA) 12 x 24 x 14 (2 EA) <i>4</i>	Westinghouse 5BFC 3 HP, 1730 RPM, 230/460 VAC, 3-Ph, Fr 182T Air Mod Md1: AM 5-46 E/N 031-00791-000 S/N PE KA011 A

AIR HANDLING UNITS/RETURN AIR FANS

UNIT#	UNIT DESCRIPTION	BELTS/FILTERS	MOTOR/AIR MODULATOR
RAF1	Aladdin BA365 14,780 CFM S/N 83346	B162 (2 EA)	G.E. 5K215BC205 10 HP, 1740 RPM, 230/460 VAC, 3-Ph, Fr 215T Air Mod Mdl: NOT MARKED P/N 808223 S/N PE JH013 ("6-pack")
RAF2	Aladdin BA300 12,875 CFM S/N 83347-1	BP140 (2 EA)	G.E. 5K215BC205 10 HP, 1740 RPM, 230/460 VAC, 3-Ph, Fr 215T Air Mod Mdl: NOT MARKED P/N 808223 000 S/N PE JH017 Rev. A ("6-pack")
RAF3	Aladdin BA365 17,445 CFM S/N 83348-1	BX158 (3 EA)	G.E. 5K254B1205D2 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N 031-00794-000 S/N PE AK012 A
RAF4	Aladdin BA300 12,200 CFM S/N 83347-2	BX136 (2 EA)	G.E. 5K215BC205 10 HP, 1740 RPM, 230/460 VAC, 3-Ph, Fr 215T Air Mod Mdl: AM 10A-46 P/N 031-00793-000 S/N PE JH001 A ("6-pack")
RAF5	Aladdin BA365 18,105 CFM S/N 83348-2	B162 (2 EA)	G.E. 5K254BC206 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-00794-000 S/N: PE KA005 A
RAF6	Aladdin BA365 18,920 CFM S/N 83348-3	B162 (2 EA)	G.E. 5K254BC205 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-000794-000 S/N: PE KA009A
RAF7	Aladdin BA365 15,060 CFM S/N 83348-4	BX162 (2 EA)	G.E. 5K254BC205 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-00794-000 S/N: PE KA010 A

AIR HANDLING UNITS/RETURN AIR FANS

UNIT#	UNIT DESCRIPTION	BELTS/FILTERS	MOTOR/AIR MODULATOR
RAF8	Aladdin BA365 17,920 CFM S/N 83348-5	B173 (2 EA)	G.E. 5K254BC205 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-00794-000 S/N: PE KA006 A
RAF9	Aladdin BA300 13,690 CFM S/N: 83347-3	BX150 (2 EA)	G.E. 5K215BC205 10 HP, 1740 RPM, 230/460 VAC, 3-Ph, Fr 215T Air Mod Mdl: AM 10A-46 P/N: 031-00796-000 S/N: PE JL007
RAF10	Aladdin BA365 17,025 CFM S/N: 83348-6	B162 (2 EA)	G.E. 5K254BC205 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-00794-000 S/N: PE KA007 A
RAF11	Aladdin BA365 18,670 CFM S/N: 83348-7	B180 (2 EA)	G.E. 5K254BC205 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-00794-000 S/N: PE KA013A
RAF12	Aladdin BA402 21,215 CFM S/N: 83349	B180 (2 EA)	G.E. 5K254BC205 15 HP, 1760 RPM, 230/460 VAC, 3-Ph, Fr 254T Air Mod Mdl: AM 15A-46 P/N: 031-00794-000 S/N: PE KA014 A
RAF13	ILG Industries, Inc Mdl SQLB 425 CFM	AX46 (1 EA).	Westinghouse Series CH82 Type ES 1 HP, 1725 RPM, 230/460 VAC, 3-Ph, Fr 66 Conventional Starter MCC
RAF14	Aladdin BA445 29,850 CFM S/N: 83350	B173 (4 EA)	G.E. 5K284BL205D 25 HP, 1765 RPM, 230/460 VAC, 3-Ph, Fr 284T Air Mod Mdl: AM 25-46 P/N: 031-00796-000 S/N: PE JL006
RAF15	Aladdin BA402 23,245 CFM S/N 83351	B162 (4 EA)	G.E. 5K256BC205 20 HP, 1755 RPM, 230/460 VAC, 3-Ph, Fr 256T Air Mod Mdl: AM 20A-46 P/N: 031-00795-000 S/N: PE JM004 C

AIR HANDLING UNITS/RETURN AIR FANS

UNIT#	UNIT DESCRIPTION	BELTS/FILTERS	MOTOR/AIR MODULATOR
-------	------------------	---------------	---------------------

RAF 16	ILG Industries, Inc Mdl SQLB 1856 CFM		
--------	---	--	--

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 1 LOCATION: R-119 SEC. 1 1ST FLOOR NORTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER VAV

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA 15510 RA 14780 OA 1915 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 2 LOCATION: R-218 SEC. 1 2nd floor NORTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER VAV

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA 13525 RA 12875 OA 1410 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV [] 74.5°
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN EXHAUST FAN [] OTHER []

FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []

PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCG HEAT _____ °F UNOCG HEAT _____ °F OCG COOL _____ °F UNOCG COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

Return fan pressurizing intake plenum, forcing
air out the OA louvers. Overridden + made operational
economy. ¹ ECU

T_{RA} = 75.2

T_{HO} = 74.5

T_{SA} = 57.2

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 3 LOCATION: R-317 SEC. 1 NORTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 18350 RA 17445 OA 2200 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____
DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____
SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 4 LOCATION: R-118 SEC. 1 @ 1st floor SOUTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 13716 RA 12200 OA 1090 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS: _____

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 5 LOCATION: R-217 SEC. 1 2nd floor SOUTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [X] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 19795 RA 18105 OA 1945 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [X] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [X] DX [] SPRAY [] OTHER []

REMARK: _____
DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____
SUPPORT FANS: UNIT _____ RETURN FAN [X] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS: _____

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 6 LOCATION: R-316 SEC. 1 SOUTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [2] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 20590 RA 18920 OA 2575 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [X] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [X] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [X] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 7 LOCATION: R-131 WEST 1st floor SEC. 3
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 16680 RA 15060 OA 2150 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 18 LOCATION: R-230 SEC, 3 WEST
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER: [X] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 19750 RA 17920 OA 7200 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [X] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [X] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [X] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS: _____

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: _____
AHU NO: 9 LOCATION: R-323 SEC. 3 @ WEST
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 15370 RA 13690 OA 2220 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____
DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____
SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 10 LOCATION: R-132 SEC.3 East 1st floor
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER VAV

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA 18010 RA 17025 OA 2440 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN EXHAUST FAN [] OTHER []

FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []

PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 11 LOCATION: R-231 SEC.3 EAST
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 19730 RA 18670 OA 2095 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____
DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____
SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: _____
AHU NO: 12 LOCATION: R-324 SEC. 3 EAST
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 22240 RA 21215 OA 2206 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105.000
AHU NO: AHU-13 LOCATION: R-011 NORTH BASEMENT
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 2040 RA 245 OA 2040 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

100% OA UNIT (SAME AS 16)

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 1/13/92
BY: JW

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 14 LOCATION: R-010 BASEMENT SEC 1 SOUTH
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] VAV

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA 33465 RA 29850 OA 5570 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS: _____

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: _____
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 15 LOCATION: R-019 WEST BASEMENT SEC. 3
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER VAV

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA 24075 RA 23245 OA 3546 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN EXHAUST FAN [] OTHER []

FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []

PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: 3105
AHU NO: 16 LOCATION: R-020 EAST SEC. 3 BASEMENT
ZONE NO. SERVED: 0 REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER VAV

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA 2640 RA 1856 OA 2040 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

100% OA UNIT (SAME AS 513)

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 200 BLDG NAME: ADMIN JOB: _____
AHU NO: 17 LOCATION: R-136 1st floor LOBBY
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER: [X] VAV

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA 1910 RA 1590 OA 125 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [X] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [X] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [X] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

3rd floor

Bldg 200

3rd floor
2nd Section

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
300									
301	28	1	175	MH					
302	15	2	34	F ^{warm light}	ON	Y	Y	4	Y
303	1	2	34	F	ON	Y	Y	1	Y
304	1	2	34	F	OFF	Y	N	1	N
305	2	2	34	F	OFF	Y	N	1	N
306	1	2	34	F	ON	Y	Y	1	Y
307	1	2	34	F	ON	Y	Y	1	Y
308	1	2	34	F	OFF	Y	N	1	N
309	2	2	34	F	OFF	Y	N	1	N
310	1	2	34	F	ON	Y	Y	1	Y
326	27	3	34	F	ON	Y	N	(1 3way) 3	N
326	10	1	100	I		Y			
327	2		34	F		Y		2	
328	9	2	34	F		Y		(2 3way) 6	
	24	1	200	I		Y		See E-18 Drawg. 329	
329	5	3	34	F	ON	Y	Y	2	N
330	3	3	34	F	OFF	Y	N	1	N

126
13
315
72
84

325 206 3way 9
 # OF EXIT SIGNS -
 326 A 16

COMMENTS:

310A 6 2 34 F 2ON Y N 1 N

3rd floor
2nd section

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
331	1	3	34	F		Y		1	
332	1	2	34	F		Y		1	
333	5	1	200	I	OFF	Y	Y	1	N
	4	1	300	I	OFF	Y	Y	1	N
334	1	2	34	F		Y		1	
335	1	2	34	F		Y		1	
336	5	1	200	I		Y		1	
	4	1	300	I		Y		1	
337	1	2	34	F		Y		1	
339	6	1	300	I		Y		1	
	6	1	200	I		Y		1	
	4	1	200	I		Y		1	
338									
340	4	3	34	F	OFF	Y	Y	2	N
341	10	1	150	I	OFF	Y	N	1	N
point work	4	1	200	I	OFF	Y	N	1	N
342									
343	1	2	34	F	OFF	Y	Y	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

3rd floor
1st Section

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
301A	23	1	175	MH					
311	4	2	34	F	ON	Y	N	1	N
312	2	2	34	F	OFF	Y	N	1	N
313	1	2	34	F	ON	Y	Y	1	N
314	5	2	34	F	ON	Y	N	1	N
315	2	2	34	F	OFF	Y	N	1	N
316	5	2	34	F		Y		1	
317	5	2	34	F		Y		1	
350	131	3	34	F	ON	Y	N	M.S. A (1)	N
351 351A	6	3	34	F	ON	Y	Y	2	Y
352 352	4	3	34	F	ON	Y	Y	2	N
353 353	4		34	F		Y		2	
354 352	2		34	F		Y		M.S. B (1)	
355 353	16	3	34	F	ON	Y	N	M.S. B (1)	N
356 354	6		34	F		Y		2	
357 355	21	3	34	F	ON	Y	N	M.S. B (1)	N
358 356	4		34	F		Y		2	
359 357	54	3	34	F	ON	Y	N	M.S. B (1)	N

316A 6 2 34 F 2ON Y N 1 N
OF EXIT SIGNS -
350A 24 3 34 F ON Y N 1 N

COMMENTS:

1 way only

16
13
12
11

4-D4
2-E2
...
04-A4
03-A3
06-A6
04-A4

3rd floor
3rd section

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
✓ 301B	24	1	175	MH					
319	4	2	34	F	ON	Y	N	1	N
320	2	2	34	F	OFF	Y	N	1	N
321	1	2	34	F	ON	Y	Y	1	Y
322	5	2	34	F	ON	Y	N	1	N
323	5	2	34	F		Y		1	
324	5	2	34	F		Y		1	
325	2	2	34	F	OFF	Y	N	1	N
110 364	114	3	34	F	ON	Y	N	M.S. A (1)	N
365	6	3	34	F	OFF	Y	Y	2	Y
24/216 366	6	4	34	F	OFF	Y	Y	2	Y
367	6	3	34	F	ON	Y	Y	2	N
368	36	3	34	F	ON	Y	Y	2	N
369	24	3	34	F	ON	Y	N	M.S. C (1)	N
216 370	216	3	34	F	ON	Y	N	M.S. B+C (2)	N
30813 370	3	3	34	F	OFF	Y	Y	2	N
371	9	3	34	F	ON	Y	N	1	N
372	9	3	34	F	ON	Y	Y	2	N

206A 5 2 34 F 2ON Y N 1 Y
OF EXIT SIGNS - _____

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

1st floor Lighting
Bldg 200

1st Floor Section 3

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
127	4	2	34	F	ON	Y	N	1	N
128	2	2	34	F	OFF	Y	N	1	N
130	5	2	34	F	ON	Y	N	1	N
129	1	2	34	F	OFF	Y	N	1	N
131	7	2	34	F		Y		1	
132	6	2	34	F		Y		1	
133	4	spots 1							
134	2	2	34	F	OFF	Y	N	1	N
160	147	3	34	F	ON	Y	N	master switch (A) (1)	N
161	4	↑	34	F		Y		2	
162	35	3	34	F	ON	Y	N	master switch (C) (1)	N
163	115	3	34	F	ON	Y	N	M.S. B (1)	N
164	121	3	34	F	ON	Y	N	M.S. C (1)	N
134A	5	2	34	F	2 ON	Y	N	1	Y

4
16
5
128
29
149

Atrium

13

162 is in
any 101E

115. from
west end of
bdg.

30
100
110

81
16

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# _____
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
10					OFF		N	1	N
11									
12									
13									
14	2								
15	10	7							
16				F					
✓ 101	6	1	5	HID	ON ^{all time}	Y	N	1	N
102	2	1	15	HID	ON	Y	N	1	N
✓ 103	4	2	34	F	ON	Y	N	1	N
104	2	2	34	F	OFF	Y	N	1	N
104	1	2	34	F	OFF	Y	N	1	N
105	5	2	34	F	ON	Y	N	7	N
106	2	2	34	F	ON	Y	Y	1	Y
107	4 18	spots 3	34	F	OFF ON	Y	N	1	N
108	2	2	34	F		Y		1	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.#: 200
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1511	4	3	34	F	ON	Y	Y	2	Y
151	2	3	34	F	ON	Y	N	MASTER SWITCH	N
152	4	3	34	F	OFF	Y	N	2	N
153	69	3	34	F	ON	Y	N	MASTER SWITCH	N
154	3	3	34	F	ON	Y	N	1	N
155	3	3	34	F	ON	Y	N	(3000p)	N
156			34	F		Y		1	
157	3	3	34	F	ON	Y	N	2	N
158	3	3	40	F	ON	Y	N	1	N
159	40	3	34	F	ON	Y	N	2	N
111AS	7	2	34	F	4 OFF 3 ON	Y	N	1	N
120S	6	2	34	F	2 ON 4 OFF	Y	N	1	Y
159A	4	3	34	F	ON	Y	Y	2	Y

32
32
68

OF EXIT SIGNS - 1111

GH 5,6, Extra copiers + printers - 12

COMMENTS: 151 & 153 are divided ⁹ fixtures from North end.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
✓ 101	1	2	34	F		Y		1	
✓ 110	2	2	34	F		Y		1	
✓ 111	1	3 ^{2'U}	40	F	ON	Y	N	1	N
	1	3	34	F	ON	Y	N	1	N
	1	3	34	F	ON	Y	N	1	N
✓ 138	3	3	34	F	ON	Y	Y	1	Y
✓ 138A	3	3	34	F	OFF	Y	Y	2	N
✓ 139	7	3	34	F	ON	Y	N	2	Y
✓ 137	0		34	F		Y		4	
✓ 137	10		34	F		Y		2	
✓ 101	30		175	HID	ON				
✓ 101A	3	1	175	HID					
✓ 101B	2	1	175	HID					
✓ 102	4	1	175	HID	ON				
✓ 103									
✓ 104	1	2	34	F	ON	Y	Y	1	Y
✓ 105	1	2	34	F		Y		1	
✓ 106	2	2	34	F		Y		1	
✓ 107	1	2	34	F	ON	Y	Y	1	N
✓ 101E	14	1	175	HID		Y			
✓ 100	12	1	175	HID					

maybe 2 (30w)

3' x 2' ceiling fixture
 floor
 pad or
 recessed
 employ
 ceiling

OF EXIT SIGNS - _____

COMMENTS: _____

12 - floor section 2

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
135	4	3	34	F	ON	Y	Y	2	N
136	23	3	34	F	ON	Y	N	3	N
140	1		34	F					
141	65	3	34	F	ON	Y	N	4	N
142	4	3	34	F	ON	Y	Y	2	Y
143	66	3	34	F	ON	Y	N	4	N
144	4	3	34	F	ON	Y	Y	4	N
145	4	3	34	F	ON	Y	Y	2	N
146	6	3	34	F	OFF	Y	Y	2	N
147	6	3	34	F	ON	Y	N	2	N
148	6	3	34	F	OFF	Y	N	2	N
149	4	3	34	F	1/2 ON	Y	Y	2	1/2
150	7	3	34	F	ON	Y	N	2	N
100C	1		34	F		Y		2	
100B	3	3	34	F	ON	Y	N	0	N
AS	1 spot	2	34	F	ON	Y	N	1	N
144A	63	3	34	F	ON	Y	N	2	N
101A	6	2	34	F	1/3 ON	Y	N	1	Y

OF EXIT SIGNS - _____

COMMENTS: 101B lighting is controlled in room 101C

JOB 3105000 G.M.
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

E M C ENGINEERS, INC.
Denver • Colorado Springs • Atlanta • West Germany

* None of the stairs are numbered, so I
has not included them in the lighting charts.
We need to count them when surveying.

Ali

LIGHTING
CONTROL

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Basement

Bldg. 200

seq. 2
~~NOT~~ 24 HRS.
069
074
073
072
057
058

Basement
Section 1

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
2	24	2	34	F	3 ON	Y	N	1	N
5	4	2	34	F	.	Y		1	
6	2	2	34	F		Y		1	
7	1	2	34	F		Y		1	
8	5	2	34	F		Y		1	
9	1	2	34	F		Y		1	
10	7	2	34	F		Y		2	
11	4	2	34	F		Y		1	
12	2	2	34	F		Y		1	
12A	2	2	34	F		Y		1	
13	22	2	34	F	1/2 ON	Y	N	2	Y
14	27	2	34	F	1/2 ON	Y	N	2	Y
29	6	4	34	F		Y		2	
30	9	4	34	F		Y		2	
31	6	3	34	F	ON	Y	Y	2	Y
13A	5	2	34	F		Y		1	
32	156	3	34	F	ON	Y	N	M.S. A (1)	N
33	87	3	34	F		Y		4	

OF EXIT SIGNS - _____

COMMENTS: _____

J9
lots of equip*
18
108
21
27
108
156

Base merit
Section 1

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# _____
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
33A	2	4	34	F		Y		2	
33B	3	2	34	F	ON	Y	Y	2	Y
33C	9	3	34	F		Y		2	
34	4	4	34	F		Y		2	
35	12	2	34	F		Y		2	
36	6	3	34	F		Y		2	
37	6	3	34	F		Y		2	
38	3	4	34	F		Y		2	
39	5	3	34	F		Y		2	
28	12	3	34	F		Y		2	
40	12	3	34	F		Y		2	
41	23	3	34	F		Y		2	
12B	6	2	34	F	2 ON	Y	N	1	Y

OF EXIT SIGNS - _____

COMMENTS: _____

Basement Section 2

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
2A	2	2	34	F					
3	3	2	34	F	.	Y		1	
4	2	2	34	F		Y		1	
22	8	4	34	F		Y		2	
23	12	3	34	F		Y		2	
23A	1	2 ^(u)	40	F		Y		1	
24	8	4	34	F		Y		2	
VAULT	1	1	100	I		Y		1	
25	1	2	34	F					
26	16	2	34	F		Y		10	
	3	1	3	I		Y			
	4	1	250	I		Y			
	6	1	200	I		Y			
26 ^{APB}	1	1	1100	I		Y			
	2	1	1100	I		Y			
27	6	2	34	F	ON	Y	Y	1	Y
42	3	2	34	F					
2C	31	2	34	F					
	3	1	175	MH					

OF EXIT SIGNS - _____

COMMENTS: _____

1 bulb out ←

✓

✓

Basement Section 2

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
2C	1	2	34	F					
2D	1	2	34	F	.				
UPPER F.O.C.	36	3	34	F					
UPPER AUDIO VISUAL	9	3	34	F					

OF EXIT SIGNS - _____

COMMENTS: _____

Basement Section 2

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 200
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
43	50	3	34	F		Y		2	
44	16	3	34	F		Y		2	
45	13	4	34	F		Y		2	
46	1	4	34	F					
47	8	3	34	F		Y		2	
48	4	3	34	F		Y		2	
49	8	3	34	F		Y		2	
50	6	3	34	F		Y		2	
M1	2	1	175	MH					
M2A	2	2	34	F					
M3	5	3	34	F		Y		2	
M4	16	3	34	F		Y		2	
M2	4	2	34	F					
M5	4	2	34	F					
M6	8	3	34	F					
M7	4	3	34	F		Y		2	
M8	19	3	34	F		Y		2	
M9	7	3	34	F		Y		2	

*elevator
lobby*

OF EXIT SIGNS - _____

COMMENTS: _____

Basement
Section 3

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
15	4	2	34	F		Y		1	
16	2	2	34	F		Y		1	
17	1	2	34	F		Y		1	
18	5	2	34	F		Y		1	
19	5	2	34	F		Y		1	
20	4	2	34	F		Y		1	
21	2	2	34	F		Y		1	
21A	2	2	34	F		Y		1	
60	9	3	34	F		Y		2	
	1	2	34	F		Y		2	
61	6	3	34	F		Y		2	
62	6	3	34	F		Y		2	
63	6	4	34	F		Y		2	
64	4	3	34	F		Y		2	
65	4	4	34	F		Y		2	
66	2	4	34	F		Y		2	
67	8	3	34	F		Y		2	
68	6	4	34	F		Y		2	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# _____
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
69	64	3	34	F		Y		4	
70	2	4	34	F		Y		2	
	4	3	34	F		Y			
71	54	3	34	F		Y		2	
72	38	3	34	F		Y		2	
73	21	3	34	F		Y		2	
74	28	3	34	F		Y		2	
76	16	3	34	F		Y		2	
75									
76A	4	3	34	F		Y		2	
77	46	3	34	F		Y		6	
77A	10	3	34	F		Y		2	
78	3	4	34	F		Y		2	
79	8	3	34	F		Y		2	

OF EXIT SIGNS - _____

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

2nd floor lighting

Bldg. 200

14
4
—
656

2nd floor
Sect. 1

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 300
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
201A	12	1	175	H IL					
212	4	2	34	F	ON	Y	N	1	N
213	2	2	34	F	OFF	Y	N	1	N
214	1	1	34	F	OFF	Y	N	1	N
215	5	2	34	F	ON	Y	N	1	N
216	2	2	34	F	OFF	Y	N	1	N
217	5	2	34	F		Y		1	
218	5	2	34	F	OFF	Y	N	1	Y
219	2	2	34	F	OFF	Y	N	1	N
220	18	2	34	F					
221	27	2	34	F	ON	Y	N	1	N
222	4	2	34	F	ON	Y	N	1	Y
223	6	3	34	F	ON	Y	N	2	N
224	1	3	34	F	OFF	Y	N	1	N
225	2	2	34	F	OFF	Y	Y	1	N
	1	1	60	HID		Y		1	
236A	129	3	34	F	ON	Y	N	M.S. A (1)	N
237	2	3	34	F	ON	Y	N	1	N

19 ✓
21
43
8
104
45
12129
13
141
12
129

236 6 3 34 F ON Y Y 1 N
OF EXIT SIGNS -
212A 7 2 34 F 2ON Y N 1 X

COMMENTS:

2nd floor
Sect 1

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
238	15	3	34	F	ON	Y	N	M.S. B (1)	N
239	112	3	34	F	ON	Y	N	M.S. B (1)	N
219A	5	2	34	F	ON	Y	N	1	Y
AT	4 SPOTS 1								
248A	24	3	34	F	ON	Y	N	1	N
AT	4 SPOTS 1								

counting
261 A WEST
OF OPENING
IS 239

$\frac{3}{24}$
 $\frac{9}{216}$

$\frac{12}{9}$
 $\frac{108$

OF EXIT SIGNS - _____

COMMENTS: _____

241-1001

Sect. 2

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
201	28	1	175	111V	ON	Y	N	1	N
203	1	2	34	F	ON	Y	Y	1	Y
204	1	2	34	F	OFF	Y	N	1	N
205	2	2	34	F		Y		1	
206	1	2	34	F	ON	Y	Y	1	Y
202 SAME ↓									
207	6	2	34	F	ON	Y	Y	2	N
208	1	2	34	F	ON	Y	Y	1	Y
209	1	2	34	F		Y		1	
210	2	2	34	F		Y		1	
211	1	2	34	F	ON	Y	Y	1	Y
202	6	2	34	F		Y		2	
233	124	3	34	F	ON	Y	N	m.s. B+C (2)	N
234	6	3	34	F	ON	Y	Y	2	N
235	3	3	34	F	ON	Y	Y	2	N
240	36	3	34	F	ON	Y	N	m.s. A 1	N
241	4	3	34	F	ON	Y	Y	2	N
242	6	3	34	F	ON	Y	Y	2	N
243	4	3	34	F	ON	Y	N	m.s. 14 (1)	N
206A	7	2	34	F	ON	Y	N	1	Y

16

76
62
34
124

14

divided
14s.
2m. North

15

OF EXIT SIGNS - _____

COMMENTS: _____

2nd floor
Sect. 3

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 200
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
201B	16	1	175	AFC					
226	4	2	34	F	ON	Y	N	1	N
227	2	2	34	F	OFF	Y	N	1	N
228	1	2	34	F	ON	Y	N	1	Y
229	5	2	34	F	ON	Y	N	1	N
230	5	2	34	F		Y		1	
231	5	2	34	F		Y		1	
232	2	2	34	F	OFF	Y	N	1	N
244	129	3	34	F	ON	Y	N	M.S. A (1)	N
245	6	3	34	F	ON	Y	Y	2	Y
246	6	3	34	F	ON	Y	Y	2	Y
247	24		34	F		Y		M.S. C	
248	216	3	34	F	ON	Y	N	M.S. C (1)	N
249	90	3 2'u	34	F	ON ON	Y Y	N N	M.S. B (1)	N N
200	4	1		MH	ON	Y	N	1	N
233A	7	3	34	F	ON	Y	Y	2	N
252	6	3	34	F	ON	Y	Y	2	Y
250	6	3	34	F	ON	Y	Y	2	N
251	6	3	34	F	ON	Y	Y	2	N
252	6	3	34	F	ON	Y	N	1	Y

13
24
22
129
15
240

OF EXIT SIGNS -

COMMENTS:

BUILDING 206

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 206

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 12/19/91

CHECKED BY _____ DATE _____

SCALE 1/8"

NAME PLATES

EAST SIDE AC UNIT:

BOHN A/C & R DIVISION

MODEL # DVS0272A002

S# BKK8124

206V 3 ϕ 60Hz (2) - 1.5HP NETURS

7.2 AMP each

SOUTH AC PACKAGE UNIT:

MC QUAY

2 COMPRESSOR (RECIPROCATING) 50HP each 165 RLA
~~208~~ 208V/60/3 1070 LRA each

R-22

DOMESTIC HW TEMP.

SOUTHWEST MEN'S ROOM = 132°F

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY UCC DATE 12-19-91
CHECKED BY _____ DATE _____
SCALE _____

BLDG 206 MAKE-UP WATER PUMP.

ARMSTRONG PUMP

UQC48S17D1051HP 50 HZ 1 ϕ 115V 1725
TYPE-SS 3.5 A 1/6 HP

DOMESTIC HW PUMP

FRANKLIN ELECTRIC


MOD 1103175400 3/4 HP 1 ϕ 3450

FM 56 115V 11.2A.

TURN ON WITH CONTROL RELAY.

DUAL TEMP. PUMP -1,2 MARATHON
VVD 213TTDR70Z6GPL
3 ϕ 7 1/2 HP 208V

FM. 213T
24A 1750 RPM 84%.



DEVICE	NAMEPLATE
M-1	SUPPLY WATER TEMPERATURE
M-2	RETURN WATER TEMPERATURE
M-3	OUTSIDE AIR TEMPERATURE
S-1	SUMMER CHANGEOVER SWITCH
S-2	P-1 PUMP SELECTOR SWITCH
OT-1	TIME CLOCK OVERRIDE SWITCH ZONES 3 & 4
OT-2	TIME CLOCK OVERRIDE SWITCH ZONES 1 & 2

Ergon Systems
5500 Oakbrook Pky., Suite 210
Norcross, GA 30063

JOB NAME
**ALTERATIONS TO BUILDINGS
205, 206 & 207
FORT MCPHERSON, GEORGIA**

JOB # 1789-9 TITLE PANEL FACE REV.

DATE 9-13-69 SALESMAN PJS ENGINEER PJS SHEET 1 OF 1

CONTROL PANEL CP-1
SEE SHEET 1 FOR INTERNAL WIRING

BILL OF MATERIAL

INST ID	LIT REF	QTY	CODE NO.	DESCRIPTION
DP	JOHNSON	3	F74FA-5	DIFF. PRESS. SWITCH
HS	TRIAD	2	HD-1-3	HUMIDITY TRANSMITTER 0-100 % R.H.
TS-1	TRIAD	4	100TX-RA-C	TEMP. TRANSMITTER 50-85 F.
TS-2	TRIAD	2	100TX-PI-B-25-W	TEMP. TRANSMITTER 40-190 F.

ALTERATIONS TO BUILDINGS
 205, 206, 207
 FT. MCPHERSON, GA.
 SHEET 4 OF 4

DESCRIPTION OF OPERATION

Note: See sheet 1 for panel mounted devices

FAN COIL UNITS Time clock TC-1 starts and stops the units according to a preset schedule. An interval timer for each building overrides the respective time clock circuits to restore day operation. A night low limit thermostat in each building cycles its respective units to prevent building space temperature from falling below the night minimum setting. The outdoor air dampers for the non-process units will remain closed when the unit are operating on the night cycle.

Heating-Cooling Units (non-process) Space thermostat furnished with the units positions the 2 position dual temperature water valve to maintain space temperature at the heating or cooling setpoint. Control valve action is changed over from cooling to heating operation by a change over thermostat sensing the entering water temperature. Outdoor air damper opens when the unit is operating in the day cycle or when the respective override timer is activated. The damper will remain closed when the unit is operating in the night cycle. A high temperature detector located in the unit air inlet will prevent unit operation if its setpoint is exceeded. A low temperature detector located in the unit discharge will stop the unit and close the outdoor air damper if the discharge air temperature falls below its setpoint.

Heating-Cooling Units (process) Units operate as described above with the following exceptions: The outdoor air damper is interlocked with an associated exhaust fan and fully opens when that fan runs. The Fan Coil unit operates on 100% return air when the associated exhaust fan is off.

Heating Only units Space thermostat cycles the 2 position water valve to maintain space temperature. The valve will be closed when the system is operating in the "Summer" mode.

BILL OF MATERIAL

INST ID	LIT REF	QTY	CODE NO.	DESCRIPTION
HTD-1-4	DYNACON	104	FS-200	MAN. RESET FIRESTAT
LTD-1.2	BC	83	TA-3441	MAN. RESET FREEZESTAT
R-1-5	DYNACON	104 104	RH1B-UAC120 SH1B-05	SPDT RELAY 120VAC RELAY SOCKET
R-6	DYNACON	10 10	RH2B-UAC120 SH2B-05	DPDT RELAY 120VAC RELAY SOCKET

DESCRIPTION OF OPERATION

Note: See sheet 1 for panel mounted devices

Dual Temperature Pumps (P-1 or P-2 as selected by switch S-2) are started and stopped by any circuit of time clock TC-1, any override timer, or any night set-back thermostat.

Summer-Winter changeover switch S-1 positions 2 position changeover valves V-2 & V-3 for chilled water flow when in "Summer" position and for hot water flow when in the "Winter" position. Time delay relays TD-1 & TD-2 delay the valve changeover for a preset time (adjustable). When S-2 is in the "Summer" position and flow is proven by the chiller flow switch, chiller C-1 is allowed to start and runs under control of its internal control system. Valve V-1 prevents flow through C-1 until the Dual temperature return water temperature is below the setpoint (adjustable) of thermostat T-1. When S-2 is in the "Winter" position and flow is proven by boiler flow switch FS-1, boiler B-1 is allowed to start and runs under control of its internal control system. See manufacturer's literature for complete description of operation.

BILL OF MATERIAL

INST ID	LIT REF	QTY	CODE NO.	DESCRIPTION
FS-1.2	M-M	2	FS4-3D	DPDT FLOW SWITCH
T-1	BC	1	TC-4111	RMT. BULB T'STAT
TS-1.2	BC	2	TS-8201	TEMP. TRANSMITTER
		2	AT-215	BULB WELL
TS-3	BC	1	TS-8501	O.A. TEMP. T'MITTER
		1	AT-211	OUTDOOR BULB SHIELD
V-1.2	BC	1	VC-9313 *	3-WAY MIXING VALVE
V-3	BC	1	VC-9223 *	3-WAY DIVERTING VALVE

* SEE VALVE SCHEDULE FOR COMPLETE VALVE INFORMATION

DESCRIPTION OF OPERATION


See sheets 2 & 3 for description of operation

BILL OF MATERIAL

INST ID	LIT REF	QTY	CODE NO.	DESCRIPTION
CP-1	BC	1	AE-631	CONTROL PANEL
ES-1	ELLESCO	1	55E	EMERG. BREAKGLASS
M-1,2	BC	2	ASP-563	METER 40-240
		2	TSP-8111	TEMP. TRANSMITTER
M-3	BC	1	ASP-561	METER -40-160
		1	TSP-8111	TEMP. TRANSMITTER
OT-1,2	RHODES	2	90017	OVERRIDE TIMER
R-1-4,6,8	DYNACON	6	RH3B-VAC120	3PDT RELAY 120VAC
		6	SH3B-05	RELAY SOCKET
R-5,7,11, & 12	DYNACON	4	RH2B-VAC120	DPDT RELAY 120VAC
		4	SH2B-05	RELAY SOCKET
R-9,10	DYNACON	2	RH1B-VAC120	SPDT RELAY 120VAC
		2	SH1B-05	RELAY SOCKET
S-1	CARLINGSWITCH	1	1L254-73	4PDT TOGGLE SWITCH
S-2	CARLINGSWITCH	1	2FBS4-73	SPDT TOGGLE SWITCH
TC-1	GRASSLIN	1	DIGI 127-9R	9 CIRCUIT TIME CLOCK
TD-1	GRAINGER	1	6X602	TIME DELAY RELAY
TD-2	GRAINGER	1	6X601	TIME DELAY RELAY
TF-1	GRAINGER	1	3A357	TRANSFORMER, 120/24V, 40VA




1	SPACE TEMP @ N.I.L.L
2	SPACE TEMP @ N.I.L.L
3	SPACE TEMP @ N.I.L.L
4	SPACE R.H. RM 140
5	SPACE R.H. RM 140
6	SPACE TEMP RM 146
7	SPACE R.H. RM 146
8	SPACE R.H. RM 146
9	CHILLER OFF/AUTO
10	CHILLER STATUS
11	BOILER OFF/AUTO
12	BOILER STATUS
13	D.T. SUPPLY WATER TEMP
14	D.T. RETURN WATER TEMP
15	C.H. WTR FLOW SW.
16	HOT WTR FLOW SW.
17	D.T. WTR PUMP (P1, P2) OFF/AUTO
18	D.T. WATER PUMPS STATUS
19	SUPPLY WTR C.O. VALVE SUM/WIN
20	RETURN WTR C.O. VALVE SUM/WIN




SPACE SENSORS
QTY AS SHOWN

TEMP (TYP 4)
HUMID (TYP 2)

IMMERSION SENSOR
TYP 2



C.O. VALVE STATUS
TYP 2




PUMP STATUS
TYP 1

TERMINATIONS BY OWNER (FUTURE)

Ergon Systems
5500 Oakbrook Pkwy., Suite 210
Norcross, GA 30093

JOB NAME: ALTERATIONS TO BUILDINGS
205-206-207
.FT. MCPHERSON, GA.


JOB #	1789-09	TITLE	EMS TERMINATION	REV.
DATE	6-5-89	ENGINEER	FPC	4
		SALESMAN	FOS	4
				4



HEATING-COOLING FAN COIL UNITS (MIN. O.A.)
TYPICAL FOR 73 SETS

INTERLOCK WITH E.F. WIRING
BY ELEC. CONTR. SEE SHEET 10


HEATING-COOLING FAN COIL UNITS (100% O.A.)
TYPICAL FOR 10 SETS




EXHAUST OR SUPPLY FAN
TYPICAL FOR 10 SETS

* NOTE: REFER TO SHEET 1 FOR
PANEL TERMINATIONS

HEATING ONLY FAN COIL UNIT
TYPICAL FOR 11 SETS




TIME BLDG/CR.	TERMINAL	INTERLOCKED	EQUIPMENT
1	2	FCU 1-15, 39-41	SF-2, EF-1
2	4	FCU 16, 20, 22-38, 42-43	SF-1, EF-2, 3
3	8	FCU 44-76, 88, 91-95	SF-3, EF-4, 5
4	10	FCU 77-87, 89, 90	SF-5, EF-16



DUAL TEMPERATURE WATER

- * WIRE TO TERMINALS LOCATED IN CONTROL PANEL CP-1 (SHT. 1)
- ** WIRE TO TERMINALS IN EMS TERMINATION CABINET. (SHT. 4)

Ergon Systems 5500 Oakbrook Pky., Suite 210 Norcross, GA 30093	
JOB NAME ALTERATIONS TO: BLDGS 205, 206, 207 FT. MCPHERSON, GA	
DATE: 5-30-89	TITLE: BLDG 207
SALESMAN: FDS	ENGINEER: FPC
SHEET: 2	OF: 4



Ergon Systems
 5500 Oakbrook Pky., Suite 210
 Norcross, GA 30093

JOB NAME: ALTERATIONS TO: BLDGS 205 206 207
 FT. McPHERSON, GA.

JOB #	1789-09	TITLE	CONTROL PANEL	REV.
DATE:	5-31-89	SALESMAN	FOS	ENGINEER
			FPC	SHEET
			1	4

* MTD. ON FACE OF PANEL

BUILDING 246

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: CEL
 CHECKED BY: _____
 DATE: 12/31/91

BLDG.# 246
 ECO 1

WALL & ROOF INSULATION


AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS	see floor plan			
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>CONCRETE</u> 3. <u>FRAME WALL</u> 4. <u>GYP BRD</u> 5. _____ 6. _____ 7. INSIDE AIR FILM


SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. <u>ROOF DECK</u> 3. <u>AIR SPACE</u> 4. <u>6" FIBERGLASS</u> MS 5. <u>DROP CEILING</u> 6. _____ 7. INSIDE AIR FILM

PERSONNEL DOOR TYPE	<u>METAL (HOLLOW)</u>	BASEMENT []
OVERHEAD DOOR TYPE	<u>NONE</u>	SLAB [<input checked="" type="checkbox"/>]
		CRAWL SPACE []

COMMENTS:



⊗ Fire Extinguisher



⊗ Fire Extinguisher

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. KC OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE 12-31-91

BLDG.# 246
 ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
AHU Room	23x28 RA	□		64	FIBERGLASS	1"	GOOD
↓	23x29 OA	□	↓		↓	↓	↓
↓	29x40 RA	□					
	30" x 8'-6" SA	□				↓	↓

COMMENTS: SUPPLY AIR - 30" X 8'-6" WITH 4 ZONES

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Fl. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. OF
CALCULATED BY:
CHECKED BY:
DATE 12-31-91

BLDG.# 246
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
AHU ROOM	1 1/2"	10'	HW	150 F	64 F	FIBERGLASS	3/4"	*
↓	2"	20'	CW	-	64 F	↓	1"	GOOD
OUTSIDE CHILLER	2"	24'	CW	-	52 F	FIBERGLASS	1/2" WITH ALUMINUM WRAP	FAIR
BOILER ROOM	2"	100'	CW	-	60 F	↓	1"	GOOD
↓	1 1/2"	15'	HW	-	60 F	↓	3/4"	GOOD
↓	4"	25'	STM	-	60 F	↓	1"	GOOD

COMMENTS: NEW PIPE WORK WAS DONE TO HW, NO INSULATION.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____

CALCULATED BY: DL
 CHECKED BY: _____
 DATE: 12/31/91

BLDG.# 246
 ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
	TYPICAL DOUBLE PANE (NEW WINDOWS)	SLIDING	METAL	ALL	NONE	CURTAINS (OPEN)	45" x 50"

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KCC
CHECKED BY: _____
DATE: 12-19-91

BLDG.# 246
ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>1/3</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>MOT 323-6-EP</u>	VOLTS	<u>115</u>	AMPS	<u>6.1</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>BELL & GOSSETT</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>HW ^{CWC} PUMP MOTOR</u>	COMMENTS	<u>CONTROLLED BY ON-OFF SW.</u>				
MOTOR #	<u>2</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1745</u>
MODEL #	<u>2547</u>	VOLTS	<u>200</u>	AMPS	<u>15.6</u>		
SERIAL #	<u>954719.</u>	PRESENT HR.				TO	<u>SUMMER</u>
MFG	<u>LINCOLN</u>	REQUIRED HR.				TO	
FRAME	<u>184T</u>	EFF.					
DESCRIPTION	<u>CW PUMP MOTOR</u>	COMMENTS	<u>NOT RUNNING. OPERATE WHEN CHILLER RUNS</u>				
MOTOR #	<u>3</u>	HP	<u>15</u>	PH	<u>3</u>	RPM	
MODEL #		VOLTS	<u>208</u>	AMPS			
SERIAL #		PRESENT HR.				TO	
MFG	<u>US ELECTRIC MOTORS</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>AHU FAN MOTOR</u>	COMMENTS	<u>* NO NAME PLATE.</u>				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: KC
 DATE: 12/31/91

BLDG.# 246
 ECO 5

10+ HP MOTORS
 MEASURED

MOTOR#	<u>AHU</u>		PHASE A	PHASE B	PHASE C
LOCATION	<u>MECH</u>	KVAR	<u>9.8</u>		
MFG	<u>US ELECTRIC</u>	KVA	<u>9.8</u> 12.0		
MODEL #	<u>R-8905-00-938</u>	KW	<u>8.1</u>	<u>9.2</u>	
SERIAL #	<u>—</u>	PF	<u>65.5</u>		
FRAME	<u>254T</u>	HP			
HP	<u>15</u>	VOLTS	<u>206</u>	<u>207</u>	
RPM	<u>1765</u>	AMPS	<u>31.0</u>	<u>35.0</u>	
PRESENT	<u>0</u> TO	PH	<u>3</u>		
REQ HR.	TO	<u>3φ 60HZ. 200V 43A 1765</u>			

MOTOR #	_____		PHASE A	PHASE B	PHASE C
LOCATION	_____	KVAR			
MFG	_____	KVA			
MODEL #	_____	KW			
SERIAL #	_____	PF			
FRAME	_____	HP			
HP	_____	VOLTS			
RPM	_____	AMPS			
PRESENT	_____ TO	PH			
REQ HR.	_____ TO				
COMMENTS	_____				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/20/91

BLDG.# 246
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
NORTH WEST MEN'S	135°F

PROBLEMS:

COMMENTS:

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 246 BLDG NAME: ADMIN JOB: 3105.000

AHU NO: _____ LOCATION: _____

ZONE NO. SERVED: 4 ZONES REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
 HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
 OTHER []

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: 15 MFG: US ELECTRIC MOTOR MODEL: _____

CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
 HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
 REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
 HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
 COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: SETUP LIKE A SZ WITH BYPASS AIR - DECK ACTUATOR WORKING.

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
 RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
 RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
 MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
 FAN HP: _____ MFG: _____ MODEL: _____


THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
 PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:



- HD REMOVED - HW TIES IN WITH CW TO CD
 - HW 3 WAY VALVE MODULATE BY DECK TEMP. RA TEMP.

- HAVE PROBLEM WITH ZON CONTROL
 - TOO HOT TOO COLD IN DIFF. ZONES

JOB Ft. McPherson / Ft. Gillem Energy Study

SHEET NO. _____ OF _____

CALCULATED BY KL DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE NTS



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions



JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ # EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/31/91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 246 BLDG NAME: _____ JOB: 3105.000
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
BUILDING MANAGER NAME: _____
PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] - ZONE NO'S. _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: CHAPEL 6:00 (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F ~~7:00~~ TO 5:30, SAT TO _____, SUN TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT TO _____, SUN TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT TO _____, SUN TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT TO _____, SUN TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 246

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 12/31/91

CHECKED BY _____ DATE _____

SCALE _____

- ① REFRIG (FULLSIZE), TV, COFFEE POT (STANDARD OFFICE EQUIP)
- ② SMALL REFRIG, MICROWAVE
- ③ STANETID

EXIT SIGNS: ~~THL~~ ~~THL~~ II

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG. 246

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY KCC DATE 12-31-91

CHECKED BY _____ DATE _____

SCALE _____

TRANE CHILLER

MOD CGAC65E

SER LZHG60217

COMP. MOTOR 208/220 V 3 ϕ 264 FLA 10.5 LRA

COND MOTOR 208/220 V 3 ϕ 23 FLA 7.5 LRA

N.GAS BOILER YORK SHIPLEY, INC.


STEAMPAK GENERATOR STM

MOD SPHV-50-N2 93948

SER 78-11923 H-71341

CAP 1,675,000 BTU

STEAM 150



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

246




MU DUCT
ON ROOF

FEU PC 2

T/STAT	BYPASS	COIL
68°F SETPOINT	↑	↑
70°F HEATING	80°F	
84°F COOLING	84°F	

NITE SETBACK 55°F
TIMER NOT PROGRAMMED




E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 246

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY KC DATE 12-31-91
CHECKED BY _____ DATE _____
SCALE _____



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 246


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____



- OAT'STAT FOR HEATING "BT-1" ORIGINAL SETPOINT 55°F NOW SET AT 80°F

• TIMECLOCK DOES NOT FUNCTION

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

#246

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

6/5/47
HEAT COOL HEAT
B R
H H
H L
L L


Coil
X 0

Midway
X 0

HEAT x $\frac{OA}{70^{\circ}F}$
By pass COOL L 0 50°F
X 0


BOILER ON
USE ELECTRIC HEATER IN FRONT OFFICE

246



FUNCTIONAL DESCRIPTION
 System is placed under operation by manual control program (MCP) (EC-1). On power accepted schedule, automatic start signal is sent to compressor through a relay. A signal line (MCP-1) is provided to prevent starting if compressor is already running (MCP-2).
OPERATIONAL INSTRUCTIONS
 With system (MCP-1) will automatically begin heating or cooling by monitoring outdoor air temperature. Chill water pump will be started when outdoor air temperature is above 55°F. Hot water pump will be started when outdoor air temperature is below 55°F.
REMARKS
 With system (MCP-1) will monitor outdoor air temperature. On a fall in room temperature below some temperature, compressor (MCP-1) will start heating. On a rise in room temperature above some temperature, compressor (MCP-1) will start cooling. On a fall in room temperature below some temperature, compressor (MCP-1) will start heating. On a rise in room temperature above some temperature, compressor (MCP-1) will start cooling. On a fall in room temperature below some temperature, compressor (MCP-1) will start heating. On a rise in room temperature above some temperature, compressor (MCP-1) will start cooling.

DATE	1-17-65
BY	J. K. P.
FOR	CONTROL SYSTEM
PROJECT	STILLING E. 108
DESIGNED BY	J. K. P.
CHECKED BY	J. K. P.
APPROVED BY	J. K. P.
SCALE	AS SHOWN
NO.	1-17-65
REV.	1-17-65




1-1-18-1-1 CONTROL PANEL

24 V

TO OTHER ZONE THERMOSTATS (4 TOTAL)

TO OTHER ZONE MOTORS (4 TOTAL)

7246




Check the following items before starting the engine:

- 1. Check the oil level in the oil sump.
- 2. Check the water level in the cooling water tank.
- 3. Check the fuel level in the fuel tank.
- 4. Check the air filter for cleanliness.
- 5. Check the battery charge.
- 6. Check the engine room for any obstructions.
- 7. Check the engine room for any leaks.
- 8. Check the engine room for any unusual noises.
- 9. Check the engine room for any unusual smells.
- 10. Check the engine room for any unusual vibrations.

When starting the engine, the following procedure should be followed:



1. Put the engine stop valve to the 'STOP' position.
2. Turn the engine stop valve to the 'START' position.
3. Press the start button.
4. When the engine starts, check the oil level, water level, fuel level, air filter, battery charge, engine room for obstructions, engine room for leaks, engine room for unusual noises, engine room for unusual smells, engine room for unusual vibrations.

Project	INSULATION FOR BULLHEAD, 24
Location	BASE INSULATION, CANTON
Contractor	W. J. M. CO.
Inspector	W. J. M. CO.
Date	4-17-55



246

GENERAL NOTES AND EQUIPMENT SCHEDULE



Program Occupancy

System is placed into operation by panel mounted program clock (PC-4). On day as occupied schedule, unit supply fan will run continuously.

A night low limit thermostat (TL) is provided to prevent heating operation dropping below 55°F (adjustable).

Heat/Cool Indenting


Both thermostat (BT-1) will automatically index heating or cooling by sensing air temperature. Chill water pump will be energized when outdoor air temperature above 55°F. Hot water pump will be energized when outdoor air temperature is below 55°F.

Heating

With system indexed to heating and on a fall in space temperature below reset temperature, respective face and bypass damper will modulate open to the heating coil (bypassing cooling coil) to satisfy heating demand. On a space temperature rise, and bypass damper will modulate closed to the heating coil and modulate open to a bypass duct or cooling coil. (Cooling is OFF below 55°F outdoor air temperature.)

Cooling

With system indexed to cooling and on a space temperature rise above reset temperature, respective face and bypass damper will modulate open to the cooling coil (bypassing heating coil) to satisfy cooling demand. On a space temperature fall, and bypass damper will modulate open to the bypass duct or heating coil. (Heating is OFF above 55°F outdoor air temperature.)



246

REVISIONS		JOB NAME	RENOVATIONS FOR BUILDING 246
DATE	CHANGE	LOCATION	PORT HENRI, GEORGIA
		ARCHITECT	WILBUR TOWNSHEND
		ENGINEER	WILLIAM E. OWEN
		CONTRACTOR	W. B. BOCH
		DRAWN BY	J. W. P.
		CHECKED BY	
		DATE	4-17-95
		DRAWING NO.	65-C5-773
		CONTROL SYSTEM	
		W. J. VIELLET COMPANY	

BUILDING 250

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ of _____

CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/31/91

BLDG.# 250
ECO 2

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE--SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
1	SINGLE	FIXED	METAL	N/W	GRAY	VECT BLINDS	22'7" x 7'
1	"	"	"	N	"	"	32" x 76"
1	"	"	"	W	"	"	"

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: _____

BLDG.# 250
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
D	EXCEL		E	40x80	1
D	"		N	"	1
D	"		S	"	1

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 1/6/92

BLDG.# 250
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
TECHNICAL SERVICES OFFICE	84°F

PROBLEMS:

COMMENTS: THE HOT WATER IN THIS BUILDING IS HEATED
BY USE OF TWO INSTANT H/W HEATERS LOCATED
UNDER THE SINKS. THE MEN'S & WOMEN'S ROOM
ARE HEATED BY THE SAME UNIT, HOWEVER, IT IS
NOT WORKING AT PRESENT TIME.
HEATER NAMEPLATE: INSTANT-FLOW WATER HEATER
M# S-30L S# 95075
120V 3000W 27A

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CS
 CHECKED BY: _____
 DATE: Jan 6, 1992

BLDG.# 250
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
Main Room	106	4	34	F	ON	Y	N	Dial controls sects. of lights	N
SW Storage	3	4	34	F	ON	Y	Y	1	Y
SW Office	2	4	34	F	ON	Y	Y	1	N
Tech. Services	4	4	34	F	ON	Y	N	1	N
Tech services	4	4	34	F	ON	Y	N	1	N
Docu. Section	6	4	34	F	ON	Y	N	2	N

OF EXIT SIGNS - _____

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 250

JOB Ft. McPherson/Ft. Gillem Energy Study

SHEET NO. EMC # 3105.000 OF _____

CALCULATED BY CS DATE 1/6/92

CHECKED BY _____ DATE _____

SCALE _____

In the middle of the Library there is a ^{approx.} 26 x 26 fixture. There are lights above plastic paneling and they can not be counted. The lights are four foot F. lights.

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 25D

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 1/6/92

CHECKED BY _____ DATE _____

SCALE _____

INSIDE AIR TEMP. \Rightarrow 73.3°F

OA TEMP AT 10:30AM \Rightarrow 60°F

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____
 SHEET NO. _____ OF _____
 CALCULATED BY _____ DATE _____
 CHECKED BY _____ DATE _____
 SCALE _____

BLDG. 250

CARRIER

MOD	50QHO08530DA
SER.	1289G35061
COMP.	2 - 208V 3 ϕ 60 HZ 16.5A
COND. FAN	2 - 208V 1 ϕ 60 HZ 2.9A 0.5HP, 0.37KW
EVAP FAN	1 - 208V 3 ϕ 60 HZ 5.7A 1.5HP 1.12KW

SINGLE ZON PACKAGE UNIT WITH OA DUCT 12" X 12"



EAST
 - UNIT IS RUNNING

* SHOULD INSULATE SA DUCT \approx 15' LONG.

THIS IS TYPICAL OF 3 UNIT

M 10-5
 T

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/31/91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 250 BLDG NAME: LIBRARY JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____
 PHONE: _____ OFFICE NO. _____

SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] _____ - ZONE NO'S. _____

T-TH
10-7pm

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 10:00 TO 5:00, SAT 12:00 TO 5:00, SUN closed
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

BUILDING 358

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/20/91

BLDG.# 358
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. _____
	3. _____
	4. _____
	5. _____
	6. _____
	7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. _____
	3. _____
	4. _____
	5. _____
	6. _____
	7. INSIDE AIR FILM

PERSONNEL DOOR TYPE _____	BASEMENT [] SLAB [] CRAWL SPACE []
OVERHEAD DOOR TYPE _____	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. KC OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE 12-9-91

BLDG.# 858
 ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH 1	3"	40'	HW	120°F	55°F	HARD BUK FOAM	1 3/4"	FAIR
MECH 1	1 1/2"	40'	HW	120°F	55°F	BULK RUBBER	3/4"	GOOD
AHU-1,2,3	1 1/2" HW & 3" CW	200'				FG. W/PAINT	2"	GOOD
AHU 5	NO PIPE							
AHU 6	1 1/2" PIPE	25'	HW			RUBBER	3/4"	GOOD
MECH 2	3"	10'	CW	NOT RUN	50°F	FB	1 1/2"	*
AHU 4	1 1/4"	30'	CW & HW	-		RUBBER	1"	**

COMMENTS: * MISSING INSL TO & FROM PUMP (CW)
 * NEED INSL 10'

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. KC
CALCULATED BY:
CHECKED BY:
DATE: 12-19-91

BLDG.# 358
ECO 1

DUCT INSULATION

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SURROUND AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
AHV-1							
AHV-2							
AHV-3	36" X 15'	□	NOT RUNNING	50°	R & W/F	2"	*
AHV5		□	↓	50	↓	↓	GOOD
AHV6	16" X 38"	□	68°F	50	↓	↓	GOOD **
AHV 4	36" X 24" SA DUCT	□	NOT RUNNING	60°	NONE		NONE
↓	18" X 80 RA DUCT	□	↓	↓	↓		↓

COMMENTS: * INSL. WAS CUTOUT ON ONE SIDE 36" X 14"
** SECTION OF INSL WAS REMOVED 4' long

BLDG.# 358
ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
① W	NONE	LOW	E	30x53	25 ³³
STORM WINDOW	FAIR/POOR	MED/HIGH	E	30x53	25 ³³
D	GOOD	LOW	CENTER EAST	34x80	1
② D	POOR	MED	SOUTH EAST	11	1
D	EXCEL	NONE	NORTH EAST	11	1
D	FAIR	LOW	SOUTH WEST	11	1
② D	POOR	MED	N	11	1

COMMENTS:
 ① INFILTRATION LOW BECAUSE STORM WINDOWS
 INSTALLED. ② DOOR IS WARPED CAUSING 1/4" AIR GAP
 AT TOP CORNER.

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/20/91

BLDG.# 358
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
NORTH WEST WEST MEN'S ROOM	134°F
SOUTH EAST MEN'S ROOM	139°F

PROBLEMS:

COMMENTS:

BLDG.# 358
ECO 5

MOTORS

MOTOR #	<u>7</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	
MODEL #	<u>6-357370-40</u>	VOLTS	<u>200</u>	AMPS	<u>21</u>		
SERIAL #		PRESENT HR.		<u>SUMMER</u>		TO	
MFG	<u>CENTURY</u>	REQUIRED HR.				TO	
FRAME	<u>M184TCZ</u>	EFF.	<u>85.5</u>				
DESCRIPTION	<u>CWP MOTOR.</u>	COMMENTS					
MOTOR #	<u>8</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>SK49UG6001</u>	VOLTS	<u>208</u>	AMPS	<u>6.8</u>		
SERIAL #		PRESENT HR.		<u>0</u>		TO	<u>2000</u>
MFG	<u>GE</u>	REQUIRED HR.				TO	
FRAME	<u>145T</u>	EFF.					
DESCRIPTION	<u>AHU-4</u>	COMMENTS	<u>T'STAT</u>				
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION		COMMENTS					

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE: 12-19-91

BLDG.# 358
ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	<u>1735</u>
MODEL #	<u>2G2-4</u>	VOLTS	<u>200</u>	AMPS	<u>7.8</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>WELLMAN US. ELEC. MOTOR.</u>	REQUIRED HR.		TO			
FRAME	<u>145JP</u>	EFF.					
DESCRIPTION	<u>HW CIR.</u>	COMMENTS	<u>ONLY IN WINTER BOILER TEMP. SETTING 120°F</u>				
MOTOR #	<u>2</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1730</u>
MODEL #	<u>F-3485-00291</u>	VOLTS	<u>200</u>	AMPS	<u>16.6</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>US ELEC. MOTORS</u>	REQUIRED HR.		TO			
FRAME	<u>184T</u>	EFF.					
DESCRIPTION	<u>AHU-1</u>	COMMENTS	<u>T'STAT CONTROL</u>				
MOTOR #	<u>3</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	
MODEL #	<u>5XBLO26D</u>	VOLTS	<u>115</u>	AMPS	<u>7.8</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>GE</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU-2</u>	COMMENTS	<u>T'STAT CONTROL</u>				

BLDG.# 358
ECO 5

MOTORS

MOTOR #	<u>4</u>	HP	<u>1</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>5K43MG8046X</u>	VOLTS	<u>230</u>	AMPS	<u>3.8</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>GE</u>	REQUIRED HR.	<u>7:00</u>	TO	<u>400 PM</u>		
FRAME		EFF.					
DESCRIPTION	<u>AHU-3</u>	COMMENTS	<u>T' STAT CONTROL</u>				
MOTOR #	<u>5</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	
MODEL #		VOLTS	<u>115V</u>	AMPS	<u>9 MAX</u>		
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU-5</u>	COMMENTS	<u>T' STAT CONTROL</u>				
MOTOR #	<u>6</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #	<u>5K43MG768010</u>	VOLTS	<u>230</u>	AMPS	<u>9.2</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>GE</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU-6</u>	COMMENTS	<u>T' STAT CONTROL</u>				

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-19-91
BY: KC

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: DEH JOB: 3105.000
AHU NO: 1 LOCATION: NW

ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: TRANE MODEL: _____
SUPPLY FAN: FAN HP: 5 MFG: US ELEC MODEL: _____

CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: MODULATING ELEC. ACTUATOR

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: RETURN AIR PULL THROUGH WALL (NEAR COFFE POTS)

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

JOB Ft. McPherson / Ft. Gillem Energy Study

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE NTS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions

AHU-1

SZ UNIT



- RETURN AIR FROM HALLWAY
- CAN NOT DUCT IN OA, PHYSICAL RESTRICTION & LOCATION
- AHU - CONTROL BY T'STAT - CYCLE FAN ON/OFF
- THE CLOSET IS A RETURN AIR RENUM
- SA DUCTS ARE NOT INSULATED IN THE CLOSET

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-19-91
BY: KC

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: _____ JOB: _____
AHU NO: 2 LOCATION: _____
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: MAGIC AIR MODEL: MAVBC/ANBC-5

SUPPLY FAN: FAN HP: 1/2 MFG: GE MODEL: _____

CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F 0 TO 2400, SAT 0 TO 2400, SUN 0 TO 2400

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: PIPE HAS GOOD INSULATION

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

JOB Ft. McPherson / Ft. Gillem Energy Study

SHEET NO. _____ OF _____

CALCULATED BY K- DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE NTS

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions

AHU-2



Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-19-91
BY: EC

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: DEH JOB: _____
AHU NO: 3 LOCATION: _____
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: CARRIER MODEL: 4085-008-540
SUPPLY FAN: FAN HP: 1 MFG: GE MODEL: 5K43 M6 8046X

CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: NO OA. DUCT

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions

AHU-3



6' CEILING

- COULD TAP TO SIDE OF RA DUCT & UP TO ROOF FOR OA

Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-19-91
BY: _____

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: DEH JOB: _____
AHU NO: 4 LOCATION: _____
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] _____

MFG: _____ MODEL: _____
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED []
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO []
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS: _____

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions

AHU-4



Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-19-91
BY: kc

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: DLIT JOB: 3105.000
AHU NO: 5 LOCATION: _____

ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: CARRIER MODEL: 5855100-CC

SUPPLY FAN: FAN HP: 1/2 MFG: _____ MODEL: _____

CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV [] ✓ PURANLE
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] ✓ SPRAY [] OTHER []

REMARK: SMALL HOME TYPE UNIT

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

JOB Ft. McPherson / Ft. Gillem Energy Study

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE NTS


E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions



Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-19-91
BY: LEC

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: DEH JOB: _____
AHU NO: 6 LOCATION: _____

ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: CARRIER (4DRS-024-D10) MODEL: 9

SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____
CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [✓] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [✓] ELEC [] MOD VLV []
REHEAT: NONE [✓] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [✓] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [✓] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

JOB Ft. McPherson / Ft. Gillem Energy Study

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-19-91

CHECKED BY _____ DATE _____

SCALE NTS

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:

Sketch AHU, Ductwork

Note Dampers, Actuators, Dimensions

AHU-6



JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/20/91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 358 BLDG NAME: DEH JOB: 3105.000
PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
AUDITORIUM [] - ZONE NO'S. _____
LABORATORIES [] - ZONE NO'S. _____
CAFETERIA [] - ZONE NO'S. _____
OTHER [] - ZONE NO'S. _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F 0630 TO 1700, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 358

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 12/20/91

CHECKED BY _____ DATE _____

SCALE _____

SPACE TEMPERATURES

OA TEMP AT 12:20PM = 52°F

MAIN LOBBY (EAST) = 67°F

SOUTH HALLWAY = 67.8°F

CENTER ENGINEERING ROOMS = 71.0°F

NORTH WEST CORNER = 71°F

BLUEPRINT ROOM (NORTH) = 74°F

NORTH EAST CORNER = 72.5°F

BUILDING 360



EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 2/6/92

BLDG.# 360
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM .17 2. 8" CMU 1.24 3. BRICK 1.24 4. EXT. INSUL 3" 11 5. _____ 6. _____ 7. INSIDE AIR FILM .68 14.33
SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM .17 2. ROOF MEMBRANE 1.25 3. (2) 1.5 RIGID INSUL 2.2 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM .68 24.1
PERSONNEL DOOR TYPE _____	BASEMENT []
OVERHEAD DOOR TYPE _____	SLAB []
	CRAWL SPACE []

COMMENTS:

BLDG.# 320

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
<i>1st floor kitchen</i>	<i>105°F</i>
<i>2nd floor Hall</i>	<i>105°F</i>
PROBLEMS:	

COMMENTS: *Max Temp. Reached in 10 min. after start*
each fixture

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 360

MOTORS

MOTOR #	<u>FAN MOTOR</u>	HP	<u>7 1/2</u>	PH	<u>3φ</u>	RPM	<u>1725</u>
MODEL #	<u>CAT M3311T</u>	VOLTS	<u>208V</u>	AMPS	<u>23</u>		
SERIAL #	<u>F1189</u>	PRESENT HR.				TO	
MFG	<u>BALDOR</u>	REQUIRED HR.				TO	
FRAME	<u>213T</u>	EFF.	<u>85.5</u>				
DESCRIPTION	<u>AHU</u>	COMMENTS	<u>NEW MOTOR</u> <u>PF 0.75</u>				

MOTOR #	<u>HW PUMP FOR AHU.</u>	HP	<u>1/10</u>	PH	<u>1φ</u>	RPM	
MODEL #		VOLTS	<u>115V</u>	AMPS			
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>HW RECIR. PUMP</u>	COMMENTS					

MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION		COMMENTS					

Ft. Story EMCS Feasibility Study
EMC# 3104.000

DATE: 12-10-91
BY: KC

II. PERIMETER RADIATION SURVEY OBSERVATIONS

BLDG NO: 360 BLDG NAME: COMMISARY JOB: 3105.000

PER. RAD. NO. 1, 2, 3, 4 LOCATION: LOADING DOCK

AREA SERVED _____

PERIMETER RADIATION TYPE: STEAM [] HOT WATER [] ELECTRIC []
OTHER [] GAS FURNACE

SOURCE OF HEATING MEDIUM: _____

ZONE HW PUMPS: NO. OF PUMPS _____ PUMP 1 HP _____ ZONE NO. _____
PUMP 2 HP _____ ZONE NO. _____
PUMP 3 HP _____ ZONE NO. _____
PUMP 4 HP _____ ZONE NO. _____

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

TEMPERATURE CONTROL MFG. AND TYPE: ROOM THERMOSTAT [] ZONE THERMOSTAT []
OUTSIDE AIR RESET [] SET POINT _____ °F
2-WAY VALVE [] 3-WAY VALVE []
ZONE PUMP CONTROL []
OTHER []

REMARKS:

T'STAT SETAT 80°F WITH SWITCH OFF
FAN MOTOR WESTING HOUSE SER EA85 TYPE FH
3/4 HP RPM 1725 115V 1Ø 11A
CAT # 15001 (GOOD CONDITION)

ITT GRINNELL MODEL# BLO-250 SERIAL # C8546028
INPUT 250,000 BTUH OUTPUT 192,500 BTUH NAT GAS
THERMAL EFF 77% POWER CONSUMPTION 650W
FOR OPERATION AT TEMP. RANGE FROM 50 TO 80°F
ELEC RATING 115V 1Ø 13.8A.

JOB 3105.000

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-10-91

CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG. 360

- SHOULD INSULATE HW PIPE

- AHU SINGLE ZONE HW & DX COILS

- HW BOILER GAS FIRE BURNHAM

HW PUMP SMALL

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105

SHEET NO. _____ OF _____

CALCULATED BY CE DATE 12/10/91

CHECKED BY _____ DATE _____

SCALE _____

360

COMPRESSORS

COMPRESSOR

MODEL

FANS

- 11 WITT WS075HZ 208V 30.2 A 3 PH 60HZ 200V 3A 5 PH 1/2 HP
- 12 G & W Behm RCD-21S 208V 30.2 A 3 PH 60HZ 200V 3A 5 PH 1/2 HP

A }
 B }
 C } Room locked,
 D } looks identical to cond. unit B
 E }

E M C ENGINEERS, INC.


Denver • Colorado Springs • Atlanta • West Germany

JOB 3105
 SHEET NO. _____ OF _____
 CALCULATED BY ORL DATE 12/10/0
 CHECKED BY _____ DATE _____
 SCALE _____

360

COOLERS

MANUF.	MODEL	COMPRESSOR	FANS
1. COPELAND	HTDB-1000-TFC-001	208V, 42A, 3PH, 60HZ	2 ea, 208V, 4.1A, 1/2HP ON
3. "	9RS3-0765-TFC	208V, 29.4A, 3PH, 60	2 ea, 208V, 1.7A, 1/4HP OFF ACCUMS
14 HUSSMAN	H760 FSK2110663	208V, 29.4A, 3PH, 60	2 ea, 208V, 1.7A, 1/5HP
	SER. NO. 6507150		
13 GW Bohn	B811ZHB	220V, 22A, 3PH, 60 HZ	1 ea, 220V, 2.3A, 3/4HP
Heat Transfer Division	SER. NO. B93642103	208V, 31.2A, 3PH, 60	2 ea, 208V, 4.0A, 1/7HP ea
15 WARREN	SAHU 7550L	208V, 12.7A, 3PH, 60 HZ	1 ea, 208V, 4.1A, 1/2 HP
14	B311ZHC	208V, 29.4A, 3PH, 60 HZ	1 ea, 208V, 1.7A, 1/4HP
17 COPELAND	9RS3-0765-TFC	208V, 29.4A, 3PH, 60 HZ	1 ea, 208V, 1.7A, 1/4HP
8 KYSOR	SAHU-70-FC	230V, 5.4A, 1PH,	1 ea, 208V, 1.5A, 1/4HP
7 "	SAHU-150-FC	208V, 5.10A 3PH	1 ea, 208V, 1.5A, 1/4 HP
9 ND NAMEPLATE		208V, 19.2A, 3PH	1 ea, 208V, 3 A 1/2 HP
16 WITT	WS050 HZ		



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

LOADING DOCK



22 1/2' CEILING HEIGHT

THERE IS AN EXISTING AIR CURTAIN.

COMMISSARY HR.

SUN, MON CLOSED
TUE-FRI 1000-1800
SAT 0930-1730

BUILDING 363

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 363
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Bath Room 17 DZ	101
Janitor Cl. 14 F1	122
Janitor C 11 F1	129.8
BR 8 F2	128
BR 1 C2	111
BR 2-4 G1	134
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 363
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
<u>HWP-1</u>				
DESCRIPTION <u>Hot Water Supply</u>	VOLTS	<u>477</u>	<u>475</u>	
MFG <u>US Electrical Motor</u>	AMPS	<u>7.5</u>	<u>8.7</u>	
MODEL # <u>N03N0310554E</u>	KW	<u>6.2</u>		
SERIAL # _____	KVAR	<u>3.0</u>		
FRAME <u>215 JM</u>	KVA	<u>7.2</u>		
HP <u>10</u> RPM <u>3500</u>	PF	<u>85.2</u>		
VOLT <u>230/460</u>		% MOTOR SPEED _____ %		
AMPS <u>24.4/12.2</u>		PRESENT _____	TO _____	
EFF. <u>88.5</u>		REQ HR. _____	TO _____	
COMMENTS _____				

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION <u>Standby Condenser Pump</u>	VOLTS			
MFG <u>Baldor</u>	AMPS			
MODEL # <u>JMM2915T</u>	KW			
SERIAL # _____	KVAR			
FRAME <u>256 JM</u>	KVA			
HP <u>20</u> RPM <u>1760</u>	PF			
VOLT <u>230/460</u>		% MOTOR SPEED _____ %		
AMPS <u>50/25</u>		PRESENT _____	TO _____	
EFF. <u>86</u>		REQ HR. _____	TO _____	
COMMENTS _____				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 363
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>Standby Chill Water (2)</u>			
MFG	<u>Baldor</u>			
MODEL #	<u>JMH 35131</u>			
SERIAL #				
FRAME	<u>215JM</u>			
HP	<u>10</u> RPM <u>1725</u>			
VOLT	<u>208-230/460</u>	% MOTOR SPEED _____ %		
AMPS	<u>30-28/14</u>	PRESENT _____ TO _____		
EFF.	<u>85</u>	REQ HR. _____ TO _____		
COMMENTS _____				

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>5A AHU-5A Rm 13F2</u>			
MFG	<u>Carrier (Baldor)</u>			
MODEL #	<u>39ED08 M3211T</u>			
SERIAL #				
FRAME	<u>182T</u>			
HP	<u>3</u> RPM <u>1725</u>	<u>75 - nameplate</u>		
VOLT	<u>208-230/460</u>	% MOTOR SPEED _____ %		
AMPS	<u>9.8-8.6/4.3</u>	PRESENT _____ TO _____		
EFF.	<u>82</u>	REQ HR. _____ TO _____		
COMMENTS _____				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 363
 ECO 5

MOTORS

MOTOR #	<u>1</u>	HP	<u>10</u>	PH	<u>3</u>	RPM	<u>1750</u>
MODEL #	<u>Century 6-357722-01</u>	VOLTS	<u>460</u>	AMPS	<u>12.5</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>Century</u>	REQUIRED HR.		TO			
FRAME	<u>SZ15T</u>	EFF.	<u>85.6</u>				
DESCRIPTION	<u>AHU #1</u>	COMMENTS	<u>477 12.3 8kW 5.8kVAR 477 11.6 7.0kVA 82.9%PF</u>				
MOTOR #	<u>2</u>	HP		PH		RPM	
MODEL #	<u>OTHER FORM</u>	VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU #2</u>	COMMENTS					
MOTOR #	<u>3</u>	HP	<u>5</u>	PH	<u>60</u>	RPM	<u>1740</u>
MODEL #	<u>unreadable</u>	VOLTS		AMPS			
SERIAL #	<u>cat No #124</u>	PRESENT HR.		TO			
MFG	<u>Marathon</u>	REQUIRED HR.		TO			
FRAME	<u>1B4T</u>	EFF.	<u>81</u>				
DESCRIPTION	<u>AHU #3</u>	COMMENTS					

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 363
ECO 5

10+ HP MOTORS

MEASURED

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>Condenser Pump</u>	<u>475</u> <u>480</u>	<u>475</u> <u>483</u>	
MFG	<u>Southwest Pump & Equip Co</u>	<u>9.9</u>	<u>13.4</u>	
MODEL #	<u>UVH 254TTDR 5044AA L</u>	<u>7.9</u>		
SERIAL #		<u>6.2</u>		
FRAME	<u>254JM</u>	<u>10</u>		
HP	<u>15</u> RPM <u>1460</u>	<u>28.89</u>		
VOLT	<u>230/460</u>	% MOTOR SPEED _____ %		
AMPS	<u>39/19.5</u>	PRESENT _____ TO _____		
EFF.	<u>88.5</u>	REQ HR. _____ TO _____		
COMMENTS _____				

MOTOR#		PHASE A	PHASE B	PHASE C
DESCRIPTION	<u>Chill Water ^{Return} Pump</u>	<u>482</u>	<u>481</u>	
MFG	<u>US Electrical Motors</u>	<u>12.8</u>	<u>10</u>	
MODEL #	<u>65-0956-116 K 210656</u>	<u>9.3</u>		
SERIAL #		<u>4</u>		
FRAME	<u>215JM</u>	<u>10.1</u>		
HP	<u>15</u> RPM <u>3400</u>	<u>91.9</u>		
VOLT	<u>230/460</u>	% MOTOR SPEED _____ %		
AMPS	<u>36.5/18.2</u>	PRESENT _____ TO _____		
EFF.	<u>85.5</u>	REQ HR. _____ TO _____		
COMMENTS _____				

BLDG.# 363
 ECO 5

MOTORS

MOTOR #	<u>16</u>	HP	<u>1/8</u>	PH	<u>1</u>	RPM	
MODEL #		VOLTS	<u>115</u>	AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>EF-1</u>	COMMENTS					
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					

BLDG.#
ECO 5

363

MOTORS

MOTOR #	HP	PH	RPM
	<u>7.5</u>		<u>1750</u>
CAT MODEL #	VOLTS		AMPS
<u>H12B</u>	<u>230/460</u>		<u>23/10.8</u>
MOD #	<u>XOVAZI3TTDR702 6G-PL</u>		
SERIAL #	PRESENT HR.	TO	
MFG	REQUIRED HR.	TO	
FRAME	EFF.		
DESCRIPTION	COMMENTS		
<u>AHU# 2</u>	<u>NEW</u>		
MOTOR #	HP	PH	RPM
MODEL #	VOLTS		AMPS
SERIAL #	PRESENT HR.	TO	
MFG	REQUIRED HR.	TO	
FRAME	EFF.		
DESCRIPTION	COMMENTS		
MOTOR #	HP	PH	RPM
MODEL #	VOLTS		AMPS
SERIAL #	PRESENT HR.	TO	
MFG	REQUIRED HR.	TO	
FRAME	EFF.		
DESCRIPTION	COMMENTS		

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 363
ECO 5

MOTORS

MOTOR #	<u>13</u>	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	<u>CP - 1</u>	COMMENTS	_____				
MOTOR #	<u>14</u>	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	<u>CWP - 1</u>	COMMENTS	_____				
MOTOR #	<u>15</u>	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	<u>HWP - 1</u>	COMMENTS	_____				

BLDG.# 363
ECO 5

MOTORS

MOTOR #	<u>10</u>	HP	<u>20</u>	PH	<u>3</u>	RPM	<u>1755</u>
MODEL #	<u>MARATHON XB256TVR7329FNW</u>	VOLTS	<u>200</u>	AMPS	<u>59</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>MARATHON</u>	REQUIRED HR.		TO			
FRAME	<u>256T</u>	EFF.	<u>87.5</u>	<u>84%PF</u>			
DESCRIPTION	<u>AHU 10</u>	COMMENTS					
							200 203 4 30 30 kW 5.5 kVA 8.9 kW 10.7 PF 52%
MOTOR #	<u>11</u>	HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>AHU 11</u>	COMMENTS	<u>inaccessible / above high ceiling</u>				
MOTOR #	<u>12</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1730</u>
MODEL #	<u>WVCLB2TDR7627AD</u>	VOLTS	<u>200</u>	AMPS	<u>10.4</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>Marathon</u>	REQUIRED HR.		TO			
FRAME	<u>LB2T</u>	EFF.	<u>81.5</u>	<u>77.7 PF</u>			
DESCRIPTION	<u>AHU 12</u>	COMMENTS					

AHU - 13. above ceiling 2nd floor

BLDG.# 363
 ECO 5

MOTORS

MOTOR #	<u>7</u>	HP	<u>7.5</u>	PH	<u>60</u>	RPM	<u>1750</u>
MODEL #	<u>H-125</u>	VOLTS	<u>208-230/460</u>		AMPS	<u>24-21.6/10.8</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Marathon</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>213T</u>	EFF.	<u>84</u>	PF	<u>76.6</u>	_____	
DESCRIPTION	<u>AHU 7</u>	COMMENTS	_____				

MOTOR #	<u>8</u>	HP	<u>7.5</u>	PH	<u>60</u>	RPM	<u>1750</u>
MODEL #	<u>H-125</u>	VOLTS	<u>208-230/460</u>		AMPS	<u>24-21.6/10.8</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>Marathon</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>213T</u>	EFF.	<u>84</u>	PF	<u>76.6</u>	_____	
DESCRIPTION	<u>AHU 8</u>	COMMENTS	_____				

MOTOR #	<u>9</u>	HP	<u>15</u>	PH	<u>3</u>	RPM	<u>1745</u>
MODEL #	_____	VOLTS	<u>230/460</u>		AMPS	<u>39/19.5</u>	
SERIAL #	_____	PRESENT HR.	_____	TO	_____	_____	
MFG	<u>MARATHON</u>	REQUIRED HR.	_____	TO	_____	_____	
FRAME	<u>254</u>	EFF.	<u>88.5</u>	PF	81.7 <u>81.7%</u>	_____	
DESCRIPTION	<u>AHU 9</u>	COMMENTS	_____				

v.ltr 465 463
 Amp 2.9 8.8
 Kw 3.8
 6.6
 7.6
 458

BLDG.# 363
 ECO 5

MOTORS

MOTOR #	<u>4</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1740</u>
CAT	<u>H124</u>	VOLTS	<u>208-230/460</u>		AMPS	<u>13.8-13.2/6.6</u>	
MODEL #		SERIAL #		PRESENT HR.		TO	
MFG	<u>Marathon</u>	REQUIRED HR.		TO			
FRAME	<u>184T</u>	EFF.	<u>85.5</u>		<u>81</u>	PF	
DESCRIPTION	<u>AHU 4</u>	COMMENTS					

MOTOR #	<u>5</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1730</u>
MODEL #	<u>Marathon</u>	VOLTS	<u>208-230/460</u>		AMPS	<u>9.4-9/4.5</u>	
Model		SERIAL #	<u>XVA182TT DR7026WG</u>	PRESENT HR.		TO	
MFG	<u>Marathon</u>	REQUIRED HR.		TO			
FRAME	<u>182T</u>	EFF.	<u>81.5</u>				
DESCRIPTION	<u>AHU 5</u>	COMMENTS	<u>Economizer</u>				

MOTOR #	<u>6</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1740</u>
Cat	<u>H124</u>	VOLTS	<u>208-230/460</u>		AMPS	<u>13.8-13.2/6.6</u>	
MODEL #		SERIAL #		PRESENT HR.		TO	
MFG	<u>Marathon</u>	REQUIRED HR.		TO			
FRAME	<u>184T</u>	EFF.	<u>85.5</u>				
DESCRIPTION	<u>AHU 6</u>	COMMENTS					

BLDG.# 363
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1	10	2 ^{8'}		F	ON	Y	N	1	Y
	6	1		MH	ON	Y	N	1	Y
2	2	4	34	F	ON	Y	Y	1	Y
3	2	4	34	F	ON	Y	Y	1	Y
4	9	2 ^{8'}	?	F	6 ON	Y	N	1	Y
5	2	2 ^{8'}		F	ON	Y	N	1	Y
6	6	4 ₁	34	F	ON	Y	Y	1	Y
7	7	2 ^{8'}		F	4 ON	Y	N	1	Y
8	5	2 ^{8'}		F	ON	Y	N	1	N
9	17	2 ^{8'}		F	ON	Y	N	1	Y
	2	1		MH	ON	Y	N	1	Y
10	8	2 ^{8'}		F	ON	Y	N	1	Y N
11	19								
12	5	2 ^{8'}		F	ON	Y	N	1	Y
	6	1	200	I	ON	Y	N	1	Y
A	4	1	54	I	OFF	N	N	1	N
C	1	2 ^{8'}		F	OFF	Y	N	1	N
B	1	1	54	I	OFF	Y	N	1	N

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 365
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
22	2	4	34	F	OFF	Y	Y	1	N
23	2	"	"	"	ON	Y	Y	1	Y
24	10	"	"	"	OFF	Y	Y	2	N
25	4	"	"	"	OFF	Y	Y	1	N
26	2	"	"	"	OFF	Y	Y	1	N
27	11	"	"	"	"	"	"	"	"
28	DITTO								
29	1	"	"	"	"	"	"	"	"
30	1	"	"	"	"	"	N	1	N
	1	2'	?	F	OFF	Y	N	1	N
31	29 29	2 8'		F	OFF	Y	N	1	N
	49 49	1	100	IMH	OFF	Y	N	1	N
32	2	4	34	F	OFF	Y	N	1	N
33	3	2 8'		F	ON	Y	N	1	Y
34	8 13	2 8'		F	OFF	Y	N	1	N
36	1	2 8'		F	ON	Y	N	1	Y
37	3	100	100	I	OFF	Y	N	1	N
35	30	2 8'		F	ON	Y	N	1	Y

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: _____
 CHECKED BY: _____
 DATE: _____

BLDG.# 367
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
37	6	4	34	F	ON	Y	Y	1	Y
	2	2 ^u	40	F	ON	Y	Y	1	Y
38	4	2 ^{8'}	34	F	ON	Y	N	1	Y
39	2	2 ^u	40	F	ON	Y	Y	1	Y
40	2	4	34	"	"	"	"	1	"
40	3	11	"	"	"	"	"	1	"

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: _____
CHECKED BY: _____
DATE: _____

BLDG.# 363
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
D	1	1	54	I	OFF	Y	N	1	N
E	3	4	34	F	ON	Y	N	1	Y
	1	1	300	I	OFF	Y	N	1	Y
F	2	4 2	34	F	ON	Y	Y	1	Y
	4	2 ⁸¹		F	ON	Y	Y	1	Y
13	3	1	*	MH	ON	Y	N	1	Y
14	5	2 ⁸¹		F	ON	Y	N	1	Y
	10	1	150	I	OFF	Y	N	1	N
15	3	1	150	I	OFF	Y	N	1	N
16	3	1		MH	OFF	Y	N	1	N
	16	2 ⁸¹		F	OFF	Y	N	1	N
17	6	2 ⁸¹		F	OFF	Y	N	1	N
18	13 3	2 ⁸¹		F	OFF	Y	N	1	N
	9	1	100	I	OFF	Y	N	1	N
	11 1	1		MH	ON	Y	N	1	Y
19	4	4	34	F	OFF	Y	Y	1	N
20	"	"	"	"	ON	Y	N Y	1	Y
21	11	"	"	"	ON	Y	N	1	Y

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 1/23/92

BLDG.# 363
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
21D2	2	4	34	F	ON	Y	Y	1	Y
21E1	4	↓	34	F	ON	Y	N	1	Y
21E3	4	↓					N	1	N
21F1	3	↓					Y		N
21F3	2	↓					Y	1	N
21F4	2	↓				N	Y	0	Y
21G3	6	↓			ON	Y	Y Y	2	ON
21G1A	1	↓			ON	Y	N	1	Y
21G1B	↓								
21C1	2	↓			OFF	Y	N	2	N
23A1 23D1	3	↓	34	F	OFF OFF	Y	Y	1	N
23D1	39	↓			OFF	Y	N	5 5	N
24G2	6	4	34	F	OFF	Y	N	2	N
24G1	2	4	↓					1	N
23G3	↓							1	N
23G1	4	4	34	F	ON	Y	Y Y	1	N
WEIGHT ROOM	8	4	34	F	ON	Y	Y	2	Y
Locker	3	2		U	ON	Y	Y	1	Y

OF EXIT SIGNS - ³ 1 4 34 F ON Y Y 1 Y
 COMMENTS: 2 2 F ON Y Y 1 Y

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 1/23/92

BLDG.# 363
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
4A1	5	4	34	F	ON	N	N		Y
4D1	2	4	34	F	ON	N	Y	0	Y
1E1	42	2	96	F	ON		N		N
3E1	7	2	96	F	ON	Y	N	1	Y
1D1	29	2	96	F	ON	Y	N	1	N
1C2	2	4	34	F	ON	Y	N	1	Y
3C1	16	4	34	F	ON	Y	N	1	N
3B1	4	2	96	F	ON	Y	N	1	Y
IA3	2 6	4	34	F	ON	Y	N	1	N
3A1	6	4	34	F	ON	Y	N	1	N
1A4	2	4	34	F	ON	Y	Y	1	N
1A5	↓	↓							
1A1	6	↓							
2A1	1	4	34	F	ON	Y	N	1	Y
21E2	2 3	4 1	34 50	F I	ON	Y	N	2	N
21D3	1	2	96	F	ON	Y	N	1	N
21D4	4	4	34	F	ON	Y	N	1	N
21D1	↓								

OF EXIT SIGNS - 111

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 1/23/92

BLDG.# 363
 ECO 15

LIGHTING

Gen
Office

NEW
4CIA

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SUIVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
11F2	2	4	34	F	ON	Y	N	1	N
91B	2	4	34	F	ON	Y	N	1	N
8F2	2	4	34	F	ON	Y	N	2	N
9F1	↓								
73	9	4	34	F	ON	Y	N	1	N
7F2	6	4	34	F	ON	Y	N	1	Y
7D3	5	4	34	F	ON	Y	N	1	N
7D1	2	4	34	F	ON	Y	N	1	N
7D2	1	2	96	F	OFF	Y	N	1	N
6D1	3	4	34	F	ON	Y	N	1	N
6F1	2	4	34	F	ON	Y	Y	1	Y
6E1	68	4	34	F	ON	⊙	N		N
6A1	4	4	34	F	ON	Y	Y	1	Y
6A2	↓								
7A1	↓								
7A2	10	4	34	F	ON		N		N
4A1A	6	4	34	F	ON	N	Y		Y
4A1A	1	4	34	F	ON	ON	Y		Y

OF EXIT SIGNS - 1

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 1/23/92

BLDG.# 363
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
12C1	4	4	34	F	ON	N	N		N
12B1	2	4	34	F	ON	Y	N	1	N
11D1	5	4	34	F	ON	Y	N		N
11A1	2	4	34	F	ON		N		N
10B1	40	4	34	F	ON		N		N
10A1	4	4	34	F	OFF	Y	Y	1	N
9B1	4	4	34	F	ON	Y	Y	1	Y
9A5	4	4	34	F	OFF	Y	Y	1	N
9A6	1 ³	4 ²	34 ³⁴	F	OFF	Y	Y	1	N
9C1	1	1	75	I	OFF	Y	N	1	N
8D1	8	4	34	F	ON	Y	N		N
10E1	26	4	34	F	ON	Y	N		ON
9E2	1	1	75	I	OFF	Y	N	1	N
9F2	4	4	34	F	ON	Y	Y	1	Y
903	4	2	34	F	ON	Y	Y	1	Y
10F1	2	4	34	F	ON	Y	Y	1	N
10F2	2	4	34	F	ON	Y	Y	1	Y
11F1	1	1 2	34	F	ON	Y	Y	1	Y

OF EXIT SIGNS - 111

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 1/23/92

BLDG.# 363
ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
14E2	4	4	34	F	ON	Y	N	1	N
15E1	15	4	34	F	ON	Y	N	0	N
15F2	8	4	34	F	ON	Y	N	1	N
14F2	2	4	34	F	ON	Y	N	1	N
15F1	2	4	34	F	ON	Y	N	1	N
14F1	2	4	34	F	ON	Y	Y	1	Y
13F1	13	4	34	F	ON	Y	N	2	N
13F2	1	1	75	I	OFF	Y	N	1	N
12F3	4	4		F	OFF	Y	Y	1	N
12F4	4	4		F	ON	Y	Y	1	N
12F1	1	4	34	F	OFF	Y	N	1	N
12D1	12	4		F	ON	Y	N		N
14C1									
13E1	11	4	34	F	ON	Y	N	1	N
13C1	4	4	34	F	OFF	Y	Y	1	N
13B1	16	4	34	F	ON	Y	N		N
13C2	1	4	34	F	OFF	Y	N	1	N
13B1A	2	4	34	F	OFF	Y	Y	1	N

15E1

12C2A

OF EXIT SIGNS - 1

COMMENTS: _____

BLDG.# 363
 ECO 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
801	1	4	34	F	ON				
(00)									
1702	1	4	34	F	ON	Y	N	1	N
1901									
19A1	3	4	34	F	ON	Y	Y	1	N
18A1	6	4	34	F	ON	Y	N	BREAKERS	NO
19C1	3	4	34	F	ON	Y	N	1	NO
17F1	3	4	34	F	OFF	Y	Y	1	NO
17E1	6	4	34	F	ON	Y	N	2	Y
1703/04	1	4	34	F	ON	Y	N	1	N
16B1	4/1	4/2	34/96	F	OFF	Y	N	1	N
16B2									
17D1	2	4	34	F	ON	Y	Y	1	N
16E1A	1	4	34	F	ON	N	N	0	N
16E1	5	4	34	F	ON	N	N	0	Y
19E1	5/8	2/2	96/34	F	ON	Y	N	2	Y
162	1	4	34	F	OFF	Y	N	1	N
15E1A	4	4	34	F	ON	Y	N	1	N

OF EXIT SIGNS - _____

COMMENTS: LIGHTS ARE ON 24 HRS/DAY

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 363

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY CS DATE _____

SCALE _____

C2

SNYDER GENERAL

MODEL # AD036H

Compressor

208V 3 ϕ

60 HZ 15.3 A

fan motor

208V 1.1 A

~~C2~~

C3 CARRIER

MODEL # 38E036300

Comp.

208V 1 ϕ

23.8 A

Fan

208V 1 ϕ

2.4 A

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Bldg 363

AHU schedule

M-F 0700 - 1800

Sat

Boiler

Continuous

Chill Water Pump

Continuous

Backup Chiller

Return

55° water

it turns on

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

363

Coding tower

BALDOR

7.5HP

23-22/11 AMP

208-230/460 V

CAT# M3311T

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Chiller

Trane Serial U91D04030

460V 60 Hz 3 ϕ

	#	V	Hz	ϕ	RLA
Compressor motor	1	460	60	3	2.0
Oil tank heater	2	115	60	1	2.0
Control circuit	1	115	60	1	1.0

Front AHU < 3 HP

- Above ceiling
serves front area

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Bldg 363

Fcu #1

Snyder General Model BYMM30-0360
SERIAL R890200328

208V 1/2 HP 3.7 FLA 60 Hz Ph1

C #2

TRANE Model: RAUC - 356 - A

Serial # C790 - 27685

208-220V

comp: 13.6 FLA 3φ

fan: 3.8 FLA 1φ 1/2 HP

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____


CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 363



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 363

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Shower

- full flow 30 sec 7.5 quart
7.0 quart

- reduced flow 30 sec
3.5 quart
3.5 quart

Bldg 40

Shower - Same shower -

full 30 sec 4.5 quart 6.5 quart
low 3.0 quart

- reducible flow head already on

Bldg 171

HW Temp 104°F

Bldg 401 Raquetball

showers full - 20 sec 7.5 quart
7.5 quart
low - 30 sec 4.0 quart

BUILDING 366

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE:

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

OF

KC

12-12-91

BLDG.# 366

DOMESTIC HOT WATER


FAUCET LOCATION	WATER TEMPERATURE
<i>BATHROOM</i>	<i>108°F</i>
PROBLEMS:	

COMMENTS:

BLDG.# 300

AIR STRATIFICATION

LOCATION _____	REQ. TEMP. _____
TEMP. AT TSTAT _____	SOURCE _____
TEMP. AT CEILING _____	OPP. HOURS _____ TO _____
TEMP. AT FLOOR _____	



COMMENTS: NOT APPLICABLE

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____


SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-12-91

CHECKED BY _____ DATE _____

SCALE NTS

Bldg 366



BUILDING 400


EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY


JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMO
 CHECKED BY: _____
 DATE: 12-11-91

BLDG.# 400

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS	20	0	30	33
OVERHEAD DOORS	—	—	—	—
PERSONNEL DOORS	32	20	0	32

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Stucco 3. 2" Polystyrene 4. CMU 5. 2x4 stud 6. GYP Board 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM 2. Shingles 3. Plywood 4. ceiling space 5. 3 1/2" Fiberglass insulation 6. ceiling tile 7. INSIDE AIR FILM

PERSONNEL DOOR TYPE <u>Glass</u>	BASEMENT [] SLAB [<input checked="" type="checkbox"/>] CRAWL SPACE []
OVERHEAD DOOR TYPE <u>—</u>	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. CM0 OF
CALCULATED BY:
CHECKED BY:
DATE: 12-11-91

400

BLDG.#

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH (ft)	FLUID TYPE	FLUID TEMP.	AIR TEMP. °F	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
Mech Room	1" Cu	100 ≈ 100	Dx supply		68.3	Rubber	1/2" 1 1/8"	GOOD
Boiler Mech. Room	3/4" Cu	≈ 50	Dx supply		70	Rubber	1/2"	Fair

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. 400 OF
CALCULATED BY:
CHECKED BY:
DATE: 12-11-91

BLDG.# 400

DUCT INSULATION
SURROUNDING

LOCATION	DUCT CROSSSECTION	SHAPE	DUCT TEMP. (°F)	SUPPLY AIR TEMP. (°F)	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
Mech Rm		Rect.	71°	73.5	Fiberglass	1" R-4	OK Very good
ROOF BALL MECH RM	24x 12		71°	70°	NONE		

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft Mcpherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO.
CALCULATED BY:
CHECKED BY:
DATE:

OF
CMD
12-11-91

BLDG.# 400

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS (INCH)
1	Double	Sliding	Al	N	None	CURTAINS	29x50
2	"	"	"	N	None	"	"
3	"	"	"	W	"	"	"
4	"	"	"	W	"	"	38x50
5	"	"	"	W	"	"	29x50
6	"	"	"	E	"	"	"
7	"	"	"	E	"	"	"
8	"	"	"	E	"	"	"

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-11-91

BLDG.# 400

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
D1	Poor * ¹	Large	N	2 @ 29x79
D2	Fair * ²	small	W	2 @ 29x79
D3	Fair * ³	Small	S	36x79

COMMENTS:

*¹ Large gap where DOORS MEET $\approx \frac{1}{2}$ "

*² Small gap between doors.

*³ DOOR DOES NOT SEAL against Frame

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMD
 CHECKED BY: _____
 DATE: 12-1-91

BLDG.# 400

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)
1	Good	very low	N	29x50
2	Good	"	N	"
3	"	"	W	"
4	"	"	W	38 x 50
5	"	"	W	29x50
6	"	"	E	"
7	"	"	E	"
8	"	"	E	"

COMMENTS:

All window look new, good condition.

BLDG.# 400

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Kitchen	109 °F
Men's Room	109 °F
PROBLEMS:	
Bad Taste in water Fountain	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMO
CHECKED BY: _____
DATE: 12-11-91

BLDG.# 400

MOTORS

MOTOR #	<u>1</u>	HP	<u>1.5</u>	PH	<u>3</u>	RPM	
MODEL #		VOLTS	<u>200</u>	AMPS	<u>5</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>TRANE</u>	REQUIRED HR.	<u>0630</u>	TO	<u>1930</u>		
FRAME		EFF.					
DESCRIPTION	<u>AHU-1</u>	COMMENTS					
MOTOR #	<u>2</u>	HP	<u>1.5</u>	PH	<u>3</u>	RPM	
MODEL #		VOLTS	<u>200</u>	AMPS	<u>5</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>TRANE</u>	REQUIRED HR.	<u>0630</u>	TO	<u>1930</u>		
FRAME		EFF.					
DESCRIPTION	<u>AHU-2</u>	COMMENTS					
MOTOR #		HP		PH		RPM	
MODEL #		VOLTS		AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION		COMMENTS					

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. OF
 CALCULATED BY: KC
 CHECKED BY:
 DATE: 12-11-91

BLDG.# 400

MOTORS

MOTOR #	HP	PH	RPM
MODEL #	VOLTS	AMPS	
SERIAL #	PRESENT HR.	TO	
MFG	REQUIRED HR.	TO	
FRAME	EFF.		
DESCRIPTION	COMMENTS		
MOTOR # <u>3</u>	HP <u>1/2</u>	PH <u>1φ</u>	RPM _____
MODEL # <u>394 GA D06φ15φ</u>	VOLTS <u>115V</u>	AMPS <u>8.5</u>	
SERIAL # _____	PRESENT HR. _____	<u>600</u> TO <u>2200</u>	
MFG <u>Bryan</u>	REQUIRED HR. <u>7:00</u>	TO <u>19300</u>	
FRAME _____	EFF. _____		
DESCRIPTION <u>FOR RACKET BALL COURT</u>	COMMENTS <u>AHU-3</u>		
MOTOR # <u>4</u>	HP <u>1/2</u>	PH <u>1</u>	RPM _____
MODEL # <u>394 GA D06φ15φ</u>	VOLTS <u>115</u>	AMPS <u>8.5</u>	
SERIAL # _____	PRESENT HR. _____	<u>600</u> TO <u>2200</u>	
MFG <u>Bryan</u>	REQUIRED HR. <u>6:30</u>	TO <u>1930</u>	
FRAME _____	EFF. _____		
DESCRIPTION <u>FOR RACKET BALL COURT</u>	COMMENTS <u>AHU-4</u>		

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# Emc # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KL
 CHECKED BY: _____
 DATE: _____

BLDG.# 400

LIGHTING

TEMP. REL ROOM 94.5°F

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
REC. RM.	31	4	34W	4' FLORES.	ON	YES	NO	4 1 PER ROOM	Y
KIT	2	4	34W	4' FL	ON	Y	Y	1	Y
MEN1	2	4	34W	4' FL	ON	Y	Y	1	Y
WOMEN1	2	4	34	4' FLR	ON	Y	Y	1	Y
O1	2	4	34W	4' FLOR.	ON	YES	Y	1	Y
O2	2	4	34W	4' FLOR	ON	Y	Y	1	Y
O3	4	4	34W	4' FLOR	ON	Y	Y	1	Y
HALL 1ST FLOOR	4	2	34W	4' FLR	ON	Y	N	2	—
C1	8	4	34W	4' FLR	OFF	Y	Y	1	N
RAC. BALL COURT(S) 2 TOTAL	each 8	1	?	MERCURY VAPOR	ON	NO YES	N	1	Y
MEN2	1	2	34W						
LADY2	1	2	34W	INC.	OFF	Y	Y	1	Y
MEN SHOWER	1	1	34W	INC	OFF	Y	Y	1	—
WOMEN SHOWER	1	1	34W	INC	OFF	Y	Y	1	—
HALL	3	2	34W	INC	ON	Y	N	1	—

OF EXIT SIGNS - 2

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# Emc # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KU
 CHECKED BY: _____
 DATE: 12-11-91

BLDG.# 400

SECOND FLOOR

LIGHTING

2ND FLOOR 77.8°F

ALSO TURN COMPUTER ON/OFF * 4 SW FOR 2ND FLOOR

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
04	4	4	34W	FLR	ON	NO	NO	2 1	—
05	4	4	34	FLR	ON	NO	NO		
06	8 4	4	34	FLR	ON	NO	NO		
07	4	4	34	FLR	ON	NO	NO		
08	8 4	4	34	FLR	ON	NO	NO	—	—
09	13	4	34W	FLR	ON	NO		—	
010	13 4	4	34W	FLR	ON	NO	NO	—	
C2	8	4	34W	FLR	ON	NO	NO		
S1	8	4	34	FLR	ON	NO	NO	—	—
S2	13 4	4	34	FLR	ON	NO	NO	—	—
HALL	∅	∅	∅	—	—	—	—	—	—
C3	1	4	34	FLR	ON	NO	NO	—	—
HALL NEAR BASKETBALL	4	2	34	FLR	ON	NO	NO	—	—

OF EXIT SIGNS - 2

COMMENTS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 400 2nd Floor


JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-11-91

CHECKED BY _____ DATE _____

SCALE NTS



JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-11-91



CHECKED BY _____ DATE _____

SCALE NTS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 400 1st Fl



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-1-91

CHECKED BY _____ DATE _____

SCALE _____

Bldg 400

1st Fl. Hours

0630 - 1930 M - Sat

BUILDING 401

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: CMD
CHECKED BY: _____
DATE: 12-11-91

BLDG.# 401

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
Kitchen	137°F
Men's Room	121°F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: [Signature]
DATE: 12-11-91

BLDG.# 401

MOTORS

MOTOR #	<u>1108</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1740</u>
MODEL #	<u>5K184AX 2048/AX</u>	VOLTS	<u>208</u>	AMPS	<u>14.6</u>		
SERIAL #		PRESENT HR.	<u>0</u>	TO	<u>2400</u>		
MFG	<u>GE</u>	REQUIRED HR.		TO			
FRAME	<u>184T</u>	EFF.	<u>85.5</u>				
DESCRIPTION	<u>AHU</u>	COMMENTS	<u>NEW</u>				

MOTOR #	<u>2</u>	HP	<u>1/4</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>6K890</u>	VOLTS	<u>115</u>	AMPS	<u>5.1</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>DAYTON</u>	REQUIRED HR.		TO			
FRAME	<u>48Y</u>	EFF.					
DESCRIPTION	<u>HWP SUPPLY</u>	COMMENTS	<u>NEW</u>				<u>HWR PUMP IS REMOVED - REPAIR?</u>

MOTOR #	_____	HP	_____	PH	_____	RPM	_____
MODEL #	_____	VOLTS	_____	AMPS	_____		
SERIAL #	_____	PRESENT HR.	_____	TO	_____		
MFG	_____	REQUIRED HR.	_____	TO	_____		
FRAME	_____	EFF.	_____				
DESCRIPTION	_____	COMMENTS	_____				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: Emc # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: CMB
 CHECKED BY: _____
 DATE: 12-11-91

BLDG.# 401

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE/INC	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
Ent	1	2	34	4ft FI	ON	NO	NO		
1	2	3	34	4ft FI	ON	Y	Y	1	
2	2	4	34	4ft FI	ON	Y	Y	1	—
1	1	2	34	18" Flu	ON	Y	Y	1	
3	1	3	34	4ft FI	OFF	Y	Y	1	
4	4	2		18" Flu	ON	Y	N		
4	2	3	34	4ft FI	ON	Y	N		
5	14	2	34	4ft FI	ON	Y	N		
6	2	3	34	4ft FI	ON	N	N		
7	30	2	60	8ft FI	ON	Y	N		
8	1	2	34	4ft FI	ON	Y	N		
8	1	4	34	4ft FI	ON	Y	N		
9	"	"	"	" "	"	"	"		
10	1	2		Flu	ON	Y	NO	1	
10	3	4	34	4ft FI	ON	Y	N		

OF EXIT SIGNS - 4

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: Emc # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-11-91

BLDG.# 401

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
LOCKER	1	2	60W	8' FLR	ON	Y	N	1	✓
OLD MECH	2	2	60W	8' FLR	ON	Y	Y	2	Y
PIN. MACH	6	2	60W	8' FLR	ON	Y	N	1	Y
S1	2	2	60W	8' FLR	ON	Y	Y	1	Y
S2	1 2	2	60W 40W	8' FLR 4' FLR	ON	Y	Y	1	Y
SS									
SS LOCKER									

OF EXIT SIGNS - _____

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY CMP DATE 12-11-91
CHECKED BY _____ DATE _____
SCALE _____

Bldg 401 hrs.

M-F 600 - 2300

SAT 900 - 2300

SUN 900 - 2100

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

Bldg 401

- ROOFTOP AHU 3 ϕ 60 HZ 12.8A 230V 5HP.

PACKAGE UNIT TRANE

- SFCB-C153LA 300,000 BTUH INPUT
225,000 " " OUTPUT

- N. GAS FURNACE

- 1 AIR COOLED CHILLER

SHOWERS

FULL - ~~20~~²⁰ sec - 7.5 gts = ~~5.0~~^{5.64} gpm

LOW - 30 sec - 4.0 gts = 2.0 gpm

BUILDING 500

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. 1 OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12-10-91

BLDG.# 500

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS	232	126	140	147
OVERHEAD DOORS	—	—	—	—
PERSONNEL DOORS	82	69	81	42

SKETCH WALL CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. STUCCO
	3. EXPOSED BRICK ≈ 1 FT
	4. STUCCO
	5.
	6.
	7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
	1. OUTSIDE AIR FILM
	2. TIN ROOF
	3. CEILING SPACE
	4. 1/2" FIBERGLASS INSULATION R-30
	5. CEILING TILE
	6.
	7. INSIDE AIR FILM

PERSONNEL DOOR TYPE <u>WOOD</u>	BASEMENT [] SLAB <input checked="" type="checkbox"/> CRAWL SPACE []
OVERHEAD DOOR TYPE <u>NONE</u>	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

Ft. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

JOB
PROJ.#
SHEET NO. 2 OF
CALCULATED BY: CAD
CHECKED BY:
DATE: 12-10-91

BLDG.# 500

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE-SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS H (INCH) W
1	S	Fixed	METAL	E	NONE	NONE	58 x 308
2	D	Sliding	AL.	E	NONE	Blinds	22 x 32
3	D	N/A	AL	E	opaque	NONE	23 x 34 23 x 34
4	D	Fixed	WOOD	S (ADD)*	NONE	SHUTTERS	55 x 65
5	"	"	"	"	"	"	3 @ 55 x 65
6	"	"	"	N (ADD)	"	NONE	5 @ 55 x 65
7	D	Sliding	AL	E	opaque	NONE	44" x 18"
8	"	"	"	N	"	"	"
9	S	Sliding	WOOD	N	NONE	NONE	67" x 28" (2@)
10	S	Sliding	WOOD	N	NONE	NONE	45 x 20
11	"	"	"	"	"	"	--

COMMENTS:

* Add - Addition to Bldg

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. 3 OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12-10-91

BLDG.# 500

WINDOWS SURVEY

WINDOW NO.	SINGLE/DOUBLE PANE	TYPE - SLIDING FIXED, CASEMENT	FRAME MAT'L	ORIENTATION	GLASS SHADING	WINDOW COVER	DIMENSIONS H (INCH) W
12	D	Sliding	AL	N	None	Blinds	70 x 62
13	D	Sliding	AL	N	None	Window shade	50 x 20
14	S	Sliding	wood	W	opaque	N/A	64 x 20
15	S	Fixed	wood	N	None	shutters	40 x 95
16	"	"	metal	W	"	"	"
17	"	"	"	"	"	"	"
18	"	"	"	S	"	"	"
19	S	Fixed	wood	W	None	None	52 x 118
20	"	"	"	"	"	"	"

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: KC
CHECKED BY: _____
DATE: 12-10-91

BLDG.# 500

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
BATH ROOM (SOUTHEND DOWNSTAIR)	146° F
BATH ROOM (NORTHEND UPSTAIR NEAR TENNESY ROOM)	134° F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. 8 OF
CALCULATED BY: CMD
CHECKED BY:
DATE: 12-10-91

BLDG.# 500

MOTORS

MOTOR #	<u>13</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #		VOLTS	<u>208</u>	AMPS	<u>7.8</u>		
SERIAL #		PRESENT HR.				TO	
MFG	<u>BALDOR</u>	REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>EF-5</u>	COMMENTS					
MOTOR #	<u>14</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	<u>1740</u>
MODEL #	<u>WVD 184 TTD R 7357BP</u>	VOLTS	<u>208</u>	AMPS			
CAT SERIAL #	<u>M 317</u>	PRESENT HR.				TO	
MFG	<u>MARATHON</u>	REQUIRED HR.				TO	
FRAME	<u>184JM</u>	EFF.					
DESCRIPTION	<u>CHW Pump</u>	COMMENTS					
MOTOR #	<u>15-20</u>	HP	<u>1.5 ea.</u>	PH	<u>3 ea.</u>	RPM	<u>1740 ea</u>
MODEL #		VOLTS	<u>208 ea</u>	AMPS	<u>5.2 ea</u>		
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	<u>CHILLER FANS</u>	COMMENTS					

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson⁹/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. 4 OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12-10-91

BLDG.# 500

MOTORS

MOTOR #	<u>1</u>	HP	<u>3</u>	PH	<u>3</u>	RPM	#12 <u>1730</u>
MODEL #	<u>SBFC</u>	VOLTS	<u>208</u>	AMPS	<u>10.7</u>		
SERIAL #	<u> </u>	PRESENT HR.				TO	
MFG	<u>Westinghouse</u>	REQUIRED HR.				TO	
FRAME	<u>182T</u>	EFF.	<u>81.5</u>				
DESCRIPTION	<u>Supply Fan, AHU-1</u>		COMMENTS				
MOTOR #	<u>2</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	808 <u>1740</u>
MODEL #	<u>SBFC</u>	VOLTS	<u>200</u>	AMPS	<u>15</u>		
SERIAL #	<u>8505</u>	PRESENT HR.				TO	
MFG	<u> WESTINGHOUSE</u>	REQUIRED HR.				TO	
FRAME	<u>N/A</u>	EFF.	<u>N/A</u>				
DESCRIPTION	<u>Supply Fan, AHU-2</u>		COMMENTS				
MOTOR #	<u>3</u>	HP	<u>5</u>	PH	<u>3</u>	RPM	857 <u>1740</u>
MODEL #	<u>SBFC</u>	VOLTS	<u>200</u>	AMPS	<u>15</u>		
SERIAL #	<u>8505</u>	PRESENT HR.				TO	
MFG	<u>WESTINGHOUSE</u>	REQUIRED HR.				TO	
FRAME	<u>184T</u>	EFF.	<u>86.5</u>				
DESCRIPTION	<u>Supply Fan, AHU-3</u>		COMMENTS				

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. 5 OF
CALCULATED BY: CMP
CHECKED BY:
DATE: 12-10-91

BLDG.# 500

MOTORS

MOTOR #	<u>4</u>	HP	<u>2</u> 3	PH	<u>3</u>	RPM	<u>1063</u> 1063
CAT MODEL #	<u>N 315 TT</u>	VOLTS	<u>208</u>	AMPS	<u>6.8</u>		4.8
SERIAL #	<u>F1088</u>	PRESENT HR.		TO			
MFG	<u>BALDOR</u>	REQUIRED HR.		TO			
FRAME	<u>145 T</u>	EFF.	<u>78.5</u>				
DESCRIPTION	<u>Supply Fan, AHU-4</u>	COMMENTS					

MOTOR #	<u>5</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	<u>1785</u> 1063
MODEL #	<u>RVD145 TTR5328AA</u> Marathon Electric	VOLTS	<u>208</u>	AMPS	<u>5.5</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>MARATHON ELECTRIC</u>	REQUIRED HR.		TO			
FRAME	<u>145T-0</u>	EFF.					
DESCRIPTION	<u>Supply Fan, AHU-5</u>	COMMENTS					

MOTOR #	<u>6</u>	HP	<u>1</u>	PH	<u>3</u>	RPM	<u>1252</u>
MODEL #		VOLTS	<u>208</u>	AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	<u>supply Fan AHU-6</u>	COMMENTS					

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. 6 OF
CALCULATED BY: CND
CHECKED BY:
DATE: 12-10-91

BLDG.# 500

MOTORS

MOTOR #	7	HP	1.5	PH	3	RPM	1735
MODEL #	RVD145TTER5328AA	VOLTS	208	AMPS	5.5		1735
SERIAL #		PRESENT HR.				TO	
MFG	Marathon	REQUIRED HR.				TO	
FRAME	140T-70	EFF.					
DESCRIPTION	Supply Fan, AHU-7	COMMENTS					
MOTOR #	8	HP	2	PH	3	RPM	1252 1017
MODEL #	SBFc	VOLTS	208	AMPS	6.7		
SERIAL #	8505	PRESENT HR.				TO	
MFG	Westinghouse	REQUIRED HR.				TO	
FRAME	145T	EFF.					
DESCRIPTION	Supply Fan, AHU-8	COMMENTS					
MOTOR #	9	HP	1/6	PH	1	RPM	1140
MODEL #		VOLTS	120	AMPS			
SERIAL #		PRESENT HR.				TO	
MFG		REQUIRED HR.				TO	
FRAME		EFF.					
DESCRIPTION	EF-1	COMMENTS					

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJECT NO. EMC # 3105.000
 SHEET NO. 7 OF
 CALCULATED BY: CMD
 CHECKED BY:
 DATE: 12-10-91

BLDG.# 500

MOTORS

MOTOR #	10	HP	1/6	PH	1	RPM	1140
MODEL #		VOLTS	120	AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	EF-2	COMMENTS					
MOTOR #	11	HP	1/2	PH	3	RPM	1750
MODEL #		VOLTS	208	AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	EF-3	COMMENTS					
MOTOR #	12	HP	1/6	PH	1	RPM	1140
MODEL #		VOLTS	120	AMPS			
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	EF-4	COMMENTS					

DATE: 12-10-91
BY: CAD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-Club JOB: 3125.000
AHU NO: 3 LOCATION: _____
ZONE NO. SERVED: main ball rm REF. SYS. SERVING AHU: CHLL-1
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] _____
MFG: McQuay MODEL: 3QFB0606-060(9C)
SUPPLY FAN: FAN HP: 5 MFG: _____ AM MODEL: LSL1P8CV
CFM: SA 3960 RA _____ OA 1250 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

3105.000

JOB _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

SHEET NO. _____ OF _____

CALCULATED BY VC DATE 12-11-91

CHECKED BY _____ DATE _____


SCALE _____

DTWC-3

ANNEX BLDG 500

IN AUTO


ELECTRONIC CONTROL



JOB 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY KC DATE 12-10-91
 CHECKED BY NTS DATE _____
 SCALE _____


E M C ENGINEERS, INC.
 Denver • Colorado Springs • Atlanta • West Germany

AHU 4 BLDG 500



- DDC LOCAL CONTROL
- EXISTING ECONOMIZER CONTROL
- HAS ~~RA~~ RETAIR DAMPER
- DAMPER ACTUATOR
 COLMAN HYDRAULIC ACTUATOR
 MP-5430

AHU-3



SAME AS AHU 4

DATE: 12-10-91
BY: cmo

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-Club JOB: 3105.000
AHU NO: 2 LOCATION: Mech closet Bx dining
ZONE NO. SERVED: Main Dining REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] _____

MFG: McQuay MODEL: _____
SUPPLY FAN: FAN HP: 5 MFG: _____ MODEL: _____
CFM: SA 4000 RA _____ OA ~~4000~~ 500 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____


SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS: _____

JOB 3105.000
SHEET NO. _____ OF _____
CALCULATED BY KC DATE 12-10-91
CHECKED BY 1 DATE _____
SCALE NTS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 500 AHU-2



DATE: 12-10-91
BY: CAD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-CLUB JOB: _____
AHU NO: 1 LOCATION: Hand Room near in ENTERE HALL
ZONE NO. SERVED: Alex Coor REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: McQuay MODEL: 3QF06604-06
SUPPLY FAN: FAN HP: 3 MFG: _____ MODEL: _____
CFM: SA 3600 RA _____ OA 400 (MEASURED [] ESTIMATED []) Schedule
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____


SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 500

JOB 3105.000
SHEET NO. _____ OF _____
CALCULATED BY CMD DATE 12-10-91
CHECKED BY _____ DATE _____
SCALE NTS



DATE: 12-10-91
BY: CMD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-club JOB: 3105.000

AHU NO: 4 LOCATION: _____

ZONE NO. SERVED: Private Dining Rm REF. SYS. SERVING AHU: CHL-1

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: Mc QUAY MODEL: 3 R F Ø Ø 611 - Ø 6 (SERIAL) LSL106CH (MFG)

SUPPLY FAN: FAN HP: 2 MFG: _____ MODEL: _____

CFM: SA 2100 RA _____ OA 375 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []

FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []

PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

DATE: 12-10-91
BY: CMD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-Club JOB: 3105.000
AHU NO: 5 LOCATION: Tennessee Rm
ZONE NO. SERVED: Tennessee Rm. REF. SYS. SERVING AHU: CHLR-1

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: N/A MODEL: N/A
SUPPLY FAN: FAN HP: 2 MFG: _____ MODEL: _____

CFM: SA 2500 RA N/A OA 300 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

JOB 3105.000

SHEET NO. _____ OF _____



CALCULATED BY KC DATE 12-10-91

CHECKED BY _____ DATE _____

SCALE NTS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany



DATE: 12-10-91
BY: CMD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-CLUB JOB: 3105.000
AHU NO: 6 LOCATION: Terrace Ln
ZONE NO. SERVED: SMALL DOWNWELL AREA REF. SYS. SERVING AHU: CHLR-1
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []
MFG: McQUAY MODEL: LSL103CV ser-3QF00609-06
SUPPLY FAN: FAN HP: 1 MFG: _____ MODEL: _____
CFM: SA 1200 RA _____ OA 175 (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____
DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____
SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____
THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

L.

DATE: 12-10-91
BY: CMD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-CLUB JOB: 3105.000

AHU NO: 7 LOCATION: _____

ZONE NO. SERVED: FORMAL BAR REF. SYS. SERVING AHU: CHLL-1

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: 1 MFG: _____ MODEL: _____

CFM: SA 1800 RA _____ OA 700 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []

RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []

RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []

MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []

FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []

PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. _____ OF _____


CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____



- AHU - 7
- UNIT HAS ECONOMIZER CONTROL
 - EXH. FAN TIES TO AHU 7
 - IN AUTO POSITION
 - DOES NOT RUN WHEN SWITCH TO HAND



Ft. McPherson/ Ft. Gillem Energy Study
EMC # 3105.000

DATE: 12-11-91
BY: CMD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-CLUB JOB: _____
AHU NO: 7 LOCATION: _____
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____

([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: McQuay MODEL: L5L106 CV Ser- 3QF00608-06
SUPPLY FAN: FAN HP: _____ MFG: _____ MODEL: _____

CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK: _____

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: _____

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F



DEMAND LIMITING, DUTY CYCLING YES [] NO []
REMARKS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

ECONOMIZER DATA:
Sketch AHU, Ductwork
Note Dampers, Actuators, Dimensions

OA 41" x 15"



DATE: 12-10-91
BY: CAD

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O-CLUB JOB: 3105

AHU NO: 8 LOCATION: _____

ZONE NO. SERVED: 2nd Floor Offices + Core REF. SYS. SERVING AHU: CHLR-1
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)

UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER []

MFG: _____ MODEL: _____

SUPPLY FAN: FAN HP: 2 MFG: _____ MODEL: _____

CFM: SA 2500 RA _____ OA 600 (MEASURED [] ESTIMATED [])

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] MOD VLV []
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RETURN AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS:

SUPPORT FANS: UNIT _____ RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____

SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F

RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F

DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study

PROJ.# EMC # 3105.000

SHEET NO. _____ OF _____

CALCULATED BY: CMU

CHECKED BY: _____

DATE: 12-11-91

BLDG.# 500

HW PUMPS

CIRCULATION PUMPS

RPM	FT HD	GPM	MODEL #	SERIAL #	MFG.	HOURS		PUMP #
						REQUIRED	PRESENT	
			A68 A68 *	102214 *	Bell & Gossett			1

PUMP MOTORS

VOLTS	AMPS	PHASE	MODEL #	SERIAL #	MFG.	HOURS		FRAME	MOTOR#
						REQUIRED	PRESENT		
115	2.4	1			Bell & Gossett				1

1/6 hp

COMMENTS: * Numbers are on plate, but not sure which is serial # which is model #

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPheerson/Ft. Gillem Energy Study

PROJ.# EMC # 3105.000

SHEET NO. OF

CALCULATED BY: *CMB*

CHECKED BY:

DATE: *12-11-91*

BLDG.# *500*

HW PUMPS

RPM	FT HD	GPM	MODEL #	SERIAL #	MFG.	HOURS		PUMP #
						REQUIRED	PRESENT	
<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>315T</i>	<i>1263510</i>	<i>Ball</i> <i>Bell & Gossett</i>			<i>1</i>

PUMP MOTORS

VOLTS	AMPS	PHASE	MODEL #	SERIAL #	MFG.	HOURS		FRAME	MOTOR #
						REQUIRED	PRESENT		
<i>208</i>	<i>5.5</i>	<i>3</i>	<i>PVF184TTP</i>	<i>NA</i>	<i>Marathon Electric</i>			<i>1845m</i>	<i>1</i>
			<i>R7357AN7</i>						

5HP

COMMENTS: *Motor P.f. 81*

E. McPherson / Ft. Gillem Energy Study
MC # 3105.000

DATE: 12-11-91
BY: CMD

III. BOILER AND CONVERTER SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: 0-club JOB: _____

BOILER/CONV. NO. _____ LOCATION: _____

BOILER TYPE: STEAM [] _____ PSI HOT WATER [] 130 °F SET POINT

BOILER FUEL: OIL [] # _____ GAS [] ELECTRIC [] OTHER [] _____

MFG. NO PLATE MODEL _____

CAPACITY: MAX BTUH OUTPUT _____ MAX BTUH INPUT _____

BURNER TYPE: _____

STACK TEMP.: _____ °F STACK GAS: _____ %O₂ _____ %CO COIN. LOAD _____ LBS/HR

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

CONTROL MFG. AND TYPE:

CONVERTER : STEAM TO HW [] _____ °F SET POINT

HTHW TO HW [] _____ °F SET POINT

HTHW TO STEAM [] _____ PSI

OUTSIDE UTILITIES: STEAM [] _____ PSI - FROM PLANT: _____

HTHW [] _____ °F - FROM PLANT: _____

OTHER [] _____

CONVERTER: USE _____ RATING _____

HW PUMPS: NO. OF PUMPS _____ PUMP 1 HP _____ PUMP 2 HP _____

PUMP 3 HP _____ PUMP 4 HP _____

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING YES [] NO [])

SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____

REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

TEMPERATURE CONTROL MFG. AND TYPE:

STEAM SUPPLY HEADER SIZE: _____ INCHES DIA.

HW SUPPLY SIZE: _____ IN DIA., HW RETURN SIZE: _____ IN DIA.

REMARKS:

DATE: 12-10-91
BY: KC

IV. REFRIGERATION EQUIPMENT SURVEY OBSERVATIONS

BLDG NO: 500 BLDG NAME: O CLUB JOB: 3105.000
CHILLER/COMPRESSOR NO: 1 LOCATION: SOUTH END OUTSIDE
REFRIG. EQUIP. TYPE: CENTRIFUGAL [] RECIPROCATING [] ABSORBTION []
OTHER []
CW [] DX [] OTHER []
MANUFACTURER: MCQUAY MODEL NO. ALR094AD
SERIAL NO. 3QD00604 14

(2) COMPRESSOR NAMEPLATE: 208 VOLTS 196 AMPS 3 PH 60 HZ 60 Hp EACH
CAPACITY: 90.6 (TONS) CHW TEMP: SUPPLY _____ °F RETURN _____ °F

AHU'S SERVED: _____

PRESENT DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____

CONDENSING EQUIP.: AIR COOLED [] EVAP. [] WINTERIZED []
WATER COOLED [] 3-WAY VALVE [] NO. OF CELLS []
OTHER []

MANUFACTURER: _____ MODEL NO. _____
SERIAL NO. _____

NO. OF FANS 6, EACH FAN: 208 VOLTS 5.2 AMPS 3 PH 60 HZ 1.5 Hp
CAPACITY: _____ (TONS) CNW TEMP: SUPPLY _____ °F RETURN _____ °F

SYSTEM AUXILIARIES:
PUMPS: CHW PUMP [] 208 VOLTS _____ AMPS 3 PH 60 HZ 5 Hp 1740 RPM
CNW PUMP [] _____ VOLTS _____ AMPS _____ PH _____ HZ _____ HP _____ RPM
CAT # M317 FRAME 184JM
MODEL WVD184TDR7357BP MARATHON.

TEMP. CONTROLS MFG. AND TYPE _____

CHILLER INTERLOCKS WITH CHW PUMP []	CNW PUMP []	OTHER []
CONTROL PANEL INDICATIONS:	HI (LGTS)	LO (LGHTS) GAUGES
MOTOR TEMP	[]	[]
REFRIG TEMP	[]	[]
COND TEMP	[]	[]
OIL TEMP	[]	[]
OIL PRESS	[]	[]
OTHER	[]	[]

REMARKS: PACKAGE UNIT

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: KC
 CHECKED BY: _____
 DATE: 12-1-91

BLDG.# 500
 EC0 15

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/FIXTURE	WATTS/BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
1	8	1	60	INC.	OFF	Y	NO	1	
2	4	10	25	INC.	ON	Y	NO	1	
2	12	1	50	INC.	ON	Y	NO	1	
2	5	1	50	INC.	ON	Y	↓	1	
2	3	1	50	INC.	ON	Y	↓	1	
3	4	1	60	↓	ON	Y	NO	1	
3	1	7	60	↓	ON	Y	Y	1	
3	2	5	60	↓	ON	Y	Y	1	
4	4	2	25	INC.	ON	Y	N	1	
4					ON	Y	N	1	
4	3 4	10 1	25 60	INC.	ON	Y	N	1	
5	5	1	60	INC.	ON	Y	N	1	
5	1	1	60	INC.	OFF	Y	X	1	
6	3 3	8 2	25 25	INC.	ON OFF	Y	Y	1	
6	9	1	50	INC.	ON	Y	Y	1	
7	2	2	34	FLOR.	ON	Y	Y	1	
8	4	1	50	INC.	ON	Y	N	1	
9	11	1	50	INC.	ON	Y	N	1	

OF EXIT SIGNS - _____

COMMENTS: _____

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# Emc # 3105.000
SHEET NO. _____ OF _____
CALCULATED BY: Cmb
CHECKED BY: ●
DATE: 12-11-91

BLDG.# 500
2nd Floor

LIGHTING

ROOM #	# OF FIXTURES	LAMPS/ FIXTURE	WATTS/ BULB	BULB TYPE	ON/OFF DURING SURVEY	SWITCH YES/NO	GOOD FOR OCC. SENSOR	NO. OF SWITCHES	UNOCC LIGHTS ON
ENT	4	1	60	IN	ON				
H2	5	1	60	I	ON	Y	N		
ENT	2	2		Fl u	ON	Y	N		
ENT	2	2	25	I	ON	Y	N		
9	2	2	40	Fl 4ft	ON	Y	Y	1	✓
H1	5	1	50	I	ON	Y	N		
1	3	2	40	Fl 4ft	ON	Y	N		
1	1	1	50	I	ON	Y	N		
2	5	5	25	I	ON	Y	N		
3	1	2		Fl u	ON	Y	N		
3a	2	2	40	Fl	ON	Y	Y-move switch	1	✓
H3	4	1	50	I	ON	Y	No		
4a	1	4	40	F 4ft	OFF	Y	Y	1	
4	1	4	40	Fl 4ft	ON	Y	Y	1	✓
7	3	2	40	Fl 4ft	ON	Y	Y	1	
7a	2	4	40	Fl 4ft	ON	Y	Y	1	✓
8	1	2		Fl u	ON	Y	Y	1	
8	1	8	54	I	ON	Y	Y		

8 1 4 40 Fl 4ft ON Y Y 1
OF EXIT SIGNS - 4

COMMENTS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

500

DTWC 1 & 2

Bohn

~~MOD#~~ MOD# 120 DA-4

208 V 46 A 3 ϕ 60 Hz

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

500

DTWC-3 ANNEX

No Plate

MOTOR - NO PLATE \approx 1/2-1 hp

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB 3105.000
SHEET NO. _____ OF _____
CALCULATED BY VEC DATE 12-1-91
CHECKED BY VEC DATE _____
SCALE BUILDING 500

CHWPUMP

PEERLESS PUMP
SERIES C
STYLE M
TYPE 825A
DESIGN DB
IMP. NO. 2683738
DIA. 7.75

JOB 3105-000

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-11-91


CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Building 500



FIRST FLOOR.

Light load: ~~8405 W~~ 12 205 W

JOB 3105-000

SHEET NO. _____ OF _____

CALCULATED BY KC DATE 12-11-91


CHECKED BY _____ DATE _____

SCALE _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Building 500



UPSTAIR

Light: 3664 w

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY CMD DATE 12-11-91

CHECKED BY _____ DATE _____

SCALE NTS

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

Bldg 500 2nd Floor Lighting

4 computer printer TV

7 computer, copy mach., printer, intercom system

1 coffee pot, big Refrig., Tea Brewer, LWAC unit

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. _____ OF _____
CALCULATED BY _____ DATE _____
CHECKED BY _____ DATE _____
SCALE _____

BLDG. 500 ANNEX

3+7 TVs

SKY LIGHT

1 JUNK BOX

1 EXIT SIGN

3 CASH REGISTERS

1 ICE MACHINE

1 SOUND SYSTEM AMP+TAPE REEL VCR+CASSETT TAPE + EQ.

2 LED BOARD

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

SERVING
11-2:00PM M-F
BAR 4-8:00 M-T
F 4-11:00F
SAT PRIVATE FUNCTION
SUN 4-8:00

M-F 7:30-5:00

PARTY PRIVATE

UP TO 200
AVG. 50-75:


WORKING

- NORMAL 16-20 PEOPLE MORNING

MEAL SERVICE 250-300 MEALS

SEQUENCE OF OPERATION

ALL VOLTAGE ARE:
 THE OFFICE FAN IS STARTED BY THE ENCL AND WIND SUBJECT TO HIGH TEMPERATURE OFF-OFF
 HIGH-1 AND LOW TEMPERATURE OFF-OFF LTR-1.
 IN THE SECTION FAN AS SELECTED BY CONTROL CONTROLS AND EN-1. SPACE TEMPERATURE,
 CONTROLLER C-1 MONITORS VALVE C-1 AND MONITORS TEMPERATURE. CONTROLLER
 C-1 CAN OPERATE C-1 THROUGH SELECTOR RELAY S-1 TO MAINTAIN A MINIMUM ROOM AIR
 TEMPERATURE OF 55°.
 IN THE CHILLER ROOM, C-1 OPERATES T-1 ALONG TO MAINTAIN SPACE TEMPERATURE.



AIR HANDLER AHU-4
 (1 SET THIS)

Building 500

SCS SHEARER CONTROL SYSTEMS INC.
 10000 W. 10TH AVENUE, DENVER, CO 80231
 TEL: 303-751-1111 FAX: 303-751-1112

PROJECT: BLDG. 500 RENOVATION
 ADDRESS: FORT MITCHELL, GA
 DRAWING NO.: 5-20-85
 SHEET NO.: 5-20-85

INDEX OF OPERATOR

SEE NUMBER AND-1, AND-2

NOTE: TEMPERATURE T-1 CYCLES THE AIR WARMER SUPPLY FAN AND WET VALVE SUBJECT TO CONTROL CONTROLS REAR 20-1 AND THE DOCS TO MAINTAIN SPACE TEMPERATURE.



SEE NUMBER AND-1, AND-2, AND-3, AND-4

NOTE: TEMPERATURE T-1 CYCLES THE AIR WARMER SUPPLY FAN AND WET VALVE SUBJECT TO 20-1 AND THE DOCS TO MAINTAIN SPACE TEMPERATURE.

NOTE: REAR 20-1 OVERLOADS THE DOCS POSITION OF THE DOCS TO MAINTAIN A SETPOINT HIGH

LOW TEMP. (LOWT), LITCO-1, LITCO-2, STOP 20-1, 20-2, 20-3, 20-4, 20-5, IF


MUSGRAVE TEMP. PAUS 66204 20-1



SHEARER CONTROL SYSTEMS INC.
SHEARER CONTROL SYSTEMS INC.
SHEARER CONTROL SYSTEMS INC.

OFFICE: 2001 KENNEDY BLVD., FORT WASHINGTON, PA 19033
TELEPHONE: (610) 666-1111
FAX: (610) 666-1112
E-MAIL: SALES@SCS.COM
WEBSITE: WWW.SCS.COM

PROJECT: PATKEN
LOCATION: LAMDEN
DATE: 9-27-95



GENERAL NOTES AND EQUIPMENT SCHEMATIC

SEQUENCE OF OPERATION

- ALL NUMBERED AMP-7
- THE SYSTEM IS STARTED BY THE OPERATOR TO RISE TEMPERATURE ON-SETS 100-1
- AMP 2 AND LOW TEMPERATURE ON-SET 100-1
- IN THE STARTER ROOM, SPACE TEMPERATURE CONTROLLER C-7 OPERATES AMP-1 AND, UNDER SETTINGS
- AS TEMPERATURE IS RAISED, AMP-1, AMP-2, AMP-3 IN SEQUENCE TO MAINTAIN
- TEMPERATURE AT SETPOINT. CONTROLLER C-7 TRIPPS RELAY R-1 TO MAINTAIN A
- STABLE TEMPERATURE. C-7 TRIPPS RELAY R-1 TO MAINTAIN A
- STABLE TEMPERATURE.
- RELAY R-1 CIRCLES THE UNIT AT NIGHT TO MAINTAIN A STABLE UNOCCUPIED SETPOINT.
- SYSTEM-2 IS CONTROLLED EXACTLY THE SAME AS AMP-7 EXCEPT IT IS NOT CIRCLED ON AT NIGHT
- AND HAS NO NIGHT RELAY.
- SYSTEM-3 OPERATES VTES EP-1.
- AMP-3
- AMP-3 IS CONTROLLED EXACTLY THE SAME AS AMP-7.
- AMP-3 OPERATES VTES EP-3





FIGURE 20-12A

▲ AIR HANDLER UNIT 2 CONTROL (3-SETS TRIP)

SCS SHEARER CONTROL SYSTEMS INC.
 11151 VERNON
 2700 BULL
 FORT WORTH, TEXAS 76116
 TEL: 817-731-1111
 FAX: 817-731-1112

PROJECT: BLDG 500 COMBINATION
 LOCATION: FORT WORTH, TEXAS
 DRAWING NO.: 20-12A
 DATE: 5-20-85

BUILDING 514

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. 1 OF 12
CALCULATED BY: KC
CHECKED BY:
DATE: 12-10-91

BLDG.# 514

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
BATHROOM NEAR OFFICE 'B' (NEW SECTION)	97.4 °F
KITCHEN SINK NEAR ROOM 4 (OPPOSITE END)	149.7 °F
PROBLEMS:	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. 2 OF 12
CALCULATED BY: [Signature]
CHECKED BY: [Signature]
DATE: [Signature]

BLDG.# 514

MOTORS

MOTOR #	<u>1</u>	HP	<u>5</u>	PH	<u> </u>	RPM	<u>45</u>
MODEL #	<u>F3 E-1</u>	VOLTS	<u>208</u>	AMPS	<u>15</u>		
SERIAL #	<u>10075 263 03</u>	PRESENT HR.	<u> </u>	TO	<u> </u>		
MFG	<u> </u>	REQUIRED HR.	<u> </u>	TO	<u> </u>		
FRAME	<u>3184</u>	EFF.	<u>8.6</u>				
DESCRIPTION	<u>Supply Fan, A11-3</u>		COMMENTS				

MOTOR #	<u> </u>	HP	<u> </u>	PH	<u> </u>	RPM	<u> </u>
MODEL #	<u> </u>	VOLTS	<u> </u>	AMPS	<u> </u>		
SERIAL #	<u> </u>	PRESENT HR.	<u> </u>	TO	<u> </u>		
MFG	<u> </u>	REQUIRED HR.	<u> </u>	TO	<u> </u>		
FRAME	<u> </u>	EFF.	<u> </u>				
DESCRIPTION	<u> </u>		COMMENTS				

MOTOR #	<u> </u>	HP	<u> </u>	PH	<u> </u>	RPM	<u> </u>
MODEL #	<u> </u>	VOLTS	<u> </u>	AMPS	<u> </u>		
SERIAL #	<u> </u>	PRESENT HR.	<u> </u>	TO	<u> </u>		
MFG	<u> </u>	REQUIRED HR.	<u> </u>	TO	<u> </u>		
FRAME	<u> </u>	EFF.	<u> </u>				
DESCRIPTION	<u> </u>		COMMENTS				

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study

PROJ.# EMC # 3105.000

SHEET NO. 1 OF 10

CALCULATED BY:

CHECKED BY:

DATE:

BLDG.# 514

ECONOMIZER DATA

UNIT #	MFG.	MODEL #	SERIAL #	UNIT TYPE
3	Leeson	E2-205-1 FW	5484021018	MIX AIR

SUPPLY FAN		DAMPERS			COILS			TYPE					
CFM	<u>1176</u>	MAX%	<u>100</u>	OA	<u>NO</u>	SA	<u>NO</u>	RA	REL. AIR	MIX AIR	MIX AIR	PREHEAT	
HP	<u>5</u>	MIN%	<u>10</u>									HEAT	<u>X</u>
MFG.	<u>CENTURY MOTOR</u>	DAMPER MTR.	<u>NO</u>									HUMID	
MODEL #	<u>N/A</u>											COOLING	<u>X</u>
SERIAL #	<u>N/A</u>												

COMMENTS:

See Form attached with SA Data

OCCUPANCY

MIN OA REQUIRED


FOR VAN MORE DATA SEE MOTOR FORM

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: 2 OF 12
 CALCULATED BY: [Signature]
 CHECKED BY:
 DATE: [Signature]

BLDG.#: 57

DUCTWORK



OA DUCT	DAMPERS				
SIZE	DAMPER#	LOCATION	SIZE	ACTUATOR	CONTROLS
SIZE: 12" x 12" CFM: 1100 RATIO: 25% V. 15" 11/2	1	50"		NONE	MANUAL

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJ.# EMC # 3105.000
SHEET NO. 4 OF 12
CALCULATED BY: KC
CHECKED BY:
DATE: 12-10-91

BLDG.# 514

ECONOMIZER DATA AHU-3

SKETCH CONTROLS AHU ON NEW SECTION ABOVE CEILING.

HAS LENNOX BM-3179 CONTROL
RL-45

FURNACE & DX WITH 7' STAT

MOTOR STR WITH H-O-A SW.

COMMENTS:

- HAS OA DUCT W/ BALANCING DAMPER SET FOR MIN OA.

- HAS ROOM FOR ECONOMIZER.

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: OF 12
 CALCULATED BY: CEC
 CHECKED BY:
 DATE: 12-10-91

BLDG.# 514

ECONOMIZER DATA

UNIT #	MFG.	MODEL #	SERIAL #	UNIT TYPE
AHU-1	CARRIER	58GP12S-DA	100	SINGLE ZONE INPUT 125000BTU/HR
AHU-2	"	"	100	"

FURNACE SECTION

SUPPLY FAN	DAMPERS	COILS	TYPE
CFM	MAX% MIN% DAMPER MTR.	OA SA RA REL. AIR MIX AIR PREHEAT	HEAT HUMID COOLING
HP 1/2 HP	NONE NONE		GAS FURNACE
MFG. CARRIER			
MODEL # 58GP12S-DA			
SERIAL #			

COMMENTS: NO OA ON SYSTEMS
 - TWO FURNACES SIDE BY SIDE
 - MOTOR FX TO FAN, NAME PLATE NOT ACCESSIBLE
 - PRESENT RUN 0-2400 S-S

OCCUPANCY 0630 - 1800
 M-F
 MIN OA REQUIRED

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany


JOB _____

SHEET NO. 7 OF 11

CALCULATED BY CEL DATE 12/10/91

CHECKED BY _____ DATE _____

SCALE _____



DATE: 12/10/91
BY: CAJ

I. AIR HANDLING UNIT SURVEY OBSERVATIONS

BLDG NO: 514 BLDG NAME: CHILD CARE JOB: _____
AHU NO: 1 & 2 LOCATION: MECH RM
ZONE NO. SERVED: _____ REF. SYS. SERVING AHU: _____
([] VERIFIED ZONE OCCUPANCY AND TEMP. REQUIREMENTS ON SURVEY FORM VI.)
UNIT TYPE: SINGLE ZONE [] MULTIZONE [] DOUBLE DT [] REHEAT []
HEAT & VENT [] 2-PIPE FC [] 4-PIPE FC [] UNIT HT []
OTHER [] FURNACE, FAN CYCLES
MFG: CARRIER MODEL: 586P125-DA
SUPPLY FAN: FAN HP: 1/2 * MFG: _____ MODEL: _____
CFM: SA _____ RA _____ OA _____ (MEASURED [] ESTIMATED [])
PRESENT DAILY STARTUP: M-F 0 TO 2400 SAT 0 TO 2400 SUN 0 TO 2400
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING, YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F 0630 TO 1800, SAT 0 TO 0, SUN 0 TO 0

COILS: PREHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HEATING: NONE [] STM [] HW [] ELEC [] ~~MOD VLV []~~ GAS *
REHEAT: NONE [] STM [] HW [] ELEC [] MOD VLV []
HUMID: NONE [] STM [] HW [] ELEC [] MOD VLV []
COOLING: NONE [] CW [] DX [] SPRAY [] OTHER []

REMARK:

DAMPERS: OUTSIDE AIR: MAX % 0, MIN % 0, DAMPER MTR YES [] NO []
RETURN AIR: MAX % 100 MIN % 100 DAMPER MTR YES [] NO []
RELIEF AIR: MAX % _____, MIN % _____, DAMPER MTR YES [] NO []
MIXED AIR CONTROL [], ECONOMIZER (DB [] OR ENTH []) NONE []

REMARKS: NO OA ON SYSTEM

SUPPORT FANS: UNIT NONE RETURN FAN [] EXHAUST FAN [] OTHER []
FAN HP: _____ MFG: _____ MODEL: _____

THERMOSTAT TYPE: SINGLE SETPOINT [] DUAL SETPOINT [] SETBACK []
PNEUMATIC [] ELECTRIC/ELECTRONIC [] NO. OF ZONES _____
SETPOINT: OCC HEAT _____ °F UNOCC HEAT _____ °F OCC COOL _____ °F UNOCC COOL _____ °F
RESET CONTROLS: YES [] NO [], DECK SETPOINT HOT _____ °F COLD _____ °F
DEMAND LIMITING, DUTY CYCLING YES [] NO []

REMARKS: TWO FURNACES, SET SIDE BY SIDE

* FURNACES SECTION

MODEL 586P125-DA
SERIES 100
INPUT 125,000 BTU/HR } 200

* MOTOR FIX TO FAN
NAMEPLATE NOT ACCESSIBLE

Ft. Story EMCS Feasibility Study
EMC #3104.000

DATE: 12/10/91
BY: BA

IV. REFRIGERATION EQUIPMENT SURVEY OBSERVATIONS

BLDG NO: 514 BLDG NAME: CITILD CARE JOB: _____
CHILLER/COMPRESSOR NO: 2 LOCATION: ON PAD
REFRIG. EQUIP. TYPE: CENTRIFUGAL [] RECIPROCATING [] ABSORPTION []
OTHER []
CW [] DX [] OTHER []
MANUFACTURER: LENNOX MODEL NO: *NAME PLATE NOT LEGIBLE
SERIAL NO. _____
COMPRESSOR NAMEPLATE: * VOLTS _____ AMPS _____ PH _____ HZ _____ Hp _____
CAPACITY: est 20 (TONS) CHW TEMP: SUPPLY _____ °F RETURN _____ °F
AHU'S SERVED: 3

PRESENT DAILY STARTUP: M-F 0 TO 2400, SAT 0 TO 2400, SUN 0 TO 2400
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F 0630 TO 1800, SAT 0 TO 0, SUN 0 TO 0

CONDENSING EQUIP.: AIR COOLED [] EVAP. [] WINTERIZED []
WATER COOLED [] 3-WAY VALVE [] NO. OF CELLS []
OTHER []

MANUFACTURER: _____ MODEL NO. _____
SERIAL NO. _____
NO. OF FANS 2, EACH FAN: * VOLTS _____ AMPS _____ PH _____ HZ _____ Hp _____
CAPACITY: _____ (TONS) CNW TEMP: SUPPLY _____ °F RETURN _____ °F

SYSTEM AUXILIARIES:
PUMPS: CHW PUMP [] _____ VOLTS _____ AMPS _____ PH _____ HZ _____ Hp _____ RPM
CNW PUMP [] _____ VOLTS _____ AMPS _____ PH _____ HZ _____ HP _____ RPM
NONE

TEMP. CONTROLS MFG. AND TYPE _____

CHILLER INTERLOCKS WITH CHW PUMP [] CNW PUMP [] OTHER []
CONTROL PANEL INDICATIONS: HI (LGTS) LO (LGHTS) GAUGES
MOTOR TEMP [] [] []
REFRIG TEMP [] [] []
COND TEMP [] [] []
OIL TEMP [] [] []
OIL PRESS [] [] []
OTHER _____

REMARKS:

Ft. Story EMCS Feasibility Study
EMC #3104.000

DATE: 12/10/91
BY: CR

IV. REFRIGERATION EQUIPMENT SURVEY OBSERVATIONS

BLDG NO: 514 BLDG NAME: CHILD CARE JOB: _____
CHILLER/COMPRESSOR NO: 1 LOCATION: ON PAD
REFRIG. EQUIP. TYPE: CENTRIFUGAL [] RECIPROCATING [] ABSORPTION []
OTHER []
CW [] DX [] OTHER []
MANUFACTURER: CARRIER MODEL NO. 38BA 009550
SERIAL NO. 4988614348
COMPRESSOR NAMEPLATE: 208 VOLTS 39.6 AMPS 3 PH 60 HZ - Hp
CAPACITY: 10 (TONS) CHW TEMP: SUPPLY _____ °F RETURN _____ °F
AHU'S SERVED: 1 & 2

PRESENT DAILY STARTUP: M-F 0 TO 2400, SAT 0 TO 2400, SUN 0 TO 2400
STARTUP METHOD: MANUAL [] TIMECLOCK [] (WORKING YES [] NO [])
SEASONAL SWITCHOVER: SUM _____ TO _____, WIN _____ TO _____
REQUIRED DAILY STARTUP: M-F 0300 TO 1800, SAT 0 TO 0, SUN 0 TO 0

CONDENSING EQUIP.: AIR COOLED [] EVAP. [] WINTERIZED []
WATER COOLED [] 3-WAY VALVE [] NO. OF CELLS []
OTHER []

MANUFACTURER: _____ MODEL NO. _____
SERIAL NO. _____
NO. OF FANS 1, EACH FAN: 208 VOLTS 3.6 AMPS 3 PH 60 HZ .31 Hp
CAPACITY: _____ (TONS) CNW TEMP: SUPPLY _____ °F RETURN _____ °F

SYSTEM AUXILIARIES:

PUMPS: CHW PUMP [] _____ VOLTS _____ AMPS _____ PH _____ HZ _____ Hp _____ RPM
CNW PUMP [] _____ VOLTS _____ AMPS _____ PH _____ HZ _____ HP _____ RPM
NONE

TEMP. CONTROLS MFG. AND TYPE _____

CHILLER INTERLOCKS WITH CHW PUMP [] CNW PUMP [] OTHER [] _____
CONTROL PANEL INDICATIONS: HI (LGTS) LO (LGHTS) GAUGES
MOTOR TEMP [] [] []
REFRIG TEMP [] [] []
COND TEMP [] [] []
OIL TEMP [] [] []
OIL PRESS [] [] []
OTHER _____

REMARKS:

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____
SHEET NO. 12 OF 12
CALCULATED BY CEL DATE 12/10/91
CHECKED BY _____ DATE _____
SCALE _____

514

HOURS OF OPERATION

> 0630 - 1300 M-F

SYSTEMS RUN ALL THE TIME

> "MAYBE (?) THEY SETBACK"

CURRENT TEMP 75.3°F

OCCUPANCY

> STAFF ————— BETWEEN

27-33

> CHILDREN —————

60-65

OTHER ECO's

- DELAMP

-

BUILDING 522

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: JW
 CHECKED BY: _____
 DATE: 12/31/91

BLDG.# 522
 ECO 1

WALL & ROOF INSULATION

AREAS IN SQ. FEET	NORTH	SOUTH	EAST	WEST
WALLS				
WINDOWS				
OVERHEAD DOORS				
PERSONNEL DOORS				

SKETCH WALL CROSS-SECTION	COMPONENTS
<p>BRICK GYP BOARD</p>	1. OUTSIDE AIR FILM 2. _____ 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

SKETCH ROOF CROSS-SECTION	COMPONENTS
<p>SHINGLES AIR SPACE WOOD R-19 6" STUCCO</p>	1. OUTSIDE AIR FILM 2. _____ 3. _____ 4. _____ 5. _____ 6. _____ 7. INSIDE AIR FILM

PERSONNEL DOOR TYPE _____	BASEMENT [] SLAB [] CRAWL SPACE []
OVERHEAD DOOR TYPE _____	

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB
PROJ.#
SHEET NO. 022 OF
CALCULATED BY:
CHECKED BY:
DATE 12/31/91

FT. McPherson/Ft. Gillem Energy Study
EMC # 3105.000

BLDG.# 522
ECO 1

PIPE INSULATION

LOCATION	PIPE DIAMETER	PIPE LENGTH	FLUID TYPE	FLUID TEMP.	AIR TEMP.	INSULATION TYPE	INSULATION THICKNESS	INSULATION CONDITION
MECH RM	1 1/2" (TYPICAL)		HW	120° HW	65°F	FIBER	1"	GOOD
"	1" (TYPICAL)		CHW	~ 45°	90°F	"	1"	"
"	1" (TYPICAL)		DHW	~ see DHW	AVG 70	"	1/2"	"
"	1 1/2"		CHW	45°	90°	"	1"	"
"	3/4"		DHW*	~ see DHW	AVG 70	"	1/2"	"

COMMENTS:

ESTIMATE 6' OF HW LINE NOT INSULATED
 " 6' OF 3/4" DHW RETURN LINE NOT INSULATED
 * DHW RETURN REGIRC LINE

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
 PROJ.#: EMC # 3105.000
 SHEET NO.: _____ OF _____
 CALCULATED BY: J W
 CHECKED BY: _____
 DATE: 12/31/91

BLDG.# 522
 ECO 3

WEATHERSTRIPING AND CAULKING

DOOR/ WINDOW	CONDITION OF W.S./CAULK	INFILTRATION	ORIENTATION	DIMENSIONS (INCH)	#
W	GOOD	NONE	W	32x61	14
D	FAIR	MED	E	36x81	1
W	GOOD	NONE	E	32x61	20 16
W	GOOD	NONE	E	24x48	4
D	GOOD	LOW	N	36x81	1
W		NONE	N	32x61	1
W		NONE	W	24x48	5
W			W S	32x61	10
D			S		

COMMENTS:

EMC ENGINEERS, INC.
 DENVER * ATLANTA * GERMANY

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB: Ft. McPherson/Ft. Gillem Energy Study
PROJ.#: EMC # 3105.000
SHEET NO.: _____ OF _____
CALCULATED BY: JW
CHECKED BY: _____
DATE: 12/31/91

BLDG.# 522
ECO 4

DOMESTIC HOT WATER

FAUCET LOCATION	WATER TEMPERATURE
KITCHEN SINK	125°F

PROBLEMS:

COMMENTS:

EMC ENGINEERS, INC.
DENVER * ATLANTA * GERMANY

JOB Ft. McPherson/Ft. Gillem Energy Study
PROJECT NO. EMC # 3105.000
SHEET NO. OF
CALCULATED BY: JW-EMC ENGINEERS
CHECKED BY: DENVER * ATLANTA * GERMANY
DATE: 12/31/91

BLDG.# 522
ECO 5

MOTORS

MOTOR #	<u>CHWP</u> DWTEMP GE	HP	<u>2</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>5K49UG1342H</u>	VOLTS	<u>200</u>	AMPS	<u>8.1</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>GE</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						
MOTOR #	<u>DOM. HW CIRC.</u>	HP	<u>1/2</u>	PH	<u>1</u>	RPM	<u>1725</u>
MODEL #	<u>M09181 4-90</u>	VOLTS	<u>115</u>	AMPS	<u>1.75</u>		
SERIAL #		PRESENT HR.		TO			
MFG	<u>BELL & GOSSETT</u>	REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						
MOTOR #	<u>HWP</u>	HP	<u>2</u>	PH	<u>3</u>	RPM	<u>1725</u>
MODEL #		VOLTS	<u>200</u>	AMPS	<u>4.2</u>		
SERIAL #		PRESENT HR.		TO			
MFG		REQUIRED HR.		TO			
FRAME		EFF.					
DESCRIPTION	COMMENTS						

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. 1 OF _____

CALCULATED BY CB DATE 12/31/91

CHECKED BY _____ DATE _____

SCALE _____

522 FOR ECO 9, HEAT RECLAIM

DOMESTIC HW HEATER

- BRADFORD WHITE WATER HEATER

- MODEL M-F - 22 U - 199 - 3N

- 82 GAL

- INPUT 99,999 BTU/HR N. GAS

- 181.8 GAL/HR RECOVERY

JOB Ft. McPherson/Ft. Gillem Energy Study
 PROJ.# EMC # 3105.000
 SHEET NO. _____ OF _____
 CALCULATED BY: DAVID W. BROWN JR
 CHECKED BY: _____
 DATE: 12/31/91

VI. BUILDING DATA SURVEY OBSERVATIONS

BLDG NO: 522 BLDG NAME: OFFICERS QTRS JOB: 3105.000
 PRIMARY FUNCTION: _____ GROSS SQ FT _____ NO OF FLRS _____
 BUILDING MANAGER NAME: _____

PHONE: _____ OFFICE NO. _____
 SPECIAL AREAS: COMPUTER FACILITY [] - ZONE NO'S. _____
 AUDITORIUM [] - ZONE NO'S. _____
 LABORATORIES [] - ZONE NO'S. _____
 CAFETERIA [] - ZONE NO'S. _____
 OTHER [] - ZONE NO'S. _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F 0 TO 240, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

ZONE NO. _____ FUNCTION: _____ SPECIAL REQ. YES [] NO []
 LOCATION: _____ (IDENTIFIED ON FLOOR PLAN [])
 OCCUPANCY HOURS: M-F _____ TO _____, SAT _____ TO _____, SUN _____ TO _____
 PRESENT TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F
 REQUIRE TEMP: WINTER OCC _____ °F UNOCC _____ °F, SUMMER OCC _____ °F UNOCC _____ °F

REMARKS: _____

E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY _____ DATE _____

CHECKED BY _____ DATE _____

SCALE _____

BLDG. 522

6 ROOMS

2 - DOWNSTAIR

4 - UPSTAIR

THE ROOM


FAN DATA

3 - SPEED FAN (OFF-L-M-H)

MOTOR

5KSP290K 14875

1.5A 1/30 HP 115V



SHOWER 5 QT IN 30 SEC
3 1/2 QT IN 30 SEC

FAUSETTS 5 CUPS IN 3 SEC.


8 FAN COILS DOWNSTAIR

6 " " UPSTAIR

WINDOW - WOOD FRAME

32" X 61" DOUBLE PANE

32" X 37" " " "



E M C ENGINEERS, INC.

Denver • Colorado Springs • Atlanta • West Germany

BLDG 522

JOB _____

SHEET NO. _____ OF _____

CALCULATED BY JW DATE 12/31/91

CHECKED BY _____ DATE _____

SCALE _____

~~DUAL TEMP PUMP:~~

~~GE~~
MOD:


CHILLER TYPE: 3 FAN w/ WATER (NO DX)

TRANE
S# L79K07794
208-240V

2 COMPRESSORS
3 ϕ 60Hz 37.8 RLA
179 LRA
3 FAN MOTORS
1 ϕ 60Hz 2.3 FLA 1/3 HP

MOD #
CGAA0156JB53CG5C4A311CK


BUILDING DIMENSION



Checklist, Wiring and Equipment Schedule

SEQUENCE OF OPERATION

1. ALL INSTRUMENTS ARE TO BE CALIBRATED AND CHECKED FOR ACCURACY.
 2. MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 3. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 4. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 5. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 6. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 7. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 8. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 9. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.
 10. ALL INSTRUMENTS ARE TO BE CHECKED FOR AIR AND WATER SUPPLY AND THE MAIN INSTRUMENTS TO BE CHECKED FOR AIR AND WATER SUPPLY.



SHEARER CONTROL SYSTEM

DATE	1/12/2000
PROJECT	PROJECT 111/PRESGAIN, GA
DESIGNER	DAVIDSON
CHECKED BY	L. WILSON
DATE	1/12/2000