


**ENERGY SURVEY OF
ARMY DINING FACILITIES
FORT BRAGG, NC**



EXECUTIVE SUMMARY

Contract #DACA21-86-C-0059
April 8, 1988

DISTRIBUTION STATEMENT E
Approved for public release
Declassification Unclassified

Final Report Submitted to:

Commander
US Army Engineer District, Savannah
ATTN: SASEN-MP
100 Oglethorpe Avenue
Savannah, GA 31401

Submitted by:

Donald R. Burroughs, PE

DR Koenigshofer

Daniel R. Koenigshofer, PE
President, IES Engineers

19971023 193




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.



A handwritten signature in black ink, appearing to read "Marie Wakefield".

Marie Wakefield,
Librarian Engineering

TABLE OF CONTENTS, EXECUTIVE SUMMARY

Page

1.1	Introduction	1
1.2	General Description of the Facilities	3
1.3	Present Energy Consumption	4
1.4	Energy Conservation Analysis	4
1.5	Energy Cost and Savings	20
1.6	Projects Developed	20

List of Figures

1-1	Total Annual Energy Consumption of Detailed Buildings	5
1-2	Calculated Annual Energy Cost of Detailed Buildings 1987	6
1-3	Energy Consumption Before and After for Detailed Buildings	23
1-4	Energy Cost Before and After for Detailed Buildings	24
1-5	Energy Cost Before and After for All Buildings	27

List of Tables

1-1	List of Dining Facilities Audited	2
1-2	Estimated Building Energy Consumption and Cost	7
1-3	Sample ECO Checklist	8
1-4	Order of Computer Runs to Account for Interaction	14
1-5	Recommended ECOs, Ranked by SIR, All Buildings	15
1-6	Typical ECOs Not Recommended	20
1-7	Recommended ECOs by Category	21
1-8	Total Energy Cost and Consumption, Before and After Conservation (Detailed Buildings)	22
1-9	Energy Summary Data, Detailed Buildings	25
1-10	Extrapolated Energy Data, Walk-thru Buildings	26
1-11	Project Summary Totals	29

DTIG QUALITY INSPECTED 3

EXECUTIVE SUMMARY

1. Introduction

1.1 Scope of Work

IES Engineers was contracted by the Savannah District of the US Army Corps of Engineers in July 1986 to perform a complete energy audit and analysis of forty-three dining facilities at Fort Bragg, North Carolina. The essential elements of the Scope of Work (SOW) are listed below. The majority of the buildings are permanent structures with a remaining useful life of over 25 years. Five of the buildings are temporary structures which are expected to remain in use for at least ten years.

BRIEF DESCRIPTION OF WORK: The Architect-Engineer (AE) shall:

1. Perform a complete energy Audit and Analysis of the dining facilities.
2. Identify all Energy Conservation Opportunities (ECOs) including low cost/no cost ECOs and perform complete evaluations of each.
3. Prepare programming documentation [DD 1391, Life Cycle Cost Analysis Summary Sheet with backup calculations and Project Development Brochure (PDB)] for any Energy Conservation Investment Program (ECIP) projects.
4. Prepare implementation documentation for all justifiable energy conservation opportunities.
5. List and prioritize all recommended Energy Conservation Opportunities.
6. Prepare a comprehensive report which will document the work accomplished, the results and recommendations.

The project consisted of detailed audits of twenty dining facilities and "walk-through" audits of the remaining twenty-three buildings. The buildings are listed by number in Table 1-1. Per the SOW, the Building Loads Analysis and Systems Thermodynamics (BLAST) computer program was used to simulate existing energy consumption and to evaluate energy conservation opportunities (ECOs) in the buildings receiving detailed audits. "Walk-through" audits were then performed on the remaining buildings in order to determine which of the previously identified ECOs could be duplicated.

In addition to the energy audits, the SOW also called for the testing of solar domestic hot water systems in buildings C-4122 and H-5718, and ventilation studies in all of the "C" buildings.

Table 1-1. List of Dining Facilities Audited

Buildings Included in Detailed Audit

Building	Sq ft	Building	Sq ft
C-4122	4,850	O-9013	4,800
C-4422	4,850	P-3042	7,857
C-6432	4,850	I-1242	3,168
C-8344	4,850	4-1437	7,500
C-8750	5,050	A-3275	5,608
C-9349	5,050	AT-4622	2,800
C-7236	4,850	AT-4632	2,800
D-2626	11,313	AT-4686	2,800
D-3404	9,346	MT-6115	2,375
H-5718	14,920	8T-3849	13,400

Buildings Receiving Walk-through Audits

Building	Sq ft	Building	Sq ft
C-3020	4,850	C-7433	4,850
C-3027	4,850	C-7634	4,850
C-3321	4,850	C-8339	4,850
C-4120	4,850	C-8541	4,850
C-4125	4,850	C-6726	4,850
C-4424	4,850	C-8438	4,850
C-4426	4,850	D-2105	11,313
C-4428	4,850	D-3039	11,313
C-5528	4,850	D-3055	11,313
C-5725	4,850	H-4842	14,920
C-6525	4,850	2-1105	3,168
		2-1138	3,168

1.2 General Description of the Facilities

Refer to Table 1-1 for a listing of all of the facilities. The "C area" buildings (buildings with the C prefix) are all similar concrete block structures consisting of a dining facility connected to a three story barracks. The barracks portion of each building was not included in the SOW of this study. The buildings are of two types; type 64 and type 121, with the only difference being slight variations in the floor plan.

The "D" buildings are dining facilities serving the "D area barracks". The barracks portion of each building was not included in the SOW of this study. All of the buildings are identical brick and block with the exception of D-3404. The floor plan and interior equipment of building D-3404 is slightly different from the other buildings.

Buildings H-4842 and H-5718 are relatively new dining facilities. The two buildings are similar brick and block buildings with slight variations in floor plans.

Building 0-9013 is a prefabricated metal building which serves as a classroom and dining facility at the Mott Lake Training Center. The classroom portion of the building was not included in the SOW of this study.

Building P-3042 is a concrete block structure which houses a warehouse and dining facility for Simmons Army Airfield. The warehouse portion of the building was not included in the SOW of this study.

Buildings 1-1242, 2-1105, and 2-1138 are three story brick and block structures which serve as military police barracks. Each building houses a kitchen and dining facility on the ground floor. The SOW of this study included only the dining area portion of the building.

Building 4-1437 is a relatively new brick and block structure, half of which serves as a dining facility and the remaining half as storage and offices. The storage and offices are not part of the dining facility and were not included in the SOW of this study.

Buildings AT-4622, AT-4632, and AT-4686 are identical temporary wood frame dining facilities. The buildings have recently been covered with wall insulation and metal siding. Building MT-6115 is similar to these buildings with the only difference being a slight variation in size and the absence of new insulation and metal siding.

Building 8T-3849 is a large temporary wood frame structure serving as a dining facility. One dining room wing of the structure is currently used only periodically as a classroom, but was surveyed under this contract.

1.3 Present Energy Consumption

1.3.1 Total Annual Energy Used

The total estimated energy consumption of the detailed buildings audited, as predicted by the BLAST computer model is shown in Figure 1-1. The total energy cost including demand charges is estimated at \$495,716. This assumes completion of all planned or ongoing projects. Figure 1-2 shows the total energy cost by fuel type.

1.3.2 Energy Consumption by Building

Table 1-2 lists the energy consumption and cost by fuel type for all detailed buildings audited. These costs include electric demand costs.

1.4 Energy Conservation Analysis


1.4.1 ECOs Investigated

All of the ECOs shown in the sample checklist (Table 1-3) on the following pages were investigated for each building in the SOW. Similar checklists for each building appear in the respective chapter for that building. A "Yes" means that the ECO seemed feasible in the field and was considered further. All those marked "Yes" are described in this report, although after further analysis some resulted in not being recommended. A "No" on the checklist indicates that the ECO was unfeasible as explained. A comparison of the SOW checklist and each of the building lists will show that many additional ECOs were investigated.


All of the ECOs were evaluated relative to the base case building simulations on BLAST. The BLAST runs were run interactively, i.e., assuming implementation of previously analyzed ECOs. The order of the BLAST runs is shown in Table 1-4. This order is based on the assumption that ECO's which will reduce the load on the HVAC equipment should be implemented before HVAC ECO's are implemented.

1.4.2 ECOs Recommended

Table 1-5 lists all ECOs recommended for the detailed and walk-through buildings in order of SIR. As indicated, the total installed cost is estimated to be \$261,975 with a total annual savings of \$110,880 for a payback of 2.4 years.

Figure 1-1.**TOTAL ANNUAL ENERGY CONSUMPTION
OF DETAILED BUILDINGS
BASED ON BLAST ANALYSIS**Buildings Included in Detailed Audit

Building	Sq ft	Building	Sq ft
C-4122	4,850	O-9013	4,800
C-4422	4,850	P-3042	7,857
C-6432	4,850	I-1242	3,168
C-8344	4,850	4-1437	7,500
C-8750	5,050	A-3275	5,608
C-9349	5,050	AT-4622	2,800
C-7236	4,850	AT-4632	2,800
D-2626	11,313	AT-4686	2,800
D-3404	9,346	MT-6115	2,375
H-5718	14,920	8T-3849	13,400

Figure 1-2.**CALCULATED ANNUAL ENERGY COST 1987
OF DETAILED BUILDINGS
BASED ON BLAST ANALYSIS**Buildings Included in Detailed Audit

Building	Sq ft	Building	Sq ft
C-4122	4,850	0-9013	4,800
C-4422	4,850	P-3042	7,857
C-6432	4,850	I-1242	3,168
C-8344	4,850	4-1437	7,500
C-8750	5,050	A-3275	5,608
C-9349	5,050	AT-4622	2,800
C-7236	4,850	AT-4632	2,800
D-2626	11,313	AT-4686	2,800
D-3404	9,346	MT-6115	2,375
H-5718	14,920	8T-3849	13,400

Table 1-2. Estimated Building Energy Consumption and Cost

Building	KWH	KW	Electricity MBTU	Cost	GAL	Fuel MBTU	Oil \$	Therms	GAS MBTU	\$	TOTAL MBTU	\$
C-4122	361236	113.3	1232.9	20244	0	0.0	0	15063	1506.3	5634	2739.2	25877
C-4422	324905	110.4	1108.9	18793	0	0.0	0	18287	1828.7	6839	2937.6	25633
C-6432	343246	112.9	1171.5	19597	0	0.0	0	17541	1754.1	6560	2925.6	26158
C-8344	336947	110.8	1150.0	19230	0	0.0	0	15119	1511.9	5655	2661.9	24884
C-8750	306680	105.8	1046.7	17846	0	0.0	0	19753	1975.3	7388	3022.0	25234
C-9349	311691	106.2	1063.8	18045	0	0.0	0	19686	1968.6	7363	3032.4	25408
C-7236	297158	76.2	1014.2	15481	0	0.0	0	31448	3144.8	11762	4159.0	27243
D-2626	267682	81.4	913.6	14824	0	0.0	0	48679	4867.9	18206	5781.5	33030
D-3404	247612	51.9	845.1	12100	0	0.0	0	29206	2920.6	10923	3765.7	23023
H-5718	761764	217.5	2599.9	41207	0	0.0	0	59887	5988.7	22398	8588.6	63604
O-9013	54439	39.4	185.8	4593	1665	231.0	1365	1651	165.1	617	581.9	6575
P-3042	139672	27.4	476.7	6693	10917	1514.2	8949	12020	1202.0	5289	3192.9	20931
I-1242	212716	106.6	726.0	24147	11576	1605.6	9489	0	0	0	2331.6	33637
4-1437	235130	100.0	802.5	23612	0	0.0	0	35371	3537.1	13229	4339.6	36841
A-3275	162028	41.9	553.0	11626	0	0.0	0	17000	1700.0	7480	2253.0	19106
AT-4622	65280	38.3	222.8	8377	0	0.0	0	10282	1028.2	4524	1251.0	12901
AT-4632	63493	37.8	216.7	8242	0	0.0	0	9217	921.7	4055	1138.4	12297
AT-4686	633375	37.8	216.3	8239	0	0.0	0	9671	967.1	4255	1183.4	12494
MT-6115	60973	36.7	208.1	7983	0	0.0	0	9223	922.3	4058	1130.4	12041
8T-3849	162291	39.9	553.9	8337	22433	3111.5	18389	4708	470.8	2072	4136.2	28798
	4778318	1592.5	16308.4	309218	46592	6462.3	38192	383812	383812	148306	61151.9	495716

Table 1-3. Sample ECO Checklist

FACILITY: Fort Bragg, NC

ENERGY ANALYSIS CHECKLIST, page 1 of 6

<u>ENERGY CONSERVATION OPPORTUNITIES (ECOs)</u>		<u>YES</u>	<u>NO</u>	<u>EXPLANATION</u>
A. Heating, ventilating, and air conditioning				
1. Night setback/setup, shut off AHUs when possible		X		E EMCs
2. Reduce OA intake when air must be heated or cooled before use.		X		E already at minimum
3. Reduce supply and/or exhaust air flows		X		E already at minimum
4. Shut off/reduce speed of room fan coils		X		NA no fan coil units
5. Shut off/reduce stairwell or vestibule heating		X		NA vestibule not heated
6. Shut off unneeded circulating pumps		X		E no unneeded pumps
7. Reduce humidification to minimum requirements		X		NA no humidification exists
8. Reduce condenser water temperature		X		NA central chiller plant
9. Cycle fans and pumps		X		E EMCs
10. Reduce pumping flow		X		E already at minimum
11. Maintain authorized temperatures		X		See A-29
12. Use damper controls to shut off air to unoccupied areas		X		NA no unoccupied areas
13. Repair and maintain steam lines and traps				E good condition
14. Reset hot and cold deck temperatures based on areas with the greatest need				NA single zone system
15. Raise chilled water temperature				NA central chiller plant
16. Shed loads during peak electrical use periods				No available loads
17. Use OA for dry bulb economizer cycle		X		NA not a reheat system
18. Reduce reheating of cooled air recovery units		X		See G-3 and G-4
19. Recover heating/cooling energy with energy cooling loads		X		NCE small system
20. Reduce chilled water circulated during light				

E - existing
 NCE - not cost effective
 NA - not applicable/does not exist/not appropriate

ENERGY CONSERVATION OPPORTUNITIES (ECOs)

A. Heating, ventilating, and air conditioning (continued)

	YES	NO	EXPLANATION
21. Install minimum sized motor to meet loads	X		E already minimum size NCE efficient system exists
22. Install infrared heating systems	X		NCE small system
23. Convert to variable air volume system	X		NA central chiller plant
24. Common manifolding of chillers	X		E insulation exists
25. Insulate ducts and piping	X		E no simultaneous heating and cooling
26. Eliminate simultaneous heating and cooling	X		See maintenance items See maintenance items
27. Clean coils	X		See maintenance items
28. Maintain filters	X		See maintenance items
29. Repair and/or maintain AHU controls	X		NA central boiler/chiller plant
30. Water treatment or prevent tube fouling	X		NA central chiller plant
31. Multispd/variable spd cooling tower fans	X		NA no areas with diff. schedule
32. Provide a separate cooling system	X		E system has return ducts
33. Provide return air ductwork	X		E does not leak
34. Reduce leakage of SA at AHU	X		E already at minimum
35. Reduce static pressure	X		E dining room has ceiling fans
36. Install destratification fans	X		E system is balanced
37. Balance airflows	X		E exhaust has integral make-up
38. Install make-up air systems in kitchen	X		NCE small system
39. Use thermal storage systems	X		E systems are shut off between meals
40. Shut off exhaust systems when not in use	X		E planned project
41. Install computerized energy monitoring and control system	X		

FACILITY: Fort Bragg, NC

ENERGY ANALYSIS CHECKLIST, page 3 of 6

Building No: 4122

Date collected:

IES Inc., Chapel Hill, NC

ENERGY CONSERVATION OPPORTUNITIES (ECOS)

	YES	NO	EXPLANATION
B. Boiler plant			
1. Reduce steam distribution pressure	X		NA central boiler plant
2. Increase boiler efficiency	X		NA central boiler plant
3. Repair, replace or install condensate return system.		X	NA central boiler plant
4. Insulate boiler and/or piping		X	NA central boiler plant
5. Install boiler economizer		X	NA central boiler plant
6. Install air pre-heater		X	NA central boiler plant
7. Check boiler water chemistry program.		X	NA central boiler plant
8. Clean boiler tubes		X	NA central boiler plant
9. Blowdown controls		X	NA central boiler plant
10. Modify boiler controls		X	NA central boiler plant
11. Install smaller boiler		X	NA central boiler plant
C. Lighting			
1. Shut off lights when not needed		X	lights are off between meals
2. Reduce lighting levels		X	already at minimum
3. Revise cleaning schedules		X	fixtures are clean
4. Convert to energy efficient systems	X		Dining hall

FACILITY: Fort Bragg, NC

ENERGY ANALYSIS CHECKLIST, page 4 of 6

Building No: 4122
Date collected:
IES Inc., Chapel Hill, NC

ENERGY CONSERVATION OPPORTUNITIES (ECOS)

EXPLANATION

D. Building Envelope

1. Reduce infiltration by caulking and weatherstripping
2. Install double pane windows
3. Install roof insulation
4. Install loading dock seals
5. Install vestibules on entrances
6. Install solar shading, films, screening, curtains, for blinds
7. Install insulation in walls
8. Install floor insulation
9. Install plastic strips at personnel entrances
10. Install insulating panels over windows

	YES	NO	EXPLANATION
1. Reduce infiltration by caulking and weatherstripping	X		E double pane windows recently installed
2. Install double pane windows		X	E retrofitted insulation installed
3. Install roof insulation		X	NCE usage too low
4. Install loading dock seals		X	E main entrance is through barracks
5. Install vestibules on entrances		X	E tinted windows
6. Install solar shading, films, screening, curtains, for blinds		X	E planned project
7. Install insulation in walls		X	NA floor over hot pipe chase
8. Install floor insulation		X	NA not practical for kitchen
9. Install plastic strips at personnel entrances		X	E top panels are insulated
10. Install insulating panels over windows		X	

E. Electrical Equipment

1. Use emergency generator to reduce peak demand
2. Shed/cycle electric loads to reduce peak demand
3. Convert to energy efficient motors
4. Improve power factor
5. Shut off electric equipment when not needed

1. Use emergency generator to reduce peak demand	X	NA no emergency generator
2. Shed/cycle electric loads to reduce peak demand	X	NA no loads which can be cycled
3. Convert to energy efficient motors	X	NCE small motors
4. Improve power factor	X	NA no current penalty charge
5. Shut off electric equipment when not needed	X	E personnel turn off unneeded equipment

FACILITY: Fort Bragg, NC

ENERGY ANALYSIS CHECKLIST, page 5 of 6

Building No: 4122
Date collected:
IES Inc., Chapel Hill, NC

ENERGY CONSERVATION OPPORTUNITIES (ECOs)

F. Plumbing

- | | YES | NO | EXPLANATION |
|--|-----|----|---------------------------------|
| 1. Reduce domestic hot water temperature | | X | E already at minimum |
| 2. Repair and/or install water heater and hot water piping insulation | | X | E good condition |
| 3. Install flow restrictors | | X | NA not practical for kitchen |
| 4. Install faucets which automatically shut off water flow | | X | NA not practical for kitchen |
| 5. Decentralize hot water heating | | X | NA kitchen uses majority of DHW |
| 6. Use booster heaters on dishwashing equipment | | X | Convert to steam |
| 7. Recover heat from hot wastewater | X | | |
| 8. Install heat pump water heaters to provide hot water and cool the dining area | X | | |
| 9. Improve water heater efficiency | X | | E good efficiency |
| 10. Shut off water heater during unoccupied period | | X | NA needed for barracks |

- - - - - ENERGY CONSERVATION OPPORTUNITIES (ECOS) - - - - -

6. Kitchen

	YES	NO	EXPLANATION
1. Shut off range hood exhaust when possible and install dampers	—	X	E personnel turn off hoods E personnel turn off unneeded equipment
2. Shut off equipment and appliances whenever possible	X	—	E
3. Recover heat from refrigeration equipment	X	—	E
4. Install exhaust heat recovery systems	X	—	E
5. Install automatic pilot lights	—	X	E
6. Install low temperature chemical rinse	—	X	E
7. Optimize kitchen operational procedures	X	—	E see Chapter 1
8. Operate dishwashers only with full loads	—	X	E dishwashers used only for full loads
9. Preheat only the equipment that will be used	—	X	E
10. Preheat equipment just before using	—	X	E already done
11. Avoid use of hot water for dish scraping	—	X	E already done
12. Clean refrigeration coils	—	X	E used only when necessary
13. Cook with lids in place	—	X	E coils are clean
14. Thaw frozen food in refrigerated compartments	X	—	E lids are used
15. Direct cooling fans away from cooking equipment	—	X	NA no ceiling fans in kitchen
16. Use kitchen exhaust only when needed	—	X	E personnel turn off between meals
17. Clean exhaust hood grease filters	—	X	E filters were clean
18. Provide direct exhaust hood make-up air supply	—	X	E
19. Match pots to burner size so that pots completely cover burner	—	X	E direct supply exists
20. Steam vegetables in lieu of boiling when possible	—	X	E large pots are used
21. De-energize booster water heaters at night	—	X	E steamer is used when possible
22. Use microwave cooking equipment in lieu of conventional equipment when possible	X	—	E units are turned off at night

Table 1-4. Order of Computer Runs to Account for Interaction

- 1) base case as observed during field investigation
(including planned projects)
 - 2) implement envelope ECOS
 - 3) implement lighting ECOS
 - 4) implement ECOS to miscellaneous equipment
 - 5) implement HVAC ECOS
-

Table 1-5, Recommended ECOS, Ranked by SIR, All Buildings

ECO AND DESCRIPTION	INSTALLED COST	\$ SAVINGS ENERGY	PAYBACK YRS	ANNUAL SAVINGS		
				FIRST YEAR	GAS MBTU	OIL MBTU
B-8-8T-3849 Clean Boiler Tubes	201	1918	-130	0.1	84.25	0.0
A-29-AT-4686 Repair Controls	153	332	0	0.5	23.14	0.0
F-6-4-1437 Steam Booster Heater	3506	254	6026	0.6	16.98	113.9
C-4-AT-4622 Fluorescent Lighting	52	53	52	0.5	14.55	8.2
C-4-AT-4632 Fluorescent Lighting	52	51	52	0.5	14.28	8.2
A-1-A-3275 Night Setback Controls	1266.0	1334.0	-37.0	1.0	10.63	20.0
F-6-C-4424 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-4122 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-4120 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-8339 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-3321 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-7433 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-3027 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-6432 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-3020 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-5528 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-8541 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-4426 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-8750 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-4422 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-4125 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-8344 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-4428 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-5725 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-6525 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-9349 Steam Booster Heater	3030	530	2655	1.0	9.18	122.6
F-6-C-7634 Weatherstripping	307	137	0	2.2	8.86	0.0
D-1-0-9013 Weatherstripping	90	51	10	1.5	8.57	5.1
C-4-P-3042 Fluorescent Lighting	90	274	0	1.8	7.24	0.0
A-1-0-9013 Night Setback Thermostat	506	66	0	1.6	6.46	11.7
C-4-8T-3849 Fluorescent Lighting	104	221	219	0	4.82	1.0
D-1-P-3042 Weatherstripping	786	349	-25	2.4	4.28	6.3
A-1-MT-6115 Night Setback	90	65	0	1.4	3.72	1.2
D-1-C-6726 Weatherstripping						0.0

Table 1-5, Recommended ECOS, Ranked by SIR, All Buildings (Continued)

ECO AND DESCRIPTION	INSTALLED COST	\$ SAVINGS ENERGY	PAYBACK YRS.	ANNUAL SAVINGS		
				FIRST YEAR	ELEC MBTU	GAS MBTU
D-1-C-8438 Weatherstripping	90	65	0	1.4	3.72	1.2
D-1-C-7236 Weatherstripping	90	65	0	1.4	3.72	1.2
D-7-8T-3849 Wall Insulation	1730	669	0	2.6	3.63	-0.6
D-1-C-5528 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-4426 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-5725 Weatherstripping	90	63	0	1.4	3.41	2.9
C-4-C-4122 Fluorescent Lighting	2759	580	238	3.4	3.41	65.6
D-1-C-7634 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-4428 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-3020 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-8339 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-6525 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-4424 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-7433 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-4125 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-3321 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-3027 Weatherstripping	90	63	0	1.4	3.41	2.9
D-1-C-4120 Weatherstripping	90	63	0	1.4	3.41	2.9
F-2-AT-4622 Insulate Storage Tank	218	64	0	3.4	3.14	0.0
C-4-0-9013 Fluorescent Lighting	1341	249	90	4.0	3.02	27.7
G-5-AT-4622 Automatic Pilot Lights	545	156	0	3.5	3.02	0.7
B-11-8T-3849 Install Smaller Boiler	6374	2145	-130	3.2	2.99	0.0
G-5-AT-4686 Automatic Pilot Lights	545	153	0	3.6	2.96	0.8
D-3-8T-3849 Attic Insulation	5052	1551	0	3.3	2.94	-18.0
D-1-C-6432 Weatherstripping	90	52	0	1.7	2.93	1.4
D-7-MT-6115 Wall Insulation	618	162	0	3.8	2.88	-2.2
G-5-MT-6115 Automatic Pilot Lights	545	141	0	3.9	2.69	1.6
D-1-C-4122 Weatherstripping	90	47	0	1.9	2.67	1.0
C-4-C-3020 Fluorescent Lighting	2759	371	238	4.5	2.62	41.0
C-4-C-6525 Fluorescent Lighting	2759	371	238	4.5	2.62	41.0
C-4-C-3027 Fluorescent Lighting	2759	371	238	4.5	2.62	41.0
C-4-C-7433 Fluorescent Lighting	2759	371	238	4.5	2.62	41.0
C-4-C-5725 Fluorescent Lighting	2759	371	238	4.5	2.62	41.0

Table 1-5, Recommended ECOS, Ranked by SIR, All Buildings (Continued)

ECO AND DESCRIPTION	INSTALLED COST	\$ SAVINGS ENERGY	PAYBACK YRS	NON-ENERGY	SIR	ANNUAL SAVINGS		
						FIRST YEAR	ELEC MBTU	GAS MBTU
C-4-C-3321	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-4120	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-4428	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-8339	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-4125	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-4424	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-7634	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-4426	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
C-4-C-5528	Fluorescent Lighting	2759	371	238	4.5	2.62	41.0	-11.4
A-17-C-6432	Dry Bulb Economizer	612	180	-16	3.7	2.58	17.9	0.0
C-4-C-4422	Fluorescent Lighting	2759	300	238	5.1	2.42	31.0	-3.3
C-4-C-8541	Fluorescent Lighting	2759	293	238	5.2	2.40	30.1	-2.7
C-4-C-8344	Fluorescent Lighting	2759	293	238	5.2	2.40	30.1	-2.7
A-17-C-4122	Dry Bulb Economizer	612	167	-16	4.1	2.37	16.6	0.0
C-4-C-8750	Fluorescent Lighting	3471	310	306	5.6	2.19	32.9	-5.8
C-4-C-9349	Fluorescent Lighting	3471	307	306	5.7	2.17	32.8	-6.2
A-17-C-8541	Dry Bulb Economizer	612	153	-16	4.5	2.15	15.2	0.0
A-17-C-8344	Dry Bulb Economizer	612	153	-16	4.5	2.15	15.2	0.0
C-4-C-7236	Fluorescent Lighting	2759	232	238	5.9	2.11	24.4	-3.6
C-4-C-8438	Fluorescent Lighting	2759	232	238	5.9	2.11	24.4	-3.6
C-4-C-6726	Fluorescent Lighting	2759	232	238	5.9	2.11	24.4	-3.6
C-4-C-6432	Fluorescent Lighting	2759	233	238	5.9	2.03	26.5	-9.1
A-17-C-4426	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-3027	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-4428	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-3321	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-7634	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-4120	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-6525	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-5528	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-3020	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-4125	Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0

Table 1-5, Recommended ECOS, Ranked by SIR, All Buildings (Continued)

ECO AND DESCRIPTION	INSTALLED COST	\$ SAVINGS ENERGY	PAYBACK YRS	ANNUAL SAVINGS			
				ELEC MBTU	GAS MBTU	#2 OIL MBTU	NON-ENERGY
A-17-C-7433 Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-8339 Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-5725 Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
A-17-C-4424 Dry Bulb Economizer	612	143	-16	4.8	1.99	14.2	0.0
D-1-C-8344 Weatherstripping	90	32	0	2.8	1.83	0.7	6.7
D-1-C-8541 Weatherstripping	90	32	0	2.8	1.83	0.7	6.7
D-1-C-4422 Weatherstripping	90	30	0	3.0	1.75	0.5	6.8
D-9-8T-3849 Floor Insulation	7469	1329	0	5.6	1.68	-4.4	0.0
A-17-C-6726 Dry Bulb Economizer	612	123	-16	5.7	1.67	12.2	0.0
A-17-C-7236 Dry Bulb Economizer	612	123	-16	5.7	1.67	12.2	0.0
A-17-C-8438 Dry Bulb Economizer	612	123	-16	5.7	1.67	12.2	0.0
D-1-AT-4686 Weatherstripping	339	103	0	3.3	1.62	0.0	23.5
D-1-MT-6115 Weatherstripping	441	117	0	3.8	1.42	-0.2	27.0
D-1-AT-4632 Weatherstripping	339	89	0	3.8	1.40	0.1	20.1
D-1-8T-3849 Replace Door Weatherstr.	624	177	0	3.5	1.39	0.0	30.0
D-1-AT-4622 Weatherstripping	339	86	0	3.9	1.34	0.1	19.3
A-29-C-6432 Repair Controls	2823	291	0	9.7	1.27	16.0	34.8
D-1-C-9349 Weatherstripping	180	42	0	4.3	1.21	0.7	9.4
D-1-C-8750 Weatherstripping	180	40	0	4.5	1.16	0.6	9.1
A-29-H-5718 Repair Controls	1375	163	0	8.4	1.15	16.2	0.0
A-29-C-3321 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-5725 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-6525 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-3027 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-3020 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-4120 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-8339 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-4125 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-4424 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-4426 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-7433 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-4428 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3

Table 1-5, Recommended ECOs, Ranked by SIR, All Buildings (Continued)

ECO AND DESCRIPTION	INSTALLED COST	\$ SAVINGS ENERGY	PAYBACK YRS	SIR	ANNUAL SAVINGS		
					FIRST YEAR	ELEC MBTU	GAS MBTU
A-29-C-7634 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-5528 Repair Controls	2823	265	0	10.7	1.12	16.2	27.3
A-29-C-8750 Repair Controls	2823	254	0	11.1	1.09	14.8	28.1
A-29-C-4422 Repair Controls	2823	262	0	10.8	1.09	16.8	24.7
A-29-C-9349 Repair Controls	2926	252	0	11.6	1.04	14.6	27.9
A-17-C-4422 Dry Bulb Economizer	612	82	-16	9.3	1.02	8.1	0.0
A-1-8T-3849 Night Setback Controls	11908	1409	-74	8.9	1.01	32.1	0.0
A-29-C-8344 Repair Controls	2823	245	0	11.5	1.01	16.0	22.3
A-29-C-8541 Repair Controls	2823	245	0	11.5	1.01	16.0	22.3
A-29-C-6726 Repair Controls	2823	233	0	12.1	1.00	13.4	26.2
A-29-C-8438 Repair Controls	2823	233	0	12.1	1.00	13.4	26.2
A-29-C-7236 Repair Controls	2823	233	0	12.1	1.00	13.4	26.2
A-29-C-4122 Repair Controls	2823	242	0	11.7	1.00	15.7	22.4
T O T A L S	261975	3942	67085	3.7	4434.2	-2841.8	1632.1

1.4.3 ECOs Considered but not Recommended

Table 1-6 is a list of typical ECOs which were analyzed but were not found to be cost effective.

Table 1-6. Typical ECOs Not Recommended

<u>ECO</u>	<u>Title</u>	<u>Reason Rejected</u>
F-7	Waste Water Heat Recovery	SIR < 1.0
F-8	Heat Pump Water Heater	SIR < 1.0
G-3	Refrigerant Heat Recovery	SIR < 1.0
G-4	Exhaust Heat Recovery	SIR < 1.0
D-1	Double Pane Replacement Windows	SIR < 1.0
A-32	Replace HVAC System	SIR < 1.0

1.5 Energy and Cost Savings

Table 1-7 summarizes the ECO cost and dollar savings by type of building. As noted, the total cost of implementation is \$261,975, with an energy savings of \$43,795 and a non-energy savings of \$67,085, for a payback of 2.4 years.

Table 1-8 summarizes the total annual energy cost and consumption by fuel type for the detailed buildings before and after energy conservation. Figures 1-3 and 1-4 also show energy cost and consumption before and after energy conservation for the detailed buildings.

Table 1-9 shows the energy consumption and cost per meal and per square foot for the detailed building. The consumption and cost per square foot data was extrapolated to similar walk-thru buildings to form Table 1-10. Figure 1-5 combines the calculated energy cost for the detailed buildings and the extrapolated cost for the walk-thru buildings to show the total energy cost before and after energy conservation.

1.6 Projects Developed

Table 1-11 summarizes the projects developed. Many ECOs listed in the ECO summary table (Table 1-5) have not been programmed; thus the totals for Table 1-9 are less than Table 1-5. These ECOs were not programmed because it was discovered at the Interim Presentation that they have been included in other ongoing projects or are no longer applicable.

Table 1-7, Recommended ECOS, By Building Category

Building Type & Category	INSTALLED COST ENERGY	\$ SAVINGS	PAYBACK YRS	SAVINGS		
				ELEC MBTU	GAS MBTU	#2 OIL MBTU
Category 1, Type 64, C Buildings	158338	23264	48909	2.2	3342.0	-2786.0
Category 2, Type 64A, C Buildings	18628	2506	5754	2.3	369.2	-324.8
Category 3, Type 121, C Buildings	9504	1134	2961	2.3	170.9	-157.3
Category 4, Type 121, C Buildings	9607	1131	2961	2.3	170.7	-157.6
Category 5, Type 64, C Buildings	18852	1959	666	7.2	153.6	110.1
Category 8, H Buildings	1375	163	0	8.4	16.2	0.0
Category 9, O Buildings	2154	660	90	2.9	27.7	0.0
Category 10, P Buildings	311	270	10	1.1	6.1	0.0
Category 12, (4) Buildings	3506	254	6026	0.6	113.8	-175.2
Temporary Buildings, Types (AT, MT, 8T)	38434	11120	-255	3.5	44.0	379.0
Building A-1-A-3275	1266.0	1334.0	-37.0	1.0	20.0	270.0
TOTALS	261975	43795	67085	2.4	4434.2	-2841.8
						4896.3

Table 1-8. Total Energy Cost and Consumption, Before and After Conservation (Detailed Buildings)

	Before Conservation			After Conservation			Total % Reduction	
	Gas	Oil	Elec	Total	Gas	Oil	Elec	Total
\$ Cost	148,306	38,192	309,218	495,716	149,590	28,546	271,590	449,726
Consumption (MBTUs)	38,381.2	6,462.3	16,308.4	61,151.9	38,839.4	4,830.2	14,917.8	58,587.4




I.E.S.

Mechanical and Electrical Engineers
Chapel Hill, North Carolina


Figure 1-3.

ENERGY CONSUMPTION BEFORE & AFTER OF DETAILED BUILDINGS



Buildings Included in Detailed Audit

Building	Sq ft	Building	Sq ft
C-4122	4,850	O-9013	4,800
C-4422	4,850	P-3042	7,857
C-6432	4,850	I-1242	3,168
C-8344	4,850	4-1437	7,500
C-8750	5,050	A-3275	5,608
C-9349	5,050	AT-4622	2,800
C-7236	4,850	AT-4632	2,800
D-2626	11,313	AT-4686	2,800
D-3404	9,346	MT-6115	2,375
H-5718	14,920	8T-3849	13,400




I.E.S.

Mechanical and Electrical Engineers
Chapel Hill, North Carolina

Figure 1-4.

ENERGY COST BEFORE & AFTER OF DETAILED BUILDINGS



Buildings Included in Detailed Audit

Building	Sq ft	Building	Sq ft
C-4122	4,850	0-9013	4,800
C-4422	4,850	P-3042	7,857
C-6432	4,850	I-1242	3,168
C-8344	4,850	4-1437	7,500
C-8750	5,050	A-3275	5,608
C-9349	5,050	AT-4622	2,800
C-7236	4,850	AT-4632	2,800
D-2626	11,313	AT-4686	2,800
D-3404	9,346	MT-6115	2,375
H-5718	14,920	8T-3849	13,400

Table 1-9. Energy Summary Data, Detailed Buildings

BUILDING	AREA	MBTU	COST	BEFORE CONSERVATION				AFTER CONSERVATION			
				MEALS/YEAR	MBTU/SQ FT	COST/SQ FT	MEAL	MBTU	COST	MBTU/SQ FT	COST/SQ FT
C-4122	4,850	2,739.2	\$25,877	234,000	0.5648	0.0117	\$5.34	\$0.11	2,696.0	\$21,428	0.5559
C-4422	4,850	2,937.6	\$25,633	234,000	0.6057	0.0126	\$5.29	\$0.11	2,919.1	\$21,536	0.6019
C-6432	4,850	2,925.6	\$26,158	234,000	0.6032	0.0125	\$5.39	\$0.11	2,894.1	\$21,979	0.5967
C-8344	4,850	2,661.9	\$24,884	234,000	0.5488	0.0114	\$5.13	\$0.11	2,639.7	\$20,738	0.5443
C-8750	5,050	3,022.0	\$25,234	234,000	0.5984	0.0129	\$5.00	\$0.11	3,008.4	\$21,139	0.5957
C-9349	5,050	3,032.4	\$25,408	234,000	0.6005	0.0130	\$5.03	\$0.11	3,019.3	\$21,316	0.5979
C-7236	4,850	4,159.0	\$27,243	234,000	0.8575	0.0178	\$5.62	\$0.12	4,071.1	\$26,352	0.8394
D-2626	11,313	5,781.5	\$33,030	352,300	0.5110	0.0164	\$2.92	\$0.09	5,781.5	\$33,030	0.5110
D-3404	9,346	3,765.7	\$23,023	255,500	0.4029	0.0147	\$2.46	\$0.09	3,765.7	\$23,023	0.4029
H-5718	14,920	8,588.6	\$63,604	730,000	0.5756	0.0118	\$4.26	\$0.09	8,572.4	\$63,441	0.5746
0-9013	4,800	581.9	\$6,575	16,640	0.1212	0.0350	\$1.37	\$0.40	489.7	\$5,825	0.1020
P-3042	7,857	3,192.9	\$20,931	100,375	0.4064	0.0318	\$2.66	\$0.21	3,151.5	\$20,651	0.4011
I-1242	3,168	2,331.6	\$33,637	240,900	0.7360	0.0097	\$10.62	\$0.14	2,331.6	\$33,637	0.7360
4-1437	7,500	4,339.6	\$36,841	236,600	0.5786	0.0183	\$4.91	\$0.16	4,400.9	\$30,561	0.5868
A-3275	5,608	2,253.0	\$19,106	164,250	0.4017	0.0137	\$3.41	\$0.12	1,963.0	\$17,772	0.3500
AT-4622	2,800	1,250.0	\$12,901	73,000	0.4468	0.0171	\$4.61	\$0.18	1,176.8	\$12,490	0.4203
AT-4632	2,800	1,138.4	\$12,297	73,000	0.4066	0.0156	\$4.39	\$0.17	1,113.2	\$12,105	0.3976
AT-4686	2,800	1,183.4	\$12,494	73,000	0.4226	0.0162	\$4.46	\$0.17	1,050.2	\$11,906	0.3751
MT-6115	2,375	1,130.4	\$12,041	73,000	0.4760	0.0155	\$5.07	\$0.16	960.1	\$11,272	0.4043
ST-3849	13,400	4,136.2	\$28,798	119,600	0.3087	0.0346	\$2.15	\$0.24	2,583.1	\$19,868	0.2016
TOTALS	123,037	61,151.9	\$495,715	4,146,165	10,1731	0.3422	\$90.09	\$2.98	58,587.4	\$450,069	9.7862
									0.3153		\$82.11
											\$2.68

Table 1-10. Extrapolated Energy Data, Walk-thru Buildings


BUILDING	AREA	BEFORE CONSERVATION			AFTER CONSERVATION		
		MBTU	COST	SQ FT	MBTU	COST	SQ FT
C-3020	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-3027	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-3321	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-4120	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-4125	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-4424	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-4426	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-4428	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-5528	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-5725	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-6525	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-7433	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-7634	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-8339	4,850	2,867.5	\$25,889	0.5912	\$5.34	2,836.4	\$21,648
C-8541	4,850	2,661.9	\$24,884	0.5488	\$5.13	2,639.7	\$20,738
C-6726	4,850	4,159.0	\$27,243	0.8575	\$5.62	4,071.1	\$26,352
C-8438	4,850	4,159.0	\$27,243	0.8575	\$5.62	4,071.1	\$26,352
D-2105	11,313	5,781.5	\$33,030	0.5110	\$2.92	5,781.5	\$33,030
D-3039	11,313	5,781.5	\$33,030	0.5110	\$2.92	5,781.5	\$33,030
D-3055	11,313	5,781.5	\$33,030	0.5110	\$2.92	5,781.5	\$33,030
H-4842	14,920	8,588.6	\$63,604	0.5756	\$4.26	8,572.4	\$63,441
2-1105	3,168	2,331.6	\$33,637	0.7360	\$10.62	2,331.6	\$33,637
2-1138	3,168	2,331.6	\$33,637	0.7360	\$10.62	2,331.6	\$33,637
TOTALS	137,645	81,721.2	\$671,789	14,1220	\$125.35	81,071.6	\$606,314
							\$111,9903
							\$111.88

Table 1-11. Project Summary Totals

ECO AND DESCRIPTION	TOTAL INSTALLED COST	TOTAL SAVINGS ENERGY	TOTAL PAYBACK YRS	TOTAL SIR	ELEC MBTU	TOTAL SAVINGS	
						#2 OIL GAS	MBTU
Project # 1 Low Cost/No Cost ECO's	419	1982	-130	0.2	42.02	0.0	14.6
Project # 2 Install Steam Booster Heaters	67136	11384	61781	0.9	9.18	2688.5	-4137.9
Project # 3 Weatherstripping	1119	309	0	3.6	1.47	-0.1	70.6
Project # 4 Wall Insulation	618	162	0	3.8	2.88	-2.2	40.7
Project # 5 Fluorescent Lighting	69279	8676	6088	4.7	2.55	957.1	-228.1
Project # 6 Controls ECO's	2711	2289	-62	1.2	8.49	26.3	-13.9
Project # 7 Dry Bulb Economizers	13464	3106	-352	4.9	1.96	308.4	413.4
GRAND TOTALS	154746*	27908	67325	1.6	3978.0	-3826.7	357.1

Note: Projects #2-7 are assumed to be implemented in 1989; Project #1 in 1988.

* Does not include ECOs which have been programmed or determined not applicable due to demolition subsequent to the initiation of this study.

Figure 1-5.**ENERGY COST BEFORE & AFTER
(Includes All Buildings)****Notes**

- 1) Data for Detailed Buildings was based on BLAST Analysis.
- 2) Data for Walk-thru Buildings was extrapolated for similar detailed buildings.

Project #1 consists of Low Cost/No Cost ECOs. These are ECOs which will be completed with DEH funds, scheduled for 1988.

Project #2 has been programmed as a QRIP project for 1989.

Projects #3-7 do not qualify for any of the funding categories listed in the SOW (ECIP, QRIP, PECIP, OSD/PIF). Programming documentation similar to QRIP documents was completed for these projects for 1989, at the request of base personnel. These projects will be funded under other military programs.