


## 8 Session 6: New technologies for New and Existing Buildings Allowing for Energy Conservation

Demand Controlled Ventilation — Save energy with a better operating Building

Presenter: Mr. Richard Remke, Carrier Corp.



| Report Documentation Page  |                                    |                                     |  | Form Approved<br>OMB No. 0704-0188          |                                    |
|--|------------------------------------|-------------------------------------|--|---|------------------------------------|
| Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. |                                    |                                     |  |   |                                    |
| 1. REPORT DATE<br><b>01 SEP 2004</b>   |                                    | 2. REPORT TYPE<br><b>N/A</b>        |  | 3. DATES COVERED<br><b>-</b>                |                                    |
| 4. TITLE AND SUBTITLE<br><b>New technologies for New and Existing Buildings Allowing for Energy Conservation</b>   |                                    |                                     |  | 5a. CONTRACT NUMBER                         |                                    |
|  |                                    |                                     |  | 5b. GRANT NUMBER                            |                                    |
|  |                                    |                                     |  | 5c. PROGRAM ELEMENT NUMBER                  |                                    |
| 6. AUTHOR(S)   |                                    |                                     |  | 5d. PROJECT NUMBER                          |                                    |
|  |                                    |                                     |  | 5e. TASK NUMBER                             |                                    |
|  |                                    |                                     |  | 5f. WORK UNIT NUMBER                        |                                    |
| 7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)<br><b>Carrier Corp.</b>   |                                    |                                     |  | 8. PERFORMING ORGANIZATION<br>REPORT NUMBER |                                    |
| 9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)  |                                    |                                     |  | 10. SPONSOR/MONITOR'S ACRONYM(S)            |                                    |
|  |                                    |                                     |  | 11. SPONSOR/MONITOR'S REPORT<br>NUMBER(S)   |                                    |
| 12. DISTRIBUTION/AVAILABILITY STATEMENT<br><b>Approved for public release, distribution unlimited</b>  |                                    |                                     |  |   |                                    |
| 13. SUPPLEMENTARY NOTES<br><b>See also ADM001864, Building Energy Performance Improvement Through Advanced Technologies, Smart Organization, and Financing. Proceedings of the Industry Workshop Held in Chicago, IL on 7-8 October 2003. , The original document contains color images.</b>   |                                    |                                     |  |   |                                    |
| 14. ABSTRACT   |                                    |                                     |  |   |                                    |
| 15. SUBJECT TERMS  |                                    |                                     |  |   |                                    |
| 16. SECURITY CLASSIFICATION OF:  |                                    |                                     | 17. LIMITATION OF<br>ABSTRACT<br><b>UU</b> | 18. NUMBER<br>OF PAGES<br><b>131</b>        | 19a. NAME OF<br>RESPONSIBLE PERSON |
| a. REPORT<br><b>unclassified</b>   | b. ABSTRACT<br><b>unclassified</b> | c. THIS PAGE<br><b>unclassified</b> |  |   |                                    |

## Ventilation Control

*How is ventilation provided in most buildings today?*

**The same way it was in 1930.**


**With Fixed Ventilation!**

## Ventilation Control

### *Fixed Ventilation*

Building codes require ventilation rates based on cfm/person: (typically 20 cfm/person)

***Actual Occupancy: 1 person = 500cfm***




*Inefficient!*

## Ventilation Control

### *Fixed Ventilation In a Multi-Zone VAV Building*

Total cfm = Max occupants X 20 cfm



*There Is No Control!*


## Ventilation Control

*Is There A Better Way?*



## Ventilation Control

### *Temperature Control In A Multi-Zone VAV Building*



- Measure In Each Zone
- Control Based On Actual Load

*What if we did the same thing with ventilation?*

## Zone Ventilation Control

***Great Idea!***

### ***But How Does It Work?***

Delivers

The **RIGHT** Amount of Fresh Air,  
To The **RIGHT** Place,  
At The **RIGHT** Time...

## Zone Ventilation Control

### Controlling Ventilation

There is a clearly defined relationship between CO<sub>2</sub> levels & ventilation rates established by:



ASHRAE 62.1 & 90.1



ASTM CO<sub>2</sub> & Ventilation Standards

Indoor CO<sub>2</sub> levels **are** a measure of ventilation rates (cfm/person)

CO<sub>2</sub> levels are **not** a measure of overall IAQ.



**CO<sub>2</sub> is the control parameter for ventilation!**

## Zone Ventilation Control


*Actual Occupancy 1 person = 20cfm*



**Ventilation based on actual occupancy!**

## Zone Ventilation Control


### *With Zone Ventilation Control In a VAV Building*




*Healthy & Efficient!*

## Ventilation Control

### *Total Building Heating and Cooling Costs*



## Ventilation Control



## Zone Ventilation Control

### *Numerous Studies Confirm That Correct Ventilation ...*

- Increases Productivity
- Improves Occupant/Customer Satisfaction
- Helps Prevent Sick Building Syndrome Health Effects

#### **DOE/Lawrence Berkeley Labs Indoor Environment In Schools**

##### **Pupils Health & Performance In Regard To CO<sub>2</sub> Concentrations**

- A significant correlation was found between decreased performance and high CO<sub>2</sub> levels (lower ventilation rates).



## Zone Ventilation Control

Does controlling ventilation based on occupancy meet codes?

Accepted by: ASHRAE Standard 62



International Mechanical Code:  
*"Current technology (CO<sub>2</sub> sensors) can permit the design of ventilation systems that are capable of detecting the occupant load of the space and automatically adjusting the ventilation rate accordingly."*



Model, State & Local Codes

***Can Be Measured & Documented!  
 Compliance Assured...***

## Zone Ventilation Control

### *Examples Of Potential Energy Savings/ROI*




## Zone Ventilation Control

*Is Using CO<sub>2</sub> To Measure Ventilation  
A New Idea?*

*"CO<sub>2</sub> tests should be used  
...for checking the renewal  
of air and its distribution  
within the room.  
...the CO<sub>2</sub> should NOT  
exceed 8 or 10 parts in  
10,000"*

**1916 Engineers Handbook**



## Zone Ventilation Control

*Why Apply It Now?*

- CO<sub>2</sub> sensors have become cost effective and reliable.
- Building control systems can now integrate zone ventilation control.



## Zone Ventilation Control

### Payback Analysis

Software Analysis  
Tools Can Determine  
Potential Energy  
Savings and  
demonstrate  
payback



## Zone Ventilation Control

Let's review the benefits.



## Zone Ventilation Control

*Ensure for every zone...*

- Comfort
- Health & Safety
- Compliance
- And...

## Zone Ventilation Control

*A Better Operating Building*

- Ventilate to Actual vs. Assumed Occupancy
- Eliminate Wasteful Over-Ventilation
- Very Attractive ROI/Lower Operating Costs



## Conserve Energy and Improve Indoor Air Quality through Use of Hybrid HVAC Systems.

Presenter: Mr. Leon Shapiro. ADA Systems



### Conserve Energy and Improve Indoor Air Quality Through the Use of Hybrid HVAC Systems

- Building Energy Performance Improvement Through Advanced Technologies, Smart Organization and Financing  
*ERDC-CERL/DOD/ASHRAE*
- Industry Workshop  
October 7-8, 2003  
Chicago, IL
- Leon E. Shapiro  
*ADA Systems, LLC*  
Carol Stream, IL



## Evaporative Cooling: Why Is This Important To You (and your clients)?

Q There are external forces affecting the method and manner in which institutions and businesses provide ventilation, heating and cooling for their facilities:

- ASHRAE Standard 62 - 2001
- ASHRAE Standard 90.1 - 1999
- Federal Energy Policy Act of 1992
- LEED Certification
- Global Climate Change Treaty
- Current Events

## Evaporative Cooling: Why Is This Important To You (and your clients)?


Q If you could, would you provide your clients/customers with an HVAC system that:

- Supplies 100% fresh outdoor air instead of stale recirculated air
- Uses significantly **less energy** to operate than current recirculation systems
- Can be installed on a first cost basis equal to or less than a standard mechanical system
- Can be **retrofitted** to their existing systems (in most cases)
- Is **user-friendly** for maintenance personnel to operate and maintain

Q If you could, you should...so let's see how....



## Evaporative Cooling: Typical (Non-Evaporative) System



Based on using **minimum** outside supply air, and recirculating a majority of the building return (exhaust) air

## Evaporative Cooling: Typical (Non-Evaporative) System

### Weaknesses of the Typical System:

- Recirculation causes internally generated contaminants to become concentrated and spread to all spaces served by the system
- Ventilation air is not managed properly
- The process is open loop on latent heat
- The scheme is predicated on using virgin energy to achieve psychrometric state point changes.
- The process is predicated on using energy intensive processes

## Evaporative Cooling: What Does “Green” Mean To HVAC?

- ∩ “Green” is not just installing a high efficiency boiler or alternative refrigerant chiller
- ∩ “Green” is avoiding the need for that boiler or chiller (or at least significantly downsizing them)
- ∩ A high efficiency system with low efficiency equipment beats a low efficiency system with high efficiency equipment every time

## Evaporative Cooling: “Green” Strategies For HVAC

- ∩ **Dual Path Ventilation** - Separation of ventilation from heating and cooling processes permits elimination of terminal reheat and effective management of ventilation
- ∩ **Energy Recovery** - Recycling heating/cooling energy permits ventilation air to be introduced into space at low thermodynamic cost
- ∩ **Evaporative Cooling and Humidification** - Evaporative processes are the only processes which can close the loop on latent energy. They permit the avoidance of most cooling and humidification energy, and **are** applicable in all environments




## Evaporative Cooling: “Green” Strategies For HVAC

- Q **Displacement Ventilation** - Permits small, 100% outside air systems to replace much larger systems and greatly reduce energy use
- Q **Thermal Storage** - Properly employed, thermal storage can sharply reduce both the quantity and cost of heating and cooling energy use
- Q **Process Synergism** - Synergism can be created between two processes to achieve more out of them than either process could provide alone

## Evaporative Cooling: “Green” Strategies For HVAC

- Q **Multi-Funtional Process Use** - Individual pieces of equipment can be used to serve multiple design objectives. This reduces the parasitic losses systems see form equipment not in use but which require energy to overcome
- Q **Amplification** - Multiple heat exchangers can be used to amplify cooling energy for recovery while simultaneously eliminating the need for terminal reheat
- Q **Avoidance** - Use of recoverable or “free” thermal resources before expending new energy resources


## Evaporative Cooling: Understanding The Psychrometric Chart



## Evaporative Cooling: Understanding The Psychrometric Chart

Q All psychrometric processes can be seen as a combination of:

- Cooling
- Heating
- Humidifying
- Dehumidifying





## Evaporative Cooling: Multiple Forms and Technologies

- Evaporative cooling technologies form the backbone of energy efficient hybrid HVAC systems
- There are 2 forms of evaporative cooling
  - **Direct**
    - Draws warm air through a wetted media
  - **Indirect**
    - Utilizes a heat exchanger to separate the supply air from the water used for evaporation
    - Uses a secondary air stream to reject heat from the evaporation process

## Evaporative Cooling: Direct Evaporative Cooling Cycle

“Effectiveness” is defined by the following equation:


$$E = (T_{db} - T_{db}) / (T_{db} - T_{wb})$$

“Discharge Temperature” can be determined by the following equation:

$$T_{db} = T_{db} - [E \times (T_{db} - T_{wb})]$$

Factors affecting effectiveness are:

- Type of Media
- Depth of Media
- Face Velocity



## Evaporative Cooling: Indirect Evaporative Cooling Cycle

“Effectiveness” is defined by the following equation:


$$E = (T_{i,db} - T_{d,db}) / (T_{i,db} - T_{i,wb})$$

“Discharge Temperature” can be determined by the following equation:

$$T_{d,db} = T_{i,db} - [E \times (T_{i,db} - T_{i,wb})]$$

Factors affecting effectiveness are:

- Type of Heat Exchanger
- Supply Air Flow Through Exchanger
- Secondary Air Flow
- Use of Outside Air vs. Building Exhaust as the Secondary Air Source




## Evaporative Cooling: Advantages of Indirect Cooling/Heating

- Provides a sensible cooling process
- Extends the effective Economizer range
- Meets base cooling loads under part load conditions most of the time
- Can be used to provide winter energy (heat) recovery
- Makes 100% outside air applications more economical than recirculation systems
- Reduces the need for refrigeration

## Evaporative Cooling: Indirect/Direct Evaporative Cooling Cycle

An Indirect / Direct combination will provide cooler air than either process by itself

In certain climates this combined process alone will provide true "comfort cooling"



## Evaporative Cooling: Performance Chart (Low Wet Bulb Area)

### SACRAMENTO, CALIFORNIA

#### Performance of Evaporative Cooling and Heat Recovery Technologies

| Ambient OSA DB/WB | Hours/Year | INDIRECT OSA as Secondary Air | INDIRECT Bldg. Exhaust as Secondary Air | DIRECT | INDIRECT DIRECT OSA as Secondary Air |
|-------------------|------------|-------------------------------|---|--------|--------------------------------------|
| 107/70            | 7          | 79/61                         | 74/59                                   | 74/70  | 63/61                                |
| 102/70            | 59         | 78/63                         | 73/61                                   | 73/70  | 65/63                                |
| 97/68             | 144        | 75/61                         | 72/60                                   | 71/68  | 62/61                                |
| 92/66             | 242        | 72/60                         | 70/59                                   | 69/66  | 61/60                                |
| 87/65             | 301        | 70/59                         | 69/59                                   | 67/65  | 60/59                                |
| 82/63             | 397        | 68/58                         | 68/58                                   | 65/63  | 59/58                                |
| 77/61             | 497        | 65/57                         | 66/57                                   | 63/61  | 58/57                                |
| 72/59             | 641        | 62/55                         | 65/56                                   | 60/59  | 56/55                                |
| 67/57             | 821        | 60/54                         | 64/56                                   | 58/57  | 55/54                                |
| 62/54             | 1086       | 56/52                         | 63/55                                   | 55/54  | 53/52                                |


The above discharge temperatures (°F) are based on the following:

1. 75% Indirect Evaporative Effectiveness
2. 90% Direct Evaporative Effectiveness
3. 50% Heat Recovery Effectiveness
4. 75°F Building Exhaust Dry Bulb Temperature (Heat Recovery)
5. 63°F Building Exhaust Wet Bulb Temperature (Cooling)
6. DB = Dry Bulb Temperature
7. WB = Wet Bulb Temperature
8. OSA = Outside Air



## Evaporative Cooling: Psychrometric Chart (Low Wet Bulb)

- Sacramento, CA
- A: Outside air  
98/70
- B: Direct  
73/70
- C: Indirect (OSA)  
77/63
- D: Indirect/Direct  
64.5/63
- E: Indirect (bldg.  
exhaust)  
72/62




## Evaporative Cooling: Performance Chart (Low Wet Bulb Area)

| RENO, NEVADA         |                |                                     |  |        |                  |
|----------------------|----------------|-------------------------------------|--|--------|------------------|
| Ambient OSA<br>DB/WB | Hours/<br>Year | INDIRECT<br>OSA as Secondary<br>Air | IND/DIRECT<br>OSA as<br>Secondary<br>Air | DIRECT | HEAT<br>RECOVERY |
| 97/80                | 18             | 69/50                               | 52/50                                    | 64/60  |                  |
| 92/60                | 127            | 68/51                               | 53/51                                    | 63/60  |                  |
| 87/58                | 297            | 65/50                               | 52/50                                    | 61/58  |                  |
| 82/56                | 339            | 63/49                               | 50/49                                    | 59/56  |                  |
| 77/55                | 390            | 61/49                               | 50/49                                    | 57/55  |                  |
| 72/53                | 397            | 58/48                               | 49/48                                    | 55/53  |                  |
| 67/50                | 436            | 54/45                               | 46/45                                    | 52/50  |                  |
| 62/48                | 720            | 52/44                               | 45/44                                    | 49/48  | 68.5             |
| 57/46                | 783            | 49/43                               | 44/43                                    | 47/46  | 66               |
| 52/43                | 871            |                                     |  |        | 63.5             |
| 47/40                | 922            |                                     |  |        | 61               |
| 42/36                | 714            |                                     |  |        | 58.5             |
| 37/33                | 873            |                                     |  |        | 56               |
| 32/29                | 762            |                                     |  |        | 53.5             |
| 27/25                | 550            |                                     |  |        | 51               |
| 22/21                | 310            |                                     |  |        | 48.5             |
| 17/16                | 246            |                                     |  |        | 46               |
| 12/11                | 74             |                                     |  |        | 43.5             |
| 7/6                  | 10             |                                     |  |        | 41               |
| 2                    | 2              |                                     |  |        | 38.5             |
| -2                   | 3              |                                     |  |        | 36.5             |
| -7                   | 6              |                                     |  |        | 34               |

## Evaporative Cooling: Psychrometric Chart (Low Wet Bulb)

- \*Reno, NV
- \*A: Outside air  
93/60
- \*B: Direct  
63/60
- \*C: Indirect (OSA)  
68/50
- \*D: Indirect/Direct  
52/50
- \*E: Indirect (building  
exhaust)  
71/51




## Evaporative Cooling: Performance Chart (High Wet Bulb Area)

CHICAGO, ILLINOIS


| Ambient<br>OSA<br>DB/WB | Hours/<br>Year | INDIRECT<br>OSA as<br>Secondary<br>Air | INDIRECT<br>Bldg.<br>Exhaust as<br>Secondary<br>Air | DIRECT | INDIRECT<br>DIRECT<br>OSA as<br>Secondary<br>Air | HEAT RE-<br>COVERY |
|-------------------------|----------------|--|---|--------|--|--------------------|
| 97/76                   | 6              | 81/71                                  | 71/69   | 78/76  | 72/71  |                    |
| 92/74                   | 58             | 78/70                                  | 70/68   | 76/74  | 71/70  |                    |
| 87/72                   | 165            | 76/69                                  | 69/67   | 73/72  | 70/69  |                    |
| 82/70                   | 324            | 73/67                                  | 68/66   | 71/70  | 68/67  |                    |
| 77/67                   | 487            | 70/65                                  | 67/64   | 68/67  | 66/65  |                    |
| 72/64                   | 681            | 66/62                                  | 65/62   | 65/64  | 63/62  |                    |
| 67/61                   | 759            | 62/59                                  | 64/60   | 62/61  | 60/58  |                    |
| 62/57                   | 700            | 60/56                                  |   | 58/57  | 57/55  |                    |
| 57/52                   | 604            | 53/50                                  |   | 53/52  | 51/49  |                    |
| 52/47                   | 581            |  |   |        |  | 66                 |
| 47/43                   | 565            |  |   |        |  | 64                 |
| 42/38                   | 572            |  |   |        |  | 62                 |
| 37/34                   | 725            |  |   |        |  | 60                 |
| 32/30                   | 869            |  |   |        |  | 58                 |
| 27/25                   | 589            |  |   |        |  | 56                 |
| 22/21                   | 371            |  |   |        |  | 54                 |
| 17/16                   | 231            |  |   |        |  | 52                 |
| 12/11                   | 164            |  |   |        |  | 50                 |
| 7/6                     | 115            |  |   |        |  | 48                 |
| 2/1                     | 89             |  |   |        |  | 46                 |
| -3                      | 53             |  |   |        |  | 44                 |
| -8                      | 27             |  |   |        |  | 42                 |
| -13                     | 11             |  |   |        |  | 40                 |
| -17                     | 2              |  |   |        |  | 38                 |

## Evaporative Cooling: Psychrometric Chart (High Wet Bulb)

- \*Chicago, IL
- \*A: Outside air  
91/74
- \*B: Direct  
76/74
- \*C: Indirect (OSA)  
78/70
- \*D: Indirect/Direct  
71/70
- \*E: Indirect (building  
exhaust)  
70/68




## Evaporative Cooling: Dry Bulb, Wet Bulb and Relative Humidity Excursions






## Evaporative Cooling: Dry Bulb, Wet Bulb and Relative Humidity Excursions




## Evaporative Cooling: Dry Bulb, Wet Bulb and Relative Humidity Excursions







## Evaporative Cooling: Dry Bulb, Wet Bulb and Relative Humidity Excursions



## Evaporative Cooling: 3 Different Outside Air Conditions



## Evaporative Cooling: Comparison of Direct vs Indirect/Direct



## Evaporative Cooling: Typical Direct Evaporative Module

### Design Features of a Good Evaporative System

- Stainless Steel
- Bottom Drain
- Bleed and/or Purge
- Pre-filters
- Hood/Louvers
- Mist Eliminators
- Microbial Control
  - Dry the Pads
  - Run Fan After Pump Shuts Off
  - Flush Pads
  - Ozonation







## Evaporative Cooling Microbial Control

- ∩ There have been no cases of Legionnaire's Disease associated with evaporative coolers (see ASHRAE Guideline 12-2000)
- ∩ There are significant differences between evaporative coolers and cooling towers
- ∩ The *Bio-Terminator*<sup>TM</sup> ozonation system was designed for active microbial control
- ∩ Ozone ( $O_3$ ) is an extremely powerful oxidizer
  - Highly soluble in water
  - Very short half life
  - Benign at low levels

## Evaporative Cooling: Microbial Control



## Evaporative Cooling: Cooling And Humidification



## Evaporative Cooling: What Are The Adverse Affects Of Heat?

### NASA Report CR-1205-1 (Heat Stress)

| Effective Temperature | 75 | 80 | 85  | 90   | 95   | 100 | 105 |
|-----------------------|----|----|-----|------|------|-----|-----|
| Loss in Work Output   | 3% | 8% | 18% | 29%  | 45%  | 62% | 79% |
| Loss in Accuracy      | -  | 5% | 40% | 300% | 700% | -   | -   |

ACGIH has established guidelines for reducing heat stress, including:


- Increased rates of ventilation
- **Evaporative cooling of ventilation air**
- Displacement ventilation with stratification
- Increased fluid intake



## Evaporative Cooling: Industrial Cooling Strategies

Strategies to increase the effectiveness of evaporative cooling:

- Displacement Ventilation
- Stratification
- Spot Cooling
- Adjustable Diffusers



## Evaporative Cooling: Indirect/Direct Case Study

CLIENT: Indianapolis Wood Veneer Manufacturer  
 PROBLEM: Ovens Produce Over 100°F Conditions  
 GOAL: Low Cost Relief Cooling

SOLUTION:

- \* Indirect/ Direct Cooling System
- \* Stratification Strategy
- \* Spot Cooling




## Evaporative Cooling: Indirect/Direct Case Study

**EQUIPMENT SCHEDULE**

| Mark  | Manu-<br>facturer | Supply<br>Cfm | E.A.T<br>(O.S.A)<br>(°FDB) | E.A.T<br>(O.S.A)<br>(°FWB) | L.A.T.<br>Indirect<br>(°FDB) | L.A.T.<br>Indirect<br>(°FWB) | L.A.T.<br>Direct<br>(°FDB) | Efficiency<br>(Indirect)<br>(%) | Efficiency<br>(Direct)<br>(%) |
|-------|-------------------|---------------|----------------------------|----------------------------|------------------------------|------------------------------|----------------------------|---------------------------------|-------------------------------|
| AHU-1 |                   | 62,000        | 91.0                       | 75.0                       | 78.0                         | 71.5                         | 72.3                       | 80                              | 88                            |
| AHU-2 |                   | 62,000        | 91.0                       | 75.0                       | 78.0                         | 71.5                         | 72.3                       | 80                              | 88                            |
| AHU-3 |                   | 62,000        | 91.0                       | 75.0                       | 78.0                         | 71.5                         | 72.3                       | 80                              | 88                            |
| AHU-4 |                   | 25,000        | 91.0                       | 75.0                       | 78.0                         | 71.5                         | 72.2                       | 80                              | 90                            |

## Evaporative Cooling: Indirect/Direct Case Study


62,000 CFM Make Up Air Handling Unit



## Evaporative Cooling: Indirect/Direct Case Study


### SPOT COOLING

- \* Adjustable Diffusers
- \* High Air Movement
- \* Establishes Cool Zone



## Evaporative Cooling: Indirect/Direct Case Study

### Field Temperature Recording





## Evaporative Cooling: Indirect With Typical Rooftop Unit

Q Industrial facility with high outside air requirements

- Standard rooftop mechanical units
- Indirect evaporative precoolers
- DX tonnage reduced by 50%
- Heat recovery in winter operation



## Evaporative Cooling: Indirect With Chiller & Heat Recovery

Q An Indirect evaporative pre-cooler can be used to reduce the size of a new chilled water system, or can be used to reduce the outside air load on an existing system.

Q When used for energy (heat) recovery in winter operations, that same indirect unit can pre-heat the outside air.

- In certain parts of the country, the energy savings from heat recovery may be even greater than those from evaporative cooling

## Evaporative Cooling: Indirect With Chiller & Heat Recovery

### IDEC COOLING PERFORMANCE (24/7 operating hours)

IDEAL COOLING PERFORMANCE (24°/ operating) in  
RADA SYSTEMS - 955 North Lincoln Blvd., Wood Dale, IL 60191 (Ph: 630-338-1516)

| LOCATION                                  | MILWAUKEE               |
|---|-------------------------|
| HEER SEASONAL AVERAGE                     | 47.25                   |
| SUPPLY AIR TEMP                           | 55 F                    |
| EXHAUST                                   | 75 F + 50% RH           |
| TOTAL HOURS OPERATION (24/7)              | 3120                    |
| IDEC SIZE                                 | 450 Linear Ft           |
| IDEC PRIMARY and SECONDARY CFM            | 500,000 Each            |
| IDEC ENERGY DRAW (kW-hr) - ON             | 137,200 450 CFM/module  |
| IDEC ENERGY DRAW (watts-hr) - OFF         | 70,000 450 CFM/module   |
| IDEC EQUIPMENT COST                       | \$ 2.00 per CFM         |
| IDEC EQUIPMENT COST (per use unassisted)  | \$ .765 per use cooling |
| CHILLED WATER COSTS (per use unassisted)  | \$ .425 per use cooling |
| Premium for IDEC over chilled water       | \$440,000 Job Total     |
| IDEC TONS                                 | 1,307                   |
| IDEC Efficiency                           | 80%                     |
| Kwhr/ Ton                                 | \$ 0.06                 |
| Water Cost (per 1000 gallons)             | \$ 2.00                 |
| IDEC YEARLY OPERATING COST - TOTAL (24/7) | \$ 26,342               |
| EQUIVALENT MECHANICAL YEARLY COST         | \$ 28,100               |
| YEARLY SAVINGS using IDEC                 | \$ 194,900              |

| PRIMARY |     |        |     | SECONDARY |       |        |      | TERTIARY |     |     |         | INDEX   |        | INDEX |         | ENERGY  |        | ENERGY  |       | COST   |         | COST  |       | OPER- |       |
|---------|-----|--------|-----|-----------|-------|--------|------|----------|-----|-----|---------|---------|--------|-------|---------|---------|--------|---------|-------|--------|---------|-------|-------|-------|-------|
| ANALOG  |     | ANALOG |     | ANALOG    |       | ANALOG |      | IN       |     | OUT |         | IN      |        | OUT   |         | YEARLY  |        | MONTHLY |       | IN     |         | OUT   |       | ATING |       |
| DS      | WS  | DS     | WS  | DS        | WS    | DS     | WS   | DS       | WS  | DS  | WS      | DS      | WS     | DS    | WS      | 1st     | 2nd    | 3rd     | 4th   | IN     | OUT     | IN    | OUT   | IN    | OUT   |
| (F)     | (F) | (F)    | (F) | (F)       | (F)   | (F)    | (F)  | (F)      | (F) | (F) | (F)     | (F)     | (F)    | (F)   | (F)     | Wk      | Wk     | Wk      | Wk    | Total  | Total   | Total | Total | Total | Total |
| 97      | 76  | 39.32  | 75  | 63        | 28.49 | 69.5   | 62.0 | 32       | 31  | 7.0 | 1.6E+07 | 137,200 | 114.3  | 6     | 9.4E+07 | 1%      | 0.7    | 3.2E+05 | 49    | 500    | 1       | 5     | 50    |       |       |
| 92      | 74  | 24.50  | 75  | 63        | 28.49 | 68.8   | 67.0 | 32       | 31  | 5.5 | 1.2E+07 | 137,200 | 90.0   | 58    | 7.2E+05 | 5%      | 4.4    | 8.0E+05 | 477   | 4,400  | 1       | 5     | 426   |       |       |
| 82      | 72  | 25.71  | 75  | 63        | 28.49 | 67.8   | 66.6 | 31       | 31  | 4.5 | 1.0E+07 | 137,200 | 73.8   | 161   | 1.7E+09 | 11%     | 8.4    | 2.3E+07 | 1,338 | 10,500 | 5       | 21    | 1,379 |       |       |
| 72      | 70  | 33.99  | 75  | 63        | 28.49 | 66.8   | 65.0 | 30       | 25  | 3.9 | 9.5E+06 | 137,200 | 65.6   | 324   | 2.9E+09 | 8%      | 12.7   | 4.4E+07 | 2,667 | 16,000 | 32      | 6     | 2,699 |       |       |
| 77      | 67  | 31.34  | 75  | 63        | 28.49 | 65.8   | 64.2 | 28       | 70  | 3.8 | 4.6E+06 | 137,200 | 46.0   | 487   | 3.1E+09 | 21%     | 9.9    | 6.7E+07 | 4,609 | 15,000 | 33      | 6     | 4,638 |       |       |
| 72      | 64  | 29.35  | 75  | 63        | 28.49 | 64.8   | 61.8 | 28       | 70  | 1.6 | 3.5E+06 | 137,200 | 40.5   | 681   | 2.4E+09 | 19%     | 4.3    | 9.3E+07 | 5,666 | 16,000 | 32      | 5     | 5,695 |       |       |
| 62      | 51  | 27.44  | 62  | 59        | 28.49 | 63.2   | 61.9 | 27       | 23  | 1.3 | 2.7E+06 | 137,200 | 35.8   | 1,275 | 2.0E+09 | 45%     | 8.3    | 4.4E+07 | 6,498 | 15,000 | 32      | 5     | 6,527 |       |       |
| 62      | 57  | 24.11  | 62  | 59        | 28.49 | 58.0   | 55.9 | 27       | 23  | 1.1 | 2.5E+06 | 137,200 | 32.2   | 760   | 1.7E+09 | 12%     | 4.2    | 4.4E+07 | 5,762 | 15,100 | 32      | 5     | 5,779 |       |       |
|         |     |        |     |           |       |        |      |          |     |     |         | 3180    | 15E+10 | 100%  | 22      | 9.4E+07 | 52,178 | 250     | 150   | 170    | 536,343 |       |       |       |       |

## Evaporative Cooling: Indirect With Chiller & Heat Recovery

IDEC HEATING PERFORMANCE (24/7 operating hours)

PARA SYSTEMS - 435 North Dixie Ave., Carol Stream, IL 60188 / Ph: 630-871-3500


|  |              |
|--|--------------|
| LOCATION                                 | MILWAUKEE    |
| TOTAL HOURS OPERATION (24 hours / 7 day) | 3368         |
| IDEC SIZE                                | 450 Lb/Ft    |
| IDEC PRIMARY and SECONDARY CFM           | 500,000 Each |
| IDEC ENERGY DRAW (Kwh/ft) - pumps off    | 70.0         |
| IDEC EQUIPMENT COST (per CFM)            | \$ 2.00      |
| IDEC EFF (dry)                           | 85%          |
| Kwh/Gal                                  | \$ 0.00      |
| NatGas (per Therm)                       | \$ 0.40      |
| Assumed Furnace Efficiency               | 80%          |
| YEARLY HEATING SEASON SAVINGS            | \$354.20     |

| SUMMARY                 |           |
|-------------------------|-----------|
| Yearly Heating Savings: | \$354,300 |
| Yearly Cooling Savings: | \$ 98,100 |
| TOTAL Yearly Savings:   | \$452,400 |
| IDEC Premium:           | \$440,000 |
| PAYBACK - Years:        | 0.97      |


| SUPPLY<br>AIR<br>ENTERING | EXHAUST<br>AIR<br>ENTERING | HOURS<br>PER<br>YEAR | SUPPLY<br>AIR<br>LEAVING | EXHAUST<br>AIR<br>LEAVING | BTU/HR<br>RECOV-<br>ERED | BTU/HR<br>BY-<br>RECOV-<br>ERED | THERMS<br>PER<br>Btu In | SAVINGS<br>PER<br>Btu | PARA-<br>SITICAL<br>LOSS | PARA-<br>SITICAL<br>LOSS | NET<br>SAV-<br>INGS |
|---------------------------|----------------------------|----------------------|--------------------------|---------------------------|--------------------------|---------------------------------|-------------------------|-----------------------|--------------------------|--------------------------|---------------------|
| (F)                       | (F)                        | (Hrs)                | (F)                      | (F)                       | (Btu/hr)                 | (Btu/hr)                        | (Ftu In)                |                       | (Kw)                     | (\$)                     | (\$)                |
| 57                        | 75                         | 604                  | 69                       | 62                        | 6.3E+06                  | 2.83E+09                        | 47,922                  | \$ 19,169             | 42,280                   | \$ 2,527                 | \$ 16,632           |
| 57                        | 75                         | 581                  | 67                       | 60                        | 8.1E+06                  | 4.71E+09                        | 58,900                  | \$ 23,561             | 40,670                   | \$ 2,440                 | \$ 21,120           |
| 47                        | 75                         | 565                  | 65                       | 57                        | 9.9E+06                  | 5.58E+09                        | 69,732                  | \$ 27,893             | 39,550                   | \$ 2,373                 | \$ 25,520           |
| 47                        | 75                         | 572                  | 63                       | 54                        | 1.3E+07                  | 6.66E+09                        | 82,103                  | \$ 32,321             | 40,040                   | \$ 2,402                 | \$ 26,872           |
| 37                        | 75                         | 725                  | 62                       | 50                        | 1.2E+07                  | 9.71E+09                        | 121,435                 | \$ 48,574             | 50,750                   | \$ 2,045                 | \$ 45,529           |
| 37                        | 75                         | 869                  | 60                       | 47                        | 1.5E+07                  | 1.32E+10                        | 164,707                 | \$ 65,883             | 60,830                   | \$ 2,350                 | \$ 62,123           |
| 27                        | 75                         | 589                  | 58                       | 44                        | 1.7E+07                  | 9.97E+09                        | 124,618                 | \$ 49,847             | 41,230                   | \$ 2,474                 | \$ 47,373           |
| 27                        | 75                         | 271                  | 56                       | 41                        | 1.9E+07                  | 6.93E+09                        | 86,671                  | \$ 34,668             | 25,970                   | \$ 1,552                 | \$ 33,110           |
| 17                        | 75                         | 231                  | 55                       | 37                        | 2.6E+07                  | 4.72E+09                        | 59,065                  | \$ 23,622             | 16,170                   | \$ 970                   | \$ 22,652           |
| 12                        | 75                         | 164                  | 53                       | 34                        | 2.7E+07                  | 2.64E+09                        | 45,342                  | \$ 18,217             | 11,420                   | \$ 689                   | \$ 17,528           |
| 7                         | 75                         | 115                  | 48                       | 34                        | 2.2E+07                  | 2.56E+09                        | 31,974                  | \$ 12,789             | 8,050                    | \$ 483                   | \$ 12,306           |
| 2                         | 75                         | 89                   | 43                       | 34                        | 2.2E+07                  | 1.98E+09                        | 24,745                  | \$ 9,898              | 6,230                    | \$ 374                   | \$ 9,524            |
| -3                        | 75                         | 53                   | 38                       | 34                        | 2.2E+07                  | 1.18E+09                        | 14,730                  | \$ 5,894              | 3,710                    | \$ 223                   | \$ 5,672            |
| -8                        | 75                         | 27                   | 33                       | 34                        | 2.2E+07                  | 6.01E+08                        | 7,506                   | \$ 3,003              | 1,290                    | \$ 113                   | \$ 2,889            |
| -13                       | 75                         | 11                   | 28                       | 34                        | 2.2E+07                  | 2.45E+08                        | 3,058                   | \$ 1,223              | 770                      | \$ 45                    | \$ 1,177            |
| -17                       | 75                         | 2                    | 24                       | 34                        | 2.2E+07                  | 4.45E+07                        | 445                     | \$ 178                | 140                      | \$ 8                     | \$ 170              |

## Evaporative Cooling: Indirect/Mechanical (Low Energy Reheat)

- ❧ Facilities with high OSA needs often require expensive reheat
- ❧ Components of a low energy reheat system:
  - Indirect evaporative pre-cooler
  - Mechanical cooling coil
  - Secondary heat exchanger



## Evaporative Cooling: Indirect/Mechanical (Low Energy Reheat)






## Evaporative Cooling: Hybrid (Multi-Functional) System

- 2 Wausau West High School, Wausau, WI
- 2 Problems they were facing:
  - Expensive retrofit of existing chiller plant
  - Severe indoor air quality
  - Non-compliance with Standard 62



## Evaporative Cooling: Hybrid (Multi-Functional) System

### DUAL DUCT MULTI-ZONE WAUSAU SCHOOL DISTRICT (WISCONSIN)



1) Energy Efficiency is greatly enhanced through the use of evaporative coolers and air-to-air heat exchangers.  
2) IAQ is improved by the use of large quantities of outdoor air and through the washing of the supply air inside the DEC unit which extracts condensable gases responsible for sick building syndrome and which cannot be removed by conventional filters.

3) Hydronic perimeter heating is used to prevent building heat loss.  
4) Dual-Duct VAV boxes are used to provide cooling to the individual building zones.  
5) Very inexpensive cooling is provided by the IDEC(idec-2) unit which provides first stage cool, and the DEC(dec-2) unit which provides second stage cooling.  
6) Auxilliary cooling can be added in the

future - if needed - by using a chill cool supply water (through a second heat exchanger loop) before entering DEC unit.  
7) The HX (hx-2) heat exchanger free heating for the hot deck. In hot weather, the HX is bypassed.  
8) The heat exchanger located with IDEC recovers heat and cooling from building exhaust.


## Evaporative Cooling: Hybrid (Multi-Functional) System

### Wausau West High School

|                                  |                           |
|----------------------------------|---------------------------|
| Area:                            | 275,000 S/F               |
| System Type:                     | Regenerative Double Duct™ |
| Primary Heating Plant Reduction: | 60%                       |
| Primary Cooling Plant Reduction: | 92%                       |
| Gross Energy Use Reductions:     |                           |
| • Natural Gas:                   | 38%                       |
| • Electricity (kWh):             | 27.8%                     |
| • Electrical Demand:             | 25%                       |
| Gross Energy Cost Reductions:    | 29.3%                     |

## Evaporative Cooling: Hybrid (Multi-Functional) System


- “Base Line” energy consumption based on the former HVAC system that utilized **minimum outside air** and recirculated a majority of existing building air
- “Actual” energy consumption based on the new 100% **outside air** HVAC system





## Evaporative Cooling: Hybrid (Multi-Functional) System

- ASHRAE Standard 62.1-2001 uses an indoor to outdoor differential concentration not greater than 700 ppm of CO<sub>2</sub> as an indicator of acceptable indoor air quality



## Evaporative Cooling: Hybrid (Multi-Functional) System

- Advantages to the Hybrid system:
  - Lower first cost (especially for new construction)
  - Reduced energy usage (up to 70%)
  - Improved indoor air quality
    - Larger amounts of outdoor air
    - Direct section acts as an air scrubber

### EXCELLENCE IN INNOVATION AWARD Wisconsin Energy Initiative 2



Energy Efficiency  
Air Quality  
Comfort



## Evaporative Cooling: Hybrid (Multi-Functional) System



## Evaporative Cooling: Hybrid (Multi-Functional) System



## Evaporative Cooling: Hybrid (Multi-Functional) System




## Evaporative Cooling: Hybrid (Multi-Functional) System






## Evaporative Cooling: Hybrid (Multi-Functional) System

- Q Independent study commissioned by a New Jersey utility company comparing 3 proposed HVAC systems for 3 new schools
- Q With the Regenerative Double Duct™ HVAC design, these 3 schools became the first LEED silver certified schools in New Jersey



## Evaporative Cooling: Hybrid (Multi-Functional) System


\*Clintonville High School: Natural Gas Use  
(Projected Energy Consumption Using the Regenerative Double Duct™  
Compared to Gas Absorption Chillers and Boilers)






## Evaporative Cooling: Hybrid (Multi-Functional) System

\*Clintonville High School: Electrical Use  
(Projected Energy Consumption Using the Regenerative Double Duct™  
Compared to Gas Absorption Chillers and Boilers)



## Evaporative Cooling: Hybrid (Multi-Functional) System

\*Clintonville High School: HVAC Demand  
(Projected Demand Using the Regenerative Double Duct™ Compared  
to Gas absorption Chillers and Boilers)



## Evaporative Cooling: Conclusions (Part 1)

- ∞ Classical HVAC system strategies and equipment are not meeting the client's needs. Classical HVAC solutions are the problem
  - They are primarily constructed around energy intensive processes
  - Reliance on ventilation reduction is the primary cause of air quality problems
  - Recirculation compromises indoor air quality and energy efficiency
  - They place indoor air quality and energy conservation goals in fundamental conflict
- ∞ New HVAC system strategies are needed... better engineering is required

## Evaporative Cooling: Conclusions (Part 2)

- ∞ Truly “green” HVAC systems are attainable with simple technologies that are readily available
- ∞ Benefits of these “green” systems
  - Competitive construction costs
  - improved indoor air quality
  - reduced energy consumption
  - reduced heating/cooling plants
  - easy to maintain
- ∞ Both Direct and Indirect evaporative cooling are simple, reliable processes which will take you where you want to go

## Geothermal opportunities for ESPCs

Presenter: Mr. Mike Lemmon. LSB Industries.

### Opportunities for Geothermal Applications in ESPCs

---



**Mike Lemmon**  
Senior Account executive  
LSB Industries



## Introduction

---


- LSB Industries is a provider of hydronic equipment and solutions
- IEC fan coils, Climatemaster heat Pumps, ClimaCool modular chillers, and ClimateCraft air handling units in federal buildings around the world
- We are **not** an Energy Service Company but work with Energy Service Companies to provide HVAC solutions through our Climate Control Group

## Objectives : Opportunities for Geothermal


---

- The Technology
- Side by Side Comparison of Geothermal and a Central Chilled Water VAV System
- Economic Hurdles for Geothermal
- Hybrid Energy Saving Solutions


## Geothermal in the Summer




## Geothermal in the Winter



## Commercial Vertical Loop Application



## Other Ways to Reject and Recover Heat...





## Issues That Geothermal Addresses

---

- Energy Mandates
- Mechanical Room Space constraints
- Changing Building Occupancy Patterns
- Existing Building space and design constraints
- Year Round Conditioning of buildings and Zones
- Terminal Comfort and Control
- Indoor Air Quality – Humidity Control
- Comfort, Morale, Building Aesthetics

## Comparison of Geothermal with a Conventional System

---

### Garrett Office Buildings Edmond, Oklahoma



## **Geothermal Building 20,000 Sq. Ft.**

---




## **VAV Building 15,000 Sq. Ft.**

---




## Geothermal Building Floor 1 Plan

---



## Geothermal Building Floor 2 Plan

---





## Floor 2 Conference

---



## Floor 2 Private Office

---




## Floor 2 Open Office Space

---




## Geothermal Building Floor 2 Heat Pump Zoning



## Typical Heat Pump



## Geothermal Building Floor 2 Heat Pump Supply Ducts








## Loop Field Overview

---




## Geothermal Building Loop Field Site Plan

---



## Loop Field Details




## Geothermal Mechanical Room






## Geothermal Mechanical Room



## Geothermal Building Floor 2 Heat Pump Piping Zone 3



## Floor 1 Heat Pump Piping

---



## Floor 1 Heat Pump Piping

---



## Garrett Office Buildings Highway View

---



## Geothermal Building Roof View

---





## VAV Building Roof View

---



## VAV Building Central Air Handler

---



## VAV Building Air-Cooled Condensing Unit

---



## VAV Building Boiler Room


---



## Garrett Office Buildings 2000 Energy Consumption

| Month                    | VAV 15,000 ft <sup>2</sup> |                  | Geothermal 20,000 ft <sup>2</sup> |                  |
|--------------------------|----------------------------|------------------|-----------------------------------|------------------|
|                          | Gas Mcf                    | Elec kWh         | Gas Mcf                           | Elec kWh         |
| Jan-00                   | 36.2                       | 12,400           | 0.0                               | 9,920            |
| Feb-00                   | 21.0                       | 14,720           | 0.0                               | 10,880           |
| Mar-00                   | 6.9                        | 13,600           | 0.0                               | 9,960            |
| Apr-00                   | 4.3                        | 15,760           | 0.0                               | 10,120           |
| May-00                   | 3.5                        | 17,920           | 0.0                               | 11,600           |
| Jun-00                   | 4.2                        | 18,560           | 0.0                               | 12,400           |
| Jul-00                   | 3.2                        | 21,280           | 0.0                               | 13,120           |
| Aug-00                   | 3.2                        | 23,520           | 0.0                               | 14,480           |
| Sep-00                   | 3.2                        | 18,720           | 0.0                               | 11,120           |
| Oct-00                   | 11.2                       | 16,080           | 0.0                               | 9,840            |
| Nov-00                   | 21.9                       | 12,720           | 0.0                               | 10,360           |
| Dec-00                   | 69.4                       | 13,600           | 0.0                               | 13,600           |
| <b>Total</b>             | <b>188.2</b>               | <b>198,880</b>   | <b>0.0</b>                        | <b>137,400</b>   |
| <b>\$ Cost</b>           | <b>\$ 1,882</b>            | <b>\$ 17,899</b> | <b>\$</b>                         | <b>\$ 10,992</b> |
| <b>\$/ft<sup>2</sup></b> | <b>1.32</b>                |                  | <b>0.55</b>                       |                  |

## Garrett Office Buildings 2000 Energy Consumption Profile





## Garrett Office Buildings Installation Costs

---

- Geothermal System circa 1998
  - Complete exterior loop, mechanical room, interior PE piping, flushing and unit startup, heat pumps, duct work, exhausts, MUA system, time clock-based controls
  - \$128,700 (\$2,574 per ton)
- VAV System circa 1987
  - air-cooled condenser, VAV air handler, boiler, VAV boxes with reheat coils, economizer, electronic controls
  - \$100,000 (\$2000 per ton)
  - costs per building owner do not include structural or architectural

## Economic Hurdles for Geothermal

---

- Projects to Date – *the tests are over*
- Results – *are here!*
- Do the Savings generate enough cash flow for a self-funding ESPC?
- Is geothermal an economic win?
- Mitigating the project and performance risks – a sensible approach.

## **Future of Geothermal in ESPCs: *Hybrid Geothermal Systems***

---

- Continued Use of Close – Loop Vertical Systems
- Hybrid systems consisting of Geothermal and a peak demand shaving technologies
- Central Bore Fields with vertical heat exchangers, production/ re-injection wells
- Distributed Pumping
- Combined Heat and Power or Thermal Energy Storage or Injection well system

## **Geothermal with Existing Hydronic Systems**

---

- Combined Benefits
- Benefits of Geothermal Heating / Benefits of Hydronic Heating:
  - Greater comfort than forced air
  - Energy savings over forced air
  - No air movement in heating (less dust)
  - Greater flexibility in zoning
  - Lowers heat loss

## **Delivery Systems - Heating**

---


- Radiant Floor
- Baseboard radiation
- Cast iron radiators
- Fan coil units

## **Various Configurations of Geothermal Systems**


---

- Water-to-water unit's - heating only
- Water-to-water unit's for heating; water-to air unit's for cooling
- Water-to-water unit's for heating and cooling (with fan coil units)

## Water – To – Water Geothermal with Existing Fan Coil Units




## Geothermal and Boiler – Extended Capacity



\*Backup boiler is for capacity, not for higher water temperatures.



## Geothermal and Boiler – Extended Temperatures




\*Backup boiler is for capacity, not for higher water temperatures.

## Heat Pump Technology and Combined Heat and Power:

- Combined Heat and Power
  - Reciprocating Natural Gas Engine
  - Micro-Turbine
  - Fuel Cells
  
- Heat Pumps can be the key to providing enough thermal load to meet the economics hurdles of Combined Heat and Power.

## Hybrid Heat Pump / Combined Heat and Power

---



***Thank you for your time and participation!***



## Case Histories Utilizing Total Energy Recovery for Preconditioning Outside Air

Presenter: Mr. Douglas Haas. SEMCO Incorporated

### Chiller and Boiler Capacity Reduction Utilizing Total Energy Recovery Wheels

***Douglas Haas***

Chicago, Illinois  
October 8, 2003



**SEMCO**  
INCORPORATED

## Key HVAC Market Drivers

- ASHRAE Standard 62-2001 *Ventilation for Acceptable Indoor Air Quality*.
- ASHRAE Standard 90.1 *Energy Efficient Design of New Buildings Except Low Rise Residential Buildings*.
- Energy Policy Act of 1992 (EPAAct) which codifies ASHRAE 90.1 into law.
- International Building Code - Establishes specific cfm requirements for specific applications.



## ASHRAE 62-2001 IAQ Standard

- Purpose: To provide adequate dilution ventilation to occupied spaces and insure a healthy indoor environment. The outdoor air must be provided to the space continuously when occupied.
- Impact: Increases the amount of outdoor supplied to most facilities by a factor of four (20 vs. 5 cfm/person). Recommends 30-60% space RH. Major impact on the performance of conventional HVAC systems.
- Link to Energy Code 90.1
- Trend: New body of research is supporting the need for increasing the ventilation rates even further to 25 or 30 cfm/person (ie: OSHA, U.S. Airforce, DOE Schools Investigation).






## ASHRAE 62 Presents Problems for Conventional HVAC Equipment

- Increasing outdoor air elevates latent loads during the cooling season, making humidity control far more difficult. Sensible heat ratios of .55-.65 are required, far below the .8 SHR delivered by conventional equipment.
- Since the outdoor air must be provided continuously, humidity control problems occur when the coil is cycled off since humid air is dumped directly into the space.
- During the heating cycle, cold air is dumped into the space, creates drafts and low indoor relative humidity. Risk of freezing coils on cold days.
- The energy cost associated with conventional systems with increased outdoor air can be very significant (Life Cycle Cost).




## A Significant Difference in Savings: Total Recovery vs. Sensible Only



### How It Works: (Cooling Season)

2-3. Outdoor Air is  
Cooled, Dehumidified then  
Supplied to HVAC System




**SEMCO**  
INCORPORATED


### Typical Total Recovery Performance

Buffers the facility from outdoor air loads

#### Cooling Mode




#### Heating Mode



**SEMCO**  
INCORPORATED


## Why Controlling Relative Humidity is Essential to Avoid Microbial Growth



**SEMCO**  
INCORPORATED

## Indoor Humidity vs. Operating Mode:

Conventional packaged HVAC with & without Desiccant Preconditioning  
(Cooling Season)




(Actual Field Test Data, GTRI Willis Foreman School Study)

**SEMCO**  
INCORPORATED

Conventional HVAC units are designed to perform with:


- Minimal outdoor air (15%)
- High sensible heat ratio



**SEMCO**  
INCORPORATED

Conventional HVAC units do not perform well with:


- Increased or continuous outdoor air
- High latent to sensible heat ratios



**SEMCO**  
INCORPORATED



## Why Outdoor Air Must Be Supplied Continuously




**SEMCO**  
INCORPORATED




**SEMCO**  
INCORPORATED

## Fluted Media: Face Coating



**SEMCO**  
INCORPORATED

## Evolution of Energy Recovery Wheels: “Brillo Pad to Molecular Sieves”





**SEMCO**  
INCORPORATED

## Molecular Sieves: How does it work?


### Summertime Operation

Water vapor in **supply air stream** is adsorbed on the desiccant.




Molecular sieve is a man made material with controlled pore openings to adsorb only certain type of vapors and gases.

Because the vapor pressure in the colder **exhaust air stream** is lower than the water vapor pressure on the desiccant surface, the water is desorbed and exhausted back to the outside.



**SEMCO**  
INCORPORATED


## Molecular Sieve Desiccant Coating (SEM 10,000 X)



**SEMCO**  
INCORPORATED



## SEMCO Wheel is Designed for Reliability and Structural Integrity



**SEMCO**  
INCORPORATED

### Wheel Cassette:

Before Media Installation




Complete Cassette



**SEMCO**  
INCORPORATED




## Purge Assures No Re-entrainment



**SEMCO**  
INCORPORATED

## FV Series: How it Works




**SEMCO**  
INCORPORATED

## Applied Systems Overview




**SEMCO**  
INCORPORATED

## EPCH Solution



**SEMCO**  
INCORPORATED

## EPD Solution



## Total Energy Recovery Case Histories



**SEMCO**  
INCORPORATED

Only SEMCO has the expertise to produce both total energy wheels & systems



**SEMCO**  
INCORPORATED

Georgia Tech Olympic Dormitory



**SEMCO**  
INCORPORATED




## Georgia Tech – Energy Recovery Details



- 43,000 cfm of outdoor air through 4 EPD systems
- Dehumidified outdoor air (cooling) and humidified outdoor air (heating) delivered at a space neutral temperature
- 7 years of successful operation

**SEMCO**  
INCORPORATED

## Georgia Tech – Cooling Mode (EPD)



**SEMCO**  
INCORPORATED

## Georgia Tech – Benefits Recognized

- Economical application of constant volume, 100% outdoor air system to deliver preconditioned ventilation air to the corridors.
- Decoupled outdoor air and some space latent load from conventional room HVAC units, improved space humidity control.
- Significant reduction in first cost, operating cost and life cycle cost. Provided exceptional ROI.
- Reduced chiller/boiler capacity requirements.
- Free heating season humidification.



## Georgia Tech – Economic Summary

| Annual Energy Savings Summary  |                     |                              | First Cost Comparison Summary                          |                     |                           |
|--|---------------------|------------------------------|--|---------------------|---------------------------|
|  | Conventional System | EXCLU-SIEVE™ Preconditioning |  | Conventional System | SEMCO EPD Preconditioning |
| Energy Cost for outdoor air heating and cooling  | \$80,670/year       | \$22,830/year                | Cost of 3 Energy Recovery or AHU Preconditioners       | \$81,700            | \$202,900                 |
| Demand Charges for outdoor air   | \$22,420/year       | \$13,020/year                | Installation/ Ductwork                                 | \$63,500            | \$69,000                  |
| Total Energy Cost  | \$103,090/year      | \$35,850/year                | Chiller, Cooling Tower & Boiler                        | \$171,200           | \$66,000                  |
| <b>Energy Savings with Total Energy Preconditioning</b>  |                     | <b>\$67,240/year</b>         | Chilled Water Piping Credit                            | \$0                 | (\$33,000)                |
| NOTES:<br>1. Supply air 43,000 cfm, exhaust air 28,800<br>2. Electric cost is \$.055/KWH, gas at \$.55/Therm<br>3. Based on a 24 hr/day, 7 day/week operation<br>4. Assumes preheat to 68 degf. during winter with hot water<br>5. Assumes cooling to 52 degf. during cooling season with reheat to 68 degf. |                     |                              | Total Installation Cost                                | \$316,400           | \$304,900                 |
|  |                     |                              | <b>EXCLU-SIEVE™ Preconditioning First Cost Savings</b> |                     | <b>\$11,500</b>           |



## Applying a SEMCO Total Energy Recovery System to a Large Office Facility:

Analyzing the Decision After 10 Years of Operation



### 1100 Peachtree - Project Specifics



- 33 Story Headquarters Facility in Atlanta
- Designed to Meet ASHRAE 62-89 Guidelines
- Required 52,000 CFM of Outdoor Air, 31,000 CFM of Exhaust Air from Toilet Areas
- Utilized Desiccant Based Total Energy Recovery Preconditioning
- Preconditioned Outdoor Air Delivered to VAV Air Handling Units Located on Each Floor




## 1100 Peachtree – Benefits Recognized

- Reduced annual energy consumption by \$51,000 while maintaining IAQ.
- Reduced project first cost by cutting chiller capacity by 137 tons and eliminating a 600 KW electric preheating coil.
- Maintains a constant delivery of outdoor air to occupied spaces as the VAV system modulates the amount of return air.
- Free winter time humidification, reduced cooling coil condensate by 1,300 lbs/hr at design conditions.




### Schematic:

- Conditioned outdoor air leaves the TERS and is delivered to the VAV units (1).
- The VAV unit mixes recirculated room air (3) and outdoor air (1) and delivers it to the space (2).
- Air from toilet areas and janitors closets pulled through the TERS and exhausted (4).





## Independent IAQ Investigation Supports the ASHRAE 62 Guidelines



**SEMCO**  
INCORPORATED

## 1100 Peachtree – Economic Summary

| Annual Energy Savings Summary   |                     |                      |
|---|---------------------|----------------------|
|   | Conventional System | TERS Preconditioning |
| Energy Cost for outdoor air heating and cooling   | \$45,500/year       | \$23,400/year        |
| Demand Charges for outdoor air  | \$36,200/year       | \$7,200/year         |
| Total Energy Cost   | \$81,700/year       | \$30,600/year        |
| <b>Energy Savings with Total Energy Preconditioning</b>   |                     | <b>\$51,100/year</b> |
| NOTES:<br>1. Supply air 52,000 cfm, exhaust air 31,200<br>2. Electric cost is \$.07/KWH plus \$.08/KW demand charge<br>3. Based on a 12 hr/day, 5 day/week operation<br>4. Assumes preheat to 40 degf. during winter with electric<br>5. Assumes cooling to 58 degf. during cooling season<br>6. Savings would have been greater had exhaust equal supply |                     |                      |
| First Cost Comparison Summary   |                     |                      |
|   | Conventional System | TERS Preconditioning |
| Cost of Energy Recovery or AHU Preconditioner   | \$56,000            | \$110,000            |
| Installation/ Ductwork  | \$28,000            | \$23,000             |
| Chiller & Cooling Tower (260 tons)  | \$91,000            | \$43,000 (123 tons)  |
| Electric Preheat Coil (600KW)   | \$7,000             | \$0 (0KW)            |
| Total Installation Cost   | \$182,000           | \$176,000            |
| <b>Total Energy Recovery Preconditioning First Cost Savings</b>   |                     | <b>\$6,000</b>       |

**SEMCO**  
INCORPORATED

### Interview with Building Engineer

- Rated overall performance as excellent, minimal maintenance, high reliability.
- Maintenance required:
  - ✎ Quarterly filter changes;
  - ✎ Semi-annual inspection of belts, gear reducers;
  - ✎ Annual bearing lubrication.
- Would highly recommend this design approach for future buildings.



### Problems Over 9 year History

- Low cost substitute filter pulled out of filter rack during driving rain and damaged wheel media requiring replacement.
- Vane axial fan required service one time for worn part.
- Rebuilt one energy wheel gear reducer, replaced belts two times.



## 1100 Peachtree – Evaluation Summary

- Benefits promised by the technology at the design phase have been recognized over time at the 1100 Peachtree Building.
- Air quality within the building is excellent.
- Owner has saved approximately \$500,000 in energy cost over the life of the project.
- No degradation to recovery performance over time (checked after 6 and 9 years).



## Source for Additional Information

- Office Building IAQ Investigation
  - ✎ ASHRAE IAQ'91 Proceedings: Healthy Buildings, "Does a total energy recovery system provide a healthier environment?" Pages 74-76. C.W. Bayer and C.C. Downing



## Johns Hopkins Ross Research Facility

11 Years of Successful Operation



### Ross Building - Project Specifics



- 300,000 cfm of combined laboratory/hood exhaust
- 10 air changes per hour, constant volume system
- Eight SEMCO 3A molecular sieve coated total energy recovery wheels (14' diameter)
- 11 years of successful operation








**SEMCO**  
INCORPORATED

### Ross Building – Benefits Recognized


- Economical application of constant volume, 100% outdoor air system to laboratory (preferred by the Head of Health and Safety).
- Significant reduction in first cost, operating cost and life cycle cost. Provided exceptional ROI.
- Reduced chiller/boiler capacity requirements allowed for the use of central plant utilities.
- Improved humidity control, reduced condensate on cooling coils by 65% and size of steam to steam humidifiers.
- Resolved “freeze-stat” alarms with frozen coils.

**SEMCO**  
INCORPORATED

## Ross Building – Cooling Mode

**SEMCO**  
INCORPORATED

## Ross Building – Heating Mode

**SEMCO**  
INCORPORATED

## Ross Building – Economic Summary

| Annual Energy Savings Summary  |                     |                                 | First Cost Comparison Summary                                  |                     |                                 |
|--|---------------------|---------------------------------|--|---------------------|---------------------------------|
|  | Conventional System | EXCLU-SIEVE™<br>Preconditioning |  | Conventional System | EXCLU-SIEVE™<br>Preconditioning |
| Energy Cost for outdoor air heating and cooling  | \$1,070,500/yr.     | \$503,300/yr.                   | Cost of Energy Recovery or AHU Preconditioner                  | \$450,000           | \$1,056,900                     |
| Demand Charges for outdoor air   | \$151,800/yr.       | \$73,800/yr.                    | Installation/ Ductwork   | \$235,000           | \$295,000                       |
| Total Energy Cost  | \$1,222,300/yr.     | \$577,100/yr.                   | Chiller & Cooling Tower (2632 tons)                            | \$3,158,400         | \$1,536,000 (1280 tons)         |
| <b>Energy Savings with Total Energy Preconditioning</b>  |                     | <b>\$645,200/year</b>           | Boiler and Piping (818 HP)                                     | \$286,300           | \$71,400 (204 HP)               |
| NOTES:<br>1. Supply air 300,000 cfm, exhaust air 280,000<br>2. Electric cost is \$.045/KWH, gas at \$.45/Therm<br>3. Based on a 24 hr/day, 7 day/week operation<br>4. Reheat to 75 degf. during winter with humidification<br>5. Assumes cooling to 52 degf. during cooling season<br>6. Demand charges are \$14.42 from June to September |                     |                                 | Total Installation Cost  | \$4,129,700         | \$2,959,300                     |
|  |                     |                                 | <b>EXCLU-SIEVE™<br/>Preconditioning<br/>First Cost Savings</b> |                     | <b>\$1,170,400</b>              |



## Ross Building – Life Cycle Analysis

- SEMCO total energy recovery wheels resulted in a first cost **savings** of \$1,170,400.
- Provided a positive present value cash flow of \$6,959,600 based on 20 year life cycle.
- Will provide estimated energy savings in the amount of \$15,307,500 over the 20 year life cycle analysis period.

Assumes: inflation at 2.5% and cost of capital of 10%, no taxes



## Energy Saving with Demand Controlled Ventilation

Presenter: Mr. David Scheidler. Plymovent



**Energy Savings  
with  
Demand Controlled  
Process and General  
Ventilation  
Systems**

**by:  
David Scheidler  
PlymoVent Corp, USA**



## WORLD WIDE ENERGY DEMAND IS UNDER ATTACK!

- Not since the OPEC oil embargo has the world's energy supply been in question.
- The war on terrorism and conflicts in the Middle East will inevitably raise energy prices.
- The failure to continue to explore alternate energy sources in the past two decades has continued the demand on fossil fuel energy to supply most countries electric power needs.

## HOW WILL YOU HANDLE THE ENERGY COST INCREASE ? HISTORY REPEATS ITSELF. IN THE LATE 70'S THE OPEC OIL EMBARGO DOUBLED MOST ENERGY COSTS.

- **1979** gasoline costs in the United States were **.37 cents** per imperial gallon prior to the oil embargo.
- **1980** gasoline prices drastically rose to **.95 cents** per imperial gallon.
- This increase in fossil fuel demand left the US consumer with an increase in energy costs which dramatically effected corporate profits and inflated the general cost of living.
- **Energy prices rose nearly tripled.**
- **Winter of 2001**, gasoline costs in the US were **\$1.00 per** imperial gallon. This meant there was little increase in the change of the price of crude oil from the year of 1980 to the winter of 2001.
- **Summer of 2001**, gasoline cost in the US rose in less then 6 months to a **\$1.75 per** imperial gallon.
- The result of this dramatic increase has directly **effected corporate profits, initiated surge charges for peak demand users, and states like California created rolling blackouts and interruption of power.**

## DEMAND CONTROL VENTILATION IS A SOLUTION FOR SAVINGS.

### Process ventilation applications

- Machining processes
- Welding processes
- Grinding processes
- Laser and plasma cutting processes
- Finishing processes
- Vehicle tune-up processes

### General ventilation applications

- Indoor air quality control
- Vehicle emissions control
- General exhaust
- Displacement ventilation

## PROCESS VENTILATION



## DISPLACEMENT VENTILATION




## EXHAUST VENTILATION



## FUMES/DUST/ODORS VENTILATION



## PROCESS VENTILATION WITH HEAT RECOVERY





## MACHINE TOOL PROCESS WITH DEMAND CONTROLS



## TYPICAL CONTROL SENSOR TYPES

- Pressure differential sensor
- Infra-red light sensor
- Inductive electrical sensor
- Particulate sensor
- Relative humidity sensor
- CO sensor
- Hydrogen sensor
- Temp. sensor
- And many others

## PEAK DEMAND EVALUATION

When designing a demand controlled ventilation system it is important to evaluate the peak demand usage factor of the system.

**High demand** - small ventilation systems or robotic systems usually exhibit higher peak demand.

**Low demand** – large manual or semi-automatic systems usually exhibit lower peak demand.


**Example of demand :**

- 1-2      workstations - 90-80% usage
- 3-4      workstations - 70-80% usage
- 5-8      workstations - 55-70% usage
- 10+     workstations - 45-50% usage

## HOW ARE SAVINGS ACHIEVED ?

- **Lower energy consumption** – energy consumption is reduced since the ventilation system only operates when required by the demand of the process. It will also operate only for the designated air delivery which is required by process demands.
- **Lower maintenance costs** - maintenance cost will be reduced since the system will not be required to operate at 100% capacity at all times. This will reduce the quantity of filter elements and their frequency of replacement.
- **Lower operating costs** – operating costs will be reduced by more efficient energy saving blower motors which in turn are energy managed by demand controllers which are interfaced with frequency inverters.
- **Lower installation costs** – installation costs are reduced by reducing the overall size of the system and its related components such as electrical wiring, motor starters, size of ductwork, and the need for fire suppression.
- **Lower initial purchase costs** – since few manufacturing processes operate at 100% demand, a savings will be achieved by reducing the overall air volume of the system and its filtering systems.

## Controls, schematic drawing



## Energy Saving Analysis

|   |             |             |       |  |           |   |           |                                     |           |           |
|---|-------------|-------------|-------|--|-----------|---|-----------|-------------------------------------|-----------|-----------|
| Average temperature on location C                       | 6 degrees C |             |       |  |           |   |           |                                     |           |           |
| Ambient air temperature                                 | -15 C       |             |       |  |           |   |           |                                     |           |           |
| Two shift operation hours                               | 3520h       |             |       |  |           |   |           |                                     |           |           |
| Year hours  | 8760h       |             |       |  |           |   |           |                                     |           |           |
| Energy required to heat 1 m <sup>3</sup> air 1 degree C | 0,348W      |             |       |  |           |   |           |                                     |           |           |
| Min. required efficiency on heat exchanger              | 50%         |             |       |  |           |   |           |                                     |           |           |
|   |             |             |       | Without controls and<br>heat exchanger |           | With controls and<br>w/o heat exchanger |           | With controls and<br>heat exchanger |           |           |
|   |             | Airflow per | Hours | Usage                                  | Total     | Usage                                   | Total     | Usage                               | Total     |           |
|   | Pcs         | point       | m3/h  | %                                      | airflow/h | %                                       | airflow/h | %                                   | airflow/h | Total     |
| Extraction arms manual welding                          | 5           | 1 000       | 3520  | 100                                    | 5 000     | 30                                      | 1 500     | 30                                  | 1 500     |           |
| Suction tables manual welding                           | 24          | 1 800       | 3520  | 100                                    | 43 200    | 30                                      | 12 960    | 30                                  | 12 960    |           |
| Suction hoods robot welding                             | 8           | 1 800       | 3520  | 100                                    | 14 400    | 80                                      | 11 520    | 80                                  | 11 520    |           |
| General ventilation                                     | 1           | 28 000      | 8760  | 100                                    | 28 000    | 100                                     | 28 000    | 100                                 | 28 000    |           |
| Total airflow   |             |             |       |  | 90 600    |   | 53 980    |                                     | 53 980    |           |
| Energy consumption per year process ventilation         |             |             |       | kWh                                    | 1 063 000 |   | 445 885   |                                     |           | 156 153   |
| Energy consumption per year general ventilation         |             |             |       | kWh                                    | 1 195 000 |   | 1 195 000 |                                     |           | 421 431   |
| Power consumption on fan motor                          |             |             |       | kWh                                    | 497 340   |   | 419 724   |                                     |           | 419 724   |
| Total   |             |             |       | kWh                                    | 2 755 340 |   | 2 060 609 |                                     |           | 997 308   |
| Savings with control equipment                          |             |             |       | kWh                                    |           |   | 694 731   |                                     |           |           |
| Savings with control equipment and heat exchanger       |             |             |       | kWh                                    |           |   |           |                                     |           | 1 758 032 |

## WELDING PROCESS WITH DEMAND CONTROLS AND NOTIFICATION SYSTEM



QUESTIONS FROM THE AUDIENCE




**THANK YOU FOR YOUR  
PARTICIPATION.**


- If you have any questions or comments, please email them to [wlutz@plymoventusa.com](mailto:wlutz@plymoventusa.com)
- Or Call 908-209-2096

## A Robust Tool for Screening. Tool for Combined Heat and Power Technologies in Today's Energy Marketplace

Presenter: Mr. William Ryan. University of Illinois in Chicago, ERC.



### A Robust Screening Tool for CHP Technologies in Today's Energy Marketplace



Dr. William Ryan  
University of Illinois at Chicago  
Energy Resources Center  
312-996-3606

Midwest CHP Application Center (MAC)  
[www.CHPCenterMW.org](http://www.CHPCenterMW.org)  
312-413-5448

## What is a Screening Tool?



- First Look at a CHP Opportunity
  - Is Proceeding to a Concept Design Justified?



## How Does it Need to be Structured?


- Quick and Easy-to-Use
- Handle the Level of Detail Available on the Application
  - Might Be a Basic Architectural Description of a New Building, or
  - An Existing Building with a Historic Record of Energy Consumption
- The Market Today Expects More Accuracy and Sophistication in Screening Tools than in the Past

## What is the Most Common Pitfall of Existing Screening Tools

- **Averaging !**
  - Energy Analysis Often has this Inaccuracy
  - In CHP or any Heat Recovery System – It is Lethal
- **Unfortunately – It is Also Nearly Universally Done**


## Prove It

- Simplified Example
- A Continuously Operating CHP System is Rejecting Heat to a Space Heating



## Heating Load Per Month


- Simplistic Programs Start with the Total Monthly Thermal Loads






## Average Heating Load

- This Amounts to Assuming the Heating Load is Split Evenly Across the Month



## Average Heating Load


- Lets Take a Look at December and Assume that the Recovered Heat Output Capacity of a CHP System Equals the Average Load in December



***Averaging  
Programs Have No  
Choice But to  
Assume the  
Recovered Heat  
Meets the Heating  
Load***


## Nothing Could Be Further From the Truth !!

- Hour-by-Hour Heating Load (DOE-2)
- The Heating Load Varies Widely Throughout the Month




## Evaluating Hour-by-Hour

- Assume CHP System Generates Constant Electric Output
- The CHP Heating Capacity Can Meet this Portion of the Heating Load




### Some of the Heating Load Cannot be Met

- Boiler System Must be Called Upon to Meet the Remainder of the Load in High Load Hours



### And in Low Load Hours

- Some of the Heat from the CHP System Must be Dumped



## Net Effect

- Averaging Analysis has No Choice but to Base Projections on Average Loads and Average Equipment Capacity
  - The Over-Projections Can be Quite Large
- A CHP System Following the Electric Load May Make this Worse!

– In Commercial Building :

– Electric Loads and Heating Loads are Negatively Correlated

|                             | Averaging Analysis | Hour by Hour Analysis |
|-----------------------------|--------------------|-----------------------|
|                             |                    |                       |
| Total December Heating Load | 1088               | 1088                  |
| Heat Produced by CHP System | 1088               | 1088                  |
| Load Met By CHP             | 1088               | 631                   |
| Heat Required from Boiler   | 0                  | 457                   |
| CHP System Heat Dumped      | 0                  | 454                   |

## Why Is This Averaging Done

- Actual Hourly Loads are Rarely Available
  - Would Not Be Useful Anyway
  - Loads Must be Corrected to Average Weather Years




## What is Needed

- Hourly Analysis Must Have an Hourly Simulation Engine (Like DOE 2)
- Problems
  - Reputation for Complexity
  - Must be Matched to Actual Building Data
- Need
  - Package That Makes This Easy to Do

### Packaged Analysis

- Hour-by Hour DOE 2 Analysis Engine
- Simple to Use Front and Back Ends
- Highly Adaptable by Adding New Equipment Components
  - DesiCalc 1997
  - Gas Cooling Guide 1999
  - Building Energy Analyzer 2002



## Front Screen

\* BEA - PG - Input Module File ;

File Edit Help

### BUILDING ENERGY ANALYZER

| Geographical Location |   | Application Size and Type |  |
|-----------------------|---|---------------------------|--|
| State: Illinois       | Chicago; Meigs Field IL -                                       | 60030                     | sq. ft. Retail Store; 1-story slab on                              |
| City: Chicago, IL     | Lat./Long. 42N/88W Summer 1%<br>Design Dry Bulb/Mean-Coincident | Retail Store              | grade construction typical of a<br>larger department store with 10 |

| BaseLine Configuration                   |                  | Alternative Configuration                  |  |
|--|------------------|--|--|
| <h4>Energy Rates</h4>                    |                  |  |  |
| Electric: Chicago CommEd Schedule 6 -    | Electric         | Electric: Chicago CommEd Standby Rate 1 -  |  |
| Gas: Chicago: Northern Illinois Gas: Sch | Gas              | Gas: Chicago: Northern Illinois Gas: Schec |  |
| <h4>Equipment</h4>                       |                  |  |  |
| Electric Screw                           | Cooling          | Electric Screw                             |  |
| Gas                                      | Heating          | Gas  |  |
| None                                     | HVAC Options     | None                                       |  |
| None                                     | Cold Storage     | None                                       |  |
| None                                     | Power Generation | Internal Combustion Engine                 |  |

Project Description Calculate

**UIC** University of Illinois  
at Chicago



**MIDWEST  
CHP**  
APPLICATION  
CENTER

## Location & Energy Rates

\* GCG PG 1.8 (MCL) - Economic Analysis Module - Input Module File :

File Edit Help

Overall Config/Run Calculations Location and Energy Cost Application HVAC Equipment Cold Storage Power Generation

**Location** *weather file* State: Georgia City: Atlanta, GA

**Energy Rates** *Custom Energy Rate* GA: GA Pwr PLM-2/All Gas U/G-11GAC  
GA: GA Pwr PLM-2/All Gas U/G-11G  
MD: BG&E GL/BG&E C&GAC  
SC: SCE&G MGS20/SCE&G GS31&G  
IL: ComEd 6-TOU/NI Gas 4B&GAC  
OH: Chvnd Elec LgComm/E OH Gas C

**ASHRAE Design Point** Atlanta GA - Lat./Long. 34N/84W Summer 1% Design Dry Bulb/Mean-Coincident Wet Bulb: 91/74°F (Humidity Ratio)

**Energy Rates Description** GAS: Utility Name - Atlanta Gas Light, Rate Name - Schedule 6-11, Qualifications - C200 MMBtu/month Oct-Apr;

**Electric** **Rate Type** ☒ Stepped ☐ Time of Use

**Electric Rate Season**

| Month    | Season |
|----------|--------|
| Jan      | W      |
| Feb      | W      |
| Mar      | W      |
| Apr      | W      |
| May      | W      |
| June     | S      |
| July     | S      |
| Aug      | S      |
| Sep      | S      |
| Oct      | W      |
| Nov      | W      |
| Dec      | W      |
| S-Summer | W      |
| W-Winter | W      |

**Rate Basis** **Rate %**

| Charge Basis | Summer | Winter |
|--------------|--------|--------|
| Summer       | 95     | 95     |
| Winter       | 95     | 95     |
| Annual       | 0      | 0      |
| None         | 0      | 0      |

**Miscellaneous Charges**

| Charge                             | Rate   |
|------------------------------------|--------|
| Monthly Charge (\$)                | 16.75  |
| Energy Cost Adj. - Summer (\$/kWh) | 0.0151 |
| Energy Cost Adj. - Winter (\$/kWh) | 0.0151 |
| Taxes, Surcharges (\$)             | 5.03   |
| Taxes, Surch. Credits (\$/kWh)     | 0      |

**Stepped Energy Rates**

| Cutoff Type | Summer  | Winter  |
|-------------|---------|---------|
|             | Rate    | Rate    |
| 1           | 0.109   | 0.109   |
| 2           | 0.0999  | 0.0999  |
| 3           | 0.086   | 0.086   |
| 4           | 0.0667  | 0.0667  |
| 5           | 0.0111  | 0.0111  |
| 6           | 0.00836 | 0.00836 |
| 7           | 0.00732 | 0.00732 |

**UIC** University of Illinois  
at Chicago



**MIDWEST  
CHP**  
APPLICATION  
CENTER

## Building Main Page

**GCG PG 1.8 (MCL) - Economic Analysis Module - Input Module File :**

File Edit Help

Overall Config/Run Calculations Location and Energy Cost Application HVAC Equipment Cold Storage Power Generation

**Application Type and Size**

Nursing Home

Floor Area 45000 sf

Glazing 25 %

Build Orientation 0 deg

**Building Zones**

Patient Rooms

Common Areas

Service Area

**Baseline Equipment Config - Comfort Controls**

Occupied Hours Controls

Temperature

Cooling 75 deg F

Heating 74 deg F

Dehumidification

Humidification

Min 30 % RH

**Alternative Equipment Config - Comfort Controls**

Occupied Hours Controls

Temperature

Cooling 75 deg F

Heating 74 deg F

Dehumidification

Humidification

Min 30 % RH

**Annual Schedule**

Show Next Schedule

| Occupancy - % of nom | Week | Sat | Sun |
|----------------------|------|-----|-----|
| 1                    | 100  | 100 | 100 |
| 2                    | 100  | 100 | 100 |
| 3                    | 100  | 100 | 100 |
| 4                    | 100  | 100 | 100 |
| 5                    | 100  | 100 | 100 |
| 6                    | 100  | 100 | 100 |
| 7                    | 100  | 100 | 100 |
| 8                    | 50   | 50  | 50  |
| 9                    | 50   | 50  | 50  |
| 10                   | 50   | 50  | 50  |
| 11                   | 50   | 50  | 50  |
| 12                   | 50   | 50  | 50  |
| 13                   | 50   | 50  | 50  |
| 14                   | 50   | 50  | 50  |
| 15                   | 50   | 50  | 50  |
| 16                   | 50   | 50  | 50  |
| 17                   | 50   | 50  | 50  |
| 18                   | 50   | 50  | 50  |
| 19                   | 50   | 50  | 50  |

**Internal Loads**

People 175 sf/person

Lights 2 Wat/sf

Other Electric Watt/sf 0.2

Exhausted from space % 0

Latent to space % 0

Other Gas Btu/h/sf 0

Exhausted from space % 0

Latent to space % 0

**Outdoor Air Load**

Ventilation 25 cfm/person

Infiltration 0.75 exch/hr

**UIC** University of Illinois  
at Chicago



## Enhanced HVAC System Controls

**GCG PG 1.8 (MCL) - Economic Analysis Module - Input Module File :**

File Edit Help

Overall Config/Run Calculations Location and Energy Cost Application HVAC Equipment Cold Storage Power Generation

**Configuration**

Baseline Alternative

**Cooling Equipment**

Central Plant Rooftop PTAC

**Chiller Type and Options**

First Chiller Electrical Eff. kW/ton COP No. Capacity Units %

Electric Centrifugal-Inlet Vane Control 0.68 1 40

Second Chiller

Gas Engine-Driven Centrif. Heat Recove 0.02 1.8 1 40

Third Chiller

Electric Centrifugal-Inlet Vane Control 0.68 1 40

**Chiller Engine**

Idle COP Ratio Jacket Efficiency Exhaust Both

30 % 60 %

**Chill Water Pump**

Fixed Variable Efficiency

0.0464 kW/RT

**Summer Gas Chillers Sequencing**

On Peak Mid Peak Off Peak

First Last Peak

**System Options**

Economizer

None Temperature Enthalpy

Condenser

Air Water Heat Recovery Yes No

**Heat Recovery/Outside Air Treatment**

Sensible Enthalpy Heat Pipe

Desiccant Dehumidifier Dedic. OA DX Unit

**Cooling Tower**

Capacity Control

Bypass 1 Speed Fan 2 Speed Fan Var. Speed Fan

Temperature Control

Strainer Thermo None

Fixed 85 F WetBulb Reset

**Gas Heating/Boiler Eff.**

82 %

**Heat Reheat Energy Source**

Gas Electric

**Humidifier Energy Source**

Gas Electric

Max. humidity control using desiccant dehumidifier option engaged in area 1.

**UIC** University of Illinois  
at Chicago





# New Power Generation Controls

**\* GCG PG 1.8 (MCL) - Economic Analysis Module - Input Module File :**

File Edit Help

Overall Config./Run Calculations Location and Energy Cost Application HVAC Equipment Cold Storage **Power Generation**

**Configuration**  
☒ Baseline ☐ Alternative

**Power Generation Equipment**

| Lead Generator             | Part Load Parameters | No. of Units | Capacity % | Electric Efficiency % Fuel In | Stream A Quantity deq F % Fuel In | Stream B Quantity deq F % Fuel In | Variable \$/kWh | Fixed \$/year |
|----------------------------|----------------------|--------------|------------|-------------------------------|-----------------------------------|-----------------------------------|-----------------|---------------|
| Internal Combustion Engine |                      | 1            | 100        | 35                            | 250                               | 30                                | 0.002           | 100           |
| Lag Generator              | Part Load Parameters | 1            | 35         | 25                            | 500                               | 55                                | 0.001           | 200           |

**Heat Recovery**  
 Heat Recovery Options/Distributor

**Generation Equipment Sizing Method**  
☒ Peak Hour Electric Demand (%)  
☐ Peak Hour Thermal Demand (%)  
☐ Fixed Demand (kW)

**Power Generation Control Strategy**

| Summer   |  |  | Winter   |  |  |
|--|--|--|--|--|--|
| On Peak  | Mid Peak                                       | Off Peak                                       | On Peak  | Mid Peak                                       | Off Peak                                       |
| <input checked="" type="radio"/> Max. Output   | <input checked="" type="radio"/> Max. Output   | <input checked="" type="radio"/> Max. Output   | <input checked="" type="radio"/> Max. Output   | <input checked="" type="radio"/> Max. Output   | <input checked="" type="radio"/> Max. Output   |
| <input checked="" type="radio"/> Track Elec.   | <input checked="" type="radio"/> Track Elec.   | <input checked="" type="radio"/> Track Elec.   | <input checked="" type="radio"/> Track Elec.   | <input checked="" type="radio"/> Track Elec.   | <input checked="" type="radio"/> Track Elec.   |
| <input checked="" type="radio"/> Track Therm.  | <input checked="" type="radio"/> Track Therm.  | <input checked="" type="radio"/> Track Therm.  | <input checked="" type="radio"/> Track Therm.  | <input checked="" type="radio"/> Track Therm.  | <input checked="" type="radio"/> Track Therm.  |
| <input checked="" type="radio"/> Track Greater | <input checked="" type="radio"/> Track Greater | <input checked="" type="radio"/> Track Greater | <input checked="" type="radio"/> Track Greater | <input checked="" type="radio"/> Track Greater | <input checked="" type="radio"/> Track Greater |
| <input checked="" type="radio"/> Track Lesser  | <input checked="" type="radio"/> Track Lesser  | <input checked="" type="radio"/> Track Lesser  | <input checked="" type="radio"/> Track Lesser  | <input checked="" type="radio"/> Track Lesser  | <input checked="" type="radio"/> Track Lesser  |
| <input checked="" type="radio"/> Do Not Run    | <input checked="" type="radio"/> Do Not Run    | <input checked="" type="radio"/> Do Not Run    | <input checked="" type="radio"/> Do Not Run    | <input checked="" type="radio"/> Do Not Run    | <input checked="" type="radio"/> Do Not Run    |

☒ Energy TOU Based ☐ Demand TOU Based ☐ Custom Schedule Based

**Generation On/Off**

| Hr | Week | Sat | Sun |
|----|------|-----|-----|
| 1  | Off  | Off | Off |
| 2  | Off  | Off | Off |
| 3  | Off  | Off | Off |
| 4  | Off  | Off | Off |
| 5  | On   | On  | Off |
| 6  | On   | On  | On  |
| 7  | On   | On  | On  |
| 8  | On   | On  | On  |
| 9  | On   | On  | On  |
| 10 | On   | On  | On  |
| 11 | On   | On  | On  |
| 12 | On   | On  | On  |
| 13 | On   | On  | On  |
| 14 | On   | On  | On  |
| 15 | On   | On  | On  |
| 16 | On   | On  | On  |
| 17 | On   | On  | On  |
| 18 | On   | On  | On  |
| 19 | On   | On  | On  |
| 20 | On   | On  | On  |
| 21 | On   | On  | On  |
| 22 | On   | On  | On  |
| 23 | On   | On  | Off |
| 24 | On   | On  | Off |

# Generator Performance Input

**\* GCG PG 1.8 (MCL) - Economic Analysis Module - Input Module File :**

File Edit Help

**Lead Generator Part Load Performance and Ambient Temperature Correction Factor - Baseline Equipment Configuration**

**Internal Combustion Engine**

| Load % | Correction Factor             |  |   | Temp. F |
|--------|-------------------------------|--|---|---------|
|        | Electric Efficiency % Fuel In | Heat Recovery Higher Temp. Stream A Quantity % Fuel In | Heat Recovery Lower Temp. Stream B Quantity % Fuel In |         |
| 100    | 1                             | 1  | 1   | 60      |
| 75     | 0.8173                        | 0.75   | 0.75  | 70      |
| 50     | 0.6069                        | 0.5  | 0.5   | 80      |
| 25     | 0.3687                        | 0.25   | 0.25  | 90      |

**Electric Power Generation Efficiency Ambient Temp. Correction Factor**

Done



# Utilization of Recoverable Heat

GCG PG 1.8 (MCL) - Economic Analysis Module - Input Module File :

File Edit Help

## Utilization of Recoverable Heat - Baseline Equipment Configuration

| Distribution of Recoverable Heat     |                                       |                                       |                                     |                                     |
|--------------------------------------|---------------------------------------|---------------------------------------|-------------------------------------|-------------------------------------|
| Equipment Utilizing Recoverable Heat | Lead Generator Heat Recovery Stream A | Lead Generator Heat Recovery Stream B | Lag Generator Heat Recovery Stream  | Engine Chiller Heat Recovery        |
| Space Heating                        | <input checked="" type="checkbox"/>   | <input checked="" type="checkbox"/>   | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Domestic Hot Water                   | <input checked="" type="checkbox"/>   | <input checked="" type="checkbox"/>   | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Desiccant Dehumidifier               | <input type="checkbox"/>              | <input type="checkbox"/>              | <input type="checkbox"/>            | <input type="checkbox"/>            |
| Single-Effect Absorption             | <input type="checkbox"/>              | <input type="checkbox"/>              | <input type="checkbox"/>            | <input type="checkbox"/>            |
| Double-Effect Absorption             | <input type="checkbox"/>              | <input type="checkbox"/>              | <input type="checkbox"/>            | <input type="checkbox"/>            |

Min. Quality of Recoverable Heat Usable by Absorption Chillers

Single Effect:  F    Double Effect:  F

Done

**UIC** University of Illinois at Chicago




## Side-by-Side Economic Comparisons

|   |                |   |                |
|---|----------------|---|----------------|
| <b>Baseline Equipment Results</b>                                 |                | <b>Alternative Equipment Results</b>                              |                |
| Total Consumption:  | 13,771,881 kWh | Total Consumption:  | 12,079,777 kWh |
| Utility Supplied:   | 13,771,883 kWh | Utility Supplied:   | 480 kWh        |
| Generated On-Site:  | 0 kWh          | Generated On-Site:  | 12,079,297 kWh |
| Cooling:  | \$ 1,785,586   | Cooling:  | \$ 86          |
| Desiccant Dehumidifier:   | \$ 0           | Desiccant Dehumidifier:   | \$ 0           |
| Heating/Reheating:  | \$ 0           | Heating/Reheating:  | \$ 0           |
| Fans:   | \$ 3,248       | Fans:   | \$ 0           |
| Refrigeration:  | \$ 0           | Refrigeration:  | \$ 0           |
| Other Electric:   | \$ 5,963       | Other Electric:   | \$ 0           |
| Standby Charge:   | \$ 0           | Standby Charge:   | \$ 0           |
| Grid Electric Energy Cost:  | \$ 899,864     | Grid Electric Energy Cost:  | \$ 56,862      |
| <b>ANNUAL NATURAL GAS ENERGY CONSUMPTION and GAS UTILITY COST</b> |                | <b>ANNUAL NATURAL GAS ENERGY CONSUMPTION and GAS UTILITY COST</b> |                |
| Total Consumption:  | 59,810 MMBtu   | Total Consumption:  | 163,302 MMBtu  |
| Building Consumption:   | 59,810 MMBtu   | Building Consumption:   | 38,935 MMBtu   |
| Power Generation Consumption:                                     | 0 MMBtu        | Power Generation Consumption:                                     | 124,367 MMBtu  |
| Recoverable Thermal Energy:                                       | 0 MMBtu        | Recoverable Thermal Energy:                                       | 71,414 MMBtu   |
| Recovered Thermal Energy:   | 0 MMBtu        | Recovered Thermal Energy:   | 30,326 MMBtu   |
| Cooling:  | \$ 0           | Cooling:  | \$ 43,116      |
| Desiccant Dehumidifier:   | \$ 0           | Desiccant Dehumidifier:   | \$ 0           |
| Heating/Reheating:  | \$ 64,792      | Heating/Reheating:  | \$ 3,738       |
| Power Generation:   | \$ 0           | Power Generation:   | \$ 376,666     |
| Other Gas:  | \$ 120,611     | Other Gas:  | \$ 68,722      |
| Annual Gas Energy Cost:   | \$ 185,404     | Annual Gas Energy Cost:   | \$ 492,242     |
| <b>TOTAL ELECTRIC and GAS UTILITY COSTS*</b>                      |                | <b>TOTAL ELECTRIC and GAS UTILITY COSTS*</b>                      |                |
| Annual Energy Cost  | \$ 1,085,268   | Annual Energy Cost  | \$ 572,353     |

## A Variety of Charts

\*BEA - PG - Calculations Module File ;

File Reports Charts Help




**UIC** University of Illinois  
at Chicago



## A Variety of Charts

\*BEA - PG - Calculations Module File ;

File Reports Charts Help




**UIC** University of Illinois  
at Chicago



## Retrofit Calibration

### Gas Energy vs. Heating Degree Days


Unnamed Project, Run: 10/6/2003, 9:33:00 AM Print; 10/6/2003, 3:33:18 AM File; Sample 2.mdb




## Retrofit Calibration

### Gas Energy vs. Heating Degree Days


Unnamed Project, Run: 10/6/2003, 9:33:00 AM Print; 10/6/2003, 3:33:18 AM File; Sample 2.mdb



## Retrofit Calibration




## Retrofit Calibration





## Retrofit Calibration



## Does This Cover All CHP Needs

- No
  - Easy to Use Screening Tools for the Design Engineer Use “Hard” Programming to Allow “Easy” Operation
  - Set Up for Conventional Systems
- For Research
  - Need “Soft” Programmed Tools for “Easy” Modification
  - “Hard” to Use
  - Must Still Feature Hour-by Hour Operating Systems

## UIC CHP Engineering Model

- Research Tool

- Can Be Reprogrammed for Unconventional Systems in Reasonable Time
- Used for Testing New Concepts
- Requires a 50+ Megabyte Excel Spreadsheet
- Uses Hourly Building Load Files from DOE-2
  - » Use BEA to Develop Load Files
- Develops Full Economic Optimizations

## UIC CHP Engineering Model

- Research Uses to Date

- Direction for BEA Development
- Cross-Checking BEA Test Results
- Studying CHP Economic Dynamics
  - » Investment Return Vs. System Sizing
  - » Sizing Rules of Thumb
  - » Unusual Thermal Loads (Pools, Industrial Processes)
  - » Hot Thermal Storage
  - » New Generation Equipment and Packages
- “Soft” Programming Allows for Quick Revisions BUT Requires Extensive User Understanding

## Summary

- Screening Tools Have Advanced Considerably
- New Construction: Can Produce Economic Estimates from Preliminary Design Information
  - Allows Economics to be Scoped Early in the Design
  - Improves Chances of CHP Being Used
- Retrofits: Allow Fitting to Usage History
  - Calibrates Simulation to Real Utility History
  - Normalizes Results to AVERAGE Weather Years
    - » Very Important for Guaranteed Savings Financing

## References

- Picture Credits
  - Wartzilla
  - Solar Power Ventures
- More Information
  - Building Analyzer Program - Available from GTI

## **Assessment of HVAC systems reliability**

Presenter: Dr. Eugene Shilkrot. Central Research Institute for Industrial Buildings, Russia

**EUGENE SHILKROT, Ph.D**

**Head of HVAC Laboratory  
of Central Research Institute for Industrial Buildings,  
Russia, Moscow**

# **ANALYSIS of HVAC SYSTEMS RELIABILITY**



## HVAC SYSTEMS RELIABILITY –What is it?

### Small special glossary

HVAC Equipment – collection of units - fans, air heaters, water heaters, coolers, pipes, ducts, controllers and etc.

ROOM – heated and ventilated (air conditioned) premises, residential dwellings, industrial shops

HVAC SYSTEM = Rooms + HVAC Equipment

## HVAC SYSTEMS RELIABILITY –What is it?

### Small special glossary

Indoor microclimate – indoor air temperature, radiant temperature, velocity, humidity, contaminant concentration

HVAC system reliability – conditions of HVAC system when all parameters of microclimate are within a normal range of parameters

Failure – conditions of HVAC system when one or all of the parameters of the microclimate are out of a normal range

HVAC system reliability depends on its power, equipments quality and level of maintenance

HVAC system reliability is calculated as probability quantity

$$P_{en.source} \equiv 1$$
$$P_{(z)} = P_{zp.out} P_{equip}$$

$P_{(z)}$  - Total HVAC system reliability

$P_{zp.out}$  - HVAC system reliability with respect  
to outdoor climate

$P_{equip}$  - HVAC equipment reliability

$$P_{eq} = \prod_n^m P_i$$

$$P_i \dots P_{fan} \dots P_{airheater} \dots P_{cooler} \dots etc$$

$$P_i = \exp(-\lambda z)$$

$$\lambda = \frac{1}{Z_{mean}} = const$$

$$Z_{time,hr}$$

HVAC systems are systems with temporal redundancy

Temporal redundancy is dependent upon room's inertia

Change in room's temperature in case of HVAC equipment "Failure"

$$\theta = \frac{(t_{in} - t_{out})_z}{(t_{in} - t_{out})_o}$$

$$\theta = \exp \left( - \frac{qz}{w} \right)$$

$$1(10^{-3}) \leq \frac{q}{w} \leq 6(10^{-3})$$

Change of room's contaminant concentration in case of HVAC equipment  
"Failure"

$$z = \frac{1}{k_{exh}} \ln \frac{Q_{vent} c_1 - G_{pol}}{Q_{vent} c_2 - G_{pol}}$$

$$k_{exh} = \frac{Q_{vent}}{V_{room}}$$

HVAC system reliability with temporal redundancy of HVAC equipment


$$P_i = \exp(-\lambda z)$$

$$\lambda = \frac{1}{z_{mean. \Delta z}}$$

$$z_{mean. \Delta z} \approx z_{mean} \exp\left(\frac{\Delta z}{z_{repair}}\right)$$



### Reliability of air heating system with temporal redundancy



- 1- Reliability of a system without temporal redundancy
- 2- Reliability of a system without temporal redundancy – two heaters
- 3- Reliability of a system with temporal redundancy,  $\Delta z = 3\text{hr}$
- 4- Reliability of a system with temporal redundancy,  $\Delta z = 10\text{hr}$

### Conclusions

Calculations of reliability of HVAC systems provides an opportunity to choose optimal system design and predict expenses on system maintenance.

Calculations of redundancy time of HVAC systems provides an opportunity to estimate the number of required maintenance personnel.

Calculations of redundancy time of HVAC systems provides an opportunity to choose the optimal algorithms of operation and to minimize expenses.

## Energy Security

Presenter: Mr. Roch Ducey. ERDC-CERL

**CALIBRE**  
*Our Success Follows Yours*



# Army Installation Energy Security Plans: Project Overview

Project Sponsor: Assistant Chief of Staff  
of the Army for Installation Management (ACSIM)

Presented to the Industry Workshop by  
Roch Ducey, U.S. Army Engineer R&D Center/CERL  
(800)USA-CERL, x7444 – roch.ducey@us.army.mil

October 8, 2003



**Building Research Council**  
School of Architecture  
University of Illinois at Urbana-Champaign



**Sandia National Laboratories**



## Background

- Energy for training, mobilization and deployment, and other key Army missions should be available at installations when needed
- Power outages either due to an attack on a power plant or an installation (or due to any other reason) should not affect the Army's ability to perform its key missions
- The Army wants to increase energy independence and security at its installations

2

## Project Purpose

- Develops Energy Security Plans for three Army installations with the goal of ensuring that their key energy needs can be supplied by DG that is secure and clean to the greatest extent practical.
- Establishes the analytic capability for developing and integrating feasible Army Installation Energy Security Plans for IMA (Installation Management Agency) Regions and across the US.

*Goal - Installed Clean DG to meet key energy needs at Army installations*

3

## Scope

### Technical

- Consider clean fixed and mobile DG; examples include photovoltaics, wind, biomass, fuel cells, microturbines,....

DG Investment Timeframe: 2004-10 (long range planning through 2020)

### Financial

- Maximize use of private resources for DG investment

### Project

- 3 major Army installations (case studies): Forts Lewis, Carson and Riley
- Study completed by end of July 03

4

## Approach

- Determine clean DG technical potential
- Assess clean DG value added
- Examine finance options
- Develop Installation Energy Security Plans

5



## Develop Installation Energy Security Plans

- Use optimization model to develop clean DG investment strategies for Forts Lewis, Carson, and Riley
- Integrate modeled investment strategies with assessment of issues to develop Army Installation Energy Security Plans
- Examples of issues include:
  - Installation Operations (e.g., Will workforce like DG?)
  - Finance (e.g., What kinds of business risk or opportunities might the private sector face?)
  - Institutional (e.g., Are there any effects on other Service installations?)
  - Legal (e.g., Are environmental waivers possible?)
  - Policy (e.g., Are there any security risks with the use of on site contractors?)

6

## Project Team

- ACSIM/IMA-NWRO/Installations:  
Forts Lewis, Carson, and Riley
- Energy & Security Group (ESG)
- CALIBRE
- Engineer R&D Center/CERL
- Center for Army Analysis (CAA)
- Sandia National Lab

7

## General Observations

- The three case installations and their utilities are concerned about threats to energy security - agree on DG micro grid on-site as goal
- Relationship of on-site DG and transmission/ distribution privatization needs to be addressed
- Utility resource planning process could include (and rate base) on-site DG
- How much should/will energy security cost? How much energy security is sufficient? Who should pay?
- DG options vary by installation

8

## Concluding Remarks

- This project examines the pros and cons of installing clean DG at Army installations to increase energy security
- Technical data can be shared with private and public sectors - final report will be unclassified
- Questions/Comments/Suggestions?

9