



Feasibility of Water Treatment Technologies for Arsenic and Fluoride Removal

**AWWA Water Quality Technology Conference
17 November 2004; Arsenic I**

Brian C. Pickard, P.E., R.S.

*U.S. Army Center for Health Promotion and Preventive Medicine
Aberdeen Proving Ground, MD*

Muhammad Bari, P.E.

Chief, Environmental Division, Fort Irwin, CA

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE NOV 2004		2. REPORT TYPE N/A		3. DATES COVERED -	
4. TITLE AND SUBTITLE Feasibility of Water Treatment Technologies for Arsenic and Fluoride Removal				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) U.S. Army Center for Health Promotion and Preventive Medicine Aberdeen Proving Ground, MD				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release, distribution unlimited					
13. SUPPLEMENTARY NOTES Presented at the AWWA Water Quality Technology Conference November 2004, The original document contains color images.					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT UU	18. NUMBER OF PAGES 35	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			



Overview

- **Project Background**
- **Current Operations and “Consumptive Use”**
- **Contaminant Overviews**
- **Data Collection**
- **Treatment Alternative Analysis & Considerations**
- **Treatment Alternatives Screening**
- **Conclusions**



Project Background

- **Location:** Fort Irwin, CA, approximately 35 miles northeast of Barstow, California, in the north-central part of the **Mojave Desert**
- **Source Water:** 11 groundwater wells from three distinct geologic basins (Irwin, Bicycle, and Langford)
- **Water Demand:** Fort Irwin houses the Army's National Training Center, so water demand fluctuates due to troop rotations and seasonal irrigation
- **Source Water Contaminants of Concern**
 - **Arsenic (As)** > future MCL of 0.010 mg/L (January 2006)
 - **Fluoride (F)** > State MCL of 2 mg/L




Relative Basin Contributions to Total Monthly Water Production





Existing Operations - Two Systems?

- **Dual-line** (domestic and potable) water distribution system
 - Domestic Water: chlorinated groundwater at the wellhead (bathing, irrigation, toilet flushing, etc);
 - Potable Water: **0.15 MGD** Reverse Osmosis (RO) plant for potable water





“Consumptive Use” Conundrum

- In defining a Public Water System in 1996 SDWA Amendments, EPA broadened the definition of “consumptive use” to more than just drinking, stating “...human consumption includes drinking, bathing, showering, cooking, dishwashing, and maintaining oral hygiene”
- All consumptive use water, not just the RO-treated potable portion, would need to meet SDWA requirements, including compliance with arsenic and fluoride MCLs



Treatment Requirements

- Co-removal treatment technology for As and F
 - Arsenic Rule, January 2001, revised arsenic MCL from 50 $\mu\text{g/L}$ to 10 $\mu\text{g/L}$, enforceable mid-January 2006
 - Fluoride MCL is 2 mg/L (CDHS; SDWA is 4 mg/L)
- WTP design flow will increase from 0.15 to 5.0 MGD and employ 1-line distribution system
- Design/construction of a new, full-scale WTP
 - First priority: water conservation
 - Consider waste flows



Contaminant Overviews



Contaminant Overview: Arsenic

➤ Occurrence

- Common, naturally-occurring drinking water contaminant originating from arsenic-containing rocks and soil, transported to natural waters via erosion, dissolution and air emission
- Man-made sources: mining and smelting operations; agricultural applications; and the use/disposal of industrial products
- Arsenite, As(III); neutral surface charge vs. Arsenate, As(V), negative surface charge

➤ Health Effects - Both cancerous and non-cancerous effects

- Class A human carcinogen, with low arsenic exposure (< 0.05 mg/L) linked to cancer of the skin, liver, lung and bladder
- Large arsenic doses (above 60 mg/L) can cause death; lower doses (0.30-30 mg/L) may cause stomach and intestinal irritation and nervous system disorders



Contaminant Overview: Fluoride

➤ Occurrence

- contained in minerals, fluorspar (fluorite) and apatite (calcium fluorides) and released as fluoride ions when contacted with GW, thus fluoride is found naturally in all waters
- Typical GW concentrations range from trace to greater than 5 mg/L, with deeper GW generally having higher fluoride concentrations

➤ Health Effects

- Drinking water fluoride concentrations greater than 4 mg/L can cause bone disease in adults and tooth mottling (discoloring) in children
- Moderate fluoride levels (0.7 to 1.2 mg/L, temperature-dependent) in drinking water are beneficial to children during the time they are developing permanent teeth




Data Collection



Onsite Data Collection

- Supplement existing source water data
- Source water characteristics significantly affect treatment alternative selection (pH, TDS, sulfate, silica)
- Field Arsenic Speciation Kits- only reliable way to determine source water arsenic forms
 - Particulate versus dissolved (soluble)
 - Reduced [As(III)] versus oxidized [As(V)]







Source Water Characterization Results

	Parameter			
	Fluoride (mg/L)	Arsenic (µg/L)		
		Total	As(III)	As(V)
	Range	Range		
Source Water Aquifer				
Bicycle Lake	1.1 to 4.5	< 2.0 to 30.3	<10%	≥ 90%
Langford Lake	4.4 to 9.9	7.9 to 15.8	< 1%	≥ 99%
Irwin	8.0 to 10.6	32.2 to 40.1	< 5%	≥ 95%
California State MCL	2.0	Current: 50 µg/L; Future: 10 µg/L		

Source Water Aquifer	Parameter (mg/L)			
	pH	Sulfate	TDS	Silica
Bicycle Lake	7.6 to 7.9	110 to 130	590 to 650	60 to 125
Langford Lake	8.2 to 8.5	105 to 150	480 to 560	25 to 35
Irwin	8.1	132	130	85



Treatment Alternative Analysis & Considerations



Water Quality Treatment Goals

Constituent	Water Quality Goal (mg/L, unless noted)		
Primary MCL			
Arsenic ¹	0.0080	--	--
Fluoride ¹	1.6	--	--
Nitrate ¹	8.0 (as N)		
Secondary MCL			
pH	6.5-8.5	--	--
Color	15 units	--	--
Turbidity	5 units	--	--
Odor - Threshold	3 units	--	--
Iron	0.3	--	--
Manganese	0.05	--	--
Alkalinity	> 30 mg/L CaCO ₃	--	--
Corrosivity	0 to 0.05 LSI	--	--
	Recommended	Upper²	Short Term²
TDS	500	1,000	1,500
Sulfate	250	500	600
Chloride	250	500	600

1 - design for 80% of the MCL;

2 - Per California regulations.



Treatment Avoidance & Blending

- Non-treatment: contributions of targeted source water wells are either eliminated or combined such that the product water entering the distribution system meets the arsenic and fluoride MCLs
- Sidestream Treatment: treating only a portion of the source water, so that subsequent blending with the untreated portion produces finished water that meets arsenic and fluoride MCLs




Blending Strategies

Mass Balance Equation


$$Q_{SS} = Q_1 \left(\frac{C_{As/F,1} - (1 - \sigma)C_{MCL}}{\varepsilon C_{As/F,1}} \right)$$




Sidestream Treatment



Treatment and Blending



Sidestream Treatment and Blending





Treatment Options

Best Available Technologies (BATs)

<u>Arsenic</u>	<u>Fluoride</u>
Activated Alumina (AA)	AA
Ion Exchange (IX)	RO
Reverse Osmosis (RO)	
Electrodialysis Reversal (EDR)	
Oxidation/Filtration	
Enhanced Coagulation/Filtration	
Enhanced Lime Softening	




Co-removal BATs	Removal Efficiency		Water Loss	Optimal Conditions	Operator Skill
	As	F			
Activated Alumina (AA)	95%	85- 95%	1-2%	pH 5.5-8.3 (decreased efficiency at high pH); < 360 mg/L SO ₄ ; < 1,000 mg/L TDS; < 250 mg/L Cl, < 0.5 mg/L Fe; < 0.05 mg/L Mn; < 4 mg/L TOC; < 30 mg/L Silica; < 0.3 NTU Turbidity;	Low
Reverse Osmosis (RO)	> 95%	85- 95%	40-60%	< 30 mg/L silica for <15% water loss; (per RO manufacturers) No particulates.	Medium
Other Treatment Technologies	Removal Efficiency		Water Loss	Optimal Conditions	Operator Skill
	As	F			
Electrodialysis Reversal (EDR)	> 95%	85- 95% ³	20-30%	Treats most waters without preference; Process efficiency not affected by silica; Most economical for TDS of 3,000-5,000 mg/L;	Medium
Coagulation/ Micro-Filtration (C/MF)	90%	NS	5%	pH 5.5-8.5	High
Iron Based Sorbents	up to 98%	No	1-2%	pH 6-8.5 (decreased efficiency at high pH); < 1 mg/L PO ₄ ; < 0.3 NTU Turbidity;	Low
Ion Exchange (IX)	95%	No	1-2%	pH 6.5-9 (decreased efficiency at high pH); < 50 mg/L SO ₄ ; < 500 mg/L TDS; < 5 mg/L NO ₃ ; < 0.3 NTU Turbidity;	High
Point of use/Point of entry Devices	95%	Vary	Vary	Scaled down versions of IX, AA, RO processes.	Low




Adsorption Considerations

➤ Competing Ions

- Activated Alumina



- Ion Exchange (IX)



- IX is not a BAT for F removal; and SO_4^{2-} over 50 mg/L precludes IX as an economically viable technology
(all source water > 100 mg/L sulfate)



Membrane Considerations

- Silica concentrations of 75 mg/L will limit RO water recovery to about 60%, per manufacturer experience.
Source water varies from 25-125 mg/L silica
- Pretreatment for silica removal may be needed prior to RO (dependent on pilot-scale testing results).
- EDR, which uses electrical current, instead of pressure, to remove ionic contaminants is not affected by silica concentrations



Waste Stream Considerations

AA - acid (pH adjustment) and caustic (media regeneration)

RO/EDR - Concentrated brine discharge

➤ Disposal Options


- Direct discharge to evaporation ponds (100% water loss)
- Indirect discharge to WWTP (partial GW recharge)
- Vapor compression unit – near zero discharge, but \$\$\$

➤ Sludge Criteria for Landfill Disposal

- Sludge must have no free liquids - Paint Filter Test
- Final sludge/spent media must be non-hazardous for landfill
- EPA has TCLP; CA has WET (F salts)




AA Treatment Train





RO/EDR Treatment Train





Cost

TREATMENT ALTERNATIVE	COST (\$)	
	Capital	O&M/yr
ALTERNATIVE #1: STATUS QUO - Maintain current operations, including separate domestic and potable water systems.	0	155,000
ALTERNATIVE #2: ACTIVATED ALUMINA - Construct AA columns at central location; - Pre and post treatment (pH/filtration) likely needed; - Blending used to decrease hydraulic loading; - Periodic regeneration/disposal of spent media.	4.3M	455,000
ALTERNATIVE #3: REVERSE OSMOSIS/ELECTRODIALYSIS - Construct membrane units at central location; - Pre and post treatment (filtration, conditioning chemicals, pH/alkalinity adjustment), as needed; - Blending used to decrease hydraulic loading; - Multiple pass design may minimize water loss.	<u>RO</u> 15.0M <u>EDR</u> 13.0M	<u>RO</u> 1.35M <u>EDR</u> 950,000

*Note: Site-specific cost factors may increase the AA capital cost to approximately \$7.6M, per Fort Irwin Facilities Personnel



Treatment Alternatives Screening



Screening Criteria

- Each treatment alternative was screened against seven relevant criteria
- Except for cost, all criteria were qualitative, and rated on a scale of 1 to 7 (7 being best, and 1 being worst)
- Criteria scores were then summed to derive an overall alternatives ranking, with the highest scoring alternative being the preferred choice
- Criteria were weighted (2:1) toward regulatory compliance, water conservation and cost



		Treatment Alternatives		
Criteria	Wght	#1 STATUS QUO	#2 AA ADSORPTION	#3 RO/ EDR
Regulatory Compliance	.2	1 (0.2)	6 (1.2)	7 (1.4)
Water Conservation	.2	6 (1.2)	6 (1.2)	2 (0.4)
Cost	.2	1* (0.2)	6 (1.2)	3 (0.6)
Implementation	.1	1 (0.1)	5 (0.5)	4 (0.4)
Production Capacity	.1	1 (0.1)	5 (0.5)	4 (0.4)
Public Perception and Acceptance	.1	1 (0.1)	5 (0.5)	5 (0.5)
Occupational & Environmental	.1	4 (0.4)	3 (0.3)	3 (0.3)
Raw Score	49	15	36	28
Weighted Score	(7)	(2.3)	(5.4)	(4.0)

* - based on potential non-compliance penalties



Search for Comparable Facility

- **29 Palms AA WTP - 3 MGD Design flow**
 - Located in the Hi-Desert Water District in Yucca Valley, California
 - GW source concentrations: As: $< 5 \mu\text{g/L}$;
F: 5-7 mg/L; 250 mg/L of TDS
 - Blending: bypass 25% of the raw water
 - Provides excellent treatment, endorsed by operators
 - Novel precipitation/spray irrigation system (salt brush)
- **Pilot-plant studies favored AA over RO/EDR**



Conclusions



Treatment Technology Considerations

➤ Consider:

- Source water characteristics: As forms, pH, competing ions, silica, etc.
- Non-treatment options
- BATs; also look for comparable facilities
- Waste flows and sludge disposal

➤ For Fort Irwin:

- AA was the recommended treatment technology
- Conduct pilot-plant studies to verify effectiveness



Acknowledgements

The presenter would like to thank the following people for their support of and input into this project:

- Mr. Mike Wright, Lead Operator, 29 Palms Water Treatment Plant
- Mr. Fred Rubel, P.E., Rubel Engineering
- Mr. Art Lundquist, USACHPPM



Questions?

Contact Information

Brian Pickard, P.E., R.S.

USACHPPM, Water Supply Management Program

Phone: (410) 436-8226

Email: brian.pickard@apg.amedd.army.mil