

## **REPORT DOCUMENTATION PAGE**

Form Approved  
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing this collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number. **PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.**

1. REPORT DATE (DD-MM-YYYY) 22-08-2010			2. REPORT TYPE Final Technical	3. DATES COVERED (From - To) 6/1/2009-5/31/2010
4. TITLE AND SUBTITLE  (DURIP 09) - ULTRAFAST LASER SYSTEM FOR COHERENT ANTI-STOKES RAMAN SCATTERING MEASUREMENTS AT DATA RATES OF 5 KHZ			5a. CONTRACT NUMBER  5b. GRANT NUMBER FA9550-09-1-0387  5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S) Robert P. Lucht			5d. PROJECT NUMBER  5e. TASK NUMBER  5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)  Purdue University			8. PERFORMING ORGANIZATION REPORT NUMBER  School of Mechanical Engr. 585 Purdue Mall Purdue University West Lafayette, IN 47907-2088	
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES)  Air Force Office of 875 North Randolph St. Suite 325, Room 3112 Arlington, VA 22203-1768			10. SPONSOR/MONITOR'S ACRONYM(S)  11. SPONSOR/MONITOR'S REPORT NUMBER(S) AFRL-OSR-VA-TR-2012-0543	
12. DISTRIBUTION / AVAILABILITY STATEMENT Approved for public release; distribution is unlimited				
13. SUPPLEMENTARY NOTES				
14. ABSTRACT Funds were requested for the purchase of an ultrafast laser system and optical parametric amplifier (OPA) for nonlinear optical diagnostics in flames at data rates of 5 kHz. In the time period between the submission of the DURIP proposal and the initiation of the grant, the specifications for commercial ultrafast laser systems in the price range of interest had considerably improved. A Coherent laser system with pulse energies of 2.6 mJ at 5 kHz and 1.0 mJ at 10 kHz repetition rate was purchased. The ultrafast laser system includes a 128-pixel pulse shaper to correct the phase of the laser spectrum and to ensure that the amplified laser pulses are very close to Fourier-transform-limited. An OPA and frequency-mixing system were purchased to produce a tunable beam that will be used for the pump radiation in the femtosecond coherent anti-Stokes Raman scattering (CARS) measurements. This system has been delivered and installed in the Prof. Lucht's Applied Spectroscopy Laboratory.				
15. SUBJECT TERMS				
16. SECURITY CLASSIFICATION OF:  a. REPORT Unclassified		17. LIMITATION OF ABSTRACT UL	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON Julian Tishkoff
b. ABSTRACT Unclassified		c. THIS PAGE Unclassified		19b. TELEPHONE NUMBER (include area code) (703) 696-8478

**(DURIP 09)- ULTRAFAST LASER SYSTEM FOR COHERENT  
ANTI-STOKES RAMAN SCATTERING MEASUREMENTS AT  
DATA RATES OF 5 KHZ**

**AFOSR Grant Number: FA9550-09-1-0387**

**Final Performance Report  
Report Period: June 1, 2009 to May 31, 2010**

**Prepared by:**

**Dr. Robert P. Lucht (PI)**

**765-494-5623**

**765-494-0539 (fax)**

**lucht@purdue.edu**

School of Mechanical Engineering

Purdue University

West Lafayette, IN 47907

## **Executive Summary**

**AFOSR Grant Number: FA9550-09-1-0387**

**Project Title:**

(DURIP 09)- Ultrafast Laser System for Coherent Anti-Stokes Raman Scattering Measurements at Data Rates of 5 kHz

**Project Period:** June 1, 2009 to May 31, 2010

**Report Period:** June 1, 2009 to May 31, 2010

**Date of Report:** August 27, 2010

**Contacts:**

Robert P. Lucht: Phone: 765-494-5623, E-mail: [lucht@purdue.edu](mailto:lucht@purdue.edu)

### **Project Abstract:**

Funds were requested for the purchase of an ultrafast laser system and optical parametric amplifier (OPA) for nonlinear optical diagnostics in flames at data rates of 5 kHz. The ultrafast laser system as requested in the proposal system operated at 5 kHz with a pulse energy of >1.2 mJ at the fundamental wavelength of approximately 800 nm. In the time period between the submission of the DURIP proposal and the initiation of the grant, the specifications for commercial ultrafast laser systems in the price range of interest had considerably improved. A Coherent laser system with pulse energies of 2.6 mJ at 5 kHz and 1.0 mJ at 10 kHz repetition rate was purchased. The ultrafast laser system includes a 128-pixel pulse shaper to correct the phase of the laser spectrum and to ensure that the amplified laser pulses are very close to Fourier-transform-limited. An OPA and frequency-mixing system were purchased to produce a tunable beam that will be used for the pump radiation in the femtosecond coherent anti-Stokes Raman scattering (CARS) measurements. This system has been delivered and installed in the Prof. Lucht's Applied Spectroscopy Laboratory.

The Coherent ultrafast laser system will be used for high-data-rate, single-pulse coherent anti-Stokes Raman scattering measurements. In addition, the use of the system for two-photon-induced fluorescence detection and measurement of species such as OH, CH, and NO will be explored. The potential for planar imaging of two-photon-induced fluorescence from these species at data rates of up to 5 kHz will be explored.


AFOSR grant funds for the project have been fully (100%) expended.

## **Project Objectives**

The objective of the DURIP grant was to purchase an ultrafast laser system to develop and demonstrate advanced laser diagnostic techniques. In particular, the ultrafast laser system was selected to advance the state-of-the-art with respect to femtosecond (fs) coherent anti-Stokes Raman scattering (CARS) spectroscopy. Fs CARS offers some significant potential advantages compared with nanosecond (ns) CARS, i.e., CARS as usually performed with ns pump and Stokes lasers. These potential advantages include (1) performing real-time temperature and species measurements at data rates of 1 kHz or greater, (2) the absence of any effect of collisions in the determination of temperature and concentration from the fs CARS signal, and (3) higher signal-to-noise ratios due to the nearly Fourier-transform-limited (FTL) nature of the ultrafast laser radiation. In collaboration with Sukesh Roy at Spectral Energies and James Gord at AFRL, the Lucht group has been developing fs CARS techniques for temperature and concentration measurements (Lucht et al., 2006; Lucht et al., 2007; Roy et al. 2008; Roy et al., 2009a; Roy et al., 2009b; Richardson et al., 2010). The experiments described in these papers were all performed at Wright-Patterson Air Force Base using a Coherent ultrafast laser system with a repetition rate of 1 kHz and a pulse energy of approximately 1 mJ in the fundamental beam at 800 nm. While these initial experiments were very promising, extension of the fs CARS techniques to data rates of 5 kHz and higher is highly desirable so that a greater range of turbulence frequencies can be measured. An ultrafast laser system with repetition rates up to 10 kHz and a fundamental beam pulse energy of 1 mJ even at this very high repetition rate was therefore purchased.

## **Coherent Ultrafast Laser System**

The Coherent ultrafast laser system that was purchased with the DURIP funds is schematically illustrated in Fig. 1. The mode-locked oscillator for the system is a Mantis. The Mantis has a repetition rate of 80 MHz, an average power of > 500 mW, and a bandwidth of greater than 70 nm; the bandwidth is sufficient to produce pulses as short as 30 fs. The Mantis operates at a fixed wavelength of 800 nm. An optically pumped semiconductor laser (OPSL) is incorporated in the Mantis box and serves as the pump laser for the titanium-sapphire (Ti:S) slab crystal in the mode-locked oscillator cavity.



The Mantis beam is then directed into the Silhouette pulse shaper/pulse characterizer unit. The Silhouette has a 128-pixel liquid crystal spatial light modulator. The pulse can be characterized using the technique of multiphoton intrapulse interference phase scan (MIIPS) with the Silhouette. The Silhouette is used to correct the phase distortions that cause a departure from the Fourier transform limit.

The pump laser for the Legend Elite amplifier is an Evolution HE Nd:YLF laser that is diode-pumped and intracavity-frequency double to produce a 527 nm output beam. At 5 kHz 70 W of average power are used to pump the amplifier, at 10 kHz 75 W of average power is used to pump the amplifier.

The Legend Elite ultrafast amplifier is used to amplify pulses from the Mantis. The Legend Elite system includes both a regenerative amplifier stage and a single-pass amplifier stage. In both of these stages the slab Ti:S crystals are mounted on thermoelectric coolers. The Legend Elite amplifier system is capable of operation at repetition rates of either 5 kHz or 10 kHz. It also includes stretchers and compressors for either 30 fs or 60 fs pulses. During installation all four repetition rate/pulse length combinations were demonstrated. The original specification for the system pulse length were 40 fs and 90 fs. However, with the incorporation of the Silhouette into the system the actual measured pulses were 30 fs and 60 fs instead of 40 fs and 90 fs, respectively. The shorter pulse lengths were achieved because the Silhouette corrects the phase of the spectrum of pulses at the input to the amplifier so that the output pulses are within 1-2% of the Fourier transform limit. Consequently the shortest possible pulses can be extracted from the amplifier.

The output of the amplifier is then directed into the OPerA Solo, an automated optical parametric amplifier (OPA) with a harmonic generation stage after the OPA. The OPA is used to produce signal and idler pulses from the input pump pulse at 800 nm. The OPA is seeded with a white light continuum. The signal wavelengths from the OPA process range from 1140 nm to 1600 nm and the idler wavelengths range from 2600 nm to 1600 nm. The crystal for second harmonic generation of the signal beam was purchased and installed in the OPerA Solo. The wavelength range of the frequency-doubled signal beam is from 580 nm to 800 nm. For the planned fs CARS measurements, the pump beam wavelengths, powers, and pulse energies for different Raman species are listed in Table 1. For all of the species listed, the pump pulse energy is considerably higher than the pump pulse energy of 30  $\mu$ J for the single-pulse measurements reported by Roy et al. (2009b). Consequently it is anticipated that the signal to noise ratios for the planned fs CARS measurements will be considerably improved compared to the already excellent results reported by Roy et al. (2009b).

## Summary

The ultrafast laser system requested in the DURIP proposal has been purchased and installed. The specifications and characteristics of the laser system that was actually purchased are superior to the system that was specified in the proposal due to rapid advances in the technology of commercial ultrafast laser systems. The Coherent ultrafast laser system will be

used first for fs CARS measurements, but should be very useful for a wide range of nonlinear diagnostic methods for reacting flows.

Table 1. Pump wavelength, average power, and pulse energy for different species of interest. The Stokes wavelength is assumed to be 800 nm.

Species	Raman Shift (cm <sup>-1</sup> )	Pump $\lambda$ (nm)	Pump Ave. Power (W), 5 kHz	Pump Pulse Energy ( $\mu$ J), 5 kHz
CO <sub>2</sub>	1388	720	630	126
O <sub>2</sub>	1556	711	650	130
N <sub>2</sub>	2330	674	735	147
CH <sub>4</sub>	2915	649	690	138
H <sub>2</sub> O	3657	619	585	117
H <sub>2</sub>	4160	600	425	85

## References

- R. P. Lucht, S. Roy, T. R. Meyer, and J. R. Gord (2006), “Femtosecond Coherent Anti-Stokes Raman Scattering Measurement of Gas Temperatures from Frequency-Spread Dephasing of the Raman Coherence,” *Applied Physics Letters* **89**, Article No. 251112.
- R. P. Lucht, P. J. Kinnius, S. Roy, and J. R. Gord (2007), “Theory of Femtosecond Coherent Anti-Stokes Raman Scattering for Gas-Phase Transitions,” *Journal of Chemical Physics* **127**, Article No. 044316.
- D. R. Richardson, R. P. Lucht, S. Roy, W. D. Kulatilaka, and J. R. Gord (2010), “Single-Laser-Shot Femtosecond Coherent Anti-Stokes Raman Scattering Thermometry at 1000 Hz in a Driven H<sub>2</sub>-Air Flame,” *Proceedings of the Combustion Institute*, accepted for publication.
- S. Roy, P. J. Kinnius, R. P. Lucht, and J. R. Gord (2008), “Temperature Measurements in Reacting Flows By Time-Resolved Femtosecond Coherent Anti-Stokes Raman Scattering (fs-CARS) Spectroscopy,” *Optics Communications* **281**, 319-325.
- S. Roy, D. R. Richardson, P. J. Kinnius, R. P. Lucht, and J. R. Gord (2009a), “Effects of N<sub>2</sub>-CO Polarization Beating on Femtosecond Coherent Anti-Stokes Raman Scattering (CARS) Spectroscopy of N<sub>2</sub>,” *Applied Physics Letters* **94**, Article No. 144101.

S. Roy, D. R. Richardson, W. D. Kulatilaka, R. P. Lucht, and J. R. Gord (2009b), “Gas-Phase Thermometry at 1-kHz Using Femtosecond Coherent Anti-Stokes Raman Scattering (fs-CARS) Spectroscopy,” *Optics Letters* **34**, 3857-3859.