

ESL-TR-1979-302

**ENERGY CONSUMPTION AND DEMAND,
NAVAL WEAPONS CENTER**

TRW Incorporated
Energy Systems Group
One Space Park
Redondo Beach, CA 90278

Contract No. N68305-79-C-0007

June 1979

DISTRIBUTION A: Approved for public release; distribution unlimited.

**ENGINEERING & SERVICES LABORATORY
AIR FORCE ENGINEERING & SERVICES CENTER
TYNDALL AIR FORCE BASE, FLORIDA 32403**

DISCLAIMER

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not constitute or imply its endorsement, recommendation, or approval by the United States Air Force. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Air Force.

This report was prepared as an account of work sponsored by the United States Air Force. Neither the United States Air Force, nor any of its employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights

This document is submitted as an historical record of work performed. Limitations of the available media rendered editing impractical; therefore it is retained "as is."

REPORT DOCUMENTATION PAGE

*Form Approved
OMB No. 0704-0188*

The public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports (0704-0188), 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to any penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

PLEASE DO NOT RETURN YOUR FORM TO THE ABOVE ADDRESS.

| | | |
|---|---|---|
| 1. REPORT DATE (DD-MM-YYYY) 01-JUN-1979 | 2. REPORT TYPE Final Technical Report | 3. DATES COVERED (From - To) 01-JAN-1977 -- 30-DEC-1978 |
|---|---|---|

| | |
|---|--|
| 4. TITLE AND SUBTITLE Energy Consumption and Demand, Naval Weapons Center | 5a. CONTRACT NUMBER N68305-79-C-0007 |
| | 5b. GRANT NUMBER |
| | 5c. PROGRAM ELEMENT NUMBER |

| | |
|---------------------|---|
| 6. AUTHOR(S) | 5d. PROJECT NUMBER |
| | 5e. TASK NUMBER |
| | 5f. WORK UNIT NUMBER 21038008 |

| | |
|--|---|
| 7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) TRW Incorporated Energy Systems Group One Space Park Redondo Beach, CA 90278 | 8. PERFORMING ORGANIZATION REPORT NUMBER |
|--|---|

| | |
|--|--|
| 9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) Engineering Services Laboratory Air Force Engineering & Services Center 139 Barnes Drive, Suite 2 Tyndall Air Force Base, FL 32403-5323 | 10. SPONSOR/MONITOR'S ACRONYM(S) ESL |
| | 11. SPONSOR/MONITOR'S REPORT NUMBER(S) ESL-TR-1979-302 |

12. DISTRIBUTION/AVAILABILITY STATEMENT
Distribution A: Approved for public release; distribution unlimited.

13. SUPPLEMENTARY NOTES

14. ABSTRACT

Energy storage has proven to be effective in load leveling for utilities and for making feasible the switch to inconstant energy sources such as solar and wind in applications requiring nearly constant sources of power. To date, energy storage has not been used in large measure on military bases as a technique for improving energy use efficiency. To assess the potential for energy storage at a military base, the U.S. Naval Facilities at Port Hueneme, California was selected as a candidate energy storage study site. This report is the result of the first phase of that study which has three major objectives:

- 1 - Determining the historical energy use patterns at the study site
- 2 - Evaluate specific energy storage techniques at the study site
- 3 - Develop a handbook that will assist personnel at other bases in evaluating energy storage applications at their location.

15. SUBJECT TERMS
energy consumption, energy storage

| | | | | | |
|--|-------------------------|--------------------------|---|----------------------------------|---|
| 16. SECURITY CLASSIFICATION OF: | | | 17. LIMITATION OF ABSTRACT UU | 18. NUMBER OF PAGES 36 | 19a. NAME OF RESPONSIBLE PERSON William Barattino |
| a. REPORT U | b. ABSTRACT U | c. THIS PAGE U | | | 19b. TELEPHONE NUMBER (Include area code) |

Reset

TABLE OF CONTENTS

| | <u>Page</u> |
|------------------------------------|-------------|
| INTRODUCTION | 1 |
| TOTAL ENERGY CONSUMPTION | 2 |
| ELECTRIC DEMAND | 5 |
| LOAD CURVE ANALYSIS | 5 |
| ENERGY STORAGE POTENTIAL | 6 |
| SUBSTATION ELECTRICAL DEMAND | 11 |
| PETROLEUM | 21 |
| PROPANE | 21 |
| NATURAL GAS | 21 |
| WATER | 25 |
| WEATHER DATA | 30 |
| APPENDIX | 33 |

LIST OF TABLES

| | <u>Page</u> |
|---|-------------|
| NWC TOTAL ENERGY CONSUMPTION - Calendar Year 1977 | 3 |
| NWC TOTAL ENERGY CONSUMPTION - Calendar Year 1978 | 4 |
| ELECTRIC SUBMETER DATA | 14 |
| ELECTRIC SUBMETER DATA | 15 |
| ELECTRIC SUBMETER DATA | 16 |
| ELECTRIC SUBMETER DATA | 17 |
| ELECTRIC SUBMETER DATA | 18 |
| ELECTRIC SUBMETER DATA..... | 19 |
| SUBSTATION ENERGY DEMAND..... | 20 |
| GALLONS FUEL | 22 |
| PROPANE | 23 |
| NATURAL GAS (MCF) | 24 |
| WATER CONSUMPTION | 26 |
| RESERVOIR CAPACITY | 27 |
| WELL CAPACITIES | 28 |
| WATER DISTRICT CAPACITIES | 29 |
| WEATHER SUMMARY CHINA LAKE, CA..... | 31 |
| HEATING/COOLING DEGREE DAYS | 32 |

INTRODUCTION

The achievement of the goal of energy self sufficiency can be furthered through the use of energy storage techniques presently available. To assess the potential for energy storage at U.S. Navy Facilities, the Civil Engineering Laboratory (CEL) at Pt. Hueneme, California has directed TRW Energy Systems to investigate the benefits at a selected naval facility.

After reviewing available data at several facilities, TRW, with CEL concurrence, has selected the Naval Weapons Center at China Lake, California as the study site. NWC personnel have had an active program of energy conservation at their facility and have previously assessed the energy consumption and demand patterns needed for this study of energy storage applications. With the cooperation of NWC personnel, TRW has endeavored to update energy consumption data previously reported by NWC for calendar year 1976* to include data for the years 1977 and 1978. This report supplies a tabulation of that data.

The raw data has been categorized by type of energy for basewide consumption and where data are available, energy demand is shown regionally within the facility. For example, NWC has installed substation metering for electricity at twenty-five locations on the base permitting a breakdown of electrical energy consumption and demand data to localized areas of the base. This permits an assessment of energy flows to a degree not usually possible in an audit of a non-metered facility.

Data are included for all purchased energy used at NWC, supplemented with additional information expected to be of value in the subsequent study of specific energy storage applications at NWC. Furthermore, it is expected that the types of information contained in this report will serve as a sample of information needed should other facilities be evaluated for energy storage applications.

*NWC Technical Memorandum, 3295, November 1977.

TOTAL ENERGY CONSUMPTION

Composite energy use figures for calendar years 1977 and 1978 are shown in the tables on pages 3 and 4. The monthly figures represent a monthly composite as reported in utility bills and/or base consumption figures. These composites for the base are broken down into finer detail in subsequent tables.

From the composite tables, the seasonal peaking in demand is evident. Electricity demand rises sharply in the summer months in response to peak air cooling requirements. Natural gas, fuel oil and propane reflect the demand for facility heating in the cooler months. Gasoline use, primarily for transportation services, exhibits a nearly steady demand through the survey period.

Demand for all energy shows a downward trend over the two year period. Conservation programs at the base are thought to be responsible. Though not shown in the composite tables, it should be noted that energy costs for 1978 were actually higher than those of 1977, in spite of the reduced consumption. Increases in utility rate schedules have been larger than the corresponding reductions in energy use leading to the higher utility bills.

The conversion of the composite totals into Btu's for 1977 indicates that fuel oil supplied a slightly larger proportion of the base energy compared to either electricity or natural gas, the other major energy sources at China Lake. In 1978, oil use was curtailed, with natural gas taking over as the major source of base energy with oil moving into second place.

NWC TOTAL ENERGY CONSUMPTION

Calendar Year 1977

| | Electricity (MWH) | Natural Gas (MCF) | Fuel Oil (GAL) | Propane (GAL) | Gasoline (GAL) |
|-------|----------------------|----------------------|-------------------|------------------|-------------------|
| Jan | 7,884 | 78,625 | 256,020 | 99,563 | 53,238 |
| Feb | 6,660 | 36,044 | 330,676 | 89,431 | 44,232 |
| Mar | 7,632 | 40,617 | 305,629 | 39,842 | 35,592 |
| Apr | 7,200 | 26,527 | 277,568 | 88,839 | 52,352 |
| May | 6,804 | 35,967 | 170,594 | 19,814 | 43,945 |
| Jun | 8,784 | 10,456 | 140,333 | 57,717 | 43,670 |
| Jul | 9,360 | 14,350 | 74,598 | - | 43,515 |
| Aug | 9,252 | 8,207 | 167,522 | - | 42,817 |
| Sep | 8,280 | 14,617 | 126,230 | - | 52,393 |
| Oct | 6,552 | 12,388 | 126,381 | 33,347 | 51,646 |
| Nov | 6,757 | 34,694 | 185,923 | 70,914 | 43,193 |
| Dec | 7,333 | 45,616 | 306,666 | 95,817 | 26,290 |
| Total | 92,498 | 358,108 | 2,468,140 | 595,284 | 532,883 |

NWC TOTAL ENERGY CONSUMPTION

Calendar Year 1978

| | Electricity (MWH) | Natural Gas (MCF) | Fuel Oil (GAL) | Propane (GAL) | Gasoline (GAL) |
|--------------|----------------------|----------------------|-------------------|------------------|-------------------|
| Jan | 6,754 | 51,263 | 202,636 | 78,594 | 52,593 |
| Feb | 6,455 | 33,805 | 217,609 | 84,340 | 35,079 |
| Mar | 7,312 | 33,211 | 152,674 | 62,239 | 43,363 |
| Apr | 6,307 | 28,947 | 189,354 | 39,913 | 43,397 |
| May | 7,463 | 20,969 | 208,309 | 24,606 | 43,646 |
| Jun | 7,949 | 14,028 | 142,427 | 15,860 | 43,377 |
| Jul | 9,050 | 14,183 | 154,839 | 4,448 | 34,257 |
| Aug | 8,647 | 15,833 | 150,057 | 9,996 | 43,521 |
| Sep | 7,661 | 12,526 | 82,404 | 25,336 | 52,155 |
| Oct | 6,898 | 25,629 | 159,157 | 24,906 | 41,802 |
| Nov | 6,653 | 34,837 | 219,463 | 73,774 | 34,940 |
| Dec | 7,549 | 51,386 | 113,503 | 108,346 | 61,126 |
| Total | 88,698 | 336,617 | 1,992,432 | 552,358 | 529,256 |

ELECTRIC DEMAND

Fifteen-minute average electrical demand is recorded by the utility supplying the Naval Weapons Center in order to assess monthly peak demand charges (see rate schedule in the Appendix). On pages 7 to 10, data from the utility demand files have been plotted. The period shown is for the month of October, 1978, the first month in which a recording meter was installed.

LOAD CURVE ANALYSIS

The graphs show a seven day cycle beginning on Monday and ending on Sunday. For the week ending 10/8/78, the first days data are partially missing. This was the first day the recording meter was installed and readings did not begin until around two in the afternoon.

The first five cycles for that week show a recurring pattern typical of weekday energy use at the base. Starting from a low point of approximately 7000 KW, the electrical demand climbs sharply during the morning hours. At the midday lunch break, demand levels out, only to climb to the peak for the day between twelve and three in the afternoon. The combination of peak base activity and the demands of the facility air conditioning equipment during this interval generate this pattern each work day.

In an effort to limit this daily peak, facilities engineers have restricted well water pumping operations to the late afternoon and heavy morning hours. All water for the base is pumped from underground wells and stored for the next days' use. The jump in demand around six P.M. is the result of activation of the well pumps and accounts for a large part of the night time base load.

The last two cycles on the graph of 10/8/78 show the reduced demand of weekend operations at NWC. Peak demand of 10,000 KW or less is typical compared to as much as 16,600 KW during the week.

For the week ending 10/15/78, the first day, Monday October 9 shows a repeat of the weekend pattern. That day was observed as a holiday by base personnel, limiting demand to the weekend levels. The patterns for the four remaining days duplicate the curves of the previous week.

The graphs for the weeks ending 10/22/78 and 10/29/78 exhibit the same cyclical patterns for weekday and weekend with one major change. Nighttime base demand remains at around 7000 KW but daytime peaks are approximately 2000 KW less. During these two weeks, air cooling demand have fallen off in proportion to a drop in daily outside temperatures.


ENERGY STORAGE POTENTIAL

The peaks and valleys exhibited in the daily load curves for electrical demand present a textbook situation for the application of energy storage. The utility rate schedule imposes economic penalties for both energy use and energy demand during "peak" demand periods. For the months of June through November, this period is presently defined as 12:00 Noon to 6:00 P.M. The load curves shows this to be precisely the period of peak demand at the China Lake facility. Energy storage offers one means of shifting demand away from this expensive time of the day. In a subsequent phase of this study, storage applications for NWC will be explored to accomplish a shift in demand away from this critical time periods.


The rescheduling of water well pumping operations is an example of another means of shifting demand away from the peak periods. Rescheduling some base personnel to night shift operations would have an equally significant effect on controlling peak demand. Energy storage has the advantage, however, of not asking people to work during what is traditionally the less attractive working hours of night and graveyard shifts.

While on the subject of load shifting, we note that the present rate schedule adds a further complication. For the winter months (December through May), the "peak" demand period is redefined as the hours between 5:00 P.M. and 10:00 P.M. This necessitates shifting work schedules and equipment usage every six months to avoid the penalty periods. Energy storage, with its greater flexibility in rescheduling, again offers an advantage over attempting to move people and equipment operational hours.


WEEK ENDING 10/08/78



WEEK ENDING 10/15/78




WEEK ENDING 10/22/78



KILOWATT-DEMAND

0 5000 10000 15000 20000

WEEK ENDING 10/29/78



08 10/31/78 11:32 AM TIME 11:32 DATE 03/02/79 0159LW, THN/755 V.1

SUBSTATION ELECTRICAL DEMAND

NWC has installed twenty-five utility meters at substations around the facility. Energy consumption and monthly peak demand is continuously logged in an on-going program of energy use monitoring. The submeter data gives insight into basewide electrical flow to sections of the base.

The readings of the individual substations are expected to be of value in the assessment of energy storage applications. They serve to identify sections of the base that offer the most potential for load leveling in terms of peak demand shifts as well as those sections that may be ignored due to their relatively small demands for electrical energy.

Monthly energy and demand figures for calendar year 1978 have been compiled in the tables on pages 14 through 19. On page 20 is a ranking of the substations for total energy consumption. The substation code names with a brief summary of the loads they represent follows:

ML-W Michelson Laboratory West

- Altitude Chamber
- Solid State Lab
- Computer Research Lab
- Air Conditioning

ML-E Michelson Laboratory East

- Machine Shop
- Heat Treat
- Offices

FH-1, 2, 3 Harvey Field

- General Electric Service
- Street Lighting

NAF Naval Air Facility

Catapult

Boiler Plant

General Service

North

Sewage Treatment Plant

Laboratories

SWPP Salt Wells Sub.

Laboratories

Street Lighting

Office Building

CLPL China Lake Sub.

General Service

Street Lighting

South CKT 1, 2, 3

Housing

Street Lighting

RWTR Randsburg Wash Sub.

Gunline

HQ

G-Main

General Service

ER Electronics Lab.

Thompson Lab

Wind Tunnel

Anechoic Chambers

LASER Lauritsen Lab.

Laboratory

ECHO

Test Range

B-I, 4

General Service

SNORT

General Service

T Tower Road

General Service

VERN

General Service

School

ELECTRIC SUBMETER DATA

| 1978 | ML-W | | NORTH | | T8 | | T6 | |
|------|-----------|------|---------|------|--------|------|--------|-----|
| | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD |
| JAN | 736,000 | 1344 | 258,000 | 720 | 38,720 | 128 | 15,600 | 30 |
| FEB | 889,600 | 2624 | 333,000 | 720 | 39,680 | 128 | 16,800 | 60 |
| MAR | 998,400 | 2752 | 322,000 | 720 | 32,640 | 83.2 | 15,000 | 36 |
| APR | 902,400 | 2816 | 346,000 | 880 | 22,080 | 67.2 | 10,400 | 42 |
| MAY | 1,062,400 | 2880 | 880,000 | 1020 | 23,680 | 76.8 | 10,400 | 42 |
| JUN | 1,030,500 | 2380 | 408,000 | 1060 | 24,000 | 80.0 | 10,200 | 42 |
| JUL | 1,062,400 | 2048 | 480,000 | 1030 | 23,680 | 105 | 11,400 | 60 |
| AUG | 1,212,600 | 2048 | 524,000 | 1100 | 24,000 | 112 | 12,600 | 36 |
| SEP | 1,056,000 | 2048 | 490,000 | 1080 | 24,000 | 76.8 | 13,800 | 36 |
| OCT | 928,000 | 1790 | 358,000 | 1000 | 17,280 | 64.0 | 10,200 | 36 |
| NOV | 876,800 | 1408 | 310,000 | 1200 | 21,760 | 67.2 | 15,600 | 48 |
| DEC | 819,200 | 2688 | 350,000 | 1600 | 41,600 | 118 | 25,200 | 60 |

ELECTRIC SUBMETER DATA

| 1978 | RWTR | | ECHO | | SWPP | | CLPL | | ML-E | |
|------|---------|-----|--------|-----|---------|------|---------|------|-----------|------|
| | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD |
| JAN | 256,000 | * | 52,300 | 24 | 163,200 | 1056 | 268,000 | 1300 | 842,400 | 2304 |
| FEB | 248,000 | 312 | 55,200 | 24 | 369,600 | 1056 | 606,000 | 1300 | 921,200 | 2304 |
| MAR | 159,000 | 456 | 50,500 | 240 | 350,400 | 1056 | 483,000 | 1300 | 964,800 | 2112 |
| APR | 154,000 | 480 | 48,000 | 216 | 321,600 | 960 | 372,000 | 1100 | 949,600 | 2304 |
| MAY | 159,000 | 480 | 52,800 | 240 | 414,000 | 1008 | 377,000 | 1200 | 961,600 | 2304 |
| JUN | 173,000 | 612 | 69,600 | 288 | 369,600 | 1152 | 320,000 | 1000 | 965,600 | 2880 |
| JUL | 195,000 | 612 | 69,600 | 288 | 384,000 | 1152 | 331,000 | 1000 | 1,068,800 | 2816 |
| AUG | 211,000 | 636 | 72,000 | 288 | 465,600 | 1200 | 225,000 | 1500 | 1,240,000 | 2880 |
| SEP | 196,000 | 480 | 88,800 | 288 | 432,000 | 1152 | 186,000 | 1500 | 1,016,000 | 2816 |
| OCT | 132,000 | 450 | 55,200 | 24 | 356,000 | 1056 | 165,000 | 500 | 866,400 | 2304 |
| NOV | 149,000 | 420 | 48,000 | 24 | 326,400 | 1056 | 229,000 | 520 | 905,600 | 2112 |
| DEC | 183,000 | 420 | 69,600 | 288 | 388,800 | 1104 | 334,000 | 700 | 861,600 | 2368 |

*Data missing

ELECTRIC SUBMETER DATA

| 1978 | FH-1 | | FH-2 | | FH-3 | | LASER | |
|------|---------|------|---------|------|-----------|------|---------|-----|
| | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD |
| JAN | 515,000 | 1000 | 585,000 | 1000 | 1,128,000 | 1440 | 115,200 | 240 |
| FEB | 506,000 | 1000 | 569,000 | 1000 | 162,000 | 1440 | 168,000 | 240 |
| MAR | 530,000 | 1000 | 640,000 | 1500 | 1,180,800 | 1536 | 86,400 | 240 |
| APR | 491,000 | 1400 | 576,000 | 1600 | 158,400 | 1680 | 128,600 | 240 |
| MAY | 633,000 | 1700 | 717,000 | 1800 | 804,600 | 1970 | 153,600 | 336 |
| JUN | 749,000 | 1900 | 827,000 | 1800 | 864,000 | 2064 | 149,800 | 384 |
| JUL | 836,000 | 1800 | 902,000 | 1900 | 936,000 | 2160 | 158,400 | 336 |
| AUG | 799,000 | 1800 | 907,000 | 2000 | 936,000 | 2160 | 163,200 | 336 |
| SEP | 692,000 | 1800 | 756,000 | 2000 | 849,000 | 2160 | 115,200 | 336 |
| OCT | 564,000 | 1600 | 645,000 | 1700 | 748,000 | 1872 | 124,800 | 240 |
| NOV | 515,000 | 1200 | 635,000 | 1500 | 691,200 | 1584 | 148,800 | 336 |
| DEC | 530,000 | 1200 | 637,000 | 1200 | 739,200 | 1440 | 206,400 | 240 |

ELECTRIC SUBMETER DATA

| 1978 | T-13 | | VERN | | ER | | NAF | |
|------|--------|-----|-------|-----|---------|-----|---------|------|
| | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD |
| JAN | 17,280 | 211 | 4,900 | 4 | 98,800 | 480 | 434,000 | 1152 |
| FEB | 25,600 | 352 | 6,300 | 3 | 134,400 | 480 | 568,000 | 1152 |
| MAR | 24,320 | 122 | 4,800 | 2 | 134,400 | 416 | 512,000 | 1248 |
| APR | 16,000 | 48 | 3,000 | 2 | 195,200 | 416 | 438,000 | 1248 |
| MAY | 25,280 | 102 | 2,900 | 3 | 172,800 | 512 | 703,000 | 1488 |
| JUN | 24,320 | 160 | 2,100 | 3 | 192,000 | 608 | 637,000 | 1632 |
| JUL | 20,800 | 102 | 2,600 | 3 | 204,400 | 673 | 683,000 | 1632 |
| AUG | 24,640 | 236 | 2,900 | 3 | 151,600 | 640 | 810,000 | 1880 |
| SEP | 20,480 | 128 | 5,500 | 5 | 217,600 | 640 | 730,000 | 1880 |
| OCT | 14,720 | 102 | 600 | - | 147,200 | 512 | 590,000 | 1440 |
| NOV | 15,040 | 189 | 3,100 | 10 | 92,800 | 480 | 535,000 | 1344 |
| DEC | 52,160 | 640 | 8,500 | 5 | 118,400 | 512 | 592,000 | 1296 |

ELECTRIC SUBMETER DATA

| 1978 | SNORT | | B-4 | | B-1 | | G-4 | | G-Main | |
|------|--------|-----|--------|-----|--------|-----|--------|-----|---------|-----|
| | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD | KWH | KWD |
| JAN | 19,600 | 70 | 10,400 | 44 | 28,800 | 132 | 6,000 | 18 | 96,000 | 528 |
| FEB | 28,000 | 70 | 12,000 | 44 | 34,800 | 120 | 3,000 | 18 | 128,000 | 528 |
| MAR | 29,400 | 70 | 12,400 | 48 | 32,400 | 120 | 3,600 | 6 | 140,000 | 528 |
| APR | 33,600 | 70 | 11,600 | 52 | 30,600 | 114 | 4,200 | 6 | 132,000 | 528 |
| MAY | 42,000 | 98 | 14,800 | 60 | 38,400 | 150 | 9,600 | 6 | 185,000 | 528 |
| JUN | 32,200 | 122 | 14,400 | 60 | 42,000 | 162 | 16,200 | 6 | 171,000 | 528 |
| JUL | 36,200 | 168 | 16,000 | 60 | 47,400 | 180 | 18,000 | 6 | 206,000 | 576 |
| AUG | 58,800 | 168 | 16,800 | 60 | 60,600 | 180 | * | * | 233,000 | 624 |
| SEP | 40,600 | 140 | 18,400 | 60 | 49,200 | 192 | 3,000 | * | 215,000 | 576 |
| OCT | 28,000 | 140 | 7,600 | 60 | 37,800 | 150 | 3,000 | * | 145,000 | 528 |
| NOV | 36,400 | 210 | 12,800 | 48 | 33,000 | 144 | 4,200 | 30 | 127,000 | 480 |
| DEC | 26,600 | 168 | 9,200 | 52 | 40,800 | 180 | 11,400 | 18 | 259,000 | 456 |

*Data missing

ELECTRIC SUBMETER DATA

| 1978 | SOUTH CKT. 1 | | SOUTH CKT. 2 | | SOUTH CKT. 3 | |
|------|--------------|------|--------------|-----|--------------|-----|
| | KWH | KWD | KWH | KWD | KWH | KWD |
| JAN | 145,600 | 624 | 36,000 | 24 | 67,200 | 384 |
| FEB | 242,400 | 624 | 40,800 | - | 201,600 | * |
| MAR | 247,200 | 600 | 24,000 | - | 199,200 | 576 |
| APR | 210,200 | 624 | 26,400 | - | 172,800 | 576 |
| MAY | 295,200 | 690 | 31,200 | - | 225,600 | 576 |
| JUN | 271,200 | 745 | 28,800 | - | 211,200 | 624 |
| JUL | 283,200 | 745 | 31,200 | - | 223,200 | 624 |
| AUG | 590,400 | 720 | 36,000 | - | 264,000 | 624 |
| SEP | 336,000 | 720 | 28,800 | - | 223,200 | 624 |
| OCT | 14,400 | 504 | 19,200 | - | 168,000 | 528 |
| NOV | 220,800 | 1056 | 19,200 | - | 148,800 | 576 |
| DEC | 280,800 | 1248 | 14,400 | - | 206,400 | 624 |

*Data missing

SUBSTATION ENERGY DEMAND
1978

| | <u>SUBSTATION</u> | <u>MWH</u> |
|-----|-------------------|------------|
| 1. | ML-W | 11607.3 |
| 2. | ML-E | 11563.6 |
| 3. | FH-3 | 9467.2 |
| 4. | FH-2 | 8396.0 |
| 5. | FH-1 | 7360.0 |
| 6. | NAF | 7232.0 |
| 7. | NORTH | 5059.0 |
| 8. | SWPP | 4341.2 |
| 9. | CLPL | 3896.0 |
| 10. | SOUTH CKT. 1 | 3137.4 |
| 11. | SOUTH CKT. 3 | 2311.2 |
| 12. | RWTR | 2215.0 |
| 13. | G-MAIN | 2037.0 |
| 14. | ER | 1859.6 |
| 15. | LASER | 1718.4 |
| 16. | ECHO | 732.0 |
| 17. | B-1 | 475.8 |
| 18. | SNORT | 411.4 |
| 19. | SOUTH CKT. 2 | 336.0 |
| 20. | T-8 | 333.1 |
| 21. | T-13 | 280.6 |
| 22. | T-6 | 167.2 |
| 23. | B-4 | 156.4 |
| 24. | G-4 | 82.2 |
| 25. | VERN | 47.2 |
| | TOTAL | 88222.8 |

PETROLEUM

A two year summary of petroleum usage at the China Lake Naval Weapons Center appears in the table on page 22.

- Aviation Fuel - The first four columns list the demand for flight-line fueling of aircraft.
- Diesel - Remote sites typically use diesel fuel for electric power generation. Also, some boiler plants at the main facility occasionally substitutes diesel oil for steam generation requirements.
- Premium - Base gasoline requirements for ground transportation and trucking.
- #6 - Fuel oil demands of the base steam plants. Steam generation is required all year for process loads and seasonally for facility heating.

PROPANE

On page 23 is a two year summary of propane usage at various locations at China Lake. Propane is used primarily for facility heating at remote sites.

NATURAL GAS

Natural gas usage at the China Lake boiler plants is shown on page 24.

GALLONS FUEL

| | <u>100/130</u> <u>AV/GAS</u> | <u>115/145</u> <u>AV/GAS</u> | <u>JP-4</u> | <u>JP-5</u> | <u>DIESEL</u> | <u>PREMIUM</u> | <u>#6</u> |
|----------|---------------------------------|---------------------------------|-------------|-------------|---------------|----------------|-----------|
| JAN-1977 | 3500 | 9,037 | 25,596 | 326,033 | 31,062 | 53,238 | 256,020 |
| FEB | 3485 | 18,168 | 50,475 | 390,924 | 15,109 | 44,232 | 330,676 |
| MAR | 3490 | 9,013 | 25,450 | 406,268 | 30,272 | 35,592 | 305,629 |
| APR | 3488 | 9,181 | 33,669 | 292,301 | 14,833 | 52,352 | 277,568 |
| MAY | 3475 | 18,120 | 34,200 | 432,751 | 22,524 | 43,945 | 170,594 |
| JUN | 3475 | 18,098 | 33,728 | 543,611 | 29,812 | 43,670 | 140,333 |
| JUL | 3451 | 8,455 | 42,246 | 365,883 | 15,593 | 43,515 | 74,598 |
| AUG | 6887 | 17,522 | 17,082 | 549,503 | 14,990 | 42,817 | 167,522 |
| SEP | 3451 | 9,037 | 34,206 | 570,074 | 23,414 | 52,393 | 126,230 |
| OCT | 3451 | 9,131 | 33,967 | 295,297 | 48,552 | 51,646 | 126,381 |
| NOV | 6935 | 27,307 | 33,764 | 376,728 | 5,197 | 43,193 | 185,923 |
| DEC | 3483 | 17,806 | 33,881 | 318,906 | 81,757 | 26,290 | 306,666 |
| JAN-1978 | 3493 | 9,000 | 25,600 | 360,938 | 82,356 | 52,593 | 202,636 |
| FEB | 3488 | 27,182 | 41,825 | 404,530 | 75,111 | 35,079 | 217,609 |
| MAR | 6961 | 9,213 | 25,625 | 479,647 | 59,035 | 43,363 | 152,674 |
| APR | 3463 | 9,006 | 8,391 | 421,504 | 51,400 | 43,397 | 189,354 |
| MAY | 3456 | 26,717 | 49,920 | 445,228 | 22,063 | 43,646 | 208,309 |
| JUN | 3476 | 26,562 | 84,452 | 473,182 | 15,157 | 43,377 | 142,427 |
| JUL | 6903 | 9,094 | 41,538 | 423,174 | 22,285 | 34,257 | 154,839 |
| AUG | 3462 | 0 | 33,553 | 347,896 | 14,586 | 43,521 | 150,057 |
| SEP | 3461 | 17,614 | 50,184 | 464,733 | 22,518 | 52,155 | 82,404 |
| OCT | 3456 | 8,704 | 50,017 | 412,806 | 59,403 | 41,802 | 159,157 |
| NOV | 3464 | 0 | 41,468 | 418,587 | 7,170 | 34,940 | 219,463 |
| DEC | 7000 | 0 | 41,843 | 445,358 | 21,969 | 61,126 | 113,503 |

PROPANE

| | BULK | ROB | JERF | MICH LAB | RAND WASH | THOMP LAB | ER | TOTAL |
|----------|--------|--------|--------|----------|-----------|-----------|-------|---------|
| JAN 1977 | 49,893 | 20,138 | 5,199 | - | 9,880 | 4,692 | 9,761 | 99,563 |
| FEB | 49,954 | 9,820 | 10,434 | - | 9,871 | 9,352 | - | 89,431 |
| MAR | 19,864 | 10,143 | 4,607 | - | - | 5,228 | - | 39,842 |
| APR | 44,263 | 9,724 | 5,233 | - | 9,852 | 9,785 | 9,982 | 88,839 |
| MAY | 9,892 | 9,922 | - | - | - | - | - | 19,814 |
| JUN | 38,440 | - | 9,445 | - | - | 4,621 | 5,211 | 57,717 |
| JUL* | | | | | | | | |
| AUG* | | | | | | | | |
| SEP* | | | | | | | | |
| OCT | 16,249 | 3,476 | 5,062 | - | 2,640 | 3,800 | 1,800 | 33,347 |
| NOV | 36,481 | 11,167 | 6,863 | - | 3,920 | 8,283 | 4,200 | 70,914 |
| DEC | 47,977 | 15,861 | 7,253 | - | 12,512 | 6,814 | 5,400 | 95,817 |
| JAN 1978 | 45,083 | 14,007 | 6,299 | - | 4,180 | 5,622 | 3,403 | 78,594 |
| FEB | 46,637 | 14,020 | 3,521 | - | 8,766 | 8,596 | 2,800 | 84,340 |
| MAR | 32,178 | 9,230 | 5,562 | - | 6,282 | 6,087 | 2,900 | 62,239 |
| APR | 18,446 | 8,368 | 3,250 | - | 2,780 | 4,500 | 2,569 | 39,913 |
| MAY | 3,350 | 3,476 | 5,700 | - | 3,980 | 7,200 | 900 | 34,606 |
| JUN | 4,888 | 2,212 | 3,200 | - | 1,760 | 1,800 | 2,000 | 15,860 |
| JUL | 553 | 199 | 536 | 800 | 1,760 | - | 600 | 4,448 |
| AUG | 5,432 | 1,264 | 800 | - | 2,200 | - | 300 | 9,996 |
| SEPT | 15,748 | 948 | 3,400 | 400 | 2,640 | 1,600 | 600 | 25,336 |
| OCT | 13,680 | 2,528 | 3,419 | - | 2,200 | 2,900 | 179 | 24,906 |
| NOV | 46,084 | 12,640 | 6,100 | - | 4,450 | 1,500 | 3,000 | 73,774 |
| DEC | 61,707 | 19,169 | 9,200 | 600 | 4,770 | 8,400 | 4,500 | 108,346 |

*Data missing

NATURAL GAS (MCF)

| | <u>BP-1</u> | <u>BP-2</u> | <u>BP-4</u> | <u>CLPL PILOT PLT.</u> | <u>FH</u> |
|-------------|-------------|-------------|-------------|----------------------------|-----------|
| <u>1977</u> | | | | | |
| SEP | 3,822 | 0 | 2869.5 | 340.7 | 7,585 |
| AUG | 2,201 | 0 | 3.0 | 331 | 5,672 |
| JUL | 66 | 7,073 | 1589 | 297 | 5,325 |
| JUN | 0 | 2,642 | 673 | 316 | 6,825 |
| MAY | 0 | 12,105 | 3257 | 776 | 19,829 |
| APR | 2,705 | 2,697 | 1858 | 674 | 18,593 |
| MAR | 0 | 0 | 0 | 1544 | 39,073 |
| FEB | 823 | 415 | 389 | 1135 | 33,282 |
| JAN | 11,616 | 6,859 | 5808 | 1948 | 52,394 |
| OCT | 8,766 | 0 | 1421 | 547 | 11,654 |
| NOV | 5,525 | 41 | 1741 | 1297 | 26,090 |
| DEC | Missing | Missing | Missing | 1419 | 33,089 |
| <u>1978</u> | | | | | |
| JAN | 879 | 6,930 | 5465 | 1576 | 36,413 |
| FEB | 548 | 0 | 2098 | 1380 | 29,779 |
| MAR | 126 | 6,410 | 1748 | 1141 | 23,786 |
| APR | 0 | 6,983 | 1694 | 940 | 19,330 |
| MAY | 583 | 7,351 | 1482 | 545 | 11,003 |
| JUN | 4,752 | 0 | 1198 | 297 | 7,781 |
| JUL | 5,328 | 0 | 1279 | 314 | 7,262 |
| AUG | 6,970 | 0 | 1530 | 361 | 6,972 |
| SEP | 2,288 | 0 | 1526 | 326 | 8,386 |
| OCT | 6,029 | 5,722 | 1805 | 522 | 11,551 |
| NOV | 192 | 3,063 | 2006 | 1401 | 28,175 |
| DEC | 328 | 2,363 | 2427 | 2223 | 44,045 |

WATER

The water demands at China Lake are met entirely from ground based wells. Pumping loads represent a considerable electrical demand as previously noted. The next four tables give data on recent consumption figures, reservoir capacities, well capacities and water distribution capacities.

Nighttime pumping and storage for the next days' use has already been described as a means of shifting energy demand. In this study, the potential for water storage as a means of energy storage will be explored. Several storage tanks are located at elevated locations and may offer an opportunity for electric power generation as the water is released to satisfy daytime demands. Pumped hydro storage has proven to be an effective means of load leveling for utilities and may be of value at the China Lake facility.

WATER CONSUMPTION

| DATE | <u>HARVEY FIELD</u> | | <u>INTERMEDIATE</u> | |
|-------|---------------------|-------------|---------------------|-------------|
| | HOURS | GALLONS | HOURS | GALLONS |
| 7/77 | 1068 | 102,158,000 | 1274 | 136,875,000 |
| 8/77 | 1526 | 129,587,000 | 1613 | 170,517,000 |
| 9/77 | 1189 | 94,947,000 | 1284 | 129,730,000 |
| 10/77 | 1164 | 93,426,000 | 918 | 80,335,000 |
| 11/77 | 0 | 0 | 843 | 90,015,000 |
| 12/77 | 0 | 0 | 714 | 73,338,000 |
| 1/78 | 0 | 0 | 523 | 51,257,000 |
| 2/78 | 0 | 0 | 570 | 53,603,000 |
| 3/78 | 0 | 0 | 637 | 58,884,000 |
| 4/78 | 0 | 0 | 853 | 86,066,000 |
| 5/78 | 0 | 0 | 1281 | 130,217,000 |
| 6/78 | 1382 | 119,394,000 | 1328 | 140,286,000 |
| 7/78 | 1425 | 132,267,000 | 963 | 110,359,000 |
| 8/78 | 1710 | 152,328,000 | 1095 | 121,973,000 |
| 9/78 | 701 | 53,051,000 | 912 | 101,359,000 |
| 10/78 | 859 | 66,668,000 | 707 | 77,935,000 |
| 11/78 | 587 | 42,950,000 | 574 | 61,737,000 |

RESERVOIR CAPACITY

| <u>LOCATION</u> | <u>ELEVATION (FT)</u> | <u>NUMBER</u> | <u>UNIT CAPACITY (GALLONS)</u> |
|--------------------------------|-----------------------|---------------|--------------------------------|
| 1. Aqueduct (not connected) | -- | 3 | 50,000 |
| 2. Harvey Field | 2413 | 1 | 1,500,000 |
| 3. Intermediate Station | 2324 | 2 | 1,500,000 |
| 4. F-H Station | 2255 | 2 | 1,500,000 |
| 5. E System (NAF) | -- | 1 | 1,500,000 |
| 6. Booster Station #1 (B-Mtn.) | 2376 | 1 | 100,000 |
| | | 1 | 2,000,000 |
| | | 1 | 1,500,000 |
| 7. Booster Station #2 (PL Res) | 2848 | 1 | 1,500,000 |
| | | 1 | 50,000 |
| 8. CLPL Booster Station | 2325 | 2 | 50,000 |
| 9. CT Booster Station | 2224 | 1 | 50,000 |
| 10. Sky Top | -- | 1 | 5,000 |
| | | 2 | 30,000 |

WELL CAPACITIES

HARVEY FIELD

| | |
|------|----------|
| #15 | 1850 gpm |
| #12A | 1200 gpm |
| #16A | 1450 gpm |
| #27 | 2250 gpm |

INTERMEDIATE

| | |
|------|----------|
| #18B | 2400 gpm |
| #28 | 1300 gpm |
| #29 | 1600 gpm |

TOTAL 12,050 gpm = 12.6 MGD

WATER DISTRIBUTION CAPACITIES

| LINE SIZE | WATER DISTRIBUTION CAPACITIES | | | EQUALIZING RESERVOIR DISTRIBUTION | | |
|------------|-------------------------------|-----------------------|---------------------------------------|-----------------------------------|----------|--|
| | HARVEY FIELD TO INTERMEDIATE | INTERMEDIATE TO FH | INTERMEDIATE AND FH PUMP TO FH SYSTEM | TO | FROM | |
| 8" and 16" | 5100 gpm | 2700 gpm | | | | |
| | | 2250 gpm | 2250 gpm | | | |
| | | 4280 gpm | | | | |
| | | 8300 gpm | | | | |
| | | | 8000 gpm | | | |
| | | | | 700 gpm | 400 gpm | |
| | | | | 5000 gpm | 3600 gpm | |
| | | | | 5700 gpm | 4000 gpm | |
| | | 5100 gpm (7.3 MGD) | 8300 gpm to Reservoir | 10,250 gpm (14.7 MGD) | | |
| | | | 2250 gpm to FH system (3.2 MGD) | | | |
| | | | 1000 gpm | | | |

Well #19

[EMERGENCY USE ONLY]
[DIRECT TO SYSTEM]

WEATHER DATA

Composite figures for weather at China Lake are tabulated on page 31.
A summary of heating and cooling degree days appears on page 32.

WEATHER SUMMARY CHINA LAKE, CA.

| TEMPERATURES | 1977 | | | | | | 1978 | | | | | |
|--------------------------|-------|-------|------|------|------|-----|------|------|------|------|------|------|
| | JUL | AUG | SEP | OCT | NOV | DEC | JAN | FEB | MAR | APR | MAY | JUN |
| Avg. High (°F) | 104.7 | 100.9 | 92.5 | 84.8 | 71.2 | M | 56.3 | 63.5 | 71.5 | 74.0 | 87.0 | 96.7 |
| Norm (°F) | 102.3 | 100.5 | 94.0 | 81.9 | 68.0 | I | 57.8 | 63.8 | 70.4 | 76.8 | 86.2 | 95.5 |
| Avg. Low (°F) | 68.7 | 69.1 | 60.5 | 47.9 | 35.2 | S | 35.9 | 37.9 | 45.0 | 46.9 | 53.7 | 64.0 |
| Norm (°F) | 70.0 | 67.7 | 60.3 | 48.8 | 37.0 | S | 28.7 | 34.2 | 38.3 | 46.6 | 55.2 | 63.1 |
| Mean (°F) | 86.6 | 85.1 | 76.5 | 66.3 | 53.2 | I | 46.2 | 50.7 | 58.2 | 60.4 | 70.2 | 80.4 |
| Norm (°F) | 86.2 | 84.1 | 77.2 | 65.4 | 52.4 | N | 43.1 | 49.0 | 54.2 | 61.9 | 70.7 | 79.4 |
| | | | | | | G | | | | | | |
| Highest (°F) | 112 | 113 | 105 | 93 | 83 | | 66 | 74 | 88 | 89 | 100 | 106 |
| Lowest (°F) | 60 | 59 | 49 | 36 | 23 | | 26 | 30 | 37 | 35 | 40 | 55 |
| <u>RELATIVE HUMIDITY</u> | | | | | | | | | | | | |
| Mean (%) | 20 | 29 | 24 | 28 | 35 | | 67 | 59 | 56 | 39 | 30 | 28 |
| Norm (%) | 23 | 24 | 27 | 32 | 42 | | 51 | 47 | 39 | 34 | 30 | 24 |
| <u>WINDS</u> | | | | | | | | | | | | |
| Prevailing: | | | | | | | | | | | | |
| Direction | S | SSW | SSW | SSW | Var. | | SSW | SSW | SSW | SSW | SSW | SW |
| Norm | SW | SSW | SSW | SW | SSW | | SW | SW | SW | SW | SW | SW |
| Speed (MPH) | 8 | 6 | 7 | 4 | 5 | | 4 | 6 | 6 | 9 | 7 | 9 |
| Norm | 8.5 | 8.3 | 7 | 6.6 | 5.4 | | 5.4 | 6.7 | 9.1 | 9.5 | 9.6 | 8.8 |
| <u>PEAK GUST</u> | | | | | | | | | | | | |
| Direction | WNW | S | WSW | E | SW | | WSW | WSW | SSE | WSW | W | W |
| Speed (MPH) | 36 | 48 | 43 | 48 | 46 | | 44 | 43 | 39 | 46 | 53 | 44 |

HEATING/COOLING DEGREE DAYS
MONTHLY SUMMARY
CHINA LAKE, CALIFORNIA

| | | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
|------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 1976 | HEATING | 662 | 421 | 338 | 187 | 2 | 0 | 0 | 0 | 0 | 52 | 280 | 673 |
| | COOLING | 0 | 0 | 0 | 0 | 69 | 171 | 380 | 175 | 74 | 1 | 0 | 0 |
| 1977 | HEATING | 646 | 355 | 451 | 53 | 138 | 0 | 0 | 0 | 0 | 38 | 345 | 494 |
| | COOLING | 0 | 0 | 0 | 0 | 10 | 252 | 361 | 318 | 103 | 3 | 0 | 0 |
| 1978 | HEATING | 583 | 396 | 217 | 161 | 22 | 0 | 0 | 0 | 13 | 47 | 488 | 813 |
| | COOLING | 0 | 0 | 0 | 0 | 16 | 166 | 301 | 288 | 53 | 11 | 0 | 0 |

Cooling degree days per day = mean daily temperature minus 75°F

Cooling degree days per month = cumulative values of degree days per day

Heating degree days per day = 65°F minus mean observed temperature

Heating degree days per month = cumulative values of degree days per day

APPENDIX

Southern California Edison
Electric Rate Schedule No. TOU-8

Schedule No. TOU-8

GENERAL SERVICE — LARGE

APPLICABILITY

Applicable to three-phase general service, including lighting and power, supplied directly from lines of transmission voltage, or where for the Company's operating convenience service is supplied from lines of distribution voltage.

This schedule is applicable for all customers of record on August 23, 1977, served on Schedule No. A-8 and thereafter is applicable to all customers whose monthly maximum demand exceeds 5,000 kW for any three months during the preceding 12 months. Any customer whose monthly maximum demand has fallen below 4,500 kW for 12 consecutive months may elect to take service on any other applicable schedule.

TERRITORY

Within the entire territory served, excluding Santa Catalina Island.

RATES

| | Per Meter Per Month |
|--|------------------------|
| Customer Charge..... | \$800.00 |
| Demand Charge (to be added to Customer Charge): | |
| All kW of on-peak billing demand, per kW..... | \$ 2.10 |
| Plus all kW of mid-peak billing demand, per kW..... | 0.25 |
| Plus all kW of off-peak billing demand, per kW..... | No Charge |
| Energy Charge (to be added to Demand Charge): | |
| All on-peak kWh, per kWh..... | 1.408¢ |
| Plus all mid-peak kWh, per kWh..... | 1.258¢ |
| Plus all off-peak kWh, per kWh..... | 1.108¢ |

Minimum Charge:

The monthly minimum charge shall be the sum of the monthly Customer and Demand Charges. The monthly Demand Charge shall be not less than the charge for 25% of the maximum on-peak demand established during the preceding 11 months.

Daily time periods will be based on Pacific Standard Time and are defined as follows:

- On-peak: 12:00 noon to 6:00 p.m. summer weekdays except holidays
5:00 p.m. to 10:00 p.m. winter weekdays except holidays
- Mid-peak: 8:00 a.m. to 12:00 noon and 6:00 p.m. to 10:00 p.m. summer weekdays except holidays
8:00 a.m. to 5:00 p.m. winter weekdays except holidays
- Off-peak: All other hours.

Off-peak holidays are New Year's Day, Washington's Birthday, Memorial Day, Independence Day, Labor Day, Veterans Day, Thanksgiving Day, and Christmas.

For initial implementation of this schedule by the Company, winter shall consist of the billing periods for the six regularly scheduled monthly billings beginning with the first regularly scheduled billing ending after November 14, 1977. Thereafter, regularly scheduled monthly billings shall include six summer billing periods followed by six winter billing periods. In no event will winter include scheduled billing periods ending after May 31 of any year.

(Continued)

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 446-E

Edward A. Myers, Jr.
Name

Date Filed September 14, 1977

Decision No. 87744

Vice President
Title

Effective October 14, 1977

Resolution No.