

UNCLASSIFIED

Defense Technical Information Center
Compilation Part Notice

ADP011247

TITLE: Tightly Bending Loss Measurement for 1.3 Micrometers and 1.55 Micrometers Broadband Wavelength Division Multiplexing Fiber Sensor Systems

DISTRIBUTION: Approved for public release, distribution unlimited

This paper is part of the following report:

TITLE: Optical Sensing, Imaging and Manipulation for Biological and Biomedical Applications Held in Taipei, Taiwan on 26-27 July 2000. Proceedings

To order the complete compilation report, use: ADA398019

The component part is provided here to allow users access to individually authored sections of proceedings, annals, symposia, etc. However, the component should be considered within the context of the overall compilation report and not as a stand-alone technical report.

The following component part numbers comprise the compilation report:

ADP011212 thru ADP011255

UNCLASSIFIED

Tightly Bending Loss Measurement for 1.3 μm and 1.55 μm Broadband Wavelength Division Multiplexing Fiber Sensor Systems

Shyh-Lin Tsao* and Wen-Ming Cheng
Department of Electrical Engineering
Yuan Ze University
Chung-Li, Taiwan, R. O. C.

ABSTRACT

A tightly bending loss technique is developed for application in biomedical WDM fiber sensors. In this paper, we present the measurement and comparison of bending sensor in 1.3 μm and 1.55 μm wavelength region, respectively. A two - wavelength measurement setup is built for bending loss testing. Various wrapping method and turns are invested for studying the bending loss for broadband biomedical sensing system. We found that as the bending loss increases, the oblique angle of wrapping become large. These research results is helpful for multi-channel multi-array fiber optic biomedical sensor systems.

Keywords : Biomedical sensor, Fiber Sensor, Bending Loss, Wavelength Division Multiplexing

1. INTRODUCTION

Biomedical fiber-optical sensors attract a lot of attentions in last ten years¹⁻². Bending fiber-optic sensors are simple and cost effective. The fiber-optic bending sensors can be applied to measure many physical quantities, such as voltage, strain, temperature, pressure, etc³⁻¹¹. With the wavelength division multiplexing techniques intensively grew up¹², multichannel high-speed WDM distributed fiber-optic bending sensor become an important issue¹³⁻¹⁴. Such WDM fiber bending sensors can be applied in biomedical sensor systems.

In this paper, the bending fiber sensor we developed are using the Walsin- Fujikura single mode fiber (Spec No. : NWF-98F101, SM.10 / 125.04.UV)¹⁵ which is commonly used in Taiwan. Three wrapping schemes: normal wrapping, overlap

*Correspondence : E-mail : jimmy@saturn.yzu.edu.tw, Telephone : 886-3-4638800-424, Fax : 886-3-4639355

wrapping and cross wrapping are considered. The tightly bending losses are measured with the three wrapping schemes with bending radius 1 mm to 25 mm. The bending losses are different in 1.3 μm and 1.5 μm with various wrapping schemes and bending radii. We also analyze the bending loss with various wrapping turns. In broadband WDM fiber biomedical bending sensor system, it is important to determinate the wavelength responses in different wavelength channels. The experimental results can be used for clarifying the relationship between the maximum number of bending loss sensor and the operation wavelength band.

Owing to bending and unsuitable wrapping structure will induce tension in process of the fiber manufacture and construction, the optical transmission signal will experience the extra radiation losses and be attenuated. Although several bending loss measurement standard have been developed^{16,17}, only a few papers discuss about wrapping in various structure, turns and wavelength have been reported¹⁸⁻¹⁹. This work is important for future achieving wide-band WDM biomedical fiber sensors systems, including manufacturing, constructing and cabling process. In the following, we will concentrate on bending loss mechanism, and the bending loss characteristics in various wavelength windows. The following sections show the experimental setup and results.

2. DESCRIPTION OF EXPERIMENTAL ARRANGEMENT

The schematic diagram of the experimental apparatus consist of two laser sources operating at 1.3 μm and 1.55 μm wavelength, the fiber is wrapped around a mandrel with various diameters R, the end is a power meter for reading the power losses, as shown in Fig .1. The schematic diagram of the wrapping style is considered three schemes: normal wrapping, cross wrapping and overlap wrapping as shown in Fig .2.

3. EXPERIMENTAL RESULTS

3.1 The relation of bending losses v. s. bending radius

Some Walsin-Fujikura single mode fibers (SM.10 /12504UV) are used for the following experiments. Their mode field diameter is $9.3 \pm 0.5 \mu\text{m}$ at 1310 nm, cladding diameter is $125 \pm 1.0 \mu\text{m}$ and outer coating diameter is $245 \pm 10 \mu\text{m}$. Their typical refractive index difference value is 0.36 % , and intrinsic attenuation value is 0.35 dB / km at 1.3 μm wavelength and 0.22 dB / km at 1.55 μm wavelength. The bending losses versus the bending radii are shown in Fig .3. The bending losses with radii from 1mm to 10 mm are measured at 1.3 μm and 1.55 μm wavelength windows. The bending losses are larger at 1.55 μm than at 1.3 μm wavelength. When the fiber is bent smaller than radius of 10 mm, the bending loss will increase from 0 dB to 70 dB rapidly at 1.55 μm and bending loss will increase from 0.5 dB to 2.5 dB at 1.3 μm . Obviously, the smaller bending radius will induce the bigger bending loss. Especially, the bending loss is obviously become higher with radius $R < 3 \text{ mm}$ at 1.55 μm .

3.2 The relation of bending loss v. s. wrapping scheme

The fiber is wrapped around a mandrel of 25 mm diameter in this subsection. The power losses versus 1 to 20 turns with three wrapping schemes: normal, overlap and cross wrapping at 1.3 μm are shown in Fig .4. Obviously, the bending loss is a function of loop turns with various wrapping. The bending loss belongs to the cross wrapping comparing with the overlap wrapping and the normal wrapping schemes show large variation with respect to wrapping turns. Therefore, how the fiber was wrapped is important for fiber bending sensor design. The most sensitive scheme is cross wrapping bending fiber sensor. The same phenomenon happen at 1.55 μm wavelength, but losses is much higher. As shown in Fig .5, we find that the bending loss sensitivity of the wrapping scheme at 1.55 μm wavelength is higher than at 1.3 μm wavelength, so the sensitive wavelength band is 1.55 μm for WDM optical bending fiber biomedical sensor system.

3.3 The relation of bending loss v.s. wrapping oblique angle

The fiber was wrapped with oblique angle θ from 0° to 60° experimentally . As shown in Fig .6 and Fig .7, the bending loss is a function of oblique angle, the fitting bending loss functions can be written as :

$$L_{1.3\mu\text{m}}(\theta) = 0.0064 \theta^2 - 0.2144 \theta + 0.6467 , \quad (1)$$

$$L_{1.55\mu\text{m}}(\theta) = 0.0218 \theta^2 - 0.4354 \theta + 1.1514 , \quad (2)$$

For comparison, the experimental and theoretical curves shown in Fig .6 and Fig .7 show the difference between the 1.3 μm and 1.55 μm . The bigger the wrapping oblique angle, the bigger the losses in both wavelength. The bending losses are still greater at 1.55 μm than at 1.3 μm wavelength. Especially, the laser operating at 1.55 μm wavelength for WDM optical fiber biomedical sensor system show promising sensitivity with respect to the oblique angle. The oblique angle of wrapping is demonstrate as an important parameter for WDM optical bending fiber biomedical sensor system in the first time.

3.4 The relation of bending loss v. s. wrapping interval

The fiber was wrapped 5 turns with interval from 1 mm to 5 mm. In Fig .8 and Fig .9, the bending loss is a function of wrapping interval, the fitting functions can be represented as:

$$L_{1.3\mu\text{m}}(D) = - 0.0046D^2 - 0.219D + 0.3907 , \quad (3)$$

$$L_{1.55\mu\text{m}}(D) = - 0.0568D^2 - 0.1766D + 7.2921 , \quad (4)$$

Comparing the experimental and theoretical curves shown in Fig.8 and Fig.9, the theoretical fitting curve is well matched the experimental data. The bigger the wrapping interval, the smaller the losses we found. The bending loss sensitivity of wrapping interval at 1.55 μm wavelength is still higher at 1.55 μm than at 1.3 μm wavelength. So the better light source is 1.55 μm wavelength for WDM optical fiber sensor system. The interval of wrapping is also an important parameter considered for WDM fiber biomedical sensor network.

4.CONCLUSION

In summary, before achieving a broadband WDM fiber-optical bending biomedical sensor networks, we measured the

bending losses in 1.3 μm and 1.5 μm band with various bending radius, wrapping schemes, and turns. Based on those experimental results, we built up some simple theoretical models for describing the design rules. In the future, the models can be applied to develop a WDM fiber biomedical sensor system as shown in Fig.10. This work is very helpful for future broadband WDM fiber biomedical sensor network. Because the transceiver in 1.3 μm and 1.55 μm band are cost effective for applying in fiber communication systems, we believe using 1.3 μm and 1.55 μm light for broadband WDM distribution fiber biomedical sensor systems is possible in the future.

5.ACKNOWLEDGE

This work was supported in part by the communication business unit of the Walsin - Lihwa Corporation. The authors would like to thank Technology Director Ping-Ching Lin of Walsin-Lihwa Corporation for valuable experimental components and equipment supports.

REFERENCE

1. J. J. Magera and B. P. McCann, "Slica-cove fibers for medical diagnosis and therapy", *proc. Of optical Fibers in Medicine VII*, 1649, pp. 2-7, 1992.
2. L. A. Tempelman, J. P. Golden, G. P. Anderson, F. S. Ligler, "Use of cyanine dyes with evanescent wave fiber optic biomedical applications", *Droc. of Chemical, Biomedical, and Environmental Fiber SensorsVI*, 2293, pp.139,148.
3. P. Dinev," Fiber – optic voltage sensor using an optical lever ", *IEE proceedings Optoelectronics* , **144** , pp. 253 – 255, 1997.
4. A. Todoroki, T. Hotanaka, H. Kobavashi, H. Nakamura, Y. Shimamura, " Strain measurement by curved optical fiber sensor ", *Transactions of the Japan Society of Mechanical Engineers, Part C*, **62**, pp. 3710 – 3714, 1997.
5. A. Golbazi, " Prebiased microbending optical sensor ", *proceeding of SPIE*, **2839**, pp.426 – 433, 1996.
6. C. K Asawa, S. K. Yao, R. C. Streans, N. L. Mota, and J. W. Downs, " High sensitivity strain sensor for measuring structural distortion " , *Electron Lett.*, **18**, pp. 362-364, 1982.
7. J. W. Berthold, " Historical review of fiber-optic sensors " , *J. Lightwave Technol.*, **13**, pp. 1193-1199, 1995.
8. S. Tomita, H. Tachino, and N. Kasahara, " Water sensor with optical fibre ", *J. Lightwave Technol.*, **8**, pp. 1892-1832, 1990.
9. T. Yoshino, M. Nara, and K. Kurosawa, "Remote and multi-point fiber sensors using optical time domain reflectometry " *Proceedings of 13th congress of the International Commission for Optics, Sapporo*, pp. 324 – 325, 1984.
10. D. Varshneya, W. L. Ghering, and J. W. Berthold, " High-temperature fibre-optic microbend sensor". *Proceedings of 3rd Optical fiber sensors conference, San Diego*, pp.140, 1985.
11. J. N. Fields, and J. H. Cole, " Fiber microbend acoustic sensor ". *Appl. Opt.*, **19**, pp. 3236 – 3267, 1980.
12. C. D. Chen, I. Kim, D. Mizura, T. V. Nguyen, K. Ogawa, R. E. Tench, L. D. Tzeng, P. D. Yeates, " 1.2 Tbit /s (30ch \times

- 40Gbit/s) WDM transmission over 85 Km fiber “, *Electronic Letters*, **34**, pp.1002 – 1004,1998.
13. T.E. Clark et al., ” Overview of multiplexing techniques for all-fiber interferometric sensor arrays ”. *Proc. SPIE-Int. Soc. Opt. Eng.* **718**, pp. 80 – 91, 1986.
 14. E. Udd and J. P. Theriault , “ Fiber-optic microbending sensors sensitive over different bands of wavelength of light.” *U.S. Pat.* **5, 118, 931**, 1992.
 15. Walsin - Fujikura single mode optical fiber (SM.10 / 125.04UV) SPECIFICATION, Spec. No. : NWF – 98 F 101, Issue Date : Feb.25,1998.
 16. P. D. Lazay, A. D. Person, ” Developments in single-mode fiber design, materials, and performance at Bell Laboratories “ . *IEEE Trans. MTT-30*, pp. 350-356, 1982.
 17. A. O Garg, C. K. Eoll, ” Experimental characterization of bend and microbend losses in single-mode finer fibers ”. *Wire & Cable Sympos . Proceed 1986*, P.P. 406-414, 1986.
 18. T. Yoshino, K. Inoue, Y. Kobayashi, “ Spiral fibre microbend sensors “, *IEE Proc.-Optoelectron.*, **144**, 1997.
 19. T. Yoshino, K. Inoue, Y. Kobayshi, and Y. Takahashi, “Spring coil fiber microbend sensor with well – defined characteristics ” , *Proceedings of 11th Optical fiber sensors conference, Sapporo*, pp. 264 – 267 , 1996 .




Fig .1 : The schematic diagram of the experimental setup




Fig .2 : The schematic diagram of various wrapping structure




Fig . 3 : The bending loss v.s. bending radii




Fig . 4 : The bending loss v.s. wrapping turns at 1312 nm




Fig . 5 : The bending loss v.s. wrapping turns at 1544nm




Fig . 6 : The bending loss v.s. oblique angle of wrapping at 1.3 μm wavelength




Fig. 7 The bending loss v. s oblique angle of wrapping at 1.55 μm wavelength




Fig. 8: The bending loss v.s. wrapping interval at 1.3 μm wavelength




Fig .9 : The bending loss v.s. wrapping interval at 1.55 μm wavelength




Fig.10 : Schematic diagram of a WDM bending sensor