

AD-A071 172







NATIONAL BUREAU OF STANDARDS WASHINGTON DC NATIONAL M--ETC F/G 18/4
STANDARD PROCEDURE FOR USE OF THERMOLUMINESCENCE DOSIMETRY IN R--ETC(U)
MAR 79 J C HUMPHREYS, S E CHAPPELL

UNCLASSIFIED

NBSIR-79-1723

NL


1 OF 1
AD
A071172



END
DATE
FILMED

8--79

DDC



MICROCOPY RESOLUTION TEST CHART
NATIONAL BUREAU OF STANDARDS-1963-A

AD A 071 172

NBSIR 79-1723

LEVEL

②

Standard Procedure for Use of Thermoluminescence Dosimetry in Radiation-Hardness Testing of Electronic Devices

J. C. Humphreys and S. E. Chappell

Center for Radiation Research
National Measurement Laboratory
National Bureau of Standards
Washington, D.C. 20234

DDC
RECEIVED
13 1979
RECEIVED
C

March 1979

Interim Report

This document has been approved
for public release and sale; its
distribution is unlimited.

Prepared for
Defense Nuclear Agency
Washington, D.C. 20305
Sponsored under: Subtask Z99QAXTD072, work unit 09

DDC FILE COPY

79 07 13 022

NBSIR 79-1723

**STANDARD PROCEDURE FOR USE OF
THERMOLUMINESCENCE DOSIMETRY
IN RADIATION-HARDNESS TESTING OF
ELECTRONIC DEVICES**


J. C. Humphreys and S. E. Chappell

Center for Radiation Research
National Measurement Laboratory
National Bureau of Standards
Washington, D.C. 20234

March 1979

Interim Report

This document has been approved
for public release and sale; its
distribution is unlimited.



Prepared for
Defense Nuclear Agency
Washington, D.C. 20305
Sponsored under: Subtask Z99QAXTD072, work unit 09



U.S. DEPARTMENT OF COMMERCE, Juanita M. Kreps, Secretary

Jordan J. Baruch, Assistant Secretary for Science and Technology

NATIONAL BUREAU OF STANDARDS, Ernest Ambler, Director

79 07 13 022

TABLE OF CONTENTS

	Page
Introduction-----	1
Acknowledgments-----	2
Standard Recommended Practice for The Application of Thermoluminescence-Dosimetry (TLD) Systems for Determining Absorbed Dose in Radiation-Hardness Testing of Electronic Devices-----	3
1. Scope-----	3
2. Significance-----	3
3. Applicable documents-----	4
4. Definitions-----	5
5. Apparatus-----	7
6. Handling and readout procedures-----	8
7. Summary of requirements for performance testing of TLD system-----	10
8. Specific performance tests and correction factors-----	12
9. Calibration of the TLD system-----	23
10. Procedures for characterizing and monitoring a test radiation field with TLD systems-----	28
11. Report of results-----	34
References-----	35
Appendixes-----	38
A1. Recommended Procedures for Application of CaF ₂ :Mn Chips--	38
A2. Energy Absorption Coefficients and Collision Stopping Powers-----	45
A3. Determination of Electron Equilibrium Thickness-----	49
A4. Determination of Test Sample Size-----	52
Bibliography-----	55

Accession For	
NTIS GRA&I	☒
DDC TAB	☐
Unannounced	☐
Justification	
By _____	
Distribution/ _____	
Availability Codes	
Dist	Avail and/or special
A	

STANDARD PROCEDURE FOR USE OF THERMOLUMINESCENCE DOSIMETRY
IN RADIATION-HARDNESS TESTING OF ELECTRONIC DEVICES

J.C. Humphreys and S.E. Chappell
Radiation Physics Division
Center for Radiation Research
National Bureau of Standards
Washington, D.C. 20234

1. INTRODUCTION

Electronic systems of many types are employed in the nation's tactical and strategic weapons systems as well as in deep-space probes. These systems must be able to function reliably in the radiation environments they are expected to encounter in carrying out their missions. There has been a lack of consistency in the experimental results of radiation dosimetry measurements made at the various facilities that are testing the radiation hardness of these electronic systems. It became apparent that there was a need for improvement in the dosimetry procedures employed by the hardness-testing facilities. Since thermoluminescence dosimetry (TLD) systems are widely used by the hardness-testing facilities, it was clear that a standard TLD procedure would improve the reliability, reproducibility, and uniformity of dosimetry measurements at these facilities. To this end, a standard recommended practice was developed for the use of TLDs in measuring absorbed dose in a medium as a result of photon or electron irradiation. This recommended practice is in the form of an American Society for Testing and Materials (ASTM) standard. The latest draft of this standard is contained in this report.

It should be noted that this draft standard has not received final approval from ASTM (although approval is expected within the next few months); therefore, it should not be cited as a reference or published in another form without the expressed approval of the E10 Committee Chairman or the Managing Director of ASTM. When the standard has been approved and published by ASTM, it may be obtained from that organization and referenced.

This report includes a selected bibliography of TLD characteristics. This listing is not represented as being comprehensive, but is intended as a guide for those workers getting started in the field of thermoluminescence dosimetry.

The reference citations in the body of the draft standard are for the references listed within that standard (pp. 35 and 36) and are not to be confused with the bibliography.

ACKNOWLEDGMENTS

The authors wish to express their grateful appreciation to Gail de Planque and Margarete Ehrlich for their many helpful suggestions on the contents of the TLD standard and the bibliography.

Standard Recommended Practice for

THE APPLICATION OF THERMOLUMINESCENCE-DOSIMETRY (TLD) SYSTEMS FOR
DETERMINING ABSORBED DOSE IN RADIATION-HARDNESS TESTING OF ELECTRONIC DEVICES

1. Scope

1.1 This practice covers procedures for the use of thermoluminescence dosimeters (TLDs) to determine the absorbed dose in a material irradiated by ionizing radiation. Although some elements of the procedures have broader application, the specific area of concern is radiation-hardness testing of electronic devices in which the material of interest is usually silicon. This practice is applicable to the measurement of absorbed dose in materials irradiated by gamma rays, x rays, and electrons of energies up to 60 MeV. Specific energy limits are covered in appropriate sections describing specific applications of the procedures. The range of absorbed dose covered is approximately from 10^{-2} to 10^4 Gy (one to 10^6 rad) and the range of absorbed dose rates is approximately from 10^{-2} to 10^{10} Gy/s (one to 10^{12} rad/s). Absorbed dose and absorbed dose-rate measurements in materials subjected to neutron irradiation are not covered in this standard.

2. Significance

2.1 Absorbed dose in a material is an important parameter that can be correlated with radiation effects produced in electronic components and devices that are exposed to ionizing radiation. Reasonable estimates of this parameter can be calculated if knowledge of the source radiation field (i.e., energy spectrum and particle

fluence) is available. Sufficiently detailed information about the radiation field is generally not available. However, measurements of absorbed dose with passive dosimeters in a radiation test facility can provide information from which the absorbed dose in a material of interest can be inferred. Under certain prescribed conditions, TLDs are quite suitable for performing such measurements.

3. Applicable documents

3.1 ASTM standards

E 170. Definitions of Terms Relating to Dosimetry.

E 380. Metric Practice

E 665. Practice for Determining Absorbed Dose vs. Depth
in Materials Exposed to the X-Ray Output of Flash
X-Ray Machines.

E 666. Method for the Calculation of Absorbed Dose from
Gamma- or X-Radiation.

3.2 International Commission on Radiation Units and Measurements (ICRU) Reports*

ICRU Report 10b. Physical Aspects of Irradiation

ICRU Report 14. Radiation Dosimetry: X Rays and Gamma Rays
with Maximum Photon Energies Between 0.6 and 50 MeV

ICRU Report 17. Radiation Dosimetry: X Rays Generated at
Potentials of 5 to 150 kV

ICRU Report 19. Radiation Quantities and Units

ICRU Report 21. Radiation Dosimetry: Electrons with Initial
Energies Between 1 and 50 MeV

* Available from ICRU, 7910 Woodmont Avenue, Washington, D.C. 20014.

4. Definitions

4.1 absorbed dose - D , is the quotient of $d\bar{\epsilon}$ by dm , where $d\bar{\epsilon}$ is the mean energy imparted by ionizing radiation to the matter in a volume element and dm is the mass of matter in that volume element.

$$D = \frac{d\bar{\epsilon}}{dm}$$

Previously, the special unit of absorbed dose was the rad, however, the gray (Gy) has been adopted recently as the official SI unit (see ASTM E380).

$$1 \text{ Gy} = 1 \text{ J kg}^{-1} = 10^2 \text{ rad}$$

4.2 exposure- X , is the quotient of dQ by dm where dQ is the absolute value of the total charge of the ions of one sign produced in air when all the electrons (negatrons and positrons) liberated by photons in a volume element of air having mass dm are completely stopped in air.

$$X = \frac{dQ}{dm}$$

The special unit of exposure is the roentgen (R).

$$1 \text{ R} = 2.58 \times 10^{-4} \text{ C} \cdot \text{kg}^{-1}$$

4.3 absorbed-dose rate - the absorbed dose per unit time interval.

4.4 equilibrium absorbed dose - the absorbed dose at some incremental volume within the material in which the condition of electron equilibrium (as many electrons of a given energy enter as leave the volume) exists. (See reference 1 and Appendix A3.)

4.5 thermoluminescence (TL) phosphor - a material which stores, upon irradiation, a fraction of its absorbed dose in various excited energy states. When thermally stimulated, the material emits this stored energy in the form of photons in the ultraviolet, visible, and infrared regions.

4.6 thermoluminescence dosimeter (TLD) - a TL phosphor, alone, or incorporated in a material, used for determining absorbed dose in materials. For example, the TL phosphor is sometimes incorporated in a Teflon matrix.

4.7 thermoluminescence dosimeter (TLD) reader - an instrument used to measure the light emitted from a TLD consisting essentially of a heating element, a light measuring device, and appropriate electronics.

4.8 thermoluminescence dosimeter (TLD) response - the measured light emitted by the TLD and read out during its heating cycle consisting of one of the following: (a) the total light output over the entire heating cycle, (b) a part of that total light output, or (c) the peak amplitude of the light output.

4.9 thermoluminescence dosimeter (TLD) batch - a group of TLDs, generally originating from a single mix or lot of TL phosphor, having similar TL responses and similar thermal and irradiation histories.

4.10 TLD preparation - the procedure of cleaning, annealing, and encapsulating the TL phosphor prior to irradiation.

4.11 annealing - thermal treatment of a TLD prior to irradiation or prior to readout.

NOTE 1 - Pre-irradiation annealing of TLDs is usually done to erase the effects of previous irradiation and to readjust the sensitivity of the phosphor; pre-readout annealing usually is done to reduce low-temperature TLD response.

4.12 calibration conditions - the normal environmental conditions prevailing during routine calibration irradiations such as the ambient temperature, humidity, and lighting.

4.13 test conditions - the normal environmental conditions prevailing during routine hardness-test irradiations such as the ambient temperature, humidity, and lighting.

5. Apparatus

5.1 A TLD system consists of the TLDs, the equipment used for preparation of the TLDs, and the TLD reader.

5.2 A calibration facility delivers a known quantity of radiation to materials under certain prescribed environmental and geometrical conditions. Its radiation source is usually a radioactive isotope, commonly either ^{60}Co or ^{137}Cs , whose radiation output has been calibrated by specific techniques to some specified uncertainty (usually to within $\pm 5\%$).

5.3 A storage facility provides an environment for the TLDs before and after irradiation, that is light tight and that has a negligible background absorbed-dose rate. A TLD stored in the facility for the longest expected storage period should absorb no more than 1% of the lowest absorbed dose expected to be measured in hardness-testing applications.

5.4 An environmental chamber is used in testing the effects of temperature and humidity on TLD response. The chamber should be capable of controlling the temperature and humidity within $\pm 5\%$ over the range expected under both calibration and test conditions.

6. Handling and readout procedures

6.1 Bare TLDs, such as those not sealed in glass, should not be handled with the bare fingers; dirt or grease on their surfaces can affect their response. It is recommended that tweezers or vacuum pick-up tools be used in handling. If required, the TLDs can be cleaned by using the procedures given in Appendix A1.

6.2 TLDs should be protected as much as possible from light having an appreciable ultraviolet component such as sunlight or fluorescent lighting. Prolonged exposure to uv light, either before or after irradiation, can cause spurious TLD response and enhanced post-irradiation fading. Incandescent lighting is recommended for the TLD preparation and readout areas. However, brief exposures of a few minutes under normal room fluorescent lights should not significantly affect TLD response except for low absorbed-dose measurements (<1 Gy or <100 rad).

6.3 Preparation of the TLDs for irradiation consists of cleaning the TL phosphor (if required), annealing (if reusable TLDs are employed), and encapsulating the TL phosphor. Reusable TLDs require careful treatment during annealing in order to obtain the best results in dose measurements. The annealing procedure should include a reproducible temperature cycle of the annealing oven, accurate timing of the annealing period, and a reproducible cooling rate.

6.4 for low absorbed-dose measurements (<1 Gy or <100 rad), dry nitrogen should be flowed through the heating pan area of the TLD reader during readout. This technique suppresses the spurious TL response that occurs in most forms of TLDs as a result of adsorbed oxygen on the phosphor surface.

6.5 Calibration-irradiated TLDs and all subsequent test-irradiated TLDs from the same batch should be read out with the same reader using the same readout techniques and reader parameters. The calibration is valid only for that batch used in that particular reader. Readers that are different from the one used for calibration, including those of the same make and model, do not necessarily indicate the same TLD response for TLDs irradiated to the same absorbed dose.

6.6 TLDs are utilized in two basic ways: as reusable or as single-use "throw-away" dosimeters. Dosimeters employed in a reusable mode are cycled repeatedly through an anneal-irradiation-readout procedure. The single-use dosimeters are irradiated once, read out, and then discarded; they are generally used as received from the manufacturer.

7. Summary of requirements for performance testing of a TLD system

7.1 The performance of a specific TLD system should be evaluated to determine its suitability for use in a specific radiation-hardness test. Acceptable performance of the TLD system should be ascertained before applying the system in a particular radiation-hardness-testing facility. Specific performance criteria will be discussed in section 8.

7.2 Performance tests should be repeated whenever a significant change is made in the TLD system or in the specific application. Examples of such changes are: a change in the physical form or type of phosphor in the TLD, a change in any critical component or in any adjustable readout factor of the TLD reader, or a change in the irradiation source characteristics.

7.3 A particular performance test may be omitted if widely accepted documentation exists in the scientific and technical literature to show that the performance of the TLD system is satisfactory for that specific requirement. For example, if previously accepted studies document that a particular TLD has no absorbed-dose-rate dependence for the expected conditions of irradiation, then performance testing for absorbed-dose-rate dependence of that TLD system is unnecessary. All reports of test results should include appropriate references that substantiate the performance of the system and thereby justify the omission of such performance tests.

7.4 If a particular TLD system fails to meet the performance specification of any performance test, then use of that TLD system is not recommended. However, such a system may be employed, if necessary, but only if appropriate corrections to the TLD response can be determined sufficiently well in order that the results of the specific radiation-hardness test can be determined within the required uncertainty.

7.5 The number of TLDs, or the number of replicates of measurements with a single TLD, used for each test should be sufficient to assure that the test results are significant at the 95% confidence level. The number of measurements required is specified in each test procedure and is based on the assumption of random samples drawn from a TLD batch whose responses have a normal population distribution. See reference 2 for details of the procedures used to select random samples and to determine the sample size required.

NOTE 2 - If a sample of n measurements $Y_1, Y_2, \dots, Y_n$ is taken, the best estimate of the population mean, m , of a normal distribution is given by the mean value, $\bar{Y}$, of the sample:

$$\bar{Y} = \frac{1}{n} \sum_{i=1}^n Y_i .$$

The best estimate of the variance, σ^2 , of the distribution is given by the variance, s^2 , of the sample:

$$s^2 = \frac{1}{n-1} \sum_{i=1}^n (Y_i - \bar{Y})^2$$

The quantity $\sigma(\sqrt{s^2})$ is called the standard deviation of the distribution. It should be noted that the degree to which s is a best estimate of σ depends on the sample size and, as might be expected, s becomes a better estimate of σ as the sample size increases.

8. Specific performance tests and correction factors

8.1 Uniformity of TLD response within a batch.

8.1.1 Select a random sample of 30 TLDs from a batch. Treat all of the sample TLDs in an identical manner, prepare them, irradiate them in the calibration facility to the same absorbed-dose level, and read them out. Determine the variance, s^2 , of the sample and estimate the standard deviation of the TLD response distribution ($\sigma = \sqrt{s^2}$). The standard deviation σ should not exceed 8% of the sample mean value, $\bar{Y}_0$; i.e., $\sigma \leq (0.08) \bar{Y}_0$. The sample size specified (30) is the number of measurements required to estimate the standard deviation, σ , of the TLD response distribution within 25% of its true value at a 95% confidence level (see section 2.4 of reference 2).

8.1.2 For reusable TLDs that have been subjected to a number of anneal-irradiation cycles, the uniformity of the batch response should be verified periodically by repeating the test of 8.1.1. The frequency required for the test depends on the type of TLD and on its previous anneal-irradiation history. Retesting of the batch uniformity becomes particularly important for TLDs irradiated to high dose levels ($>10^2$ Gy(10^4 rad)).

8.2 Reproducibility of TLD response of individual reusable dosimeters

Certain types of TLDs may be utilized as individual reusable dosimeters. In this case, the identity of each individual dosimeter is maintained during repeated measurement cycles throughout its useful life. This is in contrast to utilization in the batch mode where individual dosimeters within the batch are not identified. To test the reproducibility of the response of an individual reusable dosimeter, the following procedures should be followed.

8.2.1 Select the individual TLD to be tested, prepare it, irradiate it in the calibration facility to a specific absorbed-dose level (e.g., at the midpoint of the absorbed-dose range of interest), and read it out. In an identical manner, repeat this procedure thirty times. Determine the variance, s^2 , of the responses and estimate the standard deviation of the TLD response distribution ($\sigma = \sqrt{s^2}$). The standard deviation, σ , should not exceed 5% of the mean response value, $\bar{Y}_0$; i.e., $\sigma \leq (0.05) \bar{Y}_0$.

8.2.2 Some types of TLDs may exhibit a change in sensitivity (i.e., response per unit absorbed dose) with repeated anneal-irradiation-readout cycling. This effect is most pronounced if the TLD is not annealed thoroughly. The test results of 8.2.1 may not show such a change in response sensitivity. However, if such a change is shown in that test or if it appears after a larger number of cycles than specified in that test, then a different analysis of the data is required. In this case, a curve should be fitted to the data of response vs. number of cycles by a least-squares method. A measure of reproducibility would then be given by the average standard deviation of the data points from the least-squares curve. The performance criterion is the same as in 8.2.1.

8.2.3 Since the identity of each TLD is maintained when it is utilized as an individual dosimeter, it is not necessary that groups of such individual TLDs meet the batch requirements of 8.1. However, for the other performance tests and correction factors discussed in Section 8, it is assumed that such tests and factors are evaluated by utilizing TLDs in a batch mode.

8.3 Dependence of TLD response on absorbed-dose rate

8.3.1. From a TLD batch meeting the requirements of 8.1.1, select a number of TLDs. Divide the TLDs into a number of groups, x , each group containing n samples. Determine the absorbed-dose-rate range of interest for the intended application and divide this range into x intervals (for example, one interval per decade). Prepare all the TLDs in an identical manner, and irradiate each group to the same dose level, but at a different absorbed-dose rate for each x group, covering the absorbed-dose-rate range of interest. Read out the TLDs. Determine the mean response, $\bar{Y}_i$, for each x group of n samples. Determine an overall mean value, $\bar{Y}_0$, for all x group means. Then the absolute difference between any group mean and the overall mean should not exceed 20% of the overall mean. That is,

$$| \bar{Y}_i - \bar{Y}_0 | \leq (0.2) \bar{Y}_0 .$$

8.3.2 If $| \bar{Y}_i - \bar{Y}_0 | > (0.05) \bar{Y}_0$, then appropriate correction factors to the TLD response as a function of absorbed-dose rate should be determined by the procedures that follow.

8.3.3 Determine the number of samples n required in each x group in order to detect a difference of $\delta = (0.05)\bar{Y}_0$ between a group mean and the overall mean for a confidence level of 95% and a probability of 0.05 of failing to detect such a difference. It is assumed that the variance (σ^2) of the TLD response, determined in 8.1.1, does not vary with absorbed-dose rate. Calculate the following parameter:

$$d = \frac{\delta}{\sqrt{2\sigma^2}} = \frac{\delta}{\sigma\sqrt{2}}$$

Then the sample size, n , required for each x group to satisfy the above parameters is read off the graph of n vs. d (Fig. A4.1) in Appendix A4.

8.3.4 Example of sample number determination.

If $\sigma = 0.03 \bar{Y}_0$ (determined in 8.1.1),

$$d = \frac{0.05 \bar{Y}_0}{\sqrt{2} \cdot 0.03 \bar{Y}_0} = 1.18.$$

From Fig. A4.1, the sample size required is $n = 4.4$. The sample size should be 5, obtained by rounding up to the nearest integer.

NOTE 3 - One method by which this test requirement can be carried out is by comparing the TLD responses with the response of another radiation dosimeter whose absorbed-dose-rate dependence is known. A suitable type of dosimeter for use in most cases would be a calorimeter whose response is absorbed-dose-rate independent and whose radiation absorption properties are similar to the TLD under test.

8.4 Dependence of TLD response on energy

8.4.1 The radiation absorption properties of the TLDs employed in radiation-hardness testing should be similar to those of the material in which the dose is to be estimated. Calculations can be made to determine the effects of a broad incident energy spectrum on the response of the TLDs compared to that of the material of interest (usually silicon). The requirements of 7.5 are not applicable to this section.

8.4.2 If the ratios $\frac{(\mu_{en}/\rho)_{TLD}}{(\mu_{en}/\rho)_{mat}}$ and $\frac{(S/\rho)_{TLD}}{(S/\rho)_{mat}}$ are equal to 1.0

within $\pm 10\%$ over a significant range of the energy spectrum (for both calibration and test irradiations) incident upon both the TLD and the material of interest, then the energy-response performance of the TLD system is acceptable. Here, μ_{en}/ρ is the mass photon energy absorption

coefficient and S/ρ is the mass collision electron stopping power. Tables of values of μ_{en}/ρ and S/ρ for several materials may be found in Appendix A2. The phrase "significant range of the energy spectrum" means the minimum and maximum energy limits containing those incident radiation particles (either photons or electrons) that contribute at least 90% of the absorbed dose. In this case, detailed energy spectral information is not required; the incident particle fluence (either photons or electrons) between the energy limits is sufficient.

8.4.3 If the energy spectrum of the radiation incident upon the TLD (under both calibration and test conditions) and the material of interest (under test conditions) is well known, then the conversion from absorbed dose in the TLD to absorbed dose in the material of interest can be calculated from such data. If this conversion can be made to an uncertainty of $\pm 10\%$ or less, then the performance of the TLD system is acceptable. In this case, the criteria concerning the ratios of μ_{en}/ρ and S/ρ in 8.4.2 need not be met. (See ASTM Method E 666 for more specific guidelines.)

8.5 Dependence of TLD response on direction of incident radiation.

8.5.1 If the geometrical orientation of the TLD with respect to the radiation-hardness test field is significantly different than its orientation with respect to the calibration radiation field, then any dependency of the TLD response on the direction of the incident radiation should be determined. Select a number of TLDs from a batch meeting the requirements of 8.1.1. Divide the TLDs into a number of groups, x , each group containing n samples. Prepare the TLDs in an identical manner, and irradiate each group to the same absorbed-dose level in the following manner: (a) group g_0 in the usually oriented direction used for routine calibration, and (b) groups $g_1, g_2, \dots, g_x$ oriented, respectively, at

angles $\theta_1, \theta_2, \dots, \theta_x$, relative to the usually oriented direction with the center of the group at the same distance from the source. These angles should divide, in equal intervals of no more than 30° each, the angle between normal and the maximum possible angle of incidence of the radiation-hardness test field. Read out all the TLDs. Determine the mean response, $\bar{Y}_i$, for each x group of n samples. Then the absolute difference between the mean, $\bar{Y}_0$, for the normally used calibration orientation and the mean for any other orientation should not exceed 5% of the mean. $\bar{Y}_0$. That is,

$$| \bar{Y}_i - \bar{Y}_0 | \leq 0.05 \bar{Y}_0 .$$

To determine the sample size n required for each x group, use the procedures of 8.3.3.

NOTE 4: CAUTION - This test applies only to a collimated-beam type calibration source geometry. If the angle of incidence of the radiation from the calibration source is nearly isotropic, then it is recommended that the TLDs and their encapsulation material should be as nearly spherical as possible.

8.6 Dependence of TLD response on time between preparation and irradiation

8.6.1 A change in TLD sensitivity can occur during the storage period between preparation and irradiation. This may be a significant effect if a wide range of storage periods is used. Use the following procedure to test for this effect. From a TLD batch meeting the requirements of 8.1.1, select two equal groups of n samples each. Prepare the first group of TLDs and place them in the storage facility

for a time interval equal to the maximum time interval expected between preparation and irradiation during routine application in either calibration or hardness testing. At a later time, prepare the second group of TLDs, and place them in the storage facility for the minimum time interval expected between preparation and irradiation. Time the procedures so that the ends of the storage periods for both groups occur simultaneously. Then irradiate both groups to the same absorbed dose level in the calibration facility and read them all out.

The difference between the mean TLD response, $\bar{Y}_1$, of the first group and the mean response, $\bar{Y}_2$, of the second group is a measure of the effect of storage time between preparation and irradiation. This difference should not exceed 20% of the average of the means of the two groups. That is,

$$| \bar{Y}_1 - \bar{Y}_2 | \leq (0.2) \frac{\bar{Y}_1 + \bar{Y}_2}{2} .$$

8.6.2 If the effect tested for in 8.6.1 exceeds 5% of the average of the group means, then the functional dependence of the TLD response on the storage period should be determined in order that appropriate correction factors may be applied. This functional dependence may be determined by the procedures that follow.

8.6.3. The range of the elapsed time intervals between preparation and irradiation of interest is determined from the minimum and maximum intervals utilized in 8.6.1. Tests should be performed at a minimum of two intervals per decade of elapsed time over the entire range. For example, if the minimum elapsed time is 0.1 hour and maximum elapsed time is 100 hours, than an appropriate set of tests would be at elapsed times of 0.1, 0.3, 1, 3, 10, 30, and 100 hours. From a TLD batch meeting the requirements of 8.1.1, select as many groups of n samples each as

there are elapsed time intervals as determined above. Prepare a group of TLDs, and place it in the storage facility for the appropriate preselected test-time interval. Repeat this procedure for all preselected storage time intervals from the maximum to the minimum elapsed time. Arrange the storage times so that the ends of all procedures occur simultaneously. Then irradiate all groups to the same dose level in the calibration facility and read them all out as quickly as possible thereafter. This procedure is designed to minimize effects on dosimeter response caused by fading and variation in reader output. Determine the mean response for each group of TLDs. A plot of mean TLD response vs. elapsed time provides a correction factor for a change in TLD sensitivity as a function of storage period. The number of samples n required for each group of TLDs should be determined by the procedures of 8.3.3.

8.7 Dependence of TLD response on time between irradiation and readout

8.7.1 Significant fading of the TLD response may occur during the storage period between the end of irradiation and readout. Use the following procedure to test for this effect. From a TLD batch meeting the requirements of 8.1.1, select two equal groups of n samples each. Prepare the first group of TLDs, irradiate them in the calibration facility to a specific dose level, then place them in the storage facility for an interval equal to the maximum time interval expected during routine application (for either calibration or hardness testing) between the end of the irradiation period and readout. Prepare the second group of TLDs, irradiate them in the calibration facility to the same dose level as the

first group, then place them in the storage facility for an interval equal to the minimum time interval expected between the end of irradiation and readout. Time the procedures so the ends of the storage periods for both groups occur simultaneously. Read out all of the TLDs. The absolute difference between the mean TLD response, $\bar{Y}_1$, of the first group and the mean response, $\bar{Y}_2$, of the second group is a measure of the effect of storage time between the end of irradiation and readout. This difference should not exceed 20% of the average of the means of the two groups. That is,

$$| \bar{Y}_1 - \bar{Y}_2 | \leq (0.2) \frac{\bar{Y}_1 + \bar{Y}_2}{2} .$$

8.7.2 If the fading effect is greater than $(0.05) \frac{\bar{Y}_1 + \bar{Y}_2}{2}$, then either a correction should be made to the TLD response or a procedure used that eliminates the need for a correction. A procedure that achieves the latter would be one in which all TLDs are read out at the same elapsed time after the end of irradiation. Such a procedure is often inconvenient or impractical. Therefore, it is usually necessary to apply a fading correction to the TLD response. The fading characteristics of the TLD system may be determined by the test procedures that follow.

8.7.3 Determine the minimum and maximum elapsed times between the end of the irradiation period and readout. Tests should be performed at a minimum of two time intervals per decade of elapsed time over the entire period as discussed in 8.6.3. From a TLD batch meeting the requirements of 8.1.1, select as many groups of n samples each as there are elapsed time intervals as determined above. Each group of TLDs should undergo identical preparation and then should be irradiated in the

calibration facility to the same dose level. The groups of TLDs are placed in the storage facility for all preselected appropriate time intervals from the maximum to the minimum elapsed time. Arrange the time of irradiations for all the groups so that the ends of their storage periods occur simultaneously. Read out all the TLDs. Determine the mean response for each group of TLDs. A plot of mean TLD response vs. elapsed time provides the fading correction factor. The number of samples n required for each group of TLDs should be determined by the procedures of 8.3.3.

8.8 Dependence of TLD response on temperature during storage or irradiation

8.8.1 If the storage temperature experienced by the TLDs between preparation and irradiation during routine radiation-hardness testing differs from the temperature during routine calibration by more than 10°C , test 8.6 should be repeated over the range of temperatures expected using the environmental chamber instead of the storage facility. The performance criteria of 8.6 are applicable to this section.

8.8.2 If the storage temperature experienced by the TLDs between irradiation and readout during routine radiation-hardness testing differs from the temperature during routine calibration by more than 10°C , test 8.7 should be repeated over the range of temperatures expected using the environmental chamber instead of the storage facility. The performance criteria of 8.7 are applicable to this section.

8.8.3 If the temperature experienced by the TLDs during the irradiation period during routine radiation-hardness testing differs from the temperature during routine calibration by more than 10°C , then the effect on TLD response should be determined by the following procedure. Select a number of TLDs from a batch meeting the requirements of 8.1.1,

prepare them in an identical manner, and separate them into two equal groups of n samples each. Irradiate the first group in the calibration facility to a specific dose level, maintaining the temperature of the TLDs at the minimum temperature expected during routine hardness-test irradiations. Irradiate the second group in the calibration facility to the same dose level, maintaining the temperature of the TLDs at the maximum temperature expected during routine hardness-test irradiations. Readout all of the TLDs. The difference between the mean TLD response, $\bar{Y}_1$, of the first group and the mean response, $\bar{Y}_2$, of the second group is a measure of the effect of temperature variation during irradiation. This difference should not exceed 20% of the average of the means of the two groups. If the magnitude of the effect is greater than 5% of the average of the means, then appropriate corrections to the TLD responses should be determined by procedures analogous to those used in 8.6.

8.9 Dependence of TLD response on humidity

8.9.1 In general, the responses of the most widely used TLDs have not been shown to be sensitive to changes in relative humidity [3]. However, if a TLD that is hygroscopic (such as lithium borate) is being considered for application in radiation-hardness testing, then the performance tests of 8.8 should be repeated with the humidity as the variable parameter and the temperature maintained at the maximum value used in the temperature tests.

NOTE 5. Once a TLD system of a particular TL phosphor type and physical configuration has met the performance requirements of Section 8, new batches of the same type need only be tested for the requirements of 8.1 (batch uniformity).

9. Calibration of the TLD system

9.1 Calibrate the TLD system in a manner such that the TLD response can be related directly to the absorbed dose in the TLD phosphor. Use a suitable, well-characterized radiation source in the calibration. Radioactive isotope sources such as ^{60}Co or ^{137}Cs are generally used for this purpose. The exposure rate (or absorbed-dose rate) produced by the source should be known to better than $\pm 5\%$ at all locations normally used for calibration irradiations. The methods used for determining the output rates of such sources include the use of secondary standard radiation measuring instruments, such as air-ionization chambers, whose calibration is traceable to the National Bureau of Standards or other recognized calibration laboratories. Other types of dosimeters, whose responses are absolute (require no calibration), such as ferrous sulfate dosimeters and calorimeters, may also be employed for source calibration.

9.2 The response of most types of TLDs generally is not linear as a function of absorbed dose [4]. The response of a typical TLD is usually linear from low absorbed-dose levels (millirad region) to approximately 10 Gy (10^3 rad), then becomes supralinear up to approximately $10^2 - 10^3$ Gy ($10^4 - 10^5$ rad) where saturation effects become evident. Exercise care in the use of the TLD system for absorbed dose levels of approximately 10^3 Gy (10^5 rad) or higher to ensure that the change in the system response per unit absorbed dose is adequate in order that the absorbed dose can be determined within the required uncertainty.

9.3 The absorbed-dose range of calibration should cover the maximum absorbed-dose range of interest for the intended application. Measure a minimum of three absorbed-dose levels per decade of absorbed dose covered. Since the TLD response vs. absorbed dose for most types of TLDs generally is

not linear, make a sufficient number of measurements at each absorbed-dose level to define accurately the shape of the characteristic response curve. The number of TLD samples required to determine the mean response at each absorbed-dose level is given by the following procedures.

9.3.1 In order to determine the mean TLD response, $\bar{Y}_0$, within $\pm 5\%$ at a 95% confidence level, the number of TLD samples required for a given absorbed-dose level is

$$n = \frac{(2.045)^2 s^2}{(0.05 \bar{Y}_0)^2},$$

where s is the estimate of the standard deviation, σ , of the TLD response distribution as determined by the procedures of 8.1.1. For example, if $s = (0.06)\bar{Y}_0$, then

$$n = \frac{(2.045)^2 (0.06 \bar{Y}_0)^2}{(0.05 \bar{Y}_0)^2} = 6.0$$

(See Section 2-3.2 of reference 2 for more details.)

9.3.2 The procedures described in 9.3.1 assume that the standard deviation of the TLD response distribution is constant for all absorbed-dose levels measured. This assumption generally is valid over most of the usable absorbed-dose range for most TLDs but may not be correct for very high absorbed-dose levels of approximately 10^3 Gy (10^5 rad) or higher. If the TLD system is used at these absorbed-dose levels, then redetermine the standard deviation of the response distribution at these levels by repeating the procedures of 8.1.1.

9.4 During a calibration irradiation, encapsulate the TL phosphor in a material with a thickness just sufficient to produce electron equili-

brum in the phosphor (see Appendix A3). If possible, the encapsulation material should have the same thickness on all sides of the dosimeter.

NOTE 6. The encapsulation material should resemble the phosphor material as closely as possible with respect to radiation absorption properties. For example, if the TL phosphor is CaF_2 , acceptable encapsulation material would be CaF_2 , Al, or Si. If the calibration source is ^{60}Co , then a thickness of 2.2 mm of Al (equal to the practical range of the highest energy secondary electrons produced) would establish electron equilibrium in the CaF_2 phosphor. This thickness is sufficient to stop secondary electrons that might be generated by the source photons in material other than the encapsulation material.

9.5 It is necessary to correct for attenuation of the photons from the source by the layer of material used to establish electron equilibrium. This should be done using the following formula:

$$X = X_0 e^{-(\mu_{\text{en}}/\rho)\rho x}$$

where X is the attenuated exposure at the position of the TLD phosphor in roentgens,

X_0 is the unattenuated exposure in roentgens,

μ_{en}/ρ is the mass energy absorption coefficient of the encapsulation material for the effective source photon energy in cm^2/g ,

ρ is the density of the encapsulation material in g/cm^3 , and

x is the thickness of the encapsulation material in cm.

Values of (μ_{en}/ρ) may be found in Appendix A2.

NOTE 7. The attenuation formula given is not rigorously correct for a broad-beam geometry as it does not include a buildup factor. Buildup factors generally are not available for a wide range of energies, materials, and geometries. However, the formula gives results that are in reasonable agreement with more rigorous treatments for materials of low to medium atomic number of relatively thin sections over the range of photon energies that are applicable to this standard.

9.6 Once the exposure has been determined, the absorbed dose (in Gy) to the encapsulated TL phosphor is found from the formula:

$$D_{\text{TLD}} = \frac{(\mu_{\text{en}}/\rho)_{\text{TLD}}}{(\mu_{\text{en}}/\rho)_{\text{air}}} (0.869 \times 10^{-2})X$$

The factor (0.869×10^{-2}) is used to convert exposure (R) to absorbed dose in air (Gy). Conversion of exposure (R) to absorbed dose in air (rad) would require a factor of 0.869. The subscripts refer to the material of interest. As in 9.5, the μ_{en}/ρ values are evaluated at the effective calibration source photon energy. This formula is valid only if electron equilibrium exists in the TL phosphor. It is assumed that the incident photon fluence is essentially monoenergetic. If this is not the case, then average all of the energy-dependent energy absorption coefficients of 9.5 and 9.6 over the appropriate energy spectrum.

9.7 The absorbed dose calibration results of the procedures of 9.3 to 9.6 are valid only for a given batch of TLDs. A different batch generally will have a different radiation sensitivity. However, this difference is usually a constant factor over the entire absorbed-dose

range. Therefore, it is usually not necessary to generate a new calibration curve over the entire absorbed-dose range covered. Measurements at a minimum of two points in the linear region and at a minimum of three points in the supralinear and saturation regions of the response curve normally is adequate to characterize the absorbed-dose sensitivity of a different batch.

9.8 Because of possible long term aging effects in the TLD reader, recalibrate the TLD system (as specified in 9.3 to 9.6) at periodic intervals over the entire absorbed-dose range of application. The time interval between calibrations depends on the long-term stability of the TLD reader and on how much it is used. If the reader is used only a few hours a week, then recalibration at 6 or 12 months intervals should be adequate. For a reader that is used daily with a heavy work load, monthly calibration is probably required.

10. Procedures for characterizing and monitoring a test radiation field with TLD systems

10.1 A variety of sources are used to produce the radiation fields that are appropriate for radiation-hardness testing of electronic devices. The most widely used fields are ^{60}Co gamma rays, x-ray (bremsstrahlung) photons from fast-pulse (flash) accelerators, and high-energy electron beams from linear accelerators (linacs). Maximum absorbed-dose rates range from about $10\text{ Gy}(\text{Si})/\text{s}$ ($10^3\text{ rad}(\text{Si})/\text{s}$) to about $10^{10}\text{ Gy}(\text{Si})/\text{s}$ ($10^{12}\text{ rad}(\text{Si})/\text{s}$).

10.2 TLDs irradiated in various locations in the test facility under free-field conditions can be used to characterize the radiation field. In addition, it may be desirable and practical to monitor the radiation field of the source during actual radiation-hardness testing of electronic devices. When there is a significant variation of the source output from irradiation to irradiation, use TLDs as monitors.

10.2.1 For irradiation by gamma rays or pulsed x rays, encapsulate the TL phosphor in material with sufficient thickness to produce electron equilibrium conditions in the TL phosphor. See Section 9.4 and Appendix A3 for details. The equilibrium material should have radiation absorption properties similar to the material in which the absorbed dose is to be determined. Since silicon is usually the material of interest, aluminum is an acceptable equilibrium material.

10.2.2 For irradiation with electrons, the absorbed dose as a function of depth for normally incident monoenergetic electrons has the characteristic shape shown in Fig. 1 [5]. For the electron energy spectrum appropriate to the test source being employed, encapsulate the TL phosphor

in a material with a thickness of approximately 0.1 the practical range (R_p in Fig. 1) of the maximum-energy electrons on the incident radiation side and with a thickness greater than the practical range on the side opposite the incident electrons. By placing the TLD at this depth in the material, possibly anomalous response caused by interface effects at the material surface is avoided. As in the case for photons, the encapsulation material should have radiation absorption properties similar to the material of interest. In all cases in which the TLD is encapsulated, the combined thickness of the encapsulation material in front of the TLD and the TLD itself should be such that the back surface of the TLD is located at a depth not much greater than the peak of the absorbed dose vs. depth curve. For normal incidence, this depth is approximately one half of the practical range of the electrons.

10.3 Select the TLDs to be used in characterizing or monitoring the test radiation field from a batch that has been calibrated previously. From the same batch, select several TLDs to be used as calibration-check TLDs. The number of TLDs required for determining a specific absorbed dose during the test irradiation may be obtained from the procedures of 9.3.

10.3.1 At a time as close as possible to that of the hardness-testing irradiations, irradiate several TLDs in the calibration facility to two or more absorbed-dose levels within the absorbed-dose range expected for the test irradiations. Read out these calibrated TLDs along with the TLDs used in the hardness-testing irradiations. These calibrated TLDs serve as checks on the stability of the TLD system.

10.3.2 If it is not convenient to use the procedure described in 10.3.1, an alternate procedure may be used. At some time before the

hardness-testing irradiations occur, irradiate a number of TLDs that will be used as calibration checks in the calibration facility to two or more absorbed-dose levels within the expected absorbed-dose range of the test irradiations. Place these calibrated TLDs in the storage facility until hardness-testing irradiations are performed. Remove a few calibrated TLDs from storage and read them out along with the test TLDs. The other calibrated TLDs remain in storage until the next test irradiations are performed, when a few more should be read out with the test TLDs. The disadvantage of this method compared to that of 10.3.1, is that different fading (and possibly temperature dependence) corrections must be applied to each group of calibrated TLDs; in addition, the fading correction is different for the calibrated TLDs than for the test TLDs. If the fading correction is excessively large ($>25\%$) for the calibrated TLDs, calibrate another group for readout with the test-irradiated TLDs.

10.3.3 If reusable TLDs are irradiated (for either calibration or testing) to high single or accumulated absorbed-dose levels ($>10^2$ Gy (10^4 rad)), recalibration may be required after each anneal-irradiation cycle because of possible changes in absorbed-dose sensitivity [6]. If the TLD system being used is subject to this effect, it is recommended that each TLD in the batch be irradiated only once until the entire batch has been used, after which the entire batch can be annealed and a new calibration performed. In addition, because of possible changes in batch response uniformity due to high absorbed-dose irradiations, repeat the tests of 8.1.1 periodically.

10.4 The equilibrium absorbed dose in a material of interest can be estimated from the absorbed dose in a TLD exposed to the same radiation

field. This involves a conversion of the absorbed dose in a TLD irradiated within a material under electron equilibrium conditions to absorbed dose in a volume element of the material of interest having comparable dimensions to the TLD, the volume element being surrounded by an equilibrium thickness of the same material of interest. It has been shown that the TLD response per unit absorbed dose in the TLD material is independent of the type (photons or electrons) or the energy spectrum of the incident radiation for the range of energies considered in this standard.

10.4.1 In a material undergoing photon irradiation, the presence of the TLD may perturb the spectrum of the secondary electrons generated by the primary photons. If the TLD is very thin compared to the range of the secondary electrons, most of the energy deposited in the TLD and in the material surrounding it come from secondary electrons produced outside the TLD (i.e., in the equilibrium layer of material). Thus, the absorbed dose in the material is given by

$$D_{\text{mat.}} = \frac{(S/\rho)_{\text{mat.}}}{(S/\rho)_{\text{TLD}}} \cdot D_{\text{TLD}} \quad (1)$$

If the TLD has a thickness much greater than the range of the secondary electrons, most of the energy deposited in it comes from secondary electrons produced within the TLD itself. Thus, the absorbed dose in the material is given by

$$D_{\text{mat.}} = \frac{(\mu_{\text{en}}/\rho)_{\text{mat.}}}{(\mu_{\text{en}}/\rho)_{\text{TLD}}} \cdot D_{\text{TLD}} \quad (2)$$

If the TLD thickness is intermediate between the two limits given above, then the two equations may be combined with appropriate weighting factors to reflect the relative contributions of each term [7]. In

general, for low atomic number material and for photon energies above about 0.2 MeV, the difference in the absorbed dose determined by equations (1) and (2) is usually less than 10%. If the equilibrium buildup material surrounding the TLD is not silicon, then the equilibrium absorbed dose in silicon is given by

$$D_{Si} = \frac{(\mu_{en}/\rho)_{Si}}{(\mu_{en}/\rho)_{mat.}} \cdot D_{mat.} \quad (3)$$

10.4.2 The effects of dosimeter size on the absorbed-dose conversion for electron irradiation are not as clearly understood as for photon irradiation [8,9]. However, reasonable estimates of the absorbed dose in the material of interest can be made using equation (1) in 10.4.1 if the initial incident electron energy is greater than 5 MeV and the TLD is less than two thirds of the practical electron range in thickness. If the material surrounding the TLD is not silicon, then the absorbed dose in silicon is given by

$$D_{Si} = \frac{(S/\rho)_{Si}}{(S/\rho)_{mat.}} \cdot D_{mat.} \quad (4)$$

10.5 Limitations of interpretation. Caution must be used in interpreting the results of using the procedures of 10.4 for converting the absorbed dose in the TLD to absorbed dose in the material of interest (assumed to be silicon). Reasons for this are given in the following sections.

10.5.1 The absorbed-dose conversions are most reliable when the TLD and the equilibrium material surrounding it are similar to silicon in radiation absorption properties.

10.5.2 The absorbed dose in the material is interpreted from an integrated or average absorbed dose in the TLD at its location in the

surrounding material and does not necessarily represent the actual absorbed dose at any other point within the volume of the material.

10.5.3 The evaluated equilibrium absorbed dose in silicon does not necessarily represent the absorbed dose in an electronic device irradiated in the same test field. A number of factors complicate a straightforward interpretation of the absorbed dose distribution within an irradiated device. Examples of such perturbing factors include attenuation of the radiation by the packaging material surrounding the device chip, variations in absorbed dose near interfaces of the thin insulation and metallized layers on or near the front surface of the chip, and changes in radiation energy spectrum due to scattered radiation from adjacent hardware.

10.5.4 These absorbed dose interpretations are valid only if the ratios of the energy absorption coefficients and stopping powers of silicon relative to the TLD are fairly constant over a significant range of the incident photon or electron spectra. Otherwise, the incident energy spectra must be known and the uncertainty in the results of the absorbed dose conversion depends on the accuracy of the spectra data.

11. Report of results

11.1 Reports of radiation-hardness testing of electronic devices should include information that fully describes the following:

11.1.1 The TLD system employed should be given, including the type and physical form of the TLDs, the type of TLD reader, and the annealing procedure used, if any.

11.1.2 The results of all performance tests carried out or reference to relevant published studies of the TLD system should be given. Such test results should include, as a minimum, the sample size, the mean value of the sample responses, the absorbed-dose level, and the standard deviation of the sample response distribution.

11.1.3 The procedure for calibrating the absorbed-dose response of the TLD system should be described, including the radiation source type, irradiation geometry, and conditions (e.g., absorbed-dose level, absorbed-dose rate, and equilibrium material).

11.1.4 A description of the radiation-hardness-test irradiations should be given, including radiation source type, geometry, and conditions, (e.g., absorbed-dose level, absorbed-dose rate, and equilibrium material) as well as any useful supplemental data (e.g., energy spectra).

11.1.5 A description of the conversion of TLD response to absorbed dose in the material of interest should be given, including calibration factors, correction factors, and absorbed-dose conversion factors. The absorbed-dose conversion factors would include information such as the radiation absorption characteristics of the material of interest and assumptions or data about the source energy spectrum.

11.1.6 An estimate of the overall uncertainty of the results should be given as well as an error analysis of the factors contributing to the random and systematic uncertainties. (For an example, see A1.6 of Appendix A1.)

REFERENCES

1. Roesch, W. C., and Attix, F. H., Basic Concepts of Dosimetry, Radiation Dosimetry, Vol. I, Second Edition, F. H. Attix, W. C. Roesch, and E. Tochilin, Eds., Academic Press, New York, pp. 2-41, 1968.
2. Natrella, M.G., Experimental Statistics, NBS Handbook 91, U.S. Government Printing Office, Washington, D.C. 20402, 1963.
3. Burgkhardt, B., Herrera, R., and Piesch, E., Fading Characteristics of Different Thermoluminescent Dosimeters, Nucl. Inst. Meth., Vol. 137, pp. 41-47, 1976.
4. Gorbics, S.G., and Attix, F.H., Thermoluminescent Dosimeters for High-Dose Application, Health Phys., Vol. 25, pp. 499-506, 1973.
5. Humphreys, J.C., Chappell, S.E., McLaughlin, W.L., and Jarrett, R.D., Measurements of Dose Distributions in Various Materials Irradiated by 10-MeV Electrons, Radiat. Phys. Chem., Vol. 9, pp. 749-761, 1977.
6. Marrone, M.J. and Attix, F.H., Damage Effects in $\text{CaF}_2\text{:Mn}$ and LiF Thermoluminescent Dosimeters, Health Phys., Vol. 10, pp. 431-436, 1964.
7. Burlin, T. E., Cavity-Chamber Theory, Radiation Dosimetry, Vol. I, Second Edition, F. H. Attix, W. C. Roesch, and E. Tochilin, Eds., Academic Press, New York, pp. 332-392, 1968.
8. Paliwal, B.R. and Almond, P.R., Applications of Cavity Theories for Electrons to LiF Dosimeters, Phys. Med. Biol., Vol. 20, No. 4, pp. 547-558, 1975.
9. Holt, J.G., Edelstein, G.R., and Clark, T.E., Energy Dependence of the Response of Lithium Fluoride TLD Rods in High Energy Electron Fields, Phys. Med. Biol., Vol. 20, No. 4, pp. 559-570, 1975.

10. Cameron, J. R., Suntharalingam, N., and Kenney, G. N., Thermoluminescent Dosimetry, University of Wisconsin Press, Madison, Wisconsin, 1968.
11. Becker, K. Solid State Dosimetry, CRC Press, Cleveland, Ohio, 1973.
12. Fowler, J. F., and Attix, F. H., Solid State Integrating Dosimeters, Radiation Dosimetry, Vol. II, Second Edition, F. H. Attix, W. C. Roesch, and E. Tochilin, Eds., Academic Press, New York, pp. 269-290, 1966.
13. Storm, E., and Israel, H. I., Photon Cross Sections from 1 keV to 100 MeV for Elements $Z = 1$ to $Z = 100$, Nuc. Data Tables, Vol. 7, No. 6, Academic Press, New York, 1970.
14. Hubbell, J. H., Photon Cross Sections, Attenuation Coefficients, and Energy Absorption Coefficients from 10 keV to 100 GeV, Nat. Std. Ref. Data Ser., Nat. Bur. Std. 29, 1969.
15. Pages, L., Bertal, E., Joffre, H., and Sklavenitis, L., Energy Loss, Range, and Bremsstrahlung Yield for 10-keV to 100-MeV Electrons in Various Elements and Chemical Compounds, Atomic Data, Vol. 4, No. 1, Academic Press, New York, 1972.
16. Attix, F. H., Basic γ -ray Dosimetry, Health Phys., Vol. 15, pp. 49-56, 1968.
17. Sinclair, W. K., Radiobiological Dosimetry, Radiation Dosimetry, Vol. III, Second Edition, F. H. Attix and E. Tochilin, Eds., Academic Press, New York, pp. 617-676, 1969.
18. Whyte, G. N., Principles of Radiation Dosimetry, John Wiley & Sons, New York, p. 62, 1959.
19. ICRU, Radiobiological Dosimetry, Report 10e, 1963.
20. Central Axis Depth Dose Data for Use in Radiotherapy, Brit. J. Radiol. Suppl. 11, M. Cohen, D. E. A. Jones, and D. Greene, Eds., British Institute of Radiology, London, 1972.




Fig. 1. Typical depth-dose curve for broad-beam 10-MeV electrons incident on aluminum. R_p is the practical (extrapolated) range. Shaded area illustrates a CaF₂ TLD of 0.089-cm thickness.

APPENDIXES

A1. Recommended Procedures for Application of $\text{CaF}_2\text{:Mn}$ Chips

A1.1 Scope

A1.1.1 The procedures in this Appendix address the use of manganese doped calcium fluoride TLDs in the form of reusable solid chips. This is done for illustrative purposes only and is not meant to imply that other types of phosphors, and physical forms of this or other phosphors, are not suitable for use in radiation-hardness testing. Each type and form of TLD requires a somewhat different application procedure. See references 10-12 for descriptions of various types of TLDs. $\text{CaF}_2\text{:Mn}$ chips do have some significant advantages over some other types and forms of TLDs. Some of these advantages include radiation absorption characteristics reasonably similar to silicon, a simple annealing schedule (compared to LiF), ease of handling compared to powders, and relatively linear absorbed-dose response characteristics. The only disadvantage in using $\text{CaF}_2\text{:Mn}$ TLDs is a moderate fading of the TLD response after irradiation.

A1.2 Dosimeter preparation

A1.2.1 Always handle chips gently and in a manner that will minimize mechanical stress as well as the possibility of scratching or chipping the dosimeter. The recommended handling tool is a vacuum pen; however, tweezers may be used. The contact points of all handling tools should be coated with Teflon if possible.

A1.2.2 Keep the chips as clean as possible at all times so that cleaning can be avoided. Clean the chips only if absolutely necessary since the process can contribute to the aging (decrease in sensitivity) of the phosphor. If cleaning is necessary, the following procedure may be used:

1. bathe the chips in cool trichloroethylene for about 10 minutes in an ultrasonic cleaner,
2. bathe the chips in distilled water for about 10 minutes in the ultrasonic cleaner, and
3. dry the chips as rapidly as possible (dry nitrogen may be used to hasten the drying).

A1.2.3 Anneal the chips for one hour at 500°C followed by rapid cooling. This annealing is essential after irradiation at high absorbed doses to avoid changes in dose sensitivity. For annealing, place the chips in a tray or container of a material that will not react with them at the annealing temperature. Platinum-plated silver or pyrex glass should be satisfactory.

A1.2.4 For photon irradiation, encapsulate the chips so as to provide electron equilibrium conditions in the dosimeter. See 9.4 and Appendix A3. The required thickness of material surrounding the chip is approximately equal to the range of the highest energy secondary electrons that are generated by the incident photons. See 10.2.2 for encapsulation of the chips for electron irradiation.

A1.3 Effects of storage and transportation

A1.3.1 Minimize the storage and transportation of the dosimeters, either between preparation and irradiation or between irradiation and readout. The dosimeters should be protected from uv light and elevated temperatures during storage or transit as much as possible. Apply corrections for any effects on dosimeter response caused by the duration and conditions

of the storage or transit periods, or both. Correction factors for fading during the storage periods before and after irradiation and for any temperature effects can be determined by the procedures of Section 8. Changes in humidity have not been shown to affect the response of $\text{CaF}_2\text{:Mn}$ chips.

A1.4 Irradiation procedures

Procedures for using the TLDs during calibration or test irradiations depend on conditions within each individual facility and on the requirements of the radiation-hardness tests. However, precautions on handling, exposure to light, and exposure to temperature variations apply. The procedures described in Sections 9 and 10 are applicable.

A1.5 Readout

A1.5.1 Pre-readout cleaning of the chips should be done only if necessary (see A1.2.2). Some types of TLDs, such as LiF , may require pre-readout annealing. This is not required for $\text{CaF}_2\text{:Mn}$.

A1.5.2 A heating rate of approximately 30°C/s should be satisfactory. The TLD chips should have been heated to a temperature of at least 450°C and preferably to 500°C at the end of the heating cycle.

A1.5.3 In general, the preferred measure of the TLD response is the peak height of the light output vs. temperature curve. However, the integrated light output is usually more conveniently obtained and is satisfactory in most cases. When trade-offs are to be made with regard to efficiency and accuracy, experience with a particular dosimeter and reader combination usually determines which parameter gives the most satisfactory measure of TLD response.

A1.5.4 Most TLD readers are furnished with some type of check light source that may be used to check the stability of the reader. This procedure provides a check of the reader stability only for the light measuring section and its associated electronics; it does not test the performance and stability of the heating and temperature measuring section. Therefore, the use of calibrated TLDs, as described in 10.3, during each readout session also is recommended.

A1.6 Precision and accuracy

A1.6.1 An example of the error analysis of a typical $\text{CaF}_2\text{:Mn}$ chip system employed in radiation-hardness testing is given in Tables A1.1 and A1.2. These tables identify the sources of error and give estimated magnitudes of the upper bounds of the errors. A basic assumption for these data is that the TLD system has been characterized and used in accordance with the recommended procedures in this standard. Therefore, as pointed out in a footnote in Table A1.1, certain potential sources of error are expected to be insignificant in this case.

A1.6.2 Table A1.1 lists systematic errors and Table A1.2 lists random errors. The systematic errors are estimates of the upper limits of the errors for the particular factors identified. Since, by their very nature, systematic errors cannot be known with great accuracy, they are estimated from observation of the long-term behavior of a given TLD system. On the other hand, random errors are obtained by standard statistical techniques. The values given in Table A1.2 are equal to one standard deviation (σ) of a batch or individual TLD response distribution.

A1.6.3 A further distinction is made in the analysis between whether the absorbed dose is determined from a TLD system utilizing dosimeters in an individual mode or in a batch mode. The difference between individual and batch mode is discussed in Section 8.

A1.6.4 A universally accepted procedure for combining systematic errors does not exist. Generally, these errors are combined either by simple addition or by a combination in quadrature (i.e., the square root of the sum of the squares). In this analysis, the systematic errors in Table A1.1 are combined in quadrature and the result is given as the total systematic uncertainty, E_S . Whatever method of combining errors is used should always be reported in the radiation-hardness test results.

A1.6.5 The random errors listed in Table A1.2 are combined in quadrature and the result given as a value of σ_T . For the purposes of this analysis, five dosimeters are assumed to be used in a specific radiation hardness test. In this case, a standard error of the mean (SEOM) of the absorbed-dose response of the five dosimeters is found by dividing the combined standard deviation, σ_T , by the square root of the number, n , of dosimeters employed; that is

$$SEOM = \frac{\sigma_T}{\sqrt{n}}$$

The total random uncertainty is taken to be equal to three times the SEOM.

A1.6.6 The overall uncertainty of the mean absorbed dose determined by five dosimeters for the conditions described is taken as the algebraic sum of the total systematic uncertainty, E_S , and the total random uncertainty, E_R . For this example, the overall uncertainty is equal to the following:

$$\text{(for individual dosimeters), } E_S + E_R = 6.7\%$$

$$\text{(for batch), } E_S + E_R = 13\%$$

Table A1.1

Estimates of Systematic Uncertainties for Typical $\text{CaF}_2\text{:Mn}$ Chip System

Source of Systematic Error	Individual Dosimeters	Batch
1. ^{60}Co source calibration	3%	3%
2. TLD absorbed dose calibration		
a. Determination of calibration curve	1%	2%
b. Conversion of exposure to dose in TLD	2%	2%
3. Time between irradiation and readout: fading correction factor	1%	3%
4. Conversion of dose in TLD to dose in Si for device test irradiation	2%	2%
5. Correction for attenuation in equilibrium material	2%	2%
6. Absorbed dose rate dependence	*	*
7. Energy dependence	*	*
8. Time between preparation and readout	*	*
9. Directional dependence	*	*
10. Temperature before, during, and after irradiation	*	*
11. Humidity dependence	*	*
12. Effect of size of TLD	*	*
Total systematic uncertainty, all errors combined in quadrature, E_s	4.8%	5.8%

* For purposes of this error analysis, it is assumed that the TLD system is utilized in such a way as to make these errors negligible. However, this assumption is not valid under all conditions of radiation-hardness testing. A careful examination of all possible sources of error must be made for the irradiation conditions and TLD system employed in each specific test.

Table A1.2

Estimates of Random Uncertainties for Typical $\text{CaF}_2\text{:Mn}$ Chip System

Sources of Random Error	Individual Dosimeters	Batch
1. Reproducibility of individual dosimeter response, σ	1%	
2. Correction for sensitivity variation between dosimeters, σ	1%	
3. Uniformity of batch response, σ		5%
Total, combined in quadrature, σ_T	1.4%	5%
Standard error of mean of dose response of five dosimeters, $\sigma_T/\sqrt{n}$	0.63%	2.2%
Total random uncertainty, $E_R = 3(\sigma_T/\sqrt{n})$	1.9%	6.7%

A2. Energy Absorption Coefficients and Collision Stopping Powers

A2.1 Values of photon mass energy absorption coefficients and electron mass collision stopping powers for several materials of interest in radiation-hardness testing are shown in Table A2.1. All values for the energy absorption coefficients are derived from reference 13, except those values for air that are from reference 14. Values for the stopping powers are from reference 15. Energy absorption coefficient values for chemical compounds not listed directly were evaluated from the coefficients μ_i/ρ_i for the constituent elements according to the weighted average

$$\mu/\rho = \sum_i w_i (\mu_i/\rho_i)$$

where w_i is the proportion by weight of the i -th constituent [14]. Ratios of the energy absorption coefficients for the various materials in Table A2.1 relative to silicon as a function of incident photon energy are shown in Figure A2.1. Similarly, ratios of stopping powers are shown in Figure A2.2.

Table A2.1. Mass Energy Absorption Coefficients: μ_{en}/ρ (cm^2/g) and
Mass Collision Stopping Powers: S/ρ ($\text{MeV}\cdot\text{cm}^2/\text{g}$)

Energy (MeV)	Air		LiF		CaF ₂		Al		Si	
	μ_{en}/ρ	S/ρ	μ_{en}/ρ	S/ρ	μ_{en}/ρ	S/ρ	μ_{en}/ρ	S/ρ	μ_{en}/ρ	S/ρ
0.01	4.61	19.7	5.74	18.2	48.3	16.6	25.4	16.4	32.4	16.9
0.02	0.511	11.5	0.632	10.7	6.58	9.93	3.06	9.79	3.99	10.1
0.04	0.0669	6.83	0.0769	6.31	0.819	5.96	0.353	5.88	0.470	6.07
0.06	0.0305	5.10	0.0317	4.71	0.247	4.48	0.108	4.42	0.142	4.56
0.08	0.0243	4.19	0.0234	3.87	0.111	3.70	0.0542	3.64	0.0682	3.76
0.1	0.0234	3.62	0.0219	3.35	0.0658	3.21	0.0373	3.16	0.0442	3.27
0.2	0.0268	2.46	0.0247	2.28	0.0309	2.20	0.0272	2.16	0.0287	2.24
0.4	0.0295	1.90	0.0273	1.74	0.0293	1.71	0.0286	1.67	0.0298	1.73
0.6	0.0295	1.74	0.0272	1.59	0.0289	1.57	0.0284	1.53	0.0296	1.58
0.8	0.0289	1.68	0.0266	1.52	0.0279	1.51	0.0277	1.48	0.0285	1.53
1.0	0.0278	1.66	0.0257	1.49	0.0271	1.49	0.0268	1.46	0.0277	1.51
2.0	0.0234	1.68	0.0217	1.48	0.0231	1.49	0.0225	1.47	0.0236	1.52
4.0	0.0186	1.79	0.0174	1.52	0.0194	1.56	0.0188	1.54	0.0197	1.60
6.0	0.0164	1.87	0.0153	1.55	0.0182	1.61	0.0175	1.58	0.0185	1.65
8.0	0.0152	1.93	0.0142	1.58	0.0178	1.64	0.0170	1.62	0.0180	1.69
10	0.0145	1.98	0.0137	1.60	0.0177	1.67	0.0168	1.64	0.0179	1.72
20	0.0131	2.13	0.0123	1.66	0.0180	1.75	0.0167	1.71	0.0180	1.80
40	0.0124	2.25	0.0119	1.72	0.0181	1.83	0.0168	1.77	0.0182	1.87
60	0.0122	2.31	0.0116	1.75	0.0177	1.87	0.0165	1.81	0.0178	1.90




Fig. A2.1. Ratios of mass energy absorption coefficients of various materials relative to silicon.




Fig. A2.2. Ratios of mass collision stopping powers of various materials relative to silicon.

A3. Determination of Electron Equilibrium Thickness

- A3.1 When a material is irradiated by a photon beam, secondary electrons are generated in the material by interaction of the photons with the atoms of the material. At some depth in the material, the number of secondary electrons of a given energy entering a small volume of the material is equal to the number of secondary electrons of the same energy leaving the volume. Within that volume, electron (charged particle) equilibrium is said to exist [1,16].
- A3.2 The thickness of material required to approximate electron equilibrium is equal to the range of the maximum-energy secondary electron that can be generated by the primary photons. This thickness as a function of maximum photon energy is shown as curve A in Fig. A3.1 [17]. It has been found that for all practical purposes electron equilibrium is achieved within a few percent of its true condition by a thickness considerably less than the maximum secondary electron range [18,19]. This lesser thickness is given by curve B of Fig. A3.1 and approximately corresponds to the depth at which the peak of the depth vs. absorbed dose buildup curve occurs for a given incident photon energy spectrum [18,20]. It should be noted that curve B has been determined from data for bremsstrahlung beams with broad energy spectra. The depth of this absorbed-dose peak to some extent depends on the incident photon energy spectrum and the determination of that depth on the method of measurement. Thus, it should be determined experimentally for a particular radiation source.
- A3.3 Obviously, it is an advantage to use the least amount of material practical to achieve equilibrium conditions since the intensity of the primary photons is attenuated by this material thickness.

Correction should be made for this attenuation (as in 9.5) since the dose is being determined for the photon fluence at the point of measurement.

- A3.4 A significant error in absorbed-dose determination can occur if the thickness given by curve B is used when an appreciable number of near-maximum-energy secondary electrons are generated by the primary photon beam outside the material of interest. These electrons might come directly from an x-ray converter or from direct interaction of the primary photon beam with collimators or other material structures within the vicinity of the measurement area. One method of removing such unwanted electrons from the photon beam would be the use of a transverse magnetic field. However, if this technique is not practical, and it is known or suspected that the primary photon beam contains a significant number of high-energy secondary electrons, then the minimum equilibrium thickness chosen should be equal to the secondary electron range given by curve A of Fig. A3.1.

NOTE A3.1 Fig. A3.1 is based on data calculated or experimentally determined for water. However, equilibrium thickness values obtained from these curves should be within 25% of the thicknesses required for most materials of low to medium atomic number (up to $Z=26$).




Fig. A3.1 Material thickness required for electron equilibrium. A: electron range. B: depth of peak dose.

A4. Determination of Test Sample Size

- A4.1 The number of TLDs (i.e., the sample size n) required for each test group in 8.3.3 is based on a two-sided t -test to detect a difference δ between means of two test groups with a confidence level of 95% and a probability of failing to detect such a difference of 0.50 (see Sec. 3-3.1.1 of reference 2). The graph of n vs. d in Fig. A4.1 was derived from table A-8 of reference 2.
- A4.2 The number of TLDs, n , required to estimate the mean TLD response at a given absorbed-dose level as described in 9.3.1 is based on the determination of a two-sided confidence interval that is expected to bracket the true mean response, m , $100(1-\alpha)\%$ of the time. In this case, the confidence level has been chosen as 95% (i.e., $1-\alpha = 0.95$ and $\alpha = 0.05$) and the confidence interval has been assigned a value of $d = \pm 5\%$ of the sample mean response, $\bar{Y}_0$. The number of TLDs required is

$$n = \frac{t^2 s^2}{d^2},$$

where t is the percentile of the t distribution at a 95% confidence level for 29 degrees of freedom. This number of degrees of freedom is determined from the number of samples used for obtaining the estimated standard deviation, s , in 8.1.1 (see sec. 2-3.2 of reference 2).

- A4.3 The statistical test methods included here are those generally accepted for product testing. The significance levels chosen are somewhat arbitrary but were selected on the basis of being

adequate for the performance tests specified. Other more or less stringent acceptable statistical requirements should be assigned upon practical assessment of the overall objectives of the hardness assurance tests.




Fig. A4.1 Sample size required to detect difference of two means.

$$d = \frac{|m_A - m_B|}{\sqrt{2 \sigma^2}}$$

BIBLIOGRAPHY

1. Aitken, J.J., Huxtable, J., Wintle, A.G., and Bowman, S.G.E. (1974) Age Determination by TL: Review of Progress at Oxford, Proc. of the 4th International Conf. on Luminescence Dosimetry, Kraków, Poland, 1974, Inst. of Nuclear Physics, Kraków, pp. 1005-1019.
2. Almond, P.R., McCray, K., Espejo, D., and Watanabe, S. (1968) The Energy Response of LiF, CaF₂, and Li₂B₄O₇:Mn from 26 keV to 22 MeV, Proc. of the 2nd International Conf. on Luminescence Dosimetry, Gatlinburg, TN, 1968, AEC-CONF-680920, pp. 411-423.
3. Almond, P.R. and McCray, K. (1970), The Energy Response of LiF, CaF₂, and Li₂B₄O₇:Mn to High Energy Radiations, Phys. Med. Biol., 15, pp. 335-342.
4. Attix, F.H. (1962), Dosimetry by Solid State Devices, USNRL Report 5777, U.S. Naval Research Laboratory, Washington, D.C.
5. Attix, F.H. (1964), Present Status of Dosimetry by Radiophotoluminescence and Thermoluminescence Methods, USNRL Report 6145, U.S. Naval Research Laboratory, Washington, D.C.
6. Becker, K., Hong-Wei Lu, R. and Weng, P. (1971), Environmental and Personnel Dosimetry in Tropical Countries, Proc. of the 3rd International Conf. on Luminescence Dosimetry, Risø, Denmark, 1971, Risø Report No. 249, pp. 960-984.
7. Becker, K. (1973) Solid State Dosimetry, CRC Press, Cleveland, Ohio.
8. Booth, L.R., Johnson, T.L., and Attix, F.H. (1971), Use of Miniature Glass-Needle-Type TL Dosimeters in Finger-Ring Applications, USNRL Report 7276, U.S. Naval Research Laboratory, Washington, D.C.
9. Burgkhardt, B., Singh, D., and Piesch, E. (1977) High-Dose Characteristics of CaF₂ and Ca SO₄ Thermoluminescent Dosimeters, Nucl. Instr. and Methods, 141, pp. 363-368.
10. Burgkhardt, B., Piesch, E., and Singh, D. (1978), High-Dose Characteristics of LiF and Li₂B₄O₇ Thermoluminescent Dosimeters, Nucl. Instr. and Methods, 148, pp. 613-617.
11. Burke, G. de P. (1974), Thermoluminescence of CaF₂:Mn Exposed at Elevated Temperatures to a Constant Rate of Low-Level Radiation, Proc. of the 4th International Conf. on Luminescence Dosimetry, Kraków, Poland, 1974, Inst. of Nuclear Physics, Kraków, pp. 315-345.
12. Burke, G. de P. (1977), Compilation of Available Studies of TLD Stability, Proceedings of 5th International Conf. on Luminescence Dosimetry, San Paulo, Brazil, 1977, I. Physikalisches Inst., Giessen, W. Germany, pp. 84-93.
13. Cameron, J.R., Suntharalingam, N., and Kenny, G.N. (1968), Thermoluminescent Dosimetry, The University of Wisconsin Press, Madison, WI.

14. Chan, F.K. and Burlin, T.E. (1970), The Energy-Size Dependence of the Response of Thermoluminescent Dosimeters to Photon Irradiation, *Health Physics*, 18, pp. 325-332.
15. Commission of the European Communities (1975), Radiological Protection - 3, Technical Recommendations for the Use of Thermoluminescence for Dosimetry in Individual Monitoring for Photons and Electrons from External Sources, EUR 5358 e.
16. Cluchet, J. and Joffre, H. (1967) Applications of Thermoluminescence Dosimetry in Health Physics, Proc. of the 1st International Conf. on Luminescence Dosimetry, Stanford, CA. 1965, AEC-CONF-650637, pp. 249-258.
17. Dua, S.K., Boulenger, R., Ghoois, L., and Mertens, E. (1971) Mixed Neutron-Gamma Dosimetry, Proc. of the 3rd International Conf. on Luminescence Dosimetry, Risø, Denmark, 1971, Risø Report No. 249, pp. 1074-1088.
18. Ehrlich, M. and Placious, R.C. (1968), Thermoluminescence Response of $\text{CaF}_2:\text{Mn}$ in Polytetrafluoroethylene to Electrons, *Health Physics*, 15, pp. 341-350.
19. Ehrlich, M. (1970), Response of Thermoluminescent Dosimeters to 15 MeV Electrons and ^{60}Co Gamma Rays, *Health Physics*, 18, pp. 287-289.
20. Ehrlich, M. (1971), Influence of Size of $\text{CaF}_2:\text{Mn}$ Thermoluminescence Dosimeters on ^{60}Co Gamma-Ray Dosimetry in Extended Media, Proc. of the 3rd International Conf. on Luminescence Dosimetry, Risø, Denmark, 1971, Risø Report No. 249, pp. 550-560.
21. Endres, G.W.R. and Kocher, L.F. (1968), The Response of Selected Thermoluminescent Material to Fast-Neutron Exposures, Proc. of the 2nd International Conf. on Luminescence Dosimetry, Gatlinburg, TN, 1968, AEC-CONF 680920, pp. 486-500.
22. Fitzsimmons, C.K. and Horn, W.H. (1972), Environmental Monitoring with Thermoluminescent Dosimeters - An Evaluation of the System and a Comparison to Photographic Methods, SWRHL-58, Southwestern Radiological Health Laboratory, U.S. Department of Health, Education and Welfare.
23. Fowler, J.F. and Attix, F.H. (1966), Radiation Dosimetry, Vol. II, 2nd Edition, F.H. Attix, W.C. Roesch, and E. Tochilin, Eds., Academic Press, New York, pp. 269-290.
24. Gayton, F.M., Harvey, J.R. and Jackson, J. H. (1972), Thermoluminescence and Its Applications in Reactor Environments, J. British Nucl. Energy Society, 11, pp. 125-140.
25. Ginther, R.J. and Kirk, R.D. (1956), Thermoluminescence of $\text{CaF}_2:\text{Mn}$ and Its Application to Dosimetry, Report of NRL Progress, Sept 12-20, U.S. Naval Research Laboratory, Washington, D.C.
26. Ginther, R.J. and Kirk, R.D. (1957), The Thermoluminescence of $\text{CaF}_2:\text{Mn}$, J. of the Electrochemical Society, 104, pp. 365-369.

27. Gorbics, S.G. and Attix, F.H. (1964), Brief Evaluation of the U.S. Navy Prototype Thermoluminescent Dosimetry System: Computer Indicator, RADIAC, CP-748(XN-1)/PD and Detector, RADIAC, DT-284(XN-1)6PD, NRL Test and Evaluation Report 37, U.S. Naval Research Laboratory, Washington, D.C.
28. Gorbics, S.G. (1967), Emission Spectra of Various Thermoluminescent Materials, Proc. of the 1st International Conf. on Luminescence Dosimetry, Stanford, CA., 1965, AEC-CONF-650637, pp. 167-182.
29. Gorbics, S.G., Attix, F.H. and Pfaff, J.H. (1967), Temperature Stability of $\text{CaF}_2\text{:Mn}$ and LiF (TLD-100) Thermoluminescent Dosimeters, Int. J. Appl. Rad. and Isotope, 18, pp. 625-630.
30. Gorbics, S.G. and Attix, F.H. (1968), LiF and $\text{CaF}_2\text{:Mn}$ Thermoluminescent Dosimeters in Tandem, Int. J. Appl. Rad. and Isotope, 19, pp. 31-89.
31. Gorbics, S.G., Nash, A.E., and Attix, F.H. (1968), Thermal Quenching of Luminescence in Six Thermoluminescent Dosimetry Phosphors, Proc. of the 2nd International Conf. on Luminescence Dosimetry, Gatlinburg, TN, 1968, AEC-CONF-680920, pp. 587-606.
32. Gorbics, S.G., Nash, A.E. and Attix, F.H. (1969), Thermal Quenching of Luminescence in Six Thermoluminescent Phosphors - I, Int. J. Appl. Rad. and Isotope, 20, pp. 829-841.
33. Gorbics, S.G., Attix, F.H., and Kerris, K. (1973), Thermoluminescent Dosimeters for High-Dose Applications, Health Physics, 25, pp. 499-506.
34. Gross, K.C., McNamara, E.J., and Brinck, W.L. (1976), Factors Affecting the Use of $\text{CaF}_2\text{:Mn}$ Thermoluminescent Dosimeters for Low-Level Environmental Radiation Monitoring, USEPA Report 600/4-76-035.
35. Johnson, T.L. and Attix, F.H. (1967), Pilot Comparison of Two Thermoluminescent Dosimetry Systems with Film Badges in Routine Personnel Monitoring, NRL Technical and Evaluation Report 69, U.S. Naval Research Laboratory, Washington, D.C.
36. Kiefer, H., Maushart, R., and Mejdahl, V. (1969), Radiation Dosimetry, Vol. III, 2nd Edition, F.H. Attix, W.C. Roesch and E. Tochilin, Eds. Academic Press, New York, pp. 584-585.
37. Lin, F.M. and Cameron, J.R. (1968), A Bibliography of Thermoluminescent Dosimetry, Health Physics, 14, pp. 495-514.
38. Lucas, A.C. and Kapsar, B.M. (1974), Operational Importance of Retrapping in $\text{CaF}_2\text{:Mn}$ Dosimeters, Health Physics, 27, 600-603.
39. Marrone, M.J. and Attix, F.H. (1964), Damage Effects in $\text{CaF}_2\text{:Mn}$ and LiF Thermoluminescent Dosimeters, Health Physics, 10, pp. 431-436.
40. Nakajima, T., Hiraoka, T., and Habu, T. (1968), Energy Dependence of LiF and CaF_2 Thermoluminescent Dosimeters for High Energy Electrons, Health Physics, 14, pp. 266-267.

41. Nash, A.E., Attix, F.H., and Schulman, J.H. (1967), Spurious Thermoluminescence of $\text{CaF}_2\text{:Mn}$ and LiF (TLD-100), Proc. of the 1st International Conf. on Luminescence Dosimetry, Stanford, CA. 1965, AEC-CONF-650637, pp. 244-258.
42. Palmer, R.C., Rutland, D., Lagerquist, R., and Blase, E.F. (1966), A Prototype Thermoluminescent Dosimetry System for Personnel Monitoring, Int. J. Appl. Rad. and Isotope, 17, pp. 399-411.
43. Partridge, J.E., Windham, S.T., Lobdell, J.L., and Oppold, J.A. (1973), Suitability of Glass-Encapsulated $\text{CaF}_2\text{:Mn}$ Thermoluminescent Dosimeters for Environmental Radiation Surveillance, USEPA Report ORP/EERF 73-1.
44. Pendurkar, H.K., Boulenger, R., Ghos, L., Nicasi, W., and Mertens, E. (1971), Energy Response of Certain Thermoluminescent Dosimeters and Their Application to the Dose Measurements, Proc. of 3rd International Conf. on Luminescence Dosimetry, Risø, Denmark, 1971, Risø Report No. 249, pp. 1089-1106.
45. Prokić, M. (1971), Determination of the Sensitivity of the $\text{CaF}_2\text{:Mn}$ Thermoluminescent Dosimeter to Neutrons, Proc. of the 3rd International Conf. on Luminescence Dosimetry, Risø, 1971, Risø Report No. 249, pp. 1051-1062.
46. Schulman, J.H., Attix, F.H., West, E.J., and Ginther, R.J. (1960a), New Thermoluminescent Dosimeter, The Review of Scientific Instruments, 31, pp. 1263-1269.
47. Schulman, J.H., Ginther, R.J., Kirk, R.D., and Goulart, H.S. (1960b), Thermoluminescent Dosimeter Has Storage Stability Linearity, Nucleonics, 18, pp. 92-102.
48. Schulman, J.H. (1967a), Survey of Luminescence Dosimetry, Proc. of the 1st International Conf. on Luminescence Dosimetry, Stanford, CA., 1965, AEC-CONF-650637, pp. 3-33.
49. Schulman, J.H. (1967b), Principles of Solid State Luminescence Dosimetry, Solid State and Chemical Radiation Dosimetry in Medicine and Biology, IAEA, Vienna, pp. 3-30.
50. Schulman, J.H., Ginther, R.J., Gorbics, S.G., Nash, A.E., West, E.J., and Attix, F.H. (1969), Anomalous Fading of $\text{CaF}_2\text{:Mn}$ Thermoluminescent Dosimeters, Int. J. of Appl. Rad. and Isotopes, 20, pp. 523-529.
51. Spurný, Z. (1969), Additional Bibliography of Thermoluminescent Dosimetry, Health Physics, 17, pp. 349-354.
52. Spurný, Z. (1971), Simultaneous Estimation of Exposure and Time Elapsed Since Exposure Using Multi peaked Thermoluminescent Phosphors, Health Physics, 21, pp. 755-761.
53. Spurný, Z. and Kvasnicka, J. (1974), Short-Term Fading of Different Thermoluminescent Phosphors, Proc. of the 4th International Conf. on Luminescence Dosimetry, Kraków, Poland, 1974, Institute of Nuclear Physics, Kraków, pp. 255-261.

54. Spurný, Z. and Sulcová, J. (1973), Bibliography of Thermoluminescent Dosimetry (1968-1972), Health Physics, 24, pp. 573-587.
55. Tochilin, E. and Goldstein, N. (1966), Dose Rate and Spectral Measurements from Pulsed X-Ray Generators, Health Physics, 12, pp. 1705-1713.
56. Tochilin, E., Goldstein, N., and Miller, W.G. (1969), Beryllium Oxide as a Thermoluminescent Dosimeter, Health Physics, 16, pp. 1-7.
57. Uran, D., Knezevic, M., Suznik, D., and Kolar, D. (1971), Some Dosimetric properties of Sintered Activated CaF_2 Dosimeters, Proc. of the 3rd International Conf. on Luminescence Dosimetry, Risø, Denmark, 1971, Risø Report No. 249.
58. Wintle, A.G., Aitken, M.J., and Huxtable, J. (1971), Abnormal Thermoluminescence Fading Characteristics, Proc. of the 3rd International Conf. on Luminescence Dosimetry, Kraków, 1974, Inst. of Nuclear Physics, Kraków, Poland.

DISTRIBUTION

Department of Defense

Assistant to the Secretary of Defense
Atomic Energy
Washington, DC 20301
ATTN Executive Assistant

Director
Command & Control Technical Center
Department of Defense
The Pentagon, Rm BE 685
Washington, DC 20301
ATTN C-362 Mr. Adkins

Defense Documentation Center
Cameron Station
Alexandria, VA 22314
ATTN TC

Commander
Defense Electronic Supply Center
1507 Wilmington Pike
Dayton, OH 45444
ATTN DESC-EQE J. Council
ATTN DESC-ECS J. Dennis
ATTN DESC-ECS D. Droege
ATTN DESC-EQE R. Grillmeier
ATTN DESC-ECS D. Hill
ATTN DESC-ECT J. Niles
ATTN DESC-ECP B. Nunke

Director
Defense Logistics Agency
Cameron Station
Alexandria, VA 22314
ATTN DLA-SE
ATTN DLA-QEL J. Slattery

Defense Material Specifications and
Standards Office
Room 105 Dwyer Bldg.
3320 Duke Street
Alexandria, VA 22314
ATTN L. Fox

Director
Defense Nuclear Agency
Washington, DC 20305
ATTN DDST
ATTN TITL
ATTN TISI Archives
ATTN RAEV H. Fitz, Jr.
ATTN RAEV Maj. M. Kemp

Commander
Field Command
Defense Nuclear Agency
Kirtland AFB, NM 87115
ATTN FCPR

Chief
Livermore Division Fld Command DNA
Department of Defense
Lawrence Livermore Laboratory
P.O. Box 808
Livermore, CA 94550
ATTN FCPL

Under Secy of Def for Rsch & Engrg
Department of Defense
Washington, DC 20301
ATTN AE
ATTN SSS

Director
National Security Agency
Ft. Meade, MD 20755
ATTN T. Brown
ATTN G. Daily
ATTN P. Deboy

Director
Defense Supply Agency
DSAH/SE 4A586
Cameron Station
Alexandria, VA 22314

Department of the Army

Commander
Aberdeen Proving Ground
Department of the Army
Aberdeen Proving Ground, MD 21005
ATTN S. Harrison

Director
BMD Advanced Technology Center
Huntsville Office
Department of the Army
P.O. Box 1500
Huntsville, AL 35807
ATTN ATC-T
ATTN BMDSC-TEN R. DeKalb

Deputy Chief of Staff for
Rsch Dev and Acq
Department of the Army
Washington, DC 20310
ATTN LTC G. Ogden

Commander
Harry Diamond Laboratories
Department of the Army
2800 Powder Mill Road
Adelphi, MD 20783

ATTN DEHLD-N-P F. Balicki
ATTN DEHLD-N-RBH H. Eisen
ATTN DEHLD-N-RBH J. Halpin
ATTN DELHD-N-RBH J. McGarrity

Commander
Redstone Scientific Information CTR
U.S. Army R & D Command
Redstone Arsenal, AL 35809
ATTN Chief, Documents

Commander
U.S. Army Armament Research &
Development Command
Dover, NJ 07801
ATTN DRDAR-LCA-PD

Project Officer
U.S. Army Electronics Rsch & Dev Command
Fort Monmouth, NJ 07703
ATTN D. Huewe

Commander
U.S. Army Nuclear & Chemical Agency
7500 Backlick Road
Building 2073
Springfield, VA 22150
ATTN MONA-WE Maj A. Lind
ATTN Nuc Surv Cmte Col A. Lowrey

Commander
White Sands Missile Range
Department of the Army
White Sands Missile Range, NM 88002
ATTN STEWS-TE-AN T. Leura
ATTN STEWS-TE-AN Maj. L. Meason
ATTN STEWS-TE-NT M. Squires
ATTN R. Williams

Department of the Navy

Chief of Naval Operations
Department of the Navy
Washington, DC 20350
ATTN OP985F

Chief of Naval Research
Ballston Center Tower #1
800 N. Quincy Street
Arlington, VA 22217
ATTN Code 220 D. Lewis
ATTN Code 427 L. Cooper

Commander
Naval Air Systems Command
Washington, DC 21360
ATTN Air 350F

Commander
Naval Electronic Systems Comd
Department of the Navy
Washington, DC 20360
ATTN 5045.11 C. Suman

Commander
Naval Ocean Systems Center
San Diego, CA 92152
ATTN Code 4471 (Tech Lib)

Superintendent (Code 1424)
Naval Postgraduate School
Monterey, CA 93940
ATTN Code 2124 Tech Rpts Librarian

Commanding Officer
Naval Research Laboratory
Washington, DC 20375
ATTN Code 6701 J. Brown
ATTN Code 5210 J. Davey
ATTN Code 6627 C. Guenzer
ATTN Code 5216 H. Hughes
ATTN Code 6600 J. McElhinney
ATTN Code 6650 A. Namenson
ATTN Code 6601 E. Wolicki

Commander
Naval Sea Systems Command
Washington, DC 20362
ATTN SEA-9931 R. Lane

Commander
Naval Ship Engineering Center
Washington, DC 20362
ATTN Code 6174D2

Commander
Naval Surface Weapons Center
White Oak, Silver Spring, MD 20910
ATTN J. Downs
ATTN R. Jenkins
ATTN Code WA52 R. Smith

Commander
Naval Weapons Center
China Lake, CA 93555
ATTN Code 533 (Tech Lib)

Commanding Officer
Naval Weapons Evaluation Facility
Kirtland Air Force Base
Albuquerque, NM 87117
ATTN Code AT-6

Commanding Officer
Naval Weapons Support Center
Crane, IN 47522

ATTN Code 7024 T. Ellis
ATTN Code 7024 J. Munarin
ATTN Code 7024 J. Ramsey

Director
Strategic Systems Project Office
Department of the Navy
Washington, DC 20376
ATTN Code 2015
ATTN Code 230 D. Gold
ATTN Code 2701 J. Pitsenberger
ATTN Code 2730 P. Spector

Department of the Air Force

Commander
Air Force Aero-Propulsion Laboratory, AFSC
Wright Patterson AFB, OH 45433
ATTN POD P. Stover

Commander
Air Force Avionics Laboratory, AFSC
Wright-Patterson AFB, OH 45433
ATTN TEA R. Conklin
ATTN DHE H. Hennecke

Commander
Air Force Institute of Technology
Wright-Patterson AFB, OH 45433
ATTN ENP C. Bridgman

Commander
Air Force Materials Laboratory, AFSC
Wright-Patterson AFBV, OH 45433
ATTN LTE

Headquarters
Air Force Systems Command
Andrews AFB
Washington, DC 20334
ATTN DLCA
ATTN Capt. T. Seale
ATTN XRLA Maj. R. Stead

Air Force Technical Applications Center
Patrick AFB, FL 32925
ATTN TAE

Commander
Air Force Weapons Laboratory, AFSC
Kirtland AFB, NM 87117

ATTN SUL
ATTN ELP J. Ferry
ATTN ELP Capt. M. Knoll
ATTN ELP Lt. Col. A. Loggins
ATTN ELP R. Maier
ATTN ELP J. Mullis

Headquarters
Electronic Systems Division
Air Force Systems Command
Hanscom AFB, MA 01731
ATTN Technical Library

Commander
Foreign Technology Division
Air Force Systems Command
Wright-Patterson AFB, OH 45433
ATTN FTD/PDJV
ATTN ETDP B. Ballard

Air Force Technical Applications Center
Patrick AFB, FL 32925
ATTN TAE

Commander
Ogden ALC
Department of the Air Force
Hill AFB, UT 84406
ATTN MMETH Maj. R. Blackburn
ATTN MMGRW G. Fry
ATTN MMEDD C. Graham
ATTN MMIFM S. Mallory
ATTN MMETH Capt. R. Padfield
ATTN MMIFM D. Stanger
ATTN MMETH Maj. F. Walter

Commander
Rome Air Development Center
RADC/RBRM
Griffiss AFB, NY 13441
ATTN RBRM J. Brauer
ATTN RBRP C. Lane

Commander
Rome Air Development Center
Hanscom AFB, MA 01731
ATTN ESR R. Buchanan
ATTN ETS R. Dolan
ATTN ESE A. Kahan
ATTN ESR W. Shedd
ATTN ESR P. Vail

Commander
Space & Missile Systems Command/SK
Post Office Box 92960
Worldway Postal Center
Los Angeles, CA 90009
ATTN AQM
ATTN AQT Lt. Col. K. Blakney
ATTN DYS Maj. L. Darda
ATTN SZJ Maj. R. Davis
ATTN C. Kelly
ATTN MNNL Lt. Col. S. Kennedy
ATTN SKF P. Stadler

Commander
Space and Missile Systems Organization
Norton AFB, CA 92409
ATTN MNNG
ATTN MNNH Capt. J. Tucker

National Aeronautics and Space Agency

NASA Headquarters
Washington, D.C. 20546
ATTN J. Murphy

Director
NASA Ames Research Center
M/S 2445
Moffett Field, CA 90035
ATTN G. DeYoung

Director
NASA Goddard Space Flight Center
Greenbelt, MD 20771
ATTN Code 311 J. Adolphsen
ATTN Code 755.1 V. Danchenko

NASA-Lewis Research Center
210100 Brook Park Rd
Cleveland, Ohio 44135
ATTN M. Baddour

Director
NASA Marshall Space Flight Center
Huntsville, AL 35812
ATTN EG02
ATTN EC43 L. Hamiter
ATTN M. Nowakowski
ATTN H. Yearwood

Department of Energy

Albuquerque Operations Office
P.O. Box 5400
Albuquerque, NM 87115
ATTN Document Control for WSSB

University of California
Lawrence Livermore Laboratory
P.O. Box 808
Livermore, CA 94550
ATTN Doc Con for Technical
Information Dept.

Los Alamos Scientific Laboratory
P.O. Box 1663
Los Alamos, NM 87545
ATTN Doc Con for J. Freed

Office of Military Application
Department of Energy
Washington, DC 20545
ATTN Doc Con for Classified
Library

Sandia Laboratories
P.O. Box 5800
Albuquerque, NM 87185
ATTN J. Barnum
ATTN F. Coppage
ATTN W. Dawes
ATTN R. Gregory
ATTN J. Hood

Solar Energy Research Institute
Golden, Colorado 80413
ATTN A. Stanley

Department of Commerce

Director
National Bureau of Standards
Washington, D.C. 20234

ATTN A353 Phy S. Chappell
ATTN A361 Tech J. French
ATTN A327 Tech K. Galloway
ATTN C216 RadP J. Humphreys
ATTN A327 Tech J. Mayo-Wells
ATTN A353 Tech W. Bullis
ATTN A327 Tech R. Scace

Other Government

Central Intelligence Agency
Hq Bldg, Rm. 5G48
Washington, DC 20505
ATTN RD/SI

Department of Defense Contractors

Advanced Microdevices, Inc.
901 Thompson Place
Sunnyvale, CA 94086
ATTN J. Schlageter

Aerojet Electro-Systems Co.
Division of Aerojet-General Corp.
P.O. Box 296
1100 W. Hollyvale Drive
Azusa, CA 91702
ATTN T. Hanscome

Aeronutronic-Ford Corporation
Division 3939 Fabian Way
Palo Alto, CA 94303
ATTN D. Cadle

Aeronutronic Ford Corporation
Electronic Technology Department
Ford Road
Newport Beach, CA 92663
ATTN J. Davison

Aerospace Corporation
P.O. Box 92957
Los Angeles, CA 90009
ATTN S. Bower
ATTN D. Fresh
ATTN W. Willis

ARACOR
1223 E. Arques Avenue
Sunnyvale, CA 94086
ATTN R. Armistead

Battelle Memorial Institute
505 King avenue
Columbus, OH 43201
ATTN R. Thatcher

BDM Corporation
2600 Yale Boulevard, S.E.
Albuquerque, NM 87106
ATTN D. Alexander
ATTN R. Pease
ATTN D. Wunch

Bendix Corporation
Flight Systems Division
Dept. 7831
Teterboro, NJ 07608
ATTN E. Meeder

Boeing Aerospace Company
MS-2R-00
P.O. Box 3999
Seattle, WA 98124
ATTN I. Arimura
ATTN D. Egelkrout
ATTN A. Johnston
ATTN C. Rosenberg
ATTN W. Rumpza

Burr-Brown Research Corporation
International Airport Ind. Park
P.O. Box 11400
Tucson, AZ 85734
ATTN H.C. Smith

California Institute of Technology
Jet Propulsion Laboratory
4800 Oak Grove Drive
Pasadena, CA 91103
ATTN W. Price
ATTN A. Shumka
ATTN A. Stanley

Charles Stark Draper Laboratories
555 Technology Square
Mail Station 62
Cambridge, MA 02139
ATTN R. Bedingfield
ATTN P. Greiff
ATTN C. Lai
ATTN R. Ledger
ATTN A. Schutz

Cincinnati Electronics Corp.
2630 Glendale-Milford Road
Cincinnati, OH 45241
ATTN L. Hammond
ATTN C. Stump

Control Data Corporation
P.O. Box 0
Minneapolis, MN 55440
ATTN J. Meehan

Denver Research Institute
University of Colorado
P.O. Box 10127
Denver, CO 80210
ATTN F. Venditti

E-Systems, Inc.,
P.O. Box 6118
Dallas, TX 75222
ATTN K. Reis

EMM Corporation
3883 No. 28th Avenue
Phoenix, AZ 85017
ATTN F. Krch

Exp. & Math. Physics Consultants
P.O. Box 66331
Los Angeles, CA 90066
ATTN T. Jordan

Fairchild Camera and Instrument Corp.
464 Ellis Street
Mountain View, CA 94040
ATTN D. Myers
ATTN R. Marshall

Ford Aerospace & Communications Corp.
Ford & Jamboree Roads
Newport Beach, CA 92663
ATTN Tech Info Services

Franklin Institute
20th Street and Parkway
Philadelphia, PA 19103
ATTN R. Thompson

Garrett Corporation
P.O. Box 92248
9851 Sepulveda Blvd
Los Angeles, CA 90009
ATTN R. Weir

General Dynamics Corporation
Convair Aerospace Division
P.O. Box 1128
San Diego, CA 92112
ATTN W. Hansen

General Dynamics Corporation
Aerosystems Division
P.O. Box 748
Ft. Worth, TX 76101
ATTN O. Wood
ATTN R. Fields

General Electric Company
P.O. Box 5000
Binghamton, NY 13902
ATTN D. Pepin

General Electric Company
Aerospace Elec Sys Dept
French Road Plant
Utica, NY 13503
ATTN D. Cole
ATTN W. Patterson
ATTN J. Gibson

General Electric Company
Aircraft Engine Business Group
Evendale Plant, Int Hwy 75S
Cincinnati, OH 45215
ATTN R. Hellen

General Electric Company
Ordnance Systems
100 Plastics Avenue
Pittsfield, MA 01201
ATTN J. Reidl

General Electric Company
Re-entry & Environmental Systems Div.
P.O. Box 7722
3198 Chestnut Street
Philadelphia, PA 19101
ATTN R. Benedict
ATTN W. Palchefskey, Jr.
ATTN W. Patterson
ATTN Tech. Lib.

General Electric Company
Valley Forge Space Center
P.O. Box 8555
Philadelphia, PA 19101
ATTN R. Casey
ATTN D. Long
ATTN J. Peden
ATTN L. Sivo

General Electric Company--Tempo
2560 Huntington Avenue
Suite 300
Alexandria, VA 22303
ATTN W. Alfonte

General Electric Company--Tempo
Center for Advanced Studies
816 State Street (P.O. Drawer QQ)
Santa Barbara, CA 93102
ATTN DASIAC E. Espig

General Research Corporation
Santa Barbara Division
P.O. Box 6770
Santa Barbara, CA 93111
ATTN R. Hill
ATTN Tech. Inf. Off.

Georgia Institute of Technology
Georgia Tech Research Institute
Atlanta, GA 30332
ATTN R. Curry

Goodyear Aerospace Corporation
Arizona Division
Litchfield Park, AZ 85340
ATTN Security Control Station

Grumman Aerospace Corporation
South Oyster Bay Road
Bethpage, NY 11714
ATTN J. Rogers

GTE Sylvania, Inc.
Electronics Systems GRP-Eastern Div
77 A Street
Needham, MA 02194
ATTN C. Thornhill
ATTN L. Pauplis

GTE Sylvania Inc.
189 B Street
Needham Heights, MA 02194
ATTN P. Fredrickson
ATTN H & V Group
ATTN C. Ramsbottom
ATTN J. Waldron
ATTN H. Ullman

Harris Corporation
Harris Semiconductor Division
P.O. Box 883
Melbourne, FLA 32901
ATTN J. Cornell
ATTN C. Anderson

Honeywell Inc.
Aerospace & Defense Group
13350 U.S. Highway 19 North
St. Petersburg, FL 33733
ATTN C. Cerulli

Honeywell, Inc.
Government & Aeronautical Prod. Div.
600 2nd Street, North
Hopkins, MN 55343
ATTN K. Gaspard

Honeywell, Inc.
Government & Aeronautical Pro.
2600 Ridgway Road
Minneapolis, MN 55440
ATTN R. Gumm

Honeywell, Inc.
Radiation Center
2 Forbes Road
Lexington, MA 02173
ATTN Technical Library

Hughes Aircraft Company
Centinela and Teale
Culver City, CA 90230
ATTN R. McGowan
ATTN J. Singletary

Hughes Aircraft Company
El Segundo Site
P.O. Box 92919
Los Angeles, CA 90009
ATTN E. Smith
ATTN W. Scott

IBM
Department L99, Bldg. 002A
Route 17C
Owego, NY 13827
ATTN F. Tietse
ATTN H. Mathers
ATTN T. Martin

IBM Research Laboratories
Box 218
Yorktown Heights, NY 10598
ATTN J. Ziegler

IIT Research Institute
10 West 35th Street
Chicago, IL 60616
ATTN I. Mindel

Institute for Defense Analyses
400 Army-Navy Drive
Arlington, VA 22202
ATTN Tech. Info. Services

Intel Corporation
3065 Bowers Avenue
Mail Stop 1-156
Santa Clara, CA 95051
ATTN M. Jordan

International Tel. & Telegraph Corp.
500 Washington Avenue
Nutley, NJ 07110
ATTN A. Richardson
ATTN Dept 608

Intersil Inc.
3250 Scott Boulevard
Santa Clara, CA 95051
ATTN D. MacDonald

IRT Corporation
P.O. Box 81087
San Diego, CA 92138
ATTN J. Harrity

JAYCOR
1401 Camino del Mar
Del Mar, CA 92014
ATTN L. Scott

Johns Hopkins University
Applied Physics Laboratory
Johns Hopkins Road
Laurel, MD 20810
ATTN P. Partridge

Kaman Sciences Corporation
P.O. Box 7463
Colorado Springs, CO 80933
ATTN J. Lubell

Litton Systems, Inc.
Guidance and Control Systems Division
5500 Canoga Avenue
Woodland Hills, CA 91364
ATTN G. Maddox

Lockheed Missiles and Space Co., Inc.
P.O. Box 504
Sunnyvale, CA 94088
ATTN P. Bene
ATTN H. Phillips
ATTN E. Smith
ATTN C. Thompson

Lockheed Missiles and Space Co., Inc.
Research Division
3251 Hanover Street
Palo Alto, CA 94304
ATTN J. Crowley
ATTN J. Smith

Martin Marietta Corporation
Denver Division
P.O. Box 179
Denver, CO 80201
ATTN E. Carter

Martin Marietta Corporation
MP 148 Orlando Division
P.O. Box 5837
Orlando, FL 32805
ATTN W. Brockett
ATTN H. Cates
ATTN R. Gaynor
ATTN W. Janocko

McDonnell Douglas Corporation
5301 Bolsa Avenue
Huntington Beach, CA 92647
ATTN D. Fitzgerald
ATTN J. Holmgren

McDonnell Douglas Corporation
Standards Engineering
P.O. Box 516
St. Louis, MO 63166
ATTN M. Stitch
ATTN D. Dohm
ATTN Library

McDonnell Douglas Corp.
3855 Lakewood Boulevard
Long Beach, CA 90846
ATTN Tech. Lib.

Messenger, George C.
Consulting Engineer
3111 Bel Air Drive, 7-F
Las Vegas, Nevada 89109

Mission Research Corporation
1150 Silverado Street
P.O. Box 1209
La Jolla, CA 92038
ATTN J. Azarewicz
ATTN R. Berger
ATTN J. Raymond
ATTN V. Van Lint

Mission Research Corp.
735 State Street
Santa Barbara, CA 93202
ATTN C. Longmire

Massachusetts Institute of Technology
Lincoln Laboratory
P.O. Box 73
Lexington, MA 02173
ATTN P. McKenzie
ATTN Library A-082

Mitre Corporation
P.O. Box 208
Bedford, MA 01730
ATTN M. Fitzgerald

Motorola Government Electronics Division
8201 E. McDowell Road
Scottsdale, AZ 85252
ATTN A. Christensen

Motorola Semiconductor Products, Inc.
P.O. Box 20912
Phoenix, AZ 85036
ATTN L. Clark

National Semiconductor Corp.
2900 Semiconductor Drive
Santa Clara, CA 95051
ATTN R. Wang
ATTN A. London

New Mexico University
Elec. Eng. & Computer Science Dept
Albuquerque, NM 87131
ATTN H. Southward

Northrop Corporation
Northrop Research & Technology Center
1 Research Park
Palos Verdes Peninsula, CA 90274
ATTN J. Srour

Northrop Corporation
Electronic Division Headquarters
1 Research Park
Palos Verdes Peninsula, CA 90274
ATTN T. Jackson
ATTN P. Eisenberg

Northrop Corporation
Electronic Division
2301 West 120th Street
Hawthorne, CA 90250
ATTN L. Apodaca
ATTN P. Gardner
ATTN D. Strobel

Physics International Company
2700 Merced Street
San Leandro, CA 94577
ATTN Div 6000
ATTN J. Huntington
ATTN J. Shea

R&D Associates
P.O. Box 9695
4640 Admiralty Way
Marina del Rey, CA 90291
ATTN C. Rogers
ATTN R. Poll

Rand Corporation
1700 Main Street
Santa Monica, CA 90406
ATTN C. Crain

Raytheon Company
Advanced Design Dept.
Hartwell Road
Bedford, MA 01730
ATTN J. Ciccio

Raytheon Company
528 Boston Post Road
Sudbury, MA 01776
ATTN H. Flescher
ATTN A. Van Doren

RCA Corporation
Camden Complex
Front & Cooper Streets
Camden, NJ 08012
ATTN E. Van Keuren

RCA Corporation
David Sarnoff Research Center
P.O. Box 432
Princeton, NJ 08540
ATTN D. OConnor
ATTN Office N103

RCA Corporation
Missile & Surface Radar
Bldg. 108-239, Marne Highway
Moorestown, NJ 08057
ATTN R. Killion

RCA Corporation
Government Systems Division
ASTRO Electronics Division
P.O. Box 800, Locust Corner
Princeton, NJ 08540
ATTN G. Bruckar
ATTN V. Mancino

RCA Corporation
Solid State Division
Box 3200
Somerville, NJ 08876
ATTN W. Allen

Rensselaer Polytechnic Institute
P.O. Box 965
Troy, NY 12181
ATTN R. Gutmann

Research Triangle Institute
P.O. Box 23194
Research Triangle Park, NC 27709
ATTN Eng Div M. Simons Jr.

Rockwell International Corp.
5701 West Imperial Highway
Los Angeles, CA 90009
ATTN TIC BA08
ATTN T. Yates

Rockwell International Corp.
Autonetics Group
3370 Miraloma Avenue
P.O. Box 3105
Anaheim, CA 92803
ATTN J. Bell
ATTN V. DeMartino
ATTN T. Oki
ATTN V. Strahan

Rockwell International Corp.
Space Division
12214 South Lakewood Boulevard
Downey, CA 90241
ATTN D. Stevens

Sanders Associates, Inc.
95 Canal Street
Nashua, NH 03060
ATTN M. Aitel
ATTN L. Brodeur

Science Applications, Inc.
2860 S. Circle Drive
Suite 2224
Colorado Springs, CO 80906
ATTN D. Stribling

Science Applications, Inc.
1200 Prospect Street
P.O. Box 2351
La Jolla, CA 92038
ATTN J. Naber
ATTN V. Orphan
ATTN V. Verbinski

Science Applications, Inc.
8400 Westpark Drive
McLean, VA 22101
ATTN W. Chadsey

Singer Company-Kearfott Div.
Dept. 5830
150 Totowa Road
Wayne, NJ 07470
ATTN R. Spiegel

Singer Company
Kearfott Division
1150 McBride Avenue
Little Falls, NJ 07424
ATTN J. Brinkman

Sperry Rand Corporation
Sperry Microwave Electronics
P.O. Box 4648
Clearwater, FL 33518
ATTN Engineering Laboratory

Sperry Rand Corporation
Sperry Division
Marcus Avenue
Great Neck, NY 11020
ATTN C. Craig
ATTN P. Maraffino
ATTN F. Scaravaglione
ATTN R. Viola

Sperry Rand Corporation
Sperry Flight Systems
P.O. Box 21111
Phoenix, AZ 85036
ATTN D. Schow

Sperry Univac
Univac Park
P.O. Box 3525
St. Paul, MN 55165
ATTN J. Inda

Spire Corporation
P.O. Box D
Bedford, MA 01730
ATTN R. Little

SRI International
333 Ravenswood Avenue
Menlo Park, CA 94025
ATTN A. Whitson
ATTN P. Dolan

Teledyne Ryan Aeronautical
Box 311
San Diego, CA 92112
ATTN J. Rawlings

Texas Instruments, Inc.
13500 N. Central Expressway
P.O. Box 5474, M.S. 262
Dallas, TX 75222
ATTN A. Peletier
ATTN R. Stehlin

TRW Incorporated
Defense and Space Systems Group
One Space Park
Redondo Beach, CA 90278
ATTN O. Adams
ATTN P. Guilfoyle
ATTN H. Haid
ATTN H. Holloway
ATTN R. Kingsland
ATTN A. Pavelko
ATTN R. Schnieder
ATTN A. Witteles

TRW Defense & Space Sys Group
San Bernardino Operations
P.O. Box 1310
San Bernardino, CA 92402
ATTN M. Gorman
ATTN R. Kitter
ATTN F. Fay

TRW Systems and Energy
P.O. Box 368
Clearfield, Utah 84015
ATTN J. Spehar
ATTN D. Millward

Vought Corporation
P.O. Box 5907
Dallas, TX 75222
ATTN Library
ATTN Tech Data Ctr
ATTN R. Tomme

Westinghouse Electric Corporation
Radiation Effects Technology
P.O. Box 1521 M/S 3330
Baltimore, MD 21203
ATTN D. Crichi
ATTN H. Kalapaca

Westinghouse Electric Corporation
Aerospace Division
P.O. Box 746, M/S 292
Baltimore, MD 21203
ATTN L. McPherson

Other Organizations

Aerospace Industries Association
of America Inc.
1725 E. Sales Street, N.W.
Washington, DC 20036
ATTN S. Siegel

Electronic Industries Association
2001 Eye Street, N.W.
Washington, DC 20006
ATTN J. Hessman

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET		1. PUBLICATION OR REPORT NO. <u>14</u> NBSIR-79-1723	2. Gov't Accession No.	3. Recipient's Accession No.
4. TITLE AND SUBTITLE STANDARD PROCEDURE FOR USE OF THERMOLUMINESCENCE DOSIMETRY IN RADIATION-HARDNESS TESTING OF ELECTRONIC DEVICES			5. Publication Date May 1979	6. Performing Organization Code <u>11</u> Mar 79
7. AUTHOR(S) J.C. Humphreys and S.E. Chappell			8. Performing Organ. Report No.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, D.C. 20234			10. Project/Task/Work Unit No.	
12. Sponsoring Organization Name and Complete Address (Street, City, State, ZIP) Defense Nuclear Agency Washington, D.C. 20305			11. Contract/Grant No. <u>12</u> 74p.	
			13. Type of Report & Period Covered	
			14. Sponsoring Agency Code	
15. SUPPLEMENTARY NOTES <u>9</u> Interim rept.				
16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.) A standard recommended practice for the use of thermoluminescence dosimetry (TLD) systems has been developed. It is intended for the use of facilities that are engaged in the radiation-hardness testing of electronic components and systems. The practice has been written in the form of an ASTM standard for determination of absorbed dose in a medium as a result of photon or electron irradiation. It covers various aspects of TLD systems such as performance testing, dose calibration, and use procedures and precautions. A selected bibliography of TLD characteristics is included. <u>16</u> Z990AXT <u>17</u> D072 411 036 LHM				
17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons) Electronic devices; electrons, photons, radiation hardness; standard practice; thermoluminescence dosimeters				
18. AVAILABILITY ☒ Unlimited ☐ For Official Distribution. Do Not Release to NTIS ☐ Order From Sup. of Doc., U.S. Government Printing Office Washington, D.C. 20402, SD Cat. No. C13 ☒ Order From National Technical Information Service (NTIS) Springfield, Virginia 22151		19. SECURITY CLASS (THIS REPORT) UNCLASSIFIED	21. NO. OF PAGES 74	
		20. SECURITY CLASS (THIS PAGE) UNCLASSIFIED	22. Price \$5.25	