


R82-955750-4

AD A119310

**FLOW DISTRIBUTION CONTROL CHARACTERISTICS
IN MARINE GAS TURBINE WASTE-HEAT
STEAM GENERATORS**

**Annual Technical Report
July 1982**

**Ho-Tien Shu
Simion C. Kuc, Principal Investigator**



**Prepared for
The Office of Naval Research, Arlington, Virginia
Under Contract No. N00014-80-C-0476, Modification P00002**

DTIC FILE COPY



**UNITED
TECHNOLOGIES
RESEARCH
CENTER**

East Hartford, Connecticut 06108


82 09 16 042-1

BEST AVAILABLE COPY

R82-955750-4

Flow Distribution Control Characteristics
in Marine Gas Turbine Waste-Heat
Recovery Systems
Phase II - Waste-Heat Steam Generators

Annual Technical Report



Simion C. Kuo
Principal Investigator
(203) 727-7258

Prepared for:
The Office of Naval Research, Arlington, Virginia
Under Contract No. N00014-80-C-0476
Mr. M. Keith Ellingsworth, Scientific Officer

July 1982

BEST AVAILABLE COPY

REPRODUCTION QUALITY NOTICE

This document is the best quality available. The copy furnished to DTIC contained pages that may have the following quality problems:

- **Pages smaller or larger than normal.**
- **Pages with background color or light colored printing.**
- **Pages with small type or poor printing; and or**
- **Pages with continuous tone material or color photographs.**

Due to various output media available these conditions may or may not cause poor legibility in the microfiche or hardcopy output you receive.

☐

If this block is checked, the copy furnished to DTIC contained pages with color printing, that when reproduced in Black and White, may change detail of the original copy.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER UTRC R82-955750-4	2. GOVT ACCESSION NO. AD-A119310	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) Flow Distribution Control Characteristics in Marine Gas Turbine Waste-Heat Recovery System (Phase II - Flow Distribution Control in Waste-Heat Steam Generators)		5. TYPE OF REPORT & PERIOD COVERED Annual Technical Report July 1981 to July 1982
7. AUTHOR(s) Simion C. Kuo Ho-Tien Shu		6. PERFORMING ORG. REPORT NUMBER UTRC R81-955750-4
9. PERFORMING ORGANIZATION NAME AND ADDRESS United Technologies Research Center Silver Lane, East Hartford, CT 06108		8. CONTRACT OR GRANT NUMBER(s) M00014-80-C-0476 Modification P00002
11. CONTROLLING OFFICE NAME AND ADDRESS Office of Naval Research 800 North Quincey Street Arlington, VA 22217		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS Program Element: 61153N Project: RRO 24-3 Task Area: RRO 24-03-02 Work Unit: NR 097-411
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)		12. REPORT DATE July 1982
		13. NUMBER OF PAGES 138
		15. SECURITY CLASS. (of this report) Unclassified
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; Distribution unlimited		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report) Same as block 16		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Waste-Heat Steam Generator Marine Gas Turbine Exhausts Waste-Heat Recovery Flow Maldistribution Flow Distribution Control Heat Exchanger Model Waste-Heat Boiler		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) This technical report is concerned with the effect of flow distribution control on the design and performance of marine gas turbine waste-heat steam generators. Major design requirements and critical problems associated with a waste-heat steam generator were reviewed, and an existing two-dimensional heat exchanger model based on the compact heat exchanger design criteria and		

DD FORM 1 JAN 73 1473

EDITION OF 1 NOV 65 IS OBSOLETE
S/N 0102-LF-014-6601

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

BEST AVAILABLE COPY

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

the relaxation approach was modified and updated to estimate the waste-heat steam generator performance at any inlet gas flow distribution. Performance estimates were made of the steam generator using a uniform velocity distribution, and also actual flow distribution data available (at the diffuser inlet) with and without flow distribution controls, all at design and off-design operating conditions of the gas turbine engine. Results of the study indicate that the exit steam temperatures of the baseline waste-heat steam generator with and without flow distribution controls would be 725°F and 450°F, respectively, for a constant design flow rate of 7.9 lb/sec, and for a constant exit temperature of 700°F, the water flow rates would be 8.1 lb/sec and 6.6 lb/sec, respectively. A suggested experimental program to provide information for comparison with the analytical results, and to obtain applicable operational experience is also described in this report.

FOREWORD

The work described in this Annual Technical Report was performed at the United Technologies Research Center (UTRC) under Contract N00014-80-C-0476, Modification P00002, entitled "Study of Flow Distribution Control Characteristics in Marine Gas Turbine Waste-Heat Recovery Systems", for the Office of Naval Research (ONR). This report summarizes results obtained for the Phase II (second year) study on flow distribution control characteristics in waste-heat steam generators which was preceded by the first-year study on diffusers. Dr. Simion C. Kuo is the Principal Investigator for this contract program, and Dr. Ho-Tien Shu is the major contributor to this phase of the study. The computer program used in analyzing the steam-generator was derived from an existing Fuel Vaporization Model originally developed by Messrs. Chiappetta and Szetela, both of UTRC.

The research contract was signed by ONR on July 23, 1980, and the Scientific Officer is Mr. M. Keith Ellingsworth, Mechanics Division, ONR, Arlington, Virginia. Valuable guidance and comments received from Mr. Ellingsworth are gratefully appreciated.

Accession For	
NTIS COPY	<input checked="" type="checkbox"/>
DTIC	<input type="checkbox"/>
Unpublished	<input type="checkbox"/>
Classification	
By	
Distribution	
Availability Codes	
Avail. and/or	
Dist. Statement	
A	



BEST AVAILABLE COPY

R82-955750-4

R82-955750-4

Flow Distribution Control Characteristics in Marine Gas
Turbine Waste-Heat Recovery Systems

Phase II - Flow Distribution Control in Waste-Heat Steam Generators

TABLE OF CONTENTS

	<u>Page</u>
SUMMARY	1
RESULTS AND CONCLUSIONS	2
INTRODUCTION	4
REFERENCES	6
SECTION I - SELECTION OF CANDIDATE STEAM GENERATOR CONFIGURATIONS	7
I.1 Design Concepts and Considerations of Marine Gas Turbine Waste Heat-Boilers	7
I.2 Waste-Heat Boiler Design Data and Critical Technology Problems	11
I.3 Selection of Candidate Steam Generator Configuration	13
REFERENCES	14
TABLES	16
FIGURES	20
SECTION II - PERFORMANCE ANALYSIS OF FLOW DISTRIBUTION CONTROL ON WASTE-HEAT STEAM GENERATOR	24
II.1 Formulation of Analytical Model	24
II.2 Design and Off-Design Flow Conditions	32
II.3 Parametric Performance Analyses	32
II.4 Off-Design Performance Analysis	34
II.5 Baseline Waste-Heat Boiler	35
II.6 Effect of Flow Distribution Control on Baseline Waste-Heat Boiler	37
REFERENCES	39
TABLES	40
FIGURES	41

R82-955750-4

Flow Distribution Control Characteristics in Marine Gas
Turbine Waste-Heat Recovery Systems

Phase II - Flow Distribution Control in Waste-Heat Steam Generators

TABLE OF CONTENTS (Cont'd)

	<u>Page</u>
SECTION III - FORMULATION OF EXPERIMENT PROGRAM AND SCHEDULE	73
III.1 Technical Information and Operational Experience	
Desired from the Experimental Program	73
III.2 Experiment Program Plan	75
III.3 Overall Program Schedule and Effort	79
TABLES	80
FIGURES	82
APPENDIX A - DESCRIPTIONS OF WASTE HEAT BOILER COMPUTER PROGRAM	84
A.1 Program Structure	84
A.2 Descriptions of Input Data	85
A.3 Sample Results	88
A.4 List of Computer Programs	88
TABLES	90
DISTRIBUTION LIST	135

SUMMARY

The objective of this study was to investigate the effect of flow distribution control on the design and performance of marine gas turbine waste-heat steam generators. The applicable steam generator design concepts and general design consideration were reviewed and critical problems associated with the design of marine waste-heat steam generators were identified. A once-through counter crossflow heat exchanger was selected as the candidate waste-heat steam generator for recovering the waste heat from the exhaust of a marine gas turbine. A two-dimensional heat exchanger model suitable for the study objective was formulated and computerized. Parametric performance analyses were made of the waste-heat steam generators for four different tube arrangements from which the most desirable design was selected (as baseline waste-heat steam generator) for further investigation. The effect of flow distribution control on the baseline waste-heat boiler performance, under both design and off-design gas turbine operating conditions were analyzed. It was estimated that, at design condition without flow distribution control, the overall heat transfer rate would be approximately 16 percent less than that obtainable based on uniform flow distribution. With appropriate flow distribution control (using one flow guide vane and one flow injection for boundary layer separation control), the boiler efficiency can be expected to improve by approximately 20 percent as compared with that of the uncontrolled case. Based on the results of this analytical study, a suggested experiment program was formulated for ONR consideration.

This study program was conducted by the Thermal Engineering Group at UTRC under Contract N00014-80-C-0476, Modification P00002, from the Office of Naval Research, Mechanics Division, Arlington, Virginia.

RESULTS AND CONCLUSIONS

- . The design of a gas turbine waste-heat boiler or hot-water heater depends on the gas turbine model to which it would be mated, its end-use, and space and economic criteria. Units designed for industrial applications have been custom-built to fit different configurations using mostly finned carbon steel tubes.
- . For naval propulsion applications, a once-through forced-circulation steam generator design should be selected because of stability, reliability, compactness and lightweight considerations. In order to achieve maximum performance, the gas-side pressure loss for the steam generator should be limited to 200 mm water-gage, and the pinch-point temperature should not be less than 50°F.
- . The analytical model developed to predict the waste-heat boiler performance is based on the use of compact heat exchanger design criteria and the relaxation-approach method. The model is capable of estimating the waste-heat boiler performance at any inlet gas flow distribution.
- . Results of an extensive parametric performance analysis indicate that among the four candidate tube size and arrangements combinations, a circular finned tube with the following dimensions is the most effective for the baseline waste-heat boiler design: tube length =290 ft; outside diameter =0.774 inch; fin diameter =1.403 inches; fins per inch =9; fin arrangement: staggered with longitudinal pitch =1.75 inches and transverse pitch =1.557 inches.
- . At its design condition (corresponding to a 50-percent power output of the gas turbine), the baseline waste-heat steam generator with a uniform gas flow distribution is estimated to be able to generate approximately 28000 pound per hour of superheated steam at 700°F and 300 psia. At this condition, the calculated overall heat transfer rate would be approximately 10000 Btu/sec; the gas-side pressure loss would be 0.55 psia; and the pinch-point temperature would be approximately 75°F.
- . When the water flow rate of the baseline waste-heat steam generator is maintained at its design value of 7.9 lb/sec, the steam temperatures with and without flow distribution controls are estimated to be 725°F and 450°F, respectively. When the steam temperature is maintained at its design value of 700°F, the water flow rates with and without flow distribution control would be 8.1 lb/sec and 6.6 lb/sec, respectively.

R82-955750-4

- . To provide adequate technical information so a comparison with the analytical results can be made and to produce operational experience with a gas turbine waste-heat steam generator in naval propulsion applications, an experimental program should be undertaken. A suggested program consisting of nine major tasks would require approximately sixteen months to complete and a level of effort of approximately 3000 man-hours.

INTRODUCTION

As a result of a system feasibility study conducted by NAVSEA in 1977 (Ref. 1) the Rankine Cycle Energy Recovery (RACER) system was selected as a candidate system for future advanced naval propulsion system. The RACER system uses waste heat recovery from the exhaust of the marine gas turbines to provide additional propulsion power for the U.S. Naval combatants. Since then, the development of a reliable, efficient and compact waste heat steam generator has become one of the most important engineering disciplines. Critical technology areas were defined and appropriate programs were initiated to address these and thereby to reduce the risk of system development (Refs. 2 and 3). Results of these critical-technology programs indicate that a self-cleaning boiler is feasible, a low-leakage system can be demonstrated, and IN625 or IN825 would be the candidate material for construction of the waste-heat boiler. Based on the general design objectives outlined by the Navy and on the results of these critical technology programs, contracts for the preliminary design of the RACER system were awarded in 1979 and those for its development, testing and evaluation were awarded in 1981 (Ref. 4).

Although the results of system studies and critical technology programs continue to support the use of RACER system for Naval propulsion applications, some problems related to the general design practices remained to be solved by the design engineers. Because each component of the RACER system must be designed to satisfy specific system performance requirements, and particularly those related to the waste heat steam generators, uncertainties related to heat-transfer and pressure-loss coefficients, as well as to nonuniform flow distributions must be eliminated. Although the degree of nonuniformity and its effect on the waste-heat boiler performance are not completely clear, what is apparent is that the waste heat boiler must be designed with care because of such factors as cost, the space and weight limitations, and performance and reliability requirements. Therefore, an experimental program becomes a necessity. However, for large units like the RACER system, it would be impractical, if not impossible, to build a full-scale test apparatus to conduct a comprehensive test program. Accordingly, the present analytical study was conducted first to provide some basic understanding of the flow distribution characteristics and the effect this flow has on marine gas turbine waste-heat boiler performance. Based on the analytical results, a desirable and constructive experiment program can be formulated for ONR consideration.

It is well understood that any nonuniform flow distribution will reduce the heat transfer performance and at the same time, increase the pressure loss in a heat transfer device to various degrees, depending on specific design and actual operating condition. Several studies have been made in the past to investigate the effect of flow distribution nonuniformity on the heat exchanger performance (Refs. 5 to 8). Because the actual flow distribution would be different from one design to another, these studies were made based on

arbitrarily assumed nonuniform flow profiles for the working fluids. Results of these studies indicated that as much as 30 percent reduction in overall heat transfer unit (NTU) could be ascribed to the poor flow distribution in the heat exchanger core. Because the flow distribution profiles assumed in these studies are quite different from that of the marine gas turbine exhaust, and furthermore the heat exchanger core considered are often unsuitable for naval propulsion system applications, these study results can be used for reference purposes only, but not suitable for direct applications. Therefore, an analytical study of waste-heat boiler performance based on actual flow distributions measured in a typical marine gas turbine exhaust was performed and the results obtained are presented in this report.

The overall analytical program has been structured into two phases. Phase I (Ref. 9) emphasizes the understanding of the basic flow-distribution phenomena and its impact on two-dimensional diffuser design and performance. Results of the Phase-I study indicate that flow distribution in marine gas turbine exhaust was highly irregular and nonuniform, and that this flow will remain nonuniform through a two-dimensional diffuser unless proper flow distribution control means are used. This nonuniform flow distribution can be made more uniform by using a specially designed diffuser which incorporates appropriate guide vanes and, if necessary, flow injection at critical locations. The results of Phase-I study were then used in this Phase-II study which emphasizes the effect of nonuniform flow distribution on the waste-heat boiler performance.

This report presents the technical approach and the results of an analytical study of flow distribution control in marine gas turbine waste-heat steam generators. The report consists of three sections and one appendix. In Section I, the applicable steam generator design concepts and general design considerations are reviewed; the design data used by many manufacturers of waste-heat boiler are evaluated; the critical-problem areas associated with design of marine waste heat steam generators are discussed; and a candidate waste heat steam generator configuration was selected. Section II discusses the analytical model formulation and presents the results of parametric performance analysis, including those for both design and off-design operations of candidate waste heat steam generators. Based on the results of this analytical study, a proposed experiment program plan and schedule was prepared; this is presented in Section III. The detailed descriptions of the computer program developed for the analytical model are presented in Appendix A.

REFERENCES (FOR INTRODUCTION)

1. Marron, H. D. and R. S. Carleton: The Gas Turbine Waste Heat Recovery System and the U. S. Navy. ASME Paper 78-GT-170, April 1978.
2. Marron, H. D.: Gas Turbine Waste Heat Recovery Propulsion for U. S. Navy Surface Combatants. Naval Engineers Journal, Oct. 1981.
3. Muench, R. K. et al.: A Study of Waste-Heat-Boiler Size and Performance of a Conceptual Marine COGAS System. DTNSRDC TM-27-80-19, Feb. 1980.
4. Miller, C. L. and H. D. Marron: RACER-An Energy Conserving System for Ship Propulsion. 16th IECEC Proceedings, Vol. 2, 1981.
5. Chiou, J. P.: Thermal Performance Deterioration in Crossflow Heat Exchanger Due to the Flow Nonuniformity. J. of Heat Transfer, Trans. ASME Vol. 100, Nov. 1978.
6. Wilson, D. G.: A Method of Design for Heat-Exchanger Inlet Headers. ASME Paper 66-WA/HT-41, Sept. 1967.
7. Anderson, A. F.: Recuperator Development Program Solar Brayton Cycle System. NASA Contract NAS3-2793, Final Design Report, March 9, 1968.
8. Bauver, W. P. and J. G. McGowan: Modeling the Distribution and Effect of Steam Flow in Marine Superheaters. Combustion, March 1980.
9. Shu, Ho-Tien and S. C. Kuo: Flow Distribution Control Characteristics in Marine Gas Turbine Waste-Heat Recovery Systems, Phase I-Flow Distribution Characteristics and Control in Diffusers. UTRC R81-955200-4, August 1981.

SECTION I

SELECTION OF CANDIDATE STEAM GENERATOR CONFIGURATIONS

Gas turbine waste heat recovery systems have been designed and used with success for generating either hot water or steam or both for various applications (Refs. 1.1 to 1.4). In addition, results of technical and economic feasibility studies have shown that the combined gas and steam turbine power system is attractive for use in marine propulsion applications (Refs. 1.5 and 1.6). The use of small-scale heat exchanger units for recovering waste heat from service gas turbine generators of U.S. DD963 ships has also been reported in Refs. 1.7 and 1.8. Furthermore, the research and development efforts leading to an efficient, lightweight, and reliable waste heat recovery system for U.S. Navy surface combatant propulsion application is underway (Refs. 1.9 and 1.10). Accordingly, the objective of this task was to select a candidate waste heat steam generator configuration which could be integrated with the candidate gas turbine and diffusers investigated in the Phase-I study. In order to achieve this objective, the applicable steam generator design concepts and general design considerations were reviewed; the design data, which include the system operating conditions (flow rate, temperature, and pressure), the boiler, its efficiency, and the tube material, used by manufacturer of waste-heat boiler or hot-water heaters were evaluated; and the critical problem areas associated with design of marine waste heat boilers were investigated. Based on this information, a candidate waste heat steam generator configuration was selected.

I.1 Design Concepts and Considerations of Marine Gas Turbine Waste-Heat Boilers

In the process of specifying a marine gas turbine waste heat boiler, a designer must determine: (1) the total amount of heat that can be recovered economically; and (2) the type of equipment that is best suited to the available space and the quality of the steam. Based on the results obtained, the designer proceeds to investigate other basic design considerations the most important of which are summarized in Table I.1. These considerations are based on general design practices of industrial gas turbine waste heat boiler designs, or on the general constraints and requirements of naval ship operations.

I.1.1 Design-Point Performance Considerations

Capacity sizing: in practice, the design of marine gas turbine waste heat boiler is conducted on one of two approaches. The first is to design the system for a ship which would operate at full load for long periods of time (such as commercial marine and naval auxiliary ships); the other is to design

the system for efficient operation at cruise, but still taking into consideration the need to operate for intermittent periods at full-power (such as the naval combat ships). The method of integrating the waste heat steam generator with the marine gas turbine will depend on both the ship type (maximum installed power and duty cycle) and the gas turbine engine selected. If two gas turbines were needed to power one propeller, it would be desirable to have the exhaust systems of these two turbines directed through a single waste-heat boiler for the steam turbine, thereby reducing weight of the waste-heat recovery system. In this case, the maximum heat which could be recovered will depend on the performance characteristics of the gas turbines and their operating profiles. The off-design performance of the steam cycle will depend on whether it is designed for cruise- or full-power operation.

Flow Parameters: Because the ratio of gas to liquid (water) flow rates in the waste-heat boiler or hot water heater are inherently high, externally extended (finned) tubes are more desirable than bare tubes. Many studies (Ref. 1.2, 1.7, 1.11 and 1.12) indicate that when the gas flows across the finned side of the tubes, the heat transfer will be maximized, and therefore, the designers of most gas turbine recovery systems have adopted this cross flow pattern. To handle the relatively large amount of gas flow at low pressure and high temperature and to satisfy the low-pressure-drop requirement, the flow area on the gas side must be adequate. When external finned tubes are considered, gas-side pressure drop through the heat recovery system may impose significant penalties on the operation of the gas turbine. In industrial waste heat boilers, the pressure drop is normally limited to approximately 15 inches of water (0.6 psia). Therefore, the tube size and tube arrangement must be carefully selected. To increase the flow area and heat transfer area, the use of a suitable diffuser to connect the waste heat boiler with the gas turbine exhaust box becomes necessary. The candidate diffuser identified during Phase-I study will serve this purpose.

Pinch Point: It is difficult to assess practical limits on the degree of heat recovery without considering the cost of the equipment, and one of the most important parameter in sizing the waste heat boiler is the pinch point temperature. Figure 1.1 shows the profile of the turbine exhaust gas and the water/steam temperature for a typical unfired waste-heat steam generator. The pinch point generally occurs where the liquid reaches its saturated state. The selection of the pinch-point temperature not only effects the liquid-side flow condition (flow rate and pressure), but also the boiler size. As indicated in Ref. 1.11, waste-heat boilers with pinch-point less than 50°F are normally not considered to be economical.

Temperature Differential: Unlike that in a conventional oil or coal fired boiler, the temperature differential between the two working fluids in a gas turbine waste-heat boiler is low. Accommodating this low temperature differential requires a special design in terms of tube arrangement and material selection. Finned tubes with high thermal conductivity can be considered as long as the sum of the material cost and manufacturing cost do not exceed the economic limit.

1.1.2 Tube Design Considerations

After the flow conditions, tube material, tube size, and the tube arrangement have been selected and defined, the waste-heat steam generator performance can be estimated; the selection of the tube size and tube arrangement has a significant effect on boiler performance and size. Use of small diameter tubes yields a high heat transfer coefficient on both sides of the working fluids and results in small boiler. The advantage can be taken of using small tubes only when working with organic fluids or extremely high quality water so hardness or fouling problems are eliminated. However, from a practical standpoint, the tube size selected should be sufficiently large to accommodate a pneumatic tube reamer. This precaution is taken so that if untreated water is used for an emergency condition, or if the cooling water (river water or sea water) leaks into the condensate, the tubes can be cleaned mechanically if chemical cleaning is impossible or if the tubes become plugged to the point where chemicals cannot be introduced. Therefore, from a practical viewpoint, tubes smaller than 3/4 inch in diameter should not be considered.

Heat exchanger tubes should be arranged in such a manner that thermal stress concentration can be avoided; both U-shape and coil arrangements are good candidates in this respect. However these arrangements are not generally regarded as being compact and their accessibility for maintenance and replacement of parts is generally poor. A modular design, similar to the evaporator of the automobile air conditioning unit (with finned straight tubes used as the heat transfer core and with the ends of the tubes welded to a U-shape tube joints which are located outside of the tube sheet as shown in Fig. II.7), may be a better choice for marine gas turbine waste heat applications.

The baffles needed to act as tube support plates and flow guide vanes must be located so that the maximum tube length between support plates, or between a tube sheet and a supporting plate, does not exceed 36 inches. Holes for tubes in baffles, baffles clearances, and tie rod standards must be designed in accordance with the latest standards of the ASME boiler design code (Ref. 1.16).

The selection of tube material affects not only on the heat transfer performance and the initial cost, but also the boiler reliability and its operation. For landbased waste-heat recovery systems, carbon steel or low alloy are commonly used. However, for naval ship propulsion system applications, high-temperature stainless steel (such as 304 or 316) or Incoloy 800 may be used to cope with the possible dry-running conditions.

1.1.3 Performance Degradation Considerations

In designing heat transfer equipment, the possible performance deterioration due to flow leakage, nonuniform flow distribution, and fouling must be considered. Leakage is one of the most exasperating problems in heat exchanger fabrication and

maintenance, for it not only effects the heat exchanger performance, but also requires flow make-up and clean-up equipment. Therefore, use of all-welded tubes may be considered to ease the leakage problem. Nonuniform flow distribution has some effects on heat exchanger performance (Refs. 1.14 and 1.15). In Ref. 1.15 it is indicated that poor flow distribution through the cores of a typical counterflow exchanger can cause degradation in excess of 30 percent in the operating effectiveness as compared with the values predicted for the ideal case of uniform flow distribution. Therefore, applicable flow distribution control, wherever is necessary, must be incorporated into the design of a waste heat boiler to avoid any unnecessary performance degradations.

Fouling has also been a problem common to all waste heat recovery equipment. In order to design a marine waste heat boiler capable of sustaining its design capability over a desired period of operation with minimum maintenance and repair, the designer must give serious consideration to the selection of materials. The material specified must be able to offer maximum resistance to corrosion, and to the fouling characteristics of the fluids being handled.

As an added design burden, consideration must be given to the varying degrees of inclination encountered in sea service. In naval practice, all heat transfer equipment must be designed to perform satisfactorily under conditions of 5 degrees trim, 10 degrees pitch, 15 degrees list, and 45 degrees roll.

1.1.4 System Layout Considerations

The physical arrangement of the gas turbine exhaust relative to the location of the heat recovery unit has considerable effect on turbine maintenance as well as the cost of the overall installed recovery system. For industrial applications, the horizontal side-discharge gas turbine exhaust (Fig. 1.2) is preferred. This arrangement provides good access for turbine maintenance, has less structural support for the waste heat recovery components, and provides adequate space for bypass stack and/or supplementary firing. This arrangement also offers the opportunity to use natural circulation (through vertical tube arrangement) for reliable flow circulation and uniform heat distribution, both of which are of particular importance if supplementary firing were required. Because of space and weight constraints in ship propulsion system applications, a vertical top-discharge gas turbine exhaust (Fig. 1.3) is more desirable (Refs. 1.9, 1.10, and 1.12). The advantages of this arrangement are primarily for saving in cost and space as well as good exhaust gas distribution across the boiler heating surface provided that diffuser is properly designed. Generally speaking, this arrangement does not create any special gas turbine maintenance problems because the engine is housed in its own enclosure and can be removed through the intake for major services. For easy installation, maintenance and replacement, the heat exchanger tube elements are arranged horizontally. However, this arrangement would require forced circulation of liquid to satisfy such operational requirements as ease of control and dry-running. In addition to having the characteristic of good stability and reliability, the forced circulation design is known to be more compact and lighter in weight in comparison with the natural circulation (vertical) design.

The physical location for the auxiliary components, such as the pump, the automatic (pneumatic) control devices, the feed water treatment system, and the pipings must be carefully selected so that accessibility for their maintenance and parts replacement is adequate. If the space limitation were such that an integral waste-heat boiler system would cause problems in accessibility, dispersed arrangement of some secondary auxiliary component must be considered.

I.1.5 Structural Rigidity Considerations

Due to the rough sea service condition, all components of the waste-heat boiler must be provided with adequate foundation supports. Additional allowances must be made in the design of the heat recovery equipment supports to provide for expansion, contraction and high-impact shock. Furthermore, all design features must conform to the ASME Boiler and Pressure Vessel Code (Ref. 1.16). The design data commonly used by manufacturers of industrial waste-heat boiler and waste-heat economizer (hot water heater) and the critical problem associated with marine gas turbine waste heat boiler design are discussed in the section which follows.

I.2 Waste Heat Boiler Design Data and Critical Problems

A comprehensive survey was performed to identify the state of the art of waste heat boiler design (including the gas and liquid flow conditions, the unit capacity, the efficiency, and the materials used) and the critical technology problem areas. The data obtained from this survey are shown in Table I.2, and the critical technology problem areas are summarized in Table I.3.

It was discovered that there are more than one hundred waste-heat-boiler/economizer manufacturers worldwide and those shown in Table I.2 represent only a few of this total. The design approaches used by these firms have been varied depending on the heat sources, amount of heat which can be recovered economically, the end-use of the recovered heat, and space and economic concerns. The left column of Table I.2 shows that most manufacturers can provide custom-built units (shown with an affixed "*" mark) to meet a specific design requirement. Therefore, the design data obtained vary over a wide range. For example, on the fourth line SA Babcock Belgium NV can provide both waste heat boiler and waste heat economizer (hot water heater) for gas flow rates ranging from 27 to 333 cu. meter/sec, gas temperatures from 400 to 700°C, and gas-side pressure losses from 20 to 60 mm W.G. The liquid flow rate, liquid temperature, and unit capacity would then vary according to the design requirements. The unit capacities and heat recovering efficiencies of these designs vary from 10 to 200 MW and 60 to 75 percent, respectively. The design data for other manufacturers are similar in nature, but different in level of absolute values.

Among the design data presented, the gas-side pressure loss information is probably the most useful to this present study. It was found that (from column No. 4 of Table I.2) a pressure loss between 100 to 200 mm W.G. would be a practical value for marine gas turbine waste heat boiler design. Other information, such as tube materials (shown on the far right column of the same table) and the boiler design configuration (not shown in the table), offer further insight into boiler design. For industrial applications, finned carbon steel tubes are the most commonly used although stainless steel tubes are also used in some designs. The boiler configurations are mostly once-through designs.

The critical technology problem areas of waste-heat boilers are listed in Table I.3. These critical problem areas are generally related to material selection, mechanical design, or operational requirements. From available information, it appears that problems with materials are the most common and serious of these observed in the steam generator equipment. The commonly encountered material problems are related to corrosion damage in the boiler tubes including those of denting, pitting, cracking, and erosion. These problems results from the attack of concentrated aggressive chemical impurities on the tube materials. Laboratory tests made on samples removed from dented steam generator tubes indicate that denting is an acid chloride reaction (Ref. 1.17). Tube wall thinning has also been observed in the region near the tube sheet when phosphates have been used in water treatment. Examination of tubes removed from a once-through steam generator has also revealed that stress corrosion cracking may result from sulfuric acid attack. In view of these severe material problems, Navy initiated a material study program in FY79 at DTNSRDC/Annapolis to determine the best material for use in boiler tubes. The results of the study indicate that Incoloy 800 can resist to oxygen and chloride stress corrosion as well as that from sulfurous and sulfonic acid attack.

The cause of the problem of tube fretting and wear can be traced to vibration. The tube vibration can be induced not only by fluid flow perpendicular to the tube but also that parallel to the tubes. Because the movement between the rubbing surfaces is oscillatory and usually small in amplitude, the rubbing process taking place is termed "fretting". It is well known that the fretted region is highly susceptible to fatigue cracks. The immediate consequence of the fatigue cracks is the leakage of working fluid and/or cooling water. The leakage in the boiler affects system performance, increases feed-water makeup requirements, and demands more frequent cleaning (including deoxygenation) operations. Minimizing the flow-induced vibration is a critical task. One common approach has been to use an all-tubular boiler with no connections other than the water inlet and steam outlet manifolds to reduce the leakage. However, use of flow distribution control to achieve a more uniform flow distribution is even more essential, and in the long run may prove to be the most beneficial solution.

The results of Phase-I study indicate that the flow distribution within the exit diffuser of the gas turbine exhaust is highly nonuniform in the absence of flow distribution controls. This nonuniform flow distribution not only could reduce the heat transfer performance (Refs. 1.14 and 1.15), but also could create thermal and mechanical stress concentrations, local hot spots, and dryout problems (Ref. 1.18). Therefore, before the accurate performance can be predicted, both analytical and experimental programs must be conducted to investigate the actual flow distribution pattern inside the waste heat boiler predicted.

Problems related to transient operation of the marine waste-heat boiler must also be addressed. Because of the self-cleaning requirement, the waste-heat boiler may have to be operated under dry condition for a period of 15 to 30 minutes at elevated temperatures, as recommended by the manufacturer. Additionally, the boiler has to be operated under off-design condition every so often to meet the duty-cycle requirements. These transient and off-design operation and the routine start-up and shut-down procedures will undoubtedly have profound effect on the boiler reliability and life expectancy. However, available information indicate that the allowable thermal distortion for the steam turbine would limit the rate of load change to not more than approximately 2% per minute. Even at this seemingly slow rate of load change, care still must be exercised to control the boiler and its auxiliary system so that the pressure, temperature, and water inventory distributions in the system create no severe conditions throughout the starting period.

1.3 Selection of Candidate Steam Generator Configuration

Based on the results of Tasks I.1 and I.2 obtained in this study, and the need to simplify the maintenance, increase the reliability, and reduce the size and weight of the system, a once-through cross-counterflow type boiler was selected as the steam generator configuration for this analysis. The criteria used in this selection are consistent with those reported in Refs. I.9 and I.10, and therefore, the results obtained from this study should have direct relevance to the U.S. Navy RACER Program. A sketch of the conceptual steam generator configuration is shown in Fig. I.4 and a summary of its characteristics is presented in Table I.4.

Since the objective of this study was to investigate the effect of gas flow distribution control on waste-heat boiler performance, the liquid flow has been assumed to be uniform. As shown in Fig. I.4, the feedwater would be supplied through a water manifold and distributed evenly among the top two rows of the boiler tubes; the superheated steam (or hot water) would be discharged from the bottom row tubes and then collected in a steam manifold. The gas flow would enter the boiler from its bottom. The flow distribution and flow conditions have been based on the results of the Phase-I study.

In the section which follows, an analytical model of flow distribution control formulated for the candidate steam generator is presented, and results obtained from its analysis are discussed.

REFERENCES

- 1.1 Reay, D. A.: Heat Recovery Systems, A directory of equipment and techniques, E. & F. N. Spon Ltd., 1979.
- 1.2 Stewart, J. C. and H. J. Streich: The Design and Application of the Gas Turbine Heat Recovery Boiler, ASME Publication 67-GT-38, March 1967.
- 1.3 Ecabert, R. J.: Steam Generators for Combined Steam and Gas Turbine Plants. J. of Engineering for Power, Trans. of the ASME, Paper No. 66-GT/CMC-63, December 1965.
- 1.4 Bush, G. W. and J. W. Godbey: Field Testing the Performance of Gas Turbine Exhaust Heat Recovery Steam Generators. ASME publication 75-GT-76, March 1975.
- 1.5 Berman, P. A.: Combine Cycle Gas Turbine Systems for Marine Propulsion. PB179033, Westinghouse Electric Corp., Pittsburgh, PA. 1963.
- 1.6 Giblon, R. P. and I. H. Rolih: COGAS, Marine Power Plant for Energy Savings, Marine Technology, July 1979.
- 1.7 Katz, Y. and J. L. Boyen: Design Considerations for Heat Recovery System for DD-963 Class Ship, ASME Paper 77-GT-106, March 1977.
- 1.8 Graf, T. E. and J. E. Nagengast: DD-963 Class Waste Heat Recovery System Experience, ASME paper 79-GT-159, January 1979.
- 1.9 Miller, C. L. and H. D. Marron: RACER - An Energy Conserving System for Ship Propulsion, 16th IECEC, Vol. 2, 1981.
- 1.10 Marron H. D.: Gas Turbine Waste Heat Recovery Propulsion for U.S. Navy Surface Combatants, Naval Engineers J. October 1981.
- 1.11 Hambleton, W. V.: General Design Considerations for Gas Turbine Waste Heat Steam Generators, ASME paper 68-GT-44, March 1968.
- 1.12 Katz, Y.: Design Considerations for Future Heat Recovery Boilers Aboard Naval Vessels, ASME paper 78-GT-162, April 1978.
- 1.13 Muench, R. K., D. T. Knauss and J. G. Purnell: A Study of Waste-Heat Boiler Size and Performance of A Conceptual marine COGAS System, DTNSRDC TM-27-80-19, February 1980.

R82-955750-4

REFERENCES (Cont'd)

- 1.14 Chiou, J. P.: The Effect of Nonuniform Fluid Flow Distribution on Thermal Performance of Crossflow Heat Exchanger, ASME paper 77-WA/HT-3, November 1977.
- 1.15 Wilson, D. G.: A method of Design for Heat Exchanger Inlet Headers, ASME paper 66-WA/HT-41, September 1967.
- 1.16 ASME Boiler and Pressure Vessel Code, An American National Standard, Section IV, ANSI/ASME BPV-IV, 1977.
- 1.17 Layman, W. H. et. al: Status of Steam Generators, Combustion, September 1979.
- 1.18 Fraas, A. P. and M. N. Ozisik: Heat Exchanger Design, John Wiley & Sons, Inc. 1965.

TABLE I.1

CENERAL DESIGN CONSIDERATIONS FOR MARINE GAS
TURBINE WASTE HEAT STEAM GENERATORS

- . Design -Point Performance Considerations: to handle the large amount of gas flow at low pressure and high temperature; to satisfy the gas-side low pressure drop requirement; to cope with low temperature differential between the two working fluids.
- . Tube Design Considerations: tube size, material, and arrangement.
- . Performance Degradation Consideration: flow leakage, nonuniform flow distribution, and fouling, sea-service condition.
- . Economic Considerations: material, sizing, and effectiveness.
- . Operational Requirement Considerations: thermal load, duty cycle, dry running, emergency operation, and control devices.
- . System Layout Considerations: accessibility for maintenance and repair, reliability, space and weight limitations.
- . Structural Rigidity Consideration: shock and vibration, structural expansion and contraction.

TABLE 1.2 REPRESENTATIVE MANUFACTURERS OF WASTE-HEAT STEAM GENERATOR/
HOT-WATER HEATER AND DESIGN DATA

Manufacturer	Gas T °C	Gas AP mm W.G.	Hot Water or Steam W m ³ /h	T °C	P bar	Capacity (MW)	Efficiency	Tube Material
ACA-CTC (WNB, WHE)*	600	AR	AR	AR	50	50-100	VARIED	Finned or Plain C.S.
ALCO INC. (WNB)*	370	65	100	225	AR	+ 16.5	65	Finned or Plain C.S.
AMSTRONG CO. (WNB)*	1100	1.13	AR	AR	700	AR	VARIED	CS, SS, Monel
LA BAROQUE BELGIUM BV (WNB, WHE)*	400-700	20-60	AR	AR	10-60	+ 30	60-75	MS, AS
MILITAN & COOPER LTD (WNB)*	200-500	10-25	5-500	AR	+ 40	+ 30	30	Finned or Plain C.S.
NEVELEY CHEMICAL ENG. LTD (WNB)*	200-1200	10-500	0.1	AR	+ 35	+ 30	75	C.S., S.S.
IONO (WNB, WHE)*	500-1000	50-150	AR	AR	10-20	-	50-80	MA
MONSIEUR HEAT TRANSFER BV (WNB)*	300-1000	20-300	8-300	AR	+ 100	+ 300	20-50	Metal
P. CASIMIRANT & FIGLIO (WNB, WHE)*	300-1000	10-200	AR	AR	7-170	-	-	Steel
SOALTECH (WNB)*	480-540	+ 250	40	AR	-	+ 5.5	-	C.S., S.S.
XONSECO (WNB)*	+ 340	+ 200	6.8	AR	7.0	+ 5.4	65	-
DURVEN & MEYER LTD (WNB)*	50-800	25-40	AR	AR	AR	AR	70	Cor-ten, C.S., S.S.
CLIPSE LOOKOUT CO. (WNB)*	+ 500	-	AR	AR	-	+ 5.3	VARIED	C.S., S.S.
FUEL FORMATES LTD. (WNB)*	200-900	2.5-500	AR	AR	-	+ 0.2	VARIED	Cast Iron
MAHAM MANUFACTURING LTD (WNB)*	300-750	25-50	0.13	AR	10	+ 4	VARIED	C.S., S.S.
J. GREEN & SON LTD (WNB, WHE)*	500-600	AR	AR	AR	10	AR	VARIED	MS, AS
LAMORTHY ENGINEERING CO. LTD (WNB, WHE)*	+ 650	AR	AR	AR	35	-	-	Steel Finned
MARRIS THERMAL TRANSFER PRODUCTS INC (WNB, WHE)*	+ 30	72	AR	AR	35	+ 3	67	Finned or Plain C.S.
MATHISON LESLIE ENG. LTD. (WNB)*	280-430	140	0.03-0.1	AR	6.5	+ 6.0	68	Finned C.S.
MILWAUKEE IRON WORKS LTD (WNB, WHE)*	150-950	10-145	0.07-6.5	AR	9.5	+ 1.4	-	Finned STB
MITACHI SHIPBUILDING & ENG. CO. LTD. (WNB)*	450-700	100-115	0.013-0.018	AR	14-40	-	-	Finned or plain C.S.
NORTHERN ENGINEERING INDUSTRIES (WNB)*	540-1000	20-254	0.02-0.04	AR	+ 110	20-100	80-92	Plain MS or low chrome steel
P-DOT INTERNATIONAL CORP (WNB)*	260-650	25-76	0.4-2.2	AR	10.3	+ 6.5	82	Finned Steel
OTT INDUSTRIES INC (WNB)*	160-350	3.7-11	AR	AR	-	+ 15	40-60	Steel
TRUTHERS WELLS CORP (WNB, WHE)*	400-1200	200-800	20-150	AR	50-150	+ 200	85-92	-

* - Custom-Built
- = up to

WNB = Waste Heat Boiler (Steam Generator)

WHE = Waste Heat Economizer (Hot Water Heater)

AR = As Requested

TABLE I.3

CRITICAL PROBLEM AREAS OF GAS TURBINE WASTE HEAT BOILERS

- . Material Problems: Tube denting, pitting, cracking, erosion-corrosion
- . Vibration Problems: Tube fretting and wear, high-cycle fatigue, stress corrosion
- . Leakage Problems: Performance degradation and feed-water makeup and cleanup including deoxygenation
- . Flow Maldistribution Problems: Effective flow distribution control, soot formation prevention and self-cleaning methods
- . Transient Behavior Problems: dry cleaning operation, and duty cycle operation of gas turbine, regular or emergency shut-down and start-up.


R82-955750-4


TABLE I.4

CANDIDATE STEAM GENERATOR CONFIGURATION


- . Gas Flow: one-pass flowing upward without supplementary firing
- . Water Flow: once-through forced circulation, counter cross to gas stream
- . Tubes and Tube Arrangement: all-welded finned tubes made of corrosion resistant material (IN 800); placed horizontally along the gas turbine centerline direction
- . Boiler Geometry: rectangular corss-section of 10 ft by 7 ft (compatible with the diffuser obtained from Phase-I study), height be less than 8 ft (compatible with the ship)
- . Self-cleaning on the gas side and scaling prevention on the water side
- . Heat Recovery Capacity: between 12,000 to 20,000 kw

LAYOUT OF TYPICAL INDUSTRIAL COMBINED-CYCLE GAS TURBINE SYSTEM




POTENTIAL LAYOUT OF COMBINED-CYCLE GAS TURBINES MARINE PROPULSION SYSTEM

TYPICAL TEMPERATURE PROFILE OF GAS COOLING AND STEAM GENERATION PROCESSES



**LAYOUT OF MARINE GAS TURBINE WASTE-HEAT STEAM GENERATOR: ONCE-THROUGH,
COUNTER-CROSS FLOW HEAT EXCHANGER**



SECTION II

PERFORMANCE ANALYSIS OF FLOW DISTRIBUTION CONTROL ON WASTE-HEAT STEAM GENERATOR

This section describes the formulation of an analytical model and the analysis of flow distribution control on marine gas turbine waste-heat boiler (or steam generator) performance. The analytical model formulated is based on compact heat exchanger design concept (Ref. 2.1) and the relaxation-approach method (Ref. 2.2). The configuration of the candidate waste-heat boiler is a once-through, counter crossflow heat exchanger selected in Section I.3. The performance characteristics of this candidate waste-heat boiler at its design and off-design conditions were analyzed for three different flow inlet conditions obtained from Phase-I study (Ref. 2.3). The three flow inlet conditions are: (1) a uniform flow distribution; (2) a nonuniform flow distribution (based on actual flow distribution of a typical marine gas turbine exhaust) without flow distribution control; and (3) a nonuniform flow distribution with flow distribution control.

II.1 Formulation of Analytical Model

The analytical model used in this study is modified version of the distillate fuel vaporization model originally developed by Chiappetta and Szetela (Ref. 2.2). Although the basic assumptions and the method of approach for the fuel vaporization model are adequately described in Ref. 2.2, additional assumptions as well as working formulas pertaining to this present study are presented below to allow a better understanding of the results of this study.

The procedure used in formulating the working model for this present study consists of the following five steps: (1) establishing a nodal system to represent the overall waste heat boiler; (2) compiling all heat transfer and pressure loss working formulas and empirical constants; (3) developing a computer program for computing the thermal and physical properties of water substance for the applicable flow conditions; (4) establishing a numerical computation procedure for computational analysis of the waste-heat boiler; and (5) developing a computer program based on results obtained from steps (1) through (4) to facilitate the computational analysis of flow distribution control in marine gas turbine waste-heat boilers. A detailed discussion of each step follows.

II.1.1.1 Establishment of Heat Exchanger Nodal System

As cited in Ref. 2.2, in order to use a nodal system for easy computation of crossflow heat exchanger performance, several assumptions must be made. Two basic assumptions made are: (1) the heat exchanger must be rectangular and of uniform thickness; and (2) the working fluid on the shell side must be a gas although the working fluid on the tube side can be either a gas or a liquid. Based on these two assumptions, the overall waste heat boiler can be subdivided into several nodes as shown in Fig. III.1. Each node represents a rectangular parallelepiped of same length, l , but of a different width, Δx_i and height, Δy_i . The overall waste-heat boiler then can be described by a two-dimensional nodal array in i , and j , where $i=1,2,3\dots i_{\max}$, and $j=1,2,3\dots j_{\max}$. Nodes are connected to form several groups which represent the flow paths and flow direction. For example, Fig. II.1 shows a 5 by 10 array. Assuming that the gaseous flow for this 5 by 10 array is divided into five paths and is flowing upwards, then the first gas path can be represented by (1,1), (1,2), (1,3),... (1,10), and the second gas path can be represented by (2,1), (2,2), (2,3),... (2,10), etc. If the water were flowing in a single path counter cross to the gas stream, then the nodal connection for the water path can be represented by (5,10), (4,10), (3,10), ... (1,10), (1,9), (2,9)... (5,1). The flow conditions, including the mass flow rate, the temperature, and the pressure, are specified at the inlet of each flow path to provide a starting point for numerical computation.

It should be noted that each node is treated as a miniature heat exchanger. Because of the nodal arrangement, the exit flow condition of each node will automatically become the inlet flow condition of the subsequent node. In order to preserve the mass flow rate for each gas path, a plate-fin-type heat exchanger or a baffle plate tube supporting structure must be specified in the construction of the flow path for the waste heat boiler if experimental and analytical results are to be compared.

The heat transfer coefficient for the "miniature" heat exchanger is computed based on the averaged local flow conditions. Since the number of nodes in each path and the number of paths for each fluid are arbitrarily selected, proper arrangement of the nodal connection can be made to simulate any two-dimensional heat exchanger geometry.

II.1.2 Heat Transfer and Pressure Loss Working Formula

The heat transfer coefficient (convective film coefficient) and the pressure loss characteristics are functions of the surface geometry, fluid properties, and flow conditions. It is not the objective of the present study to develop these functional relationships, but rather to compile the existing working formulas from the open literature and to use them for computing the heat transfer and pressure loss characteristics of the waste-heat boiler being studied. The formula and/or test data which were used in the present analytical model are summarized in the following sections.

II.1.2.1 Gas-Side Working Formulas

The heat transfer and pressure loss characteristics for the gas-side (shell-side) working fluid are based on the data presented in Ref. 2.1. The friction coefficient (f) and the Stanton number ($St = h / C_p \rho U$) were expressed in terms of Reynolds number for various surface geometry in Chapter IX of Ref. 2.1. When extended surfaces were considered, the fin-effect formulas presented in Chapter II of the same reference were also used.

II.1.2.2 Liquid-Side Working Formula

Because the working fluid (water) on the liquid side may experience phase changes from a liquid to a vapor and possibly to a superheated vapor, it was necessary to define different formulas for heat transfer and pressure loss in each phase. In addition, the working fluid might be in laminar flow, turbulent flow, or supercritical flow, appropriate working formulas had to be used.

For liquid-phase flow, the heat transfer coefficient can be computed using one of the following formulas:

$$\text{laminar flow: } N_u = C_1 \left(\frac{Re_b Pr_b}{L/D} \right) C_2 \left(\frac{\mu_b}{\mu_w} \right)^{C_3} \quad (1a)$$

$$\text{turbulent flow: } N_u = C_1 (Re_b)^{C_2} (Pr_b)^{C_3} \quad (1b)$$

$$\text{supercritical flow: } N_u = C_1 (Re_w)^{C_2} (Pr_w)^{C_3} \left(\frac{\rho_w}{\rho_b} \right)^{C_4} \quad (1c)$$

where C_1 , C_2 , C_3 and C_4 are empirical constants presented in Table II.1. The Reynolds number (Re), Prandtl number (Pr), viscosity (μ) and flow density (ρ)

are computed based on either the bulk temperature or the wall temperature as designated by the subscripts of b or w, respectively. The pressure drop, Δp , can be calculated using the following relationship from Ref. 2.1:

$$\Delta p = \frac{G^2}{2g_c} \rho_{in} \left[(K_c + 1 - \sigma^2) + 2 \left(\frac{\rho_{in}}{\rho_{out}} - 1 \right) + f \frac{A_{ht}}{A_{cf}} \frac{\rho_{in}}{\rho_{av}} - (1 - \sigma^2 - K_e) \frac{\rho_{in}}{\rho_{out}} \right] \quad (2)$$

where K_c and K_e are entrance and exit coefficients, σ is the ratio of free-flow area to frontal area, and A_{ht} and A_{cf} are the heat transfer area and core flow area, respectively.

For boiling-phase flow, the heat transfer coefficients were calculated using the correlations developed by Chen (Ref. 2.4), who assumed that the overall boiling heat transfer coefficient consists of two additive basic mechanisms: an ordinary macro-convective mechanism and a micro-convective mechanism associated with bubble nucleation and growth. He defined these two convective heat transfer coefficients as:

$$h_{mac} = 0.023 (Re_L)^{0.8} (Pr_L)^{0.8} \left(\frac{K_L}{D} \right) F \quad (3a)$$

$$h_{mic} = 0.00122 \left(\frac{K_L^{0.79} C_{pL}^{0.45} \rho_L^{0.49} g_c^{0.25}}{\sigma^{0.5} \mu_L^{0.29} \lambda^{0.24} \rho_v^{0.24}} \right) (\Delta T)^{0.24} (\Delta p)^{0.75} S \quad (3b)$$

where F and S are called the effective two-phase Reynolds number function and the bubble growth suppression function, respectively. Both F and S are determined from empirical correlations of heat transfer data and the momentum-analogy analysis and are presented in graphic form in Ref. 2.4. The terms, σ and λ in Eq. (3b) are the vapor-liquid surface tension and latent heat of vaporization, respectively. The difference between the wall temperature and the saturation temperatures, ΔT , and Δp is the difference in vapor pressure corresponding to this ΔT . The subscripts L and v refer to liquid and vapor, respectively.

If the two-phase boiling process were isothermal, the pressure loss can be estimated using the model developed by Lockhart and Martinelli (Ref. 2.5). In this model, the overall pressure loss consists of three additive components: a gravitational loss (Δp_G), a momentum loss (Δp_M), and a frictional loss (Δp_F), which are defined as:

$$\Delta P_G = \left[(1-\alpha) \rho_l + \alpha \rho_v \frac{\sin \theta}{g_c} \right] \quad (4a)$$

$$\Delta P_M = \frac{\rho_l U^2}{g_c^2} \Delta \left[\left(\frac{1-\alpha}{1-\alpha} \right) \frac{1}{\rho_l} + \frac{\chi^2}{\alpha \rho_v} \right] \quad (4b)$$

$$\Delta P_F = \left[1 + Y^{2/N} \right]^N \left(\frac{\Delta p}{\Delta x_i} \right) s_v \quad (4c)$$

where α and Y are defined as:

$$\alpha = \left[1 + \frac{1-\chi}{\chi} \left(\frac{\rho_v}{\rho_l} \right)^{3/2} \right]^{-1} \quad (5a)$$

$$Y = \frac{Re_v^m C_l \rho_v}{Re_l^n C_v \rho_l} \left(\frac{1-\chi}{\chi} \right)^2 \quad (5b)$$

where m , n , C_p , C_v , N are constants presented in Table II.1. The term, χ , is the steam quality, and Δx_i is the nodal width defined in Section II.1.1.

For the supercritical flow, the analytical and experimental results presented in Chapters V and VI of Ref. 2.1 were used to calculate the heat transfer and the pressure losses. In this procedure, the friction coefficient and Stanton number were expressed in terms of the Reynolds number in graphical form, which were tabulated as input data to the computer program which is discussed in Appendix A.

In order to increase the flow depth to satisfy specific design requirements, each flow path may be reversed alternately to form several passes. The pressure drop associated with the turns were calculated using the averaged dynamic head evaluated at the nodes before and after the turn.

II.1.3 Thermodynamic and Transport Properties of Water Substance

Because the original analytical model (Ref. 2.2) was developed for distillate fuel, vaporization application, the development of a computer program which could estimate the thermodynamic and transport properties of water at any flow condition became an essential part of the analytical model for the present study. In this model the thermodynamic and physical properties needed are the temperature, pressure, specific volume, enthalpy, specific heat, viscosity, and thermal conductivity. The numerical values for the thermodynamic properties (the first six items) can be obtained from a fundamental equation, called the Helmholtz free energy equation, which is described in Ref. 2.6. The advantage of using this fundamental equation is that all thermodynamic properties can be obtained from its derivatives. Because differentiation, unlike integration, produces no undetermined functions or constants, the information yield is complete and unambiguous.

To calculate the thermal-conductivity and the viscosity, two well-known relationships contained in Refs. 2.7 and 2.8 were used. These two working relationships, along with the derivatives of the Helmholtz free energy equations, were then incorporated into computer programs for use in this program.

II.1.4 Numerical Computation Procedure

The numerical computation procedure used in this study is the same as that presented in Ref. 2.2. To provide a better understanding of this analytical model, a brief discussion of its computational procedure is given as follows.

As mentioned in Section II.1.1 that each subdivision (called node) will be treated as a miniature heat exchanger. The performance of each miniature heat exchanger will be calculated based on the averaged temperature for each fluid and for the walls in each node during the previous iteration (to be described below). Since the heat transfer areas on the shell-side and tube-side for a finned-tube bundle are not equal, the overall heat transfer coefficient is conventionally referenced to the shell-side. The steady-state heat transfer rate for the K^{th} node can be expressed as:

$$Q_K = (U)_K (A_g)_K \left[(T_g)_K - (T_l)_K \right] \quad (6)$$

where the subscripts g and l denote the gas and liquid sides, respectively. The term, U , represents the overall heat transfer coefficient determined from the film coefficient of the working fluids on both sides of the tubes and the thermal conductivity of the tube material.

The averaged fluid temperatures of the gas and liquid (T_g and T_l) are functions of the heat transfer rate between these fluids. For example the averaged gas temperature is

$$(T_g)_K = 1/2 \left[(T_g)_{in_K} + (T_g)_{out_K} \right] \quad (7)$$

and

$$(T_g)_{out_K} = \left[(T_g C_{p_g})_{in_K} - \frac{\dot{Q}_K}{(M_g)_K} \right] / (C_{p_g})_{out_K} \quad (8)$$

By definition, the inlet temperature for this node is the outlet temperature of the previous node (or the gas supply temperature if this is the initial node for the path containing this node). Similarly, for the liquid side:

$$(T_l)_K = 1/2 \left[(T_l)_{in_K} + (T_l)_{out_K} \right] \quad (9)$$

and

$$(T_l)_{out_K} = \left[(T_l C_{p_l})_{in_K} - \frac{\dot{Q}_K}{(M_l)_K} \right] / (C_{p_l})_{out_K} \quad (10)$$

Substituting Eqs. (7) through (10) into Eq. (6), one obtains

$$\dot{Q} = \left[(T_g)_m (1+\beta_g) - T_l)_m (1+\beta_l) \right] / \left[\frac{2}{UA_g} + \frac{1}{M_g (C_{p_g})_{out}} + \frac{1}{M_l (C_{p_l})_{out}} \right] \quad (11)$$

where $\beta = (C_p)_{in}/(C_p)_{out}$, and the subscript K has been omitted in Eq. (11) to facilitate typing.

The temperature distributions in gas, liquid and the tube walls of the waste heat boiler were calculated using a relaxation method. This method is described as follows: The averaged temperature of each fluid and of the walls at each node estimated during the previous iteration was used to calculate the thermal properties and the heat transfer coefficients for each fluid. At the completion of each iteration, the outlet temperatures at the last node in each path on each side of the working fluid were compared with those calculated during

the previous iteration. If all outlet temperatures were within a specified tolerance, the iteration was then terminated. Otherwise, the new averaged fluid temperatures, together with the new wall temperatures, were used as bases for the next iteration. It should be mentioned that, for the steady-state operation, the inlet condition were used as the initial guesses of the average temperature distribution for each path. This simple iteration algorithm was shown to be quite stable for most cases analyzed by the authors. Typically convergence occurs within fifteen iterations with a convergent tolerance of 5 degree F.

II.1.5 Development of Computer Program

In order to minimize the computer program development effort, the existing fuel vaporization heat exchanger program was updated to satisfy the study objective. This modification was made with permission and assistance from Messrs. Chiappetta and Szetela. The modification included allowance for: (1) isothermal vaporization; (2) variable nodal size, (3) use of water as the working fluid; and (4) inclusion of overall size and cost estimates. Description of this computer program, which includes the program capability and input/out format, is given in Appendix A.

II.2 Design and Off-Design Flow Condition

The shell-side flow distribution and flow condition at the inlet to the waste heat boiler are obtained from the Phase-I study (Ref. 2.3). In Figs. II.2 and II.3, two typical diffuser flow distributions are shown for a gas turbine operating at 50% power with and without flow distribution control. The flow distribution and flow conditions at the exit of the diffuser were calculated for each of the several sections which extend the entire width of the flow paths, as shown in Fig. II.1. The resulting flow conditions are tabulated in Figs. II.4 and II.5 for gas turbine operated at 100- and 50-percent power, respectively. Three different sets of flow distribution data are presented for each operating condition, namely, a uniform flow distribution, an actual flow distribution without control, and an actual flow distribution with control. For the first two data sets, the flow was divided into five paths equally spaced while for the third data set, the flow was divided into six paths because a pressure difference exists between the two sides of the flow guide vane. The averaged flow distribution data were used as input conditions to the parametric performance analyses which are discussed as follows.

II.3 Parametric Performance Analyses

Parametric performance analyses of the waste heat steam generator were made using the computer program discussed in Section II.1.5. The parameters, which were varied, included: (1) the tube arrangement, (2) the effective tube length, and (3) the water flow rate. The uniform gas flow distribution data presented in Figs. II.4 and II.5 were used as a reference for comparison with the results of the nonuniform flow cases. The range of the parameters used were based on the following rationales.

As noted in Section I.3, the candidate steam generator selected was a once-through, counter crossflow design. For this design, optimal heat transfer surface geometry and the tube arrangement still had to be determined in order to define its most efficient performance. Four different tube design configurations, depicted in Fig. II.6, were obtained from Ref. 2.1. Each configuration is comprised of circular finned tubes with tube diameter equal either to 1.024 inch or to 0.774 inch. For each tube diameter, two different longitudinal and transverse pitches and fin geometries were considered. The effect of the tube designs on the performance of the candidate waste-heat boiler were then investigated.

The next parameter determined was the effective tube length which is related to the following factors: (1) ease of installation and removal in the ship (i.e. maximum height of each heat transfer module should be less than 8 ft); (2) acceptable thermal gradient within each node (assumed to be equal to or less than 25°F for numerical stability); and (3) design and manufacture of boiler tubes according to the ASME Boiler Codes. With those concerns in mind,

the maximum nodal width (Δx_i) would be approximately 24 inches, and the maximum nodal height, (Δy_i) would be approximately 4 inches. The best tube arrangement which would meet these constraints is shown in Fig. II.7. Based on this tube arrangement, the maximum effective tube length was estimated to be approximately 200 ft.

The maximum water flow was calculated from an energy balance. From the Phase-I study, it was determined that the flow rates of the gas turbine engine exhaust were approximately 160 lb/sec and 100 lb/sec for full-load and half-load operation, and that the corresponding temperatures were 856°F and 796°F, respectively. If the gas exit temperature from the waste heat boiler were kept above 300F to avoid sulfuric-acid condensation (or corrosion) problems, the maximum amount of heat that could be recovered would be approximately 21 MW and 12 MW for engines operated at 100-percent and 50-percent power, respectively. Assuming that the feed water enters the waste heat boiler at 115.7°F (corresponding to a condenser pressure of 3 inch Hg.) and 300 psia, and leaves the boiler as a superheated steam, the maximum water flow rates for a gas turbine operated at 100-percent and 50-percent power would be approximately 18 lb/sec and 11 lb/sec, respectively. In parametric performance analyses, the water flow rates were varied in increment of 0.5 lb/sec per step to investigate the effect of this factor on the performance of the waste-heat boiler.

After the values of all parameters were defined, the parametric performance analyses were conducted. The results of these analyses (which are presented in terms of steam temperature, gas exit temperature, gas side pressure loss, and overall heat transfer rate as function of water flow rate) for all four tube-design configurations and for gas turbine operated at full power are shown in Figs. II.8 through II.11. The water-side pressure loss is not shown because the pumping power required for pressurizing the water has essentially no effect on the cycle efficiency. Results shown in Figs. II.8 through II.11 indicate that the arrangements of tube design indeed have a significant effect on the performance of the waste-heat boiler. Generally speaking, Configuration 1 would perform better than Configurations 3, 2, and 4 in that order if boiler efficiency were the only concern.

Figure II.8 shows that, for a given tube design configuration, the water flow rate can be regulated to yield a wide range of steam temperatures desired. However if the water flow rate were greater than 15.6 lb/sec for Configuration No. 3 (Fig. II.6) a wet steam would be produced. If the water flow rate were too low, the boiler would operate below its attainable efficiency (see Fig. II.11). The experience gained at UTRC from studies of waste-heat recovery systems indicates that a 700-degree Fahrenheit steam at approximately 300 psia would be a practical design for a Rankine-cycle power conversion system application. Therefore, this steam condition was selected as reference in the final selection of a baseline design of waste heat boiler for naval applications.

In order to examine the sulfuric-acid condensation problem on the cold end of the waste heat boiler, the gas exit temperatures were plotted as a function of the water flow rate for all four tube design configurations; these data are shown in Fig. II-9. The constant temperature lines (shown in dash-line) were obtained from Fig. II.8. It is seen that for an effective tube length of 200 ft, the gas exit temperature would be between 370°F and 480°F, or well above the sulfuric corrosion formation temperature of 300°F. Another implication of these data is that it is possible to improve the waste-heat boiler performance by increasing the overall heat transfer area if there is no space limitation and if the gas-side pressure loss can be tolerated.

The effects of tube design configuration and water flow rate on the gas-side pressure loss and on the overall heat transfer rate are shown in Figs. II.10 and II.11, respectively. It can be seen from these figures that the pressure loss varied between 0.7 psia and 2.0 psia for the parameter ranges considered. These pressure loss values were used in identifying the correction factor for gas turbine output power which will be discussed later (Section II.5).

II.4 Off-Design Performance Analysis

In order to compare the performance characteristics of a given waste heat boiler design at different operating conditions, the uniform flow distribution data presented in Fig. II.5 for gas turbines operated at 50-percent power were also considered. The results of this parametric performance analysis were compared with those obtained previously based on the design-point conditions. In Figs. II.12 through II.15, these comparisons are shown in terms of steam temperature, overall heat transfer rate, gas exit temperature, and gas-side pressure loss, respectively. The solid lines are results for gas turbine operated at 100-percent power and the dotted lines are for 50-percent power cases. The relationships of performance to tube design configuration is presented in detail in the following Section (II.5).

Figure II.12 shows that if these candidate waste-heat boilers (Configurations 1 through 4) were integrated with a given gas turbine which was operated at half-load, the water flow rate must be reduced significantly in order to generate the same quality steam (i.e. with the same steam temperature). For example, if the steam temperature required is 700°F, the water flow rate would have to be between 6.8 and 8.4 lb/sec for gas turbine operated at half power, and between 11.0 and 14.5 lb/sec for gas turbine operated at full power. The overall heat transfer characteristics which correspond to these operating conditions are shown in Fig. II.13. There, it can be seen that the maximum heat transfer rate attainable by these candidate boilers would range between 9600 and 11500 Btu/sec at half power and between 15400 and 19400 Btu/sec at full power of the gas turbine engine considered (LM 2500 or similar model).

The gas exit temperature and the gas-side pressure loss characteristics for the waste-heat boilers are shown in Figs. II.14 and II.15. It is seen that the lowest gas temperature shown in Fig. II.14 still exceeds 300°F, which implies that the sulfuric corrosion would not occur. Figure II.15 shows that when these candidate waste-heat boilers were integrated with gas turbine at 50-percent power, the gas turbine back pressure would be between 0.3 and 0.8 psia, indicating that those tube design configurations are technically acceptable from the turbomachinery performance view point.

II.5 Baseline Waste Heat Boiler

The background information which was used to select a baseline design configuration for waste-heat boiler in marine propulsion applications are presented in Figs. II.16 through II.19. Figure II.16 summarizes the performance characteristics of four candidate tube design configurations at steam temperature of 700°F for a gas turbine operated at 100-percent power. Similar performance data for a gas turbine operated at 50-percent power are presented in Fig. II.17.

Based on the heat transfer rate shown on the far right frame of Figs. II.16 and II.17, Configuration No. 1 would yield better performance than Configuration No. 3, No. 2 and No. 4 in that order. However, the gas-side pressure losses for these boiler configurations also decreases in the same order. Unfortunately the higher the gas-side pressure loss, the higher is the back pressure to the gas turbine, and according to the correction factor for exhaust pressure loss shown in Fig. II.18 the greater will be the loss in turbine power output.

It is known that a most desirable waste-heat boiler design should be one which can provide the greatest net gain in power output when coupled with a Rankine cycle power conversion system. In order to evaluate the net gain in power output, the cycle efficiency of the Rankine cycle power conversion system must be identified. From the results of a waste-heat recovery system study conducted at UTRC (Ref. 2.9), it was determined that, for steam condition of 700°F and 3000 psia and a condenser pressure of 3 inch Hg, the cycle efficiency of a typical steam Rankine system is approximately 22 percent. Therefore, the net gain in overall power system is equal to the difference between the Rankine cycle power output and the loss in gas turbine output power due to the increased back pressure. The results of this comparison is shown in Fig. II.19.

The left frame of Fig. II.19 shows the net-gain power for a gas turbine operated at 100-percent power. It was found that Configurations No. 2 and No. 4 would provide almost equal value of net-gain power and this gain is substantially higher than that estimated for the other two configurations. In contrast, the right frame of the same figure shows that at a 50-percent (gas turbine) power condition, Configuration No. 3 is the most desirable selection. Because improvement in the propulsion system efficiency at cruise conditions is of primary concerns in naval ship operation, Configuration No. 3 was selected

as baseline design configuration for the marine gas turbine waste-heat steam generator application. The design conditions of the baseline waste-heat boiler can now be defined as those which correspond to gas turbines operated at 50-percent power, and off-design conditions are defined as those where gas turbines operate at any power level other than the 50-percent point.

The temperature distribution inside the baseline waste heat boiler operated at its design condition (as defined immediately above) is shown in Fig. II.20, and the overall heat transfer coefficients (defined as UA in Equation 6) are shown in Fig. II.21. These results were obtained from performance calculations using the miniature heat exchanger approach and the nodal system. Similar information for off-design condition (corresponding to gas turbine 100-percent power) are shown in Figs. II.22 and II.23. From the temperature distribution maps (Figs. II.20 and II.22), it was determined that this waste-heat boiler can be divided into three distinctive regions; a liquid-phase heating region, a boiling-phase region, and a superheated-vapor region. In liquid-phase region, which occupies about one-third of the upper portion of the boiler, the feedwater is heated from 115°F to its saturation temperature (which is 417°F for steam pressure of 300 psia). In the boiling-phase region, which is shown by a shaded boundary and occupies approximately 60 percent of the boiler volume, the feedwater would go through an isothermal boiling process. After boiling, the saturated steam would be superheated in the last 10 percent of the boiler whereupon it would be discharged at 700°F .

From these two temperature distribution maps in Figs. II.20 and II.21, it was determined that the temperature gradient between any two nodes is less than 20°F and relatively uniform under the two steady-state operations. Therefore, the thermal stress concentration should not be a problem. However, based on the performance and design requirements, the water velocity was calculated to be approximately 0.5 to 1.2 ft/sec and the gas velocity was approximately between 80 to 130 ft/sec. The transient response of heat transfer characteristics and thermal stress concentration could become severe under the dry-running or changing load operations and this should be investigated before the final design is undertaken.

The product of the overall heat transfer coefficient (U) and the gas side heat transfer areas (A_g) for all nodes (miniature heat exchangers) are shown in Figs. II.21 and II.23 for baseline waste heat boiler operated at design (gas turbine 50-percent power) and off-design (gas turbine 100-percent power) condition, respectively. These values were computed using the averaged temperatures shown in Figs. II.20 and II.22. From these results, it was determined that the value of UA varied between 1720 and 2585 Btu/hr-F for the design condition and between 2100 and 3000 Btu/hr-F for the off-design operation. It is believed that these values are mainly determined by the gas-side film coefficient rather than by the water-side film coefficient, and are generally within the range of current design practices.

II.6 Effect of Flow Distribution Control on Baseline Waste-Heat Boiler

The actual flow distribution data with and without flow distribution control (see Figs. II.4 and II.5) were used as input to the analytical model for analyzing the effect of flow distribution-control on the performance of the baseline waste heat boiler. The results of this analysis are presented in Figs. II.24 to II.31.

The effects of flow distribution control on steam temperature of the baseline waste heat boiler operated at design (gas turbine 50-percent power) and off-design (gas turbine 100-percent power) conditions are shown in Figs. II.24 and II.25, respectively. It should be noticed that only those water flow rates which can provide superheated steam were considered. The steam temperatures attainable for the uniform flow distribution, actual flow distribution with and without flow distribution controls cases are shown in solid, dashed, and semi-broken lines, respectively. These results show that if the baseline waste heat boiler were designed for uniform flow distribution and for generated steam 700°F, and if it were operated with actual flow distribution without flow distribution, the steam temperature would decrease to approximately 450°F. However, the steam temperature could be maintained at 700°F if the water flow rate were reduced from 7.9 lb/sec to 6.6 lb/sec. If this occurred, the overall heat transfer rate would be reduced from 10167 to 8540 Btu/sec. On the other hand, from Fig. II.24, it can be seen that if flow distribution control were employed and if the water flow rate were maintained at its design condition (7.9 lb/sec), the steam temperature would increase by approximately 25°F. Alternately, if the steam temperature were to be maintained at the design condition (700°F), the water flow would increase to 8.1 lb/sec. The factors attributing to this improvement in boiler efficiency are believed to be partly attributable to more uniform flow distribution and partly to increased gas flow rate in boundary layer separation control (see Fig. II.3).

The heat transfer performance characteristics of the baseline waste heat boiler operated at design and off-design condition for cases with and without flow distribution controls are shown in Fig. II.26. Again the solid lines represent the results of the assumed uniform flow condition, and the dash lines and semi-broken lines are for cases with and without flow distribution controls. The asterisk represents the conditions where the 700°F steam would be generated. One can readily see that significant improvement in boiler efficiency would be expected if flow distribution controls were employed. The percentage of the boiler efficiency improvement is shown in Fig. II.27 for the baseline waste-heat boiler operated at its design condition.

In Fig. II.27 which illustrates the effect of flow distribution control on the performance of a waste-heat boiler, the overall heat transfer rate for the assumed uniform flow distribution was used as reference. The overall heat transfer rates for constant water (or steam) flow rate and for constant steam temperature were obtained from Fig. II.26. In Fig. II.27 it can be seen that, without flow distribution control (blank bars), if the water flow rate were held

constant at 7.9 lb/sec, the overall heat transfer rate would be reduced by approximately 10 percent which, in turn, would lower the steam temperature by approximately 250°F. On the other hand, if the water flow rate were regulated so as to maintain a constant steam temperature of 700°F, the overall heat transfer rate would be reduced by approximately 16 percent. Although this loss is greater than that for the constant flow rate case, a constant-steam-temperature operation would probably be more suitable for Rankine cycle power conversion system applications. Similarly, the shaded bars shown in the same figure are for the results with flow distribution control. It was found that approximately a 20 percent improvement in boiler efficiency would be expected for the baseline waste heat boiler if flow distribution control were considered.

The predicted temperature distribution for the baseline waste-heat boiler operating at design conditions and based on the actual velocity data with and without flow distribution controls are shown in Figs. II.28 and II.29, respectively; the corresponding overall heat transfer coefficients for these two flow cases are shown in Figs. II.30 and II.31. From Figs. II.28 and II.29, it is seen that the gas temperature near the exit becomes highly nonuniform, and that this nonuniformity is more apparent in the absence of flow distribution controls. This temperature distribution nonuniformity is certain to cause uneven thermal expansion in the heat-exchanger tubes, which in turn may result in thermal stress concentration problems. It is also seen that due to the no-flow condition occurring in the far-right column (uncontrol case), the gas temperatures and the liquid temperature may be in equilibrium (see Fig. II.28), indicating a region of "no-heat-transfer" within the waste-heat boiler (see Fig. II.30). The performance degradation of the waste-heat boiler can then be expected when no proper flow distribution control methods are implemented.

The effects of gas inlet temperature on the baseline waste heat boiler performance were also investigated and the results obtained are shown in Fig. II.32. From these results, it can be seen that change in gas inlet temperature would have more profound effect on the baseline waste heat boiler performance under constant steam temperature operation than under constant steam flow rate operation.

REFERENCES

- 2.1 Kays, W. M. and A. L. London: Compact Heat Exchanger, McGraw Hill, 1958.
- 2.2 Chiappetta, L. M. and E. J. Szetela: A Heat Exchanger Computational Procedure for Temperature Dependent Fouling, ASME paper 81-HT-75, August, 1981.
- 2.3 Shu, Ho-Tien and Simion C. Kuo: Flow Distribution Control Characteristics in Marine Gas Turbine Waste-Heat Recovery Systems, Phase 1 - Flow Distribution Characteristics and Controls in Diffusers, UTRC R81-955200-4, August 1981.
- 2.4 Chen, J. C.: Correlations for Boiling Heat Transfer to Saturated Fluids in Convective Flow, I&EC Process Design and Development, Vol. 5, No. 3, July 1966.
- 2.5 Lockhart, R. W. and R. C. Martinelli: Proposed Correlation of Data for Isothermal Two-Phase, Two-Component Flow in Pipes. Chem. Eng. Progress Vol. 45, No. 1, 639, Jan. 1949.
- 2.6 Keenan, J. H. et al: Steam Tables; Metric Units, John Wiley and Sons, New York, 1969.
- 2.7 Kestin, J.: Thermal Conductivity of Water and Steam, Mech. Eng., 48, Aug. 1978.
- 2.8 No Author: New Values for the Viscosity of Water Substance, Mech. Eng. Vol. 98, No. 7, July 1976.
- 2.9 Biancardi, F. R. et al.: Technology Data Base Evaluation of Waste Heat Recovery Systems. UTRC R77-952642-1, Jan. 1977.

TABLE II.1


(A) Constant for Equation (1a), (1b), and (1c)

Laminar Flow	:	$C_1 = 0.595$	$C_2 = 0.498$	$C_3 = 0.140$	
Turbulent Flow	:	$C_1 = 0.0046$	$C_2 = 0.927$	$C_3 = 0.628$	
Supercritical Flow:		$C_1 = 0.003354$	$C_2 = 0.951$	$C_3 = 0.435$	$C_4 = 0.38$

(B) Constant for Equations (4a), (4b), (4c), (5a), and (5b)


	Turbulent-Turbulent $NRe_f > 2000, NRe_g > 2000$	Viscous-Turbulent $NRe_f < 1000, NRe_g > 200$	Turbulent-Viscous $NRe_f > 2000, NRe_g < 1000$	Viscous-Viscous $NRe_f < 1000, NRe_g < 1000$
m	0.25	0.25	1.0	1.0
n	0.25	1.0	0.25	1.0
C_l	0.079	16.0	0.079	16.0
C_v	0.079	0.079	16.0	16.0
N	4.0	3.50	3.50	2.75*

NODALIZATION OF MARINE C 3INE WASTE HEAT STEAM GENERATOR



ACTUAL FLOW DISTRIBUTION WITHOUT FLOW DISTRIBUTION CONTROL


● GAS TURBINE 50% POWER



81-6-95-19

ACTUAL FLOW DISTRIBUTION WITH FLOW DISTRIBUTION CONTROL

● GAS TURBINE 50% POWER



**GAS FLOW INLET CONDITIONS FOR MARINE GAS TURBINE
WASTE HEAT BOILER — GAS TURBINE 100% POWER**

ΔX = WIDTH OF THE GAS FLOW PATH, (in)

\dot{M} = AVERAGED FLOW RATE, (lb/sec)

P = AVERAGED STATIC PRESSURE, (psia)

T = AVERAGED STATIC TEMPERATURE, (°F)

FLOW DISTRIBUTION	AVERAGED FLOW PARAMETERS						
	PARA.	GAS FLOW PATH NUMBER					
		1	2	3	4	5	6
UNIFORM FLOW	ΔX	24	24	24	24	24	—
	\dot{M}	32	32	32	32	32	—
	T	856	856	856	856	856	—
	P	14.94	14.94	14.94	14.94	14.94	—
ACTUAL FLOW DISTRIBUTION WITHOUT CONTROL	ΔX	24	24	24	24	24	—
	\dot{M}	80.3	50.6	15.5	13.6	0.0	—
	T	856	856	856	856	856	—
	P	14.90	14.90	14.90	14.90	14.90	—
ACTUAL FLOW DISTRIBUTION WITH CONTROL	ΔX	24	24	12	12	24	24
	\dot{M}	16.7	45.8	33.4	27.3	33.8	19.0
	T	856	856	856	856	856	856
	P	14.96	14.96	14.96	14.89	14.89	14.89

**GAS FLOW INLET CONDITIONS FOR MARINE GAS TURBINE
WASTE HEAT BOILER — GAS TURBINE 50% POWER**

ΔX = WIDTH OF THE GAS FLOW PATH, (in)

\dot{M} = AVERAGED FLOW RATE, (lb/sec)


P = AVERAGED STATIC PRESSURE, (psia)

T = AVERAGED STATIC TEMPERATURE, (°F)

FLOW DISTRIBUTION	AVERAGED FLOW PARAMETERS						
	PARAMETER	GAS FLOW PATH NUMBER					
		1	2	3	4	5	6
UNIFORM FLOW	ΔX	24	24	24	24	24	—
	\dot{M}	20	20	20	20	20	—
	T	796	796	796	796	796	—
	P	14.83	14.83	14.83	14.83	14.83	—
ACTUAL FLOW DISTRIBUTION WITHOUT CONTROL	ΔX	24	24	24	24	24	—
	\dot{M}	50.2	31.6	9.7	8.5	0.0	—
	T	796	796	796	796	796	—
	P	14.82	14.82	14.82	14.82	14.82	—
ACTUAL FLOW DISTRIBUTION WITH CONTROL	ΔX	24	24	12	12	24	24
	\dot{M}	10.4	28.6	20.9	17.1	21.1	11.9
	T	796	796	796	796	796	796
	P	14.84	14.84	14.84	14.82	14.82	14.82

CONFIGURATIONS OF CIRCULAR FINNED TUBES FOR MARINE WASTE-HEAT BOILER APPLICATION

(FROM CONTACT HEAT EXCHANGER BY KAYS AND LONDON)




**TUBE DESIGN
CONFIGURATION**

	$\frac{a}{(in.)}$	$\frac{b}{(in.)}$	$\frac{d_1}{(in.)}$	$\frac{d_2}{(in.)}$	$\frac{FINS}{inch}$
1	1.900	2.000	1.400	1.000	8.8
2	3.000	2.000	1.400	1.000	8.8
3	1.900	1.750	1.400	0.750	9.00
4	2.750	1.750	1.400	0.750	9.00

BEST AVAILABLE COPY


81-12-58-6

TUBE ARRANGEMENT FOR MARINE GAS TURBINE WASTE-HEAT STEAM GENERATOR APPLICATIONS




**EFFECT OF TUBE DESIGN CONFIGURATION AND WATER FLOW RATE ON
STEAM TEMPERATURE — GAS TURBINE 100% POWER**

- GAS INLET CONDITION UNIFORM (160 lb/sec, 14.94 psia)
- WATER INLET CONDITION UNIFORM, 115.7°F, 300 psia
- EFFECTIVE TUBE LENGTH = 200 ft




**EFFECT OF TUBE DESIGN CONFIGURATION AND WATER FLOW RATE ON
GAS EXIT TEMPERATURE — GAS TURBINE 100% POWER**

- GAS INLET CONDITION: UNIFORM (160 lb/sec, 14.94 psia)
- WATER INLET CONDITION: UNIFORM (115.7°F, 300 psia)
- EFFECTIVE TUBE LENGTH: 200 ft




**EFFECT OF TUBE DESIGN CONFIGURATION AND WATER FLOW RATE ON
GAS SIDE PRESSURE LOSS — GAS TURBINE 100% POWER**

- GAS INLET CONDITION: UNIFORM (160 lb/sec, 14.94 psia)
- WATER INLET CONDITION: UNIFORM (115.7°F, 300 psia)
- EFFECTIVE TUBE LENGTH = 200 ft




**EFFECT OF TUBE DESIGN CONFIGURATION AND WATER FLOW RATE ON
HEAT TRANSFER RATE — GAS TURBINE 100% POWER**

- GAS INLET CONDITION: UNIFORM (160 lb/sec, 14.94 psia)
- WATER INLET CONDITION: UNIFORM (115.7°F, 300 psia)
- EFFECTIVE TUBE LENGTH: 200 ft



COMPARISON OF STEAM TEMPERATURE FOR WASTE HEAT BOILERS OPERATED AT DESIGN AND OFF-DESIGN CONDITIONS


• UNIFORM FLOW AND EFFECTIVE TUBE LENGTH = 200 ft



82-5-86-14


COMPARISON OF HEAT TRANSFER RATE FOR WASTE HEAT BOILERS OPERATED AT DESIGN AND OFF-DESIGN CONDITIONS

● UNIFORM FLOW AND EFFECTIVE TUBE LENGTH = 200 ft



COMPARISON OF GAS EXIT TEMPERATURE FOR WASTE HEAT BOILERS OPERATED UNDER DESIGN AND OFF-DESIGN CONDITIONS


● UNIFORM FLOW AND EFFECTIVE TUBE LENGTH = 200 ft



82-3-86-9



COMPARISON OF GAS-SIDE PRESSURE LOSS FOR WASTE HEAT BOILERS OPERATED AT DESIGN AND OFF-DESIGN CONDITIONS

● UNIFORM FLOW AND EFFECTIVE TUBE LENGTH = 200 ft





PERFORMANCE CHARACTERISTICS OF WASTE HEAT BOILERS AT CONSTANT STEAM TEMPERATURE — 700°F

- EFFECTIVE TUBE LENGTH = 200 ft
- GAS TURBINE 100% POWER, UNIFORM FLOW DISTRIBUTION
- WATER INLET CONDITION: 15.7°F, 300 psia




PERFORMANCE CHARACTERISTICS OF WASTE HEAT BOILER AT CONSTANT STEAM TEMPERATURE — 700°F

- EFFECTIVE TUBE LENGTH = 200 ft
- GAS TURBINE 50% POWER, UNIFORM FLOW
- WATER INLET CONDITION 115.7°F, 300 psia





**APPROXIMATE OUTPUT POWER CORRECTION FACTOR
FOR EXHAUST PRESSURE DROPS**



COMPARISONS OF NET GAINS IN POWER BY INSTALLATIONS OF WASTE-HEAT BOILER


- NET-GAIN POWER (shp) = $0.22 \times \text{HEAT TRANSFER RATE}/0.746$ — CF X TURBINE POWER WHERE
CF REPRESENTS CORRECTION FACTOR GIVEN IN FIG II.18



**DISTRIBUTION OF AVERAGED TEMPERATURES FOR BASELINE WASTE HEAT BOILER
OPERATED AT DESIGN CONDITION (GAS TURBINE 50% POWER, UNIFORM FLOW)**


T_l = LIQUID TEMPERATURE, °F

T_g = GAS TEMPERATURE, °F



DISTRIBUTION OF OVERALL HEAT TRANSFER COEFFICIENT FOR BASELINE WASTE HEAT BOILER OPERATED AT DESIGN CONDITION (GAS TURBINE 50% POWER, UNIFORM FLOW)


• HEAT TRANSFER COEFFICIENT IN $\text{Btu/hr}\cdot\text{ft}^2\cdot\text{F}$



**DISTRIBUTION OF AVERAGED TEMPERATURES FOR BASELINE WASTE HEAT BOILER
OPERATED AT OFF-DESIGN CONDITION (GAS TURBINE 100% POWER, UNIFORM FLOW)**


T_l = LIQUID TEMPERATURE, °F

T_g = GAS TEMPERATURE, °F




**DISTRIBUTION OF OVERALL HEAT TRANSFER COEFFICIENT FOR BASELINE WASTE HEAT
BOILER OPERATED AT OFF-DESIGN CONDITION (GAS TURBINE 100% POWER,
UNIFORM FLOW)**


• HEAT TRANSFER COEFFICIENT IN $\text{Btu/hr}\cdot\text{ft}^2$




82-6--88-4

**EFFECT OF FLOW DISTRIBUTION CONTROL ON STEAM TEMPERATURE OF BASELINE
WASTE HEAT BOILER AT DESIGN CONDITION**

**EFFECT OF FLOW DISTRIBUTION CONTROL ON STEAM TEMPERATURE OF BASELINE
WASTE HEAT BOILER AT OFF-DESIGN CONDITION**



OFF-DESIGN PERFORMANCE CHARACTERISTICS OF GAS TURBINE WASTE-HEAT STEAM GENERATOR




82-3-108-1


EFFECT OF FLOW DISTRIBUTION CONTROL ON WASTE HEAT RECOVERY STEAM GENERATOR PERFORMANCE

Q_u OVERALL HEAT TRANSFER RATE FOR ASSUMED
UNIFORM FLOW DISTRIBUTION 50 % POWER

□ WITHOUT FLOW DISTRIBUTION CONTROL
▨ WITH FLOW DISTRIBUTION CONTROL




**DISTRIBUTION OF AVERAGED TEMPERATURE FOR BASELINE WASTE HEAT BOILER
OPERATED AT DESIGN CONDITION WITHOUT FLOW DISTRIBUTION CONTROL**



DISTRIBUTION OF AVERAGED TEMPERATURE FOR BASELINE WASTE HEAT BOILER OPERATED AT DESIGN CONDITION WITH FLOW DISTRIBUTION CONTROL


T_l = LIQUID TEMPERATURE, °F

T_g = GAS TEMPERATURE, °F



DISTRIBUTION OF OVERALL HEAT TRANSFER COEFFICIENT FOR BASELINE WASTE HEAT BOILER OPERATED AT DESIGN CONDITION WITHOUT FLOW DISTRIBUTION CONTROL


• HEAT TRANSFER COEFFICIENT (UA) IN Btu/hr-F




82-5-86-26

DISTRIBUTION OF OVERALL HEAT TRANSFER COEFFICIENT FOR BASELINE WASTE HEAT BOILER OPERATED AT DESIGN CONDITION WITH FLOW DISTRIBUTION CONTROL

• HEAT TRANSFER COEFFICIENT (UA) IN Btu/hr-F



**EFFECT OF GAS INLET TEMPERATURE ON PERFORMANCE OF MARINE GAS TURBINE
WASTE-HEAT STEAM GENERATOR**



SECTION III

FORMULATION OF EXPERIMENTAL PROGRAM AND SCHEDULE

The effect of flow distribution control on a marine gas turbine waste-heat boiler has been analyzed, and the results of this analysis are presented in Section II. It is obvious that a complex system like a waste-heat boiler cannot be designed and operated successfully without first conducting a carefully designed experimental program to generate sufficient technical information and operational experience. In this section, an experimental program formulated for the candidate waste-heat boiler is presented. The technical information and operational experience desired from this experimental program, the experiment program plan, and the overall program schedule and effort are discussed in detail.

III.1 Technical Information and Operational Experience Desired from the Experimental Program

As shown in Table III.1 the objectives of this suggested experimental program can be divided into two categories: (1) that which would provide sufficient technical information so comparisons with the analytical results can be made, and (2) that which would allow operational experience to be gained with the use of gas turbine waste-heat recovery propulsion systems. In order to obtain this technical information and operational experience, an experimental program must first provide for the preparation of components and instrumentation necessary for testing. Such preparation would include design specification of the component and instrument designs, then fabrication, preliminary demonstrations, and testing apparatus check-out.

A demonstration of steady state operation of an experiment model would seem the first step in the experiment program following the preparation tasks. However, before the experimental model can be operated at its steady state condition, the start-up and shut-down procedures would have to be specified and evaluated. Then the technical information and operational experience expected to be gained from this steady state operation can be obtained from flow visualization, and temperature and pressure measurements. Once the steady state demonstration is completed, the transient characteristics of the model can be demonstrated, particularly as they relate to naval ship propulsion applications. The technical information and operational experience expected to be gained from this transient (dynamic) operation demonstration should include those related to flow and temperature stability, thermal performance response, and possibly thermal stress concentration problems.

One major consideration in the design of a waste-heat steam generator for naval ship propulsion application is the characteristics and limitation of the additional shaft power obtainable from waste-heat recovery at different part-power operating condition of the gas turbine engine in order to match the duty-cycle operational (i.e. speed and time) requirements. The suggested experiment program should identify, at least qualitatively, the nature of these characteristics and limitations, if not specifically by estimating their magnitude. The effect of flow distribution control on power output limitation must also be estimated experimentally so that the results obtained can be compared with the analytical results of Section II in this report.

To assess control methodology, the experimental program should also provide sufficient information relating to the use of either pneumatic or electronic controls to regulate the performance of the waste-heat boiler system. This control system should be able to regulate the boiler pressure and feedwater flow rate so the temperature and flow rate of the gas turbine exhaust can be matched with the specified steam outlet temperatures. Since the waste-heat boiler will be required to operate under dry-running condition for self-cleaning purposes, the control system required to cope with the lost-of-coolant problem may not be critical, however appropriate devices to prevent such operating condition will be required.

The procedure to assess the dry-running operation of a marine gas turbine waste-heat boiler has yet to be established, although many of the routine operating procedures for marine waste-heat boilers may be similar to those for landbased combined cycle system operation. However, for the dry-running operation, special consideration must be given to the rate at which the feed water is drained and recharged to avoid undesirable damage or deterioration of the boiler tubes. This experimental program should produce valuable information to assist in establishing the dry-running procedure.

The U.S. Navy is expected to be quite interested in identifying the manpower requirements for a marine waste-heat recovery propulsion system. Again, the experimental program should clarify this question through an assessment of system maintainability and reliability. Areas of manpower needs should be quite similar to those of landbased waste-heat recovery plants, while the number of men needed in a marine propulsion application could be reduced if the waste-heat boiler were designed with less complexity and higher reliability. The importance of gaining as much data and operating experience as possible cannot be overemphasized when dealing with the maintainability, reliability and safety characteristics which are common concerns for any new system.

III.2 Experiment Program Plan

An experimental program plan for the flow distribution control study of marine gas turbine waste heat boiler has been prepared. This program consists of four major tasks as shown in Table III.2. The first task involves the design and fabrication of the experiment model, while the second task is devoted to the set-up of experimental apparatus including the acquisition of necessary auxiliary components. Tasks 3 and 4 are directed toward conducting the actual experiment, including data recording and post test evaluation.

III.2.1 Design and Fabrication of Experiment Model

The first step in the design and fabrication of the experimental model is to determine the model size. Because the cost of building a full-scale test model as well as the heat source required for the experiment would be enormous, a one-fifth scale model is suggested. It is believed that this scaled model can be designed and fabricated in a reasonable time frame and at an acceptable cost that would provide these desired information described in Table III.1.

The thermal condition (flow rate, temperature, and pressures) of the working fluid are usually determined from the availability of the test (auxiliary) equipment and by using the principles of similitude. In principle, the test model and the full-scale unit should have the same Nusselt, Prandtl, Reynolds, and Mach numbers. The flow passage in the test model and that of the full-scale unit should also be geometrically similar. Because the detailed temperature and flow distributions are the primary concerns in the present study, it is more desirable to use larger flow passages with fewer number of tubes in the model. As long as the flow conditions are based on the principles of similitude, the pressure loss and heat transfer characteristics in the test model should differ little from the full-scale unit.

The instrumentation needed for the present study must be capable of measuring temperature, pressure, and flow conditions. In a conventional heat exchanger experiment, as few as four temperature measurements might suffice (that is, the inlet and outlet temperatures for the hot and cold fluids). However, in the suggested program where the boiler is a single-pass counter crossflow heat exchanger, the outlet temperatures will not be uniform. Accordingly, at least fifteen temperature measurements would be required to identify the inlet and exit flow conditions. If internal temperature distributions are also to be measured (as shown in Figs. II.20 and II.22), additional temperature probes would be needed.

The magnitude of pressure drop across the heat-transfer matrix particularly on the gas side of the waste-heat boiler is as important as the heat-transfer performance. The test rig may be designed so the duct cross section is the same as that of the inlet face of the heat-transfer matrix under test, in which

case simple static pressures in the duct may be satisfactory. If this is not practical, allowances should be made for differences in the kinetic pressure head which changes with flow passage size. It is important that at least ten diameters of straight duct precede the heat-transfer matrix to assume a uniform velocity distribution across the face of the duct. Because pressure drop data are important, it is more desirable to use the piezometer ring.

The simplest and most accurate means of measuring the gas flow for this experimental program would be to use a flow nozzle mounted at the air inlet and a draft fan be mounted on the outlet side of the heat-transfer matrix. This would preclude errors stemming from turbulence and poor velocity distribution in the flow-rate measurements. To measure the flow distribution in each gas path (see Fig. 11.20), pitot static tubes can be used. At least two pitot static tubes must be used for each gas path and each tube should be installed downstream of the heat transfer matrix in order to avoid disturbing the flow field in the test section. Finally, care must be exercised to minimize the flow leakage, heat loss, and boundary effect during the design and fabrication of the experiment model as severe flow leakage and heat loss could cause difficulties in the analysis of test results.

111.2.2 Auxiliary Equipment Set-Up

The auxiliary equipment needed for this experiment will include: a hot-air (or gas) supply and discharge system; a pressurized feedwater and steam handling system; a control device to regulate the flow rate, flow distribution, temperature, and pressure for both working fluids; and data acquisition and recording devices. One possible arrangement of the experimental apparatus is shown in Fig. 111.1.

The hot-air/hot-gas supply and discharge system would require a draft fan which should be mounted at the downstream of the test model, and a combustor which burns either natural gas or propane for generating hot gas needed to simulate the gas turbine exhaust. Both draft fan and combustor could be controlled from a central control box to obtain desirable gas flow rates and gas temperature. The pressurized feedwater supply system would consist of a pressurized feedwater manifold, a flow rate regulator, a steam manifold, a radiator, a condensate tank, and a pump. Both the flow rate regulator and the pump would be controlled by the central control device. A baffle plate should be installed in the diffuser to regulate the desirable gas flow distribution. All the test data including temperature, pressure, flow rates would be recorded by means of an automatic data acquisition and recording device for later evaluation and analysis.

II.2.3 Test Procedure

The test procedures to be conducted in this suggested experimental program must include, as a minimum, all items shown in category C of Table III.2. The first step in conducting the experiment would be to assemble and check-out the major components according to the layout drawing. Shakedown testing would then follow to demonstrate the functional capability and structural integrity of the experiment apparatus. Some minor modifications and adjustment might be necessary in the early stage of the experiment before substantive test program can be commenced. Piping and wiring details would be determined prior to the assembly of the experimental unit, and instrumentation and controls of the flow rate, temperature, and pressure would be installed and calibrated before the actual experiments were performed.

An extremely important aspect of the suggested program is flow visualization test in the flow distribution control study of gas turbine waste-heat recovery steam generator. As cited in Phase-I study (Section II.2 of Ref. II.3) the actual flow distribution at the exit of the gas turbine exhaust is highly irregular and nonuniform. The major portion of the flow was found to be near the rear section of the elbow and some reversed flow as observed in the regions near the front section. To complicate matters, these flow distributions are actually three-dimensional. In order to gain an insight into flow distribution nonuniformity in the waste-heat boiler performance, two-dimensional flow distributions were assumed in the analytical study. However, the results of such an analytical study can only be compared with those of the experimental study on the same basis, i.e. of a two-dimensional flow experiment. Therefore, for naval applicators, the experiments must also include three-dimensional flow distributions, since the results obtained from three-dimensional flow testing would be beneficial in any modifications of the analytical model, which is deemed necessary.

Flow visualization for the hot combustion gas can be conducted by attaching tufts of thread or yarn to the passage walls, or by attaching these tufts to a wire probe that can be moved about in the flow field. Smoke can also be employed, but its use is usually not very satisfactory because the smoke filament tends to be dispersed so rapidly by turbulence that the technique is applicable only for relatively low Reynolds numbers and simple geometries. It should be obvious that flow visualization tests can be conducted more conveniently if the models are made of a transparent plastic, such as Lucite.

When preparing for heat transfer performance testing, particularly with nonuniform flow distributions, consideration must be given to the flow stability to assure that the test data are consistent and repeatable. During the literature survey conducted in Phase-I study, it was noticed that the flow in the transitory stall region of a two-dimensional diffuser is inherently unstable, and any

disturbance could shift the stall region from one wall to the other. Therefore, a flow stability test must be conducted in conjunction with flow visualization. A simple way of assuring that fluid flow is stable is to take periodic flow measurements (five to ten-minute intervals are suggested) at each fixed operating condition. This procedure should be continued until three successive readings of flow measurement show negligible change.

The last item in the suggested test procedure of Table III.2 is the heat transfer performance test which should consist of a steady-state operation test and a transient (dynamic) operation test. In the steady-state operation, the thermal output characteristics and limitation of the waste heat boiler under various flow conditions should be determined. The effect of variations in flow rate and/or pressure of feedwater must be assessed, and the magnitude of such parameters as critical temperature, pressures, stresses, control feedbacks must be determined and examined as well.

The transient operation test would investigate the dynamic characteristics of the marine gas turbine waste heat boiler during the dry running and off-design operations. The first dynamic test should assess the effect of the heat input which varies according to the duty cycle operations. There are three possible operation modes: (1) variable gas temperature with constant flow rate; (2) variable gas flow rate with constant gas temperature; and (3) both variable gas temperature and flow rate. The response time and stability of heat exchanger performance under these dynamic tests should be determined and examined. If the steam temperature were maintained constant, the control procedure and control requirements would have to be identified. The most important information to be acquired from a dry running test would be the rate of draining and recharging the feedwater. In addition, following dry running, the metal temperature would be approximately 900 to 1000°F, and therefore the requirement of cool-down process must be determined. Finally, the possibility of wet running with static flow condition should also be explored during the transient.

III.2.4 Post Test Evaluation

The last task of the suggested experimental program plan should be the post experiment inspection and evaluation of the test results. This task would seek to assess the results of the experiment in terms of establishing requirements for future modifications to the waste heat boiler design and analysis.

The first phase of this last task would be routine inspection and examination of the test model to determine its general condition and to estimate whether any degradation in conditions may have affected the test results. Evaluation of the test results would then be made with particular emphasis being directed toward the technical information and operational experiences desired (refer to the discussion in Section III.1). Recommendations regarding to the future

design of marine gas turbine waste heat recovery propulsion systems should be included as part of this last task; methods directed at removing operational limitations should be explored; and reliability and maintenance requirements should also be assessed.

III.3 Overall Program Schedule and Effort

The overall program schedule formulated and man-hour effort estimated to conduct this suggested experimental study are shown in Fig. III.2. Although overlaps in program schedule for certain activities are necessary because of the nature of a particular test or because of the need to shorten the performance period, it can be seen that the activities described are generally consistent with the program plan discussed in Section III.2.

The longest period required for this suggested experimental study would be those for model preparation (activities No. 1 and No. 2) and heat transfer performance testing (activity No. 8); these would require approximately five and four months, respectively. The experiment apparatus setup time (including that for the acquisition of control devices, data recording system, pumps, blower, burner test site preparation, utility hook-up, piping, and wiring) as well as the shakedown would require approximately three months. Collectively, the flow visualization and flow stability tests would require approximately two months, and finally, two months would be needed for post test evaluations, analysis of test results, recommendation, and reports preparations.

The last column of Fig. III.2 shows the man hours estimated to completed each task. It can be seen that most of the engineering effort would be spent in model design definition and post test evaluation while the technician's time would be directed toward model fabrication, test rig setup, testing, and data recording. It should also be emphasized that a joint effort from engineer and technician is also necessary during each task to assure the success of the experimental program. Therefore, for the entire suggested program the total engineering time is estimated to be approximately 1000 hours and that for technician, approximately 2050 hours.

TABLE III.1

Technical Information and Operational Experience
Wanted From Experimental Program

A. Related to Flow Distribution Control Study

- . Design Specification of Test Apparatus
- . Steady-State Operation Demonstration
- . Transient (Dynamic) Operation Demonstration
- . Output Characteristics and Limitation Identification

B. Related to Naval Propulsion System Applications

- . Control Characteristics Assessment
- . Dry Running and Duty Cycle Operating Procedure Assessment
- . Maintainability, Reliability, and Safety Assessment
- . Operational Manpower Requirement Assessment

TABLE III.2

Experiment Program Plan

A. Design and Fabrication of Experiment Model

- . Size of experiment model
- . Test condition and consideration
- . Principles of similitude
- . Adequate and potent instrumentation
- . Leakage, heat loss, and boundary effects

B. Auxiliary Equipment Setup


- . Hot air/gas supply and discharge equipments
- . Water supply and steam handling equipments
- . Control devices
- . Data acquisition and recording devices

C. Test Procedure


- . Shake-down flow and structural tests
- . Calibration of instrumentation
- . Flow visualization test
- . Flow stability test
- . Heat transfer performance test

D. Post Test Evaluation

POTENTIAL LAYOUT OF EXPERIMENT APPARATUS FOR FLOW DISTRIBUTION
CONTROL STUDY OF MARINE WASTE HEAT STEAM GENERATOR



**PROGRAM SCHEDULE AND EFFORT FOR EXPERIMENTAL STUDY OF FLOW DISTRIBUTION
CONTROLS IN MARINE GAS TURBINE WASTE HEAT STEAM GENERATOR**



APPENDIX A

DESCRIPTIONS OF WASTE-HEAT BOILER COMPUTER PROGRAM

The heat exchanger computer program which was used to study the effect of flow distribution control on marine waste-heat steam generator performance was developed from the analytical model presented in Section II of this report. This program can be used to predict the overall performance, size, and manufacturing cost for many types of crossflow heat exchangers. It is applicable to nearly any kind of gas and liquid provided that their heat transfer and pressure loss correlations are expressed in the form shown in the book "Compact Heat Exchangers" by Kays and London. The surfaces of the heat exchanger core can be of plate-fin, finned-tube, or screen-matrices geometries. Although the program can be easily extended to other heat exchanger applications, it is currently limited to the cases where the gases are flowing on the shell side and the liquid is on the tube side. The liquid may undergo phase changes (from liquid phase to boiling phase, and then to superheated vapor, but not in reverse process) depending on the design requirement specified.

Program Structure

The program was organized in hierarchical structure as shown in Fig. A.1. The main program which is called HXMAIN is the commanding portion used to call the three subroutines (HXINPUT, HXCALC, and HXOUTPUT) which perform the specific tasks as indicated in their respective boxes in the figure. The subroutine HXINPUT reads the input data, interprets and initializes these data prior to the heat exchanger performance calculations, and finally stores all of the relevant information in the common blocks. The input data consists of a job title, job control parameters, the inlet flow conditions, the interconnection of flow paths, flow properties, and heat transfer and pressure loss correlations, all of which are explained in the next section.

The subroutine HXCALC is the calculation section of the heat exchanger program which is based on the flow equations and the computation process described in Section II of this report. This program takes the input data from the common blocks as needed during the computation process and also stores the computed results in the common blocks. The function of the HXOUTPUT routine is to translate the results of the heat exchanger performance computed by the HXCALC routine into practical engineering units and print them as hard-copy. The output results consist of convergence information, summary results, temperature distributions for gas, liquid, and tube walls, and heat transfer coefficients throughout the entire heat exchanger core.

The program which is written in Fortran language is implemented on a UNIVAC 1110/80 computer system and requires approximately 50K core storage. The computational time required for a typical study varies according to the tolerance of convergence and the number of nodes specified for the heat exchanger core. For the cases studied, each of which consist of five gas paths and one liquid path, one hundred nodes in heat exchanger core, and a five-degree-fahrenheit tolerance on the exit temperatures for both working fluids, the computational time was approximately 30 to 40 seconds.

In the following section, the input parameters are discussed, the results of a example run are presented, and the listing of the Fortran statements for the main program and three major subroutines are given.

Description of Input Data

The input data for the Waste-Heat Boiler Computer Program are listed in Tables A.1 and A.2. Table A.1 contains four different types of input data; the job title, the job control parameters, the inlet flow conditions, and the nodal connection method for each flow path.

The job title, which may be comprised of up to 72 characteristics, must be punched on a BCD card. The job control parameters (there are twenty two of them) are defined as follows:

NI = No. of nodes in I-direction (≤ 30)
 NJ = No. of nodes in J-direction (≤ 30)
 NPTHA = No. of paths for gas side (≤ 10)
 NPTHB = No. of paths for liquid side (≤ 10)
 NPRNT = option for printing the intermediate iteration results (=0 or 1)
 NDUMP = option for dumping the detail calculation for each iteration (=0 or 1)
 KOMPLX = option for using or not using the boiling heat transfer model (=0 or 1)
 NITER = maximum No. of iterations (default value = 25)
 YLEN = overall core height (= $\sum N_j \Delta j_j$ inches)
 XLEN = overall core width (= $\sum N_i \Delta x_i$ inches)
 ZA-ZB = overall core depth (inches)
 THKWAL = tube wall thickness (inches)
 TOTITR = convergence tolerance for iteration of the exit temperature of the fluids ($^{\circ}\text{F}$)
 TURNLA = factor for turn loss on the gas-side
 TURNLB = factor for turn loss on the liquid side
 NCOST = option for cost estimate (=0 or 1)
 NTYPE = types of heat exchanger (1 to 5)
 MTCORE = types of tubes material (1 to 8)
 MTSHEL = types of shell material (1 to 8)
 FACTF = fabrication complexity factor
 FACTE = escalation factor from Mid '70 dollar value

In addition to the job control parameters, there are several sets of input data which were used to describe the inlet flow conditions and the nodal connection method for each flow path (see line 6 to line 28, or line 29 to 51, etc. of Table A.1). The number of these data sets is equal to the number of gas paths (NPTHA) plus the liquid paths (NPTLB). The first two data cards for each data set contain ten parameters which are defined as follows:

WDOT = gas flow rate (lb/sec)
 PZRO = gas inlet pressure (psia)
 TZRO = gas inlet temperature (°F)
 DHYD = hydraulic diameter (inches)
 DELTAX = nodal width (inches)
 FAOFA = flow area/frontal area
 SAOV = surface area/volume
 FINTHK = fin thickness (inches)
 FINLEN = fin length (inches)
 FINSRF = fin area/surface area

The remainder of the input data are for flow direction, number of nodes, and nodal connection sequence. The liquid-side flow conditions and nodal connections (lines 122 to 223) are similar to those for the gas flow except that the last five parameters are replaced by a NTUBES parameter which is used to specify the number of tubes for that path.

The development of this heat exchanger computer code was developed to be independent of the working fluids, and therefore the user has complete freedom of choosing a working fluid to meet a specific need. Consequently, the thermal and physical properties of working fluids must be specified as part of the input data for the program. For application in the present study, the properties of air and water are tabulated in a special format as shown in Table A.2. It should be noted that each data set is preceded by an integer number which specifies the number of entries to be read.

The thermal and physical properties for the liquid-side working fluid are given in lines No. 1 through 209 of Table A.2. Lines No. 1 to No. 24 (which were not used in the present study) are the coke (scale) properties, the coke thickness as function of temperature, and the coke formation history as function of time. Lines 26 to 30 tabulate the saturation pressures (psia) and temperatures (°F). The formats for these entries are E10.5. Lines 31 to 33 are the empirical constants for computing the convective heat transfer coefficients (see Eqs. 1a to 1c in Section II of this report) for laminar-, turbulent-, or supercritical-flow.

Lines 35 to 56 provide the heat transfer correlations in terms of Reynolds number and $StPr^{2/3}$ for the vapor phase. Lines 58 to 66 tabulate the liquid properties including its the temperature ($^{\circ}F$), viscosity ($lb_m/ft\text{-}sec$), thermal conductivity ($Btu/ft\text{-}F\text{-}Hr$), specific heat at constant pressure ($Btu/lb_m F$) and density (lb_m/ft^3). The input format is also in E10.5. Line 67 consists of three parameters which represent the critical pressure (psia), critical temperature ($^{\circ}F$), and molecular weight.

Lines 68 to 119 are the tabulations of vapor properties which consist of the pressure (psia), temperature ($^{\circ}F$), density (lb/ft^3), viscosity ($lb_m/ft\text{-}sec$), thermal conductivity ($Btu/ft\text{-}F\text{-}Hr$) and specific heat at constant pressure ($Btu/lb_m\text{-}F$). Each parameter will be read in E10.5 format. The number of the pressure entries is specified by the first parameter on line 68 and the numbers of entries for other parameters at a given pressure are specified on line 69. The second parameter shown on line 68 represent the type of the working fluid: 1 for distillate and 2 for pure substance.

Lines 121 through 125 tabulate the saturation pressure (psia) and the heat capacity ($Btu/lb_m\text{-}F$) for the boiling mixture if the boiling heat transfer model is not used (i.e. $KOHFLX=0$). Lines 128 to 139 are the pressure (psia), the temperature ($^{\circ}F$) and the density (lb_m/ft^3) above the critical point. These data are also read in E10.5 format. There are three sets of pressure data (as shown on line 126) and at each pressure value, there are four sets of data for the temperature and density. Lines 141 to 145 give five saturation pressures (psia) and their corresponding values of heat of vaporization (Btu/lb). They all have the same input format of E10.5.

Lines 147 and 148 presents the data for temperature ($^{\circ}F$) and surface tension (dyne/cm). The F-function and the S-function required for boiling phase heat transfer computations (see Eqs. 3a and 3b in Section II of this report) are presented in lines 150 to 170 and lines 172 to 186, respectively. Finally, the friction coefficient (which was defined as $\Delta p = 4f\rho V^2 L / (2gD)$ as function of Reynolds number are presented in lines 188 to line 209.

The gas-side thermal and physical properties are tabulated in lines 210 to 265. Line 210 specifies the molecular weight of the gas while the temperature ($^{\circ}F$), molecular viscosity ($lb_m/ft\text{-}sec$), thermal conductivity ($Btu/ft\text{-}F\text{-}Hr$), and specific heat at constant pressure ($Btu/lb_m\text{-}F$) are presented in lines 212 to 230. The friction coefficient and the Stanton numbers as functions of Reynolds number are given in lines 232 to 246 and lines 248 to 262, respectively. Finally the wall (tube) thermal conductivity ($Btu/ft\text{-}F\text{-}Hr$) as function of temperature ($^{\circ}F$) are tabulated in lines 264 and 265. All these entries are also read in E10.5 format.

Sample Results

Based on the input data shown in Table A.1 and A.2, the computed results for heat exchanger performance are presented in Tables A.3 through A.7.

Table A.3 presents the convergence information; i.e., number of iterations and the tolerated errors in exit temperature of the working fluids between the last two iterations. The summary results, which include the flow conditions, the heat exchanger size, and the manufacturing cost estimate (not shown in this example), are shown in Table A.4.

Table A.5 shows the temperature distribution for the entire heat exchanger core, including the inlet, and the outlet as well as the mean temperatures for both working fluids and the wall temperatures on each side of the tubes for each node. The distributions of the convective heat transfer coefficient, the Reyno'ds number, and the overall heat transfer coefficient are shown in Table A.6. The liquid-side pressure loss characteristics, the steam quality, and the boiling heat transfer coefficients are shown in Table A.7.

List of Computer Programs

The listing for Fortran statement for the four major computer programs (HXMAIN, HXINPUT, HXCALC, HXOUTPUT) and the common block allocations are shown in Tables A.8 to A.12.

STRUCTURE OF WASTE-HEAT BOILER COMPUTER PROGRAM




TABLE A.1 INPUT DATA FOR MARINE WASTE-HEAT BOILER STUDY

1 MARINE WASTE-HEAT BOILER DESIGN STUDY (UNIFORM FLOW, 50% POWER)
 2 BRUNCON NI=27, NJ=5, NPTHA=5, NPTHE=1, APRNT=C, NDUMP=D, KOMPLX=1,
 3 YLEN=70.0, XLEN=120.0, ZA=84.0, ZB=84.0, THKVAL=C.095,
 4 TOLITR=5.0, TURNLA=C.0, TURNLB=C.0, NCOST=C, NTYPE=4,
 5 MTCORE=1, MTSHEL=1, FACTF=1.25, FACTE=3.11, 1END
 6
 7 20.0 14.834 796.0 0.322 24.0
 8 0.572 85.17 0.012 0.3445 0.835
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31 20.0 14.834 796.0 0.322 24.0
 32 0.572 85.17 0.012 0.3445 0.835
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53 20.0 14.834 796.0 0.322 24.0
 54 0.572 85.17 0.012 0.3445 0.835
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73

BEST AVAILABLE COPY

R82-955750-4

TABLE A.1 Cont'd

74	20.572	14.834	796.0	0.322	24.0
75	20.572	85.1	0.012	0.3445	0.835
76	20.572	85.1	0.012	0.3445	0.835
77	20.572	85.1	0.012	0.3445	0.835
78	20.572	85.1	0.012	0.3445	0.835
79	20.572	85.1	0.012	0.3445	0.835
80	20.572	85.1	0.012	0.3445	0.835
81	20.572	85.1	0.012	0.3445	0.835
82	20.572	85.1	0.012	0.3445	0.835
83	20.572	85.1	0.012	0.3445	0.835
84	20.572	85.1	0.012	0.3445	0.835
85	20.572	85.1	0.012	0.3445	0.835
86	20.572	85.1	0.012	0.3445	0.835
87	20.572	85.1	0.012	0.3445	0.835
88	20.572	85.1	0.012	0.3445	0.835
89	20.572	85.1	0.012	0.3445	0.835
90	20.572	85.1	0.012	0.3445	0.835
91	20.572	85.1	0.012	0.3445	0.835
92	20.572	85.1	0.012	0.3445	0.835
93	20.572	85.1	0.012	0.3445	0.835
94	20.572	85.1	0.012	0.3445	0.835
95	20.572	85.1	0.012	0.3445	0.835
96	20.572	85.1	0.012	0.3445	0.835
97	20.572	85.1	0.012	0.3445	0.835
98	20.572	85.1	0.012	0.3445	0.835
99	20.572	85.1	0.012	0.3445	0.835
100	20.572	85.1	0.012	0.3445	0.835
101	20.572	85.1	0.012	0.3445	0.835
102	20.572	85.1	0.012	0.3445	0.835
103	20.572	85.1	0.012	0.3445	0.835
104	20.572	85.1	0.012	0.3445	0.835
105	20.572	85.1	0.012	0.3445	0.835
106	20.572	85.1	0.012	0.3445	0.835
107	20.572	85.1	0.012	0.3445	0.835
108	20.572	85.1	0.012	0.3445	0.835
109	20.572	85.1	0.012	0.3445	0.835
110	20.572	85.1	0.012	0.3445	0.835
111	20.572	85.1	0.012	0.3445	0.835
112	20.572	85.1	0.012	0.3445	0.835
113	20.572	85.1	0.012	0.3445	0.835
114	20.572	85.1	0.012	0.3445	0.835
115	20.572	85.1	0.012	0.3445	0.835
116	20.572	85.1	0.012	0.3445	0.835
117	20.572	85.1	0.012	0.3445	0.835
118	20.572	85.1	0.012	0.3445	0.835
119	20.572	85.1	0.012	0.3445	0.835
120	20.572	85.1	0.012	0.3445	0.835
121	20.572	85.1	0.012	0.3445	0.835
122	20.572	85.1	0.012	0.3445	0.835
123	20.572	85.1	0.012	0.3445	0.835
124	20.572	85.1	0.012	0.3445	0.835
125	20.572	85.1	0.012	0.3445	0.835
126	20.572	85.1	0.012	0.3445	0.835
127	20.572	85.1	0.012	0.3445	0.835
128	20.572	85.1	0.012	0.3445	0.835
129	20.572	85.1	0.012	0.3445	0.835
130	20.572	85.1	0.012	0.3445	0.835
131	20.572	85.1	0.012	0.3445	0.835
132	20.572	85.1	0.012	0.3445	0.835
133	20.572	85.1	0.012	0.3445	0.835
134	20.572	85.1	0.012	0.3445	0.835
135	20.572	85.1	0.012	0.3445	0.835
136	20.572	85.1	0.012	0.3445	0.835
137	20.572	85.1	0.012	0.3445	0.835
138	20.572	85.1	0.012	0.3445	0.835
139	20.572	85.1	0.012	0.3445	0.835
140	20.572	85.1	0.012	0.3445	0.835
141	20.572	85.1	0.012	0.3445	0.835
142	20.572	85.1	0.012	0.3445	0.835
143	20.572	85.1	0.012	0.3445	0.835
144	20.572	85.1	0.012	0.3445	0.835
145	20.572	85.1	0.012	0.3445	0.835

BEST AVAILABLE COPY

R82-955750-4

TABLE A.1 Cont'd

146	16	45
147	16	45
148	15	45
149	15	45
150	15	45
151	15	45
152	14	45
153	14	45
154	14	45
155	14	45
156	14	45
157	14	45
158	13	45
159	13	45
160	13	45
161	13	45
162	13	45
163	13	45
164	13	45
165	13	45
166	13	45
167	13	45
168	11	45
169	11	45
170	11	45
171	11	45
172	11	45
173	10	45
174	10	45
175	10	45
176	10	45
177	9	45
178	9	45
179	9	45
180	9	45
181	9	45
182	9	45
183	9	45
184	9	45
185	9	45
186	9	45
187	9	45
188	7	45
189	7	45
190	7	45
191	7	45
192	7	45
193	6	45
194	6	45
195	6	45
196	6	45
197	6	45
198	5	45
199	5	45
200	5	45
201	5	45
202	5	45
203	5	45
204	5	45
205	5	45
206	5	45
207	5	45
208	5	45
209	5	45
210	5	45
211	5	45
212	5	45
213	5	45
214	5	45
215	5	45
216	5	45
217	5	45

BEST AVAILABLE COPY

R82-955750-4

TABLE A.1 Cont'd

218
219
220
221
222
223

1
1
1
1
1
1

CAJJD .PROPTY3

5
4
3
2
1

BEST AVAILABLE COPY

TABLE A.2 THERMAL AND PHYSICAL PROPERTIES FOR WATER AND AIR

1	0.33	19			
2					
3	150.0				
4	200.0				
5	250.0				
6	300.0				
7	350.0				
8	400.0				
9	450.0				
10	500.0				
11	550.0				
12	600.0				
13	650.0				
14	700.0				
15	750.0				
16	800.0				
17	850.0				
18	900.0				
19	1000.0				
20	1200.0				
21	1300.0				
22					
23					
24					
25					
26	.2000+03		.3619+03		
27	.2500+03		.4010+03		
28	.3000+03		.4401+03		
29	.3500+03		.4792+03		
30	.4000+03		.5183+03		
31	.4500+03		.5574+03		
32	.5000+03		.5965+03		
33	.5500+03		.6356+03		
34	.6000+03		.6747+03		
35	.6500+03		.7138+03		
36	.7000+03		.7529+03		
37	.7500+03		.7920+03		
38	.8000+03		.8311+03		
39	.8500+03		.8702+03		
40	.9000+03		.9093+03		
41	.9500+03		.9484+03		
42	1.0000+03		.9875+03		
43	1.0500+03		1.0266+03		
44	1.1000+03		1.0657+03		
45	1.1500+03		1.1048+03		
46	1.2000+03		1.1439+03		
47	1.2500+03		1.1830+03		
48	1.3000+03		1.2221+03		
49	1.3500+03		1.2612+03		
50	1.4000+03		1.3003+03		
51	1.4500+03		1.3394+03		
52	1.5000+03		1.3785+03		
53	1.5500+03		1.4176+03		
54	1.6000+03		1.4567+03		
55	1.6500+03		1.4958+03		
56	1.7000+03		1.5349+03		
57	1.7500+03		1.5740+03		
58	.5000+02	.8776+03	.3369+00	.1005+01	.6246+02
59	.1000+03	.4582+03	.3622+00	.9987+00	.6205+02
60	.1500+03	.2897+03	.3765+00	.1001+01	.6124+02
61	.2000+03	.2044+03	.3908+00	.1006+01	.6017+02
62	.2500+03	.1550+03	.3957+00	.1016+01	.5887+02
63	.3000+03	.1237+03	.3959+00	.1030+01	.5736+02
64	.3500+03	.1027+03	.3911+00	.1051+01	.5564+02
65	.4000+03	.8786+04	.3818+00	.1079+01	.5367+02
66	.4174+03	.8366+04	.3774+00	.1092+01	.5292+02
67	.3206+04	.7054+03	.1800+02		
68					
69					
70	.2000+03	.3619+03	.4368+00	.1047+04	.2196+01
71	.2000+03	.4000+03	.4235+00	.1077+04	.2199+01
72	.2000+03	.4500+03	.3925+00	.1159+04	.2269+01
					.6488+00
					.6236+00
					.5762+00

TABLE A.2 Cont'd

73	.2	.5	.3	.1	.2	.5
74	.2	.5	.3	.1	.2	.5
75	.2	.5	.3	.1	.2	.5
76	.2	.5	.3	.1	.2	.5
77	.2	.5	.3	.1	.2	.5
78	.2	.5	.3	.1	.2	.5
79	.2	.5	.3	.1	.2	.5
80	.2	.5	.3	.1	.2	.5
81	.2	.5	.3	.1	.2	.5
82	.2	.5	.3	.1	.2	.5
83	.2	.5	.3	.1	.2	.5
84	.2	.5	.3	.1	.2	.5
85	.2	.5	.3	.1	.2	.5
86	.2	.5	.3	.1	.2	.5
87	.2	.5	.3	.1	.2	.5
88	.2	.5	.3	.1	.2	.5
89	.2	.5	.3	.1	.2	.5
90	.2	.5	.3	.1	.2	.5
91	.2	.5	.3	.1	.2	.5
92	.2	.5	.3	.1	.2	.5
93	.2	.5	.3	.1	.2	.5
94	.2	.5	.3	.1	.2	.5
95	.2	.5	.3	.1	.2	.5
96	.2	.5	.3	.1	.2	.5
97	.2	.5	.3	.1	.2	.5
98	.2	.5	.3	.1	.2	.5
99	.2	.5	.3	.1	.2	.5
100	.2	.5	.3	.1	.2	.5
101	.2	.5	.3	.1	.2	.5
102	.2	.5	.3	.1	.2	.5
103	.2	.5	.3	.1	.2	.5
104	.2	.5	.3	.1	.2	.5
105	.2	.5	.3	.1	.2	.5
106	.2	.5	.3	.1	.2	.5
107	.2	.5	.3	.1	.2	.5
108	.2	.5	.3	.1	.2	.5
109	.2	.5	.3	.1	.2	.5
110	.2	.5	.3	.1	.2	.5
111	.2	.5	.3	.1	.2	.5
112	.2	.5	.3	.1	.2	.5
113	.2	.5	.3	.1	.2	.5
114	.2	.5	.3	.1	.2	.5
115	.2	.5	.3	.1	.2	.5
116	.2	.5	.3	.1	.2	.5
117	.2	.5	.3	.1	.2	.5
118	.2	.5	.3	.1	.2	.5
119	.2	.5	.3	.1	.2	.5
120	.2	.5	.3	.1	.2	.5
121	.2	.5	.3	.1	.2	.5
122	.2	.5	.3	.1	.2	.5
123	.2	.5	.3	.1	.2	.5
124	.2	.5	.3	.1	.2	.5
125	.2	.5	.3	.1	.2	.5
126	.2	.5	.3	.1	.2	.5
127	.2	.5	.3	.1	.2	.5
128	.2	.5	.3	.1	.2	.5
129	.2	.5	.3	.1	.2	.5
130	.2	.5	.3	.1	.2	.5
131	.2	.5	.3	.1	.2	.5
132	.2	.5	.3	.1	.2	.5
133	.2	.5	.3	.1	.2	.5
134	.2	.5	.3	.1	.2	.5
135	.2	.5	.3	.1	.2	.5
136	.2	.5	.3	.1	.2	.5
137	.2	.5	.3	.1	.2	.5
138	.2	.5	.3	.1	.2	.5
139	.2	.5	.3	.1	.2	.5
140	.2	.5	.3	.1	.2	.5
141	.2	.5	.3	.1	.2	.5
142	.2	.5	.3	.1	.2	.5
143	.2	.5	.3	.1	.2	.5
144	.2	.5	.3	.1	.2	.5

BEST AVAILABLE COPY

TABLE A.2 Cont'd

	.4000+03	.7032+03
145		
146		
147	0.0	73.00
148	550.0	73.70
149		
150	21	
151		1.2
152		1.2
153		1.5
154		1.7
155		
156		
157		
158		
159		
160		
161		
162		
163		
164		
165		
166		
167		
168		
169		
170		
171		
172		
173		
174		
175		
176		
177		
178		
179		
180		
181		
182		
183		
184		
185		
186		
187		
188		
189		
190		
191		
192		
193		
194		
195		
196		
197		
198		
199		
200		
201		
202		
203		
204		
205		
206		
207		
208		
209		
210		
211		
212		
213		
214		
215		
216		
217		
218		
219		
220		
221		
222		
223		
224		
225		
226		
227		
228		
229		
230		
231		
232		
233		
234		
235		
236		
237		
238		
239		
240		
241		
242		
243		
244		
245		
246		
247		
248		
249		
250		
251		
252		
253		
254		
255		
256		
257		
258		
259		
260		
261		
262		
263		
264		
265		
266		
267		
268		
269		
270		
271		
272		
273		
274		
275		
276		
277		
278		
279		
280		
281		
282		
283		
284		
285		
286		
287		
288		
289		
290		
291		
292		
293		
294		
295		
296		
297		
298		
299		
300		
301		
302		
303		
304		
305		
306		
307		
308		
309		
310		
311		
312		
313		
314		
315		
316		
317		
318		
319		
320		
321		
322		
323		
324		
325		
326		
327		
328		
329		
330		
331		
332		
333		
334		
335		
336		
337		
338		
339		
340		
341		
342		
343		
344		
345		
346		
347		
348		
349		
350		
351		
352		
353		
354		
355		
356		
357		
358		
359		
360		
361		
362		
363		
364		
365		
366		
367		
368		
369		
370		
371		
372		
373		
374		
375		
376		
377		
378		
379		
380		
381		
382		
383		
384		
385		
386		
387		
388		
389		
390		
391		
392		
393		
394		
395		
396		
397		
398		
399		
400		
401		
402		
403		
404		
405		
406		
407		
408		
409		
410		
411		
412		
413		
414		
415		
416		
417		
418		
419		
420		
421		
422		
423		
424		
425		
426		
427		
428		
429		
430		
431		
432		
433		
434		
435		
436		
437		
438		
439		
440		
441		
442		
443		
444		
445		
446		
447		
448		
449		
450		
451		
452		
453		
454		
455		
456		
457		
458		
459		
460		
461		
462		
463		
464		
465		
466		
467		
468		
469		
470		
471		
472		
473		
474		
475		
476		
477		
478		
479		
480		
481		
482		
483		
484		
485		
486		
487		
488		
489		
490		
491		
492		
493		
494		
495		
496		
497		
498		
499		
500		
501		
502		
503		
504		
505		
506		
507		
508		
509		
510		
511		
512		
513		
514		
515		
516		
517		
518		
519		
520		
521		
522		
523		
524		
525		
526		
527		
528		
529		
530		
531		
532		
533		
534		
535		
536		
537		
538		
539		
540		
541		
542		
543		
544		
545		
546		
547		
548		
549		
550		
551		
552		
553		
554		
555		
556		
557		
558		
559		
560		
561		
562		
563		
564		
565		
566		
567		
568		
569		
570		
571		
572		
573		
574		
575		
576		
577		
578		
579		
580		
581		
582		
583		
584		
585		
586		
587		
588		
589		
590		
591		
592		
593		
594		
595		
596		
597		
598		
599		
600		
601		
602		
603		
604		
605		
606		
607		
608		
609		
610		
611		
612		
613		
614		
615		
616		
617		
618		
619		
620		
621		
622		
623		
624		
625		
626		
627		
628		
629		
630		
631		
632		
633		
634		
635		
636		
637		
638		
639		
640		
641		
642		
643		
644		
645		
646		
647		
648		
649		
650		
651		
652		
653		
654		
655		
656		
657		
658		
659		
660		
661		
662		
663		
664		
665		
666		
667		
668		
669		
670		
671		
672		
673		
674		
675		
676		
677		
678		
679		
680		
681		
682		
683		
684		
685		
686		
687		
688		
689		
690		
691		
692		
693		
694		
695		
696		
697		
698		
699	</	

TABLE A.2 Cont'd

217	8000.00	2.23	0.0337	0.2568
218	9000.00	2.23	0.0339	0.2622
219	11000.00	2.23	0.0341	0.2676
220	13000.00	2.23	0.0343	0.2727
221	15000.00	2.23	0.0345	0.2777
222	17000.00	2.23	0.0347	0.2815
223	19000.00	2.23	0.0349	0.2860
224	21000.00	2.23	0.0351	0.2903
225	23000.00	2.23	0.0353	0.2943
226	25000.00	2.23	0.0355	0.2980
227	27000.00	2.23	0.0357	0.3015
228	29000.00	2.23	0.0359	0.3048
229	31000.00	2.23	0.0361	0.3079
230	33000.00	2.23	0.0363	0.3108
231	35000.00	2.23	0.0365	0.3136
232	37000.00	2.23	0.0367	0.3162
233	39000.00	2.23	0.0369	0.3187
234	41000.00	2.23	0.0371	0.3211
235	43000.00	2.23	0.0373	0.3234
236	45000.00	2.23	0.0375	0.3256
237	47000.00	2.23	0.0377	0.3277
238	49000.00	2.23	0.0379	0.3297
239	51000.00	2.23	0.0381	0.3316
240	53000.00	2.23	0.0383	0.3334
241	55000.00	2.23	0.0385	0.3351
242	57000.00	2.23	0.0387	0.3367
243	59000.00	2.23	0.0389	0.3382
244	61000.00	2.23	0.0391	0.3396
245	63000.00	2.23	0.0393	0.3409
246	65000.00	2.23	0.0395	0.3421
247	67000.00	2.23	0.0397	0.3433
248	69000.00	2.23	0.0399	0.3444
249	71000.00	2.23	0.0401	0.3455
250	73000.00	2.23	0.0403	0.3465
251	75000.00	2.23	0.0405	0.3475
252	77000.00	2.23	0.0407	0.3484
253	79000.00	2.23	0.0409	0.3493
254	81000.00	2.23	0.0411	0.3502
255	83000.00	2.23	0.0413	0.3510
256	85000.00	2.23	0.0415	0.3518
257	87000.00	2.23	0.0417	0.3526
258	89000.00	2.23	0.0419	0.3533
259	91000.00	2.23	0.0421	0.3540
260	93000.00	2.23	0.0423	0.3547
261	95000.00	2.23	0.0425	0.3553
262	97000.00	2.23	0.0427	0.3559
263	99000.00	2.23	0.0429	0.3565
264	100000.00	2.23	0.0431	0.3570

BEST AVAILABLE COPY

TABLE A.3 CONVERGENCE INFORMATION FOR HEAT EXCHANGER PERFORMANCE STUDY

PROGRAM CONVERGED AFTER 19 ITERATIONS

SIDE PATH	ERROR-DEG F
A	1.450
A	2.553
A	-4.571
A	2.486
A	.661
B	-2.499

TABLE A.4 RESULTS OF HEAT EXCHANGER PERFORMANCE STUDY

A. FLOW CONDITIONS FOR MARINE WASTE-HEAT BOILER DESIGN STUDY (UNIFORM FLOW, 50% POWER)									
SIDE PATH	START	END	FLOW LB/SEC	T-IN DEG F	T-OUT DEG F	P-IN PSIA	P-OUT PSIA	Q BTU/SEC	
A	1	1	20.00	796.00	343.94	14.83	14.23	2521.54	
A	2	2	20.00	796.00	345.38	14.83	14.23	2514.04	
A	3	3	20.00	796.00	343.35	14.83	14.23	2525.39	
A	4	4	20.00	796.00	345.57	14.83	14.23	2514.85	
B	5	5	20.00	793.00	345.77	14.83	14.23	2514.48	
	1	1	9.75	115.70	704.00	300.00	286.84	12590.30	

B. THE CORE SIZE OF THIS HEAT EXCHANGER IS APPROXIMATELY = 5.83 FT. BY 10.00 FT. BY 7.00 FT.

TABLE A.3 TEMPERATURE DISTRIBUTION FOR HEAT EXCHANGER CORE

RESULTS OF MARINE WASTE-HEAT BOILER DESIGN STUDY (UNIFORM FLOW, 50% POWER)										
I	J	TA-IN DEG F	TA-OUT DEG F	TA-MEAN DEG F	TWALL-A DEG F	TWALL-B DEG F	TCOKE DEG F	TB-IN DEG F	TB-OUT DEG F	TB-MEAN DEG F
1	1	796.000	784.873	790.437	744.015	738.603	738.603	671.604	704.002	697.803
1	2	796.000	793.377	789.688	737.023	730.884	730.884	677.586	691.604	684.595
1	3	796.000	779.686	788.843	729.123	722.103	722.103	661.753	677.586	669.670
1	4	796.000	777.774	787.887	720.192	712.103	712.103	643.904	661.753	652.829
1	5	796.000	777.611	786.806	710.087	701.148	701.148	623.847	643.904	633.876
2	1	784.873	753.217	769.045	637.013	621.673	621.673	496.248	527.194	511.721
2	2	784.873	755.529	769.453	653.306	639.811	639.811	527.194	555.436	541.315
2	3	784.873	755.253	769.470	667.587	655.727	655.727	555.436	580.954	568.195
2	4	784.873	758.367	769.070	679.787	669.414	669.414	580.954	603.701	592.377
2	5	784.873	758.926	768.268	690.339	681.286	681.286	603.701	623.847	613.774
3	1	777.611	721.116	737.167	603.345	587.880	587.880	496.248	466.670	481.459
3	2	777.611	718.932	737.230	584.663	567.031	567.031	435.192	466.670	450.931
3	3	777.611	697.887	727.685	480.076	451.523	451.523	417.400	435.192	426.296
3	4	777.611	697.695	727.810	471.344	441.771	441.771	417.400	417.400	417.400
3	5	777.611	696.695	727.810	467.840	437.848	437.848	417.400	417.400	417.400
4	1	771.932	662.621	692.777	456.088	429.186	429.186	417.400	417.400	417.400
4	2	771.932	645.691	671.789	454.222	429.372	429.372	417.400	417.400	417.400
4	3	771.932	645.256	671.130	455.411	432.778	432.778	417.400	417.400	417.400
4	4	771.932	645.248	670.972	456.500	432.011	432.011	417.400	417.400	417.400
4	5	771.932	648.559	641.191	448.303	426.400	426.400	417.400	417.400	417.400
5	1	662.621	616.700	639.661	448.049	426.296	426.296	417.400	417.400	417.400
5	2	645.691	603.378	624.517	446.422	426.264	426.264	417.400	417.400	417.400
5	3	645.248	603.152	624.204	446.912	426.849	426.849	417.400	417.400	417.400
5	4	645.248	603.175	624.211	447.049	427.002	427.002	417.400	417.400	417.400
5	5	645.248	603.372	624.211	447.049	427.002	427.002	417.400	417.400	417.400
6	1	616.700	580.558	598.628	443.646	425.065	425.065	417.400	417.400	417.400
6	2	616.700	580.504	586.641	441.512	425.246	425.246	417.400	417.400	417.400
6	3	616.700	580.362	586.267	441.771	425.557	425.557	417.400	417.400	417.400
6	4	616.700	580.390	586.263	441.720	425.498	425.498	417.400	417.400	417.400
6	5	616.700	580.390	586.263	441.720	425.498	425.498	417.400	417.400	417.400
7	1	580.390	551.696	566.543	438.882	424.610	424.610	417.400	417.400	417.400
7	2	580.390	551.696	566.543	438.882	424.610	424.610	417.400	417.400	417.400
7	3	580.390	551.696	566.543	438.882	424.610	424.610	417.400	417.400	417.400
7	4	580.390	551.696	566.543	438.882	424.610	424.610	417.400	417.400	417.400
7	5	580.390	551.696	566.543	438.882	424.610	424.610	417.400	417.400	417.400
8	1	541.696	527.568	539.633	436.387	424.910	424.910	417.400	417.400	417.400
8	2	541.696	527.568	539.633	436.387	424.910	424.910	417.400	417.400	417.400
8	3	541.696	527.568	539.633	436.387	424.910	424.910	417.400	417.400	417.400
8	4	541.696	527.568	539.633	436.387	424.910	424.910	417.400	417.400	417.400
8	5	541.696	527.568	539.633	436.387	424.910	424.910	417.400	417.400	417.400
9	1	527.568	519.577	523.572	434.856	424.231	424.231	417.400	417.400	417.400
9	2	527.568	519.577	523.572	434.856	424.231	424.231	417.400	417.400	417.400
9	3	527.568	519.577	523.572	434.856	424.231	424.231	417.400	417.400	417.400
9	4	527.568	519.577	523.572	434.856	424.231	424.231	417.400	417.400	417.400
9	5	527.568	519.577	523.572	434.856	424.231	424.231	417.400	417.400	417.400
10	1	501.407	486.703	494.090	430.804	423.712	423.712	417.400	417.400	417.400
10	2	501.407	486.703	494.090	430.804	423.712	423.712	417.400	417.400	417.400
10	3	501.407	486.703	494.090	430.804	423.712	423.712	417.400	417.400	417.400
10	4	501.407	486.703	494.090	430.804	423.712	423.712	417.400	417.400	417.400
10	5	501.407	486.703	494.090	430.804	423.712	423.712	417.400	417.400	417.400

TABLE A.5 Cont'd

RESULTS OF MARINE WASTE-HEAT BOILER DESIGN STUDY (UNIFORM FLOW, 50% POWER)											
I	J	TA-IN DEG F	TA-OUT DEG F	TA-MEAN DEG F	TWALL-A DEG F	TWALL-B DEG F	TCOME DEG F	TB-IN DEG F	TB-OUT DEG F	TB-MEAN DEG F	
1	1	955	941	948	929	929	588	400	417	400	1
1	2	955	940	948	928	928	586	400	417	400	2
1	3	955	939	947	927	927	586	400	417	400	3
1	4	955	938	946	926	926	586	400	417	400	4
1	5	955	937	945	925	925	586	400	417	400	5
1	6	955	936	944	924	924	586	400	417	400	6
1	7	955	935	943	923	923	586	400	417	400	7
1	8	955	934	942	922	922	586	400	417	400	8
1	9	955	933	941	921	921	586	400	417	400	9
1	10	955	932	940	920	920	586	400	417	400	10
1	11	955	931	939	919	919	586	400	417	400	11
1	12	955	930	938	918	918	586	400	417	400	12
1	13	955	929	937	917	917	586	400	417	400	13
1	14	955	928	936	916	916	586	400	417	400	14
1	15	955	927	935	915	915	586	400	417	400	15
1	16	955	926	934	914	914	586	400	417	400	16
1	17	955	925	933	913	913	586	400	417	400	17
1	18	955	924	932	912	912	586	400	417	400	18
1	19	955	923	931	911	911	586	400	417	400	19
1	20	955	922	930	910	910	586	400	417	400	20
1	21	955	921	929	909	909	586	400	417	400	21
1	22	955	920	928	908	908	586	400	417	400	22
1	23	955	919	927	907	907	586	400	417	400	23
1	24	955	918	926	906	906	586	400	417	400	24
1	25	955	917	925	905	905	586	400	417	400	25
1	26	955	916	924	904	904	586	400	417	400	26
1	27	955	915	923	903	903	586	400	417	400	27
1	28	955	914	922	902	902	586	400	417	400	28
1	29	955	913	921	901	901	586	400	417	400	29
1	30	955	912	920	900	900	586	400	417	400	30
1	31	955	911	919	899	899	586	400	417	400	31
1	32	955	910	918	898	898	586	400	417	400	32
1	33	955	909	917	897	897	586	400	417	400	33
1	34	955	908	916	896	896	586	400	417	400	34
1	35	955	907	915	895	895	586	400	417	400	35
1	36	955	906	914	894	894	586	400	417	400	36
1	37	955	905	913	893	893	586	400	417	400	37
1	38	955	904	912	892	892	586	400	417	400	38
1	39	955	903	911	891	891	586	400	417	400	39
1	40	955	902	910	890	890	586	400	417	400	40
1	41	955	901	909	889	889	586	400	417	400	41
1	42	955	900	908	888	888	586	400	417	400	42
1	43	955	899	907	887	887	586	400	417	400	43
1	44	955	898	906	886	886	586	400	417	400	44
1	45	955	897	905	885	885	586	400	417	400	45
1	46	955	896	904	884	884	586	400	417	400	46
1	47	955	895	903	883	883	586	400	417	400	47
1	48	955	894	902	882	882	586	400	417	400	48
1	49	955	893	901	881	881	586	400	417	400	49
1	50	955	892	900	880	880	586	400	417	400	50

TABLE A.6 DISTRIBUTIONS OF HEAT TRANSFER COEFFICIENTS FOR HEAT EXCHANGER CORE

RESULTS OF MARINE WASTE-HEAT BOILER DESIGN STUDY (UNIFORM FLOW, 50% POWER)												
I	J	BTU/HR-SQFT-F	H-A	ETA-F	ETA-N	REN NO.-A	BTU/HR-SQFT-F	H-B	REN NO.-B	BTU/HR-F	J-A	QDOT BTU/SEC
1	1	123	123	509089	590089	30080	19417	1775	6975	5206	44	64
1	1	123	123	509119	590119	30091	19414	1775	6975	5206	44	64
1	1	123	123	509151	590151	30104	19409	1775	6975	5206	44	64
1	1	123	123	509184	590184	30116	19416	1775	6975	5206	44	64
1	1	123	123	509211	590211	30136	19450	1775	6975	5206	44	64
1	1	123	123	509239	590239	30142	19450	1775	6975	5206	44	64
1	1	123	123	509263	590263	30146	19450	1775	6975	5206	44	64
1	1	123	123	509289	590289	30150	19450	1775	6975	5206	44	64
1	1	123	123	509313	590313	30150	19450	1775	6975	5206	44	64
1	1	123	123	509333	590333	30150	19450	1775	6975	5206	44	64
1	1	123	123	509350	590350	30150	19450	1775	6975	5206	44	64
1	1	123	123	509369	590369	30150	19450	1775	6975	5206	44	64
1	1	123	123	509389	590389	30150	19450	1775	6975	5206	44	64
1	1	123	123	509409	590409	30150	19450	1775	6975	5206	44	64
1	1	123	123	509429	590429	30150	19450	1775	6975	5206	44	64
1	1	123	123	509449	590449	30150	19450	1775	6975	5206	44	64
1	1	123	123	509468	590468	30150	19450	1775	6975	5206	44	64
1	1	123	123	509488	590488	30150	19450	1775	6975	5206	44	64
1	1	123	123	509508	590508	30150	19450	1775	6975	5206	44	64
1	1	123	123	509528	590528	30150	19450	1775	6975	5206	44	64
1	1	123	123	509548	590548	30150	19450	1775	6975	5206	44	64
1	1	123	123	509568	590568	30150	19450	1775	6975	5206	44	64
1	1	123	123	509588	590588	30150	19450	1775	6975	5206	44	64
1	1	123	123	509608	590608	30150	19450	1775	6975	5206	44	64
1	1	123	123	509628	590628	30150	19450	1775	6975	5206	44	64
1	1	123	123	509648	590648	30150	19450	1775	6975	5206	44	64
1	1	123	123	509668	590668	30150	19450	1775	6975	5206	44	64
1	1	123	123	509688	590688	30150	19450	1775	6975	5206	44	64
1	1	123	123	509708	590708	30150	19450	1775	6975	5206	44	64
1	1	123	123	509728	590728	30150	19450	1775	6975	5206	44	64
1	1	123	123	509748	590748	30150	19450	1775	6975	5206	44	64
1	1	123	123	509768	590768	30150	19450	1775	6975	5206	44	64
1	1	123	123	509788	590788	30150	19450	1775	6975	5206	44	64
1	1	123	123	509808	590808	30150	19450	1775	6975	5206	44	64
1	1	123	123	509828	590828	30150	19450	1775	6975	5206	44	64
1	1	123	123	509848	590848	30150	19450	1775	6975	5206	44	64
1	1	123	123	509868	590868	30150	19450	1775	6975	5206	44	64
1	1	123	123	509888	590888	30150	19450	1775	6975	5206	44	64
1	1	123	123	509908	590908	30150	19450	1775	6975	5206	44	64
1	1	123	123	509928	590928	30150	19450	1775	6975	5206	44	64
1	1	123	123	509948	590948	30150	19450	1775	6975	5206	44	64
1	1	123	123	509968	590968	30150	19450	1775	6975	5206	44	64
1	1	123	123	509988	590988	30150	19450	1775	6975	5206	44	64
1	1	123	123	510008	591008	30150	19450	1775	6975	5206	44	64
1	1	123	123	510028	591028	30150	19450	1775	6975	5206	44	64
1	1	123	123	510048	591048	30150	19450	1775	6975	5206	44	64
1	1	123	123	510068	591068	30150	19450	1775	6975	5206	44	64
1	1	123	123	510088	591088	30150	19450	1775	6975	5206	44	64
1	1	123	123	510108	591108	30150	19450	1775	6975	5206	44	64
1	1	123	123	510128	591128	30150	19450	1775	6975	5206	44	64
1	1	123	123	510148	591148	30150	19450	1775	6975	5206	44	64
1	1	123	123	510168	591168	30150	19450	1775	6975	5206	44	64
1	1	123	123	510188	591188	30150	19450	1775	6975	5206	44	64
1	1	123	123	510208	591208	30150	19450	1775	6975	5206	44	64
1	1	123	123	510228	591228	30150	19450	1775	6975	5206	44	64
1	1	123	123	510248	591248	30150	19450	1775	6975	5206	44	64
1	1	123	123	510268	591268	30150	19450	1775	6975	5206	44	64
1	1	123	123	510288	591288	30150	19450	1775	6975	5206	44	64
1	1	123	123	510308	591308	30150	19450	1775	6975	5206	44	64
1	1	123	123	510328	591328	30150	19450	1775	6975	5206	44	64
1	1	123	123	510348	591348	30150	19450	1775	6975	5206	44	64
1	1	123	123	510368	591368	30150	19450	1775	6975	5206	44	64
1	1	123	123	510388	591388	30150	19450	1775	6975	5206	44	64
1	1	123	123	510408	591408	30150	19450	1775	6975	5206	44	64
1	1	123	123	510428	591428	30150	19450	1775	6975	5206	44	64
1	1	123	123	510448	591448	30150	19450	1775	6975	5206	44	64
1	1	123	123	510468	591468	30150	19450	1775	6975	5206	44	64
1	1	123	123	510488	591488	30150	19450	1775	6975	5206	44	64
1	1	123	123	510508	591508	30150	19450	1775	6975	5206	44	64
1	1	123	123	510528	591528	30150	19450	1775	6975	5206	44	64
1	1	123	123	510548	591548	30150	19450	1775	6975	5206	44	64
1	1	123	123	510568	591568	30150	19450	1775	6975	5206	44	64
1	1	123	123	510588	591588	30150	19450	1775	6975	5206	44	64
1	1	123	123	510608	591608	30150	19450	1775	6975	5206	44	64
1	1	123	123	510628	591628	30150	19450	1775	6975	5206	44	64
1	1	123	123	510648	591648	30150	19450	1775	6975	5206	44	64
1	1	123	123	510668	591668	30150	19450	1775	6975	5206	44	64
1	1	123	123	510688	591688	30150	19450	1775	6975	5206	44	64
1	1	123	123	510708	591708	30150	19450	1775	6975	5206	44	64
1	1	123	123	510728	591728	30150	19450	1775	6975	5206	44	64
1	1	123	123	510748	591748	30150	19450	1775	6975	5206	44	64
1	1	123	123	510768	591768	30150	19450	1775	6975	5206	44	64
1	1	123	123	510788	591788	30150	19450	1775	6975	5206	44	64
1	1	123	123	510808	591808	30150	19450	1775	6975	5206	44	64
1	1	123	123	510828	591828	30150	19450	1775	6975	5206	44	64
1	1	123	123	510848	591848	30150	19450	1775	6975	5206	44	64
1	1	123	123	510868	591868	30150	19450	1775	6975	5206	44	64
1	1	123	123	510888	591888	30150	19450	1775	6975	5206	44	64
1	1	123	123	510908	591908	30150	19450	1775	6975	5206	44	64
1	1	123	123	510928	591928	30150	19450	1775	6975	5206	44	64
1	1	123	123	510948	591948	30150	19450	1775	6975	5206	44	64
1	1	123	123	510968	591968	30150	19450	1775	6975	5206	44	64
1	1	123	123	510988	591988	30150	19450	1775	6975	5206	44	64
1	1	123	123	511008	592008	30150	19450	1775	6975	5206	44	64
1	1	123	123	511028	592028	30150	19450	1775	6975	5206	44	64
1	1	123	123	511048	592048	30150	19450	1775	6975	5206	44	64
1	1	123	123	511068	592068	30150	19450	1775	6975	5206	44	64
1	1	123	123	511088	592088	30150	19450	1775	6975	5206	44	64
1	1	123	123	511108	592108	30150	19450	1775	6975	5206	44	64
1	1	123	123	511128	592128	30150	19450	1775	6975	5206	44	64
1	1	123	123	511148	592148	30150	19450	1775	6975	5206	44	64
1	1	123	123	511168	592168	30150	19450	1775	6975	5206	44	64
1	1	123	123	511188	592188	30150	19450	1775	6975	5206	44	64
1	1	123	123	511208	592208	30150	19450	1775	6975	5206	44	64
1	1	123	123	511228	592228	30150	19450	1775	6975	5206	44	64
1	1	123	123	511248	592248	30150	19450	1775	6975	5206	44	64
1	1	123	123	511268								

102

TABLE A.7 PRESSURE DROP CHARACTERISTICS AND STEAM QUALITY

B-SIDE PRESSURE DROP/QUALITY AND OTHER DETAILS FOR MARINE WASTE-HEAT BOILER DESIGN STUDY									
I	J	DELTA-P-FP PSIA	DELTA-P-MOM PSIA	DELTA-P-TOT PSIA	QUALITY PERCENT	BTU/HR-SOFT-F	BIGX BTU/HR-SOFT-F	MB-CONV BTU/HR-SOFT-F	MB-GURGLING
20	1	.00409	.00000	.00409	.00000	.00000	.00000	.18867+03	.00000
20	2	.00403	.00000	.00403	.00000	.00000	.00000	.19641+03	.00000
20	3	.00398	.00000	.00398	.00000	.00000	.00000	.21386+03	.00000
20	4	.00392	.00000	.00392	.00000	.00000	.00000	.22717+03	.00000
20	5	.00386	.00000	.00386	.00000	.00000	.00000	.23876+03	.00000
19	4	.00383	.00000	.00383	.00000	.00000	.00000	.25137+03	.00000
19	3	.00381	.00000	.00381	.00000	.00000	.00000	.26658+03	.00000
19	2	.00379	.00000	.00379	.00000	.00000	.00000	.27651+03	.00000
19	1	.00377	.00000	.00377	.00000	.00000	.00000	.28693+03	.00000
18	4	.00379	.00000	.00379	.00000	.00000	.00000	.29754+03	.00000
18	3	.00377	.00000	.00377	.00000	.00000	.00000	.30846+03	.00000
18	2	.00379	.00000	.00379	.00000	.00000	.00000	.31664+03	.00000
18	1	.00379	.00000	.00379	.00000	.00000	.00000	.32471+03	.00000
17	4	.00379	.00000	.00379	.00000	.00000	.00000	.33279+03	.00000
17	3	.00379	.00000	.00379	.00000	.00000	.00000	.34067+03	.00000
17	2	.00380	.00000	.00380	.00000	.00000	.00000	.34826+03	.00000
17	1	.00380	.00000	.00380	.00000	.00000	.00000	.35416+03	.00000
17	4	.00383	.00000	.00383	.00000	.00000	.00000	.35919+03	.00000
17	3	.00384	.00000	.00384	.00000	.00000	.00000	.36529+03	.00000
17	2	.00385	.00000	.00385	.00000	.00000	.00000	.37059+03	.00000
17	1	.00385	.00000	.00385	.00000	.00000	.00000	.37569+03	.00000
16	4	.00386	.00000	.00386	.00000	.00000	.00000	.38145+03	.00000
16	3	.00388	.00000	.00388	.00000	.00000	.00000	.38545+03	.00000
16	2	.00388	.00000	.00388	.00000	.00000	.00000	.38844+03	.00000
16	1	.00389	.00000	.00389	.00000	.00000	.00000	.39222+03	.00000
15	4	.00390	.00000	.00390	.00000	.00000	.00000	.39537+03	.00000
15	3	.00391	.00000	.00391	.00000	.00000	.00000	.39845+03	.00000
15	2	.00392	.00000	.00392	.00000	.00000	.00000	.40206+03	.00000
15	1	.00393	.00000	.00393	.00000	.00000	.00000	.40511+03	.00000
14	4	.00394	.00000	.00394	.00000	.00000	.00000	.40806+03	.00000
14	3	.00395	.00000	.00395	.00000	.00000	.00000	.41108+03	.00000
14	2	.00396	.00000	.00396	.00000	.00000	.00000	.41356+03	.00000
14	1	.00397	.00000	.00397	.00000	.00000	.00000	.41582+03	.00000
13	4	.00748	.00923	.01672	.39049	.63175	.41974+03	.41974+03	.00000
13	3	.01582	.00101	.01375	.93199	16.46162	.42157+03	.42157+03	.00000
13	2	.01862	.00103	.01685	1.48019	5.61764	.56677+03	.56677+03	.00000
13	1	.02516	.00116	.02291	2.06557	4.32712	.63832+03	.63832+03	.00000
12	4	.02846	.00146	.02667	3.38749	3.67614	.70321+03	.70321+03	.00000
12	3	.03148	.00139	.02992	4.11055	2.24458	.82540+03	.82540+03	.00000
12	2	.03447	.00143	.03287	4.78527	1.95297	.88872+03	.88872+03	.00000
12	1	.03745	.00146	.03590	5.46564	1.54811	.95662+03	.95662+03	.00000
11	4	.04104	.00180	.04284	6.96673	1.37399	.10424+04	.10424+04	.00000
11	3	.04460	.00183	.04643	7.82338	1.12086	.11363+04	.11363+04	.00000
11	2	.05190	.00204	.04997	8.65402	1.01856	.11735+04	.11735+04	.00000
11	1	.05501	.00203	.05394	9.56404	1.09317	.12758+04	.12758+04	.00000
11	4	.05501	.00003	.05504	10.48118	.93178	.13857+04	.13857+04	.00000
11	3	.05501	.00000	.05504	10.48118	.93178	.13857+04	.13857+04	.00000
11	2	.05501	.00000	.05504	10.48118	.93178	.13857+04	.13857+04	.00000
11	1	.05501	.00000	.05504	10.48118	.93178	.13857+04	.13857+04	.00000

TABLE A.7 Cont'd

B-SIDE PRESSURE DROP/QUALITY AND OTHER DETAILS FOR MARINE WASTE-HEAT BOILER DESIGN STUDY									
I	J	DELTA-P-FF PSIA	DELTA-P-MOM PSIA	DELTA-P-TOT PSIA	QUALITY PERCENT	BIGX BTU/HR-SQFT-F	HB-CONV BTU/HR-SQFT-F	HB-GURGLING	
100	1	06035	00004	06039	11.60387	84304	14525+04	16706+03	
100	1	06559	00006	06564	12.72076	76930	15156+04	15330+03	
100	1	07039	00006	07045	13.76059	71069	15779+04	12978+03	
100	1	07513	00008	07520	14.80388	65961	16355+04	14064+03	
100	1	07979	00009	07988	15.84997	61467	16930+04	13745+03	
100	1	08559	00013	08572	17.13066	56662	17503+04	16004+03	
100	1	09173	00016	09189	18.41372	52470	18202+04	14887+03	
100	1	09785	00024	09803	19.70034	48776	18898+04	12534+03	
100	1	10435	00029	10459	21.08820	45260	19672+04	12948+03	
100	1	11068	00043	11113	22.48961	42117	20576+04	14378+03	
100	1	11699	00051	11750	24.21195	38714	21485+04	14344+03	
100	1	12331	00055	12386	25.92263	35742	22300+04	12638+03	
100	1	13063	00064	13127	27.52789	33281	23707+04	10505+03	
100	1	13795	00074	13869	29.11761	31069	24548+04	10792+03	
100	1	14527	00081	14608	30.71461	29066	25391+04	10435+03	
100	1	15259	00106	15340	32.67558	26851	26334+04	12640+03	
100	1	16091	00124	16182	34.63925	24862	27301+04	11976+03	
100	1	16923	00145	17018	36.61208	23059	28133+04	10532+03	
100	1	17755	00181	17853	38.83889	21301	29212+04	10144+03	
100	1	18587	00217	18691	40.88355	19696	30303+04	12254+03	
100	1	19419	00307	19533	43.52544	17915	31642+04	11027+03	
100	1	20251	00359	20377	46.35826	16398	32429+04	9567+02	
100	1	21083	00439	21220	48.39480	14982	33422+04	9074+01	
100	1	21915	00500	22058	51.07244	13757	34743+04	10841+03	
100	1	22747	00570	22899	53.47242	12629	35371+04	10204+03	
100	1	23579	00644	23739	56.46492	11353	36074+04	10755+03	
100	1	24411	00716	24579	59.08912	10057	36771+04	13911+03	
100	1	25243	00787	25419	61.67779	87057	37471+04	13156+03	
100	1	26075	00855	26259	64.21031	74904	38161+04	12127+03	
100	1	26907	00928	27098	67.21440	62023	38811+04	11087+03	
100	1	27739	01000	27940	69.94592	50023	39530+04	99517+02	
100	1	28571	01073	28786	72.83269	38203	40241+04	86776+02	
100	1	29403	01145	29630	75.27657	26517	40992+04	67993+02	
100	1	30235	01217	30473	77.00000	15000	41912+02	41912+02	
100	1	31067	01289	31318	79.00000	10000	42833+02	00000	
100	1	31900	01361	32169	81.00000	10000	43754+02	00000	
100	1	32732	01433	33029	83.00000	10000	44675+02	00000	
100	1	33564	01505	33892	85.00000	10000	45596+02	00000	
100	1	34396	01577	34779	87.00000	10000	46517+02	00000	
100	1	35228	01649	35629	89.00000	10000	47438+02	00000	
100	1	36060	01721	36959	91.00000	10000	48359+02	00000	
100	1	36892	01793	37799	93.00000	10000	49280+02	00000	
100	1	37724	01865	38658	95.00000	10000	50199+02	00000	
100	1	38556	01937	39533	97.00000	10000	51118+02	00000	
100	1	39388	02009	40418	99.00000	10000	52037+02	00000	
100	1	40220	02081	41313	100.00000	10000	52956+02	00000	
100	1	41052	02153	42218	100.00000	10000	53875+02	00000	
100	1	41884	02225	43133	100.00000	10000	54794+02	00000	
100	1	42716	02297	44048	100.00000	10000	55713+02	00000	
100	1	43548	02369	44963	100.00000	10000	56632+02	00000	
100	1	44380	02441	45878	100.00000	10000	57551+02	00000	
100	1	45212	02513	46793	100.00000	10000	58470+02	00000	
100	1	46044	02585	47708	100.00000	10000	59389+02	00000	
100	1	46876	02657	48623	100.00000	10000	60308+02	00000	
100	1	47708	02729	49538	100.00000	10000	61227+02	00000	
100	1	48540	02801	50453	100.00000	10000	62146+02	00000	
100	1	49372	02873	51368	100.00000	10000	63065+02	00000	
100	1	50204	02945	52283	100.00000	10000	63984+02	00000	
100	1	51036	03017	53198	100.00000	10000	64903+02	00000	
100	1	51868	03089	54113	100.00000	10000	65822+02	00000	
100	1	52700	03161	55028	100.00000	10000	66741+02	00000	
100	1	53532	03233	55943	100.00000	10000	67660+02	00000	
100	1	54364	03305	56858	100.00000	10000	68579+02	00000	
100	1	55196	03377	57773	100.00000	10000	69498+02	00000	
100	1	56028	03449	58688	100.00000	10000	70417+02	00000	
100	1	56860	03521	59603	100.00000	10000	71336+02	00000	
100	1	57692	03593	60518	100.00000	10000	72255+02	00000	
100	1	58524	03665	61433	100.00000	10000	73174+02	00000	
100	1	59356	03737	62348	100.00000	10000	74093+02	00000	
100	1	60188	03809	63263	100.00000	10000	75012+02	00000	
100	1	61020	03881	64178	100.00000	10000	75931+02	00000	
100	1	61852	03953	65093	100.00000	10000	76850+02	00000	
100	1	62684	04025	66008	100.00000	10000	77769+02	00000	
100	1	63516	04097	66923	100.00000	10000	78688+02	00000	
100	1	64348	04169	67838	100.00000	10000	79607+02	00000	
100	1	65180	04241	68753	100.00000	10000	80526+02	00000	
100	1	66012	04313	69668	100.00000	10000	81445+02	00000	
100	1	66844	04385	70583	100.00000	10000	82364+02	00000	
100	1	67676	04457	71498	100.00000	10000	83283+02	00000	
100	1	68508	04529	72413	100.00000	10000	84202+02	00000	
100	1	69340	04601	73328	100.00000	10000	85121+02	00000	
100	1	70172	04673	74243	100.00000	10000	86040+02	00000	
100	1	71004	04745	75158	100.00000	10000	86959+02	00000	
100	1	71836	04817	76073	100.00000	10000	87878+02	00000	
100	1	72668	04889	76988	100.00000	10000	88797+02	00000	
100	1	73500	04961	77903	100.00000	10000	89716+02	00000	
100	1	74332	05033	78818	100.00000	10000	90635+02	00000	
100	1	75164	05105	79733	100.00000	10000	91554+02	00000	
100	1	75996	05177	80648	100.00000	10000	92473+02	00000	
100	1	76828	05249	81563	100.00000	10000	93392+02	00000	
100	1	77660	05321	82478	100.00000	10000	94311+02	00000	
100	1	78492	05393	83393	100.00000	10000	95230+02	00000	
100	1	79324	05465	84308	100.00000	10000	96149+02	00000	
100	1	80156	05537	85223	100.00000	10000	97068+02	00000	
100	1	80988	05609	86138	100.00000	10000	97987+02	00000	
100	1	81820	05681	87053	100.00000	10000	98906+02	00000	
100	1	82652	05753	87968	100.00000	10000	99825+02	00000	
100	1	83484	05825	88883	100.00000	10000	100744+02	00000	
100	1	84316	05897	89798	100.00000	10000	101663+02	00000	
100	1	85148	05969	90713	100.00000	10000	102582+02	00000	
100	1	85980	06041	91628	100.00000	10000	103501+02	00000	
100	1	86812	06113	92543	100.00000	10000	104420+02	00000	
100	1	87644	06185	93458	100.00000	10000	105339+02	00000	
100	1	88476	06257	94373	100.00000	10000	106258+02	00000	
100	1	89308	06329	95288	100.00000	10000	107177+02	00000	
100	1	90140	06401	96203	100.00000	10000	108096+02	00000	
100	1	90972	06473	97118	100.00000	10000	109015+02	00000	
100	1	91804	06545	98033	100.00000	10000	109934+02	00000	
100	1	92636	06617	98948	100.00000	10000	110853+02	00000	
100	1	93468	06689	99863	100.00000	10000	111772+02	00000	
100	1	94300	06761	100778	100.00000	10000	112691+02	00000	
100	1	95132	06833	101693	100.00000	10000	113610+02	00000	
100	1	95964	06905	102608	100.00000	10000	114529+02	00000	
100	1	96796	06977	103523	100.00000	10000	115448+02	00000	
100	1	97628	07049	104438	100.00000	10000	116367+02	00000	
100	1	98460	07121	105353	100.00000	10000	117286+02	00000	
100	1	99292	07193	106268	100.00000	10000	118205+02	00000	
100	1	100124	07265	107183	100.00000	10000	119124+02	00000	
100	1	100956	07337	108098	100.00000	10000	120043+02	00000	
100	1	101788	07409	109013					

TABLE A.8 LISTS OF HEAT EXCHANGER MAIN PROGRAM

```

      INCLUDE PFOCO, LIST
      DIMENSION TBAR(2,MAXY,MAXX)
C-----SET DATA
C
      DATA LCTTA/29244/
      DATA NCKSTR,NCKSAV/10,C/
      DATA NSTORE/9/
      ISDYN=1
      CALL INPUT($100,$200)
100 CONTINUE
      NUMREC = 2* NI * NJ
      NUMWRD = 10
      NSAVE = 8
      CALL ERTNAN(6,'@ASG,T 5 : : ')
      CALL ERTNAN(6,'@ASG,T 9 : : ')
C
      DEFINE FILE NSAVE (NUMREC,NUMWRD,U,LREC )
      CALL CALC(LCTTA)
1000 CONTINUE
      DO 1100 I=1,NI
      DO 1100 J=1,NJ
      TBAR(1,I,J)=0.5*(TWALL(1,I,J)+TWALL(2,I,J))
1100 CONTINUE
      IF (ISDYN.EJ.1) GO TO 1050
      WRITE(KW,650) QNET,SUMCP,DTAU,TAU
650 FORMAT(//10X,'FROM DYNAMIC RESPONSE MODEL...'/
X/10X,'Q-NET' =',E12.5,1X,'BTU/SEC',
X/10X,'SUM(M*CP*DT)' =',E12.5,1X,'BTU',
X/10X,'DELTA TAU' =',E12.5,1X,'SECONDS',
X/10X,'TAU' =',E12.5,1X,'SECONDS',
X//)
1050 CONTINUE
      ISDYN=ISDYN+1
      CALL INPUT($300,$400)
300 CONTINUE
      CALL CALC(LCTTA)
      DO 1200 I=1,NI
      DO 1200 J=1,NJ
      TBAR(2,I,J)=0.5*(TWALL(1,I,J)+TWALL(2,I,J))
1200 CONTINUE
C-----MASS PER NODE
      DMASSEL=ELMASS/(NI*NJ)
      SUMCPC=C
      DO 1300 I=1,NI
      DO 1300 J=1,NJ
      TEE=0.5*(TBAR(1,I,J)+TBAR(2,I,J))
      CALL LOCK(TCPMET,CPMET,NCPMET,TEE,CPEE,KK)
      SUMCP=SUMCP+DMASSEL*CPEE*(TBAR(2,I,J)-TBAR(1,I,J))
1300 CONTINUE
      DTAU = ABS(2.0*SUMCP/QNET)
      TAU = TAU+DTAU
      GO TO 100
C
400 CONTINUE
      CALL ERTNAN(6,'@FREE 9 : : ')
      WRITE(KW,600)NSAVE
600 FORMAT(//10X,'UNIT ',IS,1X,'HAS NOT BEEN FREED'//)
C
200 CONTINUE
C
      IF(NCKSAV.NE.1 .AND. NCKSAV.NE.2)GO TO 210
      WRITE(KW,600)NCKSTR
      IF(NCKSAV.NE.1)GO TO 210
      NDUM=MAXX*MAXY
      CALL NTRAN(NCKSTR,22,10,22,1,12,TITLE,LL,22,
X 1,NDUM,THKCK,LL,22,10,22)
      WRITE(KW,610)NCKSTR
610 FORMAT(//10X,'COKE THICKNESS DATA HAVE BEEN STORED',
X 1X,'ON UNIT',IS/)
210 CONTINUE
C
      STOP
      END

```

TABLE A.9 LISTS OF HEAT EXCHANGER INPUT PROGRAM

```

SUBROUTINE INPUT(I,J)
INCLUDE PROCO, LIST
DIMENSION NTEE(10), TYTLE(12)
DATA KR,KW/5,6/
DATA PI,GC/3.141592, 32.174/
DATA ELMASS/0.7/
DATA NCPMET,ATYPE,MTCORE,MTSHEL,FACTF,FACTF/D,1,1,1,1.0,2.3/

C
NAMESLIST /INPUT/ NCPMET,CPMET,TCPMET,ELMASS
NAMESLIST /RUNCON/ NI,NJ,NPTHA,NPTHB,NPRNT,NCUMP,KOMPLX,NITER,
X NCCST,ATYPE,MTCORE,MTSHEL,FACTF,FACTF,
X YLEN,XLEN,ZA,ZB,SWEEP,THKWAL,TOLITR,TURNLA,TURNLE

C
C
C
C
C-----DUMMY PARAMETERS SET FOR USE IN WRITE STATEMENTS
MAXJ = MAXX
MAXI = MAXY
MAXP = MAXPTH
MAXT = MAXTA7
MAXN = MAXNOD

C
C
NERR=0
IF(ISDYN.EQ.1)GO TO 10010
READ(KR,INPUT,ERR=10000,END=10000)
ISDYNX=ISDYN-1
WRITE(KW,10005)ISDYNX
10005 FORMAT(1H1/1CX,'*****STARTING DYNAMIC RESPONSE',
X 1X,'CODE - STEP',15,1X,'*****'/)
GO TO 10020
10010 CONTINUE
C-----CARD 1
READ(KR,500) (TYTLE(I),I=1,12)
500 FORMAT(12A6,18)
510 FORMAT(2I10)
520 FORMAT(2E10.5)
READ(5,RUNCON)
10020 CONTINUE
C-----CARDS 10 - 19
DO 100 N=1,NPTHA
READ(KR,510) IST,NODE,LSTEP
1START(1,N)=IST
NODES(1,N)=NODE
KANSTP(N)=0
IF(LSTEP.GT.0)KANSTP(N)=1
READ(KR,520) WDOT(1,N),PZRO(1,N),TZRO(1,N),DHYD(1,N),
1 DELTAX(N)
READ(KR,520) FAOFA(N),SAOV(N),FINTHK(N),FINLEN(N),FINSRF(N)
DO 110 L=1,NODE
READ(KR,511) I,J, TIN(1,I,J), HASIDE(I,J)
511 FORMAT(2I10,2E10.5)
512 FORMAT(2E10.5,1I10,2E10.5)
IARAY(1,N,L)=I
JARAY(1,N,L)=J
110 CONTINUE
100 CONTINUE
C-----CARDS 21 - 29
DO 200 N=1,NPTHB
READ(KR,510) IST, NODE
1START(2,N)=IST
NODES(2,N)=NODE
READ(KR,512) WDOT(2,N),PZRO(2,N),TZRO(2,N),
X NTUBES(N),DHYD(2,N),DELTAY(N)
DO 210 L=1,NODE
READ(KR,510) IARAY(2,N,L), JARAY(2,N,L)
210 CONTINUE
200 CONTINUE
C
IF(ISDYN.NE.1)GO TO 10030
C

```

TABLE A.9 Cont'd

```

C-----CARD 32 COKE DATA
      READ(KR,520) XKCOKE
      READ(KR,510) NCOKE
      DO 310 L=1,NCOKE
      READ(KR,520) TCTAB(L), THKCT(L)
C 310 CONTINUE
C
      READ(KR,520) PRSMAX
      READ(KR,510) NHOURS,NCKSAV
      DO 311 L=1,NHOURS
      READ(KR,520) HOURS(L)
C 311 CONTINUE
C
C-----CARD 32
      READ(KR,510) NSAT
      DO 320 L=1,NSAT
      READ(KR,520) PSATTP(L),TSATTB(L)
C 320 CONTINUE
C
C-----CARDS 33-39
C
      LIQCOP=1
      READ(KR,520,ERR=321) ALAM,BLAM,CLAM,CLAM
      READ(KR,520) ATURB,ETURB,CTURE
      READ(KR,520) ASUP,PSUP,CSUP,DSUP
      GO TO 312
C 321 CONTINUE
C-----LIQUID L FACTOR USED INSTEAD OF CORRELATIONS
      LIQCOP=2
      READ(KR,510) NLJAY
      DO 322 L=1,NLJAY
      READ(KR,520) RENLIQ(L),STNLIQ(L)
C 323 CONTINUE
C
C 322 CONTINUE
      READ(KR,510) NSTNTB
      DO 330 L=1,NSTNTB
      READ(KR,520) RENSTB(L),STNTB(L)
C 330 CONTINUE
C
C-----CARDS 40-49
C
      READ(KR,510) NTABB
      DO 420 L=1,NTABB
      READ(KR,520) TEMST(L),VISBT(L),XKBT(L),CPBT(L),RHOB(T)
C 420 CONTINUE
      READ(KR,520) PCRTTB,TCRTTB,AMUB
C-----FUEL VAPOR PROPERTIES
      READ(KR,510) NP,ISPURE
      NPROPS=5
      NTRY = NPROPS+1
      READ(KR,510) NTEE(L),L=1,NP)
      TABVAP(1)=NP
      TABVAP(2)=NPROPS
      DO 430 L=1,NP
      TABVAP(2+L)=NTEE(L)
C 430 CONTINUE
      LAST=2+2*NP
      DO 432 N=1,NP
      NT=NTEE(N)
      DO 434 K=1,NT
      READ(KR,520) PEE, (TABVAP(LAST+L),L=1,NTRY)
      IF(K.EQ.1) TABVAP(2+NP+N)=PEE
      LAST=LAST+NTRY
C 434 CONTINUE
C
C 432 CONTINUE
C-----MIXTURE HEAT CAPACITY
      READ(KR,510) NMIX
      DO 438 L=1,NMIX
      READ(KR,520) PMIXTB(L),CPMIXB(L)

```

TABLE A.9 Cont'd

```

436 CONTINUE
C
C-----DENSITY ABOVE CRITICAL CONDITIONS
  READ(KR,510) NP
  READ(KR,510) NTEE(L),L=1,NP)
  NPROPS=1
  NTRY = NPROPS+1
  TABCRT(1)= NP
  TABCRT(2)= NPROPS
  DO 440 L=1,NP
    TABCRT(2+L)= NTEE(L)
440 CONTINUE
  LAST=2+2*NP
  DO 442 N=1,NP
    NT=NTEE(N)
    DO 444 K=1,NT
      READ(KR,520) PEE, (TABCRT(LAST+L),L=1,NTRY)
      IF(K.EQ.1) TABCRT(2+NP+N)=PEE
      LAST=LAST+NTRY
444 CONTINUE
C
442 CONTINUE
C
C-----HEAT OF VAPORIZATION
  READ(KR,510) NVAPT8
  DO 480 L=1,NVAPT8
    READ(KR,520) FLAMTB(L),HVAPT8(L)
480 CONTINUE
C
C-----SURFACE TENSION
  READ(KR,510) NSIGMA
  DO 481 L=1,NSIGMA
    READ(KR,520) TSIGMA(L),SIGTAB(L)
481 CONTINUE
C
C-----F FUNCTION FOR BOILING
  READ(KR,510) NOVXF
  DO 482 L=1,NOVXF
    READ(KR,520) XOVFTB(L),FOVFTB(L)
482 CONTINUE
C
C-----S FUNCTION FOR BOILING
  READ(KR,510) NSTAB
  DO 483 L=1,NSTAB
    READ(KR,520) SRELTB(L),STAB(L)
483 CONTINUE
C
C-----FRICTION COEFFICIENT
  READ(KR,510) NFRB
  DO 446 L=1,NFRB
    READ(KR,520) PENFB(L),FBTAB(L)
446 CONTINUE
C
C-----CARDS 50-59
  READ(KR,520) AMUA
  READ(KR,510) NTAB
  DO 450 L=1,NTAB
    READ(KR,520) TEMAT(L),VICAT(L),XKAT(L),CPAT(L)
450 CONTINUE
C
  READ(KR,510) NFPIC
  DO 460 L=1,NFPIC
    READ(KR,520) RENF(L),FTAB(L)

```

TABLE A.9 Cont'd

```

460 CONTINUE
  READ(KR,510) NSTANT
  DO 470 L=1,NSTANT
    READ(KR,520) RENST(L),STNTAB(L)
470 CONTINUE
C-----CARDS CC-69
C
  READ(KR,510) KWALK
  DO 620 L=1,NWALK
    READ(KR,520) TWNTAB(L),XKWTAB(L)
620 CONTINUE
C
  END OF INPUT
C
  WRITE INPUTS
  IF(NPRNT.EQ.0) GO TO 7471
  WRITE(KW,6000)
6000 FORMAT(1H1)
  WRITE(KW,6010) (TITLE(I),I=1,12)
6010 FORMAT(10X,'INPUT SPECIFICATIONS OF ',12A6/)
  WRITE(KW,6020) NI,NJ,NPTHA,NPTHB,NPRNT,NDUMP,KOMPLX
6020 FORMAT(
  X/10X,'NO. OF NODES IN Y-DIR. ',I10,
  X/10X,'NO. OF NODES IN X-DIR. ',I10,
  X/10X,'NO. OF A - PATHS ',I10,
  X/10X,'NO. OF B - PATHS ',I10,
  X/10X,'NPRNT ',I10,
  X/10X,'NDUMP ',I10,
  X/10X,'KOMPLX ',I10,
  X/)
  WRITE(KW,6030) YLEN,XLEN,ZA,ZB,THKAL,TOLITR,
  X TURNLA,TURNLB
6030 FORMAT(
  X/10X,'Y-SIDE LENGTH ',E12.5,1X,'INCHES',
  X/10X,'X-SIDE LENGTH ',E12.5,1X,'INCHES',
  X/10X,'A-SIDE DEPTH ',E12.5,1X,'INCHES',
  X/10X,'B-SIDE DEPTH ',E12.5,1X,'INCHES',
  X/10X,'ALL THICKNESS ',E12.5,1X,'INCHES',
  X/10X,'ITERATION TOLERANCE ',E12.5,1X,'DEG F',
  X/10X,'SIDE A TURN LOSS FACTOR ',E12.5,
  X/10X,'SIDE B TURN LOSS FACTOR ',E12.5,
  X/)
  WRITE(KW,6031) SWEEP
6031 FORMAT(
  X/10X,'SWEEP ANGLE ',E12.5,1X,'DEGREES'/)
  WRITE(KW,6049)
6049 FORMAT(1H1,10X,'A-SIDE PATH DESCRIPTIONS'/)
C
10030 CONTINUE
  DO 7000 N=1,NPTHA
    WRITE(KW,6050) N,ISTART(1,N),NODES(1,N),KANSTP(N),WDOT(1,N),
    X PZWO(1,N),TZRO(1,N),DHYD(1,N)
6050 FORMAT(
  X/10X,'PATH NUMBER ',I12,
  X/10X,'START INDICATOR ',I12,
  X/10X,'NUMBER OF NODES ',I12,
  X/10X,'STEPPING SWITCH ',I12,
  X/
  X/10X,'FLOWRATE ',E12.5,1X,'LBM/SEC',
  X/10X,'INITIAL PRESSURE ',E12.5,1X,'PSIA',
  X/10X,'INITIAL TEMPERATURE ',E12.5,1X,'DEG F',
  X/10X,'HYDRAULIC DIAMETER ',E12.5,1X,'INCHES',
  X/)
  WRITE(KW,6060) FAOFA(N),SAOV(N),FINTHK(N),FINLEN(N),
  X FINSHF(N)
6060 FORMAT(
  X/10X,'FLOW AREA/FRONTAL AREA ',E12.5,
  X/10X,'SURFACE AREA/VOLUME ',E12.5, 1X,'FT**2-1',
  X/10X,'FIN THICKNESS ',E12.5, 1X,'INCHES'

```

TABLE A.9 Cont'd

```

X/10X,'FIN LENGTH',E12.5, 1X,'INCHES ',
X/10X,'FIN AREA/SURFACE AREA',E12.5,
X/
NODE = NODES(1,N)
IF(KANSTP(N).GT.1)GO TO 7010
WRITE(KW,6070) (IARAY(1,N,L),JARAY(1,N,L),L=1,NODE)
6070 FORMAT(/10X,'NODE CO-ORDINATES (I,J)=(Y,X)-1',
/ (10X,10(I3,' ',I3,3X)) )
GO TO 7010
CONTINUE
7010 WRITE(KW,6071)
6071 FORMAT(/10X, ' I J', : TEMPERATURE
X /10X, 8X, : DEG F BTU/HR-SQFT-F')
DO 7020 L=1,NODE
I = IARAY(1,N,L)
J = JARAY(1,N,L)
WRITE(KW,6072) IARAY(1,N,L),JARAY(1,N,L),TIN(1,I,J),HASIDE(I,J)
6072 FORMAT(10X,2I4, F12.3, E14.5)
7020 CONTINUE
WRITE(KW,6073)
6073 FORMAT(///)
7030 CONTINUE
C
WRITE(KW,6100)
6100 FORMAT(1H1,/10X,'B-SIDE PATH DESCRIPTIONS')
DO 7100 N=1,NPTM3
WRITE(KW,6053) N,ISTART(2,N), NODES(2,N),NTUBES(N),WDOT(2,N),
X PZRO(2,N), TZPO(2,N), DHYD(2,N)
6053 FORMAT(
X/10X,'PATH NUMBER',I12,
X/10X,'STAPT INDICATOR',I12,
X/10X,'NUMBER OF NODES',I12,
X/10X,'NUMBER OF TUBES',I12,
X/
X/10X,'FLOWRATE',E12.5,1X,'LBM/SEC',
X/10X,'INITIAL PRESSURE',E12.5,1X,'PSIA',
X/10X,'INITIAL TEMPERATURE',E12.5,1X,'DEG F',
X/10X,'HYDRAULIC DIAMETER',E12.5,1X,'INCHLS',
X/10X,'TUBE DENSITY',E12.5,1X,'IN*-2',
X/
NODE=NODES(2,N)
WRITE(KW,6070) (IARAY(2,N,L), JARAY(2,N,L),L=1,NODE)
7100 CONTINUE
IF(ISDYN.NE.1)GO TO 10040
C
WRITE(KW,6110) XKCOKE
6110 FORMAT(/10X, 'COKE THERMAL COND.',E12.5,1X,
X 'BTU/LBM-FT-HR')
WRITE(KW,6120)
6120 FORMAT(/10X, ' N TEMPERATURE COKE THICK',
X/15X, ' DEG F INCHES')
DO 7110 N=1,NCOKE
WRITE(KW,6130) N, TCTAB(N), THKCT(N)
6130 FORMAT(10X,I3,2X, 2E12.5 )
7110 CONTINUE
C
WRITE(KW,6131)HRSMAX
6131 FORMAT(/10X, 'COKE CURVE REPRESENTS CONDITIONS AT',E12.5,1X,
X 'HOURS')
IF(INCKSAV.EQ.1)WRITE(KW,6121)INCKSTR
IF(INCKSAV.EQ.2)WRITE(KW,6122)INCKSTR
6121 FORMAT(/10X, 'SAVE COKE THICKNESS DATA ON UNIT',I5/)
6122 FORMAT(/10X, 'READ COKE THICKNESS DATA FROM UNIT',I5/)
C
WRITE(KW,6132)
6132 FORMAT(/10X, ' N TIME',10X,3X,2X,7X,'HOURS')
DO 7111 N=1,NHOURS
WRITE(KW,6130) N,HOURS(N)
7111 CONTINUE

```

TABLE A.9 Cont'd

```

      WRITE(KW,6140)
6140 FORMAT(//10X,'SATURATION TEMPERATURE TABLE',
X          /10X,' A      SAT.-PRESS      SAT.-TEMP',
X          /10X,'      PSIA      DEG F',/)
      DO 7120 N=1,NSAT
      WRITE(KW,6130) N, PSATTB(N),TSATTB(N)
7120 CONTINUE
      GO TO (7121,7122), LIQCOR
7121 CONTINUE
      WRITE(KW,6200) ALAM,BLAM,CLAM,DLAM, ATURB,BTURB,CTURB,
X          ASUP,RSUP,CSUP,DSUP
6200 FORMAT(//10X,'HEAT TRANSFER CORRELATION CO-EFFICIENTS',/
X/10X,' FLOW      A      C      D',
X/10X,' LAMINAR      , 4E10.5,
X/10X,' TURBULENT      , 3E10.5,
X/10X,' SUPERCRIT.      , 4E10.5,
X/)
      GO TO 7129
7122 CONTINUE
      WRITE(KW,6205)
6205 FORMAT(//10X,'E-SIDE STANTON NUMBER TABLE (LIQUID)',/
X/10X,'      REYN NO.      ST*PR**2/3',/)
      DO 7123 N=1,NLJAY
      WRITE(KW,6310) N, REALIQ(N), STNLIQ(N)
7123 CONTINUE
C
7129 CONTINUE
C
      WRITE(KW,6210)
6210 FORMAT(//10X,'E-SIDE STANTON NUMBER TABLE (VAPOR)',/
X/10X,'      REYN NO.      ST*PR**2/3',/)
      DO 7130 N=1,ASTNTR
      WRITE(KW,6310) N, REFNSTB(N), STNTRB(N)
7130 CONTINUE
      WRITE(KW,6300)
6300 FORMAT(//10X,'LIQUID THERMAL PROPERTY DATA ',
X/10X,' TEMPERATURE      VISCOSITY      THERM COND',
X          SPEC HEAT      DENSITY',
X/15X,' 7X,' DEG F', ' LBM/FT-SEC BTU/FT-F-HR      BTU/LBM-F',
X          LBM/CU.FT',/)
      DO 7300 N=1,NTAPB
      WRITE(KW,6310) N, TEMPT(N), VISBT(N), XKBT(N), CPRT(N), PHOBT(N)
6310 FORMAT(10X,13,2X,5E12.5)
7300 CONTINUE
C
      WRITE(KW,6320) PCRTTB,TCRTTB,AMUB
6320 FORMAT(
X/10X,' LIQUID CRIT. PRESSURE      ,E12.5,1X,' PSIA',
X/10X,' CRIT. TEMPERATURE      ,E12.5,1X,' DEG F',
X/10X,' MOLECULAR WEIGHT      ,E12.5,
X/)
C
      WRITE(KW,6330) ISPURE
6330 FORMAT(//10X,'B-SIDE VAPOR THERMAL PROPERTIES (ISPLRE=',
X          12,1X,')',/
X/10X,' NP      NT      PRESSURE      TEMPERATURE      DENSITY',
X          VISCOSITY      THERM COND      SPEC. HEAT      QUALITY',
X/10X,' 12X,' PSIA', 7X,' DEG F', ' LBM/FT-SEC BTU/FT-F-HR      BTU/LBM-F      LBM/CU.FT',
X          LBM/FT-SEC BTU/FT-F-HR      BTU/LBM-F      PERCENT',/)
      NP= TABVAP(1)
      NTRY= TABVAP(2)+1
      LAST= 2+2*NP
      DO 7310 N=1,NP
      NT= TABVAP(2+N)
      PEE= TABVAP(2+NP+N)
      DO 7320 K=1,NT
      WRITE(KW,6340) N,K,PEE, (TABVAP(LAST+L),L=1,NTRY)
6340 FORMAT(10X,215,2X,7E12.5)
      LAST=LAST+NTRY
7320 CONTINUE
7310 CONTINUE

```

TABLE A.9 Cont'd

```

WRITE(KW,6140)
6140 FORMAT(/10X,'SATURATION TEMPERATURE TABLE',
X /10X,' N SAT.-PRESS SAT.-TEMP',
X /10X,' PSIA DEG F' /)
DO 7120 N=1,NSAT
WRITE(KW,6130) N, PSATTB(N),TSATTB(N)
7120 CONTINUE
GO TO (7121,7122), LIQCOR
7121 CONTINUE
WRITE(KW,6200) ALAM,BLAM,CLAM,DLAM, ATURB,BTURB,CTURB,
X ASUP,BSUP,CSUP,DSUP
6200 FORMAT(/10X,'HEAT TRANSFER CORRELATION CO-EFFICIENTS',/
X/10X,'FLOW' A B C D,
X/10X,'LAMINAR' : 4E10.5,
X/10X,'TURBULENT' : 3E10.5,
X/10X,'SLPERCRIT.' : 4E10.5,
X/)
GO TO 7129
7122 CONTINUE
WRITE(KW,6205)
6205 FORMAT(/10X,'B-SIDE STANTON NUMBER TABLE (LIQUID)'/
X/10X,' N REYN NO. ST*PR**2/3' /)
DO 7123 N=1,NLJAY
WRITE(KW,6310) N, REALIQ(N), STNLIQ(N)
7123 CONTINUE
C
7129 CONTINUE
C
WRITE(KW,6210)
6210 FORMAT(/10X,'P-SIDE STANTON NUMBER TABLE (VAPOR)'/
X/10X,' N REYN NO. ST*PR**2/3' /)
DO 7130 N=1,ASTNTB
WRITE(KW,6310) N, REFSIB(N),STNTB(N)
7130 CONTINUE
WRITE(KW,6300)
6300 FORMAT(1H1,/10X,'LIQUID THERMAL PROPERTY DATA',
X/10X,' N TEMPERATURE VISCOSITY THERM COND',
X SPEC HEAT DENSITY',
X/15X,' 7X,'DEG F', ' LBH/FT-SEC BTU/FT-F-HR BTU/LBH-F',
X ' LBH/CU.FT' /)
DO 7300 N=1,NTARB
WRITE(KW,6310) N, TEMBT(N),VISBT(N),XKBT(N),CPBT(N),PHOBT(N)
6310 FORMAT(10X,13,2X,5E12.5)
7300 CONTINUE
C
WRITE(KW,6320) PCRTIB,TCRTIB,AMUB
6320 FORMAT(
X/10X,' LIQUID CRIT. PRESSURE :E12.5,1X,' PSIA',
X/10X,' CRIT. TEMPERATURE :E12.5,1X,' DEG F',
X/10X,' MOLECULAR WEIGHT :E12.5,
X/)
C
WRITE(KW,6330)ISPURE
6330 FORMAT(1H1,/10X,'B-SIDE VAPOR THERMAL PROPERTIES (ISPURE=',
X 12,1X,') /)
X/10X,' NP NT PRESSURE TEMPERATURE DENSITY',
X VISCOSITY THERM COND SPEC. HEAT QUALITY',
X/10X,12X,' 8X,'PSIA',7X,'DEG F', ' LBH/CU.FT',
X ' LBH/FT-SEC BTU/FT-F-HR BTU/LBH-F PERCENT' /)
NP= TABVAP(1)
NTRY= TABVAP(2)+1
LAST= 2+2*NP
DO 7310 N=1,NP
NT= TABVAP(2+N)
PEE= TABVAP(2+NP+N)
DO 7320 K=1,NT
WRITE(KW,6340) N,K,PEE, (TABVAP(LAST+L),L=1,NTRY)
6340 FORMAT(10X,215,2X,7E12.5)
LAST=LAST+NTRY
7320 CONTINUE
7310 CONTINUE

```


TABLE A.9 Cont'd

```
C
      WRITE(KK,6350)
6350 FORMAT(//10X,'MIXTURE HEAT CAPACITY TABLE',//
X/10X,' N ', ' PRESSURE SPEC. HEAT',
X/10X,' SA, ' PSIA BTU/LBM-F'')
DO 7330 N=1,NMIX
      WRITE(KK,6310) N,PMIXTB(N),CPMIXB(N)
7330 CONTINUE
      WRITE(KK,6360)
6360 FORMAT(//10X,'DENSITY ABOVE CRITICAL POINT',//
X/10X,' NP NT ' PRESSURE TEMPERATURE DENSITY',
X/10X,' 1CA, ' PSIA DEG F LBM/CU.FT'')
NP=TABCR1(1)
NTRY=TABCR1(2)+1
LAST=2+NMIX
DO 7340 N=1,NP
      NT=TABCR1(2+N)
PEE=TABCR1(2+NP+N)
DO 7345 M=1,NT
      WRITE(KK,6340) N,M,PEE,(TABCR1(LAST+L),L=1,NTRY)
      LAST=LAST+NTRY
7345 CONTINUE
7340 CONTINUE
C
      WRITE(KK,6380)
6380 FORMAT(//10X,'HEAT OF VAPORIZATION TABLE',//
X/10X,' N ', ' PRESSURE H-VAP',
X/10X,' SA, ' PSIA BTU/LBM'')
DO 7380 N=1,NVAPT
      WRITE(KK,6310) N,PLAMTB(N),HVAPT(BIN)
7380 CONTINUE
C
      WRITE(KK,6381)
6381 FORMAT(//1 X,'SURFACE TENSION TABLE',//
X/10X,' N ', ' TEMPERATURE SIGMA',
X/10X,' SA, ' DEG F DYNES/CM'')
DO 7391 N=1,NSIGMA
      WRITE(KK,6310) N,TSIGMA(N),SIGTAB(N)
7391 CONTINUE
C
      WRITE(KK,6382)
6382 FORMAT(//10X,'F-FUNCTION FOR BOILING',//
X/10X,' N ', ' 1/BIGX F' //)
DO 7382 N=1,NOVXF
      WRITE(KK,6310) N,XOVFTB(N),FOVFTB(N)
7382 CONTINUE
      WRITE(KK,6383)
6383 FORMAT(//10X,'S-FUNCTION FOR BOILING',//
X/10X,' N ', ' RE=F**1.25 S' //)
DO 7394 N=1,NSTAS
      WRITE(KK,6310) N,SFLTBN(N),STAB(N)
7394 CONTINUE
C
      WRITE(KK,6370)
6370 FORMAT(//10X,'B-SIDE FRICTION FACTOR TABLE',//
X/10X,' N ', ' REYN NO. F-FACTOR'//)
DO 7350 N=1,NFRB
      WRITE(KK,6310) N,RENFBN(N),FBTAB(N)
7350 CONTINUE
C
C
      WRITE(KK,6400)AMUA
6400 FORMAT(//10X,'A-SIDE THERMAL PROPERTY DATA',
X/10X,' MOLECULAR WEIGHT E12.5/
X/10X,' N TEMPERATURE VISCOSITY THERM COND',
X/10X,' SPEC HEAT',
X/10X,' DEG F LBM/FT-SEC BTU/FT-F-HR BTU/LBM-F'//)
DO 7400 N=1,NTABA
      WRITE(KK,6310) N,TEMAT(N),VISAT(N),XKAT(N),CPAT(N)
7400 CONTINUE
C
```

TABLE A.9 Cont'd

```

      WRITE(KW,6450)
6450 FORMAT(1H1,/,10X,'A-SIDE FRICTION FACTOR TABLE',/,
X/10X,' N ',' REYN NO. F-FACTOR'/)
      DO 7450 N=1,NFRIC
      WRITE(KW,6310) N, RENF(N), FTAB(N)
7450 CONTINUE
C
      WRITE(KW,6460)
6460 FORMAT(1H1,/,10X,'A-SIDE STANTON NUMBER TABLE',/,
X/10X,' N ',' REYN NO. ST*PR**2/3'/)
      DO 7460 N=1,NSTANT
      WRITE(KW,6310) N, RENST(N), STNTAB(N)
7460 CONTINUE
C
      WRITE(KW,6470)
6470 FORMAT(1H1,/,10X,'WALL THERMAL CONDUCTIVITY TABLE',/,
X/10X,' N ',' TEMPERATURE THERM COND',
X/15X,' DEG F BTU/FT-F-HR'/)
      DO 7470 N=1,NWALK
      WRITE(KW,6310) N, TWTAB(N), XKWTAB(N)
7470 CONTINUE
7471 CONTINUE
7472 FORMAT(1H1,' P-SIDE FLOW RATES FOR EACH PATH ARE:',/,10(1X,
1 E12.5))
C
C
      IF(ISPURE.LT.1)ISPURE=1
      IF(ISPURE.GT.2)ISPURE=2
      IF(ISPURE.GE.2 .AND. NPRNT.EQ.0) WRITE(KW,7472)
      1 (WCOT(2,N),N=1,NPTHB)
C
C
      CONVERT TO A CONSISTENT SET OF UNITS
      LENGTH - FEET
      MASS - POUNDS
      TIME - SECONDS
      TEMPERATURE - RANKINE
C
      XLEN = XLEN /12.0
      YLEN = YLEN /12.0
      ZA = ZA /12.0
      ZB = ZB /12.0
      THKWAL = THKWAL/12.0
C
      XKCOKE = XKCOKE /3600.0
      PCRTTB = PCRTTB*144.0
      TCRTTB = TCRTTB*460.0
10040 CONTINUE
      DO 8000 N=1,MAXP
      PZRO(1,N) = PZRO(1,N) * 144.0
      PZRO(2,N) = PZRO(2,N) * 144.0
      TZRO(1,N) = TZRO(1,N)+460.0
      TZRO(2,N) = TZRO(2,N)+460.0
C
      DHYD(1,N) = DHYD(1,N) /12.0
      DHYD(2,N) = DHYD(2,N) /12.0
      DELTAX(N) = DELTAX(N) /12.0
      DELTAY(N) = DELTAY(N) /12.0
      FINTHK(N) = FINTHK(N) /12.0
      FINLEN(N) = FINLEN(N) /12.0
C
      8000 CONTINUE
      IF(ISOYA.NE.1)GO TO 10050
      DO 8100 N=1,MAXT
      TCTAB(N) = TCTAB(N)+460.0
      THKCT(N) = THKCT(N)/12.0
C
      PSATTB(N) = PSATTB(N)*144.0
      TSATTB(N) = TSATTB(N)+460.0
C
      TEMRT(N) = TEMRT(N)+460.0
      XKBT(N) = XKBT(N)/3600.0
C

```

TABLE A.9 Cont'd

```

      PMIXTR(N) = PMIXTB(N)*144.0
C      TEMAT(N) = TEMAT(N)+460.0
      XKAT(N) = XKAT(N)/3600.0
C      TWTAB(N) = TWTAB(N)+460.0
      XKWTAB(N) = XKWTAB(N)/3600.0
C      PLAMTB(N) = PLAMTB(N)*144.0
C      TSIGMA(N) = TSIGMA(N) + 460.0
C-----DYNE/CM TO LBF/FT
      SIGTAB(N) = SIGTAB(N) * 2.248E-6* 30.48
C
C      8100 CONTINUE
C      NP= TABVAP(1)
      NTRY = TABVAP(2)+1
      LAST=2+2*NP
      DO 8210 K=1,NP
      NT= TABVAP(2+N)
      TABVAP(2+NP+N)= TABVAP(2+NP+N)*144.0
      DO 8210 K=1,NT
      TABVAP(LAST+ 1) = TABVAP(LAST+1) + 460.0
      TABVAP(LAST+ 4) = TABVAP(LAST+4) / 3600.0
      TABVAP(LAST+ 6) = TABVAP(LAST+6) * 0.01
      LAST=LAST+NTRY
      8210 CONTINUE
      8200 CONTINUE
C
      NP= TABCRT(1)
      NTRY= TABCRT(2)+1
      LAST=2+2*NP
      DO 8220 K=1,NP
      NT= TABCRT(2+N)
      TABCRT(2+NP+N)= TABCRT(2+NP+N)*144.0
      DO 8230 K=1,NT
      TABCRT(LAST+1)= TABCRT(LAST+1)+460.0
      LAST=LAST+NTRY
      8230 CONTINUE
      8220 CONTINUE
C
      10050 CONTINUE
      DO 8240 K=1,NPTHA
      IF(KANSTP(N).LE.C)GO TO 8240
      NCODE= NCODES(1,N)
      DO 8241 L=1,NCODE
      I= JARAY(1,N,L)
      J= JARAY(1,N,L)
      TIN(1,I,J)= TIN(1,I,J) + 460.0
      HASIDE(1,J) = HASIDE(1,J) /3600.0
      8241 CONTINUE
      8240 CONTINUE
C
      IF(ISDYN.NE.1)GO TO 10060
C
C
C
C
      INITIALIZATION
      DO 5000 I=1,NI
      DO 5100 J=1,NJ
      DO 5200 K=1,2
      IF(K.EQ.2) TIN(K,I,J)=0.0
      TOUT(K,I,J) = 0.0
      TWALL(K,I,J) = 0.0
      TMEAN(K,I,J) = 0.0
      CPMEAN(K,I,J) = 0.0
      5200 CONTINUE
      QDOT(I,J) = 0.0
      THKCK(I,J) = 0.0
      AREE(I,J) = 0.0

```

TABLE A.9 Cont'd

```

      TERMS(1,1,J) = 0.C
      TERMS(2,1,J) = 0.C
      TERMS(3,1,J) = 0.C
5100 CONTINUE
5J00 CONTINUE
C
10060 CONTINUE
C
C-----INITIAL TEMPERATURE ASSIGNMENTS
C
      DO 6500 N=1,NPTHA
      NODE= NCDES(1,N)
      DO 6510 L=1,NCDE
      I= IARRAY(1,N,L)
      J= JARRAY(1,N,L)
      IF(KANSTP(N).GT.0)GO TO 6520
      TIN(1,I,J)= TZRO(1,N)
      TOUT(1,I,J)= TZRO(1,N)
      TMEAN(1,I,J)= TZRO(1,N)
      GO TO 6510
6520 CONTINUE
      TOUT(1,I,J)= TIN(1,I,J)
      TMEAN(1,I,J)= TIN(1,I,J)
6510 CONTINUE
6500 CONTINUE
      IF(ISDYN.NE.1)GO TO 10070
      DO 6600 N=1,NPTHb
      NODE= NCDES(2,N)
      DO 6610 L=1,NODE
      I = IARRAY(2,N,L)
      J = JARRAY(2,N,L)
      TIN( 2,I,J) = TZRO(2,N)
      TOUT(2,I,J) = TZPO(2,N)
      TWALL(1,I,J) = TZPO(2,N)
      TWALL(2,I,J) = TZRO(2,N)
      TCOKE(1,J) = TZRO(2,N)
      TMEAN(2,I,J) = TZRO(2,N)
      THKCK(I,J) = 0.C
6610 CONTINUE
6600 CONTINUE
C
      IF(INCKSAV.NE.2)GO TO 6700
C
C      RECALL COKE THICKNESS DATA
C
      NDUM=MAXX*MAXY
      CALL NTRAN(INCKSTR,22,10,22,2,12,ITYLE,LL,22,
      X      2,NDUM,THKCK,LL,22,10,22)
      WRITE(KW,6710)(ITYLE(I),I=1,12)
6710 FORMAT(/10X,'COKE THICKNESS DATA HAVE BEEN RECALLED ',
      X/10X, 'FROM CASE',1X,12A6/)
6700 CONTINUE
C
C      END OF INITIALIZATION
C
C
      IF(NEPR.LE.0) RETURN 1
10070 CONTINUE
      IF(ISDYN.GT.2)RETURN 1
C
C-----RESET PRINT OPTION
C
      NPRNT=0
C
C-----COKE THICKNESS CANNOT CHANGE DURING TRANSIENT
C
      HOURS(1)= HOURS(NHOURS)
      NHOURS= 1

```

TABLE A.9 Cont'd

```

      WRITE(KW,10072) ELMASS
10072 FORMAT(//1,X,'ELMASS      = ',E12.5,1X,'LBM'/)
      WRITE(KW,10074)
10074 FORMAT(//10X,'METAL HEAT CAPACITY TABLE'/
X/10X,' N' ,      ' TEMPERATURE      CP' ,
X/10X,2X,      '      DEG F      BTU/LBM-F'//)
      DO 10076 N=1,NCPMET
      WRITE(KW,10078)N, TCPMET(N),CPMET(N)
10078 FORMAT(10X,I2,2E12.5)
      TCPMET(N)=TCPMET(N)+460.0
10076 CONTINUE
      WRITE(KW,10080)
10080 FORMAT(//)
      RETURN 1
10000 CONTINUE
C
C      ERROR SUMMARY
C
      RETURN 2
      END

```

TABLE A.10 LIST OF HEAT EXCHANGER CALCULATION PROGRAM

```

SUBROUTINE CALC(LOTTA)
  INCLUDE PROCO,LIST
  DIMENSION ZTAR(10),TERROR(2,MAXPTH),QPATH(2,MAXPTH)
  DIMENSION FILDAT(10),INVRSA(MAXY,MAXX),INVRSB(MAXY,MAXX),
X   QSAT(MAXPTH),UA(MAXY,MAXX),MATEPL(10),TRATE(MAXY,MAXX)
  DATA (MATERL(N),N=1,10)/ 6HCARBON, 6HSTEEL, 6HMOLYBD, 6HENUM,
X   6HSTNLS, 6HSTEEL, 6HMOMEL, 6H, 6HSUPER, 6HALLOYS/
  DATA RZERO /1545.0/
  REAL NEWHOM

C   COSB=COS(SWEEP*PI/180.)
C
C-----SET UP INVERSE ARRAY
C
C   DO 20 N=1,NPTH
C     NODE=NODES(1,N)
C     DO 20 L=1,NODE
C       I=IARAY(1,N,L)
C       J=JARAY(1,N,L)
C       INVRSA(I,J)=N
C   20 CONTINUE
C   DO 21 N=1,NPTH
C     NODE=NODES(2,N)
C     DO 21 L=1,NODE
C       I=IARAY(2,N,L)
C       J=JARAY(2,N,L)
C       INVRSB(I,J)=N
C   21 CONTINUE
C
C   OUTER LOOP CONTROLS AGING OF HEAT EXCHANGER
C   DO 50000 ISHOUR=1,NHOURS
C     TIME
C     THEHR = HOURS(ISHOUR)
C     SET COKE THICKNESS
C     IF(ISHOUR.LE.1)GO TO 50100
C     DHOURS = THEHR - HOURS(ISHOUR-1)
C     IF(ISHOUR.GT.2)GO TO 50050
C
C     GET RATE OF COKE THICKNESS FORMATION BASED
C     UPON FIRST SOLUTION
C
C     DO 50010 I=1,NI
C     DO 50010 J=1,NJ
C     CALL LOCK(ITCTAB,THKCT,NCOKE,TWALL(2,I,J),THICK,KK)
C     TRATE(I,J)=THICK/HRSMAX
C 50010 CONTINUE
C 50050 CONTINUE
C
C     UPDATE COKE THICKNESSES
C     DO 50060 I=1,NI
C     DO 50060 J=1,NJ
C     THKCK(I,J)=THKCK(I,J)+ TRATE(I,J) * DHOURS
C 50060 CONTINUE
C 50100 CONTINUE
C
C     IF(NITER .LT. 1) NITER=25
C     QNET=0.C
C     THTA=0.C
C     DO 10000 ITER=1,NITER
C
C     SAVE PREVIOUS PASS'S OUTLET TEMPERATURES

```

TABLE A.10 Cont'd

```

DO 100 N=1,NPTHA
NODE= NCDES(1,N)
ILAST= IAPAY(1,N,NODE)
JLAST= JAPAY(1,N,NODE)
TOUTSV(1,N)= TOUT(1,ILAST,JLAST)
100 CONTINUE
DO 110 N=1,NPTHA
NODE= NCDES(2,N)
ILAST= IAPAY(2,N,NODE)
JLAST= JAPAY(2,N,NODE)
TOUTSV(2,N)= TOUT(2,ILAST,JLAST)
110 CONTINUE

C
C
C
A-PATH CONDITIONS

DO 200 N=1,NPTHA
NODE= NCDES(1,N)
DO 210 L=1,NODE
I= IAPAY(1,N,L)
J= JAPAY(1,N,L)
NP=INVRSE(I,J)
EL= DELTAX(N)
IF(ISTART(1,N).EQ.1) EL= DELTAY(NB)
IF(SWEEP.GT.0.1) GO TO 111
FRONAR(N)= ZA*EL
FLARA(N)= FACFA(N)*FRONAR(N)
SRFARA(N)= SAOV(N)*ZA*DELTAX(N)*DELTAY(NB)
FINAR(N)= FINSRF(N)*SRFARA(N)
GO TO 112
111 CONTINUE
FAOFA(N)= 1.0
FRONAR(N)= EL*ZA*COSB
FLARA(N)= FRONAR(N)
SRFARA(N)= DELTAX(N)*DELTAY(NB)
SAOV(N)= 1.0/ZA
FINSRF(N)= 0.0
FINAR(N)= 0.0
112 CONTINUE
ETAF=0.0
ETAZRO=1.0
REN=0.0
HA= HASIDE(1,J)
IF(KANSTP(N).GT.0)GO TO 205
C----- THERMAL PROPERTIES
CALL LOOK(ITEMAT,VISAT,NTABA,TMEAN(1,I,J),VIS,KK)
CALL LOOK(ITEMAT,XKAT,NTABA,TMEAN(1,I,J),XK,KK)
C----- TRANSPORT COEFFICIENTS
GEE= WDOT(1,N)/FLARA(N)
REN= GEE*OHYD(1,N)/VIS
PRN= VIS*CPMEAN(1,I,J)/XK
CALL LOOK(RENST,STNTAB,NSTANT,REN,STANT,KK)
HA= STANT/PRN**0.66667*GEE*CPMEAN(1,I,J)
C----- FIN EFFECTIVENESS
CALL LOOK(TWTAB,XKWTAB,NWALK,TWALL(1,I,J),XKWA,KK)
EM= SORT(2.0*HA/(XKWA*FINTHK(N)))
ETAF= TANH(EM*FINLEN(N))/(EM*FINLEN(N))
ETAZRO= 1.0-FINAR(N)/SRFARA(N)*(1.0-ETAF)
205 CONTINUE
FILDAT(1)= HA
FILDAT(2)= ETAF
FILDAT(3)= ETAZRO
FILDAT(4)= REN
TERMS(1,I,J)=1.0/(ETAZRO*SRFARA(N)*HA)
LREC=(1-I)*NJ+J
WRITE(1,SAVE=LPEC)(FILDAT(KK),KK=1,NUMWRD)
IF(ITER.GT.1) GO TO 210
QNET= QNET+1.0/TERMS(1,I,J)*(TMEAN(1,I,J)-
X 0.5*(TWALL(1,I,J)+TWALL(2,I,J)))
THTA=THTA+SRFARA(N)
210 CONTINUE
C
200 CONTINUE

```

TABLE A.10 Cont'd

```

C
C      B-PATH CONDITIONS
C
      CGAIN=.7
      DO 300 N=1,NPTH8
      NODE = NODES(2,N)
      X=0.0
      XCK=0.0
      HSV=0.0
      QSAT(N)=.0
C
C-----MAXIMUM HEAT ADDITION FOR CONSTANT TEMPERATURE VAPORIZATION. PHCCE
      CALL LOCK(PLANTB,HVAFB, NVAPTE, PZRO(2,N), HVAP, KK)
      QHVAP=WCOT(2,N)*HVAP
C
      DO 30 I=1,NI
      DO 30 J=1,NJ
      QUAL(I,J)=0.0
      3L CONTINUE
C
C-----SATURATION TEMPERATURE
C
      CALL LOCK(PSATB,TSATB, NSAT, PZRO(2,N),TSAT(N), KK)
      DO 310 L=1,NODE
      I = IARAY(2,N,L)
      J = JARAY(2,N,L)
      NA = INVPSA(I,J)
      EL=DELTA(NA)
      IF(ISTART(2,N).EQ.2) EL=DELTA(N)
      IF(SWEEP.GT.0.1) GO TO 11
      FLARB(N) = NTUBES(N)*PI/4.C * DHYD(2,N)**2
      AWALL(1,N) = NTUBES(N)* PI * (DHYD(2,N)+THKWAL)*EL
      AWALL(2,N) = NTUBES(N)* PI * DHYD(2,N)*EL
      GO TO 10
      11 CONTINUE
      EL=DELTA(NA)
      IF(ISTART(2,N).EQ.1) EL=DELTA(N)
      NTUBES(N)=1
      FLARB(N) = EL*ZB*COSB
      DHYD(2,N) = 2.0* EL* ZB *COSB / (EL*COSB+ZB)
      AWALL(1,N) = DELTA(NA)*DELTA(N)
      AWALL(2,N) = AWALL(1,N)
      10 CONTINUE
C
C
      IF(PZRO(2,N).GT.PCRITB) GO TO 311
C-----GET QUALITY
C
      GO TO (331,332),ISPURE
      331 CONTINUE
C
      DISTILLATE SUBSTANCE
      CALL LOCKUP(TABVAP,PZRO(2,N),TMEAN(2,I,J),ZTAB,KK)
      QUAL(I,J)= ZTAB(5)
      GO TO 333
C
      332 CONTINUE
C
      PURE SUBSTANCE, QUALITY DETERMINED FROM PREVIOUS NODE.
      IF(L.EQ.1) GO TO 333
      IP=IARAY(2,N,L-1)
      JP=JARAY(2,N,L-1)
      QUAL(I,J)=QUAL(IP,JP)
      333 CONTINUE
C
      IF(QUAL(I,J).LE.0.0) GO TO 311
      IF(QUAL(I,J).GT.0.0 .AND. QUAL(I,J).LT.1.0) GO TO 312

```


TABLE A.10 Cont'd

```

C-----FLOW IS 100% VAPOR
C
  IFLAG(I,J) = 7
C
C-----THERMAL PROPERTIES
  CALL LOCKUP(TABVAP,PZRO(2,N),TMEAN(2,I,J),ZTAB,KK)
  XK = ZTAB(3)
  VIS = ZTAB(2)
  RHOB = ZTAB(1)
  CPMEAN(2,I,J) = ZTAB(4)
C-----TRANSPORT COEFFICIENTS
  GEE = WDOT(2,N)/FLAFB(N)
  REN = GEE * DHYD(2,N)/VIS
  PRN = VIS * CPMEAN(2,I,J) / XK
  CALL LOCK(RENSTB,STNTB,NSTNTB,REN,STANT,KK)
  HB = STANT * GEE * CPMEAN(2,I,J) / PRN ** 0.66667
  HCONV = HB
  HGURG = 0.0
  HREAL = HB
  GO TO 37
311 CONTINUE
C
C-----FLOW IS 100% LIQUID
C
  IFLAG(I,J) = 1
C-----THERMAL PROPERTIES
  CALL LOCK(ITEMPT,VISBT,NTABB,TMEAN(2,I,J),VIS,KK)
  CALL LOCK(ITEMPT,XKBT,NTABB,TMEAN(2,I,J),XK,KK)
  CALL LOCK(ITEMPT,CPBT,NTABB,TMEAN(2,I,J),CPMEAN(2,I,J),KK)
  CALL LOCK(ITEMPT,RHOB,NTABB,TMEAN(2,I,J),RHOB,KK)
  CALL LOCK(ITEMPT,RHOB,NTABB,TCOKE(I,J),RHOB,KK)
C-----TRANSPORT COEFFICIENTS
  GEE = WDOT(2,N)/FLAFB(N)
  REN = GEE * DHYD(2,N)/VIS
  PRN = VIS * CPMEAN(2,I,J) / XK
C
  GO TO (341,342), LICCOR
341 CONTINUE
C
  IF(PZRO(2,N).GT.PCRITB)GO TO 340
C-----T LESS THAN TSAT / P LESS THAN PC
  IF(REN.GT.2300.0) GO TO 320
345 CONTINUE
  CALL LOCK(ITEMPT,VISBT,NTABB,TCOKE(I,J),VISW,KK)
  X=X*EL
  ANU=ALAM*(REN*PPN/(X/DHYD(2,N)))**BLAM
  X=X*(VISW/VIS)**CLAM
C-----MINIMUM LAMINAR NUSSELT NO. IS FOR FULLY
DEVELOPED FLOW
C-----
  IF(ANU.LT.3.66)ANU=3.66
  HB = ANU * XK / DHYD(2,N)
  HCONV = HB
  HGURG = 0.0
  HREAL = HB
  GO TO 37
320 CONTINUE
  ANU = ATURB*REN**BTURB * PRN**CTURB
  HB = ANU * XK / DHYD(2,N)
  HCONV = HB
  HGURG = 0.0
  HREAL = HB
  GO TO 37
340 CONTINUE
C-----P GREATER THAN PC
  IF(REN.LT.2300.0)GO TO 345
  CALL LOCK(ITEMPT,VISBT,NTABB,TCOKE(I,J),VISW,KK)
  CALL LOCK(ITEMPT,XKBT,NTABB,TCOKE(I,J),XKW,KK)
  CALL LOCK(ITEMPT,CPBT,NTABB,TCOKE(I,J),CPW,KK)
  REN = GEE * DHYD(2,N)/VISW
  PRN = VISW * CPW/XKW
  XK = XKW
  ANU = ASUP * REN**BSUP*PRN**CSUP*(RHOW/RHOB)**DSUP

```

TABLE A.10 Cont'd

```

      HB = ANU* XK / DHYD(2,N)
      HCONV = HB
      HGURG = 0.0
      HBREAL=HB
      GO TO 370
342 CONTINUE
C-----LIQUID STANTON NUMBER
      CALL LOCK(RENLIQ,STNLIQ,NLIJAY,REN,STANT,KK)
      HB = STANT* GEE* CPMEAN(2,I,J) / PRN** C.66667
      HCONV = HB
      HGURG = 0.0
      HBREAL=HB
      GO TO 370
312 CONTINUE
C
C-----FLOA IS A MIXTURE
      CALL LOCK(PMIXTB,CPMIXB,NMIXE,PZRO(2,N),CPMEAN(2,I,J),KK)
      IF(KOMPLX .GT. 0) GO TO 375
      HB = 1.0E+20
      HCONV = HB
      HGURG = 0.0
      HBREAL=0.0
      IFLAG(I,J)=?
      GO TO 370
C
C
375 CONTINUE
C
C-----TWO PHASE BOILING
      IF(EQUAL(I,J) .GT. 0.7) GO TO 371
      GEE = WDOT(2,N) / FLARB(N)
      CALL LOCK(ITEMBT,VISBT,NTABB,TMEAN(2,I,J),VISL,KK)
      CALL LOCK(ITEMBT,XKBT,NTABB,TMEAN(2,I,J),XKL,KK)
      CALL LOCK(ITEMBT,CPRT,NTABB,TMEAN(2,I,J),CPL,KK)
      CALL LOCK(ITEMBT,RHCBT,NTABB,TMEAN(2,I,J),RHOL,KK)
      CALL LOCK(PLAHTB,HVAPTB,NVAPTB,PZRO(2,N),HVAP,KK)
      CALL LOCK(ITSIGMA,SIGTAB,NSIGMA,TMEAN(2,I,J),SIGMA,KK)
      CALL LOCK(ITSATTB,PSATTB,NSAT,TMEAN(2,I,J),PSTTB,KK)
      CALL LOCK(ITSATTB,PSATTB,NSAT,TCOKE(I,J),PSTTW,KK)
      CALL LOCKUP(ITABVAP,PZRO(2,N),TMEAN(2,I,J),ZTAB,KK)
      RHOV = ZTAB(1)
      VISV = ZTAB(2)
      VFG=1./RHOV - 1./RHOL
      REN = GEE*(1.0-QUAL(I,J)) *DHYD(2,N) / VISL
      PRN = VISL * CPL/XKL
      XFUNCT = (QUAL(I,J)/(1.0-QUAL(I,J)))*0.9
      X = *(RHOL/RHOV)*0.5 * (VISV/VISL)*0.1
      CALL LOCK(XOVFTB,FOVFTB,NOVXF,XFUNCT,FVAL,KK)
      HCONV = 0.023*XKL / DHYD(2,N) * REN**0.8 *PRN**0.4 * FVAL
      SARG = REN* FVAL**1.25
      CALL LOCK(SRELTB,STAB,NSTAB,SARG,ESS,KK)
      HGURG = 0.0
      DT = 0.0
      DP = 0.0
      IF(TCOKE(I,J) .LT. TSAT(N)) GO TO 372
      DT=TCOKE(I,J) - TSAT(N)
      DP=778.16*DT*HVAP/(TSAT(N)*VFG)
      HGURG = 0.00122 * XKL**0.79 *CPL**0.45 *RHOL**0.49 * GC**C.25
      X = / (SIGMA**0.25 * VISL**0.29 * HVAP**0.24 * RHOV**0.24)
      X = * DT**0.24 * DP**0.75 * ESS
372 CONTINUE
      HMAC=HCONV
      HMIC=HGURG
      HB = HCONV+HGURG
      HBREAL=HB
      GO TO 370
371 CONTINUE
C
C-----HIGH QUALITY MIXTURE

```

TABLE A.10 Cont'd

```

      IF(HBV.GT.0.C) GO TO 373
      CALL LOCKUP(TABVAP,PZRO(2,N),TMEAN(2,I,J),ZTAB,KK)
      XK=ZTAB(3)
      VIS=ZTAB(2)
      RHOB=ZTAB(1)
      CPV=ZTAB(4)
      GEE=WDOT(2,N)/FLARB(N)
      REN=GEE*DHVD(2,N)/VIS
      PRN=VIS*CPV/XK
      CALL LOCK(RENSTB,STNTB,ASTNTB,REN,STANT,KK)
      HBV=STANT*GEE*CPV/PRN**0.66667
373  CONTINUE
      HCONV=HBV + ((1.-QUAL(I,J))/C.3)**0.5*(HMAC-HBV)
      HSURG=HMC*(1.-QUAL(I,J))/C.3**0.5
      HB=HCONV + HSURG
      HREAL=HB
C
370  CONTINUE
      FILDAT(1) = HF
      FILDAT(2) = RFN
      FILDAT(4) = HCONV
      FILDAT(5) = HCUPG
C
C-----COKE
C
      THKC = THMCK(I,J)
C-----TERMS IN EFFECTIVE HEAT TRANSFER EQUATION
      TERMS(3,I,J) = THKC/(XKCKOKE*AWALL(2,N))
      ABEE(I,J)=NTUPES(N)*PI*EL*(DHVD(2,N)-THKC)
      IF(KANSTP(NA).GT.C) ABEE(I,J)=SRFARA(NA)
      TERMS(4,I,J) = 1.C/(HB*ABEE(I,J))
      TRAP= C.5*(TWALL(1,I,J)+TWALL(2,I,J))
      CALL LOCK(TWTAB,XKWTAB,NWALL,TBAR,XKW,KK)
      TERMS(2,I,J) = THKWAL/(XKW*AWALL(1,N))
C
C-----HEAT TRANSFER RATE (BTU/ SEC)
      UA(I,J)=C.O
      DO 38C LQ=1,4
      UA(I,J) = UA(I,J) + TERMS(LQ,I,J)
38C  CONTINUE
      FILDAT(3) = 1.O/UA(I,J)
      CALL LOCK(ITEMAT,CPAT,NTABA,TIN(1,I,J),CPAIN,KK)
      CALL LOCK(ITEMAT,CPAT,NTABA,TOUT(1,I,J),CPAOUT,KK)
      QDOT(I,J)=(TIN(1,I,J)-TIN(2,I,J))/
      X      (UA(I,J)+1.C/(2.C*WDOT(1,NA)*CPMEAN(1,I,J))
      X      +1.O/(2.C*WDOT(2,N)*CPMEAN(2,I,J)))
      TOUT(2,I,J)=TIN(2,I,J)+QDOT(I,J)/(WDOT(2,N)*CPMEAN(2,I,J))
C
      GO TO (390,392),ISPURE
392  CONTINUE
      IF(WDOT(1,NA).LE.C.C.OR.WDOT(2,N).LE.C.C) QDOT(I,J)=C.C
      TOUT(2,I,J)=TIN(2,I,J)+QDOT(I,J)/(WDOT(2,N)*CPMEAN(2,I,J))
      IF(IFLAG(I,J).EQ.1.AND.TOUT(2,I,J).GT.TSAT(N))
      1  TOUT(2,I,J)=TSAT(N)
      IF(QSAT(N).GT.C.C.AND.QSAT(N).LT.OHVAP) TOUT(2,I,J)=TSAT(N)
      QGAIN=QGAIN + QDOT(I,J)
C
C-----CONSTANT TEMPERATURE HEAT ADDITION PROCESS
C
      IF(TOUT(2,I,J).LT.TSAT(N).OR.XCK.GT.2.O) GO TO 390
      IFLAG(I,J)=2
      TOUT(2,I,J)=TSAT(N)
C-----ACCUMULATED HEAT TRANSFER INCLUDES CORRECTION
C-----FOR FIRST NODE THAT JUST CONTAINS MIXTURE
C-----AND TOUT JUST EXCEEDS TSAT
      QSAT(N)=QSAT(N)+QDOT(I,J)-WDOT(2,N)*CPL*(TSAT(N)-TIN(2,I,J))
      IF(QSAT(N).GT.O.C) GO TO 391
      IFLAG(I,J)=1
      QSAT(N)=C.O
391  CONTINUE
      QUAL(I,J)=QSAT(N)/OHVAP
      IF(QUAL(I,J).GT.1.C)QUAL(I,J)=1.O
      IF(QUAL(I,J).LT.1.C)GO TO 390

```

TABLE A.10 Cont'd

```

C-----FLOW HAS JUST BECOME VAPOR
TSAT(N)=TSAT(N)+.C1
CALL LOOKUP(TABVAP,PZPO(2,N),TSAT(N),ZTAB,KK)
CPMEAN(2,I,J)=ZTAB(4)
TOUT(2,I,J)=TSAT(N)+(QSAT(N)-QHVAP)/(WDOT(2,N)*CPV)
QSAT(N)=QHVAP
IFLAG(1,J)=3
XCK=3.0
390 CONTINUE

C
C
IF(L.EQ.NODE)GO TO 381
IP = IARRAY(2,N,L+1)
JP = JARRAY(2,N,L+1)
TIN(2,IP,JP)= TOUT(2,I,J)
TMEAN(2,IP,JP)=TIN(2,IP,JP)
381 CONTINUE
LREC = KI*NU + (I-1)*NU+J
WRITE(NSAVE,LREC) (FILDAT(KK),KK=1,NUMWRD)
IF(ITER.EQ.1)
X QNET = QNET - HREAL*ABEE(I,J) *(TBAR-TMEAN(2,I,J))
310 CONTINUE
300 CONTINUE

C
C
UPDATE TEMPERATURES

QLOST = 0.0
DO 400 N=1,NPTHA
QPATH(1,N)=0.0
NODE= NODES(1,N)
DO 410 L=1,NODE
I = IARRAY(1,N,L)
J = JARRAY(1,N,L)
IF(WDOT(1,N).LE.0.0) TIN(1,I,J)=TIN(2,I,J)
IF(KANSTP(N).GT.0) GO TO 301
CALL LOCK(ITEMAT, CPAT, NTABA, TIN(1,I,J), CPAIN,KK)
TCUT(1,I,J)=TIN(1,I,J) - QDOT(I,J)/(WDOT(1,N)*CPAIN)
I3=0
302 CONTINUE
I3=I3+1
TOTIJ=TCUT(1,I,J)
CALL LOCK(ITEMAT, CPAT, NTABA, TOTIJ, CPAOUT,KK)
TOUT(1,I,J)=(CPAIN*TIN(1,I,J)-QDOT(I,J)/WDOT(1,N))/CPAOUT
IF(ABS(TOUT(1,I,J)-TCUTIJ).LT.1.0.OR. I3.GT.5) GO TO 301
GO TO 302
301 CONTINUE
QPATH(1,N)=QPATH(1,N) + WDOT(1,N)*(CPAIN*TIN(1,I,J)-CPAOUT*
X TOLT(1,I,J))
TMEAN(1,I,J)= 0.5*(TIN(1,I,J)+ TOUT(1,I,J))
TWALL(1,I,J)= TMEAN(1,I,J)- QDOT(I,J) * TERMS(1,I,J)
TWALL(2,I,J)= TWALL(1,I,J)- QDOT(I,J) * TERMS(2,I,J)
TCOKE(I,J) = TWALL(2,I,J)- QDOT(I,J) * TERMS(3,I,J)
IF(L.EQ.NODE.OR.KANSTP(N).EQ.1)GO TO 410
IP= IARRAY(1,N,L+1)
JP= JARRAY(1,N,L+1)
TIN(1,IP,JP) = TOUT(1,I,J)
410 CONTINUE
QLOST=QLOST + QPATH(1,N)
400 CONTINUE

C
DO 420 N=1,NPTHR
QPATH(2,N)=0.0
NODE = NODES(2,N)
DO 430 L=1,NODE
I = IARRAY(2,N,L)
J = JARRAY(2,N,L)
QPATH(2,N)=QPATH(2,N) + QDOT(I,J)
TMEAN(2,I,J)= 0.5 *(TIN(2,I,J) + TOUT(2,I,J))
430 CONTINUE
420 CONTINUE

```

TABLE A.10 Cont'd

```

C
C      CONVERGENCE CHECK
C
      NOGOOD = 0
      DO 500 N=1,NPTHA
      NODE = NODES(1,N)
      I = IARRAY(1,N,NODE)
      J = JARRAY(1,N,NODE)
      TCHK = TOUT(1,I,J) - TOUTSV(1,N)
      TERROR(1,N)=TCHK
      IF(ABS(TCHK).GT. TOLITR) NOGOOD= NOGOOD+1
500  CONTINUE
      DO 510 N=1,NPTRR
      NODE = NODES(2,N)
      I = IARRAY(2,N,NODE)
      J = JARRAY(2,N,NODE)
      TCHK = TOUT(2,I,J)- TOUTSV(2,N)
      TERROR(2,N)=TCHK
      IF(ABS(TCHK).GT. TOLITR) NOGOOD = NOGOOD+1
510  CONTINUE
      ITAT= ITER
      IF(NOGOOD.LE.DIGO TO 20000
C
      IF(NDUMP.LE.DIGO TO 10000
C
C      DUMP OF INTERMEDIATE RESULTS
C
      NALL = 0
      DO 2000 ID=1,NI
      DO 2050 JD=1,NJ
      NALL=NALL+1
      IF(MOD(NALL-1,50).NE.0) GO TO 2100
      WRITE(KW,2110) ITAT,NOGOOD
2110  FORMAT(1H1,/,1X,'DUMP FOR ITERATION',I5,1X,'NOGOOD=',I5,/,
X      /1X,'      I      J      TA-IN      TA-OUT      TA-MEAN      TWALL-A',
X      '      TWALL-B      TCOKE      TB-IN      TB-OUT      TB-MEAN',
X      '      CDOT',
X      /20X, 9(5X,'DEG R'),3X,'BTU/SEC'/)
2100  CONTINUE
      WRITE(KW,2120) ID,JD, TIN(1,ID,JD), TOUT(1,ID,JD),
X      TMEAN(1,ID,JD), (TWALL(L,ID,JD),L=1,2),
X      TCOKE(ID,JD), TIN(2,ID,JD), TOUT(2,ID,JD),
X      TMEAN(2,ID,JD), CDOT(ID,JD)
2120  FORMAT(10X,2I5,9F10.3,E10.5)
2050  CONTINUE
2000  CONTINUE
      NALL=0
      DO 2001 ID=1,NI
      DO 2002 JD=1,NJ
      NALL=NALL+1
      NA=INVRSA(ID,JD)
      NB=INVRSB(ID,JD)
      IF(MOD(NALL-1,50).NE.0) GO TO 2003
      WRITE(KW,2004) ITAT,NOGOOD
2004  FORMAT(1H1,/,1X,'DUMP FOR ITERATION',I5,1X,'NOGOOD=',I5,/,
X      /1X,'      I      J      CPMEAN-A      CPMEAN-B      TERM-1      TERM-2',
X      '      TERM-3      TERM-4      UA      QUALITY      DELTAX',
X      '      DELTAY ?      IFLAG'/)
2003  CONTINUE
      WRITE(KW,2105) ID,JD,(CPMEAN(I1,ID,JD),I1=1,2),
X      (TERMS(I2,ID,JD),I2=1,4),UA(ID,JD),QUAL(ID,JD),
X      DELTAX(NA),DELTAY(NB),IFLAG(ID,JD)
2105  FORMAT(1X,2I5,7E10.5,3F10.4,I10)
2002  CONTINUE
      WRITE(KW,2001) QLOST,QGAIN
2001  FORMAT(/////,1X,'HEAT LOST FROM A-SIDE = ',E11.5,' BTU/SEC',
X      /1X,'HEAT GAINED BY B-SIDE = ',E11.5,' BTU/SEC')
      WRITE(KW,2130)
2130  FORMAT(////)
C
10000 CONTINUE
C

```

TABLE A.10 Cont'd

```

C      NO CONVERGENCE
C
      WRITE(KW,600) ITAT, NOGOOD
600  FORMAT(///10A,'FAILED TO CONVERGE...AFTER ',I5,' ITERATIONS,',
X      1X,'NOGOOD = ',I10//)
      GO TO 31000
20000 CONTINUE
C
C      CONVERGENCE
C
      WRITE(KW,610) ITAT
61  FORMAT(///10X,'PROGRAM CONVERGED AFTER ',I5,1X,'ITERATIONS'//)
30000 CONTINUE
      WRITE(KW,601)
601  FORMAT(///10X,'SIDE PATH      ERROR-DEG F'//)
      DO 11000 N=1,NPTHA
      LABSD=4+ A
      WRITE(KW,602) LABSD,N,TERROR(1,N)
602  FORMAT(10X,A4,I5,5X,F10.3)
11000 CONTINUE
      DO 12000 N=1,NPTHB
      LABSD=4+ B
      WRITE(KW,602) LABSD,N,TERROR(2,N)
12000 CONTINUE
C
C      PRESSURE DROP CALCULATION
C
C      A SIDE
C
      DO 31000 N=1,NPTHA
      NODE = NODES(1,N)
      DELP(1,N) = 0.0
      HEADNU = 0.0
      DO 31100 L=1,NODE
      HEADOL=HEADNU
      I = IARRAY(1,N,L)
      J = JARRAY(1,N,L)
C
      ROIN = PZRO(1,N)*AMUA / (RZERO * TIN(1,I,J))
      ROEX = PZRO(1,N)*AMUA / (RZERO * TOUT(1,I,J))
      LREC=(I-1)*NJ+J
      READ(1,SAVE='LHFC')(FILDAT(KK),KK=1,NUMWRD)
      REN=FILCAT(4)
      CALL LOCK(REN,FTAB,NFRIC,REN,FRIC,KK)
      GEE = WDOT(1,N)/ FLARA(N)
      DELP(1,N) = DELP(1,N) + GEE**2 / (2.0*GC *ROIN)
X      * (1.0* (FLARA(N)/FRONAR(N))**2) * (ROIN/ROEX-1.0)
X      + FRIC * SRFARA(N)/ FLARA(N)*ROIN / (0.5*(ROIN+ROEX))
      HEADNU = GEE**2 / (2.0* GC * 0.5*(ROIN+ROEX))
      IF(L.EQ.1)GO TO 31100
C
C-----TURN LOSS
C
      KSCORE=C
      IM1= IARRAY(1,N,L-1)
      JM1= JARRAY(1,N,L-1)
      IF(ISTART(1,N).EQ.2)GO TO 31120
C-----HORIZONTAL TRAVERSE
      IF(INJ.EC.2)GO TO 31100
      IF(J.EQ.1 .OR. J.EQ.NJ) KSCORE=1
      IF(JM1.EQ.1 .OR. JM1.EQ.NJ) KSCORE=KSCORE+1
      GO TO 31150
31120 CONTINUE
C-----VERTICAL TRAVERSE
      IF(NI.EC.2) GO TO 31100
      IF(I.EC.1 .OR. I.EQ.NI) KSCORE=1
      IF(IM1.EQ.1 .OR. IM1.EQ. NI) KSCORE= KSCORE+1
31150 CONTINUE
      IF(KSCORE.EQ.2) DELP(1,N) = DELP(1,N)+ C.5*(HEADNU+HEADOL)*TURNLA
31100 CONTINUE
C

```

TABLE A.10 Cont'd

```

31000 CONTINUE
C
C      B SIDE
C
      DO 32000 N=1,NPTH8
      NODE=NODELS(2,N)
      DELP(2,N) = 0.0
      HEADNU = 0.0
      NEWMOM = 0.0
      DO 32900 L=1,NODE
      HEADOL = HEADNU
      OLD MOM = NEW MOM
      I= IAPAY(2,N,L)
      J= JAPAY(2,N,L)
      NA=INVRSA(I,J)
      EL = DELTAX(NA)
      IF(ISTART(2,N).EQ.2) EL = DELTAY(N)
      IF(S*EEP.GT.0.1) GO TO 32001
      FLARB(N) = NTUBES(N)*PI/4.0 * DHYD(2,N)**2
      AWALL(1,N) = NTUBES(N)* PI * (DHYD(2,N)+THKWAL)*EL
      AWALL(2,N) = NTUBES(N)* PI * DHYD(2,N)*EL
      GO TO 32002
32001 CONTINUE
      EL=DELTA(NA)
      IF(ISTART(2,N).EQ.1) EL=DELTAY(N)
      NTUBES(N)=1
      FLARB(N) = EL*25*COSB
      DHYD(2,N) = 2.0* EL* 28 *COSB / (EL*CCSB+Zb)
      AWALL(1,N) = DELTAX(NA)*DELTAY(N)
      AWALL(2,N) = AWALL(1,N)
32002 CONTINUE
      ALPHA(I,J) = 0.0
      KGO = IFLAG(1,J)
      GO TO (32100, 32200, 32300), KGO
32100 CONTINUE
C
C      FLOW IS 100% LIQUID
C
      GEE = WDOT(2,N)/FLARB(N)
      CALL LOCK(TEMPBT,VISBT, NTABB, TMEAN(2,I,J), VISB,KK)
      CALL LOCK(TEMPBT,VISBT, NTABP, TCOKE(I,J), VISW,KK)
      IF(PZRO(2,N).GT.PCRITB .AND. TMEAN(2,I,J).GT. TCRITB) GO TO 32110
      CALL LOCK(TEMPBT,RHOB, NTABB, TMEAN(2,I,J), RHOB,KK)
      GO TO 32110
32105 CONTINUE
      CALL LOCKUP(TABCRT,PZRO(2,N),TMEAN(2,I,J),ZTAB,KK)
      RHOB=ZTAB(1)
32110 CONTINUE
      REN = GEE* DHYD(2,N)/ VISB
      CALL LOCK(RENFB,FBTAE, NFRB, REN,FRIC,KK)
      DELTAP(1,I,J) = 4.0* FRIC* EL/ DHYD(2,N)*GEE**2 / (2.0*GC*RHOB)
      * (VISW /VISB) ** 0.14
      NEWMOM = 0.0
      GO TO 32200
32200 CONTINUE
C
C      MIXTURE
C
      GEE= WDOT(2,N)/FLARB(N)
C-----LIQUID
      CALL LOCK(TEMPBT,VISBT, NTABB, TIN(2,I,J), VISL,KK)
      CALL LOCK(TEMPBT,RHOB, NTABP, TIN(2,I,J), RHOL,KK)
C-----VAPOR
      CALL LOCKUP(TABVAP,PZRO(2,N),TOUT(2,I,J),ZTAB,KK)
      RHOV = ZTAB(1)
      VISV = ZTAB(2)
      RENL = (1.0 - QUAL(I,J))*GEE* DHYD(2,N)/VISL
      RENV = QUAL(I,J)* GEE* DHYD(2,N)/VISV
      CALL GETEX(RENV,RENL,RHOV,RHOL,QUAL(I,J),BIGX(I,J),PSIV2,PSIL2,
      * KW)
C-----DETERMINE WHICH PRESSURE DROP IS APPLICABLE

```

TABLE A.10 Cont'd

```

      IF (BIGX(I,J).GT.1.0) GO TO 32250
C----- VAPOR DELTA P
      RHOB = RHOV
      VISB = VISV
      VISW = VISE
      GEE = WDOT(2,N)* QUAL(I,J)/ FLARB(N)
      REN = GEE*DHYD(2,N)/VISB
      EX = 0.0
      PSIFAK = PSIV2
      GO TO 32255
32250 CONTINUE
C----- LIQUID DELTA P
      VISB = VISL
      RHOB = RHOL
      CALL LOCK(ITEMBT,VISBT,NTABB,TCOKE(I,J),VISW,KK)
      GEE = (1.0 - QUAL(I,J))*WDOT(2,N)/FLARB(N)
      REN = GEE*DHYD(2,N)/VISB
      EX = 0.14
      PSIFAK = PSIL2
32255 CONTINUE
      CALL LOCK(IRENFB,FBTAB,NFRB,REN,FRIC,KK)
      DELTAP(1,I,J) = 4.0*FRIC*EL/DHYD(2,N)*GEE**2 / (2.0*GC*RHOB)*
      X (VISW/VISB)**EX *PSIFAK
      ALPHA(I,J) = 1.0/(1.0 + (1.0 - QUAL(I,J))/QUAL(I,J)
      X *(RHOV/RHOL)**C.66667)
      NEWMOM = (1.0 - QUAL(I,J))*2 / (1.0 - ALPHA(I,J))/RHOL
      X + QUAL(I,J)*QUAL(I,J)/ALPHA(I,J)/RHOV
      EXPNLS = GEE**2 / (2.0*GC*RHOL*(1.0 - ALPHA(I,J)))
      GO TO 32300
32300 CONTINUE
C
C      FLOW IS 100% VAPOR
C
      CALL LOOKUP(TABVAP,PZPO(2,N),TMEAN(2,I,J),ZTAB,KK)
      VISB = ZTAB(2)
      RHOB = ZTAB(1)
      GEE = WDOT(2,N)/FLARB(N)
      REN = GEE*DHYD(2,N)/VISB
      CALL LOCK(IRENFB,FBTAB,NFRB,REN,FRIC,KK)
      DELTAP(1,I,J) = 4.0*FRIC*EL/DHYD(2,N)*GEE**2 / (2.0*GC*RHOB)
      NEWMOM = 1.0/RHOB
C
32300 CONTINUE
      DELTAP(2,I,J) = 0.0
      IF (L.GT.1) DELTAP(2,I,J) = GEE**2/ GC *(NEWMOM - OLDMOM)
      DELP(2,N) = DELP(2,N) + DELTAP(1,I,J) + DELTAP(2,I,J)
      HEADNU = GEE**2/(2.0*GC*RHOB)
      IF (L.EQ.1) GO TO 32900
C
C----- TURN LOSS
C
      KSCORE = 0
      IM1 = IAFAY(2,N,L-1)
      JM1 = JAHAY(2,N,L-1)
      IF (ISTART(2,N).EQ.2) GO TO 32810
C----- HORIZONTAL TRAVERSE
      IF (NJ.EQ.2) GO TO 32900
      IF (J .EQ. 1 .OR. J .EQ. NJ) KSCORE = 1
      IF (JM1.EQ.1 .OR. JM1 .EQ. NJ) KSCORE = KSCORE + 1
      GO TO 32850
32810 CONTINUE
C----- VERTICAL TRAVERSE
      IF (NI .EQ. 2) GO TO 32900
      IF (I .EQ. 1 .OR. I.EQ.NI) KSCORE = 1
      IF (IM1.EQ.1 .OR. IM1.EQ.NI) KSCORE = KSCORE + 1
32850 CONTINUE
      IF (KSCORE.NE.2) GO TO 32900
      ADDLOS = 0.5*(HEADNU+HEADOL)* TURNLB
      IF (IFLAG(I,J).EQ.2) ADDLOS = EXPNLS * TURNLB
      DELP(2,N) = DELP(2,N) + ADDLOS
32900 CONTINUE
C

```


TABLE A.10 Cont'd

```

32000 CONTINUE
C
  IF(INPRNY.LE.0)GO TO 51000
  IF(ISHOUR.ST.1 .AND. ISHOUR .LT. NHOURS)GO TO 50000
51000 CONTINUE
C
C-----WRITE FLOW CONDITIONS FOR THIS HEAT EXCHANGER
C
  NALL=0
  DO 4000 N=1,2
    GO TO (4010,4020),N
4010 CONTINUE
    NP=NP+1
    SIDE = 4H A
    GO TO 4030
4020 CONTINUE
    NP=NP+1
    SIDE = 4H B
4030 CONTINUE
C
  DO 4100 N=1,NP
    NALL = NALL+1
    IF(MOD(NALL-1,50).NE.0)GO TO 4200
    WRITE(KW,4110) (TITLE(L),L=1,12)
4110 FORMAT(1H1,75X,'A. FLOW CONDITIONS FOR ',12A6/
X/10X,' SIDE PATH START END FLOW T-IN T-OUT'
X/ 6X,'P-IN P-OUT QDOT'
X/ 42X,'LB/SEC',2(5X,'DEG F'),2(6X,'PSIA'),3X,'ETC/SEC'/)
4200 CONTINUE
    NCDE= NCDES(K,N)
    I1 = IARAY(K,N,1)
    IL = IARAY(K,N,NCDE)
    J1 = JARAY(K,N,1)
    JL = JARAY(K,N,NCDE)
    T1=TIN(K,I1,J1) - 460.C
    T2=TOUT(K,IL,JL) - 460.C
    P1=PZRO(K,N)/144.C
    P2=(PZRO(K,N)-DELP(K,N))/144.C
    WRITE(KW,4220) SIDE,N,I1,J1,IL,JL,QDOT(K,N),T1,T2,P1,P2,
X QPATH(K,N)
4220 FORMAT(10X,2X,A4,I6,2(1X,I3,' ',I3, ), 6F10.2)
4100 CONTINUE
4300 CONTINUE
C
C-----WRITE HEAT EXCHANGER SIZE
C
  WRITE(KW,51001) YLEN,XLEN,ZA
51001 FORMAT(7775X,'B. THE CORE SIZE OF THIS HEAT EXCHANGER IS ',
X 'APPROXIMATELY = ',2(F5.2,' FT. BY '),F5.2,' FT. ')
C
C-----ESTIMATE HEAT EXCHANGER MANUFACTURING COST
C
  IF(ITER.GE.NITER .OR. NCOST.EQ.0) GO TO 51005
  PAMAX=0.C
  PBMAX=0.C
  DO 51002 N=1,NP+1
    IF(PAMAX.LT.PZRO(1,N)) PAMAX=PZRO(1,N)
51002 DO 51003 N=1,NP+1
    IF(PBMAX.LT.PZRO(2,N)) PBMAX=PZRO(2,N)
51003 PAMAX=PAMAX/144.C
    PBMAX=PBMAX/144.C
    IF(MTCORE.LT.1) MTCORE=1
    IF(MTSHEL.LT.1) MTSHEL=1
    CALL HXCOST(THTA,PBMAX,PAMAX,NTYPE,MTCORE,MTSHEL,COSTB,
X FACTD,FACTPB,FACTPA,FACTM,FACTF,FACTC,COSTM)
    MTCORE=2*MTCORE-1
    MTSHEL=2*MTSHEL-1
    MTC2=MTCORE + 1
    MTS2=MTSHEL + 1
    WRITE(KW,51004) THTA,PAMAX,PBMAX,MATERL(MTSHEL),MATERL(MTS2),
X MATERL(MTCORE),MATERL(MTC2)

```

TABLE A.10 Cont'd

```

51004 FORMAT(///5X,'C. THE MANUFACTURING COST OF THIS HEAT ',
X 'EXCHANGER WAS ESTIMATED BASED ON THE FOLLOWING DATA:',
X //10X,'1. TOTAL HEAT TRANSFER AREA (A-SIDE) = ',F8.0,' SQ-FT',
X //10X,'2. A-SIDE (OR SHELL-SIDE) PRESSURE = ',F6.2,' PSIA',
X //10X,'3. B-SIDE (OR TUBES-SIDE) PRESSURE = ',F8.2,' PSIA',
X //10X,'4. A-SIDE (OR SHELL) MATERIAL = ',2A6,
X //10X,'5. B-SIDE (OR TUBES) MATERIAL = ',2A6)
WRITE(NEW,51005) FACTD,FACTPA,FACTPB,FACTM,FACTF,FACTC,COSTM
51005 FORMAT(10X,'6. AND FOLLOWING ADJUSTMENT FACTORS: ',//13X,
X 'DESIGN TYPE FACTOR = ',F5.2,'/13X,
X 'A-SIDE PRESSURE FACTOR = ',F5.2,'/13X,
X 'B-SIDE PRESSURE FACTOR = ',F5.2,'/13X,
X 'MATERIAL COSTING FACTOR = ',F5.2,'/13X,
X 'MANUFACTURING COMPLEXITY FACTOR = ',F5.2,'/13X,
X 'ESCALATION FACTOR FROM MID-7 = ',F5.2,'/1-X,
X '7. TOTAL MANUFACTURING COST = ',F10.0,' DALLORS')
51006 CONTINUE
C
C      OUTPUT
C
C-----STORE ALL DATA ON DRUM SINCE OUTPUT WILL ALTER UNITS
CALL OUTPUT(1)
50100 CONTINUE
RETURN
END

```

1

11

TABLE A.11 Cont'd

```

DO 2500 J=1,NJ
IF(TWALL(K,I,J).LT.TMAX)GO TO 2500
IX= I
JX= J
TMAX= TWALL(K,I,J)
2500 CONTINUE
WRITE(KW,2510) TMAX, IX,JX
2510 FORMAT(10X,'MAXIMUM WALL TEMPERATURE =',F10.3,1X,'F',
1X,'AT I=',I5,1X,'J=',I5//)
C
NALL = F
DO 3000 I=1,NI
DO 3050 J=1,NJ
NALL=NALL+1
IF(MOD(NALL-1,50).NE.0)GO TO 3100
WRITE(KW,3110) (TITLE(K),K=1,12)
3110 FORMAT(1H1,71X,'RESULTS OF',1X,12A6/
X/10X,' I J H-A',3X,'ETA-F ETA-D',
X 'REN NO.-A H-R REN NO.-B U*A COKE THK.
X/10X,10X, ' BTU/HR-SOFT-F',8X,8X,10X,
X 'RTL/HR-SOFT-F',10X, 6X,'BTU/HR-F', 4X,'INCHES',
X/ )
3100 CONTINUE
LREC = (I-1)*NJ+J
READ(NSAVE,LRFC) (RECA(KK),KK=1,NUMWRD)
LREC = NI*NJ + (I-1)*NJ+J
READ(NSAVE,LRFC) (RECB(KK),KK=1,NUMWRD)
RECA(1) = RECA(1) * 3600.0
RECB(1) = RECB(1) * 3600.0
RECB(3) = RECB(3) * 3600.0
WRITE(KW,3120)I,J,(RECA(KK),KK=1,4),(RECB(KK),KK=1,3),
X TMAX(K,I,J)
3120 FORMAT(10X,2I5,E14.5, 2F8.6, E10.5, E14.5, E10.5, E14.5,F10.5)
3050 CONTINUE
3000 CONTINUE
C
C
C PATH SUMMARY
NALL=0
DO 4000 K=1,2
GO TO (4010,4020),K
4010 CONTINUE
NP=NPTHA
SIDE = 4H A
GO TO 4030
4020 CONTINUE
NP=NPTHB
SIDE= 4H B
4030 CONTINUE
C
DO 4100 N=1,NP
NALL = NALL+1
IF(MOD(NALL-1,50).NE.0)GO TO 4200
WRITE(KW,4110) (TITLE(L),L=1,12)
4110 FORMAT(1H1,71X,'PATH SUMMARY FOR ',12A6/
X/10X,' SIDE PATH START END T-IN T-OUT',
X 3X,'DELTA P',
X/10X, 6X,6X, 8X,8X, 2(5X,'DEG F'),6X,'PSIA'//)
4200 CONTINUE
NODE= NCODES(K,N)
I1 = IARAY(K,N,1)
IL = IARAY(K,N,NODE)
J1 = JARAY(K,N,1)
JL = JARAY(K,N,NODE)
WRITE(KW,4220) SIDE, N, I1,J1, IL,JL, TIN(K,I1,J1),TOUT(K,IL,J1)
X DELP(K,N)
4220 FORMAT(10X,2X,A4,I6,2(1X,I3,',',I3,), 3F10.3)
4100 CONTINUE
4000 CONTINUE
C
C
C B SIDE PRESSURE DROP DATA TABLE

```

TABLE A.11 Cont'd

```

NALL=0
DO 5100 N=1,NPTH3
NODE=ACDES(2,N)
DO 5110 L=1,NODE
NALL=NALL+1
IF(MOD(NALL-1,50).NE.0) GO TO 5120
WRITE(KW,5110) (TITLE(K),K=1,12)
5110 FORMAT(1H1,75X,'B-SIDE PRESSURE DROP/QUALITY AND OTHER DETAILS',
X
X/5X,' PATH I J', DELTA-P-FR DELTA-P-MOM',
X
X ' DELTA-P-TOT QUALITY BIGX',
X ' HB-CONV HB-GURGLING ALPHA',
X/20X,3(1X,'PSIA'), 5X,'PERCENT',
X 2(' BTU/HR-SQFT-F'),
X/)
5120 CONTINUE
I = IARAY(2,N,L)
J = JARAY(2,N,L)
DPTOT= DELTAP(1,I,J)+DELTAP(2,I,J)
LREC = NI*NJ + (I-1)*NJ + J
READ(NSAVE,LREC) (RECB(KK),KK=1,NUMWRD)
RECB(4) = RECB(4)*3600.0
RECB(5) = RECB(5)*3600.0
WRITE(KW,5130) N,I,J,(DELTAP(K,I,J),K=1,2),DPTOT,QUAL(I,J),
X BIGX(I,J),RECB(4),RECB(5),ALPHA(I,J)
5130 FORMAT(5X,3I5,5F12.5,2E14.5,E10.4)
5100 CONTINUE
C 5000 CONTINUE
RETURN
END

```

TABLE A.12 LIST OF HEAT EXCHANGER COMMON BLOCKS

```

PROCC PROC
PARAMETER MAXX=30, MAXY=30,
PARAMETER MAXPTH=10, MAXNOD=200,
PARAMETER MAXTAB=30,
COMMON /ALLVAR/ GC,PI,KF,KW,
X      MAXI,MAXO,MAXP,MAXN,MAXT,
X      TITLE(12),NI,NJ,NPTHA,NPTHB,NPRNT,NDUMP,KOMPLX,NITER,
X      XLEN,YLEN,ZA,ZB,SWEEP,THKWAL,TOLITR,TURNLA,TURNLB,
X      NCOST,NTYPE,MTCORE,MTSHEL,FACTF,FACTE,ISTART(2,MAXPTH),
X      NCDES(2,MAXPTH),DELTAX(MAXPTH),DELTAY(MAXPTH),
X      WDOT(2,MAXPTH),PZRO(2,MAXPTH),TZRO(2,MAXPTH),CHYC(2,MAXPTH)
COMMON /ALLVAR/ FAOFA(MAXPTH),SAOV(MAXPTH),
X      FINTHK(MAXPTH),FINLEN(MAXPTH),FINSRF(MAXPTH),
X      IARAY(2,MAXPTH,MAXNOD),JARAY(2,MAXPTH,MAXNOD),
X      NTUBES(MAXPTH),TCTAB(MAXTAB),THKCT(MAXTAB),NCOKE,XKCOKE,
X      TSATTB(MAXTAB),PSATTB(MAXTAB),NSAT,
X      TEMBT(MAXTAB),VISBT(MAXTAB),XKBT(MAXTAB),
X      CFBT(MAXTAB),RHOBT(MAXTAB),NTABB,AMUB,PCRTTB,TCRTTB,
X      TEMAT(MAXTAB),VISAT(MAXTAB),XKAT(MAXTAB),
X      CFAT(MAXTAB),NTABA,AMUA
COMMON /ALLVAR/ RENF(MAXTAB),FTAB(MAXTAB),NFRIC,
X      RENST(MAXTAB),STNTAB(MAXTAB),NSTANT,
X      TWTAB(MAXTAB),XKWTAB(MAXTAB),NWLK
COMMON /ALLVAR/ FRONAR(MAXPTH),FLARA(MAXPTH),SRFARA(MAXPTH),
X      FINAR(MAXPTH),FLARB(MAXPTH),AWALL(2,MAXPTH),
X      TCUTSV(2,MAXPTH),TSAT(MAXPTH)
COMMON /ALLVAR/
X      TIN(2,MAXY,MAXX),TOUT(2,MAXY,MAXX),TWALL(2,MAXY,MAXX),
X      TCUKE(MAXY,MAXX),GDOT(MAXY,MAXX),
X      TMLAN(2,MAXY,MAXX),CPMFAN(2,MAXY,MAXX),
X      AREA(MAXY,MAXX),THKCK(MAXY,MAXX),
X      TERMS(4,MAXY,MAXX)
COMMON /ALLVAR/
X      ALAM,BLAM,CLAM,DLAM,
X      ATURE,FTURE,CTURB,
X      ASCP,BSUP,CSUP,DSUP,
X      OGAIN,CLOST,ISPURE,
X      NSAVE,NUMREC,NUMWRD,LREC
COMMON /ALLVAR/ IFLAG(MAXY,MAXX),QUAL(MAXY,MAXX),
X      RENSTB(MAXTAB),STNTB(MAXTAB),NSTNTB,
X      TAEVAP(1022),TABCRT(422),
X      PMIXTB(MAXTAB),CPMIXB(MAXTAB),NMIX,
X      DELP(2,MAXPTH),DELTAP(2,MAXY,MAXX),
X      RENFB(MAXTAB),FBTAB(MAXTAB),NFRB,
X      ALPHA(MAXY,MAXX),BIGX(MAXY,MAXX)
COMMON /ALLVAR/
X      PLAMTB(MAXTAB),HVAPTB(MAXTAB),NVAPTB,
X      TSIGMA(MAXTAB),SIGTAB(MAXTAB),NSIGMA,
X      XCVFTB(MAXTAB),FOVFTB(MAXTAB),NOVXF,HASIDE(MAXY,MAXX),
X      SRELTB(MAXTAB),STAB(MAXTAB),NSTAB,KANSTP(MAXPTH)
COMMON /ALLVAR/ LIQCOR,NLJAY,RENLIQ(MAXTAB),STNLIQ(MAXTAB)
COMMON /ALLVAR/ HRSMAX,NHOURS,HOURS(MAXTAB),
X      NCKSAV,NCKSTR
COMMON /DYNAMIC/ CNET,ISDYN,TAU,NCPMET,CPMET(50),TCPMET(50),
X      NSTORE,ELMASS
END

```

DISTRIBUTION LIST

Fluid Mechanics and Heat Transfer

(One copy except as noted)

Mr. M. Keith Ellingsworth (5)
Materials and Mechanics Programs
Office of Naval Research
800 N. Quincy St.
Arlington, VA. 22203

Defense Documentation Center (12)
Bldg. 5, Cameron Station
Alexandria, VA. 22314

Technical Information Division (6)
Naval Research Laboratory
4555 Overlook Ave., S.W.
Washington, D.C. 20375

Dr. A. Wood
Director, Mechanics Program
Office of Naval Research
800 N. Quincy St.
Arlington, VA. 22203

Professor P. Marto
Dept. of Mechanical Engineering
U.S. Naval Post Graduate School
Monterey, CA. 93940

Professor B. Rankin
Naval Systems Engineering
U.S. Naval Academy
Annapolis, MD. 21402

Office of Naval Research/Eastern
Eastern Central Regional Office
Bldg. 114, Section D
666 Summer St.
Boston, MA. 02210

Office of Naval Research Branch Office
536 Clark St.
Chicago, Ill. 60605

Office of Naval Research
Western Regional Office
1030 E. Green St.
Pasadena, CA. 91106

Mr. C. Miller, Code 05R13
Crystal Plaza #6
Naval Sea Systems Command
Washington, D.C. 20362

Steam Generators Branch, Code 5222
National Center #4
Naval Sea Systems Command
Washington, D.C. 20362

Heat Exchanger Branch, Code 5223
National Center #3
Naval Sea Systems Command
Washington, D.C. 20362

Mr. E. Ruggiero, NAVSEA 08
National Center #2
Washington, D.C. 20362

Dr. E. Quandt, Jr., Code 272
David Taylor Ship R&D Center
Annapolis, MD. 21402

Mr. W. Adamson, Code 2722
David Taylor Ship R&D Center
Annapolis, MD. 21402

Dr. Win Aung
Heat Transfer Program
National Science Foundation
Washington, D.C. 20550

Mr. M. Perlswieg
Dept. of Energy
Mail Station E-178
Washington, D.C. 20545

DISTRIBUTION LIST (Continued)

Dr. W. H. Thielbahr
Chief, Energy Conservation Branch
Dept. of Energy
Idaho Operations Office
550 Second St.
Idaho Falls, ID. 83401

Professor E. M. Sparrow
Dept. of Mechanical Engineering
University of Minnesota
Minneapolis, MN. 55455

Professor J.A.C. Humphrey
Dept. of Mechanical Engineering
University of California, Berkeley
Berkeley, CA. 94720

Professor B. Launder
Thermodynamics & Fluid Mechanics Division
University of Manchester
Institute of Science & Technology
P088 Sackville St.
Manchester M601QD ENGLAND

Professor Shi-Chune Yao
Dept. of Mechanical Engineering
Carnegie-Mellon University
Pittsburgh, PA 15213

Professor C. B. Watkins
Chairman, Mechanical Engineering Dept.
Howard University
Washington, D.C. 20059

Professor A. Bejan
Dept. of Mechanical Engineering
University of Colorado
Boulder, CO. 80309

Professor D. M. McEligot
Dept. of Aerospace & Mechanical Engineering
Engineering Experiment Station
University of Arizona
85721

Professor P. A. Libby
Dept. of Applied Mechanics &
Engineering Sciences
University of California, San Diego
PO Box 109
LaJolla, CA. 92037

Professor C. Forbes Dewey, Jr.
Fluid Mechanics Laboratory
Massachusetts Institute of Technology
Cambridge, MA. 02139

Professor W. G. Characklis
Dept. of Civil Engineering &
Engineering Mechanics
Montana State University
Bozeman, Montana 59717

Professor R. Webb
Dept. of Mechanical Engineering
Pennsylvania State University
208 Mechanical Engineering Bldg.
University Park, PA. 16802

Professor W. Rohsenow
Mechanical Engineering Dept.
Massachusetts Institute of Technology
77 Massachusetts Ave.
Cambridge, MA. 02139

Professor A. L. London
Mechanical Engineering Dept.
Bldg. 500, Rm. 501B
Stanford University
Stanford, CA. 94305

Professor J. G. Knudsen
Associate Dean, School of Engineering
Oregon State University
219 Covell Hall
Corvallis, Oregon 97331

Professor A. E. Bergles
Mechanical Engineering Dept.
Iowa State University
Ames, Iowa 50011

BEST AVAILABLE COPY

DISTRIBUTION LIST (Continued)

Professor K. J. Bell
School of Chemical Engineering
Oklahoma State University
Stillwater, Oklahoma 74074

Dr. J. Lorenz
Component Technology Division
Argonne National Laboratory
9700 S. Cass Ave.
Argonne, ILL 60439

Dr. D. M. Eissenberg
Oak Ridge National Laboratory
PO Box Y, Bldg. 9204-1, MS-0

Dr. J. Taborek
Technical Director
Heat Transfer Research Institute
1000 S. Fremont Ave.
Alhambra, CA. 91802

Dr. S. C. Kuo
Manager, Thermal Engineering
United Technologies Research Center
Silver Lane
E. Hartford, CT. 06118

Mr. J. Yampolsky
General Atomic Company
PO Box 81608
San Diego, CA. 92138

Mr. T. Carnavos
Noranda Metal Industries Inc.
Prospect Dr.
Newtown, CT. 06470

Dr. R. K. Shah
Harrison Radiator Division
General Motors Corp.
Lockport, N.Y. 14094

Dr. R. K. Sakhuja
Manager, Advanced Programs
Thermo Electron Corp.
101 First Ave.
Waltham, MA. 02154

Dr. K. E. Starnner
York Division, Borg-Warner Corp.
PO Box 1592
York, PA. 17405

Mr. P. Wishart
C-E Power Systems
Combustion Engineering, Inc.
Windsor, CT. 06095

Mr. H. W. Braum
Manager, Condenser Engineering Dept.
Delaval
Front St.
Florence, N.J. 08518

Dr. T. Rabas
Steam Turbine-Generator Technical
Operations Division
Westinghouse Electric Corp.
Lester Branch
PO Box 9175 N2
Philadelphia, PA. 19113

Mr. W. Ritz
Code 033C
Naval Ships Systems Engineering Station
Philadelphia, PA. 19112

Mr. R. F. Wyvill
Code 5232
National Center #4
Naval Sea Systems Command
Washington, D.C. 20362

Mr. D. Marron, Code 5231
National Center #4
Naval Sea Systems Command
Washington, D.C. 20362

Mr. T. M. Herder
Bldg. 46462
General Electric Co.
1100 Western Ave.
Lynn, MA. 01910

BEST AVAILABLE COPY

DISTRIBUTION LIST (Concluded)

Mr. E. Strain
AiResearch of Arizona
Dept. 76, MS 301-2
PO Box 5217
Phoenix, AZ. 85010

Mr. N. McIntire
Solar Turbines International
2200 Pacific Highway
2200 Pacific Highway
San Diego, CA. 92101

Professor D. Metzger
Chairman, Mechanical & Energy Systems Engineering
Arizona State University
Tempe, AZ. 85281

BEST AVAILABLE COPY