

Calhoun: The NPS Institutional Archive
DSpace Repository

Theses and Dissertations

Thesis and Dissertation Collection

1992-12

Model fan passage flow simulation

Myre, David D.

Monterey, California. Naval Postgraduate School

<http://hdl.handle.net/10945/23962>

Downloaded from NPS Archive: Calhoun



Calhoun is a project of the Dudley Knox Library at NPS, furthering the precepts and goals of open government and government transparency. All information contained herein has been approved for release by the NPS Public Affairs Officer.

Dudley Knox Library / Naval Postgraduate School
411 Dyer Road / 1 University Circle
Monterey, California USA 93943

<http://www.nps.edu/library>

NAVAL POSTGRADUATE SCHOOL

Monterey, California



THESIS

MODEL FAN PASSAGE
FLOW SIMULATION

by

David D. Myre

December, 1992

Thesis Advisor:

Raymond P. Shreeve

Approved for public release; distribution is unlimited

REPORT DOCUMENTATION PAGE

1a. REPORT SECURITY CLASSIFICATION Unclassified			1b. RESTRICTIVE MARKINGS		
2a. SECURITY CLASSIFICATION AUTHORITY			3. DISTRIBUTION/AVAILABILITY OF REPORT Approved for public release; distribution is unlimited.		
2b. DECLASSIFICATION/DOWNGRADING SCHEDULE					
4. PERFORMING ORGANIZATION REPORT NUMBER(S)			5. MONITORING ORGANIZATION REPORT NUMBER(S)		
6a. NAME OF PERFORMING ORGANIZATION Naval Postgraduate School		6b. OFFICE SYMBOL (If applicable) 33		7a. NAME OF MONITORING ORGANIZATION Naval Postgraduate School	
6c. ADDRESS (City, State, and ZIP Code) Monterey, CA 93943-5000			7b. ADDRESS (City, State, and ZIP Code) Monterey, CA 93943-5000		
8a. NAME OF FUNDING/SPONSORING ORGANIZATION Naval Air Warfare Center Aircraft Division		8b. OFFICE SYMBOL (If applicable) PE 31		9. PROCUREMENT INSTRUMENT IDENTIFICATION NUMBER N6237692WR00134	
8c. ADDRESS (City, State, and ZIP Code) P.O. Box 7176 Trenton NJ 08628-0176			10. SOURCE OF FUNDING NUMBERS		
			Program Element No WR024	Project No 03	Task No 001
11. TITLE (Include Security Classification) Model Fan Passage Flow Simulation					
12. PERSONAL AUTHOR(S) David D. Myre					
13a. TYPE OF REPORT Master's Thesis		13b. TIME COVERED From To		14. DATE OF REPORT (year, month, day) December 1992	
15. PAGE COUNT 173					
16. SUPPLEMENTARY NOTATION The views expressed in this thesis are those of the author and do not reflect the official policy or position of the Department of Defense or the U.S. Government.					
17. COSATI CODES			18. SUBJECT TERMS (continue on reverse if necessary and identify by block number)		
FIELD	GROUP	SUBGROUP	Shock-Boundary Layer Interaction, Transonic Fan Simulation, Fan Passage Loss Estimation, Boundary Layer Separation		
19. ABSTRACT (continue on reverse if necessary and identify by block number) Two-dimensional experimental and numerical simulations of a transonic fan blade passage were conducted at a Mach number of 1.4 to provide baseline data for the study of the effects of vortex generating devices on the suction surface shock-boundary layer interaction. In the experimental program, a probe and traverse system were designed and constructed. A new data acquisition system was adapted to record data from probe measurements and multiple scans of static pressure ports. Impact pressure behind two model fan passages and static pressures across the shock-boundary layer interaction were measured for a design and one off-design flow incidence in a blow-down wind tunnel. The passage shocks were positioned in similar locations by rotating the model to a decreased flow incidence. Fan passage losses were obtained by integrating probe measurements. The losses compared favorably with a numerical Navier-Stokes solution and one engineering loss model. Static pressure distributions were also found to compare favorably with numerical results.					
20. DISTRIBUTION/AVAILABILITY OF ABSTRACT ☒ UNCLASSIFIED/UNLIMITED ☐ SAME AS REPORT ☐ DTIC USERS			21. ABSTRACT SECURITY CLASSIFICATION Unclassified		
22a. NAME OF RESPONSIBLE INDIVIDUAL Raymond P. Shreeve			22b. TELEPHONE (Include Area code) (408) 656-2593		22c. OFFICE SYMBOL AA/SF

Approved for public release; distribution is unlimited.

Model Fan Passage
Flow Simulation

by

David D. Myre
Lieutenant, United States Navy
B.S.A.E., United States Naval Academy

Submitted in partial fulfillment
of the requirements for the degree of

MASTER OF SCIENCE IN AERONAUTICAL ENGINEERING

from the

NAVAL POSTGRADUATE SCHOOL

December, 1992

ABSTRACT

Two-dimensional experimental and numerical simulations of a transonic fan blade passage were conducted at a Mach number of 1.4 to provide baseline data for the study of the effects of vortex generating devices on the suction surface shock-boundary layer interaction. In the experimental program, a probe and traverse system were designed and constructed. A new data acquisition system was adapted to record data from probe surveys and multiple scans of static pressure ports. Impact pressure behind two model fan passages and static pressures across the shock-boundary layer interaction were measured for a design incidence and one off-design incidence in a blow-down wind tunnel. The passage shocks were positioned in similar locations by rotating the model to a decreased flow incidence. Fan passage losses were obtained by integrating the probe measurements. The losses compared favorably with a numerical Navier-Stokes solution and one engineering model. Static pressure distributions were also found to compare favorably with numerical results.

TABLE OF CONTENTS

I.	INTRODUCTION	1
A.	SHOCK-BOUNDARY LAYER INTERACTION	1
B.	BOUNDARY LAYER CONTROL	2
C.	2-D FAN PASSAGE SIMULATION	6
II.	EXPERIMENTAL SIMULATION	9
A.	TRANSONIC CASCADE WIND TUNNEL	9
1.	Wind Tunnel Description	9
2.	Optical System	13
B.	TEST SECTION INSTRUMENTATION	14
1.	Static Pressure Taps	14
2.	Impact Probe and Vertical Traverse	15
C.	DATA ACQUISITION AND ANALYSIS SYSTEM	18
1.	Pressure Measurement System	18
a.	ZOC-14 Data Acquisition System	18
b.	Pressure Monitoring System	19
c.	NF90 Stepping Motor Controller/Unislide Motor Driven Assembly	20

2.	Data Acquisition and Analysis Programs	22
a.	The Data Acquisition Program "SCAN_ZOC_06"	22
b.	The "READ_ZOC2" Data Reduction Program	23
III.	EXPERIMENTAL PROGRAM AND RESULTS	24
A.	EXPERIMENTAL PROGRAM	24
1.	Initial Tests	24
2.	Probe Surveys at Design Incidence (1.15 degrees)	25
3.	Probe Surveys at -0.85 Degree Incidence	25
B.	EXPERIMENTAL RESULTS	28
1.	Measurements at Design Incidence	28
2.	Measurements at -0.85 degree Incidence	30
IV.	NUMERICAL SIMULATION	34
A.	GRID GENERATION	34
B.	COMPUTATIONAL SCHEME	34
1.	The Solution Method	34
2.	RVCQ3D Inputs	37
C.	COMPUTATIONAL SOLUTION	38
1.	Summary of Previous Numerical Results	38
2.	Current Numerical Solution	38
3.	Computational Results	39
a.	Suction Surface Pressure Profile	39
b.	Flow Separation	40

c. Shock Resolution	43
d. Loss Calculation	43
V. DISCUSSION OF RESULTS.....	44
A. BLADE SURFACE PRESSURE DISTRIBUTIONS	44
B. CASCADE LOSS ESTIMATION	46
VI. CONCLUSIONS AND RECOMMENDATIONS	49
APPENDIX A. WIND TUNNEL INSTRUMENTATION	53
APPENDIX B. PROBE AND TRAVERSE DESIGN	57
APPENDIX C. ZOC-14 DAS PROGRAM DEVELOPMENT	73
APPENDIX D. DATA ANALYSIS PROGRAM READ_ZOC2	106
APPENDIX E. SELECTED DATA	119
APPENDIX F. SAMPLE RVCQ3D INPUT AND SUMMARY OF RESTARTS	148
APPENDIX G. SAMPLE CALCULATION USING KOCH AND SMITH	149
LIST OF REFERENCES	156
INITIAL DISTRIBUTION LIST	159

LIST OF TABLES

TABLE I.	Static Pressure Tap Locations	14
TABLE II.	UNISLIDE Lead Screw Parameters	21
TABLE III.	Scan Types Available	22
TABLE IV.	Experimental Program	26
TABLE V.	Summary of Solution Outputs.....	39
TABLE VI.	Mass Averaged Quantities and Losses	46
TABLE VII.	Loss Model Inputs and Predicted Losses	47
TABLE VIII.	Comparison of Loss Estimates	48
TABLE IX.	Scan Types Available	75
TABLE X.	NF90 Commands Used in SCAN_ZOC_06.....	77
TABLE XI.	Modifications to Program SCAN_ZOC_06	78
TABLE XII.	Summary of RVCQ3D Restart Inputs	148

LIST OF FIGURES

Figure 1	Shock Boundary Layer Interaction	2
Figure 2	Low Profile Vortex Generators [Ref. 2]	3
Figure 3	Vortex Generating Jets [Ref. 2]	4
Figure 4	Passive Cavity Operation	5
Figure 5	Transonic Cascade Blade Geometry	7
Figure 6	Wind Tunnel Laboratory Schematic	9
Figure 7	Schematic of the Transonic Wind Tunnel	10
Figure 8	Transonic Wind Tunnel	10
Figure 9	Back Pressure Valve	11
Figure 10	Test Section Schematic	12
Figure 11	Test Section	12
Figure 12	Optical System	13
Figure 13	Impact Probe and Probe Holder	16
Figure 14	Impact Probe and Probe Holder	16
Figure 15	Probe Traverse Assembly	17
Figure 16	Data Acquisition System Schematic	19
Figure 17	NF90 and VELMEX UNISLIDE	21
Figure 18	Continuous Light Shadowgraph	27
Figure 19	Spark Light Shadowgraph	27

Figure 20	Lower Blade Surface Pressure Distribution ($P_2/P_1 = 2.04$)	29
Figure 21	Lower Blade Surface Pressure Distribution ($P_2/P_1 = 2.14$)	29
Figure 22	Loss Distribution at Design Incidence (1.15 degrees)	30
Figure 23	Lower Blade Surface Pressure Distribution	31
Figure 24	Middle Blade Side Plate Pressure Distribution	31
Figure 25	Loss Distribution at Off-Design Incidence (-0.85 degrees)	33
Figure 26	Viscous Grid	35
Figure 27	Viscous Grid Leading Edge	35
Figure 28	Viscous Grid Trailing Edge	36
Figure 29	RMS Density Residuals	39
Figure 30	Blade Surface Pressure Distribution	40
Figure 31	Skin Friction Coefficient (x1000)	41
Figure 32	Velocity Profile at Shock Induced Separation	42
Figure 33	Particle Trace at Shock Induced Separation	42
Figure 34	Mach Number Contours	43
Figure 35	Surface Pressure Distributions	45
Figure A1	Side Plate Instrumentation	53
Figure A2	Window Blank Instrumentation	55
Figure A3	Lower Blade Instrumentation	56
Figure B1	Probe Traverse Assembly Drawing	57
Figure B2	Probe Traverse Assembly Drawing	58

Figure B3 Test Section Lower Block Modification	59
Figure B4 Fixed Block	60
Figure B5 Sliding Block	61
Figure B6 Probe and Traverse Interface	63
Figure B7 Probe Mounting Block	64
Figure B8 Traverse Mounting	65
Figure B9 VELMEX UNISLIDE	67
Figure B10 Probe and Probe Holder	68
Figure B11 Stainless Rod	70
Figure B12 Plumbing Detail	71
Figure B13 Initial Probe Design	72
Figure C1 Program "SCAN_ZOC_06"	85
Figure D1 Program "READ_ZOC2"	106
Figure E1 Run 3, 16 Nov 1992	119
Figure E2 Run 4, 19 Nov 1992	126
Figure E3 Run 2, 1 Dec 1992	133
Figure E4 Run 1, 7 Dec 1992	140
Figure G1 Loss Estimation by Koch and Smith Method	149

ACKNOWLEDGMENTS

I would like to express my deep appreciation to those people who have assisted me in this study. Professor Raymond Shreeve has given me invaluable insight into the realm of scientific exploration while keeping me focused on my objectives. Professor Garth Hobson has helped me to understand the relationship between computational methods and experimentation and has always been a sounding board for my ideas. I am grateful to Rick Still for his amazing technical skill, creativity and steadying influence on my work. Without his tireless efforts this study would not have been possible. I would like to thank John Moulton for his skilled craftsmanship in manufacturing a probe and traverse system for the transonic wind tunnel and Don Harvey and Pat Hickey for their guidance in the design of the apparatus. Finally, I thank my wife Karla, whose patience, support and constant encouragement make it possible for me to reach any height.

I. INTRODUCTION

A. SHOCK-BOUNDARY LAYER INTERACTION

The demand for higher levels of thrust and the desire to limit the physical size of turbofan engines have combined to drive fan and leading compressor stage relative Mach numbers higher into the supersonic range. A shock system is inevitable in a transonic stage and "... the design principle is not the avoidance of shocks, but control of their locations and strengths so as to minimize aerodynamic losses." [Ref. 1] At operating conditions in such a stage, a shock forms at the leading edge of each blade and impinges on the suction side boundary layer of the adjacent blade. The resulting flow structure is illustrated in Figure 1. The subsonic portion of the boundary layer may not be able to negotiate the steep pressure gradient in the neighborhood of the shock and may separate locally and reattach at some point downstream. This results in a shock structure called a lambda-foot where the original normal shock branches into two oblique shocks near the wall. In a fan passage, reattachment must take place in a very small percentage of the chord to allow further diffusion to the design pressure ratio.

Characterization of the opposing loss mechanisms present in this flow regime are of interest to the designer. The size of the interaction will determine the normal shock losses and the behavior of the boundary layer. As the interaction is suppressed, high normal shock losses dominate. If the interaction region is large then the boundary layer

will thicken, mixing losses will increase and the design flow turning angles will not be achieved.




Figure 1. Shock-Boundary Layer Interaction

B. BOUNDARY LAYER CONTROL

Several promising methods for controlling the shock-boundary layer interaction have been examined recently [Ref. 2]. Among these are vortex generator jets (VGJ's), low-profile vortex generators and the passive cavity. The first two devices energize the low momentum flow nearest the wall with higher momentum flow via streamwise vortices. This provides the inner layer with enough momentum to overcome the adverse pressure gradient transmitted forward through the subsonic layer. The passive cavity

induces suction downstream of the shock and injection upstream of the shock which reduces the separation region while increasing boundary layer thickness [Ref. 3].

Conventional vane-type vortex generators have been studied since the nineteen fifties. NACA first investigated their usefulness for controlling flow separation and shock-boundary layer interactions. The low-profile vortex generator is relatively new and offers promise of reducing separation with less parasitic drag than conventional vortex generators [Ref. 3]. Examples of such devices are the "Wheeler Doublet" [Ref. 4] and the "wishbone" profile low-profile vortex generators both examined by Linn, et al and shown in Figure 2 [Ref. 2]. These vortex generators are submerged in the boundary




Figure 2. Low profile Vortex Generators [Ref. 2]

layer many boundary layer thicknesses upstream of the shock-boundary layer interaction. For external flows over surfaces and internal flow in diffusers these wedge shapes would be easy to apply, but there may be more difficulty in applying them to fan blades with adequate precision.

VGJ's, shown in Figure 3, have been studied extensively by Johnston and Nishi as well as Johnston and Compton [Ref 5, 6]. VGJ's are pitched and skewed to the streamwise direction and can be passively or actively operated. In studies completed in subsonic flows they provide the largest vorticity when pitched at about forty-five degrees and yawed between forty-five and ninety degrees. These jets can be implemented in the fan application simply by drilling holes through blading. In passive operation the jet




Figure 3. Vortex Generating Jets [Ref. 2]

would pass high pressure air from the pressure surface to the suction surface. An alternative approach would be to actively provide air to the jets through the blade only in the transonic range of operation. In both cases blade strength would be an issue and in the active case, mechanical complexity would be added.

The passive cavity is illustrated in Figure 4. Passive cavity operation is described as follows. "The pressure rise across the shock induces a passive suction downstream of the shock, which tends to close down the separation bubble, and an injection of flow upstream of the shock, causing a series of compression waves to form (resulting in more isentropic compression) and the pressure rise to spread over a larger axial distance (which tends to suppress separation)." [Ref. 3]




Figure 4. Passive Cavity Operation

C. 2-D FAN PASSAGE SIMULATION

The effects of various flow control devices, including vortex generators, on the shock-boundary layer interaction have been examined by McCormick [Refs. 3, 7] in a round tube geometry. In the present work, it is planned to examine the most promising configurations shown in McCormick's results in a model simulation of the flow in a fan passage. The present work is an extension of studies performed by Golden [Ref. 8] and Collins [Ref. 9]. The wind tunnel used in the present work was designed by Demo [Ref. 10] and first used for blading studies by Hegland [Ref. 11]. The data acquisition system designed by Wendland [Ref. 12] was adapted and implemented in the course of the present study.

The geometry of the model was intended to generate a 2-D simulation of the relative flow on a stream surface through an advanced fan rotor at approximately 63% of the span. The geometry of the model is shown in Figure 5. The blade profile was approximated very closely as a wedge arc for ease of manufacture, and since streamline contraction could not be simulated in the experiment. Measurements made by Golden showed the flow through the model passage to be acceptably two dimensional [Ref. 8].

In the current study, an impact pressure probe and vertical traverse were designed and manufactured, and the "Zero Operate and Calibrate" (ZOC) Data Acquisition System (DAS) developed by Wendland [Ref. 12] was adapted to acquire data from probe surveys and multiple scans of static pressure ports in order to establish a baseline performance of the unmodified blade. This system was then implemented on the wind tunnel. With the

Blade Geometry

L.E. Radius	= 0.015 in
T.E. Radius	= 0.015 in
Wedge Angle	= 3.5°
Wedge Length	= 2.85 in
Suction Surface	
Arc Radius	= 13.53 in




Figure 5. Transonic Cascade Blade Geometry

model at design incidence, surface pressure distributions and impact pressure distributions impact pressure distributions behind the lower and middle blade were measured. Cascade losses were obtained by integrating the probe measurements. When it was discovered that similar shock locations in the two passages could be obtained by rotating the model to a decreased flow incidence, static and impact pressure profiles were obtained at this condition. The measured behavior was analyzed and comparisons were made with computational simulations and one engineering loss model.

In the present report, the wind tunnel and model simulation, the probe design and DAS modification are described in Chapter II. In Chapter III, the experimental program and results are presented. A computational simulation of the blade geometry is presented in Chapter IV and in Chapter V, the experimental and numerical results are compared. Chapter VI provides conclusions based on the progress of the current study and recommendations for future work.

II. EXPERIMENTAL SIMULATION

A. TRANSONIC CASCADE WIND TUNNEL

1. Wind Tunnel Description

The wind tunnel used was a blow-down apparatus located in the Gas Dynamics Laboratory (Bldg. 216) at the Naval Postgraduate School. A schematic of the facility is shown in Figure 6. A schematic of the wind tunnel and a photograph of the tunnel are shown in Figures 7 and 8, respectively.




Figure 6. Wind Tunnel Laboratory Schematic




Figure 7. Schematic of the Transonic Wind Tunnel




Figure 8. Transonic Wind Tunnel

The wind tunnel inlet pressure was maintained by a pneumatically operated control valve. The test section back pressure required to simulate fan pressure ratios was adjusted using a hand-operated hydraulic flap valve mounted aft of the test section. The valve is shown in Figure 9. A convergent-divergent nozzle provided a Mach 1.4 flow to the test section inlet. A test section schematic and photograph are shown in Figures 10 and 11 respectively. Boundary layer scoops were provided on the upper and lower as




Figure 9. Back Pressure Valve

well as right and left sides of the test section in order to divert the boundary layers from the model. The test section modeled two fan passages, between three fan blades. The middle blade in the model was the only complete blade, while the upper and lower sections were half blades, modeling only lower and upper surfaces respectively. The incidence of the model could be varied. The blade upper surface was inclined 1.15

degrees to the freestream flow at the design condition, while the blade wedge angle was 3.5 degrees. Further details of the wind tunnel can be found in Ref. 9. Details of the back pressure valve design are contained in Ref. 8.




Figure 10. Test Section Schematic




Figure 11. Test Section

2. Optical system

The optical system provided both schlieren and shadowgraph capabilities. A diagram of the arrangement used is shown in Figure 12. A continuous or spark light source was available from a combination unit. A parabolic lense collimated the light, directing it through the test section and into a parabolic mirror where the beam was reflected into the camera. Shadowgraph photos were made during selected tunnel runs to record the shock position and shock structure.




Figure 12. Optical System

B. TEST SECTION INSTRUMENTATION

1. Static Pressure Taps

Pressure taps were provide on side plates, window blanks and the lower blade as described by Golden [Ref. 8]. Two side plate pressure taps were used to measure the inlet and exit static pressures. The lower blade centerline pressure taps were used to measure the static pressures across the shock-boundary layer interaction region as well as to measure possible flow field disturbance caused by probe surveys. Aluminum window replacement blanks were instrumented in a fashion that would provide similar information to that of the lower blade. Table I summarizes the pressure tap locations. Drawings of the instrumented components are given in Appendix A.

TABLE I. STATIC PRESSURE TAP LOCATIONS

Section	Ports	Location	Purpose
Side Plates	2	Upstream/down-stream of test section	Measure cascade pressure ratio
Lower Blade	25	Centerline of blade surface	Measure static pressure through shock
Window Blanks	8	Close to blade surface	"
Plenum	1	Plenum, aft of screen	Provide tunnel Reference pressure

2. Impact Probe and Vertical Traverse

A probe was designed and mounted in a vertical traverse for conducting pressure surveys downstream of the cascade model. The probe was an impact tube with 0.02 inch internal diameter and a 0.032 inch external diameter. It was mounted in a probe holder designed to cause minimum disturbance to the flow. The probe and holder are shown in Figures 13 and 14. The probe holder was mounted on a solid shaft that passed out of the test section through a bearing surface and connected to a mounting block. This mounting block was then bolted to the mounting block of a VELMEX UNISLIDE Motor Driven Assembly. The entire assembly is shown Figure 15. The assembly consisted of a hardened aluminum dovetail base with an aluminum sliding element fitted with bonded bearing pads. A high precision lead screw converted rotational motion to linear motion for up to 6.6 inches of travel. Further details are given in Reference 13. Drawings for the probe and UNISLIDE assembly are contained in Appendix B.




Figure 13. Impact Probe and Probe Holder




Figure 14. Impact Probe and Probe Holder




Figure 15. Probe Traverse Assembly

C. DATA ACQUISITION AND ANALYSIS SYSTEM

1. Pressure Measurement System

The pressure measurement system consisted of three main elements: namely the "Zero Operate and Calibrate" (ZOC-14) Data Acquisition System (DAS) for recording pressure data, a continuous pressure monitoring system for setting pressure ratio prior to data taking and the VELMEX NF90 Stepper Motor Controller which operated the UNISLIDE Motor Driven Assembly to provide probe surveys behind the test section blading. A schematic of the pressure measurement system is shown in Figure 16. The present application of this system was an extension of the work done by Wendland [Ref. 12].

a. ZOC-14 Data Acquisition System

The Zero Operate and Calibrate (ZOC) Data Acquisition System (DAS) consisted of the HP9000 Series 300 Desk Top Computer System, three Scanivalve ZOC-14 Electronic Scanning Modules, the CALSYS2000 calibration standard and the HP6944A Multiprogrammer. The HP 9000 Series 300 Desktop Computer acted as the master controller for the system as well as a data storage and processing tool. Extensive documentation provided with this language is described further in Reference 12. The HP9000 is equipped with 10 mega-bytes of Random Access Memory and a 40 mega-byte hard drive as well as a 1.44 mega-byte floppy drive. HP Basic version 5.13 software was used. A comprehensive guide to the system is given in Reference 12.




Figure 16. Data Acquisition System Schematic

b. Pressure Monitoring System

The Pressure Monitoring System allowed the tunnel operator to set the pressure ratio across the cascade prior to recording data by providing a continuous display of the test section inlet (P1) pressure, exit pressure (P2) and exit to inlet pressure ratio (P2/P1) to the screen of the HP9000. This was implemented using two 100 PSID

transducers, multi-port signal conditioner, a Digital Voltmeter (HP3455A), Data Acquisition/Control Unit (HP3497A) and the HP9000 Series 300 Computer. The HP9000 provided program control for the controller and the voltmeter. Details on the programming of these devices are contained in Reference 14 and 15.

c. NF90 Stepping Motor Controller/Unislide Motor Driven Assembly

The VELMEX Stepping Motor Controller and the UNISLIDE Motor Driven Assembly provided a fully programmable and highly precise traverse mechanism. The NF90 Stepper Motor Controller could operate in a "stand alone" mode or an "interactive mode". A three wire serial RS-232C port allowed the host controller to enter commands and data, poll for status and read position information. It was capable of operating up to three stepper motors as well as being daisy-chained with multiple NF90's. It had a 400 step (0.9 degree) resolution, which equated to a 0.025 inch linear resolution for the lead screw that was used. Other features of interest in the present study were its programmable baud rate, speed control, poll for status, and return to zero position commands. Further details concerning the NF90 Stepping Motor Controller are contained in Reference 16. Though provided with IBM compatible controller software it was fully compatible with the HP9000 equipped with an RS-232C port. The serial port used was separate from the port used for the CALSYS2000 and was made available by installing the Asynchronous Serial Interface (HP98644A) expansion card into the HP9000 [Ref. 17].

The UNISLIDE Motor Drive Assembly was model number MB2509P40J with a Bodine #2010 (2410) Drive Motor. A precision roll-formed lead screw held by

preloaded ball bearings drove a low friction, adjustable anti-backlash nut. The lead screw provided in the model P40J allowed capabilities outlined in Table II. Installation and maintenance instructions for the VELMEX UNISLIDE are contained in Reference 13. The NF90 and UNISLIDE are shown in Figure 17.

Table II. UNISLIDE LEAD SCREW PARAMETERS

UNISLIDE Lead Screw	Advance/ Revolution	Advance/ Step	Speed at 1000 Steps/Second
P40,C	0.025 inches	0.0000625 inches	0.0625 inches/second




Figure 17. NF90 and VELMEX UNISLIDE

2. Data Acquisition and Analysis Programs

a. *The Data Acquisition Program "SCAN_ZOC_06"*

Program "SCAN_ZOC_06" was developed to provide the data acquisition options shown in Table III. The program was an adaptation and extension of the "SCAN_ZOC_05" program developed by Wendland [Ref. 12]. The extensions involved adding commands to provide continuous monitoring of the cascade pressure ratio prior to acquiring data with the ZOC system and commands to control the probe traverse. The development and description of the new software, program listing and operating manual are given in Appendix C.

Table III. SCAN TYPES AVAILABLE

Scan Type	Purpose	Options	Comments
0	Single Scan of all ZOC's	Number of Samples up to 1021	Original SCAN_ZOC_05 operation
1	Multiple Scans of all ZOC's	Number of Samples Avail. based on 1021/#Scans	Allows multiple Successive Observations
2	Probe Survey of Lower Blade	Scans = 33 Samples = 10	Parameters "hard wired" to avoid probe damage
3	Probe Survey of Middle Blade	"	"

b. The "READ_ZOC2" Data Reduction Program

The "READ_ZOC2" program was an adaptation of the "READ_ZOC" utility program given in Reference 12. The previous version was developed to examine ZOC data to verify the ZOC-14 DAS performance. The current version was specifically developed to analyze data taken from the Transonic Cascade Wind Tunnel. "READ_ZOC2" converted the acquired ZOC voltage data to pressures in psia. It provided a print out of data indexed to each port and scan taken, saved pressure data to an ASCII file, plotted surface pressures normalized by inlet total pressure versus percent of chord, plotted displacement versus probe survey pressure and calculated the mass averaged loss coefficient. This program is listed in Appendix D. Output from this program is shown in Appendix E and referred to in Chapter III.

III. EXPERIMENTAL PROGRAM AND RESULTS

A. EXPERIMENTAL PROGRAM

The program of tests is summarized in Table VI. After initial tests to verify the probe and traverse mechanism, and data acquisition and control program operation, probe and surface pressure measurements were acquired with the model at design incidence and with incidence increased by 2 degrees. The latter condition was found to give similar shock patterns in the upper and lower passages at the design pressure ratio. Useful test data are given in Appendix E.

1. Initial Tests

Eleven preliminary tests were conducted with the model set at the design incidence. The shadowgraph system was adjusted optimally and experience was gained in operating the back pressure control valve to position the passage shocks in the model. Data acquisition procedures using the ZOC-14 DAS were exercised and verified by comparing with measurements reported in Reference 8. Also, multiple scans of blade surface taps revealed less than 1% uncertainty (see Figure E1, page 124). When shocks were positioned and data were taken, the pressure ratio across the blading was approximately two. The probe and traverse proved to be very rigid and no noticeable vibrations could be sensed external to the test section. The traverse was programmed to step 32 times and a probe measurement was recorded at each stop. At each stop, during a pause of one second, all 32 ZOC pressure ports were scanned ten times. One minute and

13 seconds were required to complete the traverse. Surveys were conducted at the exit of the lower passage while using the instrumented lower blade to provide surface static pressures across the passage normal shock. This shock was placed at the "design" location using a pressure ratio of approximately 2.04. Observation and measured data revealed that no significant disturbances or additional unsteadiness of the shock structure was present during probe surveys. Four such surveys were completed and a representative data set, together with a sample data reduction, is given in Appendix E.

2. Probe Surveys at Design Incidence (1.15 degrees)

Seven tunnel runs were conducted to survey across a full passage centered on the middle blade. The cascade was operated at a pressure ratio of approximately 2.14, at which the upper passage normal shock was located at the "design" location and the lower passage shock was slightly ahead of this location. The two shocks were within ten percent of chord of the same axial location on the blade suction surface. A typical data set is given in Appendix E. These and all subsequent surveys were taken at one inch downstream of the blade trailing edge.

3. Probe Surveys at -0.85 Degree Incidence

Five tunnel runs were conducted to examine various off-design incidence angles. The cascade model was rotated such that the incidence to the suction surface was varied by plus or minus 2 degrees. The setting which resulted in a suction surface incidence of -0.85 degrees caused the upper and lower passage normal shocks to move into approximately the same position within the passage at the same pressure ratio. Rotation in the opposite direction (increased incidence) had the opposite effect. Two

complete center blade surveys were conducted at -0.85 degrees incidence to examine the changes in the losses as well as in the blade surface pressure distributions. A set of survey data is given in Appendix E together with sidewall pressure measurements. Shadowgraph photographs of the flow at -0.85 degrees using continuous and spark light sources are shown in Figures 18 and 19 respectively.

TABLE IV. EXPERIMENTAL PROGRAM

Date	Runs	Measured	Purpose	Appendix E pages
4 Nov 92	1-4	Plenum, P2/P1, Blade Surface Static	DAS Testing	
6 Nov 92	1-7	Plenum, P2/P1, Blade Surface Static	DAS Testing	
16 Nov 92	1-4	Plenum, Impact P2/P1, Blade Surface Static	DAS/Probe tests and Preliminary Data	1-7 (Run 3)
19 Nov 92	1-5	Plenum, Impact P2/P1, Blade Surface Static	Center Blade Survey at Design i_{ss}	8-14 (Run 4)
25 Nov 92	1-5	P2/P1, Blade Surface Static	Vary i_{ss}	
1 Dec 92	1-2	Plenum, Impact P2/P1, Blade Surface Static, Plenum Temperature	Survey Center Blade at Off-Design $i_{ss} = -0.85$ deg	15-21 (Run 2)
7 Dec 92	1-3	Plenum, Impact P2/P1, Blade Surface and Side-wall Static, Plenum Temperature	Survey Center Blade at Off-Design $i_{ss} = -0.85$ deg	22-29 (Run 1)



Figure 18. Continuous Light Shadowgraph




Figure 19. Spark Light Shadowgraph

B. EXPERIMENTAL RESULTS

1. Measurements at Design Incidence

The suction surface pressure distribution at a pressure ratio of 2.04, normalized by inlet total pressure, is shown in Figure 20. A very gradual expansion is seen as the flow approaches the shock-interaction region. The interaction is centered at approximately 40% chord and steady diffusion continues toward the trailing edge of the blade. It is significant to note that pressure ratios used to place shocks in the upper and lower passage (2.04 and 2.14 respectively) at design incidence did not change with the installation of the probe and the suction surface static pressure distribution was unaffected by the probe movement. At design incidence, shocks could not be positioned in the same location on the blade suction surface in the two passages. The upper passage normal shock was positioned in the design location (approximately 40% chord) at a pressure ratio of 2.14. The lower passage shock was then centered at 30% chord as determined by the surface pressure measurements. The lower blade surface pressure distribution at a pressure ratio of 2.14 is shown in Figure 21.

The loss distribution resulting from the probe survey conducted downstream of the center blade at a pressure ratio of 2.14 is shown in Figure 22. Exit static and plenum pressures during the probe survey are shown (dashed lines) with the impact pressure measurements against displacement. The shock losses experienced in the upper passage are higher than those experienced in the lower passage. The increased losses may be due to the lower passage normal shock which is now forward of the center blade leading edge. In addition, a slight reduction in loss is present just above the wake region, which




Figure 20. Lower Blade Surface Pressure Distribution ($P_2/P_1 = 2.04$)




Figure 21. Lower Blade Surface Pressure Distribution ($P_2/P_1 = 2.14$)




Figure 22. Loss Distribution at Design Incidence (1.15 degrees)

may be attributed to the shock-boundary layer interaction. This effect was also present in the lower passage (see Figure E1). The wake is mixed out to some degree as revealed by the level of the test section exit static pressure. The mass averaged loss coefficient, calculated by integration of the distribution across one blade space, was 0.10065 for the design incidence.

2. Measurements at -0.85 Degree Incidence

As can be seen by the shadowgraph photographs in Figure 18 and 19, the passage normal shocks were in approximately the same location in the two passages at a pressure ratio of 2.14. The lower blade surface pressure distribution and an upper passage sidewall pressure distribution are shown in Figures 23 and 24 respectively. These




Figure 23. Lower Blade Surface Pressure Distribution (-0.85 degrees)




Figure 24. Middle Blade Side Plate Pressure Distribution (-0.85 degrees)

data indicate that the shocks differed in position by no more than 2% of chord. The blade surface pressure distributions for the design cases showed a small acceleration prior to the shock interaction region. At the negative incidence, no such expansion is apparent. Also, the level of pressure prior to the shock in this case is 5-10% higher than for the design incidence, suggesting the presence of an oblique shock at the blade leading edge. Though the flow is eventually diffused to the same pressure in both cases, in the reduced incidence case the shock interaction region is reduced in length. The reduced incidence case shows the shock pressure rise occurring over approximately 15% of chord compared to 30% of chord at design incidence. This is consistent with having a lower Mach number at the shock (higher pressure) and a reduced region of separation and associated lambda structure.

The impact pressure survey shown in Figure 25 indicates that the wake was shed at a higher vertical location, as should be the case since the higher incidence was arrived at by rotating the test section. Shock losses for the two passages were closer to the same value and losses were in fact less overall for this incidence. The mass averaged loss coefficient for this case was calculated to be 0.07393. The loss distribution just above the wake (from the lambda interaction on the suction side) appears in Figure 25 to be quite similar to the design incidence case in Figure 22, but the passage shock loss above this interaction is not as uniform.




Figure 25. Loss Distribution at Off-Design Incidence (-0.85 degrees)

IV. NUMERICAL SIMULATION

A. GRID GENERATION

The numerical simulation was carried out on a C-grid generated with the GRAPE grid generation program. GRAPE (GRids about Airfoils using Poisson's Equation) was written by Sorenson [Refs. 18, 19] and revised by Chima [Ref. 20] to accommodate periodic cascades for turbomachinery. A flow solution was obtained on a grid of 250 x 49 points generated by Golden [Ref. 8]. This grid was non-dimensionalized for use in the latest version of the flow solver. The grid is shown in Figures 26 through 28. The existing grid has been optimized for this particular flow regime by adding more points at the leading and trailing edges and a finer grid at the walls to improve resolution of shocks and boundary layers.

B. COMPUTATIONAL SCHEME

1. The Solution Method

The numerical scheme used was RVCQ3D (Rotor Viscous Code Quasi-3D) developed by Roderick Chima at NASA Lewis Research Center in Cleveland, Ohio. RVCQ3D was specifically designed for the analysis of blade to blade flows in turbomachinery [Ref. 21]. The code is an explicit multistage Runge-Kutta scheme which solves either the Euler or Navier-Stokes (thin-layer) equations and features the following:




Figure 26. Viscous Grid




Figure 27. Viscous Grid Leading Edge




Figure 28. Viscous Grid Trailing Edge

- A spatially varying time step
- Second and fourth order artificial viscosity
- Implicit residual smoothing
- An ideal gas assumption
- A Baldwin-Lomax or Cebeci-Smith turbulence model
- Stream tube variation
- Rotation effects

A thin layer approximation is employed such that derivatives in the streamwise direction are dropped while calculating viscous derivatives. The Baldwin-Lomax turbulence model was used in all calculations. The code uses an initial guess and time marches to a steady-state solution. The code is second-order accurate in space due to central

differencing and has been used up to a fifth-stage Runge-Kutta format providing fifth-order accuracy in time. All calculations herein were completed using a four-stage scheme. Version 3.7 of the code was used for the most current work. This version allows for almost completely dimensionless inputs and provides a powerful restart capability. This version was updated by Dan Tweedt of NASA Lewis [Ref. 22]. A complete mathematical description of RVCQ3D is contained in Reference 23 and a comparison of this scheme to other multigrid codes is given in Reference 24.

2. RVCQ3D Inputs

In the current simulation only 2-D cascade flow effects with no rotation, were modeled. An adiabatic wall temperature boundary condition was imposed. Reynolds number based on chord length and total conditions was input using a total temperature of 520 deg R or 15 deg C. A Courant number of 4.5 was used and allowed convergence in 7000 iterations (5.78 hours on a Silicon Graphics Iris Indigo). Residual smoothing was increased as much as 100% above recommended amounts early in the solution and reduced to the recommended values as the solution converged. A ratio of outlet static pressure to inlet total pressure was required. It was initially set above design to accelerate placement of shocks and reduced to an approximate design value as the solution converged. Further details concerning RVCQ3D inputs are contained in Reference 21. The restart capability now included in RVCQ3D allowed optimization of the quantities previously discussed, which saved time and improved performance. A sample RVCQ3D input file listing and a summary of restart inputs used to obtain the solution is contained in Appendix F.

C. COMPUTATIONAL SOLUTION

1. Summary of Previous Numerical Results

An "unsteady" solution was obtained by Golden [Ref. 8] in 4000 iterations. In this solution the "normal shock merges with the leading edge bow shock on the pressure surface and with the turbulent boundary layer on the suction surface." [Ref. 8] The lambda foot was not predicted, but some increase in boundary layer thickness was present. Boundary layer transition was predicted to be at ten percent chord and the flow incidence angle to the suction surface was predicted to be 2.53 degrees. (design incidence was 1.15 degrees) The results were "unsteady" because the convergence history showed that residuals increased late in the solution process and a steady state solution was not realized.

2. Current Numerical Solution

The inputs to the code represented conditions in the test section that gave a Reynolds number of about 8 million, and a nominal back pressure was specified ($P_2/P_{t1} = 0.7$). The inlet Mach number was set at 1.4 and the inlet flow angle to the "machine" axis (normal to the leading edge plane) was set for the design incidence case of 56.49 degrees. A constant CFL of 4.5 was used. The shock system was moved to the "on-design" condition by increasing the back pressure to about 0.76 of inlet stagnation pressure. The convergence history in Figure 29 shows a three order of magnitude drop in RMS density residuals in 7000 iterations. Other solution outputs such as incidence angle, Mach number, continuity and energy conservation are summarized below in Table V.




Figure 29. RMS Density Residuals

TABLE V. SUMMARY OF SOLUTION OUTPUTS

Quantity	Inlet	Exit	Global	Comments
Mach Number	1.378	0.633		For M_1 guess = 1.4
β (deg)	57.518	52.609		For $i_{ss} = 2.178$
Loss Coefficient			0.1123	Mass Averaged
Mass Conservation			-0.0011	$1 - \dot{M}(\text{out})/\dot{M}(\text{in})$
Energy Conservation			0.00091	$1 - H_t(\text{out})/H_t(\text{in})$

3. Computational Results

a. Suction Surface Pressure Profile

The static pressure distribution given by RVCQ3D is shown in Figure 30.

The current solution predicted the suction surface shock interaction starting at 30% chord

extending to 55% chord. The flow expanded very slightly as it approached the interaction region, dipped after the shock induced compression and continued to subsonically diffuse across the remainder of the blade after the interaction region.




Figure 30. Blade Surface Pressure Distribution

b. Flow Separation

Separation was predicted at the leading edge, in the neighborhood of the shock and at the trailing edge. Figure 31 shows the skin friction coefficient distribution and Figure 32 shows the boundary layer in the normal shock region. Transition to turbulent flow was predicted to occur at about 5% chord. Flow detachment was predicted at 38% and reattachment at 45% chord. This separation was associated with the shock-boundary layer interaction. The trailing edge separation was predicted to start at 99% chord and was caused by the adverse pressure gradient caused by further

diffusion through the passage. The leading edge separation "bubble" was confined to very few points. Figure 33 shows a particle trace at the location of the shock induced separation. It shows a very flattened separation region which is a function of the turbulent shock-boundary layer interaction, but may also be caused by the inadequate boundary layer resolution afforded by the Baldwin-Lomax turbulence model.




Figure 31. Skin Friction Coefficient Distribution (x1000)




Figure 32. Velocity Profile at Shock Induced Separation




Figure 33. Particle Trace at Shock Induced Separation

c. Shock Resolution

Mach number contours are shown in Figure 34. The normal shock merges with the leading edge bow shock on the pressure surface causing the attendant separation bubble previously described. This configuration is similar to that observed in the experiment and would appear to be the "design condition".




Figure 34. Mach Number Contours

d. Loss Calculation

RVCQ3D predicted a mass averaged loss coefficient of 0.1123. This prediction will be compared to mass averaged losses calculated from experimental data as well as with a currently accepted empirical loss model.

V. DISCUSSION OF RESULTS

A. BLADE SURFACE PRESSURE DISTRIBUTIONS

The experimental and computational results for the surface pressure distribution on the blade suction side are shown in Figure 35. The numerical solution predicts the interaction region to be located about 2% chord upstream of where it was measured to be at the design incidence. The experimental results show a somewhat reduced Mach number upstream of the shock interaction and the shock induced compression does not reach the same peak value downstream as is shown in the numerical solution. However, the slope of the pressure rise in the interaction region and in the subsonic diffusion after the shock-boundary layer interaction compare favorably in the two simulations. It should be noted that the computational scheme generates a solution for what the inlet flow angle should be for the specified inlet Mach number (to allow periodic conditions through the cascade geometry). Thus the inlet air angle for the computation was 57.656 degrees, whereas it was 56.49 degrees in the experiment. Also, the outlet static-to-inlet total pressure was 0.704 in the computation and 0.68 in the experiment. A further difference between the experiment and computation was the unavoidable presence of side-walls in the experiment. While the RVCQ3D code has provisions for streamline contraction, in the experiment, determination of streamline contraction was not possible with the presently available instrumentation.

At the -0.85 degree incidence (an inlet flow angle of 54.49 degrees), which is further from the angle output by the computational solution than the design setting, the slope of the pressure rise across the shock is higher than for the design case. The sharper rise is followed by a near plateau through the passage throat and then a steeper rise over the curved surface. Since the pressure ahead of the shock is higher, corresponding to a lower Mach number, the steep rise through the shock suggests less or even the absence of separation. This contrasts with the design incidence case, at which the shock pressure rise (and interaction) is spread over 30% chord. The significant difference between the boundary layers entering the subsonic diffusion passage in the two cases, as deduced from the wake measurements, could account for the different rate of pressure rise.




Figure 35. Surface Pressure Distributions

B. CASCADE LOSS ESTIMATION

Mass-averaged pressures and losses derived from probe surveys are summarized in Table VI. It was of interest to compare these loss values with the predictions of current loss models, and with the losses predicted by the numerical simulation.

TABLE VI. MASS AVERAGED QUANTITIES AND LOSSES

Case	Pt1ma (psia)	Pt2ma (psia)	Pt1-P1 (psia)	Ttave (deg R)	ω_{ma}
Design	54.334	50.612	36.983	511	0.1006
Off-design	54.204	51.478	36.865	507.5	0.0739

The Koch and Smith method [Ref. 25] was selected since it was recommended in a recent review sponsored by AGARD [Ref. 26]. This empirical method can provide an estimate of the design point efficiency potential of a multistage compressor, taking into account viscous loss, shock and leading edge bluntness losses as well as end-wall and part-span shroud losses. The intent here was to use only the relevant parts of this model, inputting experimental conditions and estimating those unavailable from the data. A sample calculation is contained in Appendix G. Only profile, shock and leading edge bluntness losses were appropriate for the present cascade flow. Both the design and off-design incidence cases were examined. Deviation angle was estimated using Equation 3.5 of Reference 25 in combination with Figure 160 of Reference 27 and by using Equations 268 and 269 of Reference 27. Table VII gives the inputs (and their sources) to the loss calculation and the predicted losses.

TABLE VII. LOSS MODEL INPUTS AND PREDICTED LOSSES

Parameter	Design	Off-design	Comments
Modified Carter Deviation (deg)	2.48	2.48	Based on Stagger Angle (used in loss estimate)
NASA SP-36 Deviation (deg)	2.11	2.07	Function of β_1 , Solidity, Shape and Thickness
Inlet Flow Angle β_1 (deg)	56.49	54.49	Set in Test Section to 0.1 Degree
Outlet Flow Angle β_2 (deg)	49.402	49.402	Function of Metal Angle and Deviation
Average Outlet Velocity V_2 (ft/sec)	717.183	753.384	Based on Measured Pt2, P2 Tt1
Average Inlet Mach Number M_1	1.389	1.387	Based on Pt1, P1
Momentum Thickness to Chord θ_c	0.00656	0.00525	Corrected for Equivalent Diffusion, M_1 and Surface Roughness
Trailing Edge Form Factor H_{TE}	2.414	2.229	"

(TABLE VII. is continued on the next page)

TABLE VII. (continued)

Parameter	Design	Off-Design	Comments
Shock Inlet Mach Number	1.4	1.36	Based on Surface Pressures
Profile Losses	0.02608	0.0225	
Normal Shock Losses	0.065	0.05	Based on Shock Inlet Mach number
L.E. Bluntness Losses	0.00855	0.0081	
Loss Coefficient	0.0996	0.0806	

A summary of the losses obtained by measurement, by the application of the Koch and Smith method and from the numerical simulation, is provided in Table VIII. There is seen to be a reasonable agreement between the measurements and the Koch and Smith model at both incidence angles. The slightly higher loss from the numerical simulation is consistent with there being a slightly higher Mach number at the shock.

TABLE VIII. COMPARISON OF LOSS ESTIMATES

Case	Measured	Koch and Smith	Numerical
Design	0.1006	0.0996	0.1123
Off-Design	0.0739	0.0806	

VI. CONCLUSIONS AND RECOMMENDATIONS

In the present study, the losses due to the shock-boundary layer interaction in a simulated fan blade passage were measured at design and one off-design flow angle. The results were compared with the losses predicted using the Koch and Smith loss model. Also, numerical results were obtained using a 2-D thin layer Navier-Stokes flow solver for blade-to-blade flows. Both surface pressure distribution through the interaction and losses predicted by the code were compared with the experimental results. A new data acquisition system and programmable probe and traverse system were implemented to obtain the measurements.

The following conclusions were drawn:

- ♦ The new data acquisition system was very successful and provided repeatable and accurate measurements. This was determined by comparing pressure levels to those measured in Reference 8 and by examining multiple scans of blade surface pressures.
- ♦ The new probe and traverse mechanism provided precise positional accuracy and pressure survey measurements
- ♦ As the back pressure was increased at the design incidence (a suction surface incidence of 1.15 degrees) the lower passage shock entered the cascade first and could be placed no closer than 10% chord to the upper passage shock.

- ♦ At a suction surface incidence of -0.85 degrees the upper and lower passage shocks were placed at approximately the same location at the same pressure ratio ($P_2/P_1=2.1$).
- ♦ At design incidence angle, blade surface pressures showed the shock-boundary layer interaction to be spread over 30% of chord. The slopes of the early shock compression and subsonic diffusion compared favorably with numerical predictions.
- ♦ At the reduced incidence angle blade surface pressures revealed a reduced Mach number prior to the shock, steep shock compression and a pressure plateau for 25% chord followed by a more rapid pressure rise over the back of the blade. The absence of significant separation would explain this change in behavior.
- ♦ Mass averaged losses were calculated from impact pressure measurements for both incidence angles and compared to predictions using the Koch and Smith loss model. The results compared favorably and each gave a twenty percent reduction in losses at the reduced incidence angle.
- ♦ The loss measurements at design incidence angle compared reasonably well with those given by the computational simulation.

Conclusions concerning the numerical simulation are:

- ♦ The flow solution is highly grid dependent. Repeated attempts to increase grid size to obtain more precise viscous solutions resulted in shock patterns, incidence angles and losses that did not reflect reality.
- ♦ The current numerical solution, using the latest version of RVCQ3D, predicted separation in the shock-boundary layer interaction region. It also predicted a small separation bubble on the leading edge and a slightly larger separated region at the trailing edge. On a similar grid, using the previous version of the code, separation was not predicted.
- ♦ The new version of the code demonstrated more rapid convergence on the present geometry than was observed previously with the earlier version. Placement of

shocks at a desired location could be accelerated by slightly increasing back pressure above anticipated levels. The restart feature in the present code is a very powerful aide in obtaining solutions.

The following recommendations are made concerning the apparatus and instrumentation:

- ♦ Obtain an additional CALMOD 2000 such that lower pressure (15PSID) ZOC-14 scanning modules can be calibrated concurrently with higher pressure (50PSID) modules, but with equal accuracy.
- ♦ Expand the ZOC-14 DAS to enable more test section pressures to be measured in one test.
- ♦ Acquire pressure data from the instrumented side plates ahead of the test section to more fully examine the upstream flow as incidence angle is changed.
- ♦ Systematically replace all model sections exposed to the flow with parts made of harder steel since erosion due to contamination is severe.
- ♦ Do not exceed plus or minus two degrees of rotation from the design incidence because of potential damage to the lower blade pressure tubing.
- ♦ Design a three sensor pressure probe for the present traverse apparatus and calibrate it to return Mach number and pitch angle.

Based on the understanding gained in the present program, the following steps are proposed to achieve the stated goals of the project:

- ♦ Verify the absence of separation at the negative incidence using a surface injection technique.

- ♦ Experiment with "tailboards" to achieve similar flows (with separation) within the two passages at positive flow incidence angles.
- ♦ Obtain reference blade wake surveys at selected incidence angles using displacement increments of $1/32$ inch (currently $1/16$).
- ♦ Install a center blade with VGJ's and repeat the surveys with flow visualization.
- ♦ Install Wheeler Doublets on the lower and center blade (separately and then together), and repeat the surveys with flow visualization.
- ♦ Evaluate the results.

APPENDIX A. WIND TUNNEL INSTRUMENTATION




Figure A1. Side Plate Instrumentation (Right Side)




Figure A2. Window Blank Instrumentation (Left Side)

Lower Blade Pressure Tap Locations




Figure A3. Lower Blade Instrumentation

APPENDIX B. PROBE AND TRAVERSE DESIGN




Figure B1. Probe Traverse Assembly Drawing





Figure B2. Probe Traverse Assembly Drawing



22-144 100 SHEETS
 22-144 200 SHEETS

Figure B5. Sliding Block (Bottom View)




Figure B7. Probe Mounting Block




Figure B8. Traverse Mounting






Figure B8. Traverse Mounting (Auxiliary View)



EXISTING TRAVERSE
MECHANISM
(PROVIDED AS NEC.)
DAVID D. MYRE
NO SCALE
DWG. # : 9
DATE :

Figure B9. VELMEX UNISLIDE






Figure B10. Probe and Probe Holder (Rear View)

22-141 30 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS





Figure B12. Plumbing Detail

APPENDIX C. ZOC-14 DAS SOFTWARE DEVELOPMENT

1. Data Acquisition Program SCAN_ZOC_05

The ZOC-14 DAS software development integrated the ZOC-14 modules, CALSYS2000 and the HP6944A Multiprogrammer with the HP9000 series 300 Desktop Computer System and the HP6944A Computer Aided Test (CAT) software package. All programming was done in HP BASIC version 5.13. The HP6944A CAT software package provided software and documentation to configure and operate the HP6944A Multiprogrammer. This package formed the framework around which the main program, "SCAN_ZOC_05", was written. The CAT software provided routines which allow the programmer to integrate the operation of individual Multiprogrammer cards into powerful data acquisition tools. The A/D cards and Memory cards have been combined to operate as a data buffer and the Pacer and Counter cards combined to operate as a timer. The buffer stored raw strain gauge voltages in extremely fast RAM during acquisition and thus did not require transfer to the HP9000 RAM and finally to disk until the data run was complete. The timer function provided a square wave pulse at a prescribed pulse width and number of repetitions. The pulse width determined the scanning frequency and the number of repetitions (always a multiple of 32) determined the number of samples taken per scan of the 32 ZOC ports. The program generated three files for storage of raw data (prefix "ZW"), calibration data (prefix "ZC") and reduced data (prefix "ZR"). The files were labeled by the program in a fashion that is very useful

as illustrated below. With its file management system, multiple data runs could be



completed without stopping to reduce the data until tunnel operations were complete. The program made use of multiple subprograms and user defined functions for repetitive tasks affording a "top down" program structure. Further details on "SCAN_ZOC_05" program development are contained in reference 12.

2. Modified ZOC-14 DAS Software ("SCAN_ZOC_06")

"SCAN_ZOC_05" was modified to provide continuous monitoring of cascade pressure ratios prior to data acquisition, operate a probe traverse for cascade surveys and conduct a complete scan of all ZOC's at each new probe position. This version of the program was designated "SCAN_ZOC_06". The purpose of this section is to document modifications to the original program. The new program listing is contained in Figure C1. An updated operating procedure for the system including hardware interface is also contained in Appendix C. Changes from the previous operational procedures found in reference 12 are indicated.

The initial setup routine was modified to include options available in the new version of the program. These included the current day atmospheric pressure and the type of scan or "scan type". The options are illustrated below in Table III. The program is menu driven with additional user inputs clearly prompted by the program.

Other selections which include the frequency of data acquisition, ZOC's to be operated and CALMOD utilized have been retained.

Table IX. SCAN TYPES AVAILABLE

Scan Type	Purpose	Options	Comments
0	Single Scan of all ZOC's	Number of Samples up to 1021	Original SCAN_ZOC_05 operation
1	Multiple Scans of all ZOC's	Number of Samples Avail. based on 1021/#Scans	Allows multiple Successive Observations
2	Probe Survey of Lower Blade	Scans = 33 Samples =10	Parameters "hard wired" in to avoid probe damage
3	Probe Survey of Middle Blade	"	"

The operation of the Transonic Cascade Wind Tunnel required knowledge of the pressure ratio across the test section prior to data acquisition. A routine was adapted from the program "SCAN" listed in reference 8 to provide a continuous display of the inlet (P1), exit (P2) and exit to inlet pressure ratio (P2/P1). The routine initialized both the HP3497A Data Acquisition/Control Unit and the HP3455A Digital Voltmeter. It then repetitively commanded the HP3497A to set the correct signal conditioner port and triggered the voltmeter to read the voltage across the transducers connected to the signal conditioner. It input this data to variables, scaled them appropriately and printed out the two pressures in psia followed by the P2/P1 ratio. This process began upon pressing the function key F4 which initiated the "Data Preps" routine. Prior to the start

of the continuous cascade of pressure ratios the probe traverse moved to its initial position (if "scan_type" was greater than 1) and the CALMOD was initialized.

Routines to operate the NF90 Stepping Motor Controller were added to the software such that a probe mounted on the VELMEX UNISLIDE Motor Driven Assembly could be initially positioned prior to taking data, survey behind a cascade passage and finally return to its original position. As mentioned above the NF90 would be placed on line and the probe would move to its initial position during the "Data Preps" phase of ZOC operations, provided a scan type of 2 (Lower Blade) or 3 (Middle Blade) was chosen. When the cascade pressure ratio was at the appropriate value the function key F5 was pressed to begin collecting data. After each scan (after the subprogram "Scan_zocs" was called) was completed the subroutine "Traverse" was called which stepped the traverse a preset linear distance that was "hard-wired" into the program (a program edit was required to change this parameter) to avoid inadvertent damage to the probe. The probe moved after each pressure measurement, but ceased to move after the final measurement. The system completed 33 scans causing the probe to move 32 times at 0.0625 inches each time for a total of two inches traversed. More detailed surveys could be completed by changing the number of steps per scan (currently 1000) to a smaller value. After pressure measurements were completed another routine included in the "Collect Data" phase of the program moved the probe back to its starting position out of the flow and placed the NF90 off-line. A summary of the ASCII commands transmitted to the NF90 via the serial RS-232C port is provided in Table IV.

Table X. NF90 COMMANDS USED IN SCAN_ZOC_06

Command	Definition	Purpose	Comments
"FN"	On-line & Zero Motors	Place NF90 on-line	Used at the beginning of traverse ops
"Q"	Quit	Take NF90 off-line	Used at the completion of traverse ops
"C"	Command	Alerts NF90 to new command	Used at the beginning of each command
"S1M1000"	Speed of Motor One at 1000 Steps/Second	Set motor speed	1000 steps/sec is the optimum speed of operation
"I1M1000"	Index Motor One 1000 steps	Moves UNISLIDE 1000 steps	500 steps is equivalent to 1/32 inches

In making first time probe surveys in the Transonic Cascade Wind Tunnel, measurements were required to determine the significance of disturbances caused by the probe itself. The procedure was modified so that it was possible to measure a portion of the cascade pressure field at each survey point. "SCAN_ZOC_05" was modified such that it would perform one scan of all ZOC's for each new position of the probe. This required the addition of the traverse routines described above and the modification of the following routines listed in Table V. These changes essentially added a "global loop" around the entire acquisition process (with the exception of the transfer of data to the HP9000, gathering of calibration data and final data reduction) thus enabling the system to scan all ZOC pressure ports, including the port reserved for the probe, multiple times

while still taking multiple samples. These operations were limited by the HP6944A buffer space such that the number of scans times the number of samples times 32 ZOC ports had to be less than 32,672.

Table XI. ROUTINES MODIFIED IN SCAN_ZOC_O6

Routine	Purpose	Modifications	Comments
Initialize_spac	Initializes variables	1. Added parameter "Itrav" for total number of scans/traverse points 2. Added one column to "Zoc_cal" arrays for storage of additional program inputs	See "Collect_data" for more on "Itrav"
Key_menu	Prints ZOC operating menu	1. Changed "F4" selection to "Final Checklist and P2/P1 Cascade"	
Input	Provides Program inputs	1. Added input for Atmospheric Pressure and Type of scan desired. 2. Replaced LIF Hard Drive selection with LIF Floppy Drive for data storage	Inputs stored in Zoc_cal array and Cal file in "Initial_cal"
Data_prep	Initializes CALMOD and probe traverse and prints out pressure ratio	1. Added routine to preposition the probe traverse depending on "Scan_type" selected in "Input" 2. Added routine that prints continuous cascade of pressure ratios (P2/P1)	"P2p1" routine starts after probe is in position.

(TABLE XI. is continued on the next page)

TABLE XI. (continued)

Routine	Purpose	Modifications	Comments
Collect_data	Scans ZOC's desired number of times	1. The variable "Iscan" is now passed to SUB "Scan_zocs" . When Iscan is greater than one the HP6944A buffer will not reinitiate such that data from all scans will be stored. 2. SUB "Traverse" is now called after each measurement and moves the probe vertically down at a set increment.	See SUB "Scan_zocs" for use of variable "Iscan" and also see SUB "Traverse"
		3. At completion of measurements a routine returns the probe to its initial position.	
Initial_cal	Initializes arrays necessary for storage of calibration data	1. Additional program inputs are now stored in "Zoc_cal" arrays for current data run. 2. New inputs included are "Scan_type", number of scans ("Itrav"), traverse "Increment" and atmospheric pressure. 3. Variable "Iscan" is reset to one so that buffers initiate for storage of calibration data.	All inputs are stored in the calibration file which is read later during data analysis.
Collect_cal_dat	Collects raw calibration data for each CALSYS pressure	1. Variable "Iscan" added to call of SUB "Scan_zocs". 2. Since Iscan reset to one the HP6944A buffer initializes to store calibration data only.	
Reduce_data	Reduces raw calibration and measured data	1. Replaced LIF Hard Drive option with LIF Floppy Drive .	SEE SUB "Raw_red_dat"

(TABLE XI. is continued on the next page)

TABLE XI. (continued)

Routine	Purpose	Modifications	Comments
View_files	Displays filenames from storage media	1. Replaced LIF Hard Drive option with LIF Floppy Drive .	
SUB Scan_zocs	Operates HP6944A for scanning ZOC's	1. Program passes additional variable "Iscan" . 2. Conditional "IF" statement skips reinitiating of HP6944A buffer if Iscan greater than one.	
SUB Traverse	Steps probe traverse a preset distance when "Scan_type" is greater than one	1. Increments for upper and middle blade survey can be varied with program edit. 2. Routine verifies probe movement complete by awaiting "^" character from NF90 Stepping Motor Controller.	Survey increment "hard-wired" into program to avoid probe damage
SUB Raw_dat	Collects raw data from memory for storage on disk drive	1. The number records read into the HP9000 memory and stored on disk drive were multiplied by the factor "Itrav". 2. CREATE BDAT, Input_iblock and CONTROL statements were affected.	"Itrav" is the total number of scans.
SUB Cal_dat	Stores calibration data on disk drive	1. Data file size and size of file buffer were increased to account for additional column in Zoc_cal array. 2. CREATE BDAT and CONTROL statements were changed.	Zoc_cal array size increased to hold amplifying information.
SUB Raw_red_dat	Loads raw data and cal data from disk, reduces data and stores on drive	1. Add outer loop to account for multiple scans now implemented. 2. Repetitively set read pointer to second element of each scan in raw data file.	

OPERATING THE ZOC-14 DAS PROGRAM

1. Start-up

- ♦ Turn on HP6944A, CALSYS2000, ZOC Enclosures, HP3497A, HP3455A, NF90, and HP9000.
- ♦ Verify traverse assembly is in correct position for desired survey if applicable. Also, ensure lead screw is lubricated to avoid motor stall.
- ♦ From main menu shown type F7 and set time and date in the following format: Time 10:25:45 (hours:minutes:seconds); Date 17 Dec 1992. If entries are correct enter "Y" when prompted.
- ♦ Type F2 to enter HP6944A directory menu.

2. Calibration

- ♦ From this menu type F2 again to calibrate individual transducers. 100PSID transducers 1 and 2 are on ports 0 and 4 of the signal conditioner. Set zero calibration and then range scale calibration using test pressure. Set range to one-half (1/2) actual test pressure for 100PSID transducers.
- ♦ Type an out of range value in calibration menu to reenter HP6944A menu.
- ♦ Type F1 to proceed to ZOC-14 Modules menu.
- ♦ Ensure the nitrogen gas supply is connected to the CALSYS2000 and 90 psi is set on the regulator.
- ♦ CALSYS2000 regulators: Set the high, medium and low pressure regulators over a range of pressures to be measured. If specific levels are known, set regulators close to those levels.
- ♦ **WARNING:** Do not over pressurize ZOC's that are not rated for the higher pressures such as the 15PSID ZOC's.
- ♦ CALSYS2000 verification: Select F4 from the ZOC Modules menu and verify pressure settings.

- ♦ **NOTE:** This should always be completed when the CALSYS2000 is first energized to ensure the RS-232C line is clear and ZOC's are initialized.
- ♦ Type F2 to return to ZOC menu.

3. SCAN_ZOC_06 Set Up

- ♦ Type F1 to load and run "SCAN_ZOC_06". **NOTE:** HP6944A must be energized to run this program.
- ♦ An introduction screen is displayed which indicates the program is waiting for a function key input. Function key options are listed at the bottom of the screen. Typing F1 displays the introduction screen again. Typing F2 will display a menu screen with same function key options listed at the bottom the screen.
- ♦ **NOTE:** Typing F4 or F5 at this time results in an error.
- ♦ Type F3 to supply set-up inputs to the program. All inputs are prompted and a list of these inputs is provided below:
 - a. Input atmospheric pressure in psia.
 - b. Select data storage drive (0 is HFS hard drive ":",700,0" and 1 is LIF floppy drive ":",700,1")
 - c. Select "Scan_type" as described in Table IX above. The number of samples available is determined by this selection.
 - d. Select the number of samples based on selection of "Scan_type".
 - e. Select the number of ZOC's (1-3) for recording data.
 - f. Select the CALMOD assigned to each ZOC by entering 1 or 2 when prompted. (currently only one is available).

4. Data Collection Preparations ("Final Checklist and P2/P1 Cascade")

- ♦ Verify nitrogen is supplied to CALSYS2000 at 90 psi.
- ♦ Verify wind tunnel is prepared for operation:
 - a. Back pressure valve is wide open.

b. Control air is supplied to the pneumatic regulator valve.

- ♦ **NOTE:** The next step is to type F4 for final preparations and checklist, but the outcome will vary depending on Scan_type selected.
- ♦ If Scan_type 0 or 1 is chosen, type F4 prior to commencing wind tunnel operations. This will provide a continuous display of tunnel pressure ratio.
- ♦ If Scan_type 2 or 3 is selected, type F4 just prior to opening tunnel inlet valve by coordinating with the operator. This will avoid placing probe in unsteady initial tunnel flow and save run time by positioning probe in an expeditious manner.
- ♦ **WARNING:** Probe motion is "hard-wired" into program. Ensure probe is positioned such that current settings will not damage the probe or traverse.

5. Data Collection

- ♦ When prompted, and when tunnel pressure ratio is at desired level, type F5 to commence data collection. The HP9000 will display "Collecting raw pressure data."
- ♦ The HP9000 will display "Raw data collection complete." and then store raw data to the disk drive selected. At this time the wind tunnel can be secured if desired. The HP9000 will also take and store raw calibration data at this time and display all filenames for raw data and raw calibration data storage.
- ♦ At this point there are several options available. Type F4 to repeat the previous data run. Type F3 to reset program set up. Type F6 to reduce the current day raw data, or F8 to exit program.

6. Data Reduction and File Listing

- ♦ Typing F7 will list all current day data files on the storage drive. The program prompts the user if copying files to the floppy drive (":,700,1") is desired.
- ♦ Type F6 to reduce current day raw data. It is recommended that all data be reduced the day it is taken.
- ♦ **NOTE:** Data reduction of large data files (multiple scans required for probe surveys) takes several minutes.

- ♦ Type F8 to exit the program and return to the ZOC menu.

7. Data Analysis with READ_ZOC2

- ♦ Typing F2 enters the program "READ_ZOC2" for data analysis.
- ♦ A menu is displayed with various choices for data analysis. Typing F1 prompts the user for the ZOC number, date (YMMDD) and run number from that day. It then prompts the user for the storage drive where this data is saved (must be the HFS hard drive or LIF floppy drive). This will read the reduced pressure and calibration data from the files generated by "SCAN_ZOC_06".
- ♦ **NOTE:** All other function key selections will result in an error before entering the ZOC data (typing F1).
- ♦ Functions available by typing the function key shown are as follows:
 - F1 Read ZOC data stored on disk drives
 - F2 Save pressure data array in psia to an ASCII file
 - F3 Print pressure data to CRT or printer
 - F4 Plot P/Pt and Mach number distributions and print out P/Pt and Mach number for multiple scans.
 - F5 Plot vertical displacement against probe pressures and calculate mass averaged losses.
 - F8 Exit READ_ZOC2
- ♦ **NOTE:** ASCII file size is "hard-wired" into the program and must be changed with a program edit.
- ♦ The program is currently configured to read the first 25 ZOC ports into the arrays for plotting surface pressure and Mach number distributions. Other distributions are possible with a simple program edit.


```

10  | Program: SCAN_ZOC_06
20  | by Richard Wendland
30  | modified for traverse operations by David Hyle
40  |
50  | Description: Application program to operate HP6944A collecting pressure
60  |               readings from 1-3 ZOC-14 32 port modules using the CALSYS
70  |               2000 to provide calibration data, reduce raw pressure data
80  |               and store data to the hard drive.
90  |
100 | Hardware:  (1) HP6944A Built-in processor
110 |             - (3) 500 Hz A/D Cards (HP69799A)
120 |             - (3) High Speed Memory Cards (HP69791A)
130 |             - (1) Timer/Pacer Card (HP69736A)
140 |             - (1) Counter Card (HP69775A)
150 |             (1) HIScan CALSYS 2000 Calibration Module
160 |             (3) ZOC-14 32 port Electropneumatic Pressure Sensing Modules
170 |             (4) VELNEX NF90 series stepping motor controller
180 |
190 | Notes: 1. This program utilizes up to three (3) Zoc Modules storing data
200 |         of each Zoc into a separate buffer memory system (HP69791A).
210 |         2. COM /Names/ line and BDAF file ZOC_CONF16_04 must match for
220 |         this program to operate.
230 |         3. CALSYS2000 requires a short period to stabilize before loading
240 |         the pressure valves. The Pause for statement sets (line 470) this
250 |         wait period in seconds. Adjustment of the variable may be required
260 |         as additional Zocs are integrated into the Data Acquisition System
270 |
280 |         4. CALSYS2000 currently configured for one (1) calibrator. This
290 |         program is written to operate one (1) or two (2) calibrators.
300 | Buffer Memory: 65536 16-bit data words in HP69791A per system
310 | Timer: Maximum 32676 counts for one HP69775A
320 | Max speed of HP system is Period=0.000002 sec. or 500 Hz.
330 |
340  COM /Issacom/ INTEGER X(1:1106)
350  COM /Issa_heap/ Issa_heap(1000)
360  COM /Names/ Buffer1,Adc1,Buffer2,Adc2,Buffer3,Adc3,Timer
370  Configure("Menu_off","ZOC_CONF16_05")
380  Configure("Ask_me","ZOC_CONF16_05")
390  |
400 Key_label: !----- KEY LABEL ASSIGNMENT -----
410  |
420  KEY LABELS ON
430  ON KEY 1 LABEL "Intro" GOTO Intro
440  ON KEY 2 LABEL "Key   Menu" GOTO Key_menu
450  ON KEY 3 LABEL "Set-up" GOTO Input
460  ON KEY 4 LABEL "Data   Preps" GOTO Data_prep
470  ON KEY 5 LABEL "Collect Data" GOTO Collect_data
480  ON KEY 6 LABEL "Reduce  Data" GOTO Reduce_data
490  ON KEY 7 LABEL "List   Copy" GOTO View_files
500  ON KEY 8 LABEL "Exit" GOTO Finish
510  |
520 Initialize_spac: !----- ASSIGN MEMORY SPACE -----
530  Pause_for=1.5 ! Wait time for CALSYS2000 stabilization
540  | COM assigns calibration data array for 32 Zoc ports and standard values.
550  COM /Zoc_dat/ REAL Zoc_cal1(33,11) BUFFER,Zoc_cal2(33,11) BUFFER,Zoc_cal3(
33,11) BUFFER
560  COM /Stats/ REAL Pulse,Sample_number,Pause_for,INTEGER Cal_mod_1d(3),Date$(
16),Run,Itrev
570  COM /Files/ Files$(1:99,1:9)(14),Data_drive$(1:24) !Data file & storage drive

```

Figure C1. Program "SCAN_ZOC_06"

```

580 |
590 DIM Command_mode$(1:7)(2)
600 Command_mode$(1)="NH"
610 Command_mode$(2)="NM"
620 Command_mode$(3)="NL"
630 Command_mode$(4)="ZO"
640 Command_mode$(5)="PL"
650 Command_mode$(6)="PM"
660 Command_mode$(7)="PH"
670 |
680 Run=0
690 Data_reduced=0
700 |
710 Intro: |----- INTRODUCTION SCREEN -----
720 |
730 CLEAR SCREEN
740 PRINT "Introduction. Program SCAN_ZOC_05:"
750 PRINT
760 PRINT " - Scans 1-3 Zoc-14 Modules simultaneously (32 pressure sensing po
rts each)."
```

770 PRINT " - Uses Zero Operate Calibrate (ZOC) principal:"	
780 PRINT " - Collects raw pressure data (Zero Operate)"	
790 PRINT " - Collects calibration data (Calibrate)"	
800 PRINT " - Reduces and stores data on selected hard or floppy drive."	
810 PRINT " - CALSYS2000 Calibration Module used for the reference pressure s	standard."
820 PRINT " - Raw pressure data reduced using calibration data from CALSYS200	0"
830 PRINT " and Zocs in the calibration mode."	
840 PRINT	
850 PRINT "Input variables: Hard and Floppy drive for data storage"	
860 PRINT " Sample frequency per port (1-50,000 Hz)"	
870 PRINT " Samples per Port (1-1021)"	
880 PRINT " Number of Zocs and their capacity"	
890 PRINT	
900 Note: HFS Files limited to 14 characters, LIF Files limited to 10 char.	
910 Output files have a length of 10 characters to support LIF files.	
920 Hard drive format is HFS Files.	
930 Floppy drive format is LIF Files.	
940 PRINT "Output files: Raw data => ZW(Zoc#)(Date YMMDD)(Run#)"	
950 PRINT " Calibration => ZC(Zoc#)(Date YMMDD)(Run#)"	
960 PRINT " Reduced data => ZR(Zoc#)(Date YMMDD)(Run#)"	
970 DISP "Select F2 key for Key Menu, F3 for system inputs, or F6 for data red	uction."
980 Hold:	
990 GOTO Hold	
1000	
1010 Key_menu: ----- KEY MENU -----	
1020	
1030 CLEAR SCREEN	
1040 PRINT "ZOC-14 Operating Menu."	
1050 PRINT	
1060 PRINT "Function	Function Key"
1070 PRINT	
1080 PRINT " Introduction	F1"
1090 PRINT " Operating Menu	F2"
1100 PRINT " System Set-up	F3"
1110 PRINT " Final checklist and P2/PI Cascade	F4"
1120 PRINT " Data Collection	F5"
1130 PRINT " Data Reduction	F6"
1140 PRINT " List Files (Copy files to Floppy)	F7"

Figure C1. (cont) Program "SCAN_ZOC_06"

```

1150 PRINT
1160 PRINT " Exit"
1170 I
1180 GOTO Hold
1190 I
1200 Input:----- INPUT VARIABLES -----
1210 I
1220 I Some array initialization and TIME DATE value
1230 I
1240 MAT Zoc_cal1= (0)
1250 MAT Zoc_cal2= (0)
1260 MAT Zoc_cal3= (0)
1270 MAT Filo$= ("")
1280 Date$=FNDate$(TIMEDATE)
1290 I
1300 I.....
1310 I The following provides inputs for current run.
1320 I.....
1330 I
1340 CLEAR SCREEN
1350 PRINT "System Set-up."
1360 PRINT
1370 INPUT "Input the Atmospheric Pressure in PSIA: ",P_atm
1380 I
1390 I Hard drive or LIF floppy selection
1400 I
1410 INPUT "Select Hard drive for storing data (0=:700 1=:700,1)",Drv
1420 IF Drv=0 THEN
1430 Data_drive$=":700,0"
1440 ELSE
1450 Data_drive$=":700,1"
1460 END IF
1470 I
1480 I Further inputs
1490 I
1500 INPUT "Enter data sampling rate (1-50Hz): ",Hz
1510 PRINT "Data acquisition rate:";TAB(50);Hz;" Hz"
1520 I
1530 I Input the type of scan made
1540 I
1550 Type_scan: I
1560 PRINT
1570 PRINT
1580 PRINT "Enter the type of scan desired."
1590 PRINT
1600 PRINT "0 for a single scan."
1610 PRINT "1 for a multiple scans."
1620 PRINT "2 for LOWER BLADE survey."
1630 PRINT "3 for MIDDLE BLADE survey."
1640 PRINT
1650 INPUT "The desired scan type is:",Scan_type
1660 PRINT "The scan type is:";TAB(50);Scan_type
1670 I
1680 I Selection of scan type routine
1690 I
1700 SELECT Scan_type
1710 CASE 0

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

1720     Itrav=1
1730     INPUT "Number of samples per port (1-1021): ",Sample_number
1740     PRINT "Number of samples per port:";TAB(50);Sample_number
1750     CASE 1
1760     PRINT "You have chosen the multiple scans option."
1770     PRINT "The number of scans chosen will determine the maximum"
1780     PRINT "number of samples per port as 1021/#scans."
1790     PRINT
1800     INPUT "Number of scans desired:",Itrav
1810     PRINT
1820     PRINT "The scans desired is:";TAB(50);Itrav
1830     PRINT "The max number of samples per port:";TAB(50);1021/Itrav
1840     PRINT
1850     INPUT "Number of samples per port: ",Sample_number
1860     PRINT "Number of samples per port:";TAB(50);Sample_number
1870     PRINT
1880     CASE 2
1890     Itrav=33
1900     Sample_number=10
1910     Increment=1000
1920     CASE 3
1930     Itrav=33
1940     Sample_number=10
1950     Increment=1000
1960     CASE ELSE
1970     BEEP
1980     PRINT "YOU DONE SCREWED UP PARD! TRY AGAIN!!"
1990     GOTO Type_scan
2000     END SELECT
2010     |
2020     |.....
2030     | ZOCs AND CALMOD COMBINATION UTILIZED
2040     |.....
2050     |
2060     INPUT "Number of Zoc's connected to Multi-programmer",Zoc_number
2070     PRINT "Number of Zocs to be scanned:";TAB(50);Zoc_number
2080     Cal_mod_id(0)=Zoc_number
2090     FOR Zoc_case=1 TO Zoc_number
2100     SELECT Zoc_case
2110     CASE 1
2120     Run=1
2130     CALL File(1)
2140     INPUT "Enter Calibration Module number set for Zoc #1 (Enter 1 or 2):"
2150     CASE 2
2160     Run=1
2170     CALL File(2)
2180     INPUT "Enter Calibration Module number set for Zoc #2 (Enter 1 or 2):"
2190     CASE 3
2200     Run=1
2210     CALL File(3)
2220     INPUT "Enter Calibration Module number set for Zoc #3 (Enter 1 or 2):"
2230     END SELECT
2240     NEXT Zoc_case
2250     |
2260     Period=1/HZ
2270     Pulse=Period/2                                |Pulse length of HP69736A trigger signal
2280     |

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

2290 PRINT "Total raw data acquisition time: ";IAB(50)/Itray*Period*Sample_number*316;" sec."
2300 PRINT "Total calibration data acquisition time: ";IAB(50)/Itray*Period*Sample_number*316*7*Pause_for_1;" sec."
2310 PRINT
2320 PRINT "Data storage disc = ";Data_device$
2330 PRINT "Data will be stored in the following files beginning with Run #";Run
2340 PRINT
2350 FOR I=1 TO Zoc_number
2360   J=(I-1)*3
2370   PRINT "Raw data file:           ";File$(Run,I*3)
2380   PRINT "Calibration data file:       ";File$(Run,I*3)
2390   PRINT "Reduced data file:           ";File$(Run,I*3)
2400   PRINT
2410 NEXT I
2420 I
2430 DISP "Select F4 key to begin data acquisition"
2440 GOTO Hold
2450 I
2460 Data_prep: I----- PREPARE FOR DATA COLLECTION -----
2470 CLEAR SCREEN
2480 PRINT "Data Collection Preparation."
2490 PRINT
2500 I
2510 I.....
2520 I  ERROR TRAP IF NO INITIAL PROGRAM SETTINGS COMPLETED
2530 I.....
2540 I
2550 IF Run=0 THEN
2560   PRINT "Program not initialized for data collection."
2570   DISP "Select F3 to initialize Setup"
2580   GOTO Hold
2590 END IF
2600 I
2610 I.....
2620 I  FINAL CHECKLIST PRIOR TO STARTING DATA RUN
2630 I.....
2640 I
2650 PRINT "Check list:"
2660 PRINT "  - HiScan CALSYS2000 on-line"
2670 PRINT "  - CALMOD supply line valve is OPEN (on back of CALSYS2000)"
2680 PRINT "  - CALSYS2000 (Nitrogen) pressure source at 90 psi"
2690 I
2700 I.....
2710 I  PLACING TRAVERSE IN INITIAL LOCATION HERE
2720 I.....
2730 I
2740 IF Scan_type<2 THEN Skip_traverse
2750 PRINT
2760 PRINT "  - The Probe traverse is now moving to its initial position."
2770 PRINT
2780 I
2790 DIM Travecmd$(1)
2800 Sc2=10                                (Select code for 2nd serial card)
2810 ASSIGN @Traverse TO Sc2              (Assign a path to the serial card)
2820 CONTROL Sc2,14130
2830 OUTPUT @Traverse;"FN"                (Place stepping motor on line)
2840 I
2850 IF Scan_type=2 THEN

```

Figure C1. (cont) Program "SCAN_ZOC_06"


```

2860 OUTPUT @Inverse;"C,SIN1200,11135500,R" FLOWER BLADE Inverse
2870 ELSE
2880 OUTPUT @Inverse;"C,SIN1200,11153000,R" MIDDLE BLADE Inverse
2890 END IF
2900 I
2910 Pre_posit: I
2920 ENTER @Inverse USING "#,-R";Inverse; Receive acknowledge from stepper
2930 IF Inverse;"^" THEN Pre_posit; If no receipt, try again.
2940 !OUTPUT @Inverse;"X"
2950 !ENTER @Inverse USING "#,80";Pre_pos
2960 I
2970 I
2980 Skip_Inverse: I
2990 I
3000 I .....
3010 I INITIALIZE CALMOD HERE
3020 I .....
3030 I
3040 PRINT
3050 PRINT " You will hear the CALMOD(s) cycle while it initiates.
3060 PRINT
3070 I
3080 CONTROL 9,513 I Set PIP & PIS to Active for CALSYS2000
3090 OUTPUT 9;VAL$(1);"IC";CHR$(13);END; Initialize Calibrator module #1
3100 OUTPUT 9;VAL$(2);"IC";CHR$(13);END; Initialize Calibrator module #2
3110 WAIT Pause_for I Allow CALSYS2000 to set Zpos
3120 I
3130 I .....
3140 I STEADY STATE P2/P1 ROUTINE HERE
3150 I .....
3160 I
3170 DISP "Monitor Pratio and select F5 to start data acquisition."
3180 I
3190 I
3200 P2p1:I
3210 I
3220 I Initialize devices
3230 Dacu=709
3240 Dvm=720
3250 ASSIGN @Dacu TO Dacu
3260 ASSIGN @Dvm TO Dvm
3270 ASSIGN @Instruments TO Dvm,Dacu
3280 CLEAR @Instruments
3290 OUTPUT @Dvm;"FIR7M3A0H0T3" IDCV,Autorange,BathOff,AutocalOff
3300 IHiresOff,IntegratorManual
3310 Ratio_loop: I
3320 FOR Id=0 TO 4 STEP 4
3330 GOSUB Read_atdy
3340 SELECT Id
3350 CASE 0
3360 P1=P_stdy*1000+P_atm
3370 CASE 4
3380 P2=P_stdy*1000+P_atm
3390 END SELECT
3400 NEXT Id
3410 Pratio=P2/P1
3420 PRINT " P2 ", " P1 ", "Pratio"

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

3430          PRINT P2,P1,Pratio
3440 GOTO Initn_loop
3450 I
3460 Read_stdv: I
3470          CLEAR @Dacu
3480          Ac$="AC"
3490          Id$=VAL$(Id)
3500          OUTPUT @Dacu;Ac$&Id$
3510          Total=0
3520          FOR I=1 TO 5
3530              TRIGGER @Dvm
3540              ENTER @Dvm;P_stdv
3550              Total=Total+P_stdv
3560          NEXT I
3570          CLEAR @Dacu
3580          P_stdv=Total/5
3590          P_stdv=2*P_stdv          ! Scaled for 100 psid transducer
3600          RETURN
3610 CLEAR @Instruments
3620 ASSIGN @Dacu TO *
3630 ASSIGN @Dvm TO *
3640 ASSIGN @Instruments TO *
3650 GOTO Hold
3660 I
3670 Collect_data: !----- COLLECT DATA -----
3680 I
3690 I
3700 I
3710 CLEAR @Instruments
3720 ASSIGN @Dacu TO *          ! Deallocate paths used in stdv state read sys
3730 ASSIGN @Dvm TO *
3740 ASSIGN @Instruments TO *
3750 I
3760 I
3770 I ERROR TRAP IF NOT INITIALIZED
3780 I
3790 IF Run=0 THEN
3800     PRINT "Program not initialized for data collection."
3810     DISP "Select F3 to initialize Set-up"
3820     GOTO Hold
3830 END IF
3840 I
3850 I
3860 I
3870 I DATA COLLECTION (CALLS Scan_zocs AND Traverse)
3880 I
3890 I
3900 CLEAR SCREEN
3910 PRINT
3920 PRINT "Collecting raw pressure data."
3930 Count=Sample_number*32          ! Set Count as function of sample number
3940                                ! and number of port readings (32) on
3950                                ! Zoc for raw data collection.
3960 I
3970 I The scan loop for all scan types is here
3980 I
3990 FOR Iscan=1 TO Itrav

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

4000 CALL Scan_zocs(Count,Pulse,Iscan) ! Collect raw data into Memory System
4010 IF Scan_Type>1 AND Iscan=Itrav THEN GOSUB Traverse
4020 NEXT Iscan
4030 I
4040 I
4050 IF Scan_Type=2 THEN ELSE
4060 PRINT "Zeroing Traverse and taking stepping order of line
4070 OUTPUT @Traverse;"C,SIN1000,1100,P"
4080 OUTPUT @Traverse;"Q"
4090 ASSIGN @Traverse=I0 *
4100 ELSE: I
4110 I
4120 PRINT
4130 PRINT "Raw data collection complete.
4140 BEEP
4150 I
4160 GOTO Raw_data_xfer
4170 !.....
4180 ! TRAVERSE OPERATIONS FOR VELINEX NF90 STEPPING MOTOR CONTROLLER
4190 !.....
4200 Traverse: I
4210 SELECT Scan_Type
4220 CASE 2
4230 OUTPUT @Traverse;"C,SIN1000,110-1000,P"
4240 CASE 3
4250 OUTPUT @Traverse;"C,SIN1000,110-1000,P"
4260 END SELECT
4270 I
4280 Pos1: I
4290 ENTER @Traverse USING "#,-K" iTravcmd$
4300 IF iTravcmd$<>"*" THEN Pos1
4310 WAIT 0
4320 OUTPUT @Traverse;"X"
4330 ENTER @Traverse USING "#,80" iPos
4340 RETURN
4350 I
4360 I
4370 Raw_data_xfer: !----- TRANSFER RAW DATA FROM MEMORY SYSTEM TO HARD DISC -----
4380 PRINT
4390 I
4400 FOR Zoc_case=1 TO Zoc_number ! Collect raw data, reduce data and
4410 SELECT Zoc_case ! and store reduce data on hard drive
4420 CASE 1
4430 CALL Raw_dat(Buffer1,1)
4440 CASE 2
4450 IF Run>1 THEN
4460 Run=Run-1
4470 END IF
4480 CALL Raw_dat(Buffer2,2)
4490 CASE 3
4500 IF Run>1 THEN
4510 Run=Run-1
4520 END IF
4530 CALL Raw_dat(Buffer3,3)
4540 END SELECT
4550 NEXT Zoc_case
4560 I

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

4570 Initial_cal:=----- CALIBRATION SET-UP
4580 ! Calibration data array for each Zoc: Zoc_cal(1:3,1:11)
4590 ! Format:
4600 !   For ports 1st to 33
4610 !       Row 0, column 0: Period
4620 !       Row 0, column 1: Sample number
4630 !       Row 0, column 2: Zoc #
4640 !       Row 0, column 3: Calibrator module ID (1-50 psi, 2-15 psi)
4650 !       Row 0: _____ MM MM MM Z0 PL PH PU (pressure Hg.)
4660 !       Row 0-3, column 11: Scan_type, Itrav, Increment, P_atm
4670 !       Row 1: A0 A1 A2 A3 MM MM MM Z0 PL PH PU (LS coef, press, volts)
4680 !       LS coef are Least Squares curve fit coef for third order polynomial.
4690 !
4700 PRINT
4710 PRINT "Collecting calibration data."
4720 REAL Cal1(1120),Cal2(1120),Cal3(1120)! Calibration data array
4730 Iscan=1.0
4740 Count=32*5 ! Set count to collect calibration data
4750 !
4760 MAT Zoc_cal1= (0)
4770 MAT Zoc_cal2= (0)
4780 MAT Zoc_cal3= (0)
4790 Zoc_cal1(0,0)=Period
4800 Zoc_cal1(0,1)=Sample_number
4810 Zoc_cal1(0,2)=1
4820 Zoc_cal1(0,3)=Cal_mod_id(1)
4830 Zoc_cal1(0,11)=Scan_type
4840 Zoc_cal1(1,11)=Itrav
4850 Zoc_cal1(2,11)=Increment
4860 Zoc_cal1(3,11)=P_atm
4870 Zoc_cal2(0,0)=Period
4880 Zoc_cal2(0,1)=Sample_number
4890 Zoc_cal2(0,2)=2
4900 Zoc_cal2(0,3)=Cal_mod_id(2)
4910 Zoc_cal2(0,11)=Scan_type
4920 Zoc_cal2(1,11)=Itrav
4930 Zoc_cal2(2,11)=Increment
4940 Zoc_cal2(3,11)=P_atm
4950 Zoc_cal3(0,0)=Period
4960 Zoc_cal3(0,1)=Sample_number
4970 Zoc_cal3(0,2)=3
4980 Zoc_cal3(0,3)=Cal_mod_id(3)
4990 Zoc_cal3(0,11)=Scan_type
5000 Zoc_cal3(1,11)=Itrav
5010 Zoc_cal3(2,11)=Increment
5020 Zoc_cal3(3,11)=P_atm
5030 !
5040 Collect_cal_dat:=---- COLLECT RAW CALIBRATION DATA ----
5050 !
5060 ! Collect raw calibration data for each CALSYS2000 setting
5070 FOR Index=1 TO 7
5080   CALL Cal2000(Command_mode$(Index),Index)
5090   CALL Scan_zocs(Count,Pulse,Iscale)
5100   FOR Zoc_case=1 TO Zoc_number
5110     SELECT Zoc_case
5120     CASE 1
5130       Input_rblock(Buffer1,Cal1(*),160,(Index-1)*160+1)

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

5140     CASE 2
5150         Input_rblock(Buffer2,Cal2(*),160,(Index-1)*160+1)
5160     CASE 3
5170         Input_rblock(Buffer3,Cal3(*),160,(Index-1)*160+1)
5180     END SELECT
5190     NEXT Zoc_case
5200 NEXT Index
5210 I
5220 I Store collected calibration data
5230 FOR Zoc_case=1 TO Zoc_number
5240     SELECT Zoc_case
5250     CASE 1
5260         CALL Cal_dat(Cal1(*),Zoc_cal1(*))
5270     CASE 2
5280         CALL Cal_dat(Cal2(*),Zoc_cal2(*))
5290     CASE 3
5300         CALL Cal_dat(Cal3(*),Zoc_cal3(*))
5310     END SELECT
5320 NEXT Zoc_case
5330 I
5340 PRINT
5350 PRINT "Calibration data collection complete."
5360 BEEP
5370 WAIT .25
5380 BEEP
5390 OUTPUT 9:VAL$(1);"IC";CHR$(13);END! Initialize Calibrator module #1
5400 OUTPUT 9:VAL$(2);"IC";CHR$(13);END! Initialize Calibrator module #2
5410 PRINT
5420 PRINT "*** Secure Calibrator pressure valve to conserve Nitrogen ***"
5430 PRINT
5440 PRINT "CALSYS2000 Calibration modes and pressures (in Hq):"
5450 Fmt1:IMAGE /,5X,K,10X,K,10X,K,10X,K
5460 PRINT USING Fmt1,"Mode","Zoc #1","Zoc #2","Zoc #3"
5470 Fmt2:IMAGE 6X,K,10X,3D.40,8X,3D.40,8X,3D.40
5480 FOR I=4 TO 10
5490     PRINT USING Fmt2;Command_modes(I-3).Zoc_cal1(0,I),Zoc_cal2(0,I),Zoc_cal3
(0,I)
5500 NEXT I
5510 DISP "Select F4 for another data run, or F6 to reduce data"
5520 GOTO Hold
5530 I
5540 Reduce_data:1----- REDUCE DATA AND STORE ON HARD DRIVE -----
5550 I Routine loads raw and calibration data from storage drive, reduces the
5560 I data, and stores the data to the storage drive.
5570 I
5580 CLEAR SCREEN
5590 PRINT "Calibration and Raw data reduction and storage."
5600 PRINT
5610 IF Run=0 THEN
5620     INPUT "Enter the date of data for reduction (YYYYDD):",Date$
5630     INPUT "Number of Zoc's connected to Multi-programmer",Zoc_number
5640     INPUT "Select data storage drive (0=:700 1=:700,1)",Drv_case
5650     SELECT Drv_case
5660     CASE 0
5670         Data_drive$="":700,0"
5680     CASE 1
5690         Data_drive$="":700,1"
5700     END SELECT

```

Figure C1. (cont) Program "SCAN_ZOC_06"


```

5710 END IF
5720 I
5730 M01 File$= (" ")
5740 FOR Zoc_case=1 TO Zoc_number IAssign files from storage to File$(*)
5750     SELECT Zoc_case
5760     CASE 1
5770         CALL File_scan(1)
5780     CASE 2
5790         CALL File_scan(2)
5800     CASE 3
5810         CALL File_scan(3)
5820     END SELECT
5830 NEXT Zoc_case
5840 I
5850 PRINT "Current files on storage disc ":"Data_drive$:" for date "(Date$
5860 PRINT
5870 FOR Rn=1 TO Run
5880     FOR Zn=1 TO Zoc_number
5890         FOR I=1 TO 3
5900             PRINT USING "3X,K,#"IFile$(Rn,(Zn-1)*3+I)
5910         NEXT I
5920         PRINT USING "+,L"
5930     NEXT Zn
5940 NEXT Rn
5950 PRINT
5960 I
5970 FOR Run_red=1 TO Run I Reduce data routine.
5980     FOR Zoc_case=1 TO Zoc_number
5990         SELECT Zoc_case
6000         CASE 1
6010             CALL Raw_red_dat(1,Run_red)
6020         CASE 2
6030             CALL Raw_red_dat(2,Run_red)
6040         CASE 3
6050             CALL Raw_red_dat(3,Run_red)
6060         END SELECT
6070     NEXT Zoc_case
6080 NEXT Run_red
6090 Run=0
6100 Data_reduced=1
6110 BEEP
6120 DISP "Select F3 reinitialize set-up for data collection, or F8 to Exit"
6130 GOTO Hold
6140 I
6150 View_files: I----- VIEW FILES ON STORAGE DRIVE -----
6160 I Routine loads files from storage drive and displays file names.
6170 I
6180 CLEAR SCREEN
6190 PRINT "List Raw, Calibration and Reduced data files."
6200 PRINT
6210 IF Data_reduced=1 THEN Print_files
6220 IF Run=0 THEN
6230     INPUT "Enter the date of data for for reduction (YYMMDD):",Date$
6240     INPUT "Number of Zoc's connected to Multi-programmer",Zoc_number
6250     INPUT "Select data storage drive (0=:700 1=:700,1)",Drv_case
6260     SELECT Drv_case
6270     CASE 0

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

6280      Data_drive$="":,700,0"
6290      CASE 1
6300      Data_drive$="":,700,1"
6310      END SELECT
6320      END IF
6330      Print_files: |
6340      PRINT "Data storage drive name = ":Data_drive$
6350      |
6360      MAT File$= ("")
6370      FOR Zoc_case=1 TO Zoc_number      |Assign files from storage to File$(.)
6380          SELECT Zoc_case
6390          CASE 1
6400              CALL File_scan(1)
6410          CASE 2
6420              CALL File_scan(2)
6430          CASE 3
6440              CALL File_scan(3)
6450          END SELECT
6460      NEXT Zoc_case
6470      |
6480      PRINT
6490      PRINT "Current files on storage disc for date ":Date$
6500      PRINT
6510      FOR Rn=1 TO Run                    |Print the files listing on the
6520          FOR Zn=1 TO Zoc_number        |designated storage drive.
6530              FOR I=1 TO 3
6540                  PRINT USING "3X,K,1" |File$(Rn,(Zn-1)*3+1)
6550              NEXT I
6560              PRINT USING "/"
6570          NEXT Zn
6580      NEXT Rn
6590      |
6600      IF Drv_case<2 THEN
6610          INPUT "Do you want to copy files from the Hard drive to Floppy? (0=No 1=
Yes)",Copy_h_to_f
6620          IF Copy_h_to_f=0 THEN End_view
6630          ON ERROR GOSUB View_error
6640          PRINT
6650          PRINT "WARNING: Any duplicate existing files on the Floppy will be copie
d over!"
6660          PRINT                    |Copy the files from the designated
6670          FOR Rn=1 TO Run            |hard drive to the floppy drive.
6680              FOR Zn=1 TO Zoc_number
6690                  FOR I=1 TO 3
6700                      F1$=File$(Rn,(Zn-1)*3+1)
6710                      COPY F1$&Data_drive$ TO F1$&"":,700,1"
6720                      IF F1$<>"-" THEN
6730                          PRINT "File " |F1$| " copied to Floppy"
6740                      END IF
6750                  NEXT I
6760              NEXT Zn
6770          NEXT Rn
6780          PRINT
6790          PRINT "Files have been copied from " |Data_drive$| " to Floppy : ,700,1"
6800      END IF
6810      GOTO End_vtew
6820      View_error: |
6830      SELECT ERRN
6840      CASE 56                    |File does not exist, then continue.

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

6850    CLEAR ERROR
6860    ERROR RETURN
6870    CASE 54
6880    PURGE FILE$: ",700,1"
6890    CLEAR ERROR
6900    RETURN
6910    CASE ELSE
6920    DISP ERRM$
6930    PAUSE
6940    END SELECT
6950    !
6960    !
6970    End view: !
6980    Run=0
6990    DISP "Select F2 to return to menu, or F8 to Exit"
7000    GOTO Hold
7010    !
7020    Finish: !
7030    LOAD "ZOC_MENU",10
7040    !
7050    END
7060    End: !=====
7070    ! Function to return todays date for input into file names
7080    DEF FNDate$(Seconds)
7090    Julian=Seconds DIV 86400-1721119
7100    Year=(4*Julian-1) DIV 146097
7110    Julian=(4*Julian-1) MOD 146097
7120    Day=Julian DIV 4
7130    Julian=(4*Day+3) DIV 1461
7140    Day=(4*Day+3) MOD 1461
7150    Day=(Day+4) DIV 4
7160    Month=(5*Day-3) DIV 153 ! Month
7170    Day=(5*Day-3) MOD 153
7180    Day=(Day+5) DIV 5 ! Day
7190    Year=100*Year+Julian
7200    IF Month<10 THEN
7210    Month=Month+3
7220    ELSE
7230    Month=Month+3
7240    Year=Year+1
7250    END IF
7260    Year$=VAL$(Year)
7270    IF Month<10 THEN
7280    Month$="0"&VAL$(Month)
7290    ELSE
7300    Month$=VAL$(Month)
7310    END IF
7320    IF Day<10 THEN
7330    Day$="0"&VAL$(Day)
7340    ELSE
7350    Day$=VAL$(Day)
7360    END IF
7370    D$=Year$[4] & Month$ & Day$
7380    RETURN D$
7390    FNCND
7400    !-----
7410    ! Subroutine to build file names as required by Run number for a specified

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

7420  I Zoc, and assign existing files to the File$ matrix.
7430  SUB File(Zn)
7440  COM /Stats/ REAL Pulse,Sample_number,Pulse_for,INTEGER Cal mod Id(3),Dat
e$,Run,ltray
7450  COM /Files/ File$(*),Data_drives$
7460  DIM Data_disc1$(23),Data_disc2$(23),Data_disc3$(23)
7470  ON ERROR GOTO Error
7480  J=(Zn-1)*3
7490  Assign_file:  I
7500  File1=0
7510  Data_file1$="ZW"&VAL$(Zn)&Date$&VAL$(Run)
7520  Data_disc1$=Data_file1$&Data_drives$
7530  ASSIGN @Check_path1 TO Data_disc1$  ICheck for existence of ZW_.
7540  File$(Run,J+1)=Data_file1$  IAssign ZW_ to matrix.
7550  File1=1  IFlag to ID file exists.
7560  I
7570  File2=0
7580  Data_file2$="ZC"&VAL$(Zn)&Date$&VAL$(Run)
7590  Data_disc2$=Data_file2$&Data_drives$
7600  ASSIGN @Check_path2 TO Data_disc2$  ICheck for existence of ZC_.
7610  File$(Run,J+2)=Data_file2$  IAssign ZC_ to matrix.
7620  File2=1  IFlag to ID file exists.
7630  I
7640  Data_file3$="ZR"&VAL$(Zn)&Date$&VAL$(Run)
7650  Data_disc3$=Data_file3$&Data_drives$
7660  ASSIGN @Check_path3 TO Data_disc3$  ICheck for existence of ZR_.
7670  File$(Run,J+3)=Data_file3$  IAssign ZR_ to matrix.
7680  I
7690  Run=Run+1  IIf ZW_ exist, reassign Run #
7700  ASSIGN @Check_path1 TO *
7710  ASSIGN @Check_path2 TO *
7720  ASSIGN @Check_path3 TO *
7730  GOTO Assign_file  ICheck storage disc again.
7740  Error:  I Subroutine if ERROR=56, files donot exist for Run and Zoc
7750  IF ERRN<>56 THEN
7760  PRINT ERRM$
7770  PAUSE
7780  END IF
7790  IF File1=0 THEN Fin  IFile ZW_ doesnot exist, exit
7800  IF File1=1 THEN  IFile ZW_ exists
7810  IF File2=0 THEN  IFile ZC_ doesnot exists, therefore
7820  ASSIGN @Check_path1 TO *
7830  PURGE Data_disc1$  Idelete ZW_.
7840  ELSE
7850  Run=Run+1  IFile ZW_ & ZC_ exist, step Run
7860  END IF  Iand continue.
7870  END IF
7880  ASSIGN @Check_path1 TO *
7890  ASSIGN @Check_path2 TO *
7900  ASSIGN @Check_path3 TO *
7910  GOTO Assign_file
7920  Fin:  I
7930  ASSIGN @Check_path1 TO *
7940  ASSIGN @Check_path2 TO *
7950  ASSIGN @Check_path3 TO *
7960  Data_file2$="ZC"&VAL$(Zn)&Date$&VAL$(Run)
7970  Data_file3$="ZR"&VAL$(Zn)&Date$&VAL$(Run)
7980  File$(Run,J+1)=Data_file1$  ICreate ZW_ to matrix.

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

7990   File$(Run,J+2)=Data_file2$      ! Create ZC_ to matrix.
8000   File$(Run,J+3)=Data_file3$      ! Assign ZP_ to matrix.
8010 SUBEND
8020 |-----|
8030 | Subroutine to operate the HP5944A Multi-programmer for scanning Zocs.
8040 SUB Scan_zocs(Count,Pulse,Iscan)
8050   COM /Names/ Buffer1,Add1,Buffer2,Add2,Buffer3,Add3,Timer
8060   Wait_time=Count*2*Pulse+10.0     ! Set Timer wait time to +10 secs.
8070   Init(Timer)                       ! Initialize Timer system
8080   Set_timeout(Timer,Wait_time)       ! Set Pause_for period of xx secs.
8090   Set_count(Timer,Count)            ! Set Count number into Timer
8100   Set_period(Timer,Pulse)           ! Set Timer pulse length to secs.
8110   IF Iscan>1 THEN Maintain_point   ! If scanning! then don't reset pointer
8120   Init(Buffer1)                    ! Initialize Buffer for data storage
8130   Init(Buffer2)
8140   Init(Buffer3)
8150 Maintain_point: !
8160   Start(Timer)                     ! Start data sample collection
8170   Wait_for(Timer)                 ! Data samples stored in Memory System
8180 SUBEND
8190 |
8200 |-----|
8210 | Subroutine to collect raw pressure data from Memory System and store
8220 | onto the hard drive for future data reduction.
8230 SUB Raw_dat(Buff,Zn)
8240   COM /Stats/ REAL Pulse,Sample_number,Pause_for,INTEGER Cal_mod_id(3),Dat
e$,Run,Itrav
8250   COM /Files/ File$(*),Data_drive$ ! Data file listing for 99 runs.
8260   ON ERROR GOTO Error
8270   INTEGER Raw_data(32672) BUFFER ! Integer raw data buffer for 32*1021
8280                                     ! data samples. Integer format for
8290                                     ! minimum transfer time to storage.
8300   DIM Data_disc$(25)
8310   It=Itrav
8320   Sn=Sample_number
8330 Assign_file: !
8340   Data_file$=File$(Run,(Zn-1)*3+1) ! Raw data file
8350   Data_disc$=Data_file$&Data_drive$
8360   CREATE BDAT Data_disc$,32*It*Sn+1*It,2 ! Create BDAT file w/2 byte recor
ds.
8370   ASSIGN @Data_path TO Data_disc$ ! Assign path to hard drive
8380   ASSIGN @Buffer_path TO BUFFER Raw_data(*):FORMAT OFF
8390   Input_iblock(Buff,Raw_data(*),It*Sn+1*It,1) ! Load data samples
8400   |
8410   !PRINTER IS 702
8420   !PRINT Raw_data(*) ! Block print raw data for test
8430   !PRINTER IS CRT
8440   |
8450   CONTROL @Buffer_path,4,32*2*It*Sn+2*It ! Close buffer when full
8460   TRANSFER @Buffer_path TO @Data_path ! Transfer data Data_disc
8470   ASSIGN @Buffer_path TO *
8480   ASSIGN @Data_path TO *
8490   PRINT "Raw pressure data: Run#":Run," Zoc#":Zn," storage drive file ":
Data_file$&Data_drive$
8500   GOTO Fin
8510 Error: !
8520   IF ERRN<>54 THEN
8530     PRINT ERRM$
8540     PAUSE
8550   END IF

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

8560 IF FRPN=54 THEN                                I Run stop routine when computing
8570     Run=Run+1                                    I multiple data runs without data
8580     CALL File(7n)                                I production.
8590     FIN IF
8600     GOTO Assign_file
8610 Fin:
8620 SUBEND
8630 I-----
8640 I Subroutine controls calibration mode and reads pressure from pressure
8650 I Standard into Zoc_cal(*) array.
8660 SUB Cal2000(Command$,I)
8670     COM /Zoc_dat/ REAL Zoc_cal(1*) BUFFER,Zoc_cal2(1*) BUFFER,Zoc_cal3(1*) BUI
8670     FER
8680     COM /Stats/ REAL Pulse,Sample_number,Pause_for,INTEGER Cal_mod_id(3),Dat
8680     e$,Run,Itrav
8690     DIN Pressure$(5)                                I Required to read data stream
8700     OUTPUT 9,VAL$(1);Command$;CHR$(13);END        I Sets calibrator #1 mode
8710     OUTPUT 9,VAL$(2);Command$;CHR$(13);END        I Sets calibrator #2 mode
8720     WAIT Pause_for                                I Allow CALSYS2000 to stabilize
8730     FOR K=1 TO Cal_mod_id(0)                        I Read CALSYS2000 cal press
8740         SELECT K
8750         CASE 1
8760             OUTPUT 9,VAL$(Cal_mod_id(1));"RP";CHR$(13);END
8770             ENTER 9 USING "%,SO,SDSZZ,K";Zoc_cal1(0,I+3),Pressure$
8780         CASE 2
8790             OUTPUT 9,VAL$(Cal_mod_id(2));"RP";CHR$(13);END
8800             ENTER 9 USING "%,SO,SDSZZ,K";Zoc_cal2(0,I+3),Pressure$
8810         CASE 3
8820             OUTPUT 9,VAL$(Cal_mod_id(3));"RP";CHR$(13);END
8830             ENTER 9 USING "%,SO,SDSZZ,K";Zoc_cal3(0,I+3),Pressure$
8840         END SELECT
8850     NEXT K
8860     IF I<=3 THEN                                    I Account for positive pressures used
8870         Zoc_cal1(0,I+3)=-Zoc_cal1(0,I+3) I by CALSYS2000 in the NH,NH, & NL mo
8870         de.
8880         Zoc_cal2(0,I+3)=-Zoc_cal2(0,I+3)
8890         Zoc_cal3(0,I+3)=-Zoc_cal3(0,I+3)
8900     END IF
8910 SUBEND
8920 I-----
8930 I Subroutine stores calibration data collected from Memory System and
8940 I CALSYS2000 calibration pressure data onto the hard drive.
8950 I Zoc_cal_ is then stored onto the hard drive.
8960 SUB Cal_dat(REAL Cal(1*),Zoc_cal(1*) BUFFER)
8970     COM /Stats/ REAL Pulse,Sample_number,Pause_for,INTEGER Cal_mod_id(3),Dat
8970     e$,Run,Itrav
8980     COM /Files/ File$(1*),Data_drive$ I Data file listing for 99 runs.
8990 I
9000 I Converting Cal(1*) to Zoc_cal(1*)
9010     FOR J=4 TO 10                                I Cal runs: NH,NH,NL,ZO,PI,PH,FI
9020         FOR I=1 TO 32                            I Zoc ports per calibration run
9030             FOR K=0 TO 4                            I Number of samples per run
9040                 Zoc_cal(I,J)=Zoc_cal(I,J)+Cal(I+K*32+(J-4)*160)
9050             NEXT K
9060             Zoc_cal(I,J)=Zoc_cal(I,J)/5 I Average of 5 samples per port I
9070         NEXT I
9080     NEXT J
9090 I
9100 I Transfer calibration data to hard drive.
9110     ON ERROR GOSUB Purge_file
9120     DIN Data_disc$(23)                            I Define string for data file name

```

Figure C1. (cont) Program "SCAN_ZOC_06"


```

9130   Zn=Zoc_cal(0,2)           ! Define Zoc number
9140   Data_file$=File$(Run,(Zn-1)*3+2) ! Calibration data file
9150   Data_disc$=Data_file$&Data_drive$
9160   CREATE BDATA Data_disc$,33,8*12 ! Create BDATA file of 12*8 byte
9170   ASSIGN @Data_path TO Data_disc$ ! Assign path to hard drive
9180   ASSIGN @Buffer_path TO BUFFER Zoc_cal(*):FOPNAL OFF
9190   CONTROL @Buffer_path,4*8*12*33 !Set data file length
9200   TRANSFER @Buffer_path TO @Data_path!Store cal data on hard drive
9210   ASSIGN @Buffer_path TO *      ! Close path
9220   ASSIGN @Data_path TO *        ! Close path
9230   PRINT "Calibration data: Run#"&Run," Zoc#"&Zn," storage drive file "&Data_disc$
9240   GOTO Fin
9250 Purge_file: !
9260   IF ERRN=54 THEN
9270     PRINT "Error occurred in SUB Cal_dat. Error:"&ERRN
9280     PAUSE
9290   END IF
9300   RETURN
9310 Fin: !
9320 SUBEND
9330 !-----
9340 ! Subroutine loads raw and calibration data from the storage drive,
9350 ! reduces the data, and stores the data onto the storage drive.
9360 ! Calibration data is reduced using the Least Squares Curve fit to obtain
9370 ! coefficients for a third-order polynomial. The raw pressure data is
9380 ! reduced using these coefficients.
9390 ! Buffer arrays are replaced with standard arrays for data manipulation.
9400 ! Utilization of Buffers and the TRANSFER routine results in lost of the
9410 ! first several data bytes when data is transferred from floppy media to
9420 ! the buffer. Utilization of OUTPUT, ENTER, and arrays results in no
9430 ! data lost with floppy media. Hard disc media works well with either
9440 ! data manipulation technique using buffers or standard arrays.
9450 SUB Raw_red_dat(Zn,Rn)
9460   COM /Names/ Buffer1,Adc1,Buffer2,Adc2,Buffer3,Adc3,Timer
9470   COM /Stats/ REAL Pulse,Sample_number,Pause_for,INTEGER Cal_mod_id(3),Data%[6],Run,Itrav
9480   COM /Files/ File$(*),Data_drive$ !Data file listing for 99 runs.
9490   Data_file1$=File$(Rn,(Zn-1)*3+2) ! Calibration data file
9500   Data_file2$=File$(Rn,(Zn-1)*3+1) ! Raw data file name
9510   Data_file3$=File$(Rn,(Zn-1)*3+3) ! Reduced data file name
9520   !
9530   IF Data_file3$<>"-" THEN ! Continue if Reduce data file
9540     GOTO Fin ! doesnot exist.
9550   END IF
9560   !
9570   IF Data_file1$<"-" THEN
9580     PRINT "Calibration file doesnot exist for Run#"&Rn," Zoc#"&Zn
9590     GOTO Fin
9600   END IF
9610   !
9620   ON ERROR GOSUB Error
9630   DIM Data_disc1$(23)
9640   DIM Data_disc2$(23)
9650   DIM Data_disc3$(23)
9660   Data_disc1$=Data_file1$&Data_drive$
9670   REAL Zoc_cal(32,11) !Array to handle calibration data
9680   !
9690 Data_reduction: !

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

9700 PRINT "Data reduction: Run#":Run,"Zoc#":Zn
9710 I
9720 ASSIGN @Data_path1 TO Data_disc1$,FORMAT OFF
9730 ENTER @Data_path1;Zoc_cal(*) ILoad raw calibration data into array
9740 ASSIGN @Data_path1 TO *
9750 I
9760 I Calibration data reduction using Least Square Polynomial fitting.
9770 REAL A(3,3),B(3),C(3),Sum_x(6),A_inv(3,3) I Least Square reduction arrays
9780 FOR K=1 TO 32 I Loop for each port
9790 I
9800 MAT C= (0)
9810 MAT Sum_x= (0)
9820 I
9830 FOR J=1 TO 6 I Routine to reduce individual port cal
9840 FOR I=4 TO 10 I data into elements to a power = J
9850 Sum_x(J)=Sum_x(J)+Zoc_cal(K,I)^J
9860 NEXT I
9870 NEXT J
9880 I
9890 FOR I=0 TO 3 I Derive A array
9900 FOR J=0 TO 3
9910 A(I,J)=Sum_x(I+J)
9920 NEXT J
9930 NEXT I
9940 A(0,0)=7
9950 I
9960 FOR J=0 TO 3 I Derive C array
9970 FOR I=4 TO 10
9980 C(J)=C(J)+Zoc_cal(K,I)^J*Zoc_cal(0,I)
9990 NEXT I
10000 NEXT J
10010 I
10020 MAT A_inv= INV(A)
10030 MAT B= A_inv*C I B array is matrix of Least Square
10040 I coefficients a0,a1,a2,& a3 for polynomial
10050 I equation fitting calibration data for a
10060 I specified port
10070 I
10080 I Collect Least Square coefficients
10090 Zoc_cal(K,0)=B(0) I Coefficient a0
10100 Zoc_cal(K,1)=B(1) I Coefficient a1
10110 Zoc_cal(K,2)=B(2) I Coefficient a2
10120 Zoc_cal(K,3)=B(3) I Coefficient a3
10130 I
10140 NEXT K
10150 I
10160 ASSIGN @Data_path1 TO Data_disc1$,FORMAT OFF
10170 OUTPUT @Data_path1;Zoc_cal(*) I Store reduced calibration data
10180 ASSIGN @Data_path1 TO *
10190 I
10200 PRINT "Calibration data reduced and transferred to ":Data_file1$
10210 I
10220 I Recover raw data, convert to real, reduce then store in blocks
10230 I of samples (32*ports scanned per block)*Itrav
10240 I
10250 Itrav=Zoc_cal(1,1)
10260 Sn=Zoc_cal(0,1) I Sample number.

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

10270 ALLOCATE INTEGER Data_integer(1:32) (Array to handle raw integer data.
10280 ALLOCATE REAL Data_real(1:32),Data(32) (Arrays to handle raw and reduced
.
10290 Data_disc2$=Data_file2$&Data_drive$ (real data.
10300 Data_file3$="2R"&VAL$(7n)&Data$&VAL$(Rn) (Reduced data file name.
10310 Data_disc3$=Data_file3$&Data_drive$
10320 CREATE DAT Data_disc3$,Sn*1trav,8*33 (RDAT file of 33*8 byte records.
10330 ASSIGN @Data_path2 TO Data_disc2$(FORHAT OFF
10340 ASSIGN @Data_path3 TO Data_disc3$(FORHAT OFF
10350 I
10360 Step_point=2
10370 Step_increment=32*Sn+1
10380 FOR Group=1 TO 1trav
10390 I
10400 CONTROL @Data_path2,5,Step_point (Set read pointer to 2nd record
10410 I (in raw integer data file.
10420 Step_point=Step_point+Step_increment (Increment pointer start point.
10430 I
10440 FOR Block=1 TO Sn
10450 ENTER @Data_path2,Data_integer(*) (Load raw data into array.
10460 SELECT Zoc_cal(0,2) (Translating raw integer data into
10470 CASE 1 (raw real data.
10480 Translate(Adc1,Data_integer(*),Data_real(*))
10490 CASE 2
10500 Translate(Adc2,Data_integer(*),Data_real(*))
10510 CASE 3
10520 Translate(Adc3,Data_integer(*),Data_real(*))
10530 END SELECT
10540 I
10550 I Data check steps commented out.
10560 I
10570 IPRINTER IS 702
10580 IPRINT "Integer data"
10590 IPRINT Data_integer(*)
10600 IPRINT "Real data"
10610 IPRINT Data_real(*)
10620 IPRINTER IS CRT
10630 I
10640 Routine to reduce raw real data:
10650
10660 Data = a0 + a1*x + a2*x^2 + a3*x^3
10670
10680 where a0,a1,a2, & a3 are Least Square coefficients, and x is
10690 the individual port raw data value.
10700
10710 Data(0)=Block ( Store reduce data sample number.
10720 FOR K=1 TO 32
10730 Data(K)=Zoc_cal(K,0)+Zoc_cal(K,1)*Data_real(K)+Zoc_cal(K,2)*Da
10740 ta_real(K)^2+Zoc_cal(K,3)*Data_real(K)^3
10750 NEXT K
10760 I
10770 IPRINTER IS 702
10780 IPRINT Data(*) ( Print block for test commented out.
10790 IPRINTER IS CRT
10800 I
10810 OUTPUT @Data_path3,Data(*) (Store block of reduced data into
10820 NEXT Block (into the file on the designated drive.
10830 NEXT Group

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

10840 1
10850 ASSIGN @Data_path3 TO 1
10860 ASSIGN @Data_path2 TO 1
10870 PRINT "Raw data reduced and transferred to "Data_file3$
10880 PRINT
10890 GOTO Fin
10900 Error: 1 Routine to trap error in program.
10910 PRINT ERRMS
10920 PAUSE
10930 RETURN
10940 Fin: 1
10950 SUBEND
10960 -----
10970 1 Subroutine to load existing files required by Run number for a specified
10980 1 Zoc, and assign existing files to the File$ matrix for Data reduction
10990 1 and List files routines.
11000 SUB File_scan(Zn)
11010 CON /Stats/ REAL Pulse, Sample_number, Pause_for, INTEGER Cat_mod id(3), Dat
e$, Run, I, trav
11020 COM /Files/ File$(*), Data_drives$
11030 DIM Data_disc1$(23), Data_disc2$(23), Data_disc3$(23)
11040 Rn=1
11050 Loop=1
11060 File_in_storage=0
11070 ON ERROR GOTO Error
11080 J=(Zn-1)*3
11090 WHILE Loop=1
11100 File1=0
11110 Data_file1$="ZW"&VAL$(Zn)&Date$&VAL$(Rn)
11120 Data_disc1$=Data_file1$&Data_drives$
11130 ASSIGN @Check_path1 TO Data_disc1$ !Check for existence of ZW_.
11140 File$(Rn,J+1)=Data_file1$ !Assign ZW_ to matrix.
11150 File1=1
11160 1
11170 Data_file2$="ZC"&VAL$(Zn)&Date$&VAL$(Rn)
11180 Data_disc2$=Data_file2$&Data_drives$
11190 ASSIGN @Check_path2 TO Data_disc2$ !Check for existence of ZC_.
11200 File$(Rn,J+2)=Data_file2$ !Assign ZC_ to matrix.
11210 1
11220 Data_file3$="ZR"&VAL$(Zn)&Date$&VAL$(Rn)
11230 Data_disc3$=Data_file3$&Data_drives$
11240 ASSIGN @Check_path3 TO Data_disc3$ !Check for existence of ZR_.
11250 File$(Rn,J+3)=Data_file3$ !Assign ZR_ to matrix.
11260 1
11270 GOTO Assign_file !Check storage disc again.
11280 Error: 1 Subroutine if ERROR=56, files donot exist for Rn and Zoc
11290 IF ERRN<>56 THEN
11300 PRINT ERRMS
11310 PAUSE
11320 END IF
11330 Assign_file:1
11340 IF File1=1 THEN !Switch to exit program
11350 File_in_storage=1
11360 END IF
11370 IF File1=0 THEN
11380 IF File_in_storage=1 THEN
11390 Loop=0
11400 END IF

```

Figure C1. (cont) Program "SCAN_ZOC_06"

```

11410      END IF
11420      ASSIGN @Check_path1 TO *
11430      ASSIGN @Check_path2 TO *
11440      ASSIGN @Check_path3 TO *
11450      IF Rn=100 THEN
11460          Loop=0
11470      END IF
11480      Rn=Rn+1
11490  END WHILE
11500 Fin: 1
11510  Run=Rn-2
11520 SUBEND
11530 I-----

```

Figure C1. (cont) Program "SCAN_ZOC_06"

APPENDIX D. DATA ANALYSIS PROGRAM "READ_ZOC2"

```

10  I Program: READ_ZOC2
20  I Description: Reads specified data compiled from program STALL_ZOC_05.
30  I by: Rick Wendland
40  I modified by David Nyren
50  I modified 5 Nov 1992
60  I .....
70  CLEAR SCREEN
80  PRINTER IS CRT
90  IVariable definition and dimension
100  DIM /Plot_Labels/ REAL Xc,Xf,Xo,Xf,Dx,Dz,Title1(60),X_Label(160),Y_Label(160)
110  INTEGER Disk_drive,Zoc,Run,View,Sample_min,Sample_max,Port_min
120  INTEGER Port_max,Scan_max,Avg
130  REAL M1,M2
140  IVariable Initialization
150  P_atm=14.696          IStandard day atmospheric pressure
160  Conv=.491154         IConversion from In Hg to psi
170  Gamma=1.4            IRatio of specific heats
180  Sc=.0025             ISub Square sizing
190  Allocated=0
200  IDimension string variable for data location:
210  DIM Data_disc1$(123)
220  DIM Data_disc2$(123)
230  I
240  I .....
250  INOT KEY ROUTINES AND INITIAL SCREEN DISPLAY
260  I .....
270  I
280  ON KEY 1 LABEL "ZOC"      INPUT      * GOTO Input
290  ON KEY 2 LABEL "SAVE AS ASCII" * GOTO Save
300  ON KEY 3 LABEL "PRINT DATA" * GOTO Print
310  ON KEY 4 LABEL "Cp"       PLOT       * GOTO Cp
320  ON KEY 5 LABEL "Pt"       PLOT       * GOTO Pt
330  ON KEY 6 LABEL " "        * GOTO Hold
340  ON KEY 7 LABEL " "        * GOTO Hold
350  ON KEY 8 LABEL "EXIT"     PROG       * GOTO Finish
360  I
370  I .....
380  I INITIAL SCREEN DISPLAY
390  I .....
400  I
410  Reset:      I
420              CLEAR SCREEN
430  PRINT
440  PRINT
450  PRINT "      READ_ZOC DATA AND DISPLAY AS SHOWN"
460  PRINT
470  PRINT "      Input ZOC information and read data          F1"
480  PRINT "      Save reduced data to an ASCII file             F2"
490  PRINT "      Print data to CRT or PRINTER                       F3"
500  PRINT "      Plot and Print P/Pt                                F4"
510  PRINT "      Plot Pt data/Print Losses                             F5"
520  PRINT
530  PRINT
540  PRINT "      Exit Program                                          F8"
550  PRINT
560  I
570  Hold:      I

```

Figure D1. Program "READ_ZOC2"


```

580          GO10 Hold
590          I
600          I.....
610          INPUT DAT INFORMATION
620          I.....
630          I
640 Input:    I
650          I
660          IF Allocated=1 THEN GOSUB Deallocate
670          I
680          CLEAR SCREEN
690          INPUT "Enter Zoc # (1,2,3), date (YMMDD), and run #:",Zoc,Date$,Run
700          PRINT
710          PRINT
720          PRINT
730          PRINT "Enter the disk drive where data is stored as below."
740          PRINT "      0 is HFS format or 700,0"
750          PRINT "      1 is LIF floppy or 700,1"
760          PRINT
770          INPUT "Enter Disc where data is located:",Disc_drive
780          PRINT
790          I
800          I.....
810          IF FILE/DISK PATH ASSIGNED
820          I.....
830          I
840          Data_file1$="ZC"&VAL$(Zoc)&Date$&VAL$(Run)
850          Data_file2$="ZR"&VAL$(Zoc)&Date$&VAL$(Run)
860          SELECT Disc_drive
870          CASE 0
880          Data_disc1$=Data_file1$":,700,0"
890          Data_disc2$=Data_file2$":,700,0"
900          CASE 1
910          Data_disc1$=Data_file1$":,700,1"
920          Data_disc2$=Data_file2$":,700,1"
930          END SELECT
940          ASSIGN @Data_path1 TO Data_disc1$
950          ASSIGN @Data_path2 TO Data_disc2$
960          I
970          I.....
980          DETERMINE NUMBER OF RECORDS AND ENTER DATA.
990          I.....
1000         I
1010        STATUS @Data_path1,3;N1          I Determine number of records
1020        STATUS @Data_path2,3;N2          I Determine number of records
1030        ALLOCATE REAL Cal(N1-1,11)      I Define REAL array of records
1040        ENTER @Data_path1;Cal(*)
1050        Period=Cal(0,0)
1060        Hz=1/Period
1070        Sample_number=Cal(0,1)
1080        Zoc=Cal(0,2)
1090        Scan_type=Cal(0,11)
1100        Scan_max=Cal(1,11)
1110        Increment=Cal(2,11)*.0000625    I Convert steps to inches.
1120        P_atm=Cal(3,11)
1130        I
1140        ALLOCATE REAL Data(1:N2,0:32)    I Allocate real data array

```

Figure D1. (cont) Program "READ_ZOC2"

```

1150 ENTER @Data_path2;Data(*)
1160 IF Scan_max<8 THEN
1170 ALLOCATE REAL Pa(1:32,1:7)
1180 ELSE
1190 ALLOCATE REAL Pa(1:32,1:Scan_max)
1200 END IF
1210 I
1220 allocated=I          I Allows deallocation of paths.
1230 I
1240 I.....
1250 IREADS AVERAGE OF ALL SAMPLES TO ARRAYS
1260 I.....
1270 I
1280 Read: IReads reduced data to array.
1290 I
1300 Sample_min=I          I First sample
1310 Sample_max=Sample_number I Last sample
1320 I
1330 FOR Scan=1 TO Scan_max
1340 I
1350     FOR Port_number=1 TO 32
1360     I
1370         Pg_sum=0
1380         FOR Sample=Sample_min TO Sample_max
1390             Pg=Data(Sample,Port_number) I Data read from reduced data.
1400             Pg_sum=Pg_sum+Pg
1410         NEXT Sample
1420     I
1430     Pa_avg=(Pg_sum/Sample_number)*Conv+P_atm
1440     Pa(Port_number,Scan)=Pa_avg
1450     I
1460     NEXT Port_number
1470     Sample_min=Sample_min+Sample_number
1480     Sample_max=Sample_max+Sample_number
1490     I
1500 NEXT Scan
1510 DISP "Data read from disk and transferred to array."
1520 WAIT 2
1530 GOTO Reset
1540 I
1550 I.....
1560 IROUTINE STORES DATA TO AN ASCII FILE
1570 I.....
1580 I
1590 Save: I
1600 I
1610     CLEAR SCREEN
1620 INPUT "Store on hard or floppy drive (0=:700, 1=:700,1):",Drv
1630 PRINT "Storing data please wait"
1640 IF Drv=0 THEN
1650 Drv$="":700"
1660 ELSE
1670 Drv$="":700,1"
1680 END IF
1690 Asc$="A"
1700 Filename$=Data_file2$&Asc$&Drv$
1710 CREATE ASCII Filename$,10
1720 ASSIGN @Path_1 TO Filename$

```

Figure D1. (cont) Program "READ_ZOC2"

```

1730 OUTPUT @Path_1;Pa(*)
1740 ASSIGN @Path_1 TO *
1750 PRINT
1760 PRINT "Data stored to ASCII file called";Filename$
1770 WAIT 2
1780 GOTO Reset
1790 I
1800 I.....
1810 IPRINTS DATA TO PRINTER OR CRT SCREEN AS DESIRED
1820 I.....
1830 I
1840 Print:I
1850 CLEAR SCREEN
1860 I
1870 INPUT "Print results to screen or printer (0=Screen 1=Printer)";View
1880 IF View=1 THEN PRINTER IS 702
1890 I
1900 I
1910 PRINT "Data Print Out for Zoc #";Zoc";, Run #:"Run";, file:"Data_file2$
1920 PRINT TAB(5);"Period between samples (sec)";:"Period
1930 PRINT TAB(5);"Sample collection rate (Hz)";:"Hz
1940 PRINT TAB(5);"Number of samples per port";:"Sample_number
1950 PRINT TAB(5);"Length of data run (sec)";:"Period*31*Sample_number*Scan_
max
1960 PRINT TAB(5);"The scan type is:";:"Scan_type
1970 PRINT TAB(5);"Number of scans/traverses:";:"Scan_max
1980 PRINT TAB(5);"Increment of traverse:";:"Increment;" Inches"
1990 PRINT TAB(5);"Atmospheric pressure is:";:"P_atm;" psia"
2000 PRINT TAB(5);"Tunnel Pressure Ratio is:";:"Pa(30,1)/Pa(29,1)
2010 PRINT
2020 PRINT
2030 I
2040 Format1: IMAGE 2D,6X,2D.3D,4X,2D.3D,4X,2D.3D,4X,2D.3D,4X,2D.3D,4X,2D.3D,4X
,2D.3D
2050 Format2: IMAGE 2D,6X,2D.3D,4X,2D.3D,4X,2D.3D,4X,2D.3D,4X,2D.3D,4X,2D.3D,4X
,2D.3D
2060 I
2070 IF Scan_max>7 THEN
2080 PRINT "Scan"," Port Number"
2090 PRINT " ", " 1", " 2", " 3", " 4", " 5", " 6", " 7"
2100 PRINT
2110 FOR I=1 TO Scan_max
2120 PRINT USING Format1;I,Pa(1,I),Pa(2,I),Pa(3,I),Pa(4,I),Pa(5,I),Pa(6,I),
Pa(7,I)
2130 NEXT I
2140 FOR J=1 TO 3
2150 PRINT
2160 NEXT J
2170 PRINT "Scan"," Port Number"
2180 PRINT " ", " 8", " 9", "10", "11", "12", "13", "14"
2190 PRINT
2200 FOR I=1 TO Scan_max
2210 PRINT USING Format1;I,Pa(8,I),Pa(9,I),Pa(10,I),Pa(11,I),Pa(12,I),Pa(13
,I),Pa(14,I)
2220 NEXT I
2230 FOR J=1 TO 3
2240 PRINT
2250 NEXT J
2260 PRINT "Scan"," Port Number"
2270 PRINT " ", "15", "16", "17", "18", "19", "20", "21"

```

Figure D1. (cont) Program "READ_ZOC2"

```

2280 PRINT
2290 FOR I=1 TO Scan_max
2300     PRINT USING Format1:I,Pa(15,I),Pa(16,I),Pa(17,I),Pa(18,I),Pa(19,I),Pa(
20,1),Pa(21,I)
2310 NEXT I
2320 FOR J=1 TO 3
2330 PRINT
2340 NEXT J
2350 PRINT "Scan","          Port Number"
2360 PRINT " ", "22", "23", "24", "25", "26", "27", "28"
2370 PRINT
2380 FOR I=1 TO Scan_max
2390     PRINT USING Format1:I,Pa(22,I),Pa(23,I),Pa(24,I),Pa(25,I),Pa(26,I),Pa(
27,I),Pa(28,I)
2400 NEXT I
2410 FOR J=1 TO 3
2420 PRINT
2430 NEXT J
2440 PRINT "Scan","          Port Number"
2450 PRINT " ", "29", "30", "31", "32"
2460 PRINT
2470 FOR I=1 TO Scan_max
2480     PRINT USING Format1:I,Pa(29,I),Pa(30,I),Pa(31,I),Pa(32,I)
2490 NEXT I
2500 I
2510 ELSE
2520 I
2530     PRINT "Port","          Scan Number"
2540     PRINT " ", "1", "2", "3", "4", "5", "6", "7"
2550     PRINT
2560     FOR I=1 TO 32
2570         PRINT USING Format2:I,Pa(I,1),Pa(I,2),Pa(I,3),Pa(I,4),Pa(I,5),Pa(I,
6),Pa(I,7)
2580     NEXT I
2590 END IF
2600 PRINTER IS CRT
2610 GOTO Reset
2620 I
2630 I
2640 I*****
2650 I PLOT AND PRINT Cp DATA AND SAVE TO ASCII FILE
2660 I*****
2670 I
2680 Cp: I
2690 I
2700 ALLOCATE INTEGER Pen(1:25)
2710 ALLOCATE REAL X(1:25)
2720 ALLOCATE REAL P_local(1:25,1:Scan_max)
2730 ALLOCATE REAL P_inf(1:Scan_max)
2740 ALLOCATE REAL P_ref(1:Scan_max)
2750 ALLOCATE REAL M_inf(1:Scan_max)
2760 I
2770 IF Scan_max<7 THEN
2780 I ALLOCATE REAL B(1:25,1:7)
2790 I ALLOCATE REAL Cp(1:25,1:7)
2800 I ALLOCATE REAL M_local(1:25,1:7)
2810 I ALLOCATE REAL P_normal(1:25,1:7)
2820 I ELSE

```

Figure D1. (cont) Program "READ_ZOC2"

```

2830 ALLOCATE REAL B(1:25,1:Scan_max)
2840 ALLOCATE REAL Cp(1:25,1:Scan_max)
2850 ALLOCATE REAL M_local(1:25,1:Scan_max)
2860 ALLOCATE REAL P_normal(1:25,1:Scan_max)
2870 END IF
2880 I
2890 RESTORE
2900 I
2910 DATA 0.1667,0.25,0.3333,0.3467,0.36,0.3733,0.3867,0.4,0.4133,0.4267,0.4400,
0.4533,0.4667,0.4800,0.4933,0.5067,0.52,0.5333,0.56,0.5867,0.6133,0.6400,0.75
2920 DATA 0.8333,0.9167
2930 I
2940 READ X(*) !Read in axial location of ports
2950 I
2960 I Calculate reference parameters.
2970 I
2980 FOR I=1 TO Scan_max
2990 P_inf(I)=Pa(29,I) !Get P_inf for all scans.
3000 P_ref(J)=Pa(31,I) !Get P_ref for all scans.
3010 M_inf(I)=SQRT(2/(Gamma-1)*((P_ref(I)/P_inf(I))**((Gamma-1)/Gamma)-1))
3020 NEXT I
3030 I
3040 I Calculate local flow parameters.
3050 I
3060 FOR I=1 TO 25
3070 FOR J=1 TO Scan_max
3080 P_local(I,J)=Pa(I,J) !Get P_local for all scans.
3090 P_normal(I,J)=P_local(I,J)/P_ref(J) !Normalized pressure
3100 Cp(I,J)=(2/(Gamma*M_inf(J)^2))*((P_local(I,J)/P_inf(J))-1)
3110 M_local(I,J)=SQRT(2/(Gamma-1)*((P_ref(J)/P_local(I,J))**((Gamma-1)/Gamma)-1))
3120 NEXT J
3130 NEXT I
3140 I
3150 !Plot Cp or M_local vs x/c below:
3160 I
3170 Plot_cpmach:I
3180 I
3190 CLEAR SCREEN
3200 I
3210 PRINT " POST PROCESSING OF Static Pressure Data"
3220 PRINT
3230 PRINT
3240 I
3250 PRINT " The following routine will plot and print P/Pt or Mach Number"
3260 PRINT " for a single scan desired or a set of seven scans."
3270 PRINT
3280 PRINT " The selections are as follows.."
3290 PRINT " 1. Plot Cp (then provide scan or scans desired)"
3300 PRINT " 2. Plot Mach Number (provide scans as above)"
3310 PRINT
3320 INPUT " Input the parameter to plot(0=P/Pt,1=Mach)",Plot_case
3330 INPUT " Input the first scan to be plotted",First_scan
3340 INPUT " Input the last scan to be plotted",Last_scan
3350 INPUT " Dump plots to Laser or Thinkjet (LJ=0,LJ=1)",Dump
3360 I
3370 IF Dump=1 THEN
3380 DUMP DEVICE IS 9
3390 ELSE

```

Figure D1. (cont) Program "READ_ZOC2"

```

3400     DUMP DEVICE IS 702
3410 END IF
3420 I
3430 !Initialize graphics environment parameters
3440 I
3450 Xo=0
3460 Yf=1
3470 Dx=10
3480 Dy=10
3490 MAT Pen= (-1) !Pen control parameter "Pen down before moving".
3500 Pen(1)=-2
3510 Pen(25)=-2 !Pen control parameter "Pen up before moving".
3520 I
3530 SELECT Plot_case
3540     CASE 0
3550         Title$="Normalized Pressure vs. Percent Chord"
3560         X_label$="x/c"
3570         Y_label$="P/Pt"
3580         Yo=0
3590         Yf=1
3600     CASE 1
3610         Title$="Mach number vs. Percent Chord"
3620         X_label$="x/c"
3630         Y_label$="Mach Number"
3640         Yo=0
3650         Yf=2
3660 END SELECT
3670 I
3680 LINE TYPE 1 !First line type
3690 N=3 !Second line type
3700 I
3710 CALL Plot !Sets up graphics background
3720 FOR J=First_scan TO Last_scan
3730 FOR I=1 TO 25
3740     SELECT Plot_case
3750         CASE 0
3760             PLOT X(I),P_normal(I,J),Pen(I)
3770         CASE 1
3780             PLOT X(I),M_local(I,J),Pen(I)
3790     END SELECT
3800 NEXT I
3810     LINE TYPE N
3820     N=N+1
3830 NEXT J
3840 I
3850 PAUSE
3860 I
3870 CLEAR SCREEN
3880 I
3890 INPUT "Would you like to make another plot (Y=yes,N=no)?",Go$
3900 IF Go$="Y" THEN Plot_cpmach
3910 I
3920 !The following routine will print P/Pt or Mach number for the scans selected
3930 I
3940 FOR P=1 TO 5
3950 PRINT
3960 NEXT P
3970 PRINT "The following will print P/Pt or Mach Number data for scans selected

```

Figure D1. (cont) Program "READ_ZOC2"


```

3980 PRINT "Select 7 scans to bracket data plotted above or any others."
3990 PRINT
4000 PRINT "The scans selected for printing must be available in the data"
4010 PRINT "is starting at scan 5 when only scans 1-7 available will results"
4020 PRINT "in ERROR 17."
4030 PRINT
4040 INPUT "Would you like to print the P/Pt or Mach Number Data (0=yes,1=no)?",
Go1$
4050 IF Go1$="N" THEN Skip_print
4060 !
4070 INPUT "Would you like to print P/Pt or Mach Number (0=P/Pt,1=Mach)?",Cp_m
4080 INPUT "Input the first of seven scans to be printed.",Fs
4090 INPUT "Print to CRT or printer(0=CRT,1=Printer)?",View
4100 !
4110 IF Cp_m=0 THEN
4120     MAT B= P_normal
4130 ELSE
4140     MAT B= M_local
4150 END IF
4160 !
4170 IF View=1 THEN PRINTER IS 702
4180 !
4190 PRINT "Port", "          Scan Number"
4200 PRINT
4210 PRINT " ",Fs,Fs+1,Fs+2,Fs+3,Fs+4,Fs+5,Fs+6
4220 PRINT
4230 FOR I=1 TO 25
4240     PRINT USING Format2;I,B(I,Fs),B(I,Fs+1),B(I,Fs+2),B(I,Fs+3),B(I,Fs+4),B
(I,Fs+5),B(I,Fs+6)
4250 NEXT I
4260 !
4270 PAUSE
4280 Skip_print: !
4290 PRINTER IS CRT
4300 DEALLOCATE Cp(*)
4310 DEALLOCATE B(*)
4320 DEALLOCATE P_local(*)
4330 DEALLOCATE P_normal(*)
4340 DEALLOCATE P_inf(*)
4350 DEALLOCATE P_ref(*)
4360 DEALLOCATE M_inf(*)
4370 DEALLOCATE M_local(*)
4380 DEALLOCATE X(*)
4390 DEALLOCATE Pen(*)
4400 KEY LABELS ON
4410 !
4420 GOTO Reset
4430 !
4440 !.....
4450 !PLOT Pt DATA AND LOAD INTO ARRAY(S) TO SAVE TO ASCII FILE
4460 !.....
4470 !
4480 Pt: !
4490 !
4500 CLEAR SCREEN
4510 !
4520 PRINT "          POST PROCESSING OF TOTAL PRESSURE DATA"
4530 PRINT
4540 PRINT

```

Figure D1. (cont) Program "READ_ZOC2"

```

4550 PRINT "      This routine will plot vertical position vs. Pt from
4560 PRINT "      the probe impact pressure and integrate losses normalized
4570 PRINT "      by inlet dynamic pressure to calculate a loss coefficient."
4580 PRINT
4590 PRINT
4600 INPUT "      Dump plots to Laser or Thinkjet (0=FI,1=LIJ).":Dump
4610 INPUT "      Maximum Recorded Plenum Temperature in deg F.":Ttmax
4620 INPUT "      Minimum Recorded Plenum Temperature in deg F.":Ttmin
4630 PRINT "      Type F2 to continue/no other inputs necessary (yet)!"
4640 PAUSE
4650 I
4660 IF Dump=1 THEN
4670     DUMP_DEVICE IS 9
4680 ELSE
4690     DUMP_DEVICE IS 702
4700 END IF
4710 I
4720 !Allocate all real variables
4730 I
4740 ALLOCATE INTEGER Pen2(1:Scan_max)
4750 ALLOCATE REAL P_ref(1:Scan_max)
4760 ALLOCATE REAL P_inf(1:Scan_max)
4770 ALLOCATE REAL P_exit(1:Scan_max)
4780 ALLOCATE REAL Y(1:Scan_max)
4790 ALLOCATE REAL Pt(1:Scan_max)
4800 ALLOCATE REAL M_inf(1:Scan_max)
4810 ALLOCATE REAL M_exit(1:Scan_max)
4820 ALLOCATE REAL Ma1(1:Scan_max)
4830 ALLOCATE REAL Ma2(1:Scan_max)
4840 ALLOCATE REAL Ma3(1:Scan_max)
4850 ALLOCATE REAL Ma4(1:Scan_max)
4860 ALLOCATE REAL Q(1:Scan_max)
4870 I
4880 Plot_pt:I
4890     I
4900 !Initialize plot parameters
4910 LINE TYPE 1
4920 Title$="Verticle Distance Traversed vs. Pt"
4930 X_label$="Total Pressure (psia)"
4940 Y_label$="Vertical Distance (in)"
4950 Xo=30
4960 Xf=60
4970 Yo=2
4980 Yf=0
4990 Dx=30
5000 Dy=32
5010 MAT Pen2= (-1)
5020 Pen2(1)=-2
5030 Pen2(Scan_max)=-2
5040 I
5050 CALL Plot           !Sets up graphics environment
5060 I
5070 !Flow quantities calculated and total pressure plotted.
5080 I
5090 Gc=32.2
5100 Rgas=53.3
5110 Ttmax=Ttmax+460
5120 Ttmin=Ttmin+460
5130 Tt=(Ttmax+Ttmin)/2

```

Figure D1. (cont) Program "READ_ZOC2"

```

5140 !
5150 FOR I=1 TO Scan_max
5160   P_inf(I)=Pa(29,I)
5170   P_exit(I)=Pa(30,I)
5180   P_ref(I)=Pa(31,I)
5190   Pt(I)=Pa(32,I)
5200   !
5210   Rhot1=144*P_ref(I)/(Rgas*Tt)
5220   Rhot2=144*Pt(I)/(Rgas*Tt)
5230   !
5240   M_inf(I)=SQRT((2/(Gamma-1))*((P_ref(I)/P_inf(I))^(1/(Gamma-1)/Gamma)-1))
5250   M_exit(I)=SQRT((2/(Gamma-1))*((Pt(I)/P_exit(I))^(1/(Gamma-1)/Gamma)-1))
5260   !
5270   T1=Tt/(1+((Gamma-1)/2)*(M_inf(I))^2)
5280   T2=Tt/(1+((Gamma-1)/2)*(M_exit(I))^2)
5290   !
5300   A1=SQRT(Gamma*Rgas*T1*Gc)
5310   A2=SQRT(Gamma*Rgas*T2*Gc)
5320   !
5330   V1=A1*M_inf(I)
5340   V2=A2*M_exit(I)
5350   !
5360   Rho1=Rhot1*(1+((Gamma-1)/2)*M_inf(I))^(-(1/(Gamma-1)))
5370   Rho2=Rhot2*(1+((Gamma-1)/2)*M_exit(I))^(-(1/(Gamma-1)))
5380   !
5390   Ma1(I)=Rho1*V1
5400   Ma2(I)=Rho2*V2
5410   Ma3(I)=Rho1*V1*P_ref(I)*144
5420   Ma4(I)=Rho2*V2*Pt(I)*144
5430   !
5440   Q(I)=P_ref(I)-P_inf(I)
5450   !
5460   Y(I)=(I-1)*Increment
5470   PLOT Pt(I),Y(I),Pen2(I)
5480 NEXT I
5490 !
5500 FOR I=1 TO Scan_max
5510 PLOT P_ref(I),Y(I),Pen2(I)
5520 NEXT I
5530 !
5540 FOR I=1 TO Scan_max
5550 PLOT P_exit(I),Y(I),Pen2(I)
5560 NEXT I
5570 !
5580 PAUSE
5590 !
5600 INPUT "Would you like to make another plot (Y=yes,N=no)?",Go$
5610 IF Go$="Y" THEN Plot_pt
5620 !
5630 CLEAR SCREEN
5640 !
5650 PRINT
5660 PRINT
5670 DISP "Now calculating cascade loss coefficient"
5680 !
5690 Rhov1=0 'Initialize totaling variables
5700 Rhov2=0

```

Figure D1. (cont) Program "READ_ZOC2"

```

5710 Rhovpt1=0
5720 Rhovpt2=0
5730 Qin=0
5740 I
5750 FOR I=1 TO Scan_max      !Total mass averaging quantities
5760     Rhov1=Rhov1+Ma1(I)
5770     Rhov2=Rhov2+Ma2(I)
5780     Rhovpt1=Rhovpt1+Ma3(I)
5790     Rhovpt2=Rhovpt2+Ma4(I)
5800     Qin=Qin+Q(I)
5810 NEXT I
5820 I
5830 Avg1=Rhov1/Scan_max
5840 Avg2=Rhov2/Scan_max
5850 Avg3=Rhovpt1/Scan_max
5860 Avg4=Rhovpt2/Scan_max
5870 Avg5=Qin/Scan_max
5880 I
5890 Ptma1=Avg3/(Avg1*144)
5900 Ptma2=Avg4/(Avg2*144)
5910 Qavg=Avg5
5920 W_bar=(Ptma1-Ptma2)/Qavg
5930 I
5940 INPUT "Print Losses to CRT or Printer (0-CRT,1-PRINTER)",Lossp
5950 IF Lossp=1 THEN PRINTER IS 702
5960 I
5970 FOR I=1 TO 5
5980 PRINT
5990 NEXT I
6000 I
6010 PRINT "      The cascade loss coefficient based on inlet "
6020 PRINT "      dynamic pressure as calculated using      "
6030 PRINT "      mass averaged quantities as shown below."
6040 PRINT
6050 PRINT
6060 PRINT
6070 PRINT "      Ptma1 = ";Ptma1;" PSIA"
6080 PRINT "      Ptma2 = ";Ptma2;" PSIA"
6090 PRINT
6100 PRINT "      Ptl-P1 = ";Qavg;" PSIA"
6110 PRINT "      Ttavg = ";Tt;" deg R"
6120 PRINT
6130 PRINT "      W_bar = ";W_bar
6140 PRINT
6150 DISP "      Type F2 to return to main menu"
6160 PAUSE
6170 !Deallocate all real variables
6180 I
6190 DEALLOCATE Pen2(*)
6200 DEALLOCATE P_inf(*)
6210 DEALLOCATE P_exit(*)
6220 DEALLOCATE P_ref(*)
6230 DEALLOCATE M_inf(*)
6240 DEALLOCATE M_exit(*)
6250 DEALLOCATE Ma1(*)
6260 DEALLOCATE Ma2(*)
6270 DEALLOCATE Ma3(*)

```

Figure D1. (cont) Program "READ_ZOC2"

```

6280 DEALLOCATE Ha4(*)
6290 DEALLOCATE Q(*)
6300 DEALLOCATE P(*)
6310 DEALLOCATE Y(*)
6320 KEY LABELS ON
6330 PRINTER IS CRT
6340 I
6350 GOTO Reset
6360 I
6370 I*****
6380 EXIT PROGRAM AND DEALLOCATE ALL BUFFERS AND PATHS
6390 I*****
6400 I
6410 Deallocate: I
6420 ASSIGN @Data_path1 TO *
6430 ASSIGN @Data_path2 TO *
6440 DEALLOCATE Cal(*)
6450 DEALLOCATE Data(*)
6460 DEALLOCATE Pa(*)
6470 RETURN
6480 I
6490 Finish: I
6500 IF Allocated=1 THEN GOSUB Deallocate
6510 PRINTER IS CRT
6520 LOAD "ZOC_MENU",10
6530 END
6540 I
6550 I*****
6560 !SUBROUTINE TO SET UP GRAPHICS WINDOW
6570 I*****
6580 I
6590 SUB Plot
6600 I
6610 !Subroutine to display plot screens, less the plot of any curves
6620 !for the specified variables in the COM/Plot_labels/ line.
6630 I
6640 COM /Plot_labels/ Xo,Xf,Yo,Yf,Dx,Dy,Title$,X_label$,Y_label$
6650 CLEAR SCREEN
6660 KEY LABELS OFF
6670 GINIT
6680 X_range=Xf-Xo
6690 Y_range=Yf-Yo
6700 LOG 6
6710 MOVE 100*RATIO/2,100
6720 CSIZE 3
6730 LABEL Title$
6740 MOVE 100*RATIO/2,0
6750 LOG 4
6760 LABEL X_label$
6770 DEG
6780 LDIR 90
6790 LOG 6
6800 MOVE 0,50
6810 LABEL Y_label$
6820 LDIR 0
6830 LOG 2
6840 VIEWPORT 10,90*RATIO,10,90

```

!Initialize graph routine
!Length of X-axis
!Length of Y-axis
!Character ref pt:top center
!Move cursor to screen loc for labels
!Sizes labeling
!Plot title
!Move cursor to bottom center screen
!Character ref pt:bottom center
!X-axis label
!Desig degrees for LDIR
!Sets Y-axis label on end
!Y-axis label
!Reset label to horizontal orientation
!Chr ref pt:left center
!Sets graph screen size

Figure D1. (cont) Program "READ_ZOC2"

```

6850 FRAME                                !Box around viewport
6860 WINDOW Xo,Xf,Yo,Yf                  !set axis lengths in VIEWPORT
6870 AXES X_range/Dx,Y_range/Dy,Xo,Yo    !Axes intersect at lower left
6880 AXES X_range/Dx,Y_range/Dy,Xf,Yf    !Axes intersect at upper right
6890 GRID X_range/Dx,Y_range/Dy,Xo,Yo,Dx,Dy,.001
6900 CLIP OFF                             !So labels can print outside VIEWPORT
6910 CSIZE 3,0,.4                         !Axes label size
6920 LOG 6                                 !Number X axis
6930 FOR I=Xo TO Xf STEP X_range/Dx
6940     MOVE I,Xo-.01*Y_range
6950     LABEL USING "#,K":I
6960 NEXT I
6970 LOG 8
6980 FOR I=Yo TO Yf STEP Y_range/Dy
6990     IF ABS(I)-1.0E-5 THEN I=0.
7000     MOVE Xo-.01*X_range,I
7010     LABEL USING "#,K":I
7020 NEXT I
7030 CLIP ON
7040 I
7050 SUBEND
7060 I
7070 SUB Square(Xo,Xf,Yo,Yf,Sc)
7080 !Subroutine to plot squares around the local origin designated
7090 !by the PLOT statement.
7100 Xd=Sc*(Xf-Xo)
7110 Yd=Sc*(Yf-Yo)*RATIO
7120 RPLOT -Xd,Yd,-2
7130 RPLOT Xd,Yd,-1
7140 RPLOT Xd,-Yd,-1
7150 RPLOT -Xd,-Yd,-1
7160 RPLOT -Xd,Yd,2
7170 SUBEND

```

Figure D1. (cont) Program "READ_ZOC2"

APPENDIX E. SELECTED DATA

Data Print Out for Zoc # 1 , Run # 3 , FileZR1211163

Period between samples (sec): .0033333333333333

Sample collection rate (Hz): 300

Number of samples per port: 10

Length of data run (sec): 34.1

The scan type is: 2

Number of scans/traverses: 33

Increment of traverse: .0625 Inches

Atmospheric pressure is: 14.71 psia

Tunnel Pressure Ratio is: 2.03894334573

Scan	Port Number						
	1	2	3	4	5	6	7
1	17.386	16.838	17.049	17.616	19.135	21.167	23.343
2	17.335	16.784	17.137	17.687	19.714	22.121	24.331
3	17.365	16.730	17.093	17.738	19.564	22.414	24.279
4	17.447	16.849	17.104	17.596	19.225	21.701	23.497
5	17.335	16.741	17.071	17.667	19.614	21.764	23.487
6	17.365	16.827	16.927	17.291	18.696	20.569	23.219
7	17.417	16.784	17.026	17.281	19.155	21.921	23.229
8	17.233	16.676	16.960	17.372	18.536	20.423	22.601
9	17.335	16.784	16.993	17.433	18.856	21.607	23.466
10	17.345	16.687	16.905	17.251	18.496	20.087	22.303
11	17.345	16.773	16.971	17.525	19.175	21.576	23.137
12	17.345	16.773	17.004	17.423	18.866	21.083	23.065
13	17.294	16.752	16.882	17.454	19.065	21.796	23.898
14	17.314	16.719	16.938	17.332	19.045	20.936	22.828
15	17.273	16.687	16.905	17.393	19.065	20.517	21.912
16	17.314	16.665	16.882	17.342	19.025	21.030	22.848
17	17.253	16.687	16.960	17.433	19.025	21.219	23.497
18	17.243	16.698	16.938	17.484	18.826	20.810	22.818
19	17.314	16.676	16.893	17.240	18.397	20.863	21.870
20	17.171	16.665	16.893	17.504	19.205	21.083	22.210
21	17.222	16.655	16.871	17.230	18.656	21.041	23.209
22	17.243	16.709	16.860	17.281	18.616	20.454	22.159
23	17.263	16.622	16.871	17.383	18.736	21.293	23.023
24	17.089	16.525	16.916	17.444	18.636	20.265	21.973
25	17.130	16.633	16.794	17.118	19.526	20.485	21.901
26	17.273	16.644	16.794	17.220	18.616	20.590	21.912
27	17.345	16.752	16.794	17.139	18.496	20.328	21.603
28	17.294	16.730	16.882	17.342	19.936	20.685	22.251
29	17.284	16.676	16.860	17.352	18.706	20.319	22.416
30	17.192	16.601	16.849	17.342	18.496	20.538	22.591
31	17.202	16.687	16.805	17.159	18.247	20.569	22.334
32	17.212	16.644	16.905	17.342	19.015	20.972	23.044
33	17.130	16.568	16.827	17.525	19.514	21.345	23.641

Figure E1. Run 3, 16 Nov 1992 (Raw Data)

Scan	Port Number						
	8	9	10	11	12	13	14
1	25.048	25.629	27.054	27.503	27.917	28.289	28.424
2	24.934	25.459	26.479	27.234	27.792	28.071	28.281
3	25.670	26.247	27.129	27.340	27.754	28.147	28.585
4	25.483	26.383	26.804	27.282	27.965	28.176	28.452
5	24.571	25.505	26.609	27.089	27.869	28.157	28.538
6	24.809	26.066	26.962	27.465	27.591	27.939	28.481
7	24.519	25.188	25.858	26.743	27.360	27.834	28.034
8	24.001	25.804	26.192	26.955	27.465	27.959	28.395
9	24.706	24.907	26.025	26.772	27.744	28.308	28.348
10	24.115	25.351	26.090	27.003	27.562	27.853	28.024
11	24.498	24.951	26.294	27.291	27.859	28.081	28.319
12	24.343	25.296	26.322	27.128	27.533	28.005	28.281
13	24.913	25.496	26.072	26.839	27.619	28.005	28.414
14	24.540	26.166	26.637	27.128	27.821	27.787	27.967
15	23.762	24.925	26.229	26.897	27.591	27.806	28.129
16	24.343	25.496	26.730	27.465	27.783	28.128	28.224
17	24.374	25.668	26.294	26.916	27.475	27.920	28.376
18	24.042	25.405	26.137	26.541	27.303	27.929	28.243
19	23.026	23.667	25.181	26.435	27.303	27.967	28.357
20	23.856	25.794	26.201	26.859	27.216	27.560	27.948
21	25.069	26.302	26.480	27.176	27.629	27.986	28.186
22	24.208	26.220	26.693	27.051	27.619	28.043	28.443
23	24.364	25.405	26.007	26.474	27.312	27.863	28.471
24	23.493	24.961	25.534	26.301	26.957	27.304	27.910
25	23.368	24.907	25.914	26.849	27.293	27.550	27.986
26	24.156	25.831	26.674	27.070	27.485	27.806	28.148
27	22.736	24.499	26.174	27.349	27.581	27.787	28.395
28	23.203	24.835	25.775	26.685	27.139	27.304	27.540
29	24.260	25.514	26.489	27.109	27.427	27.654	27.901
30	23.887	24.690	25.775	26.753	27.312	27.474	27.568
31	24.073	25.677	26.433	27.147	27.677	27.977	28.129
32	24.612	25.858	26.544	26.916	27.447	27.683	27.910
33	24.239	24.961	25.942	26.840	27.255	27.853	27.996

Figure E1. (cont) Run 3, 16 Nov 1992 (Raw Data)

Scan	Port Number						
	15	16	17	18	19	20	21
1	28.732	28.870	29.052	29.180	29.820	30.267	30.563
2	28.553	28.905	29.104	29.345	30.049	30.295	30.504
3	28.722	28.922	29.061	29.337	29.961	30.139	30.413
4	28.722	29.054	29.312	29.475	29.996	30.368	30.579
5	28.862	28.861	28.905	29.189	29.917	30.194	30.413
6	28.623	28.975	29.104	29.267	30.058	30.184	30.496
7	28.712	29.054	29.269	29.206	29.811	30.386	30.563
8	28.613	28.922	29.382	29.205	29.758	30.267	30.771
9	28.752	29.019	29.156	29.250	29.846	30.065	30.488
10	28.244	28.528	28.775	29.206	29.973	30.194	30.363
11	28.702	28.878	29.026	29.016	29.599	29.955	30.313
12	28.483	28.826	28.957	29.232	29.820	30.038	30.338
13	28.643	28.791	28.983	29.189	29.767	30.111	30.446
14	28.174	28.659	29.061	29.163	29.476	29.790	30.213
15	28.293	28.545	28.957	29.180	29.590	30.166	30.496
16	28.513	28.686	28.957	29.215	29.732	30.026	30.246
17	28.493	28.686	29.009	29.033	29.820	30.074	30.254
18	28.662	28.826	28.983	29.154	29.705	30.038	30.388
19	28.573	28.624	28.870	29.128	29.643	30.285	30.346
20	28.423	28.554	28.983	29.163	29.626	30.276	30.288
21	28.473	28.598	29.052	29.120	29.687	29.982	30.396
22	28.333	28.642	28.705	28.816	29.590	29.982	30.196
23	28.214	28.466	28.671	29.120	29.679	29.973	30.246
24	28.293	28.388	28.723	29.059	29.476	29.680	30.213
25	28.383	28.878	29.165	28.894	29.493	30.028	30.354
26	28.353	28.449	28.723	28.990	29.785	30.010	30.113
27	28.772	28.808	28.827	29.224	29.802	30.001	30.321
28	28.293	28.554	28.827	29.085	29.732	30.138	30.379
29	28.124	28.528	28.766	28.808	29.802	30.010	30.396
30	27.824	28.379	28.870	28.990	29.617	30.065	30.338
31	28.463	28.466	28.792	29.076	29.537	29.918	30.246
32	28.204	28.493	28.766	29.120	29.590	30.010	30.313
33	28.313	28.624	28.861	28.825	29.617	29.845	30.163


Figure E1. (cont) Run 3, 16 Nov 1992 (Raw Data)

Scan	Port Number						
	22	23	24	25	26	27	28
1	30.820	31.615	32.730	34.161	24.450	27.585	23.366
2	30.988	31.735	32.815	34.352	25.078	27.804	23.719
3	30.887	31.777	32.858	34.352	24.714	27.664	23.299
4	31.038	31.752	32.807	34.334	24.135	27.462	23.215
5	30.871	31.667	32.764	34.280	23.963	27.401	22.929
6	30.745	31.667	32.738	34.298	23.993	27.559	23.324
7	30.837	31.718	32.730	34.180	23.729	27.295	23.181
8	30.963	31.658	32.747	34.216	23.750	27.234	22.803
9	30.770	31.581	32.687	34.216	23.242	27.015	22.560
10	30.787	31.615	32.764	34.152	24.592	27.506	23.072
11	30.610	31.505	32.678	34.152	23.679	27.173	22.308
12	30.762	31.573	32.627	34.170	23.811	27.664	23.072
13	30.594	31.752	32.670	34.152	23.638	26.681	22.299
14	30.778	31.564	32.713	34.134	23.577	27.065	22.551
15	30.678	31.581	32.695	34.180	23.851	27.120	22.484
16	30.761	31.650	32.661	34.052	24.135	27.295	22.719
17	30.669	31.471	32.670	34.043	24.186	27.146	22.845
18	30.644	31.479	32.670	33.988	23.587	26.532	22.224
19	30.543	31.752	32.653	34.189	23.293	26.936	22.224
20	30.627	31.479	32.584	34.099	23.669	27.067	22.501
21	30.845	31.624	32.601	34.125	23.618	27.146	22.518
22	30.585	31.692	32.524	33.943	23.466	27.304	22.686
23	30.711	31.650	32.507	34.079	23.719	27.024	22.375
24	30.669	31.650	32.413	33.988	22.847	27.120	21.980
25	30.602	31.684	32.541	34.034	22.634	26.637	21.955
26	30.661	31.547	32.567	33.943	23.080	26.953	22.366
27	30.627	31.650	32.721	34.107	23.557	26.980	22.560
28	30.585	31.530	32.601	34.180	22.603	26.752	22.039
29	30.636	31.598	32.661	34.189	24.044	27.304	22.677
30	30.585	31.505	32.644	34.125	23.851	27.164	22.686
31	30.736	31.539	32.653	34.189	23.100	26.945	22.257
32	30.694	31.505	32.576	34.098	23.760	27.331	22.803
33	30.585	31.513	32.464	34.043	24.328	27.374	22.963

Figure E1. (cont) Run 3, 16 Nov 1992 (Raw Data)

Scan	Port Number			
	29	30	31	32
1	17.552	35.788	54.559	51.851
2	17.614	35.845	54.615	51.950
3	17.623	35.854	54.523	52.210
4	17.614	35.863	54.680	52.561
5	17.561	35.807	54.671	52.598
6	17.561	35.798	54.584	52.776
7	17.561	35.882	54.636	52.875
8	17.472	36.024	54.576	52.776
9	17.561	35.769	54.593	52.678
10	17.499	35.727	54.497	52.201
11	17.543	35.693	54.576	51.419
12	17.534	35.778	54.515	48.987
13	17.525	35.684	54.549	46.850
14	17.534	35.722	54.575	44.132
15	17.561	35.684	54.515	40.756
16	17.517	35.599	54.480	38.864
17	17.481	35.618	54.429	37.386
18	17.561	35.712	54.445	36.567
19	17.543	35.655	54.480	35.963
20	17.508	35.608	54.375	35.675
21	17.534	35.551	54.462	35.585
22	17.428	35.561	54.436	35.576
23	17.366	35.693	54.793	35.649
24	17.357	35.608	54.793	35.558
25	17.419	35.514	54.636	35.549
26	17.445	35.570	54.584	35.594
27	17.588	35.504	54.619	35.594
28	17.677	35.684	54.549	35.648
29	17.632	35.551	54.471	35.558
30	17.597	35.665	54.410	35.549
31	17.543	35.627	54.488	35.558
32	17.543	35.636	54.567	35.513
33	17.481	35.580	54.340	35.486

Figure E1. (cont) Run 3, 16 Nov 1992 (Raw Data)



Port	Scan Number						
	10	11	12	13	14	15	16
1	.318	.318	.318	.317	.317	.317	.318
2	.306	.307	.308	.307	.306	.306	.306
3	.310	.311	.312	.309	.310	.310	.310
4	.317	.321	.320	.320	.318	.319	.318
5	.339	.351	.346	.350	.349	.350	.349
6	.369	.395	.387	.400	.384	.376	.386
7	.409	.424	.423	.438	.418	.402	.419
8	.442	.449	.447	.457	.450	.436	.447
9	.465	.457	.464	.467	.479	.457	.468
10	.479	.482	.483	.478	.489	.481	.491
11	.495	.500	.498	.492	.497	.493	.504
12	.506	.510	.505	.506	.510	.506	.510
13	.511	.515	.514	.513	.509	.510	.516
14	.514	.519	.519	.521	.512	.516	.519
15	.518	.526	.522	.525	.516	.519	.523
16	.523	.529	.529	.528	.525	.524	.527
17	.528	.532	.531	.531	.532	.531	.532
18	.536	.532	.536	.535	.534	.535	.536
19	.548	.542	.547	.546	.540	.543	.546
20	.554	.549	.551	.552	.546	.553	.551
21	.557	.555	.557	.558	.554	.559	.555
22	.565	.561	.564	.561	.561	.563	.565
23	.580	.577	.579	.582	.578	.579	.581
24	.601	.599	.598	.599	.599	.600	.600
25	.627	.626	.627	.626	.625	.627	.625

Figure E1. (cont) Run 3, 16 Nov 1992 (P/Pt Distribution)




Figure E1. (cont) Run 3, 16 Nov 1992 (Loss Distribution)

Data Print Out for Zoc # 1 , Run # 4 , FileZR1211194
 Period between samples (sec): .003333333333333
 Sample collection rate (Hz): 300
 Number of samples per port: 10
 Length of data run (sec): 34.1
 The scan type is: 3
 Number of scans/traverses: 33
 Increment of traverse: .0625 Inches
 Atmospheric pressure is: 14.75 psia
 Tunnel Pressure Ratio is: 2.1400325976

Scan	Port Number						
	1	2	3	4	5	6	7
1	17.201	16.711	25.960	26.681	27.411	28.041	28.310
2	17.222	16.647	25.882	26.549	27.452	27.729	28.114
3	17.191	16.647	25.860	26.620	27.341	27.695	28.073
4	17.232	16.679	25.971	26.722	27.361	27.926	28.248
5	17.242	16.668	25.860	26.569	27.391	27.789	28.207
6	17.048	16.625	25.794	26.569	27.331	27.726	28.145
7	17.099	16.722	25.993	26.823	27.492	27.810	28.073
8	17.181	16.701	26.048	26.671	27.351	27.947	28.434
9	17.303	16.754	26.026	26.813	27.522	27.968	28.269
10	17.140	16.787	25.993	26.701	27.270	27.758	28.269
11	17.171	16.668	26.070	26.742	27.361	27.737	28.238
12	17.120	16.765	26.015	26.793	27.502	27.873	28.279
13	17.130	16.711	26.015	26.803	27.613	27.852	28.155
14	17.150	16.711	25.971	26.661	27.281	27.769	28.207
15	17.130	16.701	25.882	26.518	27.170	27.684	28.269
16	17.089	16.679	25.915	26.793	27.502	27.926	28.372
17	17.130	16.776	26.170	26.803	27.442	27.810	28.124
18	17.120	16.668	25.760	26.732	27.361	27.852	28.310
19	17.201	16.733	26.181	26.742	27.341	27.663	28.176
20	17.130	16.797	25.926	26.701	27.401	27.779	28.166
21	17.069	16.733	26.269	26.884	27.361	27.789	28.104
22	17.120	16.679	25.949	26.752	27.361	27.789	28.207
23	17.059	16.625	25.860	26.712	27.361	27.800	28.424
24	17.099	16.744	26.037	26.773	27.462	27.894	28.289
25	17.181	16.744	25.926	26.600	27.361	27.999	28.186
26	17.079	16.528	26.148	26.742	27.361	27.842	28.114
27	16.987	16.776	25.993	26.569	27.220	27.590	28.114
28	17.120	16.690	25.849	26.691	27.391	27.779	28.228
29	17.008	16.754	25.860	26.651	27.462	27.789	28.145
30	17.008	16.765	26.070	26.630	27.311	27.800	28.114
31	17.150	16.916	26.203	26.945	27.562	27.852	28.331
32	17.038	16.776	26.070	26.630	27.351	27.653	28.073
33	17.059	16.701	26.026	26.651	27.371	27.789	28.104

Figure E2. Run 4, 19 Nov 1992 (Raw Data)

Scan	Port Number						
	8	9	10	11	12	13	14
1	28.408	28.656	28.970	29.279	29.764	29.957	30.216
2	28.419	28.792	29.063	29.394	29.810	30.071	30.283
3	28.419	28.692	29.072	29.318	29.879	30.130	30.388
4	28.429	28.819	29.081	29.356	29.869	30.033	30.283
5	28.471	28.828	29.146	29.337	29.802	30.119	30.378
6	28.356	28.674	29.026	29.279	29.840	30.005	30.273
7	28.336	28.538	29.026	29.414	29.860	30.214	30.426
8	28.585	28.819	29.942	29.097	29.831	30.147	30.321
9	28.481	28.810	28.942	29.385	29.898	30.037	30.369
10	28.564	28.910	29.127	29.298	29.677	29.900	30.283
11	28.481	28.873	29.127	29.241	29.696	29.881	30.064
12	28.471	28.846	28.961	29.231	29.860	29.805	30.150
13	28.408	28.638	29.035	29.308	29.812	30.129	30.159
14	28.491	28.828	29.137	29.212	29.648	29.976	30.235
15	28.429	28.855	28.998	29.250	29.725	29.672	30.254
16	28.502	28.728	28.979	29.222	29.648	29.814	30.150
17	28.419	28.674	28.933	29.327	29.620	29.900	30.159
18	28.439	28.647	29.137	29.385	29.975	30.014	30.311
19	28.512	28.719	29.109	29.366	29.773	29.957	30.150
20	28.315	28.665	29.118	29.318	29.773	30.005	30.273
21	28.263	28.629	28.942	29.183	29.773	29.976	30.016
22	28.419	28.647	28.970	29.126	29.716	29.919	30.216
23	28.429	28.710	28.933	29.250	29.850	29.814	30.159
24	28.419	28.783	28.914	29.270	29.725	29.795	30.073
25	28.356	28.620	28.886	29.241	29.581	29.643	29.949
26	28.408	28.601	29.090	29.318	29.620	29.891	29.969
27	28.419	28.765	28.961	29.231	29.600	29.795	30.188
28	28.491	28.828	29.090	29.116	29.524	29.862	30.235
29	28.253	28.592	28.979	29.356	29.773	29.979	30.150
30	28.471	28.701	28.970	29.250	29.764	30.062	30.264
31	28.377	28.837	29.081	29.087	29.543	29.767	30.111
32	28.419	28.728	29.072	29.154	29.620	29.833	30.102
33	28.377	28.574	29.063	29.366	29.677	29.976	30.140

Figure E2. (cont) Run 4, 19 Nov 1992 (Raw Data)

Scan	Port Number						
	15	16	17	18	19	20	21
1	30.333	30.593	30.706	31.016	31.636	32.129	32.302
2	30.523	30.584	30.879	31.008	31.495	31.913	32.369
3	30.453	30.760	31.044	31.008	31.433	32.005	32.444
4	30.343	30.900	30.965	30.938	31.675	32.051	32.260
5	30.513	30.576	30.792	31.016	31.477	31.931	32.444
6	30.583	30.654	30.879	31.034	31.451	31.885	32.461
7	30.623	30.803	30.879	30.999	31.654	32.216	32.544
8	30.363	30.514	30.671	30.999	31.530	32.008	32.595
9	30.423	30.725	31.079	31.190	31.689	32.069	32.377
10	30.543	30.681	31.035	31.129	31.459	31.876	32.318
11	30.393	30.584	30.879	31.025	31.583	32.005	32.394
12	30.393	30.505	30.801	30.869	31.583	31.894	32.327
13	30.403	30.584	30.853	31.051	31.565	32.051	32.427
14	30.603	30.725	30.905	30.790	31.433	32.134	32.427
15	30.583	30.733	30.957	31.042	31.495	31.720	32.158
16	30.383	30.523	30.706	30.929	31.530	31.950	32.394
17	30.363	30.514	30.714	30.947	31.451	31.958	32.268
18	30.523	30.444	30.714	30.999	31.433	31.830	32.352
19	30.293	30.479	31.018	30.921	31.424	31.950	32.335
20	30.273	30.593	30.896	30.938	31.565	31.859	32.226
21	30.373	30.663	30.740	30.903	31.549	32.014	32.344
22	30.373	30.567	30.740	30.808	31.539	31.775	32.218
23	30.383	30.523	30.749	30.764	31.504	31.913	32.377
24	30.353	30.584	30.801	30.860	31.592	31.959	32.377
25	30.204	30.418	30.706	30.877	31.380	31.922	32.151
26	30.263	30.383	30.402	30.955	31.256	31.830	32.143
27	30.323	30.444	30.558	30.877	31.247	31.793	32.335
28	30.443	30.628	30.775	30.843	31.519	31.858	32.302
29	30.393	30.523	30.836	30.912	31.504	31.931	32.159
30	30.493	30.479	30.723	30.877	31.203	31.793	32.134
31	30.393	30.654	30.957	31.016	31.415	31.894	32.318
32	30.353	30.453	30.792	31.060	31.336	31.931	32.235
33	30.643	30.453	30.853	31.051	31.283	32.014	32.226


Figure E2. (cont) Run 4, 19 Nov 1992 (Raw Data)

Scan	Port Number						
	22	23	24	25	26	27	28
1	32.775	33.109	34.261	35.543	28.090	30.333	25.986
2	32.581	33.219	34.295	35.607	28.373	30.350	26.071
3	32.707	33.194	34.338	35.716	28.231	30.368	25.878
4	32.632	33.160	34.372	35.589	28.120	30.210	25.827
5	32.657	33.177	34.218	35.589	28.231	30.289	25.945
6	32.783	33.160	34.269	35.443	28.231	30.368	25.978
7	32.909	33.271	34.449	35.680	28.414	30.614	26.071
8	32.808	33.202	34.338	35.598	28.211	30.403	26.155
9	32.758	33.211	34.398	35.707	28.444	30.342	25.752
10	32.640	33.134	34.295	35.561	28.566	30.465	25.911
11	32.682	33.211	34.338	35.607	28.353	30.280	26.071
12	32.699	33.134	34.235	35.625	28.424	30.307	25.962
13	32.615	33.143	34.381	35.580	28.323	30.306	25.852
14	32.766	33.151	34.355	35.443	28.383	30.350	25.894
15	32.564	33.228	34.278	35.680	28.323	30.280	25.903
16	32.758	33.168	34.364	35.589	28.242	30.227	25.920
17	32.615	33.185	34.355	35.607	28.424	30.456	25.760
18	32.699	33.219	34.286	35.470	28.191	30.254	25.953
19	32.598	33.262	34.321	35.652	28.312	30.377	26.012
20	32.716	33.049	34.364	35.525	28.282	30.430	25.878
21	32.724	33.075	34.312	35.543	28.302	30.315	25.903
22	32.707	33.168	34.295	35.589	28.383	30.342	25.920
23	32.657	33.092	34.304	35.416	28.353	30.236	25.651
24	32.615	33.109	34.286	35.470	28.292	30.500	25.861
25	32.573	33.109	34.381	35.680	28.373	30.377	25.970
26	32.472	33.143	34.149	35.489	28.130	30.025	25.785
27	32.463	33.066	34.201	35.407	28.302	30.307	25.869
28	32.564	33.117	34.209	35.388	28.333	30.254	25.668
29	32.480	33.049	34.338	35.534	28.515	30.227	25.945
30	32.623	33.126	34.312	35.479	28.211	30.421	26.037
31	32.606	33.219	34.346	35.398	28.434	30.315	25.617
32	32.724	33.109	34.235	35.552	28.292	30.430	25.777
33	32.581	33.134	34.209	35.716	28.535	30.456	25.928

Figure E2. (cont) Run 4, 19 Nov 1992 (Raw Data)


Scan	Port Number			
	29	30	31	32
1	17.289	36.999	54.332	50.809
2	17.316	37.066	54.430	50.619
3	17.253	37.056	54.279	50.637
4	17.280	37.113	54.279	50.619
5	17.351	36.999	54.341	50.755
6	17.405	36.980	54.323	50.646
7	17.485	36.999	54.323	50.691
8	17.342	37.046	54.270	50.682
9	17.333	37.075	54.395	50.791
10	17.298	36.951	54.359	50.854
11	17.369	37.018	54.421	51.181
12	17.298	36.941	54.323	51.325
13	17.351	36.951	54.359	51.199
14	17.369	36.913	54.296	50.429
15	17.218	37.056	54.430	48.165
16	17.431	36.884	54.305	45.594
17	17.307	37.037	54.510	43.377
18	17.396	37.018	54.359	43.640
19	17.333	36.970	54.323	49.052
20	17.467	36.941	54.456	51.588
21	17.351	36.855	54.350	51.679
22	17.405	36.884	54.474	51.733
23	17.324	36.846	54.332	51.543
24	17.476	36.941	54.341	51.570
25	17.307	36.874	54.243	51.561
26	17.235	36.989	54.003	51.461
27	17.333	36.760	54.181	51.516
28	17.431	36.817	54.376	51.733
29	17.360	36.827	54.314	51.606
30	17.449	36.865	54.456	52.014
31	17.387	36.769	54.323	51.878
32	17.405	36.865	54.483	51.670
33	17.253	37.094	54.056	50.972

Figure E2. (cont) Run 4, 19 Nov 1992 (Raw Data)



Port	Scan Number						
	11	12	13	14	15	16	17
1	.316	.315	.315	.316	.315	.315	.314
2	.306	.309	.307	.308	.307	.307	.308
3	.479	.479	.479	.478	.476	.477	.480
4	.491	.493	.493	.491	.487	.493	.492
5	.503	.506	.508	.502	.499	.506	.503
6	.510	.513	.512	.511	.509	.514	.510
7	.519	.521	.518	.519	.519	.522	.516
8	.523	.524	.523	.525	.522	.525	.521
9	.531	.531	.527	.531	.530	.529	.526
10	.535	.533	.534	.537	.533	.534	.531
11	.537	.538	.539	.538	.537	.538	.538
12	.546	.550	.540	.546	.546	.546	.543
13	.549	.549	.554	.552	.545	.549	.549
14	.552	.555	.555	.557	.556	.555	.553
15	.558	.559	.559	.564	.562	.559	.557
16	.562	.562	.563	.566	.565	.562	.560
17	.567	.567	.568	.569	.569	.565	.563
18	.570	.568	.571	.567	.570	.570	.568
19	.580	.581	.581	.579	.579	.581	.577
20	.588	.587	.590	.592	.588	.589	.584
21	.595	.595	.597	.597	.591	.597	.592
22	.601	.602	.600	.603	.598	.603	.598
23	.610	.610	.610	.611	.610	.611	.609
24	.631	.630	.632	.633	.630	.633	.630
25	.654	.656	.655	.653	.656	.655	.653

Figure E2. (cont) Run 4, 19 Nov 1992 (P/Pt Distribution)



The cascade loss coefficient based on inlet dynamic pressure as calculated using mass averaged quantities as shown below.

Ptma1 = 54.3345292679 PSIA
 Ptma2 = 50.6123122685 PSIA
 Pt1-P1 = 36.9826244479 PSIA
 Ttavg = 511 deg R
 W_bar = .100647724572

Figure E2. (cont) Run 4, 19 Nov 1992 (Loss Distribution)

Data Print Out for Zec # 1 , Run # 2 , FileZRI1210017
 Period between samples (sec): .0033333333333333
 Sample collection rate (Hz): 300
 Number of samples per port: 10
 Length of data run (sec): 34.1
 The scan type is: 3
 Number of scans/traverses: 33
 Increment of traverse: .0625 inches
 Atmospheric pressure is: 14.725 psia
 Tunnel Pressure Ratio is: 2.09968174398

Scan	Port Number						
	1	2	3	4	5	6	7
1	18.311	18.602	18.663	20.067	23.040	25.376	27.196
2	18.321	18.591	18.697	19.757	22.820	25.114	26.168
3	18.372	18.655	18.619	19.828	22.181	24.643	26.373
4	18.331	18.666	18.619	19.747	22.361	25.124	26.435
5	18.311	18.591	18.486	19.076	21.652	24.643	26.785
6	18.331	18.613	18.541	19.330	22.231	24.674	26.795
7	18.362	18.613	18.686	19.696	22.331	24.464	25.931
8	18.331	18.591	18.486	18.853	21.203	23.543	25.818
9	18.300	18.602	18.541	19.219	21.672	24.381	25.900
10	18.300	18.570	18.486	19.279	22.002	24.433	26.209
11	18.280	18.602	18.430	19.076	21.293	24.339	26.332
12	18.259	18.462	18.563	19.584	22.102	24.391	26.127
13	18.219	18.516	18.552	19.371	22.231	24.779	26.229
14	18.270	18.580	18.508	19.493	22.251	24.234	26.137
15	18.259	18.559	18.552	19.137	21.872	24.224	26.137
16	18.311	18.623	18.586	19.005	21.074	23.270	25.623
17	18.229	18.570	18.508	19.239	21.293	23.826	25.756
18	18.208	18.495	18.441	19.229	21.732	24.527	26.301
19	18.290	18.537	18.452	18.995	21.263	23.815	25.839
20	18.259	18.473	18.519	19.422	21.922	24.412	26.127
21	18.188	18.548	18.630	19.269	21.642	24.758	26.322
22	18.219	18.441	18.530	19.290	22.421	24.737	26.096
23	18.188	18.409	18.419	19.117	21.503	23.794	25.767
24	18.147	18.484	18.475	19.188	21.682	23.920	25.643
25	18.126	18.441	18.419	18.914	21.293	24.349	26.075
26	18.147	18.559	18.386	19.158	21.523	24.014	25.900
27	18.188	18.323	18.408	19.117	21.602	23.951	25.859
28	18.106	18.462	18.430	19.005	21.902	24.192	25.777
29	18.085	18.301	18.475	19.747	22.421	24.307	25.664
30	18.147	18.323	18.464	19.290	21.552	24.108	26.353
31	18.075	18.452	18.552	19.615	22.351	25.020	26.404
32	18.004	18.312	18.408	19.310	21.483	24.035	25.674
33	18.075	18.430	18.297	19.676	22.231	24.758	26.332

Figure E3. Run 2, 1 Dec 1992 (Raw Data)

Scan	Port Number						
	8	9	10	11	12	13	14
1	27.965	28.331	28.827	29.653	29.807	30.106	30.473
2	27.903	28.638	29.031	29.489	29.836	30.101	30.188
3	27.768	28.376	28.836	29.307	29.616	30.139	30.369
4	27.550	28.349	28.883	29.432	29.855	30.215	30.416
5	27.768	28.313	29.040	29.432	29.740	30.034	30.330
6	27.747	28.267	28.660	29.125	29.817	29.987	30.140
7	27.311	28.385	28.725	29.144	29.707	30.109	30.235
8	27.456	28.159	28.799	29.441	29.740	30.044	30.235
9	27.083	27.842	28.697	29.345	29.759	29.977	30.168
10	27.373	28.041	28.697	29.297	29.530	29.982	30.130
11	27.363	27.896	28.660	29.297	29.606	29.844	29.940
12	27.415	28.267	28.920	29.336	29.740	30.053	30.292
13	27.311	28.096	28.577	29.230	29.779	30.006	30.168
14	27.166	27.887	28.651	29.230	29.510	29.844	30.188
15	27.249	28.285	28.957	29.211	29.597	29.958	30.226
16	26.917	27.797	28.651	29.297	29.558	29.949	30.083
17	27.207	28.077	28.354	28.971	29.453	29.797	30.111
18	27.332	28.132	28.818	29.211	29.463	29.806	29.940
19	27.145	28.059	28.632	29.317	29.530	29.673	30.035
20	27.073	27.697	28.493	28.942	29.415	29.740	29.959
21	27.508	28.258	28.781	29.067	29.300	29.835	30.064
22	26.969	27.851	28.744	29.067	29.625	29.711	30.064
23	27.176	27.887	28.595	29.115	29.577	29.683	30.083
24	26.875	27.670	28.521	29.077	29.491	29.730	29.911
25	27.093	27.824	28.679	29.134	29.472	29.740	30.111
26	27.052	27.716	28.363	28.952	29.549	29.806	30.016
27	27.104	27.860	28.372	29.009	29.309	29.730	30.006
28	27.000	28.077	28.706	29.048	29.290	29.607	30.178
29	26.574	27.942	28.632	29.067	29.453	29.683	30.083
30	27.581	27.915	28.632	29.144	29.443	29.806	30.064
31	27.259	28.050	28.679	29.019	29.434	29.901	30.054
32	26.813	27.562	28.512	29.153	29.204	29.797	30.197
33	27.581	28.105	28.456	29.000	29.510	29.749	29.673

Figure E3. (cont) Run 2, 1 Dec 1992 (Raw Data)

Scan	Port Number						
	15	16	17	18	19	20	21
1	30.470	30.664	30.618	30.808	30.914	31.090	30.988
2	30.470	30.542	30.514	30.678	30.958	30.998	31.180
3	30.550	30.656	30.705	30.765	30.805	31.090	31.205
4	30.530	30.585	30.627	30.652	30.914	30.989	31.071
5	30.421	30.533	30.644	30.634	30.852	30.861	30.938
6	30.421	30.340	30.523	30.582	30.888	31.017	31.029
7	30.351	30.533	30.505	30.695	30.755	31.008	30.988
8	30.371	30.384	30.505	30.634	30.755	30.888	30.988
9	30.431	30.340	30.497	30.634	30.667	30.989	30.887
10	30.321	30.375	30.366	30.652	30.641	30.851	30.913
11	30.091	30.340	30.340	30.521	30.623	30.741	30.946
12	30.351	30.358	30.419	30.556	30.667	30.824	30.913
13	30.291	30.279	30.314	30.513	30.729	30.933	30.879
14	30.271	30.349	30.288	30.443	30.703	30.704	30.745
15	30.261	30.445	30.332	30.591	30.667	30.787	30.954
16	30.281	30.419	30.462	30.565	30.676	30.851	30.779
17	30.361	30.366	30.358	30.695	30.782	30.870	30.862
18	30.131	30.270	30.271	30.435	30.447	30.576	30.712
19	30.221	30.323	30.375	30.365	30.676	30.796	30.938
20	30.171	30.349	30.445	30.400	30.650	30.677	30.846
21	30.181	30.270	30.358	30.400	30.685	30.741	30.737
22	30.331	30.445	30.375	30.435	30.782	30.760	30.963
23	30.221	30.436	30.497	30.530	30.773	30.787	30.996
24	30.111	30.375	30.236	30.608	30.606	30.796	30.821
25	29.992	30.121	30.297	30.339	30.641	30.714	30.587
26	30.251	30.200	30.253	30.339	30.667	30.677	30.896
27	30.351	30.252	30.080	30.452	30.676	30.548	30.704
28	30.151	30.103	30.410	30.348	30.491	30.796	30.796
29	30.121	30.165	30.236	30.374	30.526	30.530	30.762
30	30.211	30.147	30.184	30.617	30.509	30.645	30.796
31	29.992	30.130	30.210	30.374	30.412	30.741	30.670
32	30.091	30.191	30.219	30.408	30.332	30.576	30.720
33	30.101	30.270	30.071	30.322	30.606	30.668	30.553


Figure E3. (cont) Run 2, 1 Dec 1992 (Raw Data)

Scan	Port Number						
	22	23	24	25	26	27	28
1	31.347	31.630	33.022	35.091	27.019	29.064	26.704
2	31.178	31.622	33.099	35.109	26.370	29.091	26.637
3	31.162	31.605	33.201	35.008	26.613	29.151	26.738
4	31.204	31.647	33.141	34.981	26.421	29.046	26.780
5	31.120	31.664	33.141	35.063	26.410	29.090	26.569
6	31.120	31.579	33.107	34.963	26.431	29.846	26.477
7	31.036	31.528	33.099	34.944	26.441	29.099	26.653
8	31.061	31.460	32.953	34.862	26.025	28.881	26.118
9	31.162	31.537	32.842	34.890	26.269	28.899	26.536
10	30.985	31.418	33.064	35.036	26.421	29.944	26.485
11	30.884	31.520	33.056	34.844	26.279	28.793	26.418
12	30.960	31.375	33.073	34.963	26.329	28.785	26.190
13	31.111	31.596	33.133	34.963	26.340	28.627	26.477
14	30.884	31.622	33.022	34.935	26.188	28.819	26.392
15	31.002	31.613	33.082	34.954	26.279	28.915	26.451
16	30.867	31.435	32.945	34.881	26.350	28.872	26.460
17	30.926	31.418	32.987	34.835	26.167	28.828	26.460
18	30.910	31.248	32.910	34.871	26.117	28.645	26.207
19	31.002	31.486	33.064	34.908	26.238	28.715	26.266
20	30.943	31.469	33.047	34.780	26.188	28.662	26.233
21	30.977	31.562	32.833	34.835	26.238	28.706	26.477
22	30.952	31.392	33.013	34.771	26.228	28.592	26.392
23	31.010	31.528	32.987	34.963	26.309	28.654	26.350
24	30.985	31.571	32.928	34.890	26.289	28.846	26.350
25	30.775	31.256	32.970	34.771	26.096	28.785	26.342
26	31.027	31.537	32.945	34.698	26.147	28.697	26.367
27	30.792	31.503	32.808	34.826	26.036	28.514	26.123
28	30.851	31.180	32.868	34.716	25.884	28.654	26.334
29	30.867	31.239	32.782	34.835	26.157	28.645	26.308
30	30.985	31.324	32.851	34.899	26.218	28.523	26.233
31	30.809	31.392	32.936	34.680	25.975	28.558	26.106
32	30.691	31.239	32.756	34.707	26.177	28.697	26.275
33	30.800	31.477	32.859	34.634	26.198	28.793	26.207

Figure E3. (cont) Run 2, 1 Dec 1992 (Raw Data)


Scan	Port Number			
	29	30	31	32
1	17.266	36.252	54.454	52.184
2	17.337	36.528	54.340	52.003
3	17.372	36.471	54.243	51.940
4	17.354	36.518	54.428	51.795
5	17.319	36.423	54.199	51.669
6	17.363	36.471	54.428	51.624
7	17.372	36.461	54.287	51.737
8	17.345	36.366	54.252	52.031
9	17.363	36.357	54.287	52.202
10	17.292	36.366	54.173	52.239
11	17.328	36.290	54.147	51.361
12	17.363	36.347	54.322	49.695
13	17.301	36.281	54.182	45.189
14	17.337	36.328	54.278	42.759
15	17.345	36.395	54.252	46.273
16	17.408	36.414	54.331	51.587
17	17.363	36.328	54.270	52.293
18	17.345	36.290	54.217	52.266
19	17.345	36.290	54.305	52.248
20	17.319	36.338	54.472	52.320
21	17.425	36.243	54.103	52.194
22	17.399	36.205	54.357	52.248
23	17.292	36.309	54.155	52.257
24	17.328	36.271	54.103	52.211
25	17.328	36.224	54.190	52.229
26	17.337	36.186	54.120	52.193
27	17.390	36.309	54.041	52.220
28	17.301	35.939	53.936	52.302
29	17.417	36.024	53.821	52.275
30	17.452	36.129	53.927	52.428
31	17.212	35.986	54.059	52.184
32	17.230	35.882	53.901	52.031
33	17.221	36.214	54.138	51.081

Figure E3. (cont) Run 2, 1 Dec 1992 (Raw Data)



Port	Scan Number						
	10	11	12	13	14	15	16
1	.338	.338	.336	.336	.337	.337	.337
2	.343	.344	.340	.342	.342	.342	.343
3	.341	.340	.342	.342	.341	.342	.342
4	.356	.352	.361	.358	.359	.353	.350
5	.406	.393	.407	.410	.410	.403	.388
6	.451	.449	.449	.457	.446	.447	.428
7	.484	.486	.481	.484	.482	.482	.472
8	.505	.505	.505	.504	.500	.502	.495
9	.518	.515	.520	.519	.514	.521	.512
10	.530	.529	.532	.527	.528	.534	.527
11	.541	.541	.540	.539	.539	.538	.539
12	.545	.547	.547	.550	.544	.546	.544
13	.552	.551	.553	.554	.550	.552	.551
14	.556	.553	.558	.557	.556	.557	.554
15	.560	.556	.559	.559	.558	.558	.557
16	.561	.560	.559	.559	.559	.561	.560
17	.561	.560	.560	.559	.558	.559	.561
18	.566	.564	.562	.563	.561	.564	.563
19	.566	.566	.565	.567	.566	.565	.565
20	.569	.568	.567	.569	.566	.567	.568
21	.571	.572	.569	.570	.566	.571	.567
22	.572	.570	.570	.574	.569	.571	.568
23	.580	.582	.578	.583	.583	.583	.579
24	.610	.610	.609	.612	.608	.610	.606
25	.647	.644	.644	.645	.644	.644	.642

Figure E3. (cont) Run 2, 1 Dec 1992 (P/Pt Distribution)



The cascade loss coefficient based on inlet dynamic pressure as calculated using mass averaged quantities as shown below.

Ptma1 = 54.2040569826 PSIA
 Ptma2 = 51.4784813851 PSIA
 Pt1-P1 = 36.8650770313 PSIA
 Ttavg = 507.5 deg R
 W_bar = .0739338099084

Figure E3. (cont) Run 2, 1 Dec 1992 (Loss Distribution)

Data Print Out for Zoc # 1 , Run # 1 , File ZP1212071

Period between samples (sec): .00333333333333

Sample collection rate (Hz): 300

Number of samples per port: 10

Length of data run (sec): 34.1

The scan type is: 3

Number of scans/traverses: 33

Increment of traverse: .0625 inches

Atmospheric pressure is: 14.725 psia

Tunnel Pressure Ratio is: 1.93212824279

Scan	Port Number						
	1	2	3	4	5	6	7
1	18.654	18.899	19.720	22.161	25.184	26.894	28.134
2	18.613	18.824	19.787	22.669	25.095	26.926	28.144
3	18.654	18.856	19.798	22.151	24.345	26.204	27.959
4	18.613	18.845	19.610	21.755	24.005	26.769	28.031
5	18.593	18.835	19.676	22.212	24.535	26.654	27.959
6	18.623	18.813	19.643	21.846	24.755	26.643	28.113
7	18.644	18.813	19.367	21.927	24.685	26.496	27.558
8	18.542	18.792	19.500	22.110	25.005	26.905	27.915
9	18.623	18.813	19.920	22.262	24.755	26.570	27.743
10	18.552	18.781	19.489	21.643	24.625	26.601	27.815
11	18.522	18.835	19.544	21.622	24.545	26.392	27.794
12	18.603	18.802	19.522	21.460	23.735	26.193	28.000
13	18.511	18.706	19.334	21.277	24.335	26.528	27.969
14	18.542	18.684	19.389	21.582	23.905	26.057	27.732
15	18.481	18.759	19.544	21.571	24.115	26.026	27.547
16	18.491	18.749	19.312	21.329	23.965	26.465	27.650
17	18.379	18.544	19.378	21.571	24.655	26.905	27.712
18	18.522	18.759	19.411	21.561	24.195	26.256	27.743
19	18.491	18.706	19.356	21.886	24.215	26.287	27.537
20	18.461	18.587	19.345	21.378	23.825	26.308	27.671
21	18.501	18.770	19.400	21.307	24.625	26.277	27.712
22	18.522	18.706	19.544	21.866	24.245	26.214	27.702
23	18.450	18.620	19.500	21.714	24.055	26.507	27.599
24	18.369	18.706	19.632	21.815	24.145	26.057	27.558
25	18.440	18.609	19.422	21.338	24.195	26.319	27.558
26	18.491	18.673	19.334	21.582	24.425	26.695	27.990
27	18.389	18.630	19.334	21.338	24.185	26.277	27.763
28	18.440	18.663	19.224	21.043	23.905	26.036	27.516
29	18.318	18.523	19.378	21.439	23.495	25.733	27.290
30	18.430	18.523	19.213	21.409	24.065	26.475	27.527
31	18.399	18.566	19.202	21.673	24.075	25.806	27.084
32	18.287	18.555	19.312	21.256	23.665	25.774	27.527
33	18.318	18.502	19.213	21.124	24.325	26.685	27.619

Figure E4. Run 1, 7 Dec 1992 (Raw Data)

Scan	Port Number						
	8	9	10	11	12	13	14
1	28.798	29.491	29.835	30.438	30.609	30.719	31.029
2	29.026	29.617	29.974	30.380	30.657	30.900	31.191
3	29.223	29.644	30.103	30.620	30.906	30.976	31.077
4	28.767	29.292	30.020	30.438	30.713	31.014	31.096
5	28.684	29.427	29.890	30.246	30.714	31.052	31.086
6	28.642	29.436	30.094	30.351	30.638	30.977	30.982
7	28.777	29.744	30.048	30.524	30.777	31.014	31.077
8	28.819	29.509	29.974	30.274	30.618	30.862	30.972
9	28.684	29.491	29.872	30.380	30.858	30.966	30.925
10	28.705	29.301	29.770	30.361	30.781	30.938	31.153
11	29.005	29.536	29.964	30.534	30.676	30.919	30.991
12	28.798	29.382	29.844	30.399	30.647	30.786	31.039
13	28.870	29.274	29.696	30.236	30.599	30.995	31.210
14	28.777	29.328	29.742	30.217	30.494	30.758	30.934
15	28.456	29.328	29.853	30.265	30.570	30.919	31.010
16	28.456	29.048	29.779	30.226	30.590	30.777	30.887
17	28.601	29.346	29.779	30.246	30.599	30.673	30.725
18	28.839	29.084	29.668	30.274	30.542	30.815	30.953
19	28.829	29.554	29.742	30.159	30.628	30.929	30.849
20	28.777	29.455	29.779	30.217	30.580	30.702	30.896
21	28.622	29.192	29.742	30.159	30.494	30.853	31.050
22	28.694	29.220	29.714	30.207	30.494	30.654	30.963
23	28.300	29.192	29.751	30.188	30.417	30.607	30.773
24	28.694	29.427	29.547	29.957	30.398	30.541	30.896
25	28.393	28.705	29.529	30.217	30.532	30.673	30.858
26	28.725	29.346	29.807	30.217	30.494	30.597	30.887
27	28.487	29.256	29.733	30.217	30.436	30.697	31.039
28	28.300	29.183	29.584	30.044	30.436	30.626	30.763
29	28.383	28.903	29.464	29.890	30.408	30.607	30.725
30	28.331	29.220	29.547	30.111	30.551	30.512	30.678
31	28.394	29.057	29.473	30.284	30.523	30.531	30.716
32	28.819	29.129	29.510	29.919	30.436	30.777	30.782
33	28.580	28.994	29.557	29.890	30.235	30.599	30.640

Figure E4. (cont) Run 1, 7 Dec 1992 (Raw Data)

Scan	Port Number						
	15	16	17	18	19	20	21
1	31.008	31.106	31.198	31.219	31.137	31.251	22.350
2	31.187	31.202	31.337	31.419	31.295	31.454	22.731
3	31.337	31.220	31.111	31.298	31.163	31.307	21.728
4	31.277	31.220	31.181	31.428	31.330	31.247	22.193
5	31.247	31.185	31.103	31.237	31.049	31.297	21.605
6	31.088	31.132	31.051	31.185	31.183	31.325	21.183
7	31.158	31.150	31.155	31.237	31.274	31.196	21.713
8	31.178	31.158	31.120	31.245	31.181	31.270	21.572
9	31.018	31.071	30.964	31.280	31.216	31.408	21.323
10	31.237	31.193	31.051	31.115	31.137	31.233	21.290
11	30.938	31.079	30.998	31.159	31.198	31.334	21.025
12	31.128	31.106	31.051	31.159	30.987	31.150	20.918
13	31.098	31.044	30.981	31.272	31.128	31.104	21.257
14	31.029	31.193	30.955	31.107	31.181	31.068	20.479
15	31.068	31.185	31.111	30.985	30.996	31.159	20.992
16	31.088	30.957	30.842	30.985	30.881	31.095	20.239
17	30.868	30.992	30.860	31.211	31.198	31.086	21.117
18	31.038	30.974	31.051	31.167	31.101	30.994	21.108
19	30.958	30.878	30.964	31.211	31.093	31.058	20.876
20	30.898	31.088	30.929	31.072	30.978	30.976	20.777
21	31.108	31.009	30.998	31.080	30.996	31.068	20.595
22	30.928	31.001	31.094	31.072	31.075	31.077	20.852
23	30.938	31.036	30.860	30.968	30.881	31.003	21.282
24	30.938	30.869	30.868	31.072	30.864	30.875	20.868
25	31.018	30.790	30.851	31.115	30.899	30.893	20.587
26	30.829	30.834	30.834	30.985	30.837	30.875	20.934
27	31.098	30.904	30.929	30.994	30.943	31.049	21.166
28	30.898	30.904	30.704	30.907	31.031	30.930	21.199
29	30.848	30.694	30.721	30.881	30.899	30.902	20.222
30	30.779	30.790	30.825	31.063	30.908	31.022	21.539
31	30.779	30.764	30.851	30.811	30.807	30.755	21.448
32	30.809	30.939	30.730	31.089	30.934	30.829	21.199
33	30.749	30.878	30.652	30.863	30.776	30.847	21.497


Figure E4. (cont) Run 1, 7 Dec 1992 (Raw Data)

Scan	Port Number						
	22	23	24	25	26	27	28
1	27.184	29.624	30.967	31.219	31.517	31.749	31.003
2	27.512	29.437	30.864	31.055	31.370	31.270	31.020
3	27.218	29.565	30.864	31.055	31.390	31.135	30.970
4	27.478	29.539	30.787	31.073	31.410	31.231	30.936
5	27.159	29.497	30.958	31.201	31.501	31.231	30.970
6	27.058	29.531	30.864	31.091	31.451	31.205	31.020
7	26.849	29.318	30.735	31.128	31.760	31.118	30.936
8	26.949	29.182	30.615	30.991	31.360	31.126	30.810
9	27.025	29.225	30.795	31.119	31.431	31.257	30.987
10	26.622	28.928	30.392	30.772	31.157	31.100	31.020
11	26.647	28.919	30.409	30.790	31.309	31.214	30.902
12	26.748	29.131	30.658	31.027	31.269	31.039	30.944
13	26.874	29.327	30.701	30.954	31.279	31.153	30.944
14	26.160	28.775	30.444	30.854	31.248	31.100	30.793
15	26.605	29.106	30.658	30.936	31.259	31.030	30.793
16	26.504	29.106	30.547	30.772	31.198	31.091	30.869
17	26.874	29.098	30.581	30.964	31.188	30.908	30.751
18	26.614	28.953	30.401	30.845	31.168	31.048	30.793
19	26.311	28.860	30.452	30.909	31.289	30.969	30.827
20	26.135	28.741	30.358	30.790	31.157	30.890	30.810
21	26.060	28.766	30.341	30.809	31.218	31.030	30.818
22	26.261	28.775	30.349	30.827	31.157	30.925	30.818
23	26.823	29.225	30.547	30.863	31.168	30.952	30.810
24	26.244	28.817	30.324	30.745	31.016	30.873	30.760
25	26.546	28.826	30.118	30.654	31.066	30.960	30.642
26	26.244	28.707	30.478	30.827	31.157	30.934	30.709
27	26.412	28.715	30.349	30.708	31.026	30.890	30.718
28	26.681	28.996	30.504	30.763	31.168	30.873	30.650
29	26.001	28.605	30.298	30.763	31.056	30.724	30.718
30	26.958	29.208	30.607	30.790	31.117	30.917	30.701
31	26.706	29.919	30.444	30.617	31.127	31.065	30.559
32	26.597	29.030	30.281	30.553	30.925	30.839	30.726
33	26.907	28.698	30.143	30.626	30.975	30.807	30.659

Figure E4. (cont) Run 1, 7 Dec 1992 (Raw Data)


Scan	Port Number			
	29	30	31	32
1	18.945	36.604	55.220	52.948
2	19.025	36.708	55.094	52.804
3	18.980	36.651	55.346	52.921
4	18.954	36.604	55.238	52.921
5	18.972	36.594	55.328	52.930
6	18.989	36.661	55.337	52.921
7	18.954	36.585	55.346	52.948
8	18.883	36.471	55.256	52.939
9	18.989	36.594	55.382	53.192
10	19.176	36.604	55.031	52.894
11	18.998	36.423	55.229	51.179
12	18.954	36.547	55.319	47.399
13	19.060	36.547	55.229	43.675
14	18.936	36.499	55.319	44.027
15	18.972	36.528	55.292	50.359
16	19.016	36.395	55.238	53.075
17	18.945	36.585	55.283	53.138
18	18.972	36.385	55.283	53.183
19	18.954	36.556	55.364	53.174
20	19.025	36.556	55.220	52.984
21	18.954	36.471	55.220	53.102
22	18.998	36.395	55.103	53.111
23	18.990	36.328	55.094	53.021
24	19.069	36.414	54.896	53.057
25	18.865	36.271	55.166	53.084
26	18.954	36.376	55.067	53.156
27	18.954	36.347	55.094	53.219
28	18.900	36.290	55.040	53.174
29	18.989	36.357	54.887	53.084
30	18.874	36.252	54.914	53.265
31	18.785	36.139	54.941	53.201
32	18.972	36.091	54.941	53.057
33	18.891	36.177	54.716	52.154

Figure E4. (cont) Run 1, 7 Dec 1992 (Raw Data)




Port	Scan Number						
	1	2	3	4	5	6	7
1	.338	.338	.337	.337	.336	.337	.337
2	.342	.342	.341	.341	.340	.340	.340
3	.357	.359	.358	.355	.356	.355	.350
4	.401	.411	.400	.394	.401	.395	.396
5	.456	.455	.440	.449	.443	.447	.446
6	.487	.489	.473	.485	.482	.481	.479
7	.509	.511	.505	.507	.505	.508	.498
8	.522	.527	.528	.521	.518	.518	.520
9	.534	.538	.536	.530	.532	.537	.537
10	.540	.544	.544	.543	.540	.544	.543
11	.551	.551	.553	.551	.547	.548	.552
12	.554	.556	.558	.557	.555	.554	.556
13	.557	.561	.560	.561	.561	.559	.560
14	.562	.566	.561	.563	.562	.560	.561
15	.562	.566	.566	.566	.565	.562	.563
16	.563	.566	.564	.565	.564	.563	.563
17	.565	.569	.562	.564	.567	.561	.563
18	.565	.570	.565	.569	.565	.564	.564
19	.564	.568	.563	.567	.561	.563	.564
20	.566	.571	.566	.566	.566	.566	.564

Figure E4. (cont) Run 1, 7 Dec 1992 (Lower Passage P/Pt Distribution)



Port	Scan Number						
	1	2	3	4	5	6	7
21	.405	.413	.393	.402	.400	.400	.400
22	.492	.499	.492	.497	.491	.499	.495
23	.536	.534	.534	.535	.533	.534	.530
24	.561	.560	.558	.557	.560	.558	.555
25	.565	.564	.561	.563	.564	.562	.562
26	.571	.569	.567	.569	.569	.568	.567
27	.566	.568	.563	.565	.564	.564	.562
28	.561	.563	.560	.560	.560	.561	.559

Figure E4. (cont) Run 1, 7 Dec 1992 (Upper Passage P/Pt Distribution)



The cascade loss coefficient based on inlet dynamic pressure as calculated using mass averaged quantities as shown below.

Ptma1 = 55.1654793409 PSIA

Ptma2 = 52.3818787735 PSIA

Pt1-P1 = 36.1988140382 PSIA

Ttavg = 513 deg R

W_bar = .0768975625679

Figure E4. (cont) Run 1, 7 Dec 1992 (Loss Distribution)

APPENDIX F. SAMPLE RVCQ3D INPUT AND SUMMARY OF RESTARTS

1. Sample RVCQ3D Input File:

```
'GAS DYNAMICS LAB TRANSONIC FAN CASCADE'

&n11 m=250,n=49,mt1=50,mil=112 &end

&n12 nsta=4,ivdt=1,irs=1,epi=0.3,epj=0.4,
      cfl=4.5,av2=1.00,av4=1.0 &end

&n13 ibcin=1,ibcex=1,itmax=2000,iresti=1,iresto=1,
      ires= 10,icnt=10,ixim=0 &end

&n14 amle=1.40,alle=56.49,bete=53.0,prat=0.704,a=1.4,
      p0in=1.00000,t0in=1.00000 &end

&n15 ilt=2,jedge=30,renr=17.83e6,prnr=0.71,ptr=0.90,
      tw=0.0,vispwr=0.83500,cmutm=14.0 &end

&n16 omega= 0.000000,nblade= 1,nmn=0 &end
```

2. Summary of RVCQ3D restart inputs:

TABLE XII. SUMMARY OF RVCQ3D RESTART INPUTS

Iterations	P2/Pt1	Residual Smoothing (i-direction)	Residual Smoothing (j-direction)
0-500	0.76	0.55	0.65
510-1000	0.74	0.55	0.65
1010-1500	0.72	0.55	0.65
1510-2000	0.71	0.45	0.55
2010-2500	0.71	0.45	0.55
2510-3000	0.71	0.35	0.45
3010-4000	0.71	0.35	0.45
4010-5000	0.71	0.3	0.4
5010-7000	0.704	0.3	0.4

APPENDIX G. SAMPLE CALCULATION USING KOCH AND SMITH

The following is a loss estimate based on the Koch and Smith model [Ref. 25]. Experimental results will be used as inputs where possible and estimates of other quantities will be input elsewhere. Blade and passage geometry is determined. The deviation angle is estimated using NASA SP-36 [Ref. 27] and AGARD-R-745 [Ref. 26]. The loss estimate is obtained using relations, figures and tables from reference 33 and 34.

A. The cascade and passage geometry for the a suction surface incidence of 1.15 degrees is presented.

Variable geometry:	$\Delta i_{ss} = 0 \cdot \text{deg}$	
Blade Camber:	$\phi = 6.66773 \cdot \text{deg}$	
Maximum Thickness:	$t_{\max} = 0.22866 \cdot \text{in}$	
Chord:	$c = 6 \cdot \text{in}$	$t_{c\max} = \frac{t_{\max}}{c}$
Thickness (LE)	$t_{LE} = 0.015 \cdot \text{in}$	
$t/c_{\max}$:	$t_{c\max} = 0.03811$	
Blade Spacing:	$s = 3 \cdot \text{in}$	$\sigma = \frac{c}{s}$
Solidity:	$\sigma = 2$	
Slagger Angle:	$\xi = 51.84 \cdot \text{deg}$	
Wedge Angle:	$\text{wedge} = 3.5 \cdot \text{deg}$	
Metal angles:	$K_{1m} = \frac{1}{2} \cdot \text{wedge} + \xi$	$K_{1m} = 53.59 \cdot \text{deg}$
	$K_{2m} = K_{1m} - \phi$	$K_{2m} = 46.92227 \cdot \text{deg}$
Suction Surface Incidence:		
	$i_{ss} = 1.15 \cdot \text{deg} + \Delta i_{ss}$	
Suction Surface Metal Angle:		
	$K_{1s} = K_{1m} + \frac{1}{2} \cdot \text{wedge}$	
	$K_{1s} = 55.34 \cdot \text{deg}$	
Blade Incidence Angle:		
	$i_m = i_{ss} + (K_{1s} - K_{1m})$	
	$i_m = 2.9 \cdot \text{deg}$	
Inlet Flow Angle:		
	$\beta_1 = i_m + K_{1m}$	
	$\beta_1 = 56.49 \cdot \text{deg}$	

Figure G1. Loss Estimation by Koch and Smith Method

B. Deviation angle is estimated using three methods. The first two are from NASA SP-36 and the third is a modified Carter rule taken from AGRARD-R-745.

Using NASA SP-36 two "methods" can be used to find deviation angle which yield similar results:

Method 1 (EQN 268)

1. Zero camber deviation for 10% thick 65 series airfoils as a function of inlet flow angle in Figure 161

$$\delta_{o_{10\%}} = 2.5 \cdot \deg$$

2. Slope function as taken from Figure 168 as a function of inlet flow and solidity.

$$m = 0.185$$

3. Corrections to zero camber deviation for C-series airfoils and thickness. The thickness correction is from Figure 172 as a function of t/c .

$$K_{\delta_{sh_C_series}} := 1.1$$

$$K_{\delta} = 0.32$$

4. Corrected zero camber deviation from equation 271.

$$\delta_o = K_{\delta_{sh_C_series}} \cdot K_{\delta} \cdot \delta_{o_{10\%}}$$

5. Estimated deviation angle from equation 268.

$$\delta_1 = \delta_o + m \cdot \phi$$

$$\delta_1 = 2.11353 \cdot \deg$$

Method 2 (EQN 269)

1. Slope function for solidity of 1 taken from Figure 166

$$m_{\sigma_1} = 0.305$$

2. Solidity exponent taken from Figure 164.

$$b = 0.72$$

3. Using equation 269 and the zero camber deviation from method 1, the deviation can be estimated.

$$\delta_2 = \delta_o + \phi \cdot \left(\frac{m_{\sigma_1}}{\sigma^b} \right)$$

$$\delta_2 = 2.11463 \cdot \deg$$

Figure G1. (cont) Loss Estimation by Koch and Smith Method

Method 3 (Modified Carter's Rule)

1. Carter's rule slope function as taken from Figure 160 in NASA SP-36: $\xi = 51.84 \cdot \text{deg}$

$$m_{c_ca} := 0.33$$

$$m_{c_pa} = 0.275$$

2. Carter's rule: (EQN 270 in SP-36)

$$\delta_{car_ca} = \frac{m_{c_ca} \phi}{\sqrt{\sigma}} \quad \delta_{car_pa} = \frac{m_{c_pa} \phi}{\sqrt{\sigma}}$$

$$\delta_{car_ca} = 1.55588 \cdot \text{deg} \quad \delta_{car_pa} = 1.29657 \cdot \text{deg}$$

3. Modified Carter's rule relation from AGARD-R-745 (EQN 3.5)

$$\delta_3 = -1.099379 + 3.0186 \cdot \delta_{car_pa} - 0.1988 \cdot \delta_{car_pa}^2$$

$$\delta_3 = 2.48024 \cdot \text{deg}$$

$$\delta = \delta_3$$

Now, outlet flow angle can be estimated using the deviation angle(s) found above.

$$\beta_2 := \delta + K_{2m}$$

Total flow turning is..

$$\epsilon = \beta_1 - \beta_2$$

$$\beta_2 = 49.40251 \cdot \text{deg}$$

$$\epsilon = 7.08749 \cdot \text{deg}$$

C. Cascade losses are calculated using the Koch and Smith model outlined in AGARD-R-745 and described in "Loss Sources and Magnitudes in Axial-Flow Compressors" by C. C. Koch and L.H. Smith, Jr.

1. Profile Losses:

- a. The first step is to calculate the following parameters:

Velocities and Mach numbers will be taken as the average value and it should be noted that for the actual machine these would be relative velocities:

$$V_{1avg} = 1306.60877 \cdot \frac{\text{ft}}{\text{sec}} \quad V_{2avg} = 717.18277 \cdot \frac{\text{ft}}{\text{sec}}$$

$$M_{1avg} = 1.38862$$

Figure G1. (cont) Loss Estimation by Koch and Smith Method

Radius values must be determined to completely utilize the model, but their effect cancels out for the 2-D case so the radius shown is arbitrary

$$r_1 = 10 \cdot \text{in} \quad r_2 = 10 \cdot \text{in}$$

$$r_{\text{mean}} = \frac{r_1 + r_2}{2} \quad r_{\text{mean}} = 10 \cdot \text{in}$$

Other constants defined for use in this model are as shown:

$$K_1 = 0.2445 \quad K_2 = 0.4458$$

$$K_3 = 0.7688 \quad K_4 = 0.6024$$

Velocity diagram parameters:

$$\beta_{\text{mean}} := \frac{\beta_1 + \beta_2}{2} \quad \beta_{\text{mean}} = 52.94626 \cdot \text{deg}$$

$$M_{z1} = M_{1\text{avg}} \cos(\beta_1) \quad M_{z1} = 0.76663$$

$$V_{\theta 1} = V_{1\text{avg}} \sin(\beta_1) \quad V_{\theta 1} = 1089.43665 \cdot \frac{\text{ft}}{\text{sec}}$$

$$V_{\theta 2} = V_{2\text{avg}} \sin(\beta_2) \quad V_{\theta 2} = 544.55674 \cdot \frac{\text{ft}}{\text{sec}}$$

Annulus parameters of questionable value:

$$A_{a1} := s \cdot \sin(\xi) \cdot (r_2 - r_1) \quad A_{a1} = 0 \cdot \text{in}^2$$

$$A_{a2} := A_{a1}$$

$$A_p = \left(1 - \frac{K_2 \cdot \sigma \cdot \frac{t_{\text{max}}}{c}}{\cos(\beta_{\text{mean}})} \right) \cdot \left(1 - \frac{A_{a1} - A_{a2}}{3 A_{a1}} \right) \quad < \text{this term} = 1.0$$

$$A_p = 0.94361$$

Density and circulation parameters:

$$\Gamma_{\text{star}} = \frac{r_1 \cdot V_{\theta 1} - r_2 \cdot V_{\theta 2}}{r_{\text{mean}} \cdot \sigma \cdot V_{1\text{avg}}} \quad \Gamma_{\text{star}} = 0.20851$$

$$p_{\text{star}} := 1 - \left(\frac{M_{z1}^2}{1 - M_{z1}^2} \right) \left(1 - A_p - K_1 \cdot \frac{\tan(\beta_1)}{\cos(\beta_1)} \cdot \sigma \cdot \Gamma_{\text{star}} \right)$$

$$p_{\text{star}} = 1.31723$$

Figure G1. (cont) Loss Estimation by Koch and Smith Method

Equivalent diffusion factor:

$$D_{eq} := \frac{V_{1avg}}{V_{2avg}} \left[\left(\sin(\beta_1) - K_{1, \sigma} \Gamma_{star} \right)^2 + \left(\frac{\cos(\beta_1)}{A_P \Gamma_{star}} \right)^2 \right]^{\frac{1}{2}} \cdot \left(1 + K_{1, \frac{t_{max}}{c}} + K_{1, \Gamma_{star}} \right)$$

$$D_{eq} = 1.80124$$

b. The next step is to use the quantiles above as well as flow quantiles in the figures contained in the Koch and Smith paper. The quantiles obtained will be used in equation 2 of AGARD-R-745. (which is equation 264 of SP-36)

With D_{eq} and inlet Re , figures 2a and b can be used to find Momentum thickness to chord and Trailing edge boundary layer form factor.

$$Re_{1avg} := \text{mean}(Re_1) \quad Re_{1avg} = 9.10881 \cdot 10^4$$

$$D_{eq} = 1.80124$$

$$\theta_{c1} := 0.0075 \quad H_{TE} := 1.57$$

A correction for inlet Mach Number is provided by Figure 3 as a function D_{eq} and M_1 .

$$M_{1avg} = 1.38862$$

$$\theta_{M1} := 0.7 \quad H_{M1} = 1.23$$

A correction for stream tube correction based on $h1/h2$ is given, but is impossible to estimate in the current experimental configuration.

A Re /roughness Momentum Thickness correction is provided using k_s from Appendix 2 and Figure 5 both of the Koch and Smith paper.

Assuming a surface roughness of ASTM Paper number 180

$$k_{CLA} := 7.0866 \cdot 10^{-4} \text{ in } k_s := 6.2 k_{CLA}$$

$$k_{so} = \frac{k_s}{Re} \quad k_{so} = 0.00073$$

Then Figure 5 provides corrections as a function of Re

$$\theta_{k_s} := 1.25 \quad \text{and for a roughness Reynolds number as shown, the Hte is corrected in the same manner. (ie power variation of -0.06 is not applied.)}$$

$$H_{k_s} := 1.25$$

$$R_{cr} = \frac{k_s \cdot \text{mean}(\rho_1) \cdot V_{1avg}}{\text{mean}(\mu_1)}$$

$$R_{cr} = 6670.23772$$

Figure G1. (cont) Loss Estimation by Koch and Smith Method

The corrected momentum thickness per chord and wake form factor are

$$\theta_c := \theta_{M1} \cdot \theta_{k8} \cdot \theta_{c1} \quad \theta_c = 0.00656$$

$$H = H_{M1} \cdot H_{k8} \cdot H_{1E} \quad H = 2.41388$$

Now, using equation 2, the profile losses can be determined

$$\omega_{bar_profile} = 2 \cdot (\theta_c) \cdot \frac{\sigma}{\cos(\beta_2)} \cdot \left(\frac{\cos(\beta_1)}{\cos(\beta_2)} \right)^2 \cdot \frac{\frac{2 \cdot H}{3 \cdot H - 1}}{\left(1 - \theta_c \cdot \frac{\sigma \cdot H}{\cos(\beta_2)} \right)^4}$$

$$\omega_{bar_profile} = 0.02608$$

2. Shock losses and leading edge bluntness losses can be calculated as follows:

a. Shock losses obtained from Figure 7 of Koch and Smith

$$\omega_{bar_shock} := 0.065$$

b. Leading edge bluntness losses obtained as shown:

$$\Delta s := R \cdot \left[-\ln \left[1 - \frac{t_{LE}}{(s \cdot \cos(\beta_1))} \right] \left[1.28 \cdot (M_{1avg} - 1) + 0.96 \cdot (M_{1avg} - 1)^2 \right] \right]$$

$$P_{t_ratio} := e^{\frac{-\Delta s}{R}}$$

$$\Delta P_t := P_{t1ma} \cdot (1 - P_{t_ratio})$$

$$\omega_{bar_LE} = \frac{\Delta P_t}{q_{1avg}} \quad \omega_{bar_LE} = 0.00855$$

3. Finally, the total cascade losses estimated by the model are...

$$\omega_{bar} := \omega_{bar_profile} + \omega_{bar_shock} + \omega_{bar_LE}$$

$$\omega_{bar} = 0.09963$$

Figure G1. (cont) Loss Estimation by Koch and Smith Method

4. Compare experimental, empirical and numerical values... $m_{\text{num}} = 0.11231$

$$\Delta m_{\text{exp_emp}}\% = \frac{m - m_{\text{exp}}}{m} \cdot 100$$

$$\Delta m_{\text{exp_emp}}\% = 1.31097$$

$$\Delta m_{\text{exp_num}}\% = \frac{m_{\text{num}} - m}{m_{\text{num}}} \cdot 100$$

$$\Delta m_{\text{exp_num}}\% = 10.1098$$

Figure G1. (cont) Loss Estimation by Koch and Smith Method

LIST OF REFERENCES

1. Hill P. G., and Peterson C. R., Mechanics and Thermodynamics of Propulsion, 2nd ed., p. 346, Addison-Wesley, 1992.
2. Linn, J. C., Selby, G. V., and Howard, F. G., "Exploratory Study of Vortex Generating Devices for Turbulent Flow Separation Control", AIAA Paper 91-0042, January 1992.
3. McCormick, D. C., "Shock-Boundary Layer Interaction Control with Low-Profile Vortex Generators and Passive Cavity", AIAA Paper 92-0064, January 1992.
4. Wheeler, G. O., Means for Maintaining Attached Flow of a Flowing Medium, United States Patent 4,455,045, June 1984.
5. Johnston, J. P., and Nishi, M., "Vortex Generator Jets-Means for Flow Separation Control", AIAA Journal, v. 28, pp. 989-994, June 1990.
6. Compton, D. A., and Johnston, J. P. "Streamwise Vortex Production by Pitched and Skewed Jets in a Turbulent Boundary Layer", AIAA Paper 91-0638, January 1991.
7. United Technologies Research Center Report R90-957946, Transonic Fan Shock-Boundary Layer Separation Control, April 1990.
8. Golden, W. L., Static Pressure Measurements of the Shock-Boundary Layer Interaction in a Simulated Fan Passage, M.S.A.E. Thesis, Naval Postgraduate School, Monterey, California, March 1992.
9. Collins, C. C., Preliminary Investigation of the Shock-Boundary Layer Interaction in a Simulated Fan Passage, M.S.A.E. Thesis, Naval Postgraduate School, Monterey, California, March 1991.
10. Demo, Jr., W. J., Cascade Wind Tunnel for Transonic Compressor Blading Studies, M.S.A.E. Thesis, Naval Postgraduate School, Monterey, California, June 1978.

11. Hegland, M. G., Investigation of a Mach 1.4 Compressor Cascade with Variable Back Pressure Using Flow Visualization, M.S.A.E. Thesis, Naval Postgraduate School, Monterey, California, 1986.
12. Wendland, R. A., Upgrade and Extension of the Data acquisition System for Propulsion and Gas Dynamic Laboratories, M.S.A.E. Thesis, Naval Postgraduate School, Monterey, California, June 1992.
13. UNISLIDE Motor Driven Assemblies, Installation and Maintenance Instructions, VELMEX Incorporated, August 1990.
14. Operating Manual, HP3455A Digital Voltmeter, Hewlett Packard Company, 1984.
15. HP 3497A Data Acquisition and Control Unit, Operating, Programming and Configuration Manual, Hewlett Packard Company, 1982.
16. NF90 Stepping Motor Controller, NF90 Series User's Guide One, Two and Three Axis Stepping Motor Controller/Drivers, VELMEX Incorporated, March 1991.
17. HP98644A Asynchronous Serial Interface, Reference Manual, Hewlett Packard Company, 1985.
18. NASA TM-81198, A Computer Program to Generate Two-Dimensional Grids About Airfoils and Other Shapes by use of Poisson's Equation., Sorensen, R. L., 1980.
19. Steger, J. L., and Sorensen, R. L., "Automatic Mesh Point Clustering Near a Boundary in Grid Generation with Elliptic Partial Differential Equations", Journal of Computational Physics, v. 33, no. 3, pp. 405-410, December 1979.
20. Chima, R. V. "Revised GRAPE Code Input for Cascades", NASA Lewis Research Center, June 1990.
21. Chima, R. V., "RVCQ3D (Rotor Viscous Code Quasi-3-D) Documentation", NASA Lewis Research Center, August 1990.

22. Phone Conversations between Dan Tweedt, NASA Lewis Research Center, and David D. Myre, Naval Postgraduate School.
23. Chima, R. V., "Explicit Multigrid Algorithm for Quasi-Three Dimensional Viscous Flows in Turbomachinery", Journal of Propulsion and Power, v. 3, no. 5, pp. 397-405, September-October 1987.
24. NASA TM-88878, Comparison of Three Explicit Multigrid Methods for Euler and Navier-Stokes Equations, by Chima, R. V., Turkel, E., and Schaffer, S., January 1987.
25. Koch, C. C., and Smith, L. H., "Loss Sources and Magnitudes in Axial-Flow Compressors", Transactions of the ASME, Journal of Engineering for Power, pp. 411-424.
26. AGARD-R-745, Application of Modified Loss and Deviation Correlations to Transonic Axial Compressors, by Cetin, M., Ucer, A. S., Hirsch, Ch., Serovy, G. K., 1987.
27. NASA SP-36, Aerodynamic Design of Axial-Flow Compressor, 1965.

INITIAL DISTRIBUTION LIST

- | | | |
|----|--|--------|
| 1. | Defense Technical Information Center
Cameron Station
Alexandria, VA 22304-6145 | 2 |
| 2. | Library, Code 52
Naval Postgraduate School
Monterey, CA 93943-5002 | 2 |
| 3. | Department of Aeronautics and Astronautics
Naval Postgraduate School
Monterey CA, 93943-5002
ATTN: Chairman
ATTN: Code AA/SF | 1
5 |
| 4. | Commanding Officer
Naval Air Warfare Center
Aircraft Division
Trenton, NJ 08628-0176
ATTN: CR1 | 1 |
| 5. | Office of Naval Research
800 North Quincy Street
Arlington, VA 22217
ATTN: Spiro Lykoudis | 1 |
| 6. | NASA Lewis Research Center
Cleveland, Ohio 44135
ATTN: Dan Tweedt | 1 |
| 7. | United Technologies Research Center
East Hartford, CT 06108
ATTN: Duane McCormick | 1 |

8. David D. Myre
Program Executive Office
Cruise Missiles Project and
Unmanned Aerial Vehicles
Joint Project
Washington, DC 20361-1014

2

DUDLEY KNOX LIBRARY



3 2768 00019470 8