

US Army Corps of Engineers Construction Engineering Research Laboratories

Central Heating Plant Modernization Study for the Defense Personnel Support Center

by

Martin J. Savoie Russ Price Spiro J. Deligiannis Travis L. McCammon

This report documents a study to determine alternatives for modernizing the central heating plant at the Defense Personnel Support Center (DPSC), Philadelphia, PA. The central heating plant contains five boilers; four are 50 years old and one is 14 years old. The age of this equipment warranted an investigation of alternatives for providing thermal energy to the installation. These alternatives include maintaining the status quo, upgrading the existing system, installing new boilers, cogeneration, and absorption chilling. Heating and cooling loads were analyzed using computer simulations. Based on the simulations and design temperatures, life cycle costs were developed for each alternative.



19950424 046

THE CALENT INTERIOUS S

The contents of this report are not to be used for advertising, publication, or promotional purposes. Citation of trade names does not constitute an official endorsement or approval of the use of such commercial products. The findings of this report are not to be construed as an official Department of the Army position, unless so designated by other authorized documents.

DESTROY THIS REPORT WHEN IT IS NO LONGER NEEDED

DO NOT RETURN IT TO THE ORIGINATOR

USER EVALUATION OF REPORT

REFERENCE: USACERL Technical Report FE-94/25, Central Heating Plant Modernization Study for the Defense Personnel Support Center

Please take a few minutes to answer the questions below, tear out this sheet, and return it to USACERL. As user of this report, your customer comments will provide USACERL with information essential for improving future reports.

1. Does this report satisfy a need? (Comment on purpose, related project, or other area of interest for which report will be used.)

2. How, specifically, is the report being used? (Information source, design data or procedure, management procedure, source of ideas, etc.)

3. Has the information in this report led to any quantitative savings as far as manhours/contract dollars saved, operating costs avoided, efficiencies achieved, etc.? If so, please elaborate.

4. What is your evaluation of this report in the following areas?

9	Presentation:
а.	
b.	Completeness:
c.	Easy to Understand:
d.	Easy to Implement:
e.	Adequate Reference Material:
f.	Relates to Area of Interest:
	Di 1 (1 and a state of the stat
g.	Did the report meet your expectations?
h	Does the report raise upanswered questions?
11.	Does the report raise unanswered questions.

i. General Comments. (Indicate what you think should be changed to make this report and future reports of this type more responsive to your needs, more usable, improve readability, etc.)

5. If you would like to be contacted by the personnel who prepared this report to raise specific questions or discuss the topic, please fill in the following information.

6. Please mail the completed form to:

Department of the Army CONSTRUCTION ENGINEERING RESEARCH LABORATORIES ATTN: CECER-IMT P.O. Box 9005 Champaign, IL 61826-9005

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188
Public reporting burden for this collection of inf gathering and maintaining the data needed, a this collection of information, including sugge Jefferson Davis Highway, Suite 1204, Arlingtor	ormation is estimated to average 1 hour per re nd completing and reviewing the collection of stions for reducing this burden, to Washingto , VA 22202-4302, and to the Office of Manage	sponse, including the time for re information. Send comments n Headquarters Services, Dire ment and Budget, Paperwork R	eviewing instructions, searching existing data sources, regarding this burden estimate or any other aspect of ctorate for information Operations and Reports, 1215 leduction Project (0704-0188), Washington, DC 20503.
1. AGENCY USE ONLY (Leave Blank)	2. REPORT DATE September 1994	3. REPORT TYPE AND D Final	ATES COVERED
4. TITLE AND SUBTITLE Central Heating Plant Moderniza	tion Study for the Defense Person	nel Support Center	5. FUNDING NUMBERS MIPR NAPEN-MM-92001, dated 4 March 1992
5. AUTHOR(S) Martin J. Savoie, Russ Price, Spi	ro J. Deligiannis, Travis L. McCar	nmon	
7. PERFORMING ORGANIZATION NAME	(S) AND ADDRESS(ES)		8. PERFORMING ORGANIZATION
U.S. Army Construction Enginee P.O. Box 9005 Champaign, IL 61826-9005	ring Research Laboratories (USA	CERL)	FE-94/25
9. SPONSORING / MONITORING AGENC Philadelphia District, U.S. Army ATTN: CENAP-EN-MM 100 Penn Sq. East Philadelphia, PA 19107-3390	Y NAME(S) AND ADDRESS(ES) Corps of Engineers		10. SPONSORING / MONITORING AGENCY REPORT NUMBER
11. SUPPLEMENTARY NOTES Copies are available from the Na	tional Technical Information Serv	ice, 5285 Port Royal Ro	oad, Springfield, VA 22161.
12a. DISTRIBUTION / AVAILABILITY STA	TEMENT		12b. DISTRIBUTION CODE
Approved for public release; dist	ribution is unlimited.		
13. ABSTRACT (Maximum 200 words) This report documents a study to Support Center (DPSC), Philade 14 years old. The age of this equ installation. These alternatives ir cogeneration, and absorption chi simulations and design temperat	determine alternatives for modern lphia, PA. The central heating plan ipment warranted an investigation aclude maintaining the status quo, lling. Heating and cooling loads w ures, life cycle costs were develop	nizing the central heatin nt contains five boilers; of alternatives for prov upgrading the existing s ere analyzed using com ed for each alternative.	g plant at the Defense Personnel four are 50 years old and one is iding thermal energy to the system, installing new boilers, oputer simulations. Based on the
		đ	
			· • •
14. SUBJECT TERMS			15. NUMBER OF PAGES 230
Central Heating Plants Defense Personnel Support Cen life cycle costs	steam distribution s ter cost effectiveness	ystem	16. PRICE CODE
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIF OF ABSTRACT Unclassifie	EICATION 20. LIMITATION OF ABSTRACT
ISN 7540-01-280-5500		. 1	Standard Form 298 (Rev. 2-89) Prescribed by ANSI Std 239-18

٦

Foreword

This research was performed for Philadelphia District, U.S. Army Corps of Engineers (CENAP) under Military Interdepartmental Purchase Request (MIPR) No. NAPEN-MM-92001, dated 4 March 1992. The technical monitor was Roger Souser, CENAP-EN-MM.

The work was conducted by the Energy and Utility Systems Division (FE) of the Infrastructure Laboratory (FL), U.S. Army Construction Engineering Research Laboratories (USACERL). The USACERL principal investigator was Martin J. Savoie. Russ Price is a member of Stanley Consultants, Inc., Muscatine, Iowa. Dr. David M. Joncich is Acting Chief, CECER-FE, and Alan Moore is Acting Chief, CECER-FL. The USACERL technical editor was Thomas E. Rice, Information Management Office.

LTC David J. Rehbein is Commander and Acting Director of USACERL, and Dr. Michael J. O'Connor is Technical Director.

	m Tor	.44	
Access1	.011		
NTIS (RA&I		
DTIC TA	AB	<u> </u>	
Imann0	meed	U	
matif	ieation		-
04000			-1
			_
By	hand and	ŝλ	
Distri	DULION		
Avai	lability	Codes	_
	Avail a	nd/or	
	Spec1	al	
B10 C			٠.
N 1			
IN '	1 1		
A BEE	1 [

Contents

SF 298 1				
Fore	word	2		
List o	of Tables and Figures	5		
1	Introduction	9 9 9 9		
2	Existing Steam Supply Systems Central Heating Plant Steam Distribution System	1 1 2		
3	Thermal Energy Supply and Consumption	15 15 16 20		
4	Electrical Power Consumption Electrical Costs Purchased Electricity Electricity End-Use Cooling Load Versus CDD Model	30 30 31 32 32		
5	Projected Energy Consumption	40		
6	Air Quality Regulations Federal Regulatory Requirements State and Local Regulatory Requirements Summary	45 45 46 47		
7	Study Alternatives Status Quo Alternative General Improvements and Upkeep Alternative 1 - Two New Gas/Oil Boilers Alternative 2 - Two New Gas/Oil Boilers and Cogeneration	48 48 49 49 50		

	Alternative 3 - Two New Gas/Oil Boilers, Cogeneration, and Absorption Chiller	50
	Alternative 4 - Refurbish Existing Plant, Summer Boiler	51
	Alternative 5 - Refurbish Existing Plant, Summer Boiler, Cogeneration	51
	Alternative 6 - Refurbish Existing Plant, Two New Spark Gas Engine	
	Generators, and One New Absorption Chiller	52
	Summary of Alternatives and Recommendations	52
	Storage Cooling System Analysis	52
8	Selected Alternative Description	63
	Description of System	63
	Description of Operation	64
	Description of Costs	65
	Project Funding Documents	66
9	Conclusions	78
Appe	ndix A: Description of Buildings and Their Uses	81
Appe	ndix B: SHDP Model and Results	87
Appe	ndix C: BLAST Monthly Building Heating Loads	99
••		
Appe	ndix D: Chiller Equipment	121
Арре	ndix E: BLAST Monthly Building Cooling Loads	125
Арре	ndix F: Life Cycle Cost Analyses	135
Арре	ndix G: STOFEAS Analysis	189
Арре	ndix H: Monthly Electric Load Curves for Alternative 2, Option 6	197
Appe	ndix I: DD1391 Input and Project Development Brochure Forms	205

Distribution

4

List of Tables and Figures

Tables

1	Boilers No. 1 and 2 design data 13
2	Boilers No. 3 and 4 design data 13
3	Boiler No. 5 design data 13
4	CHP average monthly steam loads for 1991 22
5	CHP average monthly fuel consumption for 1991
6	Hot water heat exchangers 24
7	Building categories and energy consumption equations
8	Estimated monthly building heating loads for 1991
9	SHDP model assumptions 26
10	Unconstrained distribution results 27
11	Distribution loss estimates for 1991 28
12	Monthly average HDDs for 1991 29
13	Electric rate schedule
14	Chillers over 100-ton capacity 36
15	Monthly average CDD 37
16	Normal heating load projections 42
17	FY90 monthly electric consumption data 44
18	Status quo alternative LCC summary 55
19	Initial central heating plant improvements

20	Plant upkeep after implementation	56
21	Alternative 1 LCC summary	57
22	Alternative 1, Option 1 LCC summary	57
23	Alternative 2, Option 1 LCC summary	58
24	Alternative 2, Option 2 LCC summary	58
25	Alternative 2, Option 3 LCC summary	58
26	Alternative 2, Option 4 LCC summary	59
27	Alternative 2, Option 5 LCC summary	59
28	Alternative 2, Option 6 LCC summary	59
29	Alternative 3, Option 1 LCC summary	60
30	Alternative 3, Option 2 LCC summary	60
31	Alternative 4 LCC summary	61
32	Alternative 5 LCC summary	61
33	Alternative 6 LCC summary	61
34	LCC summary of alternatives/options	62
35	Plant upkeep after initial construction	69
36	Estimated annual energy use	73
37	Alternative 2, Option 6 LCC summary	74
38	Estimated annual energy costs	74

Figures

1	Steam distribution system	14
2	Percent boiler water makeup	14

•

3	Total boiler water makeup	14
4	Recorded steam flow for 1991	21
5	Monthly estimated steam flow for 1986-1991	23
6	Recorded and estimated steam flow for 1991	23
7	Estimated building loads and steam supply	26
8	Heat load with losses and steam supply profiles	28
9	Heat loads vs. HDD regressions	29
10	Major electric power charges for FY90	34
11	1991 daily electric consumption	35
12	1991 daily demand peaks	35
13	Half-hour demand profiles	36
14	Workdays with CDD	38
15	Monthly CDD and kW	38
16	Projection of monthly kW	39
17	Projection of monthly kWh	39
18	Tentative facility changes	41
19	Projected load profiles	43
20	Solar Centaur Type H gas turbine	67
21	Orthographic of gas turbine	67
22	Heat recovery steam generator (HRSG)	68
23	CHP boiler room layout	68
24	Winter weekend demand	70

25	Summer weekend demand
26	Winter weekday demand
27	Summer weekday demand
28	Winter load duration curve
29	Summer load duration curve
30	Monthly steam supply
31	Status quo vs. Alternative 2, Option 6 electrical costs
32	Status quo vs. Alternative 2, Option 6 fuel costs
33	Status quo vs. Alternative 2, Option 6 total energy costs
34	Initial project capital investments 77

1 Introduction

Background

This report documents results of a study to investigate alternatives for modernizing the central heating plant (CHP) at the Defense Personnel Support Center (DPSC), Philadelphia, PA. The CHP contains five boilers; four are 50 years old and one is 14 years old. The age of this equipment warranted an investigation of alternatives for providing thermal energy to the installation.

DPSC is responsible for the massive task of purchasing food, clothing, textiles, medicine, and medical equipment for the U.S. military. The organization also services the District of Columbia public school system, Veterans' Administration hospitals, and Federal prisons. A unique feature of the installation is its garment factory, which employs about 1000 workers whose task is to produce special-issue military uniforms and apparel.

DPSC has begun investigating modernization opportunities for its CHP, and because of increasing electrical costs cogeneration has been considered a potential alternative for modernizing the plant. The U.S. Army Corps of Engineers Philadelphia District, which is in charge of the modernization project, requested the U.S. Army Construction Engineering Research Laboratories (USACERL) to perform a study to determine the most viable options available to improve the energy supply situation.

Objective

The objective of this study was to identify the most cost-effective technologies for meeting current and future thermal and electrical energy needs at DPSC.

Approach

Information available from past studies and operations records was analyzed and verified to establish baseline conditions. A visual inspection was made of central heating plant equipment and the steam distribution system to assess baseline operating conditions and problem areas. 9

The next task analyzed the energy use patterns of DPSC. This analysis included current thermal and electrical energy demand, heating load, and usage patterns. This task also projected future energy use for the facility. A variety of prediction methods were used depending on the specific energy pattern being investigated.

Based on the energy use pattern analysis, potential thermal energy supply options were identified. These options were evaluated in terms of their cost, efficiency, and reliability. The evaluation also considered regionally available and appropriate fuel supplies. Potential electrical energy supply options also were identified based on the energy use pattern analysis. Like the thermal energy supply options, electrical energy will be evaluated according to cost and reliability.

Environmental factors including asbestos removal, demolition material disposal, and air pollution control requirements were evaluated and included in the cost analysis of each alternative.

Based on the findings of the above tasks, life-cycle cost (LCC) analyses were developed for maintaining the status quo, upgrading the existing system, installing new boilers, cogeneration, and absorption chilling. Additional options within these alternatives will be considered to further improve the life cycle costs.

2 Existing Steam Supply Systems

This section describes the existing central energy plant equipment and steam distribution system.

Central Heating Plant

The DPSC central heating plant, located in Building No. 8, consists of five steam boilers. Boilers 1 to 4 from east to west are Edge Moore Iron Works water tube boilers that were originally designed to burn No. 6 oil. They were installed in 1941-42, each having a current rating of 100,000 lb/hr steam at 180 psi, 435 °F. Boilers No. 1 and 2 were converted in 1944 to burn coal using dump grate technology, but operated on coal for only a few years. They have not operated for at least 25 years, and the coalfeed systems have been disconnected from the boilers. Design data for Boilers 1 and 2 are summarized in Table 1^{*}

Boilers No. 3 and 4 were converted to dual fuel (natural gas and No. 6 oil) and are used for heating all buildings and for process steam during the heating season. Because only one boiler is required to supply the complex, the second boiler is operated on a standby basis. Both boilers were retubed in February 1966 and the superheaters and crossovers were replaced in June 1983. Both units have airheaters and blowdown heat exchangers, but neither have economizers or oxygen trim control. These boilers appear to be in acceptable condition considering that the last retube was 26 years ago and that they were operated alternately most of this time. The fireside inspection showed no tube warping, blistering, pitting, or soot accumulation. The drums also appeared to be in good condition.

Boilers No. 3 and 4 are equipped with an external induced air blower (41,000 CFM) and an external forced air blower (23,600 CFM). Additional boiler support equipment includes four turbine-driven feed water pumps (two are steam-powered rated at 250 GPM each and two are steam-electric powered rated at 200 GPM each) and three electric motor-driven condensate return pumps rated at 50 GPM each. Also, both units have an air heater and a blowdown heat exchanger, but neither has an economizer or oxygen trim. Table 2 summarizes design data for Boilers No. 3 and 4.

^{*} Tables and figures are included at the end of their associated chapters.

Boiler No. 5 is a packaged dual fuel boiler installed in 1977. It has a rating of 30,000 lb/hr at 180 psi, 550 °F. This boiler has an economizer but the oxygen trim control is not operating. Boiler No. 5 typically operates in the summer to provide steam for process loads, which include heat exchangers for domestic hot water and the factory sponging plant. The CHP feedwater pumps also are driven by 180 psi steam. The boiler heating surface is 2,405 sq ft and has a 523 sq ft waterwall. Table 3 summarizes the design data for Boilers No. 5.

Steam Distribution System

The CHP provides steam for heating and process loads to 15 buildings via steam lines that measure about 33,500 linear feet. Figure 1 shows the main distribution system pipes (in bold). Because the lines run primarily through the building ceilings and utility tunnels, the heat losses will be minimal. A visual inspection of those pipes located in the ceilings was limited; however, exposed pipes were well insulated and no leaks were found.

The condensate return system also appears to be in good condition based on a visual inspection and the amount of condensate returned to the CHP. There is a small constant loss of condensate at the fuel oil pump house from steam used to heat the oil. Figures 2 and 3 show the percent boiler makeup water and the total makeup water used, respectively. Over the last 3 years, the percentage of makeup water varied from about 20 percent in the heating season to 45 percent in the summer months. The higher percentage in the summer is caused by a fairly constant condensate loss and the lower amount of steam produced. The amount of makeup used in the summer over the last 3 years was about 2.8 million lbs, and the amount in the winter ranged from 3.5 million lbs to 6 million lbs.

Manufacturer	Edge Moore
Year Built	1941 (converted 1944)
Туре	Stoker fired (originally oil fired)
Capacity	75,000 lb/hr, 275 psig allowable pressure
Boiler Size	2,100 HS (coal fired)

Table 1. Boilers No. 1 and 2 design data.

Table 2. Boilers No. 3 and 4 design data.

.

Manufacturer	Edge Moore
Year Built	1941
Serial Number	#3 - NB 3337; #4 - NB 3336
Boiler Size	2,100 HS; 1,051 HP
Fuel	No. 6 oil and natural gas
Capacity	100,000 lb/hr, 160-180 psig normal operating, 275 psig allowable pressure
Note:	There are four 4-inch safety valves set at 205, 215, 218, and 220 psig, respectively.

Table 3. Boiler No. 5 design data.

Manufacturer	Cleaver Brooks
Year Built	1976
Serial Number	WL 2633
Model Number	WT-400X-BR-3 and D-60-S
Firing Rate	40,703 MBtu/hr
Fuel	Natural gas at 55 in. w.c.; No. 6 oil at 100 psi
Pressure	260 psig; 30,000 lb/hr; 200 psi operating; 260 psig design
Note:	The feedwater control valve is Bailey Meter Co., Type VBH 11000A, size1-1/2 x 1-1/2.



Figure 1. Steam distribution system.



Figure 2. Percent boiler water makeup.



Figure 3. Total boiler water makeup.

3 Thermal Energy Supply and Consumption

This section describes current thermal energy supply and use. Central heating plant steam output and fuel use were analyzed for trends, and building heating loads and distribution systems losses were modeled. This section also develops correlations between thermal energy use and heating degree days for use in load prediction.

Cost of Steam

An estimate for the cost of steam was developed from three major cost elements: fuel, labor, and other operation and maintenance (O&M) costs. Other O&M costs such as utilities, minor repairs, and water treatment chemicals were estimated from the 1991 *Facilities Engineer Annual Work Plan*, DPSC Form 2547-1. Annual fuel costs were about \$1,155,600 (natural gas cost is about \$4.95/MBtu), labor costs were about \$240,300, and other O&M costs were about \$206,500. The total cost of producing steam was about \$1,993,400 per year. Dividing this cost by the amount of steam produced (172,703 lbs) gives a cost of \$11.5/K lb steam or \$9.61/MBtu. A good cost for steam is about \$6/MBtu, although \$10/MBtu is not unusual for DOD.

Central Heating Plant Steam Load

CHP personnel collected system data on DA Form 3995, *Daily Boiler Plant Operating Log*, which contains hourly and shift information on many important operating parameters. This information is summarized on a monthly basis in a record book maintained by the plant foreman. The hourly steam flow readings were the primary source for estimating peak steam usage because of the detail available. Monthly natural gas consumption was also used to provide a cross-check of the steam flow readings.

The baseline year selected for thermal energy consumption was 1991 because it was the most current period with complete and available records. No unusual activities were identified that might skew projections of energy consumption. Figure 4 shows the hourly steam demand for 1991, with the highest demand recorded about 53,000 lb/hr in both December and February. The summer demand averages about 7000 lbs/hr with peaks of about 10,000 lbs/hr. Table 4 shows the total steam flow and average hourly steam flow on a monthly basis for 1991.

The CHP also records the natural gas flow and No. 6 oil flow once during each operating shift; this is summarized in a monthly log book. Table 5 shows the monthly fuel input for 1991. To compare the natural gas input with steam demand, the natural gas readings were converted to lbs/hr steam by applying the following assumptions: natural gas heating value at 1000 Btu/cf, enthalpy of steam at 1197 Btu/lb, and boiler efficiency at 75 percent. Figure 5 represents estimated monthly averages for the last 6 years, showing little change in steam production for those years. The figure also shows a problem with the December 1991 fuel record, which is obviously incorrect, probably because of a natural gas outage and incorrect reading of the gas or fuel oil meters.

Figure 6 compares the recorded steam flow and natural gas estimate for 1991 to provide a comparison of the recorded steam flow and the steam flow estimated from the fuel input. The steam demand estimated from fuel input was slightly lower than the recorded steam flow, except for the month of December, which had a problem with the recorded fuel consumption. This indicates the steam flow recorder is quite close to calibration. The month of December 1991 was replaced with December 1990 for the rest of this analysis.

Steam End-Use

The CHP output is a good indicator of current thermal energy use; however, individual building and process loads must be estimated if substantial facility changes are expected so that they can be removed from the CHP load profile. DPSC has no significant steam process or cooling loads. A potentially large load from a preshrinking (sponging) plant in the factory was discontinued in 1990 with no plans to replace it. There are a few small process steam demands from hot water heaters (listed in Table 6) and from 136 steam presses at the factory.

There are currently no operating steam submeters to measure building heating or process loads. The factory had steam meters, but they have not been used since the preshrinking plant ceased operations. End-user loads had to be estimated using the modeling techniques HEATLOAD and Building Loads Analysis and System Thermodynamics (BLAST). This study used both these techniques to add another level of confidence to the estimations.

HEATLOAD

HEATLOAD, developed by USACERL, provides a simple method of calculating building heat requirements. Other computer programs such as BLAST or DOE2 can provide more accurate analysis, but require much more information to develop a heat load estimate. Experience with HEATLOAD has shown it to be quite accurate for estimating installation-wide building heat requirements for central energy plant alternatives.

HEATLOAD is based on a series of linear regressions developed from heating use measurements at typical facilities on several Army installations. The facility categories and regressions are listed in Table 7. Each building type has a corresponding daily heating energy consumption equation in the form of $E_h = a_1 + (b_1 \times HDD_d)$, where a_1 and b_1 are regression parameters. The symbol E_h is the daily heating energy consumption (Btu/sq ft/day) and HDD_d is the daily heating degree day. The regression parameter a_1 is a constant that represents energy usage that occurs for zero HDD and reflects nonheating loads such as hot water and cooking. The regression parameter b_1 is the heating load parameter. Building categories and area (sq ft) are obtained from DPSC Master Planning files.

The climatological data required for HEATLOAD, such as the historical average HHD and the design temperature, are obtained from the Army technical manual *Engineering Weather Data* (TM 5-785, 1978) or directly from the U.S. Air Force Environmental Technical Applications Center (ETAC) at Scott Air Force Base, IL. With this information, HEATLOAD will calculate the peak hourly heating load, average monthly loads, maximum monthly loads, and total annual heating load.

BLAST

The BLAST program, also developed by USACERL, is a comprehensive program for predicting energy consumption and energy system performance in buildings. BLAST uses rigorous and detailed algorithms to compute loads, to simulate fan systems, and to simulate heating and chiller systems. Because this study emphasized using a central heating plant and not individual building heating systems, only the load simulation portion of the program was used. The load simulation performs a complete radiative, convective, and conductive heat balance for each zone surface and a heat balance on room air. This heat balance includes transmission load, solar loads, internal heat gains, infiltration loads, and the temperature control strategy used to maintain the space temperature. The BLAST program contains many supporting data libraries, including Schedules, Locations, Design Days, Controls, Materials, Walls, Roofs, Floors, Doors, Windows, Passive Controls, and Weather. Because this was a conceptual study, the BLAST analysis took advantage of the many defaults available in the BLAST Libraries. Additional site-specific information was gathered over a four-day site visit. The primary site-specific inputs to BLAST were building orientation, interior temperature, number of personnel, lighting, number of computers, number of floors, floor area, window area, and roof area.

Heating Load Estimates

Table 8 shows the total monthly building heat loads estimated by HEATLOAD and BLAST. The individual building loads were estimated based on 1991 heating degree days and summed for each month. These loads are compared graphically in Figure 7 with the CHP output based on 75 percent of fuel consumption and on the recorded steam flow. It is important to note that neither HEATLOAD nor BLAST account for distribution losses. Also, HEATLOAD estimates include domestic hot water use, whereas BLAST does not. Distribution losses are estimated in the following section.

Distribution System Losses

A steam distribution system typically consists of pipes, regulators, valves, traps, and vaults. Steam enters the system at the steam plant, passes through pipes, vaults, and regulators, and is delivered to the buildings. The steam loses heat through pipe walls by conduction. As the steam passes through the pipes, regulators, and valves, steam pressure drops. Condensate formed in the pipes is removed from the system through steam traps and a condensate piping system. The amount of lost energy from the steam distribution system can be substantial.

One way of estimating the distribution losses is to look at the lowest hourly steam flow during the summer months. This technique works only if there are no substantial summer steam loads. Figure 4 shows the lowest steam demand to be about 3000 lbs steam/hr, indicating the distribution losses are about 3000 lbs steam/hr (3.6 MBtu/hr). Determining the lowest summer load by analyzing steam load data is a good method for estimating distribution losses, but is not a rigorous method. To better quantify these losses, this study used a computer model called the Steam Heat Distribution Program (SHDP) to analyze distribution system losses.

SHDP Analysis. SHDP is a pressure-flow thermal efficiency computer program for modeling steam district heating systems. This program has several capabilities, including (1) design and economic evaluation of manhole renovation and modifications or additions to existing distribution systems, and (2) economic evaluation of operating at lower pressures and improved maintenance of steam traps. In this study, SHDP was used primarily to estimate distribution losses.

In order to use SHDP, the entire DPSC steam distribution system was mapped. As discussed in Chapter 2, Figure 1 shows the distribution map with the general location of buildings on the distribution system.

SHDP is designed to estimate the total heat load to the heating plant with a breakdown of the distribution losses. This requires entering distribution line nodes, line diameters and lengths, CHP supply pressure, and individual building loads. Nodes are locations of pipe size changes, pressure reducing valves, and thermal loads (typically buildings). Pipe diameters and lengths were obtained from blueprints of the DPSC distribution system. As described in the previous section, the thermal loads for each building were estimated using the HEATLOAD program. Table 9 lists the basic assumptions that were made in creating the distribution model for DPSC.

The SHDP model was run using unconstrained pressure throughout the system to determine if adequate pressure is available to each building. The results indicated that the boiler outlet pressure is 180 psi and that Building 30 would experience the lowest pressure in the system at 158 psi. This analysis indicates that the distribution system can easily provide the required pressure at all buildings. It also indicates that absorption chillers could be located anywhere in the distribution system. Table 10 lists the unconstrained pressures and steam flows for each building.

For the design day of 14 $^{\circ}$ F, SHDP predicts that the total steam to all loads will be 57,667 lbs/hr or 62.3 Mbtu/hr, and the total plant output required will be 59,465 lbs/hr or 71.2 MBtu/hr. The total thermal system losses will be 2.27 MBtu/hr for this design temperature.

The distribution losses estimated by SHDP are shown in Table 11. The building heat loads were set to zero. The distribution loss in the summer is about 2 MBtu/hr, fairly close to the 3.6 MBtu/hr rough estimate by inspection of the hourly steam logs. These losses were added to the HEATLOAD monthly estimates to obtain a total monthly steam demand on the CHP. For BLAST, the distribution losses and an average of 8.5 MBtu/hr for process loads were added to the monthly estimates to obtain a total monthly steam demand on the CHP.

Figure 8 compares the CHP steam load profiles based on 75 percent fuel input and on recorded steam flow and the HEATLOAD and BLAST monthly load profiles. The HEATLOAD profile compares most favorably to the CHP steam load profiles.

Heating Load Versus HDD Model

Heating loads are typically closely related to the outside temperature or heating degree day (HDD). However, a single year is not a good prediction of the steam demand for the 25-year period required for life cycle cost analysis of alternatives, unless it is close to the normal HDD for the region. A correlation developed between steam demand and HDD for 1 year can be used to project the steam demand for the normal HDD.

Linear regressions were performed on the monthly load profiles in Figure 8 and the corresponding monthly HDD. The monthly HDDs for the study period obtained from ETAC are shown in Table 12. The results are shown graphically in Figure 9, and indicate that the HEATLOAD regression provides a better prediction than BLAST; therefore, the HEATLOAD regression will be used to model projected steam requirements for the modernization alternatives.





Month	Total Steam Flow (K lbs)	Average Steam Flow (Ibs/hr)	Total Average Steam Flow (MBtu)	Steam Flow (MBtu/hr)
Jan	28,472	38,269	34,081	45.8
Feb	22,834	33,979	27,332	40.5
Mar	22,255	29,913	26,639	35.7
Apr	10,977	15,246	13,139	18.2
Мау	5,709	7,673	6,834	9.1
Jun	6,149	8,540	7,340	10.2
Jul	5,557	7,469	6,652	8.9
Aug	4,500	6,048	5,387	7.2
Sep	4,468	6,483	5,348	7.7
Oct	8,172	10,984	9,782	13.1
Nov	23,347	32,426	27,946	38.7
Dec	25,499	34,273	30,522	40.9

Table 4. CHP average monthly steam loads for 1991.

 Table 5. CHP average monthly fuel consumption for 1991.

Month	Total (MBtu)	Average (MBtu/hr)
Jan	38,360	51.6
Feb	30,712	45.7
Mar	29,903	40.2
Apr	14,925	20.7
Мау	7,439	10.0
Jun	7,137	9.9
Jul	6,709	9.0
Aug	7,385	9.9
Sep	6,831	9.2
Oct	11,460	15.4
Nov	27,734	38.5
Dec	13,547	18.2



Figure 5. Monthly estimated steam flow for 1986-1991.



Figure 6. Recorded and estimated steam flow for 1991.

Bida. No.	Tank Dia. (in.)	Size Lth. (ft.)	Water Min. °F	Temp. Max. °F	Steam Temp. Press. PSI	Steam Reading °F	Steam Pipe (in.)	Water Supply
5	42"	10	110°	160°	15#	140°	2"	Bldg. #5 For Emerg. Disp. Bldg. 6
61C	42"	10	110°	145°	15#	145°	3/4"	Supplies 6-2 to Pole 46 6-1 Mail Room 8-1 Boiler Rm Elec. Shop
9 SP Base Bay	36"	9	130°	190°	15#	145°	3/4"	9-A,B,C All Floors
9-1 F	36"	9	130°	190°	20#	145°	3/4"	Rest of Bldg. All Floors
11	31"	6	140°	1 8 0°	8#	· 140°	1/2"	All Floors
12	42"	10	130°	190°	45#	135°	1"	All Floors
13	59"	10	110°	150°	15#	130°	- 1"	All Floors
14	30"	8	130°	190°	45#	158°	3/4"	Everything Kitchen
15	42"	8	120°	170°	15#	145° .	1"	All Floors
30	30"	10	130°	190°	20#	145°	1"	Bldg. #30
^m 2 _C	30"	. 6	120°	150°	8#	110°	1"	M-2-C Men's

 Table 6. Hot water heat exchangers.

Tuble 7. Dundnig dategeried and energy	
Troop housing barracks	E _h = 130.50 + (10.53 x HDD _d)
Troop housing barracks (after 1966)	E _h = 81.91 + (7.40 x HDD _d)
Troop housing barracks (modular)	E _h = 295.90 + (10.53 x HDD _d)
Dining facilities	E _h = 241.90 + 0
Family housing	E _h = 113.5 + (10.53 x HDD _d)
Administration/training	E _h = 75.71 + (7.02 x HDD _d)
Medical/dental	E _h = 254.40 + (11.41 x HDD _d)
Storage	E _h = 35.70 + (10.53 x HDD _d)
Production/maintenance	E _h = 138.25 + (10.53 x HDD _d)
Fieldhouses/gymnasiums	E _h = 73.69 + (4.39 x HDD _d)

Table 7. Building categories and energy consumption equations.

Table 8. Estimated monthly building heating loads for 1991.

Month	HEATLOAD (MBtu/hr)	BLAST (MBtu/hr)
Jan	43.9	51.7
Feb	38.1	43.5
Mar	30.7	33
Apr	20.3	18.4
Мау	10.2	4.2
Jun	8.5	1.8
Jul	8.5	1.8
Aug	8.5	1.8
Sep	10.2	4.2
Oct	16.8	13.5
Nov	29.5	31.3
Dec *	38.5	44

* December 1990



Figure 7. Estimated building loads and steam supply.

Table 9. SHDP model assumptions.

Pipe roughness	0.0025
Pipe environment temperature	65 °F
Load condensate temperature	150 °F
Steam trap leakage rate	0
Fraction of load condensate returned	0.9
Fraction of pipe condensate returned	0.9

Building	Pressure (psi)	Steam Flow (Ib/hr)
CHP	180	59465
1	178	4533
2	176	3963
3	179	2079
4	179	4246
6	180	5572
8	180	1712
9	178	15862
11	166	138
12	165	2959
13	178	8698
14	179	1827
15	179	565
20	179	2517
22	179	74
26	179	1544
30	158	1678
51	179	94

Table 10. Unconstrained distribution results.

* All values for design temperature of 14 $^{\circ}\text{F}$ or 51 HDD.

Month	Losses (MBtu/hr)
Jan	2.3
Feb	2.1
Mar	2
Apr	1.8
Мау	1.7
Jun	1.6
Jul	1.6
Aug	1.6
Sep	1.7
Oct	1.8
Nov	2
Dec *	2.1

Table 11. Distribution loss estimates for 1991.

* December 1990





Month	HDD
Jan	920
Feb	694
Mar	576
Apr	296
May	44
Jun	0
Jul	0
Aug	0
Sep	42
Oct	215
Nov	527
Dec *	701

Table 12. Monthly average HDDs for 1991.

* December 1990



Figure 9. Heat loads vs. HDD regressions.

4 Electrical Power Consumption

This section describes current electrical energy supply and use. Trends in electrical power supplied by the utility were analyzed and building cooling loads were modeled.

Electrical Costs

DPSC's electrical power is supplied by the Philadelphia Electric Company (PECO), and electricity costs are based on PECO's High-Tension Light and Power (HT) rate schedule. A three-tier energy usage charge and a demand charge make up most of the bill; a small customer charge and various tax and incentive adjustments make up the balance of the bill. The basic rate schedule is shown in Table 13.

The billed demand consists of the maximum 30-minute measured demand in the month computed to the nearest kW but not less than the measured demand, adjusted for the power factor. For October to May the billing demand cannot be less than 40 percent of the maximum demand specified in the contract (7,500 kW), nor less than 80 percent of the highest billing demand in the preceding months of June to September.

Time of use adjustments are used for customers with a measured demand of 2000 kW or greater. A credit is given for energy use during off-peak hours and an additional charge is added for energy use during on-peak hours. The on-peak hours are 8 a.m. to 8 p.m. Monday to Thursday and 8 a.m. to 4 p.m. Friday. All remaining hours, including weekends and holidays, are considered off-peak.

Of these costs, the energy-use charges and the demand charge are the most significant. Figure 10 compares the magnitude of the major electric charges for FY90 with DPSC electric bills. The demand charge accounts for about 25 percent of the annual electric charges, the energy-use charges account for 76 percent, and on-peak use accounts for about 1 percent (not including the tax and energy adjustments). The demand charge for FY90 averaged \$84,000 per month in the summer and \$54,000 per month in the winter, or \$64,240 per month for the year. The average demand cost was \$10.48/kW based on an average peak demand of 6,143 kW. The total cost of electricity was \$2.8 million for 31.7 million kWh or \$0.0895/kWh (\$26.2/MBtu). The electricity charges remain relatively constant partly because of DPSC's stable load. The winter charges, however, are constant because of the 40 percent and 80 percent minimum peak demand rates discussed previously. This minimum peak rate added another \$38,000 to the winter month bills.

Purchased Electricity

PECO provided DPSC daily and hourly electrical information for 1991. Daily records included on-peak and off-peak consumption and the highest on-peak and off-peak peak demands. Hourly records contained half-hour peak demands for the entire day. Figure 11 is an area graph that shows the off-peak electrical use in dark shade and the on-peak (light shade) added to it. The tall peaks represent the electrical use on workdays, and these peaks occur in the summer months on workdays because of the cooling load. The highest daily use is about 135,000 kWh. The dark peaks between the light peaks represent the highest electrical use on nonworking days, typically Saturday. The nonworking day electrical use also increases in the summer to maintain a minimum level of cooling.

Figure 12 shows the daily on- and off-peak demands for 1991. The on-peak demand follows a similar pattern to the on-peak use (see Figure 11), the winter and summer months being constant. The peak demand is just below 7,500 kW and the off-peak demand follows a similar pattern with the addition of two subset patterns. The pattern directly below the on-peak demand represents the off-peaks just before or after the on-peak hours of 8 a.m. to 8 p.m. The lower pattern of off-peaks is made up of nonworking days. Within this pattern are separate patterns, one for Saturdays and one for Sundays. Sundays typically have a lower peak than Saturdays. The low peaks of the Christmas holidays can be seen in the far right of the graph.

The half-hour demand profiles for the cooling season and the heating season are shown in Figure 13. This figure shows an example profile for (1) a summer workday, (2) a summer weekend, (3) a winter workday, and (4) a winter weekend. The workday profiles for summer and winter are very similar, even showing the same dip at 11 a.m. when personnel turn off lights, computers, and other equipment in the shops and the factory for their lunch break. The figure indicates the cooling load is fairly constant at about 2000 kW between 8 a.m. and 3 p.m. The weekend profiles are also similar because they remain fairly constant throughout the day. Both workday and weekend profiles show an off-peak cooling peak of about 1000 kW.

Electricity End-Use

As discussed in the previous sections, the DPSC electrical usage and demand peaks are fairly constant during the noncooling season, averaging about 2.2 million kWh per month and 5100 kW, respectively. The noncooling loads are primarily from lighting, computers, and factory operations.

The cooling season loads are fueled by approximately 75 chillers with a total chilling capacity of about 4075 tons. A significant portion of this capacity is from a few large chillers, which are listed in Table 14. Appendix B contains a complete list of the chillers. There are also numerous window units.

Like the heating loads, the building cooling loads were modeled using the BLAST program. Currently there is no counterpart to the HEATLOAD model for cooling loads. The BLAST cooling loads, however, were about one-third the load estimated from the PECO records. The BLAST simulations will be reviewed to refine the estimate.

Cooling Load Versus CDD Model

A standard practice for electrical power alternatives studies is to use the electrical consumption and demand pattern of a year with similar cooling degree days (CDD) as the normal CDD. The most recent time period with CDD similar to the normal was FY90. The next closest year was FY85, but being 7 years old it would pose additional problems in determining facility loads. The monthly normal and FY90 CDD, obtained from ETAC, are shown in Table 15.

Another method of projecting loads is to develop a linear model based on a previous year. For DPSC, a model of both peak demands (kW) and consumption (kWh) was required because electric bills are based on daily on-peak kW and monthly kWh. Although cooling peak demands and consumption are affected by many factors, they are highly dependent on CDD. Regression analyses were made between 1991 CDD data and the daily on-peak kW and monthly kWh. These regressions are shown graphically in Figures 14 and 15. The peak kW regression used only workdays and neglected days with daily peak demands below 6,500 kW to factor out the influence on nonworking days. The regression has a correlation coefficient of 0.63, indicating a strong correlation between CDD and daily on-peak demand.

Figure 15 shows the regression between monthly consumption and monthly CDD data. This regression has a correlation coefficient of 0.92, indicating a stronger correlation between CDD and monthly consumption. The points grouped near the origin (zero
CDD) are months that have no cooling load. The monthly noncooling electric load is approximately 2,300,000 kWh.

These two regressions or models were then used to project long-term (normal) energy use patterns. In Figures 16 and 17 the normal projections are compared to the FY90 energy use patterns. Figure 16 indicates that the FY90 data underpredicted the peak kW for the noncooling months, but was quite close for the cooling months. The FY90 data compared favorably with the normal projection of monthly consumption.

The FY90 data was used for the preliminary alternative analysis; however, the regression models will be used for the more detailed conceptual design of the selected alternative.

Table 13.	Electric rate schedule.	
-----------	-------------------------	--

Customer charge	\$281.48 (Jun-Sep) \$257.20 (Oct-May)			
Demand charge	\$12.52 per billed kW demand (Jun-Sep) \$ 7.93 per billed kW demand (Oct-May)			
Energy charge	 \$0.0856 per kWh for first 150 kWh per billed kW demand \$0.0582 per kWh for next 150 kWh per billed kW demand not to exceed 7,500,000 kWh \$0.0312 per kWh for all additional kWh 			
Time of use adjustments Off-Peak Credit On-Peak Charge	(Jun-Sep) \$0.0021 per kWh \$0.0057 per kWh	(Oct-May) \$0.0021 per kWh \$0.0022 per kWh		



Figure 10. Major electric power charges for FY90.



Figure 11. 1991 daily electric consumption.



Figure 12. 1991 daily demand peaks.



Figure 13. Half-hour demand profiles.

Table 14: Office	3 OVEL 100-1011 C	apacity.			
Bldg	Units	Capacity	Use	Age	Media
6-1-C	2	400 Ton	Entire Bldg	1986	R-11
9-1E&F	1	130 Ton	OTIS & Subs	1990	R-22
9-3E&F	1	140 Ton	Subs & Med	1991	R-22
12-LL	1	550 Ton	Entire Bldg	1990	R-11
12	1	1200 Ton	Factory	1973	R-11
14-R	1	130 Ton	Partial	1961	R-11
15	1	250 Ton	Entire Bldg	1973	R-12

Table 14. Chillers over 100-ton capacity.

Month	FY90	Normal
Jan	0	0
Feb	0	0
Mar	9	0
Apr	29	0
Мау	20	59
Jun	226	202
Jul	413	357
Aug	341	319
Sep	152	129
Oct	18	9
Nov	1	0
Dec	0	0
Total	1209	1075

Table 15. Monthly average CDD.



Figure 14. Workdays with CDD.



Figure 15. Monthly CDD and kW.



Figure 16. Projection of monthly kW.



Figure 17. Projection of monthly kWh.

5 Projected Energy Consumption

DPSC has not finalized a master plan projecting building, personnel, or mission changes that might affect the consumption of thermal and electrical energy. There are tentative plans to demolish some of the World War I warehouse buildings (Building 5 was demolished during this study) and add one new facility (Figure 18). The loss of the warehouses would reduce the heating load but would have little effect on the electrical load. There is also a tentative plan to construct a new Operations/ADP building located at the center of the installation. DPSC engineering personnel indicated that this building would replace existing building functions without the addition of personnel. Although the new building might increase electrical consumption because of more computer equipment, the heating load would probably drop because the building would be more energy efficient.

Because of the tentative nature of these changes, energy consumption projections will be based on normal weather data and design temperatures only. The effect will be to somewhat overdesign the heating plant and underpredict electrical consumption. The heating plant will be designed to provide adequate turndown for the tentative reductions in heating load.

Table 16 shows normal HDD, monthly heating load estimates, and design day estimate using the steam log data, 75 percent fuel data, HEATLOAD, and BLAST. The linear model of heating load and HDD developed from the 1991 data was modified using the normal HDD to estimate the average monthly heating loads. Figure 19 compares the projected heating loads, with HEATLOAD providing the best model of heating load. Based on the design HDD of 51, the maximum plant capacity is about 69.4 MBtu/hr (58,000 lbs steam/hr) output.

As discussed previously, FY90 was selected as a comparable year to the normal year for estimating the energy consumption and peak demands. Table 17 shows the monthly consumption data.



Month	Normal HDD	HEATLOAD MBtu/hr	BLAST MBtu/hr	75% Fuel MBtu/hr	Steam Log MBtu/hr
Jan	1048	51.2	69.4	54	49.8
Feb	893	48.9	66.2	51.4	47.6
Mar	718	38.3	51.4	39.4	37.3
Apr	363	24.9	32.6	24.2	24.2
Мау	127	15.1	18.9	13.2	14.7
Jun	0	10.1	11.9	7.5	9.9
Jul	0	10.1	11.9	7.5	9.9
Aug	0	10.1	11.9	7.5	9.9
Sep	33	11.6	13.9	9.1	11.2
Oct	273	20.8	26.9	19.7	20.3
Nov	576	33.4	. 44.6	34	32.6
Dec	915	46	62.2	48.1	44.8
Design	51	69.4	87.5	70.2	77.7

 Table 16. Normal heating load projections.



Figure 19. Projected load profiles.

Month	BILLED Peak kW	ACTUAL Peak kW	Rate 1&2 kW	Rate 3 kW	On-Peak kWh	Off-Peak kWh	Total kWh
Jan	6139	4992	920850	421300	952005	1310995	2263000
Feb	6139	5040	920850	341300	1028583	1154417	2183000
Mar	6139	5160	920850	308300	1035774	1114226	2150000
Apr	6139	5976	920850	557300	1052274	1346726	2399000
Мау	6366	6366	954900	648200	1154673	1373327	2528000
Jun	7263	7164	1089450	915100	1392300	1701700	3094000
Jul	7333	7248	1099950	1043100	1359837	1883163	3243000
Aug	7144	7032	1067100	1262800	1368810	2028190	3397000
Sep	7186	7110	1077900	1192200	1450011	1897989	3348000
Oct	6426	6426	963900	674200	1170546	1431454	2602000
Nov	6139	6139	920850	508800	1089531	1260969	2350500
Dec	6139	5064	920850	343300	1008516	1176484	2185000

 Table 17. FY90 monthly electric consumption data.

6 Air Quality Regulations

Air quality regulations are the most significant environmental regulations that will affect the analysis of alternatives for this study. The Clean Air Act Amendments of 1990 (CAAA) have placed tighter constraints on emissions from most industrial sources, particularly combustion sources.

Federal Regulatory Requirements

The Philadelphia area has been designated as nonattainment (does not meet current air quality standards) for ozone (O_3) , carbon monoxide (CO), and total suspended particulate (TSP) in *New Source Review* (NSR), a publication of the U.S. Environmental Protection Agency. Virtually all of the Philadelphia Consolidated Metropolitan Statistical Area (CMSA), which includes Pennsylvania, New Jersey, and Delaware, is designated a *severe* nonattainment area for O_3 . High traffic density areas in the City of Philadelphia and some areas in Trenton and Burlington, NJ, are designated as *moderate* nonattainment for CO. Some census tracts within the City of Philadelphia; Pottstown Borough in Montgomery County, PA; South Coatesville Borough in Chester County, PA; and Camden, NJ, are designated nonattainment for TSP.

The TSP nonattainment designation essentially restricts the fuel selection for DPSC to natural gas because natural gas combustion systems emit very little particulate matter. CO should not be a factor because the nonattainment designation only applies in very limited areas and mobile sources are the major source of CO problems in moderate CO nonattainment areas. Therefore, the O_3 nonattainment rules will be the controlling regulations for this study.

The 1990 CAAA's establish emission limits for O_3 precursors in areas designated as severe O_3 nonattainment. The emission limits for O_3 precursors [volatile organic compounds (VOC) and nitrogen oxides (NO_x)] are set at 25 tons per year (TPY). These limits became effective 15 November 1992. The emission thresholds defining a major modification to an existing major source in a nonattainment area under the previous rules have not been modified by the 1990 CAAA's. However, the 25 TPY major source definition is less than the old major modification definition. A major source is also defined as "any physical change or change in method of operation at an existing nonmajor source that constitutes a major stationary source by itself." Therefore, any existing source that increases emissions of VOC or NO_x by 25 TPY is subject to nonattainment NSR.

A source that is subject to nonattainment NSR in a severe O_3 area must install emission control equipment that meets Lowest Achievable Emission Rate (LAER) requirements and obtain offsetting emissions decreases from existing sources at a ratio of 1.3:1. Emissions offsets could also be obtained from reduced operation of the owner's existing boilers at a ratio of 1:1.

The 1990 CAAA's require Reasonably Available Control Technology (RACT) on all facilities (entire facility) that emit 25 TPY or more of VOC or NO_x . This will apply to existing boilers and possibly to the gas turbines or spark gas engines once the program takes effect under the federal operating permit requirements of the 1990 CAAA's.

State and Local Regulatory Requirements

A permit to construct must be obtained from the Philadelphia Air Management Service (AMS), which enforces Federal, State, and local air quality regulations. However, the Federal requirements outlined previously should be the most restrictive regulations that apply to a gas turbine or spark gas engine installation. Pennsylvania state regulations limit SO_2 emissions from any source located in the southeastern Pennsylvania air basin greater than 250 million Btu per hour (MBtu/hr) heat input to 1.0 lb/MBtu, and sources less than 250 MBtu/hr to 0.6 lb/MBtu [Pennsylvania Regulations 123.22(4)(i) and 123.22 (4)(iv)(e)(1)]. No. 2 and lighter fuel oils must contain no more than 0.2 percent sulfur by weight, and No. 4 and heavier fuel oils cannot exceed 0.5 percent sulfur by weight [Pennsylvania Regulation 123.22 (4)(iv)(e)(2)]. Sources with heat inputs greater than 250 MBtu/hr and an average annual capacity greater than 30 percent are required to install, operate, and maintain a continuous emissions monitoring system (CEMS) for NO_x.

Pennsylvania air quality regulations for nonattainment areas are still in effect at this time, although the Federal nonattainment regulations discussed previously are more rigorous and will constitute the basis for design. The Pennsylvania nonattainment regulations are found in Subchapter C of the Pennsylvania air quality regulations. A major source in a nonattainment area is defined in Section 127.63, a major VOC source is defined in Section 127.63(2), and a major CO source is defined in Section 127.63(3). These are sources that emit 50 TPY, 1000 lb/day, or 100 lb/hr of these air pollutants. Section 127.65(1) requires LAER on major sources, Section 127.65(3) requires offsets for major sources, and Section 127.66(a)(1) requires offsets in the ratio of 1.3:1 for VOC and 1.1:1 for CO from major sources.

Summary

Air pollution regulations essentially limit the combustion fuel for DPSC to natural gas. However, because of the severe nonattainment designation for ozone, DPSC will also be limited to an increase in nitrogen oxide emissions of 25 TPY to avoid RACT regulations that would require costly pollution control equipment.

7 Study Alternatives

This section presents a brief summary of the alternatives evaluated during this study. Six alternatives were evaluated with various options, and a status quo option was developed as a baseline for comparison. Life cycle cost (LCC) analyses were performed on all alternatives and status quo using the Life Cycle Cost in Design (LCCID) program.

Status Quo Alternative

The status quo or baseline alternative was developed using the STATUS QUO model developed by USACERL to provide a microcomputer-based technique to establish the existing condition of a CHP. This program was funded by the DOD coal use program. The status quo situation implies the continued operation of the CHP by performing routine maintenance and repair. The STATUS QUO model provides a baseline alternative with which to compare CHP plant alternatives.

The evaluation of the CHP's status quo is determined by a field survey and the completion of an evaluation form for major plant components. Currently, the model is capable of estimating the life expectancy and cost of oil and natural gas-fired equipment for boilers in the 20 to 200 MBtu/hr range that have a maximum plant capacity of 600 MBtu/hr. Coal technology components are under development, while electric generation and thermal distribution components are planned for future development. The current model data input is simple, consisting of equipment size (dimensions, capacity, power requirements, etc.) and year of installation. The STATUS QUO program will display (for each component) equipment cost in 1991 dollars and the year the equipment should be replaced. Costs are based on average industry prices and the replacement year is based on industry experience.

The program also allows the default values to be changed if better information is available. For instance, a good method of establishing water tube boiler life is measuring the steam drum thickness and comparing it to the original thickness and pressure rating. Boiler codes limit allowable pressures that are based on drum thickness. Many other components have methods available to determine their condition and life expectancy; these include vibration analysis, motor testing, ultrasonic listening, thickness testing, oil analysis or ferrography, infrared thermal surveys, eddy current testing, equipment performance tracking, and equipment run time. The program also contains defaults for labor, maintenance, spare parts, and utility costs. Actual costs should be used to obtain an accurate economic analysis. The STATUS QUO model uses the LCCID program to perform the LCC analysis. The STATUS QUO program produces an LCCID input file containing all the plant components with their replacement year, replacement cost, plant labor, maintenance, spare parts, and utility costs.

Table 18 shows the LCC summary for the status quo alternative. Costs are net present worth (October 1992 basis).

General Improvements and Upkeep

Because of the similarity of many of the alternatives and options, initial equipment improvements and improvements required during the life of the system were combined in Tables 19 and 20, respectively. These tables do not list the new energy conversion equipment that is discussed with each alternative section.

Alternative 1 - Two New Gas/Oil Boilers

Alternative 1 involves removing existing Boilers No. 1, 2, 3, and 4 and installing two packaged gas/oil-fired 50,000 lb/hr boilers with low NO_x burners, economizers, and O_2 trim. Boilers No. 1 and 2 would be demolished first and the new boilers, which would be operated at 125 psig (saturated), would be installed in their location. Boilers No. 3 and 4 would remain operational until the new boilers are in service. The superheater on Boiler No. 5 would be removed and the burner would be replaced with a low NO_x burner. Boiler No. 5 also would be operated at 125 psig (saturated). No. 2 fuel oil would be used as a backup fuel in place of No. 6 fuel oil.

Table 21 shows the LCC summary for Alternative 1. Costs are net present worth (October 1992 basis).

To investigate the potential of absorption chilling without cogeneration, a variation of Alternative 1 was analyzed which replaced a 1200-ton centrifugal chiller in Building 13-1 with a 1200-ton single-stage absorption chiller. Table 22 shows the LCC summary for this variation. Absorption chilling appears more cost effective compared to the existing electrically-driven chilling system. However, this option optimistically assumed no increase in capital costs or operations and maintenance (O&M) costs for the absorption system. Absorption chilling will be analyzed in combination with cogeneration to determine possible economic improvements (Alternatives 3 and 6).

Alternative 2 - Two New Gas/Oil Boilers and Cogeneration

Alternative 2 considers six options as follows:

- Option 1. Install one 1.6 megawatt (MW) spark gas engine generator with a 6,000 lb/hr heat recovery steam generator.
- Option 2. Install two 1.6 MW spark gas engine generators with two 6,000 lb/hr heat recovery steam generators.
- Option 3. Install one 1.1 MW gas turbine generator with a 6,000 lb/hr heat recovery steam generator.
- Option 4. Install two 1.1 MW gas turbine generators with two 6,000 lb/hr heat recovery steam generators.
- Option 5. Install three 1.1 MW gas turbine generators with three 6,000 lb/hr heat recovery steam generators.
- Option 6. Install one 3.5 MW gas turbine generator with an 18,000 lb/hr heat recovery steam generator.

All options for Alternative 2 consider the following:

Boilers No. 1 and 2 would be demolished and two packaged gas/oil-fired 50,000 lb/hr boilers with low NO_x burners, economizers, and O_2 trim would be installed in their place. After these new boilers are in operation, Boilers No. 3 and 4 would be demolished and the new cogeneration unit(s) would be installed in the vacated area. The new boilers would be operated at 125 psig (saturated). The superheater on Boiler No. 5 would be removed and the burner would be replaced with a low NO_x burner. Boiler No. 5 also would be operated at 125 psig (saturated). The heat recovery steam generator(s) would operate at 125 psig. No. 2 fuel oil would be used as a backup fuel for the boilers instead of No. 6 fuel oil.

Tables 23 through 28 show the LCC summary for the six options under Alternative 2. Costs are net present worth (October 1992 basis).

Alternative 3 - Two New Gas/Oil Boilers, Cogeneration, and Absorption Chiller

Alternative 3 considers the following two options:

- Option 1. Install two 1.6 MW spark gas engine generators with two 6,000 lb/hr heat recovery steam generators.
- Option 2. Install one 3.5 MW gas turbine generator with an 18,000 lb/hr heat recovery steam generator.

All options for Alternative 3 consider the following:

Boilers No. 1 and 2 would be demolished and two packaged gas/oil-fired 50,000 lb/hr boilers with low NO_x burners, economizers, and O_2 trim would be installed in their place. After these new boilers are in operation, Boilers No. 3 and 4 would be demolished and the new cogeneration unit(s) would be installed in the vacated area. The new boilers would be operated at 125 psig (saturated). The superheater on Boiler No. 5 would be removed and the burner would be replaced with a low NO_x burner. Boiler No. 5 also would be operated at 125 psig (saturated). The heat recovery steam generator(s) would operate at 125 psig. In addition, a 1200-ton centrifugal chiller in Building 13-1 would be replaced by a 1200-ton single-stage absorption chiller. No. 2 fuel oil would be used as a backup fuel for the boilers instead of No. 6 fuel oil.

Tables 29 and 30 show the LCC summary for the two options under Alternative 3. Costs are net present worth (October 1992 basis).

Alternative 4 - Refurbish Existing Plant, Summer Boiler

Alternative 4 involves removing existing Boilers No. 1 and 2. The superheaters on Boilers No. 3, 4, and 5 would be removed and the burners would be replaced with low NO_x burners. Boilers No. 3, 4, and 5 would be operated at 125 psig (saturated). This alternative will also include installing a 10,000 lb/hr fire tube boiler for summer operation. No. 2 fuel oil would be used as a backup fuel instead of No. 6 fuel oil.

Table 31 shows the LCC summary for Alternative 4. Costs are net present worth (October 1992 basis).

Alternative 5 - Refurbish Existing Plant, Summer Boiler, Cogeneration

Alternative 5 involves removing existing Boilers No. 1 and 2. The superheaters on Boilers No. 3, 4, and 5 would be removed and the burners would be replaced with low NO_x burners. Boilers No. 3, 4, and 5 would be operated at 125 psig (saturated). This alternative would include two 1.6 MW spark gas engine generators with heat recovery steam generators. These generators would operate at 100 psig. In addition, a 10,000 lb/hr fire tube boiler would be installed for summer operation. No. 2 fuel oil would be used as a backup fuel instead of No. 6 fuel oil.

Table 32 shows the LCC summary for Alternative 5. Costs are net present worth (October 1992 basis).

Alternative 6 - Refurbish Existing Plant, Two New Spark Gas Engine Generators, and One New Absorption Chiller

Alternative 6 involves removing existing Boilers No. 1 and 2. The superheaters on Boilers No. 3, 4, and 5 would be removed and the burners would be replaced with low NO_x burners. Boilers No. 3, 4, and 5 would be operated at 125 psig (saturated). This alternative would include installation of two 1.6 MW spark gas engine generators with heat recovery steam generators. These generators would operate at 100 psig. Also, the 1200-ton centrifugal chiller in Building 13-1 would be replaced with a 1200-ton single-stage absorption chiller. No. 2 fuel oil would be used as a backup fuel instead of No. 6 fuel oil.

Table 33 shows the LCC summary for Alternative 6. Costs are net present worth (October 1992 basis).

Summary of Alternatives and Recommendations

The LCC for the alternatives and options are summarized in Table 34. The difference between Alternative 2, Option 2 and Alternative 5 is adding new boilers (Alternative 2) or keeping the existing boilers (Alternative 5). Based on LCC, it is better to buy new boilers.

Based on LCC, Alternative 2, Option 6 is the best selection. However, Alternative 3, Option 2 is quite close and could be improved with a smaller absorption chiller. A 1200-ton chiller had been assumed that required a boiler to be operated to meet the chiller's energy requirements. A smaller turbine sized at about 550 ton-hr would require only the excess steam from the turbine, which is essentially free energy. If Alternative 2, Option 6 is implemented and a smaller electrically driven chiller is due for replacement, it would be economical to replace it with an absorption unit.

Another improvement would be the use of a storage cooling system (SCS) to further reduce peak electrical demands. The next section describes a preliminary analysis for SCS application.

Storage Cooling System Analysis

Storage cooling systems (SCS) have become an important tool in reducing on-peak electric demand by shifting power to off-peak periods. The need to lower electric demand has arisen because utility companies usually increase electric rates for hours associated with high demand. The effective use of "demand-side management" by U.S.

electric utility companies forestalls the addition of costly new power plants while still meeting an increasing electric demand. Therefore, electric companies have tried to control electric demand by increasing the demand charge.

The Philadelphia Electric Company charges about \$12.50 per kW in the summer and about \$8.00 per kW in the winter. However, the summer peak still affects the winter demand charges because PECO sets the winter peak demand at a minimum of 80 percent of the summer peak; therefore, a reduction of the peak demand in the summer also affects the demand charges in the winter.

A way to shift electrical demand for air-conditioning from on-peak to off-peak hours is a diurnal storage cooling system. Rather than operating a chiller to meet the cooling load as it arises, the chiller is operated either partially or solely during the off-peak period, and the refrigeration produced is stored to meet the next day's on-peak cooling requirements. It can be stored in chilled water, ice, or freezing eutectic salts. A diurnal storage cooling system uses ice as a storage medium.

To assist in evaluating these systems, USACERL has developed a computer model to estimate their economic feasibility. The program, called STOFEAS (storage feasibility), calculates the simple payback and savings-to-investment ratio (SIR) based on system first cost and the expected annual savings in the demand charge. STOFEAS provides a quick, simple, and inexpensive initial assessment of the cost-effectiveness of installing and using an SCS at a particular facility. The model estimates the annual specific savings in demand charges for each kilowatt shifted from on-peak to off-peak hours, based on a number of typical electric demand rate schedules. SCS first-cost models are run for new/replacement, retrofit, and theoretical highest cost applications.

The cost of an SCS, an important factor in determining its economic performance, is expressed in terms of dollars per storage capacity (\$/ton-hour). The cost of an SCS in STOFEAS is the differential cost between a conventional cooling system and an SCS serving the same building. For the new/replacement case the differential cost is due to the storage tanks and their associated installation. In the retrofit case an SCS is added to an existing cooling system to provide cooling during a short period (2 to 4 hours) when the installation is experiencing a peak demand. The purchase of a new condensing unit and storage tanks is required for a retrofit application and for paying for system installation charges. The upper limit case demonstrates the impact of a high system first cost on the economic feasibility of an SCS.

The model provides default economic parameters such as study life, discount rate, factors for economy of scale, demand charge escalation rates, differential SCS operation and maintenance costs, and conversion constant between the electric power input and the mechanical refrigeration output.

Besides these and a number of other factors, the most important parameters in determining the economic feasibility of an SCS are the annual savings in electric demand and system first cost. The economic feasibility of an SCS is measured by the payback period and savings-to-investment ratio.

After STOFEAS has been executed, four reports are produced: (1) a summary of the data entered for the information requested, (2) the economic analysis results for the case of new/replacement, (3) the economic analysis results for the case of retrofit, and (4) the economic analysis results for the case of upper limit. Based on these outputs, the user can determine the feasibility of a prospective SCS.

A STOFEAS model was run to examine the economic feasibility of an SCS at DPSC. The economic analysis results for the three cases indicate that the new/replacement scenario is the best alternative, while the upper limit scenario shows a potential for poor economic feasibility. (More information on STOFEAS is in Appendix G.) Example economics for a 1,050 ton-hr system for each scenario follow.

Scenario	First Costs	Payback	SIR	Savings
New/replacement	\$73,000	4.4	3:5	\$185,000
Retrofit	\$137,000	11	1:9	\$121,000
Upper limit	\$158,000	16.5	0:9	-\$16,000

A more detailed study is needed to determine if SCS is economically feasible. The addition of a small SCS would not adversely affect Alternative 2-6.

Initial investment costs	0
Energy costs: Electricity Natural Gas	\$43,213 \$32,364
Total energy costs	\$75,577
Recurring maintenance and repair/custodial costs	\$12,123
Major repair/replacement costs	\$2,656
LCC of all costs/benefits (net present worth)	\$90,355

Table 18. Status quo alternative LCC summary.

Table 19. Initial central heating plant improvements.

- * Remove asbestos from area and equipment related to alternative.
- * Remove existing turbine driven boiler feed pumps and feedwater piping; add motor-driven boiler feed pumps and feedwater piping.
- * Remove the coal and ash silos and associated equipment.
- * Remove the below-ground and above-ground fuel oil tanks; add new above-ground and below-ground fuel oil tanks.
- * Remove existing make-up air heater; add make-up air heater.
- * Remove existing air receiver; add air receiver.
- * Remove existing switch gear; add switch gear.
- * Remove existing condensate receiver; add condensate receiver.
- * Remove existing expansion tank; add expansion tank.
- * Remove existing water storage tank; add water tank.
- * Remove existing flash tank; add flash tank.
- ** Remove existing stack and breeching; add new breeching and steel stacks.
- * Alternative #1 #6.
- ** Alternative #1, #2, #3.

**	Boilers No. 3 and 4; add two packaged gas/oil-fired 80,000 lb/hr boilers and related equipment. (2001)
***	Boilers No. 3 and 4; add two packaged gas/oil-fired 50,000 lb/hr boilers and related equipment. (2001)
***	* Steel stack and breeching (2001)
٠	Fuel oil unloading pump (2004)
•	Fuel oil piping below grade (2006)
*	Air compressor center (2007)
*	Emergency generator (2008)
*	Revalve (2008, 2009, 2010)
*	Water softener system (2009)
•	Heat exchanger (2010)
٠	Condensate pump (2011)
•	Simplex pumps (2012)
*	Steel tank (2012)
•	Space heaters for building heat (2016)
*	Boiler No. 5 and related equipment (2017)
**	Remove Boiler No. 5. Note Boiler No. 5 would not be replaced. (2017)
***	Remove Boiler No. 5; add one packaged gas/oil-fired 30,000 lb/hr boiler and related equipment. (2017)
*	Transformer (2018)
٠	Alternative 1 to 6

Table 20. Plant upkeep after implementation.

** Alternative 4 and 5

*** Alternative 6

**** Alternative 4to 6

Initial investment costs	\$3,787
Energy costs:	
Electricity	\$43,213
Natural gas	\$30,341
Total energy costs	\$73,554
Recurring maintenance and repair/custodial costs	\$12,123
Major repair/replacement costs	\$605
LCC of all costs/benefits (net PW)	\$90,069

Table 21. Alternative 1 LCC summary. (Two new gas/oil boilers)

Table 22. Alternative 1, Option 1 LCC summary.(Two new gas/oil boilers, absorption chiller)

Initial investment costs	\$3,787
Energy costs:	
Electricity	\$38,430
Natural gas	\$32,364
Total energy costs	\$70,793
Recurring maintenance and repair/custodial costs	\$12,123
Major repair/replacement costs	\$605
Other O&M costs & monetary benefits	0
Disposal costs/retention value	0
LCC of all costs/benefits (net PW)	\$87,308

(One 1.6 MW spark gas engine)		
Initial investment costs	\$7,129	
Energy costs:		
Electricity	\$23,798	
Natural gas	\$42,523	
Total energy costs	\$66,321	
Recurring M&R/custodial costs	\$12,764	
Major repair/replacement costs	\$605	

\$86,820

Table 23. Alternative 2, Option 1 LCC summary.(One 1.6 MW spark gas engine)

Table 24. Alternative 2, Option 2 LCC summary. (Two 1 6 MW energy and options)

(Two 1.6 MW	spark gas	engines)
-------------	-----------	----------

LCC of all costs/benefits (net PW)

Initial investment costs	\$10,470,000
Energy costs:	
Electricity	\$23,79 <u>8,000</u>
Natural gas	\$42,523,000
Total energy costs	\$66,321,000
Recurring M&R/custodial costs	\$12,764,000
Major repair/replacement costs	\$605,000
LCC of all costs/benefits (net PW)	\$90,161,000

Table 25. Alternative 2, Option 3 LCC summary. (One 1.1 MW gas turbine)

· · · · · · · · · · · · · · · · · · ·		
Initial investment costs	\$5,521,000	
Energy costs:		
Electricity	\$31,013	
Natural gas	\$37,934	
Total energy costs	\$68,948,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$605,000	
LCC of all costs/benefits (net PW)	\$87,838,000	

Initial investment costs	\$7,255,000	
Energy costs:		
Electricity	\$19,302,000	
Natural gas	\$45,388,000	
Total energy costs	\$64,689,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$605,000	
LCC of all costs/benefits (net PW)	\$85,313,000	

Table 26. Alternative 2, Option 4 LCC summary.(Two 1.1 MW gas turbines)

Table 27. Alternative 2, Option 5 LCC summary.(Three 1.1 MW gas turbines)

Initial investment costs	\$8,989,000	
Energy costs:		
Electricity	\$10,776,000	
Natural gas	\$52,543,000	
Total energy costs	\$63,319,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$605,000	
LCC of all costs/benefits (net PW)	\$85,677,000	

Table 28. Alternative 2, Option 6 LCC summary.

(One 3.5 MW gas turbine)

Initial investment costs	\$6,874,000	
Energy costs: Electricity Natural gas	\$9,746,000 \$50,630,000	
Total energy costs	\$60,376,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$605,000	
LCC of all costs/benefits (net PW)	\$80,619,000	

Table 29. Alternative 3, Option 1 LCC summary.(New boilers, absorption chiller, two gas engines)

Initial investment costs	\$11,433,000	
Energy costs:		
Electricity	\$23,390,000	
Natural gas	\$51,234,000	
Total energy costs	\$74,623,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$605,000	
LCC of all costs/benefits (net PW)	\$99,426,000	

Table 30. Alternative 3, Option 2 LCC summary.(New boilers, absorption chiller, turbine generator)

Initial investment costs	\$7,713,000	
Energy costs:		
Electricity	\$7,111,000	
Natural gas	\$55,999,000	
Total energy costs	\$63,110,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$605,000	
LCC of all costs/benefits (net PW)	\$84,192,000	

Initial investment costs	\$2,369,000	
Energy costs:		
Electricity	\$43,213,000	
Natural gas	\$30,341,000	
Total energy costs	\$73,554,000	
Recurring M&R/custodial costs	\$12,122,000	
Major repair/replacement costs	\$2,605,000	
LCC of all costs/benefits (net PW)	\$90,651,000	

Table 31.	Alternative	4 LCC	summary.
(Refurbis)	n existing pl	ant)	

Table 32. Alternative 5 LCC summary.(Refurbish existing plant, summer boiler, cogeneration)

Initial investment costs	\$9,053,000
Energy costs:	
Electricity	\$23,798,000
Natural gas	\$42,523,000
Total energy costs	\$66,321,000
Recurring M&R/custodial costs	\$12,764,000
Major repair/replacement costs	\$2,605,000
LCC of all costs/benefits (net PW)	\$90,743,000

Table 33. Alternative 6 LCC summary.

(Refurbish existing plant, two engine generators, absorption chiller)

Initial investment costs	\$9,892,000	
Energy costs: Electricity	\$23,390,000	
Natural gas	\$51,234,000	
Total energy costs	\$74,623,000	
Recurring M&R/custodial costs	\$12,764,000	
Major repair/replacement costs	\$2,605,000	
LCC of all costs/benefits (net PW)	\$99,885,000	

Alternative		Net PW (Oct 1992) of LCC
#2	Option 6 One 3.5 MW Gas Turbine	\$80,619,000
#3	Option 2 One 3.5 MW Gas Turbine Absorption Chiller	\$84,192,000
#2	Option 4 Two 1.1 MW Gas Turbines	\$85,313,000
#2	Option 5 Three 1.1 MW Gas Turbines	\$85,677,000
#2	Option 1 One 1.6 MW Gas Engine	\$86,819,880
#1	Option 1 Absorption Chiller	\$87,308,000
#2	Option 3 One 1.1 MW Gas Turbine	\$87,838,000
#1	New Boilers	\$90,069,150
#2	Option 2 Two 1.6 MW Gas Engines	\$90,161,280
	Status Quo	\$90,355,060
#4	Refurbish Plant	\$90,650,840
#5	Refurbish Plant Two 1.6 MW Gas Engines	\$90,742,870
#3	Option 1 Two 1.6 MW Gas Engines Absorption Chiller	\$99,425,980
#6	Refurbish Plant Two 1.6 MW Gas Engines Absorption Chiller	\$99,884,690

Table 34. LCC summary of alternatives/options.

8 Selected Alternative Description

This section provides more details on Alternative 2, Option 6, the selected alternative, which consists primarily of two new natural gas boilers and a 3.5 MW natural gas turbine-generator with an 18,000 lb/hr heat recovery steam generator.

Description of System

This project requires several plant auxiliary upgrades and wornout equipment demolition to implement its major components. The following list summarizes these changes.

- Remove asbestos from area and equipment related to alternative.
- Remove existing turbine-driven boiler feed pumps and feedwater piping; add motor-driven boiler feed pumps.
- Remove coal and ash silos and associated equipment.
- Remove below-ground and above-ground fuel oil tanks; add new above ground and below-ground fuel oil tanks.
- Remove existing makeup air heater; add makeup air heater.
- Remove existing air receiver; add air receiver.
- Remove existing switch gear; add switch gear.
- Remove existing condensate receiver; add condensate receiver.
- Remove existing expansion tank; add expansion tank.
- Remove existing water storage tank; add water tank.
- Remove existing flash tank; add flash tank.
- Remove existing stack and breeching; add new breeching and steel stacks.

Boilers No. 1 and 2 would be demolished to make room for two new packaged natural gas/No. 2 oil-fired boilers rated at 50,000 lb/hr steam and 125 psig (sized to more efficiently meet steam demands). The failing No. 6 fuel oil system will be replaced by No.2 oil as the backup fuel for the boilers. This will meet air pollution regulations that restrict heavy oil burning. After the new boilers are operational, Boilers No. 3 and 4 would be removed to make room for the cogeneration system.

The cogeneration system suggested is a Solar Turbines Inc. (STI) *Centaur* Type H single-shaft industrial gas turbine-generator and an STI heat recovery steam generator (HRSG). The actual turbine-generator rating is 3.88 MW but has been derated to 3.5 MW to more accurately reflect expected production capacity at local operating conditions. The HRSG will produce a maximum of 18,000 lb/hr at 125 psig when the turbine-generator is operating at 100 percent capacity.

This type of turbine-generator is the world's second most widely distributed industrial gas turbine, with over 2200 in service. An exposed view of the gas turbine-generator is shown in Figure 20. The systems are highly reliable and easy to transport and install. They are less size and weight per capacity than engine-driven systems and are virtually vibration free, allowing for lighter foundations. Figure 21 shows front and side views of the turbine-generator. The HRSG, shown in Figure 22, is a continuous tube-type economizer. Figure 23 shows a rough layout of the boiler room, which is approximately 180 feet by 80 feet. The new gas turbine-generator and HRSG will be located in the general area where Boilers No. 3 and 4 were located.

In addition to normal equipment maintenance the plant will require replacement of wornout equipment after implementation of the project. These items are shown in Table 35. The year of replacement is estimated based on typical expected component life. Actual replacement times will vary depending on equipment maintenance and operating conditions.

Description of Operation

This project will alter the amount and type of energy used by the installation. The gas turbine-generator will increase the consumption of natural gas while decreasing the amount of electricity purchased. Although energy consumption on a Btu basis will increase, energy costs will drop significantly because natural gas is \$3.4/MBtu compared to electricity at \$26/MBtu. Cogeneration decreases electric costs by reducing both energy consumption and peak demands. The HRSG will also offset boiler fuel requirements.

Figures 24 and 25 show the electric demand for a typical weekend day in the winter and the summer, respectively. These two figures show that the 3.5 MW generating capacity of the turbine-generator will provide essentially all weekend electrical needs for the entire year.

Reducing the peak demand during workdays is a significant part of reducing electric costs. Besides reducing summer costs, the summer peak reduction also reduces winter demand charges because those charges are set at 80 percent of the summer demand.

Figures 26 and 27 show typical peak demands for winter and summer workdays, respectively. During the on-peak hours of 8 a.m. to 8 p.m., 3.5 MW will be removed from the demand peak for summer workdays and about 2 MW for winter workdays.

The same conclusions can be drawn from Figures 28 and 29, which are representative load duration curves for winter and summer months, respectively. Figure 28 shows that the turbine-generator alone will be able to meet DPSC's electricity needs for about 550 hours a month or 73 percent of the time during the heating season. Figure 29 shows the turbine-generator can meet electrical needs for about 150 hours (20 percent) during the cooling season. On an annual basis, the turbine-generator will produce about 75 percent of all the electricity needed and reduce the peak electrical demand by about 50 percent.

DPSC requires about 232 million pounds of steam per year. The HRSG will produce about 109 million pounds per year or 47 percent of the required steam. Figure 30 shows the expected monthly steam output of the boilers and the HRSG. The boilers should not have to operate during the months of June through September.

The estimated annual energy use for natural gas and electricity for both the status quo and the selected alternative are summarized in Table 36. The project uses significantly more natural gas than the status quo because of the gas turbinegenerator. The effect of cogenerating is reflected in the much smaller amount of purchased electricity and the lower peak demand for the project.

Description of Costs

The LCC analysis for this project and the status quo were revised to reflect current natural gas prices and the electric rate structure. The natural gas cost dropped from \$4.95/MCF to \$3.41/MCF, which improved the economics of using natural gas for cogeneration. The new net present worth is \$64,868,000 instead of \$80,619,000. Table 37 shows the LCC summary for the selected alternative. Costs are net present worth (October 1992 basis).

Table 38 shows a detailed breakdown of the initial costs associated with this project. The initial investment costs consist mainly of the purchase and installation of the two packaged gas/oil-fired 50,000 lb/hr boilers and the 3.5 MW gas turbine-generator with 18,000 lb/hr HRSG. The major repairs/replacements over the next 25 years were listed in Table 35.

Operation and maintenance costs also will be affected by the addition of the cogeneration equipment. Maintenance labor costs will increase because another

operator/maintenance person will be needed. However, this cost may be offset by cross-training an existing operator to maintain the cogenerating equipment. The general maintenance and supply costs increased about 10 percent over the status quo.

The lower overall energy costs will generate significant savings for DPSC. Figures 31 and 32 show the monthly electric and fuel costs, respectively, for the project versus the status quo. Although fuel costs will rise due to the increase in natural gas consumption by the turbine-generator, the purchased electricity costs will decrease greatly. The total energy costs shown in Figure 33 reflect the monthly energy savings DPSC will achieve. Table 39 summarizes the estimated annual energy costs for the status quo option and the selected alternative. The almost \$700,000 increase in fuel costs for the project is offset by the \$1,800,000 decrease in electrical costs for an estimated annual energy savings of approximately \$1,153,000.

Project Funding Documents

The initial costs for Alternative 2, Option 6 total about \$7.1 million. Unless the project is implemented in phases, it will need to be funded as a Military Construction (MILCON) project. However, because of the substantial savings it may be funded through the Energy Conservation Investment Program (ECIP). The ECIP program funding has been increased substantially over the last few years and there is a shortage of good projects, particularly cogeneration projects.

Draft 1391 information for an ECIP project is contained in Appendix I and is in the form required for the 1391 Processor computer program. The ECIP economic analysis was made using the LCCID program. The economics are quite good, showing a first year savings of \$1,043,012; total net discounted savings of \$13,607,660; discounted SIR of 1:98; and simple payback of 6.59 years.

Appendix I also contains Draft Project Development Brochure checklists (DA Form 5024).



Figure 20. Solar Centaur Type H gas turbine.



Figure 21. Orthographic of gas turbine.



Figure 22. Heat recovery steam generator (HRSG).



Figure 23. CHP boiler room layout.
Equipment To Be Replaced	Year of Replacement
Fuel oil unloading pump	2004
Fuel oil piping below grade	2006
Air compressor center	2007
Emergency generator	2008
Revalve	2008, 2009, 2010
Water softener system	2009
Heat exchanger	2010
Condensate pump	2011
Simplex pumps	2012
Steel tank	2012
Space heaters for building heat	2016
Boiler No. 5 and related equipment	2017
Transformer	2018

Table 35. Plant upkeep after initial construction.



Figure 24. Winter weekend demand.



Figure 25. Summer weekend demand.



Figure 26. Winter weekday demand.



Figure 27. Summer weekday demand.



Figure 28. Winter load duration curve.



Figure 29. Summer load duration curve.



Figure 30. Monthly steam supply.

Natural Gas	Status Quo	Alt 2-6		
Boiler, MSCF	290.7	153.9		
Turbine, MSCF		331.1		
Total, MSCF	290.7	484.0		
Electric				
Peak Demand, kW	7.3	3.1		
Purchase, GWh *	31.7	7.2		
Generated, GWh *		26.5		

Table 36. Estimated annual energy use.

* GWh = million kWh

Initial investment costs	\$6,874,000
Energy costs: Electricity Natural gas	\$9,746,000 \$34,879,000
Total energy costs	\$44,625,000
Recurring M&R/custodial costs	\$12,764,000
Major repair/replacement costs	\$605,000
LCC of all costs/benefits (net PW)	\$64,868,000

Table 37. Alternative 2, Option 6 LCC summary.(One 3.5 MW gas turbine)

 Table 38. Estimated annual energy costs.

	Status Quo	Alt 2-6
Natural Gas		
Boiler	\$991,000	\$525,000
Turbine		\$1,129,000
Total fuel	\$991,000	\$1,654,000
Electric		
Demand charge	\$771,000	\$397,000
Use charge	\$2,024,000	\$582,000
Total electric	\$2,795,000	\$979,000
Total energy cost	\$3,786,000	\$2,633,000



Figure 31. Status quo vs. Alternative 2, Option 6 electrical costs.



Figure 32. Status quo vs. Alternative 2, Option 6 fuel costs.



Figure 33. Status quo vs. Alternative 2, Option 6 total energy costs.

	QUANTI	77	LABOR & N	AATERIAL
ITEM DESCRIPTION	NO. UNITS	UNIT MEAS.	\$ PER UNIT	TOTAL
לפרזוסה לא) ALTERNATIVE # 2 - ONE 3500 KW GAS TURBINE				
DEMOLITION BOILERS NO. 1,2,3,&4 TURBINE DRIVEN BOILER FEED PUMP COAL AND ASH SILOS,CONVEYORS AND EQUIPMENT PIPING ELECTRICAL INSTRUMENT AND CONTROL ASBESTOS ABATEMENT NEW CONSTRUCTION	4 4 	EA EA LS LS LS LS	\$30,000.00 \$5,000.00 	\$120,000 \$20,000 \$100,000 \$5,000 \$50,000 \$500,000
REMOVE AND MODIFY BOILER 5 SUPERHEATER BOILER, 50,000 #/ HR ECONOMIZERS BOILER FEED PUMPS, 15 HP, 81 GPM,404FT. STEEL STACK, 24* DIA. 60' HIGH PIPING, VALVES, HANGERS, AND INSTALLATION INSTRUMENTS AND CONTROLS CONDUIT AND CABLE MOTOR CONTROL CENTER MISC. ELECTRICAL AND LIGHTING GAS TURBINE, GENERATOR AND INSTALLATION WATER INJECTION HEAT RECOVERY STEAM GENERATOR AND INSTALLATION AIR HEATER AIR RECEIVER SWITCH GEAR CONDENSATE RECEIVER EXPANSION TANK WATER STORAGE TANK ABOVE GROUND TANK FLASH TANK SUBTOTAL UNDEVELOPED DESIGN DETAILS OVERHEAD PROFIT TOTAL PROBABLE COST USE		LS EA EA EA LS LS LS LS EA EA EA EA EA EA EA EA	\$490,000.00 \$25,000.00 \$12,000.00 \$10,000.00 \$10,000.00 \$10,000.00 \$3463.00 \$382.00 \$75,969.00 \$35,700.00 \$19,444.00 \$17,595.00 \$156,442.00 \$156,442.00 \$108,375.00	\$50,000 \$880,000 \$36,000 \$20,000 \$40,000 \$150,000 \$150,000 \$150,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$122,725 \$300,000 \$1,800,000 \$122,725 \$382 \$75,969 \$35,700 \$19,444 \$176,969 \$4,949,801 \$742,470 \$44,949,801 \$742,470 \$569,227 \$7,115,339 \$7,115,000

Figure 34. Initial project capital investments.

9 Conclusions

This study evaluated six primary alternatives: (1) new boilers, (2) new boilers with absorption chilling, (3) new boilers with cogeneration, (4) refurbish plant, (5) refurbish plant with absorption chiller, and (6) refurbish plant with cogeneration. Various options within these alternatives were also analyzed. A baseline or status quo option was developed, using the Status Quo model, for comparison of the alternatives to the existing situation. Life cycle cost (LCC) analyses were performed using the Life Cycle Cost in Design (LCCID) program.

Air quality regulations are the most significant environmental regulations that affected the analysis of alternatives for this study. The Philadelphia area has been designated as nonattainment for ozone (O_3) , carbon monoxide (CO), and total suspended particulate (TSP). Virtually all of the Philadelphia Consolidated Metropolitan Statistical Area (CMSA), which includes Pennsylvania, New Jersey, and Delaware, is designated a *severe* nonattainment area for O_3 . Air quality regulations essentially limit the combustion fuel for DPSC to natural gas. However, because of the severe nonattainment designation for ozone, DPSC also will be limited to an increase in nitrogen oxide emissions of 25 TPY to avoid RACT regulations that would require costly pollution control equipment.

Based on LCC, Alternative 2, Option 6 (new natural gas boilers and a natural gas turbine-generator with a heat recovery steam generator) is the best selection. The net present worth of this alternative is \$64,868,000. On an annual basis the turbine-generator will produce about 75 percent of all the electricity needed and reduce the peak electrical demand by about 50 percent. The HRSG will produce about 109 million pounds per year or 47 percent of the required steam. The almost \$700,000 increase in fuel costs for Alternative 2-6 is offset by the \$1,800,000 decrease in electrical costs for an estimated annual energy savings of approximately \$1,153,000.

The initial costs for Alternative 2-6 total about \$7.1 million. Unless the project is implemented in phases, it will need to be funded as a MILCON project. However, because of the substantial savings, it may be funded through ECIP. The ECIP program funding has been increased substantially over the last few years and there is a shortage of good projects, particularly cogeneration projects. The ECIP economic analysis for Alternative 2-6 is quite good, showing a first year savings of \$1,043,012;

total net discounted savings of \$13,607,660; discounted SIR of 1:98; and simple payback of 6.59 years.

Alternative 3, Option 2 was quite close to the best alternative and could be improved with a smaller absorption chiller. A 1200-ton chiller had been assumed that required a boiler to be operated to meet the chiller's energy requirements. A smaller turbine sized at about 550 ton-hr would require only the excess steam from the turbine, which is essentially free energy. If Alternative 2, Option 6 is implemented and a smaller electrically driven chiller is due for replacement, it would be economical to replace it with an absorption unit.

Another improvement may be a storage cooling system (SCS) to further reduce peak electrical demands. A preliminary feasibility analysis was made using the storage feasibility model (STOFEAS). The model shows potential for an SCS; however, a more detailed study is needed to determine if an SCS is economically feasible. The addition of a small SCS would not adversely affect Alternative 2-6.

Appendix A: Description of Buildings and Their Uses

BUILDING #	DESCRIPTION OF SPACE	TYPE OF SPACE	CAC
M-1-A M-1	Corps of Engineer's Off. Area (FE) Warehouse	Administrative Storage	93166.3000 93164
M-2-C M-2-D	FE Maintenance Shops Warehouse	Maint & Prod Storage	93162 93164
M-3-A M-3-I M-3	Post Exchange Union Office, AFGE Warehouse	Community Facility Administrative Storage	93168 93166 93164
M-4-AA M-4 M-4	Box Shop Driver Training Classroom Warehouse	Maint & Prod Training Storage	93162 93161 93164
M-5-B M-5	Weatherometer Room Warehouse	R, D, T & E Storage	93163 93164
		[2760
6-1-A	Ballistics Range	К, D, 1 & E	20100 20100
6-1-A	Mail & Distribution	Administrative	90160
6-1-A	Records Holding Area	Administrative	00TCC
6-1-A	Contract Distribution	AUNINISUIAULVE	09160
6-1-A&B	Warehouse	storage	
6-1-C	OMD Warehouse	Storage	92166
6-1-C	OMD Office Area	Administrative	03161 13160
6-1-C	Quality Assurance Training Lab	Training	10100 10100
6-1-D	DOD Asst. Insp. General for Invest.	Administrative	93166
6-1-D	Department of Agriculture	Administrative	93166
6-1-D	US General Accounting ULLICE		93163
6-1-D	Medical Lab	, אר אר אר אין אין אר אר אין אין אר אין	93163
6-1-D	Environmental Kooms	N, U, I & I Administrative	93166
6-1-E	Ofc of Satety & Health	O A TARACTURINING	
[: , ,	(UILLE COMMAIL) DOD Demuty Asst Insn Gen'] for	Administrative	93166
	run depury acore andre a and Thenartions		
ц - 1 - Э	nispectrons Dispensary	Hospital & Medical	93165
0 - T - E	Machine Shop	в, р, т є Е	93163
6-1-E	Medical Laboratory	R, D, T & E	93163

BUILDING #	DESCRIPTION OF SPACE	TYPE OF SPACE	CAC
6-2-A 6-2-A&B 6-2-A&B 6-2-B&C 6-2-B,C&D 6-2-E,C&D	Internal Review Ofc (Under Command) Office of Comptroller Office of Plans & Policy US Army Support Activity DCASRA DCASRA	Administrative Administrative Administrative Administrative Administrative	93166 93166 93166 93166 93166 93166
α α α α α α α α α 	Boiler Plant Facilities Engr Shops Facilities Engr Div Office Defense Career Intern Trng Center Training Tower Guesthouse Medals Assembly	Other Buildings Maint & Prod Administrative Training Training Community Facility Maint & Prod	93169 93166 93166 93161 93161 93166
8-2	Warehouse (DCASR Storage Area)	Storage	93164
(,, ,, ,,			
9-1-A&B	Directorate/Mfg Sponging Plant	Maint & Prod	93162.3000
y-1-C&D	Warehouse Area	Storage	93164
日 1 1 1 1 1 1 1	Dir/Med Mat'l (Small Ofc Area)	Administrative	93166
9-1-E/F	Office of Telecom & Info Systems	Administrative	93166
9-2-A&B	Directorate of Manufacturing	Maint & Prod	93162
9-2-B, C&D	DSACW	Administrative	93166
9-2-E&F	Directorate of Subsistence	Administrative	93166
9-3-A&B	Directorate of Manufacturing	Maint & Prod	93162
9-3-C&D	Warehouse Area	Storage	93164
9-3-E	Directorate of Subsistence	Administrative	93166
9-3&4-F	Directorate of Medical Materiel	Administrative	93166
9-4-A&B	Directorate of Manufacturing	Maint & Prod	93162
9-4-C&D	Warehouse Area	Storage	93164
9-4-E	Ofc of Transportation &	Administrative	93166
	Traffic Mgmt		·
9-4-E	Directorate of Med Mat'l	Administrative	93166
11 150 AG	CLF VELEIAIIS COOLUIIIALOF	Administrative	93166 02265
787-77	security	Administrative	93166

83

DESCRIPTION OF SPACE	
BUILDING #	

BUILDING #	DESCRIPTION OF SPACE	TYPE OF SPACE	CAC
12-LL-B	Print Shop	Maint & Prod	93162
	Audiovisual	Maint & Prod	93162
12-LL-D	Library	Administrative	93166
12-LL	Administrative Services Division	Administrative	93166
12-1-A, B&C	Office of Civilian Personnel	Administrative	93166
12-1-D	Admin Management	Administrative	93166
12-1-D	Directorate of Instl Svcs	Administrative	93166
12-1-D	Forms Management	Administrative	93166
12-1-D	Travel Authorization	Administrative	93166
12-1-D	Records Management	Administrative	93166
12-1-D	Freedom of Info Act	Administrative	93166
12-1-D	Base Procurement	Administrative	93166
12 Room 113	Installation Contracts	Administrative	93166
12-1-E	Small Business Office	Administrative	93166
12-1-E	Equal Employment Opportunity Ofc	Administrative	93166
12 Room 109	Public Affairs Office	Administrative	93166
12-1-F	Office of Contracting	Administrative	93166
12-1-6	Office of Counsel	Administrative	93166
12-1-H	Office of Command	Administrative	93166
12-2-А - Н	Directorate of Clothing & Textiles	Administrative	93166
12-2 Rm 216	US Army Natick R & D Center	Administrative	93166
12-2 Rm 201	US Navy C&T Research Facility	Administrative	93166
12-2-Н	US Coast Guard Liaison Ofc	Administrative	93166
12-3-A - H	Directorate of Clothing & Textiles	Administrative	93166
12-3-D	Air Force C&T Office	Administrative	93166
12-3 Rms 315 & 318	Air Force C&T Office	Administrative	93166
12-3-F	US Marine Corps	Administrative	93166
12-Roof-E&W	Penthouses	Community Facility	93168
12	Warehouse Area	Storage	93164
13	Directorate of Manufacturing	Maint & Production	93162.
14	Restaurant	Community Facility	01050
	Credit Union	Community Facility	93168
	Office Areas	Administrative	93166

USACERL TR FE-94/25

62.3000

BUILDING #	DESCRIPTION OF SPACE	TYPE OF SPACE	CAC
14	Officer's Open Mess Auditorium Bowling Alley Barber Shop General Storehouse	Community Facility Community Facility Community Facility Community Facility Storage	93410 93168 93410 93410 93410 93410
15	Clothing & Textile Lab	К, D, Т & Е	93163
16	Nonmetallic Material Facility	R, D, T & E	93163
17	Scale House	Other Buildings	93169
18	Pump Station	Other Buildings	93169
20-A 20-B - G	Recreation Center US Treasury Dept. (US Mint Whse)	Community Facility Storage	93410 93164
22	FE Maintenance Shop	Maint & Prod	93162
26 26 26-A 26-C 28-C	Warehouse Area Office Area Fort George G. Meade Electronics Shop (Weapons Maint) Defense Reutilization & Market. Ofc Gas Station	Storage Administrative Maint & Prod Maint & Prod Storage Other Buildings	93164 93164 93166 93162 93162 93164
29	Flag Pole	Other Structures	93172
30 31,32,37,38, 39,40,& 41	Fort George G. Meade Sentry Stations	Maint & Prod Other Buildings	93162 93169
34	Flag Pole	Other Structures	93172
35,36,&42	Waiting Shelters	Community Facility	93172
44	Flammable Storage Facility	Storage	93164

BUILDING #	DESCRIPTION OF SPACE	TYPE OF SPACE	CAC
46	Hazardous Material Storage	Storage	93164
49	Switch House	Other Buildings	93169
50	Gas Metering Station		93169
51	FE Maintenance Shop Asst. Insp. Gen'l for Invest. Motor Equipment Pool	Maint & Prod Administrative Maint & Prod	93162 93166 93162
130&134	Underground Fuel-Oil Storage		93172
135&136	Aboveground Fuel-Oil Storage		93172
137,138&139	Footbridges		93169

Appendix B: SHDP Model and Results

.

SYSTEM VARIABLES AND EXECUTION CONTROLS

FLO	1.	FOL	ERAN	CE =	10	.00	1bm/h	ir			
UNKI	101	٧N	PARAN	IETER	TOL	ERAN	CE =	. 0	00500		
UNKI	101	٧N	PRESS	SURE	TOLE	RANC	E =	.00	0050		
UNKI	VOV	٧N	NODE	FLOW	TOL	ERAN	CE =		1.000	lbr	n/hr
PC	=	20	1	5	20	1	5	5	0	0	0
UNS	=	1	2	2	2	4	3	1	1	2	2

PIPE DESCRIPTION SECTION

NCE	FROM	TO	STATUS	DIAMETER	LENC	STH	RELATIVE	HEAT LOSS COEF	TEMP
NUM	NODE	NODE		(in)	(f)	;)	ROUGHNESS	(Btu/hr-ft-F)	(F)
1	CHP	8PRS		15.0	50.+	Ο.	.167E-3	.53	65.0
2	8PRS	8A		5.0	200.+	0.	.500E-3	.27	65.0
3	8A	8		5.0	20.+	0.	.500E-3	.27	65.0
4	8A	2C		4.0	131.+	0.	.625E-3	.27	65.0
5	2C	2		3.0	331.+	Ο.	.833E-3	.23	65.0
6	8PRS	6C		12.0	238.+	0.	.208E-3	.46	65.0
7	6C	6		12.0	20.+	Ο.	.208E-3	.46	65.0
8	6C	6D1		8.0	369.+	0.	.312E-3	.42	65.0
9	6D1	3 prs		3.0	56.+	Ο.	.833E-3	.23	65.0
10	3 prs	3		3.0	194.+	0.	.833E-3	.23	65.0
11	6D1	6D2		8.0	88.+	0.	.312E-3	.42	65.0
12	6D2	15		2.5	300.+	Ο.	.100E-2	.21	65.0
13	6D2	6E		6.0	181.+	0.	.417E-3	.30	65.0
14	6E	5C		6.0	181.+	0.	.417E-3	.30	65.0
15	5C	5E		8.0	275.+	0.	.312E-3	. 4 2	65.0
16	5E	5		6.0	394.+	0.	.417E-3	.30	65.0
17	6C	6B		14.0	112.±	Ο.	.179E-3	.48	65.0
18	6B	ROG		8.0	256.+	0.	.312E-3	.42	65.0
19	ROG	12D		5.0	219.+	Ο.	.500E-3	.27	65.0
20	12D	12B		2.0	237.+	0.	.125E-2	.22	65.0
21	12B	12		2.0	20.+	Ο.	.125E-2	.22	65.0
22	12B	12A		2.0	237.+	0.	.125E-2	.22	65.0
23	12A	11		2.0	144.+	Ο.	.125E-2	.22	65.0
24	ROG	HART		8.0	150.+	Ο.	.312E-3	.42	65.0
25	HART	13A		6.0	56.+	0.	.417E-3	.30	65.0
26	HART	14		6.0	375.+	0.	.417E-3	.30	65.0
27	6B	6AB		12.0	150.+	Ο.	.208E-3	.46	65.0
28	6AB	6A		10.0	250.+	0.	.250E-3	. 49	65.0
29	6A	9D		8.0	200.+	Ο.	.312E-3	.42	65.0
30	9D	9C		6.0	294.+	Ο.	.417E-3	.30	65.0
31	9C	9W		6.0	20.+	0.	.417E-3	.30	65.0
32	9C	13C		6.0	350.+	0.	.417E-3	.30	65.0
33	9D	9E		6.0	250.+	Ο.	.417E-3	.30	65.0
34	9E	90		6.0	20.+	Ο.	.417E-3	.30	65.0
35	9E	30A		4.0	356.+	Ο.	.625E-3	.27	65.0
36	30A	30		1.5	275.+	0.	.167E-2	.16	65.0
37	бав	1A		8.0	188.+	0.	.312E-3	. 42	65.0
38	1A	RR		10.0	62.+	0.	.250E-3	.49	65.0
39	RR	4 PRS		6.0	69.+	Ο.	.417E-3	.30	65.0
40	4 PRS	4C		10.0	381.+	0.	.250E-3	.49	65.0
41	4C	4D		9.0	162.+	0.	.278E-3	.42	65.0

PIPE DESCRIPTION SECTION

•	
•	.
-	•

(1)

NCE	FROM	то	STATUS	DIAMETER	LENG	ТН	RELATIVE	HEAT LOSS COEF	TEMP
NUM	NODE	NODE		(in)	(ft)	ROUGHNESS	(Btu/hr-ft-F)	(F)
42	4D	4E		8.0	175.+	Ο.	.312E-3	. 42	65.0
43	4E	4F		7.0	150.+	0.	.357E-3	.30	65.0
44	4F	4G		6.0	162.+	Ο.	.417E-3	.30	65.0
45	4G	4H		6.0	188.+	0.	.417E-3	.30	65.0
46	4H	4		4.0	125.+	Ο.	.625E-3	.27	65.0
47	4G	BASH		4.0	294.+	Ο.	.625E-3	.27	65.0
48	BASH	22		3.0	150.+	0.	.833E-3	.23	65.0
49	BASH	51		4.0	219.+	Ο.	.625E-3	.27	65.0
50	1A	1C		10.0	550.+	Ο.	.250E-3	.49	65.0
51	10	1D		9.0	150.+	0.	.278E-3	.42	65.0
52	1D	1E		8.0	150.+	Ο.	.312E-3	.42	65.0
53	1E	1F		7.0	175.+	Ο.	.357E-3	.30	65.0
54	1F	1F1		6.0	63.+	Ο.	.417E-3	.30	65.0
55	1F1	1L1		1.5	150.+	Ο.	.167E-2	.16	65.0
56	1F	1F2		6.0	75.+	Ο.	.417E-3	.30	65.0
57	1F2	1L2		4.0	450.+	Ο.	.625E-3	.27	65.0
58	1F2	1F3		3.0	25.+	Ο.	.833E-3	.23	65.0
59	1F3	1L3		2.5	125.+	Ο.	.100E-2	.21	65.0
60	RR	2F		10.0	975.+	Ο.	.250E-3	.49	65.0
61	2F	ALE		10.0	420.+	0.	.250E-3	.49	65.0
62	ALE	ALE1		6.0	175.+	Ο.	.417E-3	.30	65.0
63	ALE1	20D		5.0	275.+	Ο.	.500E-3	.27	65.0
64	20D	20W		5.0	288.+	0.	.500E-3	.27	65.0
65	20D	20M		5.0	375.+	Ο.	.500E-3	.27	65.0
66	ALE1	26C		4.0	312.+	Ο.	.625E-3	.27	65.0
67	26C	26		4.0	387.+	0.	.625E-3	.27	65.0

REGULATOR AND VALVE DESCRIPTION SECTION

NCE	FROM	TO	STATUS	SIZING	CONFIGURATION	MINIMUM	1
NUM	NODE	NODE		COEFFICIENT	CONSTANT	PRESSURE D	ROP

NO REGULATORS OR VALVES IN SYSTEM

TRAP INPUT DATA

NO FAULTY TRAPS

VAULT INPUT DATA

VAULT	NODE	MAIN PIPE	MAIN PIPE	HEAT TRANSFER	ENVIROMENT
NUMBER	NAME	DIAMETER	LENGTH	COEFFICIENT	TEMPERATURE
		(in)	(ft)	(Btu/hr-ft-F)	(F)

NODE INPUT DATA

NODE	PRESSURE	NODE FLOW	NODE FLOW	PIPE CONDS	LOAD CONDS
NAME	(psig)	(1bm/hr)	RETURNED	RETURNED	TEMPERATURE
СНР	180.00	20000.2	.90	.90	150.0
8PRS	180.00?	0.	.90	.90	150.0
8A	5.00?	0.	.90	.90	150.0
8	5.00?	-232.	.90	.90	150.0
20	5.00?	0.	.90	.90	150.0
2	5.007	-82.	.90	.90	150.0
6C	180.00?	0.	.90	.90	150.0
6	180.00?	-903.	.90	.90	150.0
6D1	180.00?	0.	.90	.90	150.0
3 PRS	5.00?	0.	.90	.90	150.0
3	5.00?	-72.	.90	.90	150.0
6D2	180.00?	0.	.90	.90	150.0
15	180.00?	-99.	.90	.90	150.0
6E	180.00?	0.	.90	.90	150.0
5C	180.00?	0.	.90	.90	150.0
5E	6.50?	0.	.90	.90	150.0
5	6.50?	0.	.90	.90	150.0
6B	180.00?	0.	.90	.90	150.0
ROG	180.00?	0.	.90	.90	150.0
12D	180.00?	0.	.90	.90	150.0
12B	45.00?	0.	.90	.90	150.0
12	45.00?	-517.	.90	.90	150.0
12A	45.00?	0.	.90	.90	150.0
11	45.00?	-24.	.90	.90	150.0
HART	180.00?	0.	.90	.90	150.0
13A	180.00?	-589.	.90	.90	150.0
14	180.00?	-532.	.90	.90	150.0
6AB	180.00?	Ο.	.90	.90	150.0
6A	180.00?	0.	.90	.90	150.0
9D	180.00?	0.	.90	.90	150.0
9C	180.00?	0.	.90	.90	150.0
9W	180.00?	-718.	.90	.90	150.0
13C	180.00?	-589.	.90	.90	150.0
9E	180.00?	0.	.90	.90	150.0
90	180 002	-690	.90	. 90	150.0
302	180 002	0	90	90	150 0
30	180 002	-227	90	90	150 0
1 2	180 002	<i>227</i> .	90	90	150.0
BB TU	180.002	0.	90	90	150.0
ADBG	180 002	0. 0	90	90	150.0
40	10 002	0.	90	90	150.0
40	10.001	0	.90	90	150.0
40	10.001	0.	90	90	150.0
16	10.007	0.	90	90	150.0
40	10.002	0.	. 50	. 50	150.0
40	10.007	ο. Λ	.90	.90	150.0
4 N A	10.007	-265	90	. 50	150.0
- BYCR	5 002	<u>د</u> ري. ۱	90	90	150 0
DHON 11	5.001	_10			150.0
51	5.007	-10.		. 50	150.0
· 1	5,00?	-13.	.90	.90	120.0

1C	10.00?	0.	.90	.90	150.0
1D	10.00?	0.	.90	.90	150.0
1E	10.00?	0.	.90	.90	150.0
1F	10.00?	0.	.90	.90	150.0
			(3)		

NOE	DE INPUT DATA				
NODE NAME 1F1 1L1 1F2	PRESSURE (psig) 10.00? 10.00? 10.00?	NODE FLOW (1bm/hr) 0. -94. 0.	NODE FLOW RETURNED .90 .90 .90 90	PIPE CONDS RETURNED .90 .90 .90	LOAD CONDS TEMPERATURE 150.0 150.0 150.0 150.0
1E2 1F3 1E3 2F	10.00? 10.00? 10.00? 10.00?	-94. 0. -94. 0.	.90 .90 .90	.90 .90 .90	150.0 150.0 150.0
ALE ALE1 20D 20W 20M 26C	10.00? 5.00? 5.00? 5.00? 5.00? 5.00?	0. 0. -120. -102. 0.	.90 .90 .90 .90 .90 .90	.90 .90 .90 .90 .90 .90	150.0 150.0 150.0 150.0 150.0 150.0
26	5.00?	-96.	.90	.90	150.0

NODE CORRESPONDENCE TABLE AND LIST OF ADJACENT NODES

NODE	ADJACE	NT NOD	ES (BY	NAME)
CHD	8 PRS			
8PRS	84	60	CHP	
88	8	20	8PRS	
8	а. А.			
20	2	8A		
2	2C			
- 6C	6	6D1	6B	8PRS
6	6C			
6D1	3 prs	6D2	6C	
3 PRS	3	6D1		
3	3 prs			
6D2	15	6E	6D1	
15	6D2			
6E	5C	6D2		
5C	5E	6E		
5E	5΄	5C		
5	5E			
6B	ROG	6AB	6C	
ROG	12D	HART	6B	
	NODE NAME CHP 8PRS 8A 8 2C 2 6C 6 6D1 3PRS 3 6D2 15 6E 5C 5E 5 6B ROG	NODE ADJACE NAME End CHP 8PRS 8PRS 8A 8A 8 8A 8 8C 2 2C 2 2C 2 6C 6 6D1 3PRS 3PRS 3 6D2 15 15 6D2 6E 5C 5E 5 5 5E 6B ROG ROG 12D	NODE ADJACENT NOD NAME CHP 8 PRS 8 PRS 8 A 6C 8 A 8 A 2C 8 BA 2C 2 8 A 2C 2 8 A 2C 6C 6 6D1 6 6D1 3 PRS 6D2 3 PRS 6D2 15 6E 15 6D2 15 6E 5C 5E 5 5C 5 5B ROG 6AB ROG 12D	NODE ADJACENT NODES (BY NAME - CHP 8PRS 8PRS 8A 6C CHP 8A 8 2C 8PRS 8 8A 6C CHP 8A 8 2C 8PRS 2C 2 8A 2 2C 2 8A 2 6C 6 6D1 6B 6 6C 6 6D1 6B 6 6C 6 6D1 6B 6D1 3PRS 6D2 6C 6D1 13 3 3PRS 6D2 6E 5C 6D1 15 6D2 5C 5E 5C 5C 5E 5C 5C 5E 5 5C 5

91

20	12D	12B	ROG	
21	12B	12	12A	12D
22	12	12B		
23	12A	11	12B	
24	11	12A		
25	HART	13A	14	ROG
26	13A	HART		
27	14	HART		
28	бав	6A	1A	6B
29	6A	9D	6AB	
30	9D	9C	9E	6A
31	9C	9W	13C	9D
32	9W	9C		

NODE CORRESPONDENCE TABLE AND LIST OF ADJACENT NODES

NODE	NODE	ADJACH	ENT NOI	DES (BY	NAME)
NUMBER	NAME				
33	13C	9C			
34	9E	90	30A	9D	
35	90	9E			
36	30A	30	9E		
37	30	30A			
38	1A	RR	1C	6AB	
39	RR	4 PRS	2F	1A	
40	4 PRS	4C	RR		
41	4C	4D	4 PRS		
42	4D	4 E	4C		
43	4E	4F	4 D		
44	4F	4G	4 E		
45	4G	4 H	BASH	4F	
46	4H	4	4G		
47	4	4 H			
48	BASH	22	51	4G	
49	22	BASH			
50	51	BASH			
51	1C	1D	1A		
52	1D	1E	1C		
53	1E	1F	1D		
54	1F	1F1	1F2	1E	
55	1F1	1L1	1F		
56	1L1	1F1			
57	1F2	1L2	1F3	1F	
58	1L2	1F2			
59	1F3	1L3	1F2		
60	1L3	1F3			
61	2F	ALE	RR		
62	ALE	ALE1	2F		
63	ALE1	20D	26C	ALE	
64	20D	20W	20M	ALE1	
65	20W	20D			
66	20M	20D			
67	26C	26	ALE1		
68	26	26C			

***** PROBLEM SUMMARY *****
68 NODES IN THE SYSTEM
67 PIPES IN THE SYSTEM
0 VALVES OR REGULATORS
0 FAULTY TRAPS
0 VAULTS IN THE SYSTEM
0 UNKNOWN PARAMETERS
67 UNKNOWN PRESSURES
1 UNKNOWN FLOWS

07/15/92 15:43:18 HC

SOLUTION COMPLETED IN 14 ITERATIONS SOME NODES MAY NOT BE BALANCED

*** PROBLEM SUMMARY ***
68 NODES IN THE SYSTEM
67 PIPES IN THE SYSTEM
0 VALVES OR REGULATORS
0 FAULTY TRAPS
0 VAULTS IN THE SYSTEM
0 UNKNOWN PARAMETERS
67 UNKNOWN PRESSURES
1 UNKNOWN FLOWS

COMPUTED NODE DATA

លក្រចា	PRESSURE	NODE FLOW	CONDS FLOW	FLOW LOSS	CONDS LOSS	TEMP	RESIDUAL
NAME	(nsig)	(1bm/hr)	(lbm/hr)	(Btu/hr)	(Btu/hr)	(F)	(lbm/hr)
CHP		7979.9?	-4.9	. 0	174.2	379.6	-35.68
8PRS	180.00?	.0	-35.4	.0	1249.0	379.6	66.47
8A	180.00?	.0	-17.6	.0	623.1	379.6	-17.16
8	180.00?	-231.9	-1.0	2714.4	35.5	379.6	-6.97
20	180.00?	.0	-20.8	.0	733.1	379.6	33
2	179.99?	-82.3	-14.2	963.3	500.5	379.6	.01
- 6C	179.99?	.0	-61.0	• .0	2152.6	379.6	-62.32
6	179.99?	-903.2	-1.7	10571.8	60.5	379.6	22.20
6D1	179.99?	.0	-38.1	.0	1346.6	379.6	275.19
3PRS	179.99?	.0	-10.7	.0	378.0	379.6	-260.88
3	179.99?	-72.0	-8.3	842.7	293.4	379.6	~.05
6D2	179.99?	.0	-28.7	.0	1014.2	379.6	-13.14
15	179.98?	-98.7	-11.7	1155.3	414.2	379.6	.03
6E	179.99?	.0	-20.2	.0	714.0	379.6	7.02
5C	179.99?	.0	-31.6	.0	1116.4	379.6	1172.59
5E	179.99?	.0	-43.5	.0	1536.5	379.6	-1181.35
5	179.99?	.0	-22.0	.0	777.1	379.6	5.16
6B	179.99?	.0	-42.9	.0	1514.0	379.6	49.02
ROG	179.99?	.0	-42.8	.0	1509.8	379.6	-2.87
12D	179.98?	.0	-20.7	.0	731.0	379.6	.81
12B	179.51?	.0	-20.2	.0	713.1	379.4	08
12	179.48?	-516.5	8	6045.6	28.9	379.3	.02
12A	179.51?	.0	-15.6	.0	550.3	379.4	.02
1	179.51?	-24.2	-5.9	283.3	208.0	379.4	.03
HART	179.99?	.0	-35.8	.0	1264.3	379.6	39
13A	179.99?	-589.3	-3.1	6897.7	110.5	379.6	24
14	179.98?	-531.8	-20.9	6224.6	739.6	379.6	.59
6AB	179.99?	.0	-50.4	.0	1778.1	379.6	-23.40
6A	179.99?	.0	-38.5	.0	1357.6	379.6	4.86
9D	179.98?	.0	-46.0	.0	1625.2	379.6	-4.05
9C	179.97?	.0	-37.1	.0	1309.6	379.6	12.50
9W	179.97?	-717.7	-1.1	8400.6	39.4	379.6	-10.45
13C	179.97?	-589.3	-19.6	6897.7	690.3	379.6	-1.03
9E	179.98?	.0	-33.0	.0	1164.4	379.6	6.39
90	179.98?	-689.7	-1.1	8072.8	39.4	379.6	-5.19
30A	179.97?	.0	-26.1	.0	920.9	379.6	.07
30	179.56?	-227.3	-8.2	2660.5	288.8	379.4	.00
1A	179.99?	.0	-70.5	.0	2490.7	379.6	756.27
RR	179.99?	.0	-98.5	.0	3476.8	379.6	-63.71
4PRS	179.99?	.0	-38.6	.0	1363.5	379.6	1049.99
4C	179.98?	.0	-47.4	.0	1674.7	379.6	-1038.79
4D	179.98?	.0	-26.4	.0	930.6	379.6	-4.13
4E	179.98?	.0	-22.1	.0	779.1	379.6	-2.64
4F	179.98?	.0	-17.4	.0	615.4	379.6	-4.42
4G	179.98?	.0	-34.3	.0	1212.2	379.6	188.43
4H	179.98?	.0	-16.8	.0	592.7	379.6	2.38
4	179.98?	-264.7	-6.3	3098.3	221.9	379.6	30
BASH	179.98?	.0	-32.2	.0	1137.5	379.6	-187.43
<u>^</u> 2	179.98?	-10.1	-6,4	118.2	226.8	379.6	78

ROM NODE	TO NODE	STATUS	FLOW (lbm/hr)	CONDENSATE (lbm/hr)	HEAT LOSS (Btu/hr)	DIAMETER (in)	RE NUMBER	FRIC
CHP	8PRS		8010.6	9.87	8336.1	15.00	1.65E+5	1.71E-
2 8PRS	8A		343.3	20.11	16986.7	5.00	2.13E+4	2.24E-
2 8A	8		225.9	2.01	1698.7	5.00	1.40E+4	2.93E-
2 8A	2C		116.9	13.17	11126.3	4.00	9.05E+3	3.29E-
2 2C	2		96.5	28.35	23948.0	3.00	9.96E+3	3.24E-
2 8PRS	6C		7565.4	40.77	34438.8	12.00	1.95E+5	1.71E-
26C	6		927.1	3.43	2894.0	12.00	2.39E+4	2.52E-
26C	6D1		390.2	57.72	48751.4	8.00	1.51E+4	2.84E-
26D1	3 prs		-169.9	4.80	4051.6	3.00	1.75E+4	2.45E-
3PRS	3		80.3	16.62	14035.9	3.00	8.29E+3	3.39E-
6D1	6D2		246.8	13.76	11626.3	8.00	9.56E+3	3.19E-
6D2	15		110.5	23.46	19817.5	2.50	1.37E+4	3.04E-
6D2	6E		120.8	20.22	17080.9	6.00	6.24E+3	3.59E-
26E	5C		93.5	20.22	17080.9	6.00	4.83E+3	3.85E-
25C	5E		-1110.7	43.01	36332.4	8.00	4.30E+4	2.12E-
25E	5		27.2	44.02	37181.7	6.00	1.40E+3	4.65E-
- 6C 2	6B		6249.4	20.02	16911.0	14.00	1.38E+5	1.77E-
бв 2	ROG		1825.6	40.04	33822.0	8.00	7.07E+4	2.05E-
ROG 2	12D		604.7	22.02	18600.1	5.00	3.75E+4	2.38E-
_12D 2	12B		583.2	19.38	16396.0	2.00	9.03E+4	2.37E-
- 12B 2	12		517.3	1.64	1383.2	2.00	8.01E+4	2.39E-
- 12B 2	12A		45.7	19.40	16390.7	2.00	7.08E+3	3.57E-
	11		30.1	11.79	9958.9	2.00	4.67E+3	3.96E-
ROG 2	HART		1180.9	23.46	19817.5	8.00	4.57E+4	2.22E-

COMPUTED PIFE FLOWS AND PARAMETERS

	COMPUT	ED PIPE	FLOWS AND	PARAMETERS	CONTINUED			
ROM NODE	TO NODE	STATUS	FLOW (lbm/hr)	CONDENSATE (lbm/hr)	HEAT LOSS (Btu/hr)	DIAMETER (in)	RE NUMBER	FRIC
FACTOR	13A		592.2	6.26	5284.7	6.00	3.06E+4	2.45E-
2 HART	14		553.3	41.90	35388.3	6.00	2.86E+4	2.48E-
2 6B	6AB		4332.0	25.70	21705.0	12.00	1.12E+5	1.85E-
2 6AB	6A		2437.7	45.62	38534.1	10.00	7.55E+4	2.00E-
2 6A	9D		2394.4	31.28	26423.2	8.00	9.27E+4	1.97E-
2 9D	9C		1365.8	32.84	27744.1	6.00	7.05E+4	2.10E-
2 9C	9W		708.4	2.23	1887.3	6.00	3.66E+4	2.36E-
2 9C	13C		607.8	39.10	33028.3	6.00	3.14E+4	2.43E-
2 9D	9E		986.6	27.93	23592.0	6.00	5.09E+4	2.22E-
2 9E	90		685.6	2.23	1887.4	6.00	3.54E+4	2.38E-
2 9E	30A		261.6	35.80	30235.3	4.00	2.03E+4	2.72E-
2 30A	30		235.5	16.37	13836.6	1.50	4.86E+4	2.63E-
6AB	1A		1867.3	29.41	24838.0	8.00	7.23E+4	2.04E-
2 1A	RR		1295.9	11.31	9556.4	10.00	4.01E+4	2.26E-
RR	4PRS		547.5	7.71	6511.5	6.00	2.83E+4	2.49E-
2 4PRS	4C		-541.1	69.53	58725.8	10.00	1.68E+4	2.11E-
4C	4D		450.2	25.34	21402.9	9.00	1.55E+4	2.82E-
2 4D	4 E		428.0	27.37	23120.4	8.00	1.66E+4	2.76E-
2 4E	4 F		408.6	16.76	14155.3	7.00	1.81E+4	2.75E-
4F	4G		395.6	18.10	15287.7	6.00	2.04E+4	2.67E-
2 4G	4H		289.9	21.00	17741.3	6.00	1.50E+4	2.87E-
2 4H	4		270.7	12.57	10616.5	4.00	2.10E+4	2.71E-
2 4G	BASH		-117.1	29.56	24970.0	4.00	9.07E+3	2.65E-
≥ BASH 2	22		15.7 [,]	12.85	10852.4	3.00	1.63E+3	5.12E-

FLOWS AND PARAMETERS CONTINUED

	COMPUT	ED PIPE	FLOWS AND	PARAMETERS	CONTINUED			
ROM	TO NODE	STATUS	FLOW (lbm/hr)	CONDENSATE (lbm/hr)	HEAT LOSS (Btu/hr)	DIAMETER (in)	RE NUMBER	FRIC
BASH	51		22.4	22.02	18600.1	4.00	1.74E+3	4.86E-
2 1A	1C		-255.4	100.37	84774.8	10.00	7.91E+3	2.18E-
² 1C	1D		439.8	23.46	19817.5	9.00	1.51E+4	2.83E-
1D	1E		382.7	23.46	19817.5	8.00	1.48E+4	2.86E-
1E	1F		375.4	19.55	16514.6	7.00	1.66E+4	2.79E-
2 1F	1F1		107.9	7.04	5945.2	6.00	5.57E+3	3.69E-
2 1F1	1L1		98.7	8.94	7549.3	1.50	2.04E+4	2.94E-
2 1F	1F2		245.8	8.38	7077.7	6.00	1.27E+4	2.99E-
2 1F2	1L2		116.4	45.25	38219.4	4.00	9.02E+3	3.29E-
2 1F2	1F3		103.0	2.14	1808.7	3.00	1.06E+4	3.19E-
1F3	1L3		99.1	9.78	8257.3	2.50	1.23E+4	3.11E-
RR	2F		713.7	177.92	150282.5	10.00	2.21E+4	2.38E-
2F	ALE		535.4	76.64	64737.0	10.00	1.66E+4	2.75E-
ALE	ALE1		395.7	19.55	16514.5	6.00	2.04E+4	2.12E-
ALE1	20D		303.8	27.65	23356.2	5.00	1.88E+4	2.74E-
20D	20W		133.4	28.96	24460.3	5.00	8.27E+3	3.34E-
20D	20M		121.7	37.71	31849.4	5.00	7.54E+3	3.43E-
ALE1	26C		151.5	31.37	26498.7	4.00	1.17E+4	3.09E-
26C	26		115.6	38.91	32868.5	4.00	8.95E+3	3.29E-

~ \ 100 T

Appendix C: BLAST Monthly Building Heating Loads

DATE	HEATING LO	HOURS MBTU/HR TEMP			HDD	BLDG 1
JAN	5.677E+09	727	7.81	31.4	33.6	
FEB	4.483E+09	672	6.67	33.1	31.9	
MAR	2.565E+09	639	4.01	43.1	21.9	
APR	1.011E+09	450	2.25	51.4	13.6	
MAY	8.386E+07	83	1.01	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	5.160E+08	201	2.57	57	8	
	1.938E+09	504	3.85	45.7	19.3	
DEC	4.173E+09	722	5.78	36.1	28.9	
	2.045E+10	3998	5.11			

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	BLDG 1
IAN	5.677E+09	727	7.81	31.4	33.6	6.98
FFR	4 483E+09	672	6.67	33.1	31.9	6.63
MAR	2.565E+09	639	4.01	43.1	21.9	4.63
APR	1.011E+09	450	2.25	51.4	13.6	2.96
MAY	8.386E+07	83	1.01	62.4	2.6	0.76
OCT	5.160E+08	201	2.57	57	8	0.24
NOV	1.938E+09	504	3.85	45.7	19.3	0.24
DEC	4.173E+09	722	5.78	36.1	28.9	0.24
						0.24
	Regression Ou	tput:				1.84
Constant	Ŭ	•	0.236199			4.11
Std Err o	f Y Est		0.620794			6.03
R Square	ed .		0.939826			
No of Ot	oservations		8			
Dearees	of Freedom		6		BASE	VARIABL
					0.236	0.201
X Coeffic	cient(s)	0.200586				
Std Err o	f Coef.	0.020721				

DATE	ATE HEATING LO HOURS MI			EMP	HDD	BLDG 2
JAN	2.246E+09	727	3.09	31.4	33.6	
FEB	1.772E+09	672	2.64	33.1	31.9	
MAR	1.011E+09	637	1.59	43.1	21.9	
APR	3.955E+08	450	0.88	51.4	13.6	
MAY	3.105E+07	79	0.39	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	2.014E+08	197	1.02	57	8	
NOV	7.630E+08	504	1.51	45.7	19.3	
DEC	1 .649E+09	722	2.28	36.1	28.9	
	8.069E+09	3988	2.02			

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	2.246E+09	727	3.09	31.4	33.6	2.76
FEB	1.772E+09	672	2.64	33.1	31.9	2.62
MAR	1.011E+09	637	1.59	43.1	21.9	1.83
APR	3.955E+08	450	0.88	51.4	13.6	1.17
MAY	3.105E+07	79	0.39	62.4	2.6	0.30
OCT	2.014E+08	197	1.02	57	8	0.09
NOV	7.630E+08	504	1.51	45.7	19.3	0.09
DEC	1.649E+09	722	2.28	36.1	28.9	0.09
						0.09
	Regression Ou	tput:				0.72
Constant	t	•	0.089402			1.62
Std Err o	of Y Est		0.249254			2.38
R Souare	ed		0.938217			
No. of O	bservations		8			
Degrees	of Freedom		6		BASE	VARIABL
5					0.089	0.079
X Coeffic	cient(s)	0.079414				
Std Err c	of Coef.	0.00832				

DATE	HEATING LO	HOURS MBTU/HR TEMP			HDD	BLDG 3
JAN	1.551E+09	727	2.13	31.4	33.6	
FEB	1.224E+09	672	1.82	33.1	31.9	
MAR	6.992E+08	639	1.09	43.1	21.9	
APR	2.748E+08	452	0.61	51.4	13.6	
MAY	2.232E+07	83	0.27	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	1.407E+08	201	0.70	57	8	
NOV	5286F+08	507	1.04	45.7	19.3	
DEC	1.139E+09	722	1.58	36.1	28.9	
	5.580E+09	4003	1.39			

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	1.551E+09	727	2.13	31.4	33.6	1.90
FFB	1.224E+09	672	1.82	33.1	31.9	1.81
MAR	6.992E+08	639	1.09	43.1	21.9	1.26
APR	2.748E+08	452	0.61	51.4	13.6	0.81
MAY	2.232E+07	83	0.27	62.4	2.6	0.20
OCT	1.407E+08	201	0.70	57	8	0.06
NOV	5.286E+08	507	1.04	45.7	19.3	0.06
DFC	1.139E+09	722	1.58	36.1	28.9	0.06
						0.06
	Regression Out	tput:				0.50
Constan	t	•	0.057753			1.12
Std Frr o	of Y Est		0.171053			1.65
R Squar	ed		0.939207			
No of O	bservations		8			
Degrees of Freedom			6		BASE	VARIABL
					0.058	0.055
X Coeffi	cient(s)	0.054969				
Std Err o	of Coef.	0.005709				

DATE	HEATING LO	HOURS MBTU/HR TEMP			HDD	BLDG 4
JAN	5.261E+09	727	7.24	31.4	33.6	
FEB	4.153E+09	672	6.18	33.1	31.9	
MAR	2.373E+09	639	3.71	43.1	21.9	
APR	9.335E+08	452	2.07	51.4	13.6	
MAY	7.572E+07	83	0.91	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	4.756E+08	201	2.37	57	8	
NOV	1.792E+09	504	3.56	45.7	19.3	
DEC	3.864E+09	722	5.35	36.1	28.9	
	1.893E+10	4000	4.73			

DATE	HEATING LO	HOURS	MBTU/HR TI	EMP	HDD	
JAN	5.261E+09	727	7.24	31.4	33.6	6.46
FEB	4.153E+09	672	6.18	33.1	31.9	6.15
MAR	2.373E+09	639	3.71	43.1	21.9	4.28
APR	9.335E+08	452	2.07	51.4	13.6	2.73
MAY	7.572E+07	83	0.91	62.4	2.6	0.68
OCT	4.756E+08	201'	2.37	57	8	0.20
NOV	1.792E+09	504	3.56	45.7	19.3	0.20
DEC	3.864E+09	722	5.35	36.1	28.9	0.20
						0.20
	Regression Ou	tput:				1.69
Constan	t		0.196088			3.80
Std Err c	of Y Est		0.57628			5.59
R Square	ed		0.940043			
No. of O	bservations		8			
Degrees	of Freedom		6		BASE	VARIABL
Ū.					0.196	0.187
X Coeffic	cient(s)	0.186562				
Std Err o	of Coef.	0.019235				

DATE	HEATING LO	HOURS N	18TU/HR T	HDD	BLDG 6	
						ZONE 1
JAN	2.265E+06	111	0.02	31.4	33.6	
FEB	2.538E+05	21	0.01	33.1	31.9	
MAR	0.000E+00	0	ERR	43.1	21.9	
APR	0.000E+00	0	ERR	51.4	13.6	
MAY	0.000E+00	0	ERR	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	ERR	69.2	0	
OCT	0.000E+00	0	ERR	57	8	
NOV	0.000E+00	0	ERR	45.7	19.3	
DEC	9.897E+03	3	0.00	36.1	28.9	
	2.529E+06	135	0.02			

DATE	HEATING LO) HOURS	MBTU/HR	TEMP	HDD	
JAN	2.265E+06	5 111	0.02	31.4	33.6	0.02
FEB	2.538E+05	5 21	0.01	33.1	31.9	0.01
DEC	9.897E+03	з з	0.00	36.1	28.9	-0.02
						-0.05
						-0.09
						-0.10
						-0.10
						-0.10
						-0.10
	Regression O	utput:				-0.07
Constant			-0.10003			-0.03
Std Err of Y Est			0.001719			0.00
R Squared			0.979804			
No. of Observations			3			
Degrees of Freedom			1		BASE	VARIABL
					-0.100	0.004
X Coeffic	tient(s)	0.003558				
Std Err o	f Coef.	0.000511				

DATE	HEATING	HOURS M	BTU/HR T	EMP	HDD	BLDG 6
						ZONE3
JAN	3.822E+09	726	5.26	31.4	33.6	
FEB	3.003E+09	652	4.61	33.1	31.9	
MAR	1.663E+09	599	2.78	43.1	21.9	
APR	6.784E+08	388	1.75	51.4	13.6	
MAY	6.327E+07	84	0.75	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	5.144E+05	3	0.17	69.2	0	
OCT	3.082E+08	166	1.86	57	8	
NOV	1.290E+09	464	2.78	45.7	19.3	
DEC	2.824E+09	712	3.97	36.1	28.9	
	1.365E+10	3794	3.60			

.

DATE	HEATING	HOURS	MBTU/HR	TEMP	HDD	
JAN	3.822E+09	726	5.26	31.4	33.6	0.02
FEB	3.003E+09	652	4.61	33.1	31.9	0.01
MAR	1.663E+09	599	2.78	43.1	21.9	-0.02
APR	6.784E+08	388	1.75	51.4	13.6	-0.05
MAY	6.327E+07	84	0.75	62.4	2.6	-0.09
SEP	5.144E+05	3	0.17	69.2	0	-0.10
OCT	3.082E+08	166	1.86	57	8	-0.10
NOV	1.290E+09	464	2.78	45.7	19.3	-0.10
DEC	2.824E+09	712	3.97	36.1	28.9	-0.10
	Regression	Output:				-0.07
Constant	-		0.265797			-0.03
Std Err of Y Est			0.353721			0.00
R Squared			0.962902			
No. of Observations			9			
Degrees of Freedom			7		BASE	VARIABL
-					0.266	0.135
X Coefficient(s)		0.134735				
Std Err of Coef.		0.009996				
	ZONE 1 WAF	IEHOUSE	В	LDG 8		
------	------------	---------	----------	-------	------	
DATE	HEATING LO	HOURS M	BTU/HR T	EMP	HDD	
JAN	6.608E+07	62	1.07	31.4	33.6	
FEB	3.616E+07	37	0.98	33.1	31.9	
MAR	0.000E+00	0	0.00	43.1	21.9	
APR	0.000E+00	0	0.00	51.4	13.6	
MAY	0.000E+00	0	0.00	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	0.000E+00	0	0.00	57	8	
NOV	0.000E+00	0	0.00	45.7	19.3	
DEC	0.000E+00	0	0.00	36.1	28.9	
	1.022E+08	99	1.03			

DATE	HEATING LO	HOURS M	BTU/HR T	EMP	HDD
JAN	6.608E+07	62	1.07	31.4	33.6
FEB	3.616E+07	37	0.98	33.1	31.9

m =	0.05
BASE =	-0.62

	BLDG 8				
DATE	HEATIN	HOURS M	BTU/HR TI	EMP	HDD
JAN	8.51E+07	364	0.23	31.4	33.6
FEB	4.73E+07	227	0.21	33.1	31.9
MAR	4.09E+06	51	0.08	43.1	21.9
APR	0.00E+00	0	0.00	51.4	13.6
MAY	0.00E+00	0	0.00	62.4	2.6
JUN	0.00E+00	0	0.00	70.8	0
JUL	0.00E+00	0	0.00	76.3	0
AUG	0.00E+00	0	0.00	74.6	0
SEP	0.00E+00	0	0.00	69.2	0
OCT	0.00E+00	0	0.00	57	8
NOV	1.08E+06	18	0.06	45.7	19.3
DEC	2.88E+07	202	0.14	36.1	28.9
	1.66E+08	862	0.19		

HEATIN	HOURS	MBTU/HR	TEMP	HDD	
8.51E+07	364	0.23	31.4	33.6	0.22
4.73E+07	227	0.21	33.1	31.9	0.20
4.09E+06	51	0.08	43.1	21.9	0.08
1.08E+06	18	0.06	45.7	19.3	-0.02
2.88E+07	202	0.14	36.1	28.9	-0.15
					-0.18
					-0.18
					-0.18
					-0.18
Rearessio	n Output:				-0.08
	•	-0.18059			0.05
f Y Est		0.016512			0.17
ed and		0.964973			
servations		5			
of Freedom		3		BASE	VARIABL
				-0.181	0.012
ient(s)	0.012003				
f Coef.	0.00132				
	HEATIN 8.51E+07 4.73E+07 4.09E+06 1.08E+06 2.88E+07 Regressio f Y Est cd pservations of Freedom sient(s) f Coef.	HEATIN HOURS 8.51E+07 364 4.73E+07 227 4.09E+06 51 1.08E+06 18 2.88E+07 202 Regression Output: f Y Est sd servations of Freedom sient(s) 0.012003 f Coef. 0.00132	HEATIN HOURS MBTU/HR 8.51E+07 364 0.23 4.73E+07 227 0.21 4.09E+06 51 0.08 1.08E+06 18 0.06 2.88E+07 202 0.14 Regression Output: -0.18059 f Y Est 0.016512 add 0.964973 oservations 5 of Freedom 3 sient(s) 0.012003 f Coef, 0.00132	HEATIN HOURS MBTU/HR TEMP 8.51E+07 364 0.23 31.4 4.73E+07 227 0.21 33.1 4.09E+06 51 0.08 43.1 1.08E+06 18 0.06 45.7 2.88E+07 202 0.14 36.1	HEATIN HOURS MBTU/HR TEMP HDD 8.51E+07 364 0.23 31.4 33.6 4.73E+07 227 0.21 33.1 31.9 4.09E+06 51 0.08 43.1 21.9 1.08E+06 18 0.06 45.7 19.3 2.88E+07 202 0.14 36.1 28.9 A control output: -0.18059 1 2.89 f Y Est 0.016512 20.964973 20.964973 oservations 5 5 6 Freedom 3 BASE -0.181 0.012003 6 0.0132 1.81 1.81

	ZONE 1 WAF	REHOUSE B	LDG 9		
DATE	HEATING LO	HOURS M	BTU/HR T	EMP	HDD
JAN	6.943E+09	720	9.64	31.4	33.6
FEB	5.407E+09	672	8.05	33.1	31.9
MAR	2.899E+09	606	4.78	43.1	21.9
APR	9.875E+08	392	2.52	51.4	13.6
MAY	2.925E+07	20	1.46	62.4	2.6
JUN	0.000E+00	0	0.00	70.8	0
JUL	0.000E+00	0	0.00	76.3	0
AUG	0.000E+00	0	0.00	74.6	0
SEP	0.000E+00	0	0.00	69.2	0
OCT	4.792E+08	151	3.17	57	8
NOV	2.176E+09	454	4.79	45.7	19.3
DEC	5.024E+09	712	7.06	36.1	28.9
	2.394E+10	3727	6.42		

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	6.943E+09	720	9.64	31.4	33.6	8.48
FEB	5.407E+09	672	8.05	33.1	31.9	8.07
MAR	2.899E+09	606	4.78	43.1	21.9	5.65
APR	9.875E+08	392	2.52	51.4	13.6	3.64
MAY	2.925E+07	20	1.46	62.4	2.6	0.99
OCT	4.792E+08	151	3.17	57	8	0.36
NOV	2.176E+09	454	4.79	45.7	19.3	0.36
DEC	5.024E+09	712	7.06	36.1	28.9	0.36
						0.36
	Regression Ou	tput:				2.29
Constant			0.359711			5.02
Std Err of	f Y Est		0.86747			7.34
R Square	d		0.920631			
No. of Ob	servations		8			
Degrees	of Freedom		6		BASE	VARIABL
					0.360	0.242
X Coeffic	ient(s)	0.241549				
Std Err of	Coef.	0.028954				

		ZONE 2	OFFICE	BLDG 9	
DATE	HEATING	HOURS	S MBTU/HR	TEMP	HDD
JAN	1.824E+09	620	2.94	31.4	33.6
FEB	1.390E+09	542	2.56	33.1	31.9
MAR	6.033E+08	392	1.54	43.1	21.9
APR	1.647E+08	207	0.80	51.4	13.6
MAY	2.287E+06	6	0.38	62.4	2.6
JUN	0.000E+00	0	0.00	70.8	0
JUL	0.000E+00	0	0.00	76.3	0
AUG	0.000E+00	0	0.00	74.6	0
SEP	0.000E+00	0	0.00	69.2	0
OCT	6.791E+07	65	1.04	57	8
NOV	4.377E+08	318	1.38	45.7	19.3
DEC	1.237E+09	586	2.11	36.1	28.9
	5.727E+09	2736	2.09		

DATE	HEATING	HOURS	MBTU/HR	TEMP	HDD	
JAN	1.824E+09	620	2.94	31.4	33.6	2.62
FEB	1.390E+09	542	2.56	33.1	31.9	2.49
MAR	6.033E+08	392	1.54	43.1	21.9	1.74
APR	1.647E+08	207	0.80	51.4	13.6	1.12
MAY	2.287E+06	6	0.38	62.4	2.6	0.29
OCT	6.791E+07	65	1.04	57	8	0.10
NOV	4.377E+08	318	1.38	45.7	19.3	0.10
DEC	1.237E+09	586	2.11	36.1	28.9	0.10
						0.10
	Regression	Output:				0.70
Constar	nt	•	0.095868			1.54
Std Err o	of Y Est		0.269382			2.26
R Souar	red		0.920642			
No. of C) bservations		8			
Dearees	of Freedom	-	6		BASE	VARIABL
203.000					0.096	0.075
X Coeffi	cient(s)	0.075016				
Std Err	of Coef.	0.008991				

DATE	HEATING LO	HOURS M	IBTU/HR T	EMP	HDD	BLDG 11
JAN	8.101E+07	687	0.12	31.4	33.6	
FEB	6.275E+07	610	0.10	33.1	31.9	
MAR	3.419E+07	502	0.07	43.1	21.9	
APR	1.359E+07	296	0.05	51.4	13.6	
MAY	8.816E+05	41	0.02	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	6.229E+06	121	0.05	57	8	
NOV	2.799E+07	424	0.07	45.7	19.3	
DEC	6.231E+07	659	0.09	36.1	28.9	
	2.890E+08	3340	0.09			

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	8.101E+07	687	0.12	31.4	33.6	0.11
FEB	6.275E+07	610	0.10	33.1	31.9	0.10
MAR	3.419E+07	502	0.07	43.1	21.9	0.08
APR	1.359E+07	296	0.05	51.4	13.6	0.05
MAY	8.816E+05	41	0.02	62.4	2.6	0.02
OCT	6.229E+06	121	0.05	57	8	0.02
NOV	2.799E+07	424	0.07	45.7	19.3	0.02
DEC	6.231E+07	659	0.09	36.1	28.9	0.02
						0.02
	Regression Ou	tput:				0.04
Constant	-		0.015832			0.07
Std Err of	f Y Est		0.008243			0.10
R Square	d		0.943892			
No. of Ob	servations		8			
Degrees	of Freedom		6		BASE	VARIABL
•					0.016	0.003
X Coeffic	ient(s)	0.002764				
Std Err of	Coef.	0.000275				

DATE	HEATING LO	HOURS M	BTU/HR TI	EMP	HDD	BLDG 12
.IAN	2.219E+09	709	3.13	31.4	33.6	
FFR	1.722E+09	634	2.72	33.1	31.9	
MAR	9.280E+08	532	1.74	43.1	21.9	
APR	3.707E+08	314	1.18	51.4	13.6	
MAY	2 976F+07	57	0.52	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	2 222E+05	2	0.11	69.2	0	
OCT	1 720E+08	133	1.29	57	8	÷
NOV	7 474E+08	436	1.71	45.7	19.3	
DEC	1.662E+09	678	2.45	36.1	28.9	
	7.851E+09	3495	2.25			

DATE	HEATING LO	HOURS N	MBTU/HR TI	EMP	HDD	
		700	0.40	21 /	33.6	2 89
JAN	2.219E+09	709	3.13	00.4	21.0	2.00
FEB	1.722E+09	634	2.72	33.1	31.9	1.00
MAR	9.280E+08	532	1.74	43.1	21.9	1.98
APR	3.707E+08	314	1.18	51.4	13.6	1.33
MAY	2.976E+07	57	0.52	62.4	2.6	0.47
SEP	2.222E+05	2	0.11	69.2	0	0.26
	1 720E+08	133	1.29	57	8	0.26
NOV	7 4745:08	436	171	45.7	19.3	0.26
	1 6625,00	678	245	36.1	28.9	0.26
DEC	1.0020+09		2.40	00.1		0.89
	Regression Ou	tput:				1 77
Constant			0.264806			0.77
Std Err of	Y Est		0.217821			2.52
R Square	d		0.958325			
No of Ob	servations		9			
	of Freedom		7		BASE	VARIABL
Degrees	birricedom				0.265	0.078
X Coeffic	ient(s)	0.078095				
Std Err of	Coef.	0.006155				

DATE	HEATING LO	HOURS N	IBTU/HR T	EMP	HDD	BLDG 13
JAN	2.050E+09	620	3.31	31.4	33.6	
FEB	1.553E+09	537	2.89	33.1	31.9	
MAR	7.451E+08	418	1.78	43.1	21.9	
APR	2.446E+08	242	1.01	51.4	13.6	
MAY	7.526E+06	15	0.50	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	1.213E+08	90	1.35	57	8	
NOV	6.139E+08	358	1.71	45.7	19.3	
DEC	1.475E+09	586	2.52	36.1	28.9	
	6.810E+09	2866	2.38			

DATE HEATING LO HOURS MBTU/HR TEMP HDD

JAN	2.050E+09	620	3.31	31.4	33.6	2.99
FEB	1.553E+09	537	2.89	33.1	31.9	2.85
MAR	7.451E+08	418	1.78	43.1	21.9	2.04
APR	2.446E+08	242	1.01	51.4	13.6	1.37
MAY	7.526E+06	15	0.50	62.4	2.6	0.47
OCT	1.213E+08	90	1.35	57	8	0.26
NOV	6.139E+08	358	1.71	45.7	19.3	0.26
DEC	1.475E+09	586	2.52	36.1	28.9	0.26
						0.26
	Regression OL	itput:				0.91
Constant	-		0.260151			1.83
Std Err of	Y Est		0.290664			2.61
R Square	d		0.921285			
No. of Ob	servations		. 8			
Degrees	of Freedom		6		BASE	VARIABL
Ũ					0.260	0.081
X Coeffic	ient(s)	0.081301				
Std Err of	Coef.	0.009702				

DATE	HEATING LO	HOURS N	IBTU/HR TI	EMP	HDD
JAN	1.358E+09	700	1.94	31.4	33.6
FEB	1.067E+09	621	1.72	33.1	31.9
MAR	5.915E+08	543	1.09	43.1	21.9
APR	2.502E+08	346	0.72	51.4	13.6
MAY	2.505E+07	80	0.31	62.4	2.6
JUN	0.000E+00	0	0.00	70.8	0
JUL	0.000E+00	0	0.00	76.3	0
AUG	0.000E+00	0	0.00	74.6	0
SEP	4.257E+05	4	0.11	69.2	0
OCT	1.119E+08	154	0.73	57	8
NOV	4.664E+08	447	1.04	45.7	19.3
DEC	1.013E+09	669	1.51	36.1	28.9
	4.883E+09	3564	1.37		

•

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	1.358E+09	700	1.94	31.4	33.6	1.80
FEB	1.067E+09	621	1.72	33.1	31.9	1.71
MAR	5.915E+08	543	1.09	43.1	21.9	1.22
APR	2.502E+08	346	0.72	51.4	13.6	0.82
MAY	2.505E+07	80	0.31	62.4	2.6	0.28
SEP	4.257E+05	4	0.11	69.2	0	0.15
OCT	1.119E+08	154	0.73	57	8	0.15
NOV	4.664E+08	447	1.04	45.7	19.3	0.15
DEC	1.013E+09	669	1.51	36.1	28.9	0.15
	Regression Out	tput:				0.54
Constant	-		0.15003			1.09
Std Err o	f Y Est		0.113345			1.57
R Square	ed		0.970915			
No. of Ol	bservations		9			
Degrees	of Freedom		7		BASE	VARIABL
					0.150	0.049
X Coeffic	zient(s)	0.048962				
Std Err o	f Coef.	0.003203				

HEATING LO	HOURS M	IBTU/HR T	EMP	HDD	BLDG 15
3.720E+08	511	0.73	31.4	33.6	
3.030E+08	472	0.64	33.1	31.9	
1.855E+08	442	0.42	43.1	21.9	
8.867E+07	316	0.28	51.4	13.6	
1.164E+07	100	0.12	62.4	2.6	
0.000E+00	0	0.00	70.8	0	
0.000E+00	0	0.00	76.3	0	
0.000E+00	0	0.00	74.6	0	
6.145E+05	10	0.06	69.2	0	
3.654E+07	147	0.25	57	8	
1.456E+08	373	0.39	45.7	19.3	
2.949E+08	516	0.57	36.1	28.9	
1.438E+09	2887	0.50			
	HEATING LO 3.720E+08 3.030E+08 1.855E+08 8.867E+07 1.164E+07 0.000E+00 0.000E+00 0.000E+00 6.145E+05 3.654E+07 1.456E+08 2.949E+08 1.438E+09	HEATING LO HOURS M 3.720E+08 511 3.030E+08 472 1.855E+08 442 8.867E+07 316 1.164E+07 100 0.000E+00 0 0.000E+00 0 0.000E+00 0 0.000E+00 0 0.6145E+05 10 3.654E+07 147 1.456E+08 373 2.949E+08 516	HEATING LO HOURS MBTU/HR T 3.720E+08 511 0.73 3.030E+08 472 0.64 1.855E+08 442 0.42 8.867E+07 316 0.28 1.164E+07 100 0.12 0.000E+00 0 0.00 1.455E+05 10 0.06 3.654E+07 147 0.25 1.456E+08 373 0.39 2.949E+08 516 0.57 1.438E+09 2887 0.50	HEATING LO HOURS MBTU/HR TEMP 3.720E+08 511 0.73 31.4 3.030E+08 472 0.64 33.1 1.855E+08 442 0.42 43.1 8.867E+07 316 0.28 51.4 1.164E+07 100 0.12 62.4 0.000E+00 0 0.00 70.8 0.000E+00 0 0.00 76.3 0.000E+00 0 0.00 74.6 6.145E+05 10 0.06 69.2 3.654E+07 147 0.25 57 1.456E+08 373 0.39 45.7 2.949E+08 516 0.57 36.1 1.438E+09 2887 0.50 0.50	HEATING LO HOURS MBTU/HR TEMP HDD 3.720E+08 511 0.73 31.4 33.6 3.030E+08 472 0.64 33.1 31.9 1.855E+08 442 0.42 43.1 21.9 8.867E+07 316 0.28 51.4 13.6 1.164E+07 100 0.12 62.4 2.6 0.000E+00 0 0.00 70.8 0 0.000E+00 0 0.00 76.3 0 0.000E+00 0 0.00 74.6 0 0.145E+05 10 0.06 69.2 0 3.654E+07 147 0.25 57 8 1.456E+08 373 0.39 45.7 19.3 2.949E+08 516 0.57 36.1 28.9

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	3.720E+08	511	0.73	31.4	33.6	0.67
FEB	3.030E+08	472	0.64	33.1	31.9	0.64
MAR	1.855E+08	442	0.42	43.1	21.9	0.46
APR	8.867E+07	316	0.28	51.4	13.6	0.31
MAY	1.164E+07	100	0.12	62.4	2.6	0.11
SEP	6.145E+05	10	0.06	69.2	0	0.06
OCT	3.654E+07	147	0.25	57	8	0.06
NOV	1.456E+08	373	0.39	45.7	19.3	0.06
DEC	2.949E+08	516	0.57	36.1	28.9	0.06
	Regression Ou	tput:				0.21
Constant			0.059871			0.41
Std Err o	f Y Est		0.03378			0.59
R Square	ed		0.98125			
No. of Ot	oservations		9			
Degrees of Freedom			7		BASE	VARIABL
-					0.060	0.018
X Coeffic	ient(s)	0.018271				
Std Err of	f Coef.	0.000955				

	ZONE 1 WAF	REHOUSE B	LDG 20		
DATE	HEATING LO	HOURS M	BTU/HR T	EMP	HDD
JAN	1.436E+09	727	1.98	31.4	33.6
FEB	1.133E+09	672	1.69	33.1	31.9
MAR	6.460E+08	637	1.01	43.1	21.9
APR	2.527E+08	451	0.56	51.4	13.6
MAY	1.974E+07	79	0.25	62.4	2.6
JUN	0.000E+00	0	0.00	70.8	0
JUL	0.000E+00	0	0.00	76.3	0
AUG	0.000E+00	0	0.00	74.6	0
SEP	0.000E+00	0	0.00	69.2	0
OCT	1.288E+08	196	0.66	57	8
NOV	4.877E+08	503	0.97	45.7	19.3
DEC	1.054E+09	721	1.46	36.1	28.9
	5.158E+09	3986	1.29		

DATE	HEATING LO	HOURS	MBTU/HR T	EMP	HDD	
JAN	1.436E+09	727	1.98	31.4	33.6	1.76
FEB	1.133E+09	672	1.69	33.1	31.9	1.68
MAR	6.460E+08	637	1.01	43.1	21.9	1.17
APR	2.527E+08	451	0.56	51.4	13.6	0.75
MAY	1.974E+07	79	0.25	62.4	2.6	0.19
OCT	1.288E+08	196	0.66	57	8	0.06
NOV	4.877E+08	503	0.97	45.7	19.3	0.06
DEC	1.054E+09	721	1.46	36.1	28.9	0.06
						0.06
	Regression Out	tput:				0.46
Constant	t		0.057428			1.04
Std Err o	of Y Est		0.160163			1.52
R Square	ed		0.937649			
No. of O	bservations		8			
Degrees	of Freedom		6		BASE	VARIABL
					0.057	0.051
X Coeffic	cient(s)	0.050781				
Std Err o	of Coef.	0.005346				

		ZONE 2 G	YM		BLDG 20
DATE	HEATIN	HOURS N	IBTU/HR T	EMP	HDD
JAN	2.99E+09	744	4.02	31.4	33.6
FE.B	2.45E+09	672	3.64	33.1	31.9
MAR	1.70E+09	731	2.33	43.1	21.9
APR	9.72E+08	662	1.47	51.4	13.6
MAY	2.63E+08	380	0.69	62.4	2.6
JUN	1.04E+07	35	0.30	70.8	0
JUL	0.00E+00	0	0.00	76.3	0
AUG	0.00E+00	0	0.00	74.6	0
SEP	4.23E+07	134	0.32	69.2	0
OCT	5.37E+08	508	1.06	57	8
NOV	1.36E+09	680	2.00	45.7	19.3
DEC	2.39E+09	744	3.22	36.1	28.9
	1.27E+10	5290	2.41		

DATE	HEATIN	HOURS	MBTU/HR	TEMP	HDD	
JAN	2.99E+09	744	4.02	31.4	33.6	
FEB	2.45E+09	672	3.64	33.1	31.9	3.74
MAR	1.70E+09	731	2.33	43.1	21.9	3.56
APR	9.72E+08	662	1.47	51.4	13.6	2.52
MAY	2.63E+08	380	0.69	62.4	2.6	1.66
JUN	1.04E+07	35	0.30	70.8	0	0.51
SEP	4.23E+07	134	0.32	69.2	0	0.24
OCT	5.37E+08	508	1.06	57	8	0.24
NOV	1.36E+09	680	2.00	45.7	19.3	0.24
DEC	2.39E+09	744	3.22	36.1	28.9	0.24
	Regressio	n Output:			•	1.07
Constant			0.240791			2.25
Std Err of	Y Est		0.181842			3.25
R Square	d		0.984358			
No. of Ob	servations		10			
Degrees of	of Freedom		8		BASE	VARIABL
					0.241	0.104
X Coeffici	ent(s)	0.104107				
Std Err of	Coef.	0.00464				

DATE	HEATING LO	HOURS M	IBTU/HR T	EMP	HDD	BLDG 26
JAN	1.922E+09	727	2.64	31.4	33.6	
FEB	1.517E+09	672	2.26	33.1	31.9	
MAR	8.661E+08	638	1.36	43.1	21.9	
APR	3.398E+08	452	0.75	51.4	13.6	
MAY	2.707E+07	82	0.33	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUĽ	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	ERR	69.2	0	
OCT	1.733E+08	200	0.87	57	8	
NOV	6.547E+08	505	1.30	45.7	19.3	
DEC	1.412E+09	722	1.96	36.1	28.9	
	6.912E+09	3998	1.73			

.

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	1.922E+09	727	2.64	31.4	33.6	2.36
FEB	1.517E+09	672	2.26	33.1	31.9	2.25
MAR	8.661E+08	638	1.36	43.1	21.9	1.56
APR	3.398E+08	452	0.75	51.4	13.6	1.00
MAY	2.707E+07	82	0.33	62.4	2.6	0.25
OCT	1.733E+08	200	0.87	57	8	0.07
NOV	6.547E+08	505	1.30	45.7	19.3	0.07
DEC	1.412E+09	722	1.96	36.1	28.9	0.07
						0.07
	Regression Ou	tput:				0.62
Constant	t		0.069821			1.39
Std Err o	of Y Est		0.211263			2.04
R Square	ed		0.939747			
No. of O	bservations		8			
Degrees	of Freedom		6		BASE	VARIABL
•					0.070	0.068
X Coeffic	cient(s)	0.068214				
Std Err o	of Coef.	0.007052				

DATE	HEATING LO	HOURS MBTU/HR TEMP			HDD	BLDG 30
JAN	1.602E+09	709	2.26	31.4	33.6	
FEB	1.209E+09	653	1.85	33.1	31.9	
MAR	5.839E+08	537	1.09	43.1	21.9	
APR	1.520E+08	271	0.56	51.4	13.6	
MAY	5.692E+06	17	0.33	62.4	2.6	
JUN	0.000E+00	0	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	0.000E+00	0	0.00	69.2	0	
OCT	9.781E+07	116	0.84	57	8	
NOV	4.505E+08	415	1.09	45.7	19.3	
DEC	1.101E+09	689	1.60	36.1	28.9	
	5.202E+09	3407	1.53			

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	1.602E+09	709	2.26	31.4	33.6	1.95
FEB	1.209E+09	653	1.85	33.1	31.9	1.85
MAR	5.839E+08	537	1.09	43.1	21.9	1.31
APR	1.520E+08	271	0.56	51.4	13.6	0.85
MAY	5.692E+06	17	0.33	62.4	2.6	0.25
OCT	9.781E+07	116	0.84	57	8	0.11
NOV	4.505E+08	415	1.09	45.7	19.3	0.11
DEC	1.101E+09	689	1.60	36.1	28.9	0.11
						0.11
	Regression Out	iput:				0.55
Constant	t		0.112228			1.17
Std Err c	of Y Est		0.238353			1.69
R Square	be		0.886956			
No. of Observations			8			
Degrees	of Freedom		6		BASE	VARIABL
-					0.112	0.055
X Coeffic	cient(s)	0.054586				
Std Err o	of Coef.	0.007956				

DATE	HEATING LO	HOURS N	1BTU/HR T	EMP	HDD	BLDG 51
JAN	1.060E+09	723	1.47	31.4	33.6	
FEB	8.355E+08	672	1.24	33.1	31.9	
MAR	4.860E+08	655	0.74	43.1	21.9	
APR	2.047E+08	471	0.43	51.4	13.6	
MAY	3.052E+07	148	0.21	62.4	2.6	
JUN	3.237E+05	3	0.00	70.8	0	
JUL	0.000E+00	0	0.00	76.3	0	
AUG	0.000E+00	0	0.00	74.6	0	
SEP	1.599E+06	21	0.08	69.2	0	
OCT	1.165E+08	278	0.42	57	8	
NOV	3.742E+08	530	0.71	45.7	19.3	
DEC	7.764E+08	723	1.07	36.1	28.9	
	3.886E+09	4224	0.92			

DATE	HEATING LO	HOURS	MBTU/HR	TEMP	HDD	
JAN	1.060E+09	723	1.47	31.4	33.6	
FEB	8.355E+08	672	1.24	33.1	31.9	1.30
MAR	4.860E+08	655	0.74	43.1	21.9	1.24
APR	2.047E+08	471	0.43	51.4	13.6	0.86
MAY	3.052E+07	148	0.21	62.4	2.6	0.55
JUN	3.237E+05	3	0.00	70.8	0	0.13
SEP	1.599E+06	ຸ21	0.08	69.2	0	0.03
OCT	1.165E+08	278	0.42	57	8	0.03
NOV	3.742E+08	530	0.71	45.7	19.3	0.03
DEC	7.764E+08	723	1.07	36.1	28.9	0.03
	Regression Ou	tput:				0.34
Constant			0.03454			0.76
Std Err o	f Y Est		0.096674			1.12
R Square	ed		0.966859			
No. of Observations			10			
Degrees of Freedom			8		BASE	VARIABL
-					0.035	0.038
X Coefficient(s)		0.037684				
Std Err o	f Coef.	0.002467				

Appendix D: Chiller Equipment

CHILLER EQUIPMENT

•

	BLDG.	UNITS	TONNAGE	LOCATION USE	INSTALLED	REFRIGERANT
		•		DY (not in use)	1960	R-22
	M-3	2 EA	3 Ton Chrysler	P.A. (not in use)	1990	R-22
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	M-3	1 EA	5 Ton York	P.A.	1070	R-22 *2
M-5C&D 1 EA 130 Ton Carrier C&D Bays 1961 R*14 2 6-1-A 1 EA 25 Ton Singer Ball. Range 1980 R-22 6-1-C 2 EA 400 Ton Carrier Entire Bldg 1986 R-11 *1 6-1-D 1 EA 3 Ton Dunn&Bush Environ. Rm 1975 R-22 *3 6-1-D 1 EA 3 Ton Dunn&Bush Environ. Rm 1979 R-22 *3 6-1-E 1 EA 25 Ton Trane Cmndrs Suite 1986 R-22 6-2-B 1 EA 20 Ton Liebert DCASR Comp. Rm 1983 R-22 8-1 1 EA 15 Ton Carrier F.E. Office 1986 R-22 8-3 1 EA 20 Ton Datec Computer Room 1987 R-22 9-1-F 2 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 2 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Trane </td <td>M-5</td> <td>1 EA</td> <td>5 Ton Dunn-Bush</td> <td>Environ. Rm</td> <td>1001</td> <td>P_11 *2</td>	M-5	1 EA	5 Ton Dunn-Bush	Environ. Rm	1001	P_11 *2
	M-5C&D	1 EA	130 Ton Carrier	C&D Bays	1981	
61-1.2 2 EA 400 Ton Carrier Entire Bldg 1986 R-11 *1 6-1-D 1 EA 60 Ton McQuay Medical Lab 1984 R-22 *3 6-1-D 1 EA 3 Ton Dunn&Bush Environ. Rm 1975 R-22 *3 6-1-E 1 EA 40 Ton Trane Dispensary 1979 R-22 *3 6-2-C 1 EA 25 Ton Trane Cmdrs Suite 1986 R-22 8-3 1 EA 25 Ton Carrier F.E. Office 1985 R-22 9-1E&F 1 EA 25 Ton Carrier Trng Rooms 1986 R-22 9-1F 2 EA 20 Ton Datec Computer Room 1990 R-22 9-1-F 2 EA 25 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Trane DSAC-W 1986 R-22 9-2-C 1 EA 25 Ton Trane <	6-1-N	1 57	25 Ton Singer	Ball. Range	1980	R-22
6-1-C 1 EA 400 TON MCQUAY Medical Lab 1984 R-22 *3 6-1-D 1 EA 3 TON DUNABUSH Environ. Rm 1975 R-22 *3 6-1-D 1 EA 40 TON Trane Dispensary 1979 R-22 *3 6-1-E 1 EA 25 TON Trane Cmndrs Suite 1986 R-22 6-2-B 1 EA 25 TON Carrier F.E. Office 1985 R-22 8-1 1 EA 25 TON Carrier Trng Rooms 1986 R-22 9-1E&F 1 EA 25 TON Carrier Trng Rooms 1986 R-22 9-1-F 3 EA 20 TON Liebert Computer Room 1990 R-22 9-1-F 4 EA 20 TON Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 TON Tiabert Computer Room 1990 R-22 9-1-F 1 EA 25 TON Ton Bohn DSAC-W 1980 R-22 9-1-F 1 EA 25 TON Trane DSAC-W 1981 R-22 9-1-F 1 EA 25 TON Trane DSAC-W <t< td=""><td>6 1 0</td><td></td><td>ADD Ton Carrier</td><td>Entire Bldg</td><td>1986</td><td>R-11 *1</td></t<>	6 1 0		ADD Ton Carrier	Entire Bldg	1986	R-11 *1
	6-1-0	ZEA		Medical Lab	1984	R-22
	6-1-D	1 EA	2 mar Durn Durch	Environ Bm	1975	R-22 *3
	6-1-D	1 EA	3 Ton DunneBush	Dispersion. Ida	1079	R-22
	6-1-E	1 EA	40 Ton Trane	Dispensary	1096	R-22
6-2-C1EA20Ton LiebertDCASR Comp. Rm1983R=22 $8-1$ 1EA15Ton CarrierF.E. Office1985R=22 $8-3$ 1EA25Ton CarrierTrng Rooms1986R=22 $9-1-F$ 1EA20Ton DatecComputer Room1987R=22 $9-1-F$ 4EA20Ton LiebertComputer Room1990R=22 $9-1-F$ 2EA25Ton LiebertComputer Room1990R=22 $9-1-F$ 1EA20Ton LiebertTele Comm1991R=22 $9-1-F$ 1EA25Ton LiebertComputer Room1986R=22 $9-1-F$ 1EA25Ton BohnDSAC-W1980R=22 $9-2-C$ 1EA25Ton TraneDSAC-W1980R=22 $9-3EKF$ 1EA10Ton CarrierSubs & Medical1991R=22 $9-3EKF$ 1EA40Ton CarrierSubs & Medical1991R=22 $9-4-F$ 1EA5Ton YorkMedical1991R=22 $11-1$ 1EA5Ton YorkEntire Bldg1990R=11*1 $12-LL$ 1EA5Ton CarrierCmmd Cntrl Ctr1978R=22 $12-LL$ 1EA5Ton CarrierComputer Room1985R=22*3 $12-LL$ 1EA5Ton Car	6-2-В	1 EA	25 Ton Trane	Cmndrs Suite	1002	R 22 P-22
8-11EA15TON CarrierF.E. Office1985R-22 $8-3$ 1EA25TON CarrierTrng Rooms1986R-22 $9-1-F$ 1EA20TON DatecComputer Room1990R-22 $9-1-F$ 3EA20TON LiebertComputer Room1990R-22 $9-1-F$ 2EA25TON LiebertComputer Room1990R-22 $9-1-F$ 1EA20TON LiebertComputer Room1990R-22 $9-1-F$ 1EA20TON LiebertComputer Room1990R-22 $9-1-F$ 1EA20TON LiebertComputer Room1980R-22 $9-1-F$ 1EA25TON LiebertComputer Room1980R-22 $9-1-F$ 1EA25TON TaneDSAC-W1980R-22 $9-2-D$ 1EA25TON TaneMedical1981R-22 $9-3EEF$ 1EA25TON YorkMedical1985R-22 $9-4-F$ 1EA85TON YorkMedical1991R-22 $11-1$ 1EA5TON YorkEntire Bldg1990R-11*1 $12-LL$ 1EA5TON YorkEntire Bldg1990R-22*3 $12-LL$ 1EA5TON CarrierCompdeter Room1985R-22*3 $12-LL$ 1EA5TON Carri	6-2-C	1 EA	20 Ton Liebert	DCASR Comp. Rm	1982	K-22
8-3 1 EA 25 Ton Carrier Trng Rooms 1986 R-22 9-1E&F 1 EA 130 Ton Trane OTIS & Subs 1990 R-22 9-1-F 3 EA 20 Ton Datec Computer Room 1987 R-22 9-1-F 3 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 2 EA 25 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Liebert Computer Room 1980 R-22 9-2-D 1 EA 25 Ton Trane DSAC-W 1980 R-22 9-3-E&F 1 EA 25 Ton York Medical 1985 R-22 9-4-F 1 EA 5 Ton York Security 1981 R-22 11-1 1 EA 5 Ton York Entire Bldg 1990 R-11 *1	8-1	1 52	15 Ton Carrier	F.E. Office	1985	R-22
9-1E&F1EA130TonTrane TraneOTIS & Subs1990R-22 $9-1-F$ 3EA20TonDatecComputer Room1987R-22 $9-1-F$ 4EA20TonLiebertComputer Room1990R-22 $9-1-F$ 1EA20TonLiebertComputer Room1990R-22 $9-1-F$ 1EA20TonLiebertComputer Room1990R-22 $9-1-F$ 1EA25Ton BohnDSAC-W1986R-22 $9-2-C$ 1EA25Ton TraneDSAC-W1985R-22 $9-2-D$ 1EA25Ton TraneMedical1991R-22 $9-3E&F$ 1EA140Ton CarrierSubs & Medical1991R-22 $9-4-F$ 1EA25Ton YorkMedical1991R-22 $9-4-F$ 1EA550Ton YorkSecurity1981R-22 $11-1$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA5Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA5Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA5Ton CarrierCommand Wing1976R-22 $12-1-H$ <td>8-3</td> <td>1 EA</td> <td>25 Ton Carrier</td> <td>Trng Rooms</td> <td>1986</td> <td>R-22</td>	8-3	1 EA	25 Ton Carrier	Trng Rooms	1986	R-22
9-1EkF1 EA130 TON Trane0 TON Trane0 TON Trane1917R-22 $9-1-F$ 3 EA20 Ton DatecComputer Room1990R-22 $9-1-F$ 4 EA20 Ton LiebertComputer Room1990R-22 $9-1-F$ 1 EA25 Ton LiebertComputer Room1991R-22 $9-1-F$ 1 EA25 Ton LiebertComputer Room1986R-22 $9-1-F$ 1 EA25 Ton BohnDSAC-W1986R-22 $-2-C$ 1 EA25 Ton TraneDSAC-W1985R-22 $9-2-D$ 1 EA25 Ton TraneMedical1991R-22 $9-3EkF$ 1 EA140 Ton CarrierSubs & Medical1991R-22 $9-4-E$ 1 EA25 Ton YorkMedical1991R-22 $9-4-F$ 1 EA550 Ton YorkSecurity1981R-22 $11-1$ 1 EA550 Ton YorkSecurity1981R-22 $12-LL$ 1 EA550 Ton YorkTele & Eqpt. Rm1966R-22 *3 $12-LL$ 1 EA5 Ton CarrierCmmd Cntrl Ctr1978R-22 $12-LL$ 1 EA15 Ton CarrierCommand Wing1976R-22 $12-1-H$ 1 EA10 Ton CarrierCommand Wing1976R-22 $13-1$ 1 EA10 Ton CarrierCmputer Room1983R-22 $13-1$ 1 EA10 Ton CarrierComputer Room1989R-22 $13-1$ 1 EA10 Ton CarrierCmputer Room1984R-22 <t< td=""><td></td><td>1</td><td>100 man Mmana</td><td>OTTE & Sube</td><td>1990</td><td>R-22</td></t<>		1	100 man Mmana	OTTE & Sube	1990	R-22
9-1-F 3 EA 20 TON DateC Computer Room 1990 R-22 9-1-F 4 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Liebert Tele Comm 1991 R-22 9-1-F 1 EA 15 Ton Liebert Tele Comm 1990 R-22 9-1-F 1 EA 15 Ton Liebert Computer Room 1986 R-22 2-C 1 EA 25 Ton Bohn DSAC-W 1980 R-22 9-2-D 1 EA 25 Ton Trane DSAC-W 1985 R-22 9-3E&F 1 EA 25 Ton Trane Medical 1991 R-22 9-4-F 1 EA 25 Ton York Medical 1991 R-22 11-1 1 EA 5 Ton York Medical 1991 R-22 12-LL 1 EA 550 Ton York Entire Bldg 1990 R-11 *1 12-LL 1 EA 5 Ton York Tele & Egpt. Rm 1966 R-22 *3 12-LL 1 EA 5 Ton Carrier Command Wing 1976 R-22 <	9-15%		130 Ton Trane		1987	R-22
9-1-F 4 EA 20 Ton Liebert Computer Room 1990 R-22 9-1-F 1 EA 25 Ton Liebert Tele Comm 1991 R-22 9-1-F 1 EA 15 Ton Liebert Tele Comm 1986 R-22 9-1-F 1 EA 15 Ton Liebert Computer Room 1986 R-22 9-1-F 1 EA 25 Ton Bohn DSAC-W 1980 R-22 9-2-C 1 EA 25 Ton Trane DSAC-W 1985 R-22 9-3E&F 1 EA 140 Ton Carrier Subs & Medical 1991 R-22 9-4-E 1 EA 25 Ton York Medical 1991 R-22 11-1 1 EA 5 Ton York Security 1981 R-22 12-LL 1 EA 5 Ton York Tele & Eqpt. Rm 1966 R-22 *3 12-LL 1 EA 5 Ton York Tele & Eqpt. Rm 1960 R-22 *3 12-LL 1 EA 5 Ton Carrier Cmmad Chtrl Ctr	9-1-F	3 EA	20 Ton Datec	Computer Room	1990	R-22
9-1-F2EA25Ton LiebertComputer Roum1991R-22 $9-1-F$ 1EA20Ton LiebertTele Comm1986R-22 $-1-F$ 1EA15Ton LiebertComputer Room1986R-22 $-2-C$ 1EA25Ton BohnDSAC-W1985R-22 $9-2-D$ 1EA25Ton TraneDSAC-W1985R-22 $9-3E&F$ 1EA25Ton TraneMedical1991R-22 $9-4-F$ 1EA25Ton YorkMedical1991R-22 $9-4-F$ 1EA5Ton YorkMedical1991R-22 $9-4-F$ 1EA5Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkMedical1991R-22 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1960R-22*3 $12-LL$ 1EA15Ton CarrierCmmd Chtrl Ctr1978R-22 $12-LL$ 1EA5Ton LiebertC&T Key Punch1983R-22 $12-LL$ 1EA15Ton CarrierComputer Room1989R-22 $12-LL$ 1EA5Ton CarrierComputer Room1983R-22 $12-LL$ 1EA10Ton CarrierComputer Room <td>9-1-F</td> <td>4 EA</td> <td>20 Ton Liebert</td> <td>Computer Room</td> <td>1000</td> <td>R-22</td>	9-1-F	4 EA	20 Ton Liebert	Computer Room	1000	R-22
9-1-F1EA20Ton LiebertTele Comm1991R-22 $9-1-F$ 1EA15Ton LiebertComputer Room1986R-22 $-2-C$ 1EA25Ton BohnDSAC-W1980R-22 $9-2-D$ 1EA25Ton TraneDSAC-W1985R-22 $9-3E&F$ 1EA140Ton CarrierSubs & Medical1991R-22 $9-4-E$ 1EA25Ton YorkMedical1991R-22 $9-4-F$ 1EA85Ton YorkMedical1991R-22 $9-4-F$ 1EA5Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkSecurity1981R-22 $12-LL$ 1EA5Ton CarrierCmnd Charl Ctr1976R-22 $12-LL$ 1EA15Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA5Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA5Ton CarrierComputer Room1983R-22 $12-LL$	9-1-F	2 EA	25 Ton Liebert	Computer Room	1001	R_22 R_22
a-1-F1EA15Ton LiebertComputer Room1980R-22 $2-2-C$ 1EA25Ton BohnDSAC-W1980R-22 $9-2-D$ 1EA25Ton TraneDSAC-W1985R-22 $9-3E&F$ 1EA140Ton CarrierSubs & Medical1991R-22 $9-4-E$ 1EA25Ton TraneMedical1985R-22 $9-4-F$ 1EA85Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkSecurity1981R-22 $11-1$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA15Ton CarrierCmmand Wing1976R-22 $12-LL$ 1EA15Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA15Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA5Ton LiebertC&T Key Punch1983R-22 $12-LL$ 1EA5Ton CarrierComputer Room1989R-22 $12-LL$ 1EA5Ton CarrierComputer Room1989R-22 $12-LL$ 1EA5Ton CarrierComputer Room <td>9-1-F</td> <td>1 EA</td> <td>20 Ton Liebert</td> <td>Tele Comm</td> <td>1991</td> <td>N-22</td>	9-1-F	1 EA	20 Ton Liebert	Tele Comm	1991	N-22
$-2-C$ 1EA25Ton BohnDSAC-W1980 K^{-22} $9-2-D$ 1EA25Ton TraneDSAC-W1985 $R-22$ $9-3E\&F$ 1EA140Ton CarrierSubs & Medical1991 $R-22$ $9-4-E$ 1EA25Ton TraneMedical1985 $R-22$ $9-4-F$ 1EA85Ton YorkMedical1991 $R-22$ $11-1$ 1EA5Ton YorkMedical1991 $R-22$ $11-1$ 1EA5Ton YorkMedical1991 $R-22$ $12-LL$ 1EA5Ton YorkEntire Bldg1990 $R-11$ $*1$ $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966 $R-22$ $*3$ $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966 $R-22$ $*3$ $12-LL$ 1EA15Ton CarrierCmnd Cntrl Ctr1978 $R-22$ $12-LL$ 1EA15Ton CarrierCommand Wing1976 $R-22$ $12-LL$ 1EA15Ton CarrierCommand Wing1983 $R-22$ $12-2-F$ 1EA5Ton CarrierComputer Room1984 $R-22$ $13-1$ 1EA10Ton CarrierComputer Room1989 $R-22$ $13-1$ 1EA15Ton CarrierComputer Room1989 $R-22$ $13-1$ 1 <td< td=""><td>9-1-F</td><td>1 EA</td><td>15 Ton Liebert</td><td>Computer Room</td><td>1986</td><td>R-22</td></td<>	9-1-F	1 EA	15 Ton Liebert	Computer Room	1986	R-22
9-2-D1EA25Ton TraneDSAC-W1985R-22 $9-3E&F$ 1EA140Ton CarrierSubs & Medical1991R-22 $9-4-E$ 1EA25Ton TraneMedical1985R-22 $9-4-F$ 1EA85Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkMedical1991R-22 $11-1$ 1EA5Ton YorkSecurity1981R-22 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA15Ton CarrierCmnd Cntrl Ctr1978R-22 $12-LL$ 1EA15Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA15Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA10Ton CarrierCommand Wing1976R-22 $12-LL$ 1EA10Ton CarrierComputer Room1983R-22 $12-LL$ 1EA10Ton CarrierCmputer Room1989R-22 $12-1-H$ 1EA10Ton CarrierCmputer Room1989R-22 $13-1$ 1EA1200Ton TraneFa	-2-C	1 EA	25 Ton Bohn	DSAC-W	1980	R-22
9-3E&F1EA140Ton CarrierSubs & Medical1991 $R-22$ $9-4-F$ 1EA25Ton TraneMedical1985 $R-22$ $9-4-F$ 1EA85Ton YorkMedical1991 $R-22$ $11-1$ 1EA5Ton YorkMedical1991 $R-22$ $11-1$ 1EA5Ton YorkSecurity1981 $R-22$ $11-1$ 1EA5Ton YorkEntire Bldg1990 $R-11$ $*1$ $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966 $R-22$ $*3$ $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1960 $R-22$ $*3$ $12-LL$ 1EA15Ton CarrierCmnd Cntrl Ctr1978 $R-22$ $12-LL$ 1EA15Ton CarrierCommand Wing1976 $R-22$ $12-1-H$ 1EA15Ton CarrierCommand Wing1976 $R-22$ $12-2-F$ 1EA10Ton CarrierComputer Room1983 $R-22$ $13-1$ 1EA10Ton CarrierComputer Room1989 $R-22$ $13-1$ 1EA15Ton CarrierComputer Room1989 $R-22$ $13-1$ 1EA15Ton Carrier1987 $R-22$ $14-1$ 1EA15Ton Carrier1987 $R-22$ $14-R$ 1EA15Ton	9-2-D	1 EA	25 Ton Trane	DSAC-W	1985	R-22
9-4-E1EA25Ton Trane NorkMedical1985 Medical $R-22$ $9-4-F$ 1EA85Ton YorkMedical1991 $R-22$ $11-1$ 1EA5Ton YorkSecurity1981 $R-22$ $11-1$ 1EA5Ton YorkSecurity1981 $R-22$ $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1966 $R-22$ *3 $12-LL$ 1EA5Ton YorkTele & Eqpt. Rm1960 $R-22$ *3 $12-LL$ 1EA15Ton CarrierCmnd Cntrl Ctr1978 $R-22$ $12-LL$ 1EA5Ton RundPhoto Lab1985 $R-22$ $12-LL$ 1EA15Ton CarrierCommand Wing1976 $R-22$ $12-1-H$ 1EA10Ton CarrierCommand Wing1976 $R-22$ $12-2-F$ 1EA5Ton CarrierComputer Room1983 $R-22$ $13-1$ 1EA10Ton CarrierComputer Room1989 $R-22$ $13-1$ 1EA15Ton CarrierComputer Room1989 $R-22$ $13-1$ 1EA15Ton Carrier1987 $R-22$ $14-1$ 1EA15Ton Carrier1987 $R-22$ $14-1$ 1EA15Ton Carrier1987 $R-22$ $14-R$ 1EA15Ton Carrier1961 <td>9-3E&F</td> <td>1 EA</td> <td>140 Ton Carrier</td> <td>Subs & Medical</td> <td>1991</td> <td>R-22</td>	9-3E&F	1 EA	140 Ton Carrier	Subs & Medical	1991	R-22
9-4-F1EA85Ton YorkMedical1991 $R-22$ 11-11EA5Ton YorkSecurity1981 $R-22$ 12-LL1EA550Ton YorkEntire Bldg1990 $R-11$ *112-LL1EA5Ton YorkTele & Eqpt. Rm1966 $R-22$ *312-LL1EA3Ton YorkTele & Eqpt. Rm1960 $R-22$ *312-LL1EA15Ton CarrierCmnd Cntrl Ctr1978 $R-22$ 12-LL1EA5Ton CarrierCommand Wing1976 $R-22$ 12-LL1EA15Ton CarrierCommand Wing1976 $R-22$ 12-1-H1EA10Ton CarrierCommand Wing1976 $R-22$ 12-2-F1EA10Ton CarrierCmpt Lay Out Rm1983 $R-22$ 13-11EA10Ton TraneFactory1973 $R-11$ 14-11EA15Ton Carrier1987 $R-22$ 14-R1EA15Ton Carrier1987 $R-22$ 14-R1EA15Ton Carrier1987 $R-22$ 14-R1EA15Ton Carrier1987 $R-22$ 14-R1EA15Ton Trane1987 $R-21$	9-4-E	1 EA	25 Ton Trane	Medical	1985	R-22
11-11 EA5 Ton YorkSecurity1981R-22 $12-LL$ 1 EA550 Ton YorkEntire Bldg1990R-11*1 $12-LL$ 1 EA5 Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1 EA3 Ton YorkTele & Eqpt. Rm1960R-22*3 $12-LL$ 1 EA15 Ton CarrierCmnd Cntrl Ctr1978R-22*3 $12-LL$ 1 EA5 Ton RundPhoto Lab1985R-22*3 $12-1-H$ 1 EA15 Ton CarrierCommand Wing1976R-22*3 $12-2-F$ 1 EA5 Ton LiebertC&T Key Punch1983R-22 $13-1$ 1 EA10 Ton CarrierCmpt Lay Out Rm1984R-22 $13-1$ 1 EA5 Ton CarrierComputer Room1989R-22 $13-1$ 1 EA15 Ton CarrierCmpt Lay Out Rm1989R-21 $13-1$ 1 EA15 Ton CarrierComputer Room1989R-21 $13-1$ 1 EA15 Ton Carrier1987R-21R-11 $14-1$ 1 EA15 Ton Carrier1987R-22 $14-1$ 1 EA15 Ton Carrier1987R-22 $14-1$ 1 EA15 Ton Carrier1987R-21 $14-1$ 1 EA15 Ton Carrier1987R-21 $14-1$ 1 EA15 Ton Carrier1987R-11	9-4-F	1 EA	85 Ton York	Medical	1991	R-22
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	11-1	1 EA	5 Ton York	Security	1981	R-22
12-LL1EA5Ton YorkTele & Eqpt. Rm1966R-22*3 $12-LL$ 1EA3Ton YorkTele & Eqpt. Rm1960R-22*3 $12-LL$ 1EA15Ton CarrierCmnd Cntrl Ctr1978R-22 $12-LL$ 1EA5Ton RundPhoto Lab1985R-22 $12-LL$ 1EA5Ton CarrierCommand Wing1976R-22 $12-1-H$ 1EA15Ton CarrierCommand Wing1976R-22 $12-2-F$ 1EA5Ton LiebertC&T Key Punch1983R-22 $13-1$ 1EA10Ton CarrierCmpt Lay Out Rm1984R-22 $13-1$ 1EA5Ton CarrierComputer Room1989R-22 $13-1$ 1EA1200Ton TraneFactory1973R-11 $14-1$ 1EA15Ton Carrier1987R-22 $14-R$ 1EA130Ton Trane1961R-11	12-11	1 EA	550 Ton York	Entire Bldg	1990	R-11 *1
12-LL 1 EA 3 Ton York Tele & Eqpt. Rm 1960 R-22 *3 12-LL 1 EA 15 Ton Carrier Cmnd Cntrl Ctr 1978 R-22 12-LL 1 EA 5 Ton Rund Photo Lab 1985 R-22 12-LL 1 EA 5 Ton Rund Photo Lab 1985 R-22 12-1-H 1 EA 15 Ton Carrier Command Wing 1976 R-22 12-2-F 1 EA 5 Ton Liebert C&T Key Punch 1983 R-22 13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 15 Ton Trane 1961 R-11	12-LL	1 EA	5 Ton York	Tele & Eqpt. Rm	1966	R-22 *3
12-LL 1 EA 15 Ton Carrier Cmnd Cntrl Ctr 1978 R-22 12-LL 1 EA 5 Ton Rund Photo Lab 1985 R-22 12-LL 1 EA 5 Ton Rund Photo Lab 1985 R-22 12-1-H 1 EA 15 Ton Carrier Command Wing 1976 R-22 12-2-F 1 EA 5 Ton Liebert C&T Key Punch 1983 R-22 13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1961 R-11	12_11	1 52	3 Ton York	Tele & Egot. Rm	1960	R-22 *3
12-LL 1 EA 15 Ton Rund Photo Lab 1985 R-22 12-LL 1 EA 5 Ton Rund Photo Lab 1985 R-22 12-1-H 1 EA 15 Ton Carrier Command Wing 1976 R-22 12-2-F 1 EA 5 Ton Liebert C&T Key Punch 1983 R-22 13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 15 Ton Trane 1961 R-11	10 11	1 57	15 Ton Carrier	Cmnd Cntrl Ctr	1978	R-22
12-LL 1 EA 5 Ton Kund 100 Kund 100 Kund 1976 R-22 12-1-H 1 EA 15 Ton Carrier Command Wing 1976 R-22 12-2-F 1 EA 5 Ton Liebert C&T Key Punch 1983 R-22 13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1961 R-11	12-66		5 Mon Bund	Photo Lab	1985	R-22
12-1-H 1 EA 15 TON Carrier Contained Wing 1983 R-22 12-2-F 1 EA 5 Ton Liebert C&T Key Punch 1983 R-22 13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1961 R-11	12-55	1 EA	15 Man Carrier	Command Wing	1976	R-22
12-2-F 1 EA 5 Ton Liebert Car key Funch 1965 R -22 13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1961 R-11	12-1-H	1 EA	15 Ton Caller	Command wing	1983	R-22
13-1 1 EA 10 Ton Carrier Cmpt Lay Out Rm 1984 R-22 13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1987 R-22	12-2-F	1 EA	5 Ton Liebert	Car Key Punch	1905	
13-1 1 EA 5 Ton Carrier Computer Room 1989 R-22 13-1 1 EA 1200 Ton Trane Factory 1973 R-11 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1987 R-22	13-1	1 EA	10 Ton Carrier	Cmpt Lay Out Rm	1984	R-22
13-1 1 EA 1200 Ton Trane Factory 1973 R-11 (1500 HP) (1500 HP) 1987 R-22 14-1 1 EA 15 Ton Carrier 1987 R-22 14-R 1 EA 130 Ton Trane 1961 R-11	13-1	1 EA	5 Ton Carrier	Computer Room	T 3 8 3	R-22
14-11 EA15 Ton Carrier1987R-2214-R1 EA130 Ton Trane1961R-11	13-1	1 EA	1200 Ton Trane (1500 HP)	Factory	1973	R-11
14-R 1 EA 130 Ton Trane 1961 R-11	14-1	1 EA	15 Ton Carrier		1987	R-22
	14-R	1 EA	130 Ton Trane		1961	R-11

BLDG.	UNITS	TONNAGE	LOCATION USE	INSTALLED	REFRIGE	ERANT
.5	1 EA	250 Ton Wstghse	Entire Building	1973	R-12	*1
15	1 EA	40 Ton Carrier	Ex. Cold Chamb.	1971	R-502	*1
15	1 EA	15 Ton Trane	Textile Room	1968	R-12	*1
15	1 EA	15 Ton Carrier	Textile Room	1978	R-12	*1
15, 2	6 EA	Environ. Boxes	Testing Labs	1978	R-12	*1
15	1 EA	7.5 Ton York	Optics Lab	1966	R-12	*1
15	1 EA	5 Ton Carrier	#1 Environ. Lab	1969	R-12	*1
15	1 EA	7.5 Ton Dunn&Bush	#2 Environ. Lab	1973	R-12	*1
15	1 EA	7.5 Ton Carrier	#3 Environ. Lab	1970	R-12	*1
15	1 EA	5 Ton Trane	Shading Lab	1962	R-1	*1
26-A	1 EA	25 Ton Carrier	Maint. Ft Meade	1984	R-22	
26-A	1 EA	7.5 Ton Carrier	Office	1989	R-22	
26-B	1 EA	5 Ton Rund	Small Arms	1988	R-22	
26-C	1 EA	7.5 Ton Carrier	Salvage	1962	R-22	
26-C	1 EA	3 Ton Carrier	Salvage Offices	1988	R-22	
30-1	1 EA	5 Ton Copeland	Elect. Vault	1962	R-12	*1,3
30-1	1 EA	7.5 Ton Carrier	Garage	1988	R-22	
51	1 EA	20 Ton Trane	M.P./Food Insp.	1989	R-22	

*1 Title VI of the Clean Air Act Amendments of 1990 requires that production of CFC refrigerants be prohibited by 1999.

2 Removed

*3 Not in service

123

Appendix E: BLAST Monthly Building Cooling Loads

DATE	COOLING LO	HOURS MBTU/HR TEMP			CDD	BLDG 06
						ZONE 2
JAN	0.000E+00	0	ERR	31.4	-33.6	
FEB	0.000E+00	0	ERR	33.1	-31.9	
MAR	2.766E+07	44	0.63	43.1	-21.9	
APR	4.488E+07	78	0.58	51.4	-13.6	
MAY	2.324E+08	190	1.22	62.4	-2.6	
JUN	3.749E+08	210	1.79	70.8	5.8	
JUL	4.824E+08	210	2.30	76.3	11.3	
AUG	5.212E+08	230	2.27	74.6	9.6	
SEP	3.017E+08	188	1.60	69.2	4.2	
OCT	1.596E+08	146	1.09	57	-8	
NOV	3.452E+07	64	0.54	45.7	-19.3	
DEC	1.441E+06	5	0.29	36.1	-28.9	
	2.181E+09	1365	1.60			

DATE	COOLING LO	HOURS MBTU/HR TEMP			CDD	REG
JAN	0.000E+00	0	ERR	31.4	-33.6	
FEB	0.000E+00	0	ERR	33.1	-31.9	
MAR	2.766E+07	44	0.63	43.1	-21.9	0.45
APR	4.488E+07	78	0.58	51.4	-13.6	0.87
MAY	2.324E+08	190	1.22	62.4	-2.6	1.42
JUN	3.749E+08	210	1.79	70.8	5.8	1.84
JUL	4.824E+08	210	2.30	76.3	11.3	2.11
AUG	5.212E+08	230	2.27	74.6	9.6	2.03
SEP	3.017E+08	188	1.60	69.2	4.2	1.76
OCT	1.596E+08	146	1.09	57	-8	1.15
NOV	3.452E+07	64	0.54	45.7	-19.3	0.58
DEC	1.441E+06	5	0.29	36.1	-28.9	0.10

Regression	Output:			
Constant	•	1.546868		
Std Err of Y Est		0.197005		
R Squared	(0.935769		
No. of Observations		10		
Degrees of Freedom		8	BASE	VARIABL
			1.547	0.050
X Coefficient(s)	0.049961			
Std Err of Coef.	0.004628			

DATE	COOLING LO	HOURS MBTU/HR TEMP			CDD	BLDG 08
						ZONE 2
JAN	5.335E+05	14	0.04	31.4	-33.6	
FEB	2.020E+05	5	0.04	33.1	-31.9	
MAR	2.859E+07	98	0.29	43.1	-21.9	
APR	5.932E+07	189	0.31	51.4	-13.6	
MAY	1.419E+08	220	0.65	62.4	-2.6	
JUN	1.797E+08	210	0.86	70.8	5.8	
JUL	2.133E+08	210	1.02	76.3	11.3	
AUG	2.294E+08	230	1.00	74.6	9.6	
SEP	1.571E+08	190	0.83	69.2	4.2	
OCT	1.161E+08	208	0.56	57	-8	
NOV	4.615E+07	123	0.38	45.7	-19.3	
DEC	5.962E+06	31	0.19	36.1	- 28.9	
	1.178E+09	1728	0.68			

DATE	COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	REG
JAN	5.335E+05	14	0.04	31.4	-33.6	0.03
FEB	2.020E+05	5	0.04	33.1	-31.9	0.06
MAR	2.859E+07	98	0.29	43.1	-21.9	0.27
APR	5.932E+07	189	0.31	51.4	-13.6	0.45
MAY	1.419E+08	220	0.65	62.4	-2.6	0.69
JUN	1.797E+08	210	0.86	70.8	5.8	0.86
JUL	2.133E+08	210	1.02	76.3	11.3	0.98
AUG	2.294E+08	230	1.00	74.6	9.6	0.95
SEP	1.571E+08	190	0.83	69.2	4.2	0.83
OCT	1.161E+08	208	0.56	57	-8	0.57
NOV	4.615E+07	123	0.38	45.7	-19.3	0.33
DEC	5.962E+06	31	0.19	36.1	-28.9	0.13

Regression (Dutput:			
Constant	0	.741316		
Std Err of Y Est	0	.056633		
R Śquared	0	.976794		
No. of Observations		12		
Degrees of Freedom		10	BASE	VARIABL
U U			0.741	0.021
X Coefficient(s)	0.021298			
Std Err of Coef.	0.001038			

127

DATE	COOLING LO	HOURS N	IBTU/HR T	EMP	CDD	BLDG 09
27112			•			ZONE 2
JAN	2.148E+06	7	0.31	31.4	-33.6	
FEB	5.710E+06	10	0.57	33.1	-31.9	
MAR	1.238E+08	80	1.55	43.1	-21.9	
APR	2.547E+08	156	1.63	51.4	-13.6	
MAY	7.764E+08	215	3.61	62.4	-2.6	
JUN	1.082E+09	210	5.15	70.8	5.8	
JUL	1.299E+09	210	6.19	76.3	11.3	
AUG	1.395E+09	230	6.07	74.6	9.6	
SEP	9.182E+08	190	4.83	69.2	4.2	
OCT	6.102E+08	193	3.16	57	-8	
NOV	1.984E+08	109	1.82	45.7	-19.3	
DEC	1.200E+07	14	0.86	36.1	-28.9	
	6.678E+09	1624	4.11			

DATE	COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	REG
JAN	2.148E+06	7	0.31	31.4	-33.6	0.04
FEB	5.710E+06	10	0.57	33.1	-31.9	0.26
MAR	1.238E+08	80	1.55	43.1	-21.9	1.54
APR	2.547E+08	156	1.63	51.4	-13.6	2.61
MAY	7.764E+08	215	3.61	62.4	-2.6	4.03
JUN	1.082E+09	210	5.15	70.8	5.8	5.11
JUL	1.299E+09	210	6.19	76.3	11.3	5.82
AUG	1.395E+09	230	6.07	74.6	9.6	5.60
SEP	9.182E+08	190	4.83	69.2	4.2	4.90
OCT	6.102E+08	193	3.16	57	-8	3.33
NOV	1.984E+08	109	1.82	45.7	-19.3	1.88
DEC	1.200E+07	14	0.86	36.1	-28.9	0.64
	Regression Out	nut.				

Regression	Output:			
Constant	4.361224	ł		
Std Err of Y Est	0.417566	5		
R Squared	0.965842	2		
No. of Observations	12			
Degrees of Freedom	10)	BASE	VARIABL
0			4.361	0.129
X Coefficient(s)	0.128709			
Std Err of Coef.	0.007654			

DATE	COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	BLDG 11
JAN	1.107E+03	1	0.00	31.4	-33.6	
FEB	3.994E+04	• 5	0.01	33.1	-31.9	
MAR	3.552E+06	64	0.06	43.1	-21.9	
APR	6.754E+06	129	0.05	51.4	-13.6	
MAY	2.116E+07	202	0.10	62.4	-2.6	
JUN	2.923E+07	210	0.14	70.8	5.8	
JUL	3.641E+07	210	0.17	76.3	11.3	
AUG	3.891E+07	230	0,17	74.6	9.6	
SEP	2.391E+07	187	0.13	69.2	4.2	
OCT	1.374E+07	159	0.09	57	-8	
NOV	3.880E+06	80	0.05	45.7	-19.3	
DEC	2.539E+05	13	0.02	36.1	-28.9	
	1.778E+08	1490	0.12			

DATE	COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	REG
JAN	1.107E+03	1	0.00	31.4	33.6	-0.00
FEB	3.994E+04	5	0.01	33.1	-31.9	0.01
MAR	3.552E+06	64	0.06	43.1	-21.9	0.04
APR	6.754E+06	129	0.05	51.4	-13.6	0.07
MAY	2.116E+07	202	0.10	62.4	-2.6	0.11
JUN	2.923E+07	210	0.14	70.8	5.8	0.14
JUL	3.641E+07	210	0.17	76.3	11.3	0.16
AUG	3.891E+07	230	0.17	74.6	9.6	0.16
SEP	2.391E+07	187	0.13	69.2	4.2	0.14
OCT	1.374E+07	159	0.09	57	-8	0.09
NOV	3.880E+06	80	0.05	45.7	-19.3	0.05
DEC	2.539E+05	13	0.02	36.1	-28.9	0.02

Regression (Dutput:			
Constant	•	0.121244		
Std Err of Y Est		0.010291		
R Squared		0.973842		
No. of Observations		12		
Degrees of Freedom		10	BASE	VARIABL
-			0.121	0.004
X Coefficient(s)	0.00364			
Std Err of Coef.	0.000189			

DATE	COOLING LO	HOURSN	IBTU/HR T	EMP	CDD	BLDG 12
JAN	0.000E+00	0	ERR	31.4	-33.6	
FEB	1.796E+05	2	0.09	33.1	-31.9	
MAR	7.524E+07	52	1.45	43.1	-21.9	
APR	1.324E+08	108	1.23	51.4	-13.6	
MAY	4.742E+08	199	2.38	62.4	-2.6	
JUN	6.732E+08	210	3.21	70.8	5.8	
JUL	8.314E+08	210	3.96	76.3	11.3	
AUG	8.953E+08	230	3.89	74.6	9.6	
SEP	5.421E+08	189	2.87	69.2	4.2	
OCT	2.996E+08	152	1.97	57	-8	
NOV	8.100E+07	75	1.08	45.7	-19.3	
DEC	4.594E+06	6	0.77	36.1	-28.9	
	4.009E+09	1433	2.80			

COOLING LO	HOURS N	IBTU/HR T	EMP	CDD	REG
					0.06
1.796E+05	2	0.09	33.1	-31.9	0.20
7.524E+07	52	1.45	43.1	-21.9	1.01
1.324E+08	108	1.23	51.4	-13.6	1.68
4.742E+08	199	2.38	62.4	- 2.6	2.57
6.732E+08	210	3.21	70.8	5.8	3.25
8.314E+08	210	3.96	76.3	11.3	3.70
8.953E+08	230	3.89	74.6	9.6	3.5 6
5.421E+08	189	2.87	69.2	4.2	3.12
2.996E+08	152	1.97	57	-8	2.13
8.100E+07	75	1.08	45.7	-19.3	1.22
4.594E+06	6	0.77	36.1	-28.9	0.44
	COOLING LO 1.796E+05 7.524E+07 1.324E+08 4.742E+08 6.732E+08 8.314E+08 8.953E+08 5.421E+08 2.996E+08 8.100E+07 4.594E+06	COOLING LO HOURS M 1.796E+05 2 7.524E+07 52 1.324E+08 108 4.742E+08 199 6.732E+08 210 8.314E+08 210 8.953E+08 230 5.421E+08 189 2.996E+08 152 8.100E+07 75 4.594E+06 6	COOLING LO HOURS MBTU/HR T 1.796E+05 2 0.09 7.524E+07 52 1.45 1.324E+08 108 1.23 4.742E+08 199 2.38 6.732E+08 210 3.21 8.314E+08 210 3.96 8.953E+08 230 3.89 5.421E+08 189 2.87 2.996E+08 152 1.97 8.100E+07 75 1.08 4.594E+06 6 0.77	COOLING LOHOURS MBTU/HR TEMP1.796E+0520.0933.17.524E+07521.4543.11.324E+081081.2351.44.742E+081992.3862.46.732E+082103.2170.88.314E+082103.9676.38.953E+082303.8974.65.421E+081892.8769.22.996E+081521.97578.100E+07751.0845.74.594E+0660.7736.1	COOLING LOHOURS MBTU/HR TEMPCDD1.796E+0520.0933.1-31.97.524E+07521.4543.1-21.91.324E+081081.2351.4-13.64.742E+081992.3862.4-2.66.732E+082103.2170.85.88.314E+082103.9676.311.38.953E+082303.8974.69.65.421E+081892.8769.24.22.996E+081521.9757-88.100E+07751.0845.7-19.34.594E+0660.7736.1-28.9

Regression (Dutput:			
Constant	2.782408			
Std Err of Y Est	0.306144			
R Squared	0.949269			
No. of Observations	11	-		
Degrees of Freedom	9		BASE	VARIABL
•			2.782	0.081
X Coefficient(s)	0.080992			
Std Err of Coef.	0.006241			

DATE	COOLING LO	HOURS N	IBTU/HR T	EMP	CDD	BLDG 13
JAN	2.371E+07	33	0.72	31.4	-33.6	
FEB	3.266E+07	34	0.96	33.1	-31.9	
MAR	2.550E+08	128	1.99	43.1	-21.9	
APR	4.666E+08	192	2.43	51.4	-13.6	
MAY	9.911E+08	219	4.53	62.4	-2.6	
JUN	1.227E+09	210	5.84	70.8	5.8	
JUL	1.401E+09	210	6.67	76.3	11.3	
AUG	1.506E+09	230	6.55	74.6	9.6	
SEP	1.010E+09	190	5.32	69.2	4.2	
OCT	7.127E+08	203	3.51	57	-8	
NOV	2.902E+08	130	2.23	45.7	-19.3	
DEC	4.400E+07	44	1.00	36.1	-28.9	
	7.960E+09	1823	4.37			

DATE	COOLING LO	HOURS N	IBTU/HR T	EMP	CDD	REG
JAN	2.371E+07	33	0.72	31.4	-33.6	0.41
FEB	3.266E+07	34	0.96	33.1	-31.9	0.64
MAR	2.550E+08	128	1.99	43.1	-21.9	1.98
APR	4.666E+08	192	2.43	51.4	-13.6	3.10
MAY	9.911E+08	219	4.53	62.4	-2.6	4.57
JUN	1.227E+09	210	5.84	70.8	5.8	5.70
JUL	1.401E+09	210	6.67	76.3	11.3	6.44
AUG	1.506E+09	230	6.55	74.6	9.6	6.21
SEP	1.010E+09	190	5.32	69.2	4.2	5.49
OCT	7.127E+08	203	3.51	57	-8	3.85
NOV	2.902E+08	130	2.23	45.7	-19.3	2.33
DEC	4.400E+07	44	1.00	36.1	-28.9	1.04

Regression C	Output:			
Constant		1.921291		
Std Err of Y Est	().313909		
R Squared	(0.981966		
No. of Observations		12		
Degrees of Freedom		10	BASE	VARIABL
-			4.921	0.134
X Coefficient(s)	0.13427			
Std Err of Coef.	0.005754			

DATE	COOLING LO	HOURS N	IBTU/HR T	EMP	CDD	BLDG 14
JAN	3.598E+05	4	0.09	31.4	-33.6	
FEB	5.589E+04	1	0.06	33.1	-31.9	
MAR	4.473E+07	58	0.77	43.1	-21.9	
APR	8.081E+07	110	0.73	51.4	-13.6	
MAY	2.761E+08	198	1.39	62.4	-2.6	
JUN	3.915E+08	210	1.86	70.8	5.8	
JUL	4.846E+08	210	2.31	76.3	11.3	
AUG	5.227E+08	230	2.27	74.6	9.6	
SEP	3.203E+08	188	1.70	69.2	4.2	
OCT	1.850E+08	161	1.15	57	-8	
NOV	5.905E+07	86	0.69	45.7	-19.3	
DEC	3.830E+06	7	0.55	36.1	-28.9	
	2.369E+09	1463	1.62			

COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	REG
3.598E+05	4	0.09	31.4	-33.6	0.07
5.589E+04	1	0.06	33.1	-31.9	0.15
4.473E+07	58	0.77	43.1	-21.9	0.61
8.081E+07	110	0.73	51.4	-13.6	1.00
2.761E+08	198	1.39	62.4	-2.6	1.5 1
3.915E+08	210	1.86	70.8	5.8	1.90
4.846E+08	210	2.31	76.3	11.3	2.15
5.227E+08	230	2.27	74.6	9.6	2.08
3.203E+08	188	1.70	69.2	4.2	1.82
1.850E+08	161	1.15	57	-8	1.26
5.905E+07	86	0.69	45.7	-19.3	0.73
3.830E+06	7	0.55	36.1	-28. 9	0.29
	COOLING LO 3.598E+05 5.589E+04 4.473E+07 8.081E+07 2.761E+08 3.915E+08 4.846E+08 5.227E+08 3.203E+08 1.850E+08 5.905E+07 3.830E+06	COOLING LO HOURS M 3.598E+05 4 5.589E+04 1 4.473E+07 58 8.081E+07 110 2.761E+08 198 3.915E+08 210 4.846E+08 210 5.227E+08 230 3.203E+08 188 1.850E+08 161 5.905E+07 86 3.830E+06 7	COOLING LO HOURS MBTU/HR T 3.598E+05 4 0.09 5.589E+04 1 0.06 4.473E+07 58 0.77 8.081E+07 110 0.73 2.761E+08 198 1.39 3.915E+08 210 1.86 4.846E+08 210 2.31 5.227E+08 230 2.27 3.203E+08 188 1.70 1.850E+08 161 1.15 5.905E+07 86 0.69 3.830E+06 7 0.55	COOLING LOHOURS MBTU/HR TEMP3.598E+0540.0931.45.589E+0410.0633.14.473E+07580.7743.18.081E+071100.7351.42.761E+081981.3962.43.915E+082101.8670.84.846E+082102.3176.35.227E+082302.2774.63.203E+081881.7069.21.850E+081611.15575.905E+07860.6945.73.830E+0670.5536.1	COOLING LOHOURS MBTU/HR TEMPCDD3.598E+0540.0931.4-33.65.589E+0410.0633.1-31.94.473E+07580.7743.1-21.98.081E+071100.7351.4-13.62.761E+081981.3962.4-2.63.915E+082101.8670.85.84.846E+082102.3176.311.35.227E+082302.2774.69.63.203E+081881.7069.24.21.850E+081611.1557-85.905E+07860.6945.7-19.33.830E+0670.5536.1-28.9

Regression	Output:	
Constant	1.630002	
Std Err of Y Est	0.166205	
R Squared	0.958694	
No. of Observations	12	
Degrees of Freedom	10	BASE VARIABL 1.630 0.046
X Coefficient(s)	0.046414	
Std Err of Coef.	0.003047	

DATE	COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	BLDG 15
JAN	8.527E+07	180	0.47	31.4	-33.6	
FEB	9.134E+07	176	0.52	33.1	-31.9	
MAR	1.883E+08	238	0.79	43.1	-21.9	
APR	2.319E+08	246	0.94	51.4	-13.6	
MAY	3.426E+08	362	0.95	62.4	-2.6	
JUN	4.087E+08	554	0.74	70.8	5.8	
JUL	4.704E+08	693	0.68	76.3	11.3	
AUG	4.871E+08	669	0.73	74.6	9.6	
SEP	3.503E+08	491	0.71	69.2	4.2	
OCT	2.865E+08	296	Ò.97	57	-8	
NOV	1.812E+08	216	0.84	45.7	-19.3	
DEC	1.005E+08	193	0.52	36.1	-28.9	
	3.224E+09	4314	0.75			

COOLING LO	HOURS M	IBTU/HR T	EMP	CDD	REG
8.527E+07	180	0.47	31.4	-33.6	0.64
9.134E+07	176	0.52	33.1	-31.9	0.65
1.883E+08	238	0.79	43.1	-21.9	0.69
2.319E+08	246	0.94	51.4	-13.6	0.73
3.426E+08	362	0.95	62.4	-2.6	0.77
4.087E+08	554	0.74	70.8	5.8	0.81
4.704E+08	693	0.68	76.3	11.3	0.83
4.871E+08	669	0.73	74.6	9.6	0.83
3.503E+08	491	0.71	69.2	4.2	0.80
2.865E+08	296	0.97	57	-8	0.75
1.812E+08	216	0.84	45.7	-19.3	0.70
1.005E+08	193	0.52	36.1	-28.9	0.66
	COOLING LO 8.527E+07 9.134E+07 1.883E+08 2.319E+08 3.426E+08 4.087E+08 4.704E+08 4.871E+08 3.503E+08 2.865E+08 1.812E+08 1.005E+08	COOLING LO HOURS M 8.527E+07 180 9.134E+07 176 1.883E+08 238 2.319E+08 246 3.426E+08 362 4.087E+08 554 4.704E+08 693 4.871E+08 669 3.503E+08 491 2.865E+08 296 1.812E+08 216 1.005E+08 193	COOLING LO HOURS MBTU/HR T 8.527E+07 180 0.47 9.134E+07 176 0.52 1.883E+08 238 0.79 2.319E+08 246 0.94 3.426E+08 362 0.95 4.087E+08 554 0.74 4.704E+08 693 0.68 4.871E+08 669 0.73 3.503E+08 491 0.71 2.865E+08 296 0.97 1.812E+08 216 0.84 1.005E+08 193 0.52	COOLING LO HOURS MBTU/HR TEMP 8.527E+07 180 0.47 31.4 9.134E+07 176 0.52 33.1 1.883E+08 238 0.79 43.1 2.319E+08 246 0.94 51.4 3.426E+08 362 0.95 62.4 4.087E+08 554 0.74 70.8 4.704E+08 693 0.68 76.3 4.871E+08 669 0.73 74.6 3.503E+08 491 0.71 69.2 2.865E+08 296 0.97 57 1.812E+08 216 0.84 45.7 1.005E+08 193 0.52 36.1	COOLING LOHOURS MBTU/HR TEMPCDD8.527E+071800.4731.4-33.69.134E+071760.5233.1-31.91.883E+082380.7943.1-21.92.319E+082460.9451.4-13.63.426E+083620.9562.4-2.64.087E+085540.7470.85.84.704E+086930.6876.311.34.871E+086690.7374.69.63.503E+084910.7169.24.22.865E+082960.9757-81.812E+082160.8445.7-19.31.005E+081930.5236.1-28.9

Regression O	Putput:	
Constant	0.785233	
Std-Err of Y Est	0.162294	
R Squared	0.177978	
No. of Observations	12	
Degrees of Freedom	10	BASE VARIABL
-		0.785 0.004
X Coefficient(s)	0.004377	
Std Err of Coef.	0.002975	

133

Appendix F: Life Cycle Cost Analyses

CONCEPTUAL COST ESTIMATE

		QUANTITY		LABOR & MATERIAL	
CODE	ITEM DESCRIPTION				
NO.	이 물건물 방법을 많이 많이 많이 많이 많이 많이 많이 있다. 물건물	NO.	UNIT	\$ PER	
	그렇게 비슷한 지수는 것 같아. 나는 것 같아. 가는 것 같아요. 이렇게 나는 것 같아.	UNITS	MEAS.	UNIT	TOTAL
	ALTERNATIVE # 1				
	DEMOLITION				
	BOILERS NO. 1,2,3,&4	4	EA	\$30,000.00	\$120,000
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS		\$100,000
	PIPING		LS		\$5,000
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000
	ASBESTOS ABATEMENT		LS		\$500,000
	NEW CONSTRUCTION				
			LS	_	\$50,000
	REMOVE AND MODIL T DOLENO GOL ENTERTEIT	2	EA	\$490,000.00	\$980,000
	ECONOMIZERS	2	EA	\$25,000.00	\$50,000
	BOILER FEED PUMPS 15 HP 81 GPM 404FT	3	EA	\$12,000.00	\$38,000
	STEEL STACK 24" DIA 60' HIGH	2	EA	\$10,000.00	\$20,000
	PIPING VALVES HANGERS AND INSTALLATION		LS		\$60,000
	INSTRUMENTS AND CONTROLS		LS		\$150,000
			LS		\$75,000
	MOTOR CONTROL CENTER		LS		\$40,000
	MISC ELECTRICAL AND LIGHTING		LS		\$50,000
	AIBHEATER	1	EA	\$5,463.00	\$5,463
	AIB BECEIVER	1	EA	\$382.00	\$382
	SWITCH GEAR	1	EA	\$75,969.00	\$75,969
	CONDENSATE RECEIVER	1	EA	\$35,700.00	\$35,700
	EXPANSION TANK	1	EA	\$19,444.00	\$19,444
. *	WATER STORAGE TANK	1	EA	\$17,595.00	\$17,595
	ABOVE GROUND TANK	1	EA	\$156,442.00	\$156,442
	BELOW GROUND TANK	1	EA	\$108,375.00	\$108,375
	FLASH TANK	1	EA	\$1,706.00	\$1,706
					\$2,727,076
					\$409.061
					\$470.421
	PROFIT			-	\$313,614
	FNORT				
	TOTAL				\$3,920,172
	PROBABLE COST USE				\$3,920,000

PRICES INCLUDE ESCALATION TO DATE X PRICES ARE AS OF DATE OF THIS ESTIMATE
ESTIMATOR: G.B.BLAZEK 12/1/92
CHECKER: D.R.DRAKE 12/1/92
CONST. MGR.:



SHEET 1 OF 11

CONCEPTUAL COST ESTIMATE

			QUANTITY		LABOR & MATERIAL	
CODE NO.	ITEM DESCRIPTION	NO. UNITS	UNIT MEAS.	\$ PER UNIT	TOTAL	
	ALTERNATIVE # 2 - ONE ENGINE (OPTION 1)					
	BOILERS NO. 1.2.3.&4	4	EA	\$30,000.00	\$120,000	
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000	
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS		\$100,000	
	PIPING		LS		\$5,000	
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000	
	ASBESTOS ABATEMENT		LS		\$500,000	
	NEW CONSTRUCTION					
			1.5		\$50.000	
	ROULER 50 000 #/ HB	2	EA	\$490.000.00	\$980,000	
	ECONOMIZERS	2	EA	\$25,000.00	\$50,000	
	BOILER FEED PUMPS .15 HP. 81 GPM.404FT.	3	EA	\$12,000.00	\$36,000	
	STEEL STACK. 24" DIA. 60' HIGH	2	EA	\$10,000.00	\$20,000	
	PIPING, VALVES, HANGERS, AND INSTALLATION		LS		\$60,000	
	INSTRUMENTS AND CONTROLS		LS		\$150,000	
	CONDUIT AND CABLE		LS		\$75,000	
	MOTOR CONTROL CENTER		LS		\$40,000	
	MISC. ELECTRICAL AND LIGHTING		LS		\$50,000	
	GAS ENGINES AND INSTALLATION	1	EA		\$1,740,000	
	GENERATOR AND INSTALLATION	1	EA	\$241,500.00	\$241,500	
	AUXILIARIES AND INSTALLATION	1	EA	\$264,500.00	\$264,500	
	HEAT RECOVERY STEAM GENERATOR AND INSTALLATION	1	EA	\$160,000.00	\$160,000	
	AIR HEATER	1	EA	\$5,463.00	\$5,463	
ļ	AIR RECEIVER	1	EA	\$382.00	\$382	
	SWITCH GEAR		EA	\$75,969.00	\$75,969	
			EA	\$35,700.00	\$35,700	
1				\$18,444.00	\$18,444	
	WATER STORAGE TANK			\$158.442.00	\$158.442	
		. 1	FA	\$108 375 00	\$108,375	
	FLASH TANK	1	EA	\$1,706.00	\$1,706	
	SUBTOTAL	;			\$5,133,076	
	UNDEVELOPED DESIGN DETAILS				\$769,961	
	OVERHEAD	;			\$885,456	
	PROFIT				\$590,304 	
	TOTAL				\$7,378,797	
	PROBABLE COST USE				\$7,379,000	

PRICES INCLUDE ESCALATION TO			DATE
X PRICES ARE AS OF DATE OF THIS ESTIMATE			
	ESTIMATOR:	G.B.BLAZEK	12/1/92
	CHECKER:	D.R.DRAKE	12/1/92
	CONST. MGR.:		

STANLEY CONSULTANTS

SHEET 2 OF 11

DATE

SHEET 3 OF 11

PROJECT: MECHANICAL STUDY LOCATION: CERL-DPSC STUDY JOB NO.: 10838-07-652

CONCEPTUAL COST ESTIMATE

		QUANTITY		LABOR & MATERIAL	
CODE	ITEM DESCRIPTION				
NO		NO.	UNIT	\$ PER	
<i>N</i> U.	그렇다 같아요. 잘 주는 것은 것은 것은 것은 것은 것을 하는 것을 수 없는 것을 수 없는 것을 수 없다.	UNITS	MEAS.	UNIT	TOTAL
	ALTERNATIVE # 2 - TWO ENGINE (OFTION 2)				
	DEMOLITION				
	BOILERS NO. 1.2.3.&4	4	EA	\$30,000.00	\$ 120,00 0
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS		\$100,000
	PIPING		LS		\$5,000
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000
	ASBESTOS ABATEMENT		LS		\$ 500,00 0
	NEW CONSTRUCTION				
			15		\$ 50,00 0
	REMOVE AND MODIFY BOILER 5 SUPERHEATER		EA	\$490,000.00	\$980,000
	BOILEH, 50,000 #/ HH	2	EA	\$25,000.00	\$50,000
		3	EA	\$12,000.00	\$36,000
	BUILEN FEED FUMPS, 15 MF, 61 GFM,404F1.	2	EA	\$10,000.00	\$20,00 0
	DIDING VALVES HANGERS AND INSTALLATION		LS		\$60,00 0
	INSTRUMENTS AND CONTROLS		LS		\$150,00 0
	CONDUIT AND CABLE		LS		\$75,000
	MOTOR CONTROL CENTER		LS		\$ 40,000
	MISC. ELECTRICAL AND LIGHTING		LS		\$50,000
	GAS ENGINES AND INSTALLATION	2	EA		\$3,480,000
	GENERATOR AND INSTALLATION	2	EA	\$241,500.00	\$483,000
	AUXILIARIES AND INSTALLATION	2	EA	\$264,500.00	\$529,000
	HEAT RECOVERY STEAM GENERATOR AND INSTALLATION	2	EA	\$160,000.00	\$320,000
	AIR HEATER	1	EA	\$5,463.00	\$5,463
	AIR RECEIVER	1	EA	\$382.00	\$382
	SWITCH GEAR	1	EA	\$75,969.00	\$75,969
	CONDENSATE RECEIVER	1	EA	\$35,700.00	\$35,700
	EXPANSION TANK	1	EA	\$19,444.00	\$18,444
1 I	WATER STORAGE TANK	1	EA	\$17,595.00	080,116
	ABOVE GROUND TANK	1	EA	\$158,442.00	3100,44%
	BELOW GROUND TANK	1	EA CA	\$108,3/5.00	\$106,373 \$1704
	FLASH TANK	1	CA	\$1,700.00	
	SUBTOTAL				\$7,539,076
	UNDEVELOPED DESIGN DETAILS				\$1,130,861
	OVERHEAD				\$1,300,491
	PROFIT				\$866,994
	TOTAL				\$10,837,422
	PBOBABLE COST USE				\$10,837,00 0
				l_	

PRICES INCLUDE ESCALATION TO X PRICES ARE AS OF DATE OF THIS ESTIMATE

DATE

ESTIMATOR: G.B.BLAZEK CHECKER: D.R.DRAKE CONST. MGR.: 12/1/92 12/1/92

STANLEY CONSULTANTS

CONCEPTUAL COST ESTIMATE

	statu (1996) (kardu sebe	그는 그는 것이 가지 않는 것이 같이 많이 많이 가지 않는 것이 있는 것이 없는 것이 없다.	LABOR & MATERIAL	
NO. UNITS	UNIT MEAS.	\$ PER UNIT	TOTAL	
4 4 	EA EA LS LS LS LS	\$30,000.00 \$5,000.00 	\$120,000 \$20,000 \$100,000 \$5,000 \$50,000 \$500,000	
 2 2 3 2 1 1 1 1 1 1 1 1 1 1 1 1 1	LS EA EA LS LS LS EA EA EA EA EA EA EA	\$490,000.00 \$25,000.00 \$10,000.00 \$10,000.00 \$10,000.00 \$5,463.00 \$382.00 \$35,700.00 \$19,444.00 \$17,595.00 \$158,442.00 \$108,375.00 \$108,375.00	\$50,000 \$980,000 \$50,000 \$20,000 \$150,000 \$150,000 \$150,000 \$1,020,000 \$68,400 \$1,020,000 \$68,400 \$1,020,000 \$68,400 \$1,020,000 \$1,020,000 \$1,020,000 \$1,020,000 \$1,020,000 \$1,020,000 \$1,020,000 \$3,975,476 \$596,321 \$685,770 \$457,180 \$5,714,747 \$5,715,000	
	4 4 4 4 	4 EA 4 EA 4 EA 4 EA LS LS LS LS 2 EA 1 EA 1	4 EA \$30,000.00 4 EA \$5,000.00 LS LS LS LS LS LS LS LS LS 2 EA \$490,000.00 2 EA \$10,000.00 LS LS LS LS LS LS 1 EA \$160,000.00 1 EA \$155,463.00	

DATE PRICES INCLUDE ESCALATION TO X PRICES ARE AS OF DATE OF THIS ESTIMATE ESTIMATOR: G.B.BLAZEK 12/8/92 CHECKER: D.R.DRAKE 12/8/92 CONST. MGR.:



SHEET 4 OF 11

SHEET 5 OF 11

PROJECT: MECHANICAL STUDY LOCATION: CERL-DPSC STUDY JOB NO.: 10838-07-652

CONCEPTUAL COST ESTIMATE

0005		QUANTITY		LABOR & MATERIAL	
NO.	TEM DESCHIFTION	NO. UNITS	UNIT MEAS.	\$ PER UNIT	TOTAL
	(۲۲۰۵۵ 4) ALTERNATIVE # 2 - TWO 1100 KW GAS TURBINES				
	DEMOLITION BOILERS NO. 1,2,3,&4 TURBINE DRIVEN BOILER FEED PUMP COAL AND ASH SILOS,CONVEYORS AND EQUIPMENT PIPING ELECTRICAL INSTRUMENT AND CONTROL ASBESTOS ABATEMENT NEW CONSTRUCTION	4	EA EA LS LS LS LS	\$30,000.00 \$5,000.00 	\$120,000 \$20,000 \$100,000 \$5,000 \$50,000 \$500,000
	REMOVE AND MODIFY BOILER 5 SUPERHEATER BOILER, 50,000 #/ HR ECONOMIZERS BOILER FEED PUMPS, 15 HP, 81 GPM,404FT. STEEL STACK, 24* DIA. 60' HIGH PIPING, VALVES, HANGERS, AND INSTALLATION INSTRUMENTS AND CONTROLS CONDUIT AND CABLE MOTOR CONTROL CENTER MISC. ELECTRICAL AND LIGHTING GAS TURBINE, GENERATOR AND INSTALLATION (2 EA) WATER INJECTION HEAT RECOVERY STEAM GENERATOR AND INSTALLATION AIR HEATER AIR RECEIVER SWITCH GEAR CONDENSATE RECEIVER EXPANSION TANK WATER STORAGE TANK ABOVE GROUND TANK BELOW GROUND TANK FLASH TANK SUBTOTAL UNDEVELOPED DESIGN DETAILS OVERHEAD PROFIT	2 2 3 2 	LS EA EA EA LS LS LS LS EA EA EA EA EA EA EA	\$490,000.00 \$25,000.00 \$12,000.00 \$10,000.00 \$10,000.00 \$160,000.00 \$160,000.00 \$160,000.00 \$382.00 \$75,969.00 \$35,700.00 \$19,444.00 \$17,595.00 \$156,442.00 \$108,375.00 \$108,375.00	\$50,000 \$980,000 \$38,000 \$20,000 \$150,000 \$150,000 \$150,000 \$150,000 \$2,040,000 \$136,800 \$320,000 \$324,000 \$136,800 \$322,040,000 \$136,800 \$322,040,000 \$136,800 \$325,463 \$382 \$75,969 \$35,700 \$19,444 \$17,595 \$156,442 \$108,375 \$156,442 \$108,375 \$156,442 \$108,375 \$1,706 \$5,223,876 \$783,581 \$9901,119 \$600,746 \$7,509,322
	PROBABLE COST USE				\$7,509,000

PRICES INCLUDE ESCALATION TO X PRICES ARE AS OF DATE OF THIS ESTIMATE DATE

ESTIMATOR: G.B.BLAZEK 12/8/92 CHECKER: D.R.DRAKE 12/8/92 CONST. MGR.:

CONCEPTUAL COST ESTIMATE

		QUANTITY		LABOR & MATERIAL	
CODE	ITEM DESCRIPTION				
NO.		NO.	UNIT	\$ PER	
		UNITS	MFAS		TOTAL
	(DETIAN C)	Cime			
	ALTERNATIVE # 2 - THREE 1100 KW GAS TURBINES				
	DEMOLITION				
	BOILERS NO. 1,2,3,&4	4	EA	\$30,000.00	\$120,000
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS		\$100,000
	PIPING		LS		\$5,000
•	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000
	ASBESTOS ABATEMENT		LS		\$500,000
	NEW CONSTRUCTION				
	REMOVE AND MODIFY BOILER 5 SUPERHEATER		LS		\$50,000
	BOILER, 50,000 #/ HR	2	EA	\$490,000.00	\$980,000
	ECONOMIZERS	2	EA	\$25,000.00	\$50,000
	BOILER FEED PUMPS ,15 HP, 81 GPM,404FT.	3	EA	\$12,000.00	\$36,000
	STEEL STACK, 24" DIA. 60' HIGH	2	EA	\$10,000.00	\$20,000
	PIPING, VALVES, HANGERS, AND INSTALLATION		LS		\$60,000
	INSTRUMENTS AND CONTROLS		LS		\$150,000
	CONDUIT AND CABLE				\$75,000
	MOTOR CONTROL CENTER				\$40,000
	MISC. ELECTRICAL AND LIGHTING				\$50,000
	GAS TURBINE, GENERATOR AND INSTALLATION (3EA)			*c9 400 00	\$3,000,000
	WATER INJECTION	3		\$68,400.00	\$205,200
	AID HEATED	3		\$100,000.00	\$480,000
				\$3,403.00	\$202
		1	EA	\$75,969,00	\$75 969
			EA	\$75,303.00	\$35,303
		1	EA EA	\$19,444,00	\$35,700
	WATER STORAGE TANK	1	EA I	\$17,595,00	\$17,595
	ABOVE GBOUND TANK	1	FA	\$156 442 00	\$156.442
	BELOW GROUND TANK	1	FA	\$108,375.00	\$108,375
	ELASH TANK	1	EA	\$1,706.00	\$1,706
				•	
	SUBTOTAL				\$6,472,276
	UNDEVELOPED DESIGN DETAILS				\$970,841
	OVERHEAD				\$1,116,468
	PROFIT	~		ĺ	\$744,312
	с.				
	TOTAL				\$9,303,897
					to 204 000
	PRODADLE CUSI USE		Ì		\$8,304,000

PRICES INCLUDE ESCALATION TO

X PRICES ARE AS OF DATE OF THIS ESTIMATE

ESTIMATOR: G.B.BLAZEK CHECKER: D.R.DRAKE CONST. MGR.: DATE

12/8/92 12/8/92 SHEET 6 OF 11

SHEET 7 OF 11

PROJECT: MECHANICAL STUDY LOCATION: CERL-DPSC STUDY JOB NO.: 10838-07-652

CONCEPTUAL COST ESTIMATE

		QUANTITY		LABOR & MATERIAL	
CODE NO.	ITEM DESCRIPTION	NO. UNITS	UNIT MEAS.	\$ PER UNIT	TOTAL
	کار کار کار کار کار کار کار کار کار کار 			_	
	DEMOLITION				
	BOILERS NO. 1,2,3,&4	4	EA	\$30,000.00	\$120,000
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS	—	\$100,000
	PIPING		LS		\$5,000
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000
	ASBESTOS ABATEMENT		LS	—	\$500,000
	NEW CONSTRUCTION				
			LS		\$50,000
		2	EA	\$490.000.00	\$980,000
1	ECONOMIZEBS	2	EA	\$25,000.00	\$50,000
	BOILEB FEED PUMPS 15 HP 81 GPM 404FT.	3	EA	\$12,000.00	\$36,000
	STEEL STACK 24" DIA 60' HIGH	2	EA	\$10,000.00	\$20,000
	PIPING, VALVES, HANGERS, AND INSTALLATION		LS		\$60,000
	INSTRUMENTS AND CONTROLS		LS		\$150,000
	CONDUIT AND CABLE		LS		\$75,000
	MOTOR CONTROL CENTER	[]	LS		\$40,00 0
1	MISC. ELECTRICAL AND LIGHTING	_	LS		\$50,000
	GAS TURBINE, GENERATOR AND INSTALLATION		LS	—	\$ 1,800,00 0
	WATER INJECTION	1	EA	\$122,725.00	\$122,725
	HEAT RECOVERY STEAM GENERATOR AND INSTALLATION	1	EA	\$300,000.00	\$300,00 0
	AIR HEATER	1	EA	\$5,463.00	\$ 5,46 3
	AIR RECEIVER	1	EA	\$382.00	\$382
	SWITCH GEAR	1	EA	\$75,969.00	\$75,969
	CONDENSATE RECEIVER	1	EA	\$35,700.00	\$35,700
	EXPANSION TANK	1	EA	\$19,444.00	\$19,444
]	WATER STORAGE TANK	1	EA	\$17,595.00	\$17,595
	ABOVE GROUND TANK	1	EA	\$156,442.00	\$156,442
	BELOW GROUND TANK	1	EA	\$108,375.00	\$108,375
	FLASH TANK	1	EA	\$1,708.00	\$1,706
	SUBTOTAL				\$4,949,801
	UNDEVELOPED DESIGN DETAILS				\$742,470
	OVERHEAD				\$853,841
	PROFIT	-			\$569,227
	TOTAL				\$7,115,339
	PROBABLE COST USE				\$7 ,115,00 0

PRICES INCLUDE ESCALATION TO X PRICES ARE AS OF DATE OF THIS ESTIMATE

DATE

ESTIMATOR: G.B.BLAZEK 12/8/92 CHECKER: D.R.DRAKE 12/8/92 CONST. MGR.:

STANLEY CONSULTANTS

CONCEPTUAL COST ESTIMATE

			QUANTITY		LABOR & MATERIAL	
CODE	ITEM DESCRIPTION			* 0C0		
NO.		UNITS	MEAS.	S PER UNIT	TOTAL	
	ALTERNATIVE # 3					
	DEMOLITION	·				
	BOILERS NO. 1,2,3,&4	4	EA	\$30,000.00	\$120,000	
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000	
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS		\$100,000	
	PIPING		LS		\$5,000	
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000	
	ASBESTOS ABATEMENT		LS		\$500,000	
	CENTRIFUGAL CHILLER 1200 TON		LS		\$40,000	
	NEW CONSTRUCTION					
	REMOVE AND MODIFY BOILER 5 SUPERHEATER	·	LS		\$50,000	
	BOILER, 50,000 #/ HR	2	EA	\$490,000.00	\$980,000	
	ECONOMIZERS	2	EA	\$25,000.00	\$50,000	
	BOILER FEED PUMPS, 15 HP, 81 GPM, 404FT.	3	EA	\$12,000.00	\$36,000	
	STEEL STACK, 24" DIA. 60' HIGH	2	EA	\$10,000.00	\$20,000	
	PIPING, VALVES, HANGERS, AND INSTALLATION		LS		\$ 60,000	
	INSTRUMENTS AND CONTROLS		LS		\$150,000	
	CONDUIT AND CABLE		LS		\$75,000	
	MOTOR CONTROL CENTER		LS		\$40,000	
	MISC. ELECTRICAL AND LIGHTING		LS		\$50,000	
	AIR HEATER	1	EA	\$5,463.00	\$5,463	
	AIR RECEIVER	1	EA	\$382.00	\$382	
	SWITCH GEAR	1	EA	\$75,969.00	\$75,969	
	CONDENSATE RECEIVER	1	EA	\$35,700.00	\$35,700	
	EXPANSION TANK	1	EA	\$19,444.00	\$19,444	
	WATER STORAGE TANK		EA	\$17,595.00	\$17,595	
	ABOVE GROUND TANK		EA	\$156,442.00	\$156,442	
	BELOW GROUND TANK		EA	\$108,375.00	\$108,375	
	FLASH TANK		EA	\$1,708.00	\$1,708	
	ABSORPTION CHILLER 1200 TON		EA EA	\$458,000.00	\$458,000 \$99,000	
				\$29,000,00	\$58,000	
	COOLING TOWER POMP 4800 GPM, 70 TDH, 150 HP	2	10	\$28,000.00	\$50,000	
			L3 EA		\$3 480 000	
		2	EA	\$241 500 00	\$483,000	
		2	EA	\$284 500.00	\$529,000	
	HEAT RECOVERY STEAM GENERATOR AND INSTALLATION	2	EA	\$160,000.00	\$320,000	
					to 000 070	
	SUBTOTAL				30,232,070 \$1,004.911	
1	UNDEVELOPED DESIGN DETAILS				91,234,811 \$1,400,000	
1	OVERHEAD				\$1,420,033 \$048,690	
	PHOFII				4940,009 	
	TOTAL				\$11,833,609	
	PROBABLE COST USE				\$11,834,000	

PRICES INCLUDE ESCALATION TO

X PRICES ARE AS OF DATE OF THIS ESTIMATE

DATE

ESTIMATOR: G.B.BLAZEK CHECKER: D.R.DRAKE CONST. M 3R.: 12/1/92 12/1/92 143

SHEET 8 OF 11

STANLEY CONSULTANTS

SHEET 9 OF 11

PROJECT: MECHANICAL STUDY LOCATION: CERL-DPSC STUDY JOB NO.: 10838-07-652

С	ON	CEP	TUAL	COST	EST	'IMAT	Έ
---	-----------	-----	------	------	-----	-------	---

		QUANT	ΊΤΥ	LABOR &	MATERIAL
CODE	ITEM DESCRIPTION				
NO.		NO.	UNIT	\$ PER	
		UNITS	MEAS.	UNIT	TOTAL
	ALTERNATIVE # 4				
	BOILERS NO. 142	2	FA	\$30,000,00	\$60.000
		4	EA	\$5,000.00	\$20,000
1	COAL AND ASH SILOS CONVEYORS AND EQUIPMENT		LS		\$100,000
· · ·	PIPING		LS		\$5,000
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000
	ASBESTOS ABATEMENT		LS		\$350,000
	REMOVE AND MODIFY BOILER 5 SUPERHEATER		LS		\$50,000
	BOILER, 10,000 #/ HR	1	EA	\$90,000.00	\$90,000
	SUMMER BOILER FEED PUMP 21 GPM, 404' TDH, 5 HP	1	EA	\$9,100.00	\$9,100
	BOILER FEED PUMPS , 15 HP, 81 GPM, 404FT.	3	EA	\$12,000.00	\$36,000
	PIPING, VALVES, HANGERS, AND INSTALLATION		LS		\$30,000
ĺ	INSTRUMENTS AND CONTROLS		LS		\$75,000
	CONDUIT AND CABLE		LS		\$50,000
	MOTOR CONTROL CENTER		LS		\$40,000
	MISC. ELECTRICAL AND LIGHTING		LS		\$50,000
	AIR HEATER	1	EA	\$5,463.00	\$5,463
	AIR RECEIVER	1	EA	\$382.00	\$382
[SWITCH GEAR	1	EA	\$75,969.00	\$75,969
	CONDENSATE RECEIVER	1	EA	\$35,700.00	\$35,700
	EXPANSION TANK	1	EA	\$19,444.00	\$19,444
	WATER STORAGE TANK	1	EA	\$17,595.00	\$17,595
	ABOVE GROUND TANK	1	EA	\$156,442.00	\$156,442
	BELOW GROUND TANK	1	EA	\$108,375.00	\$108,375
	FLASH TANK	1	EA	\$1,706.00	\$1,706
	REMOVE & MODIFY BOILER NO.3 SUPERHEATER & BURNER	1	EA	\$135,000.00	\$135,000
	REMOVE & MODIFY BOILER NO.4 SUPERHEATER & BURNER	1	EA	\$135,000.00	\$135,000
	SUBTOTAL				\$1,706,176
	UNDEVELOPED DESIGN DETAILS		[\$255.926
	OVERHEAD				\$294.315
	PROFIT	ľ			\$196,210
	TOTAL				\$2,452,628
	PROBABLE COST USE				\$2,453,000

PRICES INCLUDE ESCALATION TO X PRICES ARE AS OF DATE OF THIS ESTIMATE

	DATE	
		
G.B.BLAZEK	12/1/92	
D.R.DRAKE	12/1/92	
	G.B.BLAZEK D.R.DRAKE	

.
PROJECT: MECHANICAL STUDY LOCATION: CERL-DPSC STUDY JOB NO.: 10838-07-652

CONCEPTUAL COST ESTIMATE

		QUANTI	QUANTITY		LABOR & MATERIAL	
CODE NO.	ITEM DESCRIPTION	NO. UNITS	UNIT MEAS.	\$ PER UNIT	TOTAL	
	ALTERNATIVE # 5					
	DEMOLITION BOILERS NO. 1&2 TURBINE DRIVEN BOILER FEED PUMP COAL AND ASH SILOS,CONVEYORS AND EQUIPMENT PIPING ELECTRICAL INSTRUMENT AND CONTROL ASBESTOS ABATEMENT	2 4 —— ——	EA EA LS LS LS LS	\$30,000.00 \$5,000.00 	\$60,000 \$20,000 \$100,000 \$5,000 \$50,000 \$350,000	
	NEW CONSTRUCTION					
	REMOVE AND MODIFY BOILER 5 SUPERHEATER BOILER, 10,000 #/ HR SUMMER BOILER FEED PUMP 21 GPM, 404' TDH, 5 HP BOILER FEED PUMPS, 15 HP, 81 GPM,404FT. PIPING, VALVES, HANGERS, AND INSTALLATION INSTRUMENTS AND CONTROLS CONDUIT AND CABLE MOTOR CONTROL CENTER MISC. ELECTRICAL AND LIGHTING AIR HEATER AIR RECEIVER SWITCH GEAR CONDENSATE RECEIVER EXPANSION TANK WATER STORAGE TANK ABOVE GROUND TANK BELOW GROUND TANK FLASH TANK REMOVE & MODIFY BOILER NO.3 SUPERHEATER & BURNER REMOVE & MODIFY BOILER NO.4 SUPERHEATER & BURNER GAS ENGINES AND INSTALLATION GENERATOR AND INSTALLATION MEAT RECOVERY STEAM GENERATOR AND INSTALLATION SUBTOTAL UNDEVELOPED DESIGN DETAILS OVERHEAD	1 1 3 	LS EA EA LS LS LS EA EA EA EA EA EA EA EA EA EA EA EA EA	\$90,000,00 \$9,100,00 \$12,000,00 \$12,000,00 \$12,000,00 \$35,700,00 \$382,00 \$75,969,00 \$35,700,00 \$19,444,00 \$17,595,00 \$156,442,00 \$108,375,00 \$135,000,00 \$135,000,00 \$135,000,00 \$135,000,00 \$1460,000,00	\$50,000 \$90,000 \$36,000 \$36,000 \$75,000 \$50,000 \$50,000 \$540,000 \$54,63 \$382 \$75,969 \$35,700 \$19,444 \$17,595 \$156,442 \$108,375 \$1,706 \$135,000 \$135,000 \$135,000 \$135,000 \$3,480,000\$}	
	TOTAL				\$9,369,878	
	PROBABLE COST USE		<u> </u>		\$9,370,000	

PRICES INCLUDE ESCALATION TO

DATE

X PRICES ARE AS OF DATE OF THIS ESTIMATE ESTIMATOR: G.B.BLAZEK 12/1/92 CHECKER: D.R.DRAKE 12/1/92 CONST. MGR.:

STANLEY CONSULTANTS

SHEET 10 OF 11

SHEET 11 OF 11

PROJECT: MECHANICAL STUDY LOCATION: CERL-DPSC STUDY JOB NO.: 10838-07-652

CONCEPTUAL COST ESTIMATE

		QUANTITY		LABOR & MATERIAL	
CODE	TEM DESCRIPTION		l		
NO.		UNITS	MEAS.	S PEH UNIT	TOTAL
	ALTERNATIVE # 6				<u> </u>
	DEMOLITION				
	BOILERS NO. 1&2	2	EA	\$30,000.00	\$60,000
	TURBINE DRIVEN BOILER FEED PUMP	4	EA	\$5,000.00	\$20,000
	COAL AND ASH SILOS, CONVEYORS AND EQUIPMENT		LS		\$100,000
	PIPING		LS		\$5,000
	ELECTRICAL INSTRUMENT AND CONTROL		LS		\$50,000
	ASBESTOS ABATEMENT		LS		\$350,000
	CENTRIFUGAL CHILLER 1200 TON		LS		\$40,000
			1.6		
			EA	\$10 500 00	\$10 500
	BOILER FEED FOMF SUGFM, 404 TDR, 10 HF			\$10,500.00	\$10,500
	DILER FEED FOMES, 13 HE, 81 GEM, 404F1.	3		\$12,000.00	\$30,000
	INSTRUMENTS AND CONTROLS				\$30,000
			15		\$75,000
	MOTOR CONTROL CENTER				\$40,000
					\$50,000
Í	AIR HEATER	1	EA	\$5.483.00	\$5,463
	AIR RECEIVER	1	EA	\$382.00	\$382
1	SWITCH GEAR	1	EA	\$75,969.00	\$75,969
	CONDENSATE RECEIVER	1.	EA	\$35,700.00	\$35,700
	EXPANSION TANK	1	EA	\$19,444.00	\$19,444
	WATER STORAGE TANK	1	EA	\$17,595.00	\$17,595
	ABOVE GROUND TANK	1	EA	\$156,442.00	\$156,442
	BELOW GROUND TANK	1	EA	\$108,375.00	\$108,375
	FLASH TANK	1	EA	\$1,706.00	\$1,708
İ	ABSORPTION CHILLER 1200 TON	1	EA	\$458,000.00	\$458,000
	COOLING TOWER	1	EA	\$89,000.00	\$89,000
ľ	COOLING TOWER PUMP 4800 GPM, 70' TDH, 150 HP	2	EA	\$28,000.00	\$56,000
	COOLING TOWER PIPING	· [LS		\$50,000
	REMOVE & MODIFY BOILER NO.3 SUPERHEATER & BURNER	1	EA	\$135,000.00	\$135,000
	REMOVE & MODIFY BOILER NO.4 SUPERHEATER & BURNER	1	EA	\$135,000.00	\$135,000
l l	GAS ENGINES AND INSTALLATION	2	EA		\$3,480,000
	GENERATOR AND INSTALLATION	2	EA	\$241,500.00	\$483,000
	AUXILIARIES AND INSTALLATION	2	EA	\$264,500.00	\$529,000
	HEAT RECOVERY STEAM GENERATOR AND INSTALLATION	2	EA	\$160,000.00	\$320,000
	SUBTOTAL				\$7,122.576
	UNDEVELOPED DESIGN DETAILS				\$1,068.386
	OVERHEAD				\$1,228,644
	PROFIT				\$819,096
	TOTAL				\$10,238,703
	PROBABLE COST USE				\$10,239,000

PRICES INCLUDE ESCALATION TO

X PRICES ARE AS OF DATE OF THIS ESTIMATE



ESTIMATOR: G.B.BLAZEK CHECKER: D.R.DRAKE CONST. MGR.: DATE

12/1/92 12/1/92 LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:15:06 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. B; TITLE: ALTERNATIVE #1 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT 92
MIDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
ANALYSIS END DATE (AED)	JAN 19

	222222222222		
COST / BENEFIT	COST	EQUIVALENT UNIFORM	TIME(S)
DESCRIPTION	IN DOS \$	ESCALATION	COST INCURRED
	(\$ X 10**0)	(% PER YEAR)	
I INVESTMENT COSTS	3920000 0	00	111 07
ELECTRICITY	2839518.0	.00	.811 94011 18
ELECT DEMAND	.0	.00	JUI 94-JUI 18
NATURAL GAS	1438757.0	3.11	JUI 94-JUI 18
MAINT LABOR	205977.0	.00	JUL94-JUL18
MAINT SERV	479420.0	.00	JUL94-JUL18
MAINT SUPPLY	178294.0	.00	JUL94-JUL18
F_FAN	11875.0	.00	JAN 17
RELVALVE	1235.0	.00	JAN 09
RELVALVE	1175.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 09
RELVALVE	2025.0	.00	JAN 10
RELVALVE	2045.0	.00	JAN 10
RELVALVE	2048.0	.00	JAN 10
RELVALVE	2040.0	.00	JAN 10
WIBUILER	725000.0	.00	JAN 17
WIBURNER	57000.0	.00	JAN 17
POMPSIMPLEX	3000.0	.00	JAN 12
TANKSIEEL	500.0	.00	JAN 12
BUILMASTER	5000.0	.00	JAN 07
ALDCONDCENTR	10000.0	-00	JAN 07
ENERGENCYCEN	34800.0	.00	JAN U7
TRANSPOR	77500.0	.00	JAN US
CONDOLIND	32300.0	.00	JAN 18
FUDTDTNCVAL		.00	JAN 11
HEATED	8000.0	.00	JAN UD
OT PIPERFLOU	1//00 0	.00	JAN IO
DIMD	10200 0	.00	JAN UD
	5/00.0	.00	JAN UY
1 UNLOADE ONE	5400.0	.00	JAN U4

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:15:06 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. B; TITLE: ALTERNATIVE #1 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20500.0	.00	JAN 10		
SZSOFT	363334.0	.00	JAN 09		
×************************************					

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY USAGE:	10**6 BTUS	ELECTRIC DEMAND:	10**0 DOLLARS
ENERGY TYPE	\$/MBTU AMO	UNT ELECT. DEMAND	PROJECTED DATES
ELECT	26.21 10833	7.2 .0	JAN94 - JAN 19
NAT G	4.95 29065	8.0	JAN94 - JAN 19

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:15:06 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. B; TITLE: ALTERNATIVE #1 NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS		3787268.
ENERGY COSTS:		
ELECTRICITY NATURAL GAS	43213020. 30341000.	
TOTAL ENERGY COSTS		73554020.
RECURRING M&R/CUSTODIAL COSTS		12122550.
MAJOR REPAIR/REPLACEMENT COSTS		605310.
OTHER O&M COSTS & MONETARY BENEFI	TS	0.
DISPOSAL COSTS/RETENTION VALUE		0.
LCC OF ALL COSTS/BENEFITS (NET PW)	90069150.

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 12-16-92 16:14:25 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. B; TITLE: ALTERNATIVE #1 A NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT 92
MIDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
ANALYSIS END DATE (AED)	JAN 19

1	1	EQUIVALENT	1 1
COST / BENEFIT	соят	UNIFORM	TIME(S)
i		DIFFERENTIAL	
DESCRIPTION	IN DOS S	ESCALATION	COST INCURRED
	1	RATE	
i	(S X 10++3)	(% PER YEAR)	i i
INVESTMENT COSTS	3920.0	.00	JUL 93
ELECTRICITY	2525.2	.66	JUL94-JUL18
ELECT DEMAND	.0	.00	JUL94-JUL18
NATURAL GAS	1534.7	3.11	JUL94-JUL18
MAINT LABOR	206.0	.00	JUL94-JUL18
MAINT SERV	479.4	.00	JUL94-JUL18
MAINT SUPPLY	178.3	.00	JUL94-JUL18
F_FAN	11.9	.00	JAN 17
RELVALVE	1.2	.00	JAN 09
RELVALVE	1.2	.00	JAN 08
RELVALVE	3.3	.00	JAN 08
RELVALVE	3.3	.00	JAN 09
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
WTBOILER	725.0	.00	JAN 17
WTBURNER	57.0	.00	JAN 17
PUMPSIMPLEX	3.0	.00	JAN 12
TANKSTEEL	.5	.00	JAN 12
BOILMASTER	5.0	.00	JAN 07
FLAMESAFE	10.0	.00	JAN 07
AIRCOMPCENTR	34.8	.00	JAN 07
EMERGENCYGEN	174.0	.00	JAN 08
TRANSPCB	32.5	.00	JAN 18
CONDPUMP	18.8	.00	JAN 11
FWPIPINGVAL	7.8	.00	JAN 05
HEATER	8.0	.00	JAN 16
OILPIPEBELOW	14.4	.00	JAN 06
PUMP	10.2	.00	JAN 09
UNLOADPUMP	5.4	.00	JAN 04

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 12-16-92 16:14:25 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. B; TITLE: ALTERNATIVE #1 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20.5	.00	JAN 10			
SZSOFT	363.3	.00	JAN 09			

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**3 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	96345.2		.0	JAN94-JAN19
NAT G		4.95	310035.0			JAN94-JAN19

151

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 12-16-92 16:14:25 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. B; TITLE: ALTERNATIVE #1 A NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 3787.

ENERGY COSTS:

ELECTRICITY	38430.
NATURAL GAS	32364.

TOTAL ENERGY COSTS

RECURRING M&R/CUSTODIAL COSTS 12123.

MAJOR REPAIR/REPLACEMENT COSTS

OTHER O&M COSTS & MONETARY BENEFITS

DISPOSAL COSTS/RETENTION VALUE

LCC OF ALL COSTS/BENEFITS (NET PW) 87308.

*NET PW EQUIVALENTS ON OCT92; IN 10**3 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90

70793.

605.

Ο.

Ο.

152

LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY & TITLE: 1 FY 1993 INSTALLATION & LOCATION: DPSC DATE/TIME: 11-16-92 10:58:29 PROJECT NO., FY & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATOUO ALT. ID. C; TITLE: ALTERNATIVE #2- OPTION L NAME OF DESIGNER: SCI ONE 1.6 MW Spart Gas Engine BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT 92
MIDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
ANALYSIS END DATE (AED)	JAN 19

	***************		************************
	1	EQUIVALENT	
COST / RENEFIT	COST	UNIFORM	TIME(S)
		DIFFFRENTIAL	
DESCRIPTION	TN DOS S	ESCALATION	COST INCURRED
DESCRIPTION		RATE	
	/e v 10**03	AN DED YEADY	
			=============
	7170000 0	00	111 07
INVESTMENT LUSIS	1543778 0		1110/-11118
	1000110.0	.00	UH 04 - UH 19
LECT DEMAND	2014/12 0	7 11	
MATURAL GAS	270000 0	5.11	8806-8818
MAINI LABOR	230000.0		0110/-01118
MAINI SERV	200000 0		1110/- 11118
MAINI SUPPLI	11975 0		
I F FAN	1075.0	.00	
RELVALVE	1235.0	.00	
RELVALVE	11/5.0		JAN UO
KELVALVE	3200.0	.00	
RELVALVE	3280.0	.00	JAN UY
RELVALVE	2025.0	.00	JAN IU
RELVALVE	2045.0	1.00	JAN IU
RELVALVE	2048.0	.00	JAN 10
RELVALVE	2040.0	.00	JAN IU
WIBOILER	725000.0	.00	JAN 17
WIBURNER	57000.0	.00	
PUMPSIMPLEX	3000.0	.00	JAN 12
TANKSTEEL	500.0	.00	JAN 12
BOILMASTER	5000.0	.00	JAN 07
FLAMESAFE	10000.0	.00	JAN 07
AIRCOMPCENTR	54800.0	.00	JAN 07
EMERGENCYGEN	174000.0	.00	JAN US
TRANSPCB	32500.0	.00	JAN 18
CONDPUMP	18750.0	.00	JAN 11
FWP1P1NGVAL	7800.0	.00	JAN US
HEATER	8000.0	.00	JAN 16
OILPIPEBELOW	14400.0	.00	JAN 06
PUMP	10200.0	.00	JAN 09
UNLOADPUMP	5400.0	00.	JAN 04

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:58:29 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. C; TITLE: ALTERNATIVE #2 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20500.0	.00	JAN 10
SZSOFT	363334.0	.00	JAN 09

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**0 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	59663.4		.0	JAN94-JAN19
NAT G		4.95	407356.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:58:29 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. C; TITLE: ALTERNATIVE #2 NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

7129146. INITIAL INVESTMENT COSTS ENERGY COSTS: 23798250. ELECTRICITY NATURAL GAS 42522790. 66321030. TOTAL ENERGY COSTS RECURRING M&R/CUSTODIAL COSTS 12764400. 605310. MAJOR REPAIR/REPLACEMENT COSTS 0. OTHER O&M COSTS & MONETARY BENEFITS DISPOSAL COSTS/RETENTION VALUE 0. LCC OF ALL COSTS/BENEFITS (NET PW) 86819880.

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 INSTALLATION & LOCATION: DPSC DESIGN FEATURE: STATQUO ALT. ID. C; TITLE: ALTERNATIVE #2 - OPTION 2. NAME OF DESIGNER: SCI TWO J.G MW Spork Gas Engine BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT 92
MIDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
ANALYSIS END DATE (AED)	JAN 19

1		EQUIVALENT	
COST / BENEFIT	COST	UNIFORM	TIME(S)
		DIFFERENTIAL	
DECOIDTION	TN DOS &	ESCALATION	COST INCURRED
DESCRIPTION		PATE	
	20 V 10++01	VY OCD VEADY	
I	(> X 100)	(A PER TEAR)	
	40077500 0	00	111 07
INVESTMENT COSTS	10837500.0	.00	
ELECTRICITY	1503/18.0	•00	
ELECT DEMAND		.00	JUL94-JUL10
NATURAL GAS	2016412.0	3.11	JUL94-JUL10
MAINT LABOR	230000.0	.00	JUL94-JUL18
MAINT SERV	479420.0	.00	JUL94-JUL18
MAINT SUPPLY	200000.0	.00	JUL94-JUL18
F FAN	11875.0	.00	JAN 17
RELVALVE	1235.0	.00	JAN 09
RELVALVE	1175.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 09
RELVALVE	2025.0	.00	JAN 10
RELVALVE	2045.0	.00	JAN 10
RELVALVE	2048.0	.00	JAN 10
RELVALVE	2040.0	.00	JAN 10
UTBOLLER	725000.0	.00	JAN 17
UTRIPNER	57000.0	.00	JAN 17
DIMOSTINDI EY	3000.0	.00	JAN 12
TANKSTEEL	500.0	.00	JAN 12
DOLIMACTED	5000.0	00	JAN 07
ELANGCASE	10000.0	.00	JAN 07
ALDCONDCENTR	3/ 800 0	.00	JAN 07
AIRCOMPCENTR	17/000.0	.00	JAN 08
EMERGENCIGEN	72500.0	.00	
TRANSPER	19760.0	.00	
CONDPOMP		.00	
FWPIPINGVAL	7000.0	.00	
HEATER	8000.0	.00	
OILPIPEBELOW	14400.0	.00	JAN UO
PUMP	10200.0	.00	JAN UY
UNLOADPUMP	5400.0	.00	JAN U4

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:59:32 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. C; TITLE: ALTERNATIVE #2 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20500.0	.00	JAN 10
SZSOFT	363334.0	.00	JAN 09

OTHER KEY INPUT DATA

LOCATION	- PENNSYLVA	NNIA	CENS	US REGION:	1
RATES FOR	INDUSTRIAL	SECTOR.	TABLES	FROM OCT 90)

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**0 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	59663.4		.0	JAN94-JAN19
NAT G		4.95	407356.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-16-92 10:59:32 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. C; TITLE: ALTERNATIVE #2 NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS

10470540.

ENERGY COSTS:

ELECTRICITY 23798250. NATURAL GAS 42522790. TOTAL ENERGY COSTS 66321030. RECURRING M&R/CUSTODIAL COSTS 12764400. MAJOR REPAIR/REPLACEMENT COSTS 605310. OTHER O&M COSTS & MONETARY BENEFITS 0. DISPOSAL COSTS/RETENTION VALUE 0. LCC OF ALL COSTS/BENEFITS (NET PW) 90161280.

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 INSTALLATION & LOCATION: DPSC DESIGN FEATURE: STATQUO ALT. ID. I; TITLE: 1 - 1100KW GAS TURBINE NAME OF DESIGNER: SCI Alternative No. 2 - OPTION 3 BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT	92
MIDPOINT OF CONSTRUCTION (MPC)	JUL	93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN	94
ANALYSIS END DATE (AED)	JAN	19

COST / BENEFIT	COST	EQUIVALENT UNIFORM	TIME(S)
DESCRIPTION	IN DOS \$	DIFFERENTIAL	COST INCURRED
	(\$ X 10**3)	RATE (% PER YEAR)	
******************************		5225222222222	=================
INVESTMENT COSTS	5715.0	.00	
ELECTRICITY	2037.9	-66	JUL94-JÚI 18
ELECT DEMAND	.0	.00	JUI 94-JUI 18
NATURAL GAS	1798.8	3.11	JUL94-JUL18
MAINT LABOR	230.0	.00	JUL 94-JUL 18
MAINT SERV	479.4	.00	3111 94-3111 18
MAINT SUPPLY	200.0	.00	.1119411118
F FAN	11.9	.00	JAN 17
RELVALVE	1.2	-00	JAN 09
RELVALVE	1.2	.00	JAN 08
RELVALVE	3.3	.00	.IAN 08
RELVALVE	3.3	- 00	JAN 00
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
WTBOILER	725.0	_00	JAN 17
WTBURNER	57.0	.00	JAN 17
PUMPSIMPLEX	3.0	.00	JAN 12
TANKSTEEL	.5	.00	JAN 12
BOILMASTER	5.0	.00	JAN 07
FLAMESAFE	10.0	.00	JAN 07
AIRCOMPCENTR	34.8	.00	JAN 07
EMERGENCYGEN	174.0	.00	JAN 08
TRANSPCB	32.5	.00	JAN 18
CONDPUMP	18.8	.00	JAN 11
FWPIPINGVAL	7.8	.00	JAN 05
HEATER	8.0	.00	JAN 16
OILPIPEBELOW	14.4	.00	JAN 06
PUMP	10.2	.00	JAN 09
UNLOADPUMP	5.4	.00	JAN 04

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-07-92 14:29:24 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. 1; TITLE: 1 - 1100KW GAS TURBINE NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20.5	.00	JAN 10
SZSOFT	363.3	.00	JAN 09
<u> </u>			

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**3 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	77751.6		.0	JAN94-JAN19
NAT G		4.95	363401.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. I; TITLE: 1 - 1100KW GAS TURBINE NAME OF DESIGNER: SCI LIFE CYCLE COST TOTALS* INITIAL INVESTMENT COSTS 5521. ENERGY COSTS: ELECTRICITY 31013. NATURAL GAS 37934. TOTAL ENERGY COSTS 68948. RECURRING M&R/CUSTODIAL COSTS 12764. MAJOR REPAIR/REPLACEMENT COSTS 605. OTHER O&M COSTS & MONETARY BENEFITS 0. DISPOSAL COSTS/RETENTION VALUE 0. LCC OF ALL COSTS/BENEFITS (NET PW) 87838.

*NET PW EQUIVALENTS ON OCT92; IN 10**3 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-07-92 14:29:48 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. J; TITLE: 2 - 1100KW GAS TURBINES NAME OF DESIGNER: SCI ALTERNATIVE 2 - OPTION 4

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT 92
IDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
WALYSIS END DATE (AED)	JAN 19

		=========================		
	COST / BENEFIT	COST	EQUIVALENT UNIFORM	TIME(S)
	DESCRIPTION	IN DOS S	ESCALATION	COST INCURRED
		(\$ X 10**3)	(% PER YEAR)	
	INVESTMENT COSTS	7500 0		1111 07
	ELECTRICITY	1268.3	.66	.1019410118
	ELECT DEMAND	.0	.00	
1	NATURAL GAS	2152.3	3.11	JUL94-JUL18
	MAINT LABOR	230.0	.00	JUI 94-JUI 18
	MAINT SERV	479.4	.00	JUL94-JUL18
	MAINT SUPPLY	200.0	.00	JUL94-JUL18
	F_FAN	11.9	.00	JAN 17
	RELVALVE	1.2	.00	JAN 09
	RELVALVE	1.2	.00	JAN 08
	RELVALVE	3.3	.00	JAN 08
	RELVALVE	3.3	.00	JAN 09
	RELVALVE	2.0	.00	JAN 10
	RELVALVE	2.0	.00	JAN 10
	RELVALVE	2.0	.00	JAN 10
- [VIROLICO	2.0	.00	JAN 10
		(23.0	.00	JAN 17
		51.0	.00	JAN 17
	TANYSTEEI	3.0	.00	JAN 12
ì	BOLIMASTED		.00	JAN 12
	FLAMESAFE	10.0	.00	
1	AIRCOMPCENTR	7/ 8	.00	JAN 07
	EMERGENCYGEN	174.0	.00	
	TRANSPOR	72 5	.00	
	CONDELINE	18.8	.00	
ſ	FUPIPINGVAL	7 8		
	HEATER	8 0	.00	
I	OILPIPEBELOW	14.4	.00	
1	PUMP	10.2	.00	
I	UNLOADPUMP	5.4	.ŏŏ	JAN 04

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-07-92 14:29:48 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. J; TITLE: 2 - 1100KW GAS TURBINES NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20.5	.00	JAN 10	ĺ	
SZSOFT	363.3	.00	JAN 09		

OTHER KEY INPUT DATA

LOCATION	- PENNSYLVA	NNIA	CENS	SUS RE	GION:	1
RATES FOR	INDUSTRIAL	SECTOR.	TABLES	FROM	OCT 90	

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**3 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	48390.7		.0	JAN94-JAN19
NAT G		4.95	434800.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-07-92 14:29:48 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. J; TITLE: 2 - 1100KW GAS TURBINES NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 7255. ENERGY COSTS: ELECTRICITY 19302. NATURAL GAS 45388. TOTAL ENERGY COSTS 64689. RECURRING M&R/CUSTODIAL COSTS 12764. MAJOR REPAIR/REPLACEMENT COSTS 605. OTHER O&M COSTS & MONETARY BENEFITS 0. DISPOSAL COSTS/RETENTION VALUE 0. LCC OF ALL COSTS/BENEFITS (NET PW) 85313.

*NET PW EQUIVALENTS ON OCT92; IN 10**3 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 INSTALLATION & LOCATION: DPSC DESIGN FEATURE: STATQUO ALT. ID. K; TITLE: 3 - 1100KW GAS TURBINES NAME OF DESIGNER: SCI ALTERNATIVE Z - OPTION S BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE:Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT	92
MIDPOINT OF CONSTRUCTION (MPC)	JUL	93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN	94
ANALYSIS END DATE (AED)	JAN	19

	================	=======================================	
COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL	TIME(S)
DESCRIPTION	IN DOS \$	ESCALATION	COST INCURRED
	(\$ X 10**3)	(% PER YEAR)	
INVESTMENT COSTS ELECTRICITY ELECT DEMAND NATURAL GAS MAINT SERV MAINT SERV MAINT SUPPLY F FAN RELVALVE RELVALV	9304.0 708.1 708.1 2491.5 230.0 479.4 200.0 11.9 1.2 3.3 3.3 2.0 2.0 2.0 2.0 2.0 725.0 57.0 3.0 57.0 3.0 57.0 3.0 57.0 3.0 57.0 3.0 10.0 34.8 174.0 32.5 18.8 7.8 8.0 14.4 10.2	-00 -66 -00 3.11 -00 -00 -00 -00 -00 -00 -00 -00 -00 -	JUL 93 JUL 93 JUL94-JUL18 JUL94-JUL18 JUL94-JUL18 JUL94-JUL18 JUL94-JUL18 JUL94-JUL18 JUL94-JUL18 JAN 09 JAN 09 JAN 09 JAN 09 JAN 00 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 17 JAN 17 JAN 17 JAN 17 JAN 07 JAN 08 JAN 10 JAN 10 JAN 07 JAN 07 JAN 07 JAN 08 JAN 10 JAN 07 JAN 07 JAN 07 JAN 08 JAN 10 JAN 07 JAN 07 JAN 08 JAN 08 JAN 07 JAN 07 JAN 07 JAN 07 JAN 08 JAN 08 JAN 07 JAN 07 JAN 07 JAN 08 JAN 07 JAN 07 JAN 08 JAN 07 JAN 07 JAN 07 JAN 08 JAN 07 JAN 07 JA
I encourrent our	2.4	.00	JAN U4

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-07-92 14:30:13 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. K; TITLE: 3 - 1100KW GAS TURBINES NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20.5	.00	JAN 10
SZSOFT	363.3	.00	JAN 09
		========================	

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY USAGE: 10**6 E ENERGY TYPE \$/MBTU ELECT 26.21 NAT G 4.95	BTUS AMOUNT 27016.2 503343.0	ELECTRIC DEMAND: ELECT. DEMAND .0	10**3 DOLLARS PROJECTED DATES JAN94-JAN19 JAN94-JAN19
---	---------------------------------------	---	--

LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC DESIGN FEATURE: STATQUO ALT. ID. L; TITLE: 3500 KW GAS TURBINE NAME OF DESIGNER: SCI ALTERNATIVE 2- OPTION &

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT	92
MIDPOINT OF CONSTRUCTION (MPC)	JUL	93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN	94
ANALYSIS END DATE (AED)	JAN	-19

COST / BENEFIT DESCRIPTION	COST IN DOS \$ (\$ X 10**3)	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE (% PER YEAR)	TIME(S) COST INCURRED
INVESTMENT COSTS ELECTRICITY ELECT DEMAND NATURAL GAS MAINT LABOR MAINT SERV MAINT SUPPLY F FAN RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE RELVALVE BOILER WTBURNER PUMPSIMPLEX TANKSTEEL BOILMASTER FLAMESAFE AIRCOMPCENTR EMERGENCYGEN TRANSPCB CONDPUMP FWPIPINGVAL HEATER OILPIPEBELOW PUMP	$\begin{array}{c} 7115.0\\ 640.4\\ 0.0\\ 2400.9\\ 2330.0\\ 479.4\\ 200.0\\ 11.9\\ 1.2\\ 1.2\\ 3.3\\ 3.3\\ 2.0\\ 2.0\\ 2.0\\ 2.0\\ 2.0\\ 2.0\\ 2.0\\ 57.0\\ 5.0\\ 5.0\\ 10.0\\ 34.8\\ 174.0\\ 32.5\\ 18.8\\ 7.8\\ 8.0\\ 14.4\\ 10.2\\ 5.4\end{array}$	$\begin{array}{c} .00\\ .66\\ .00\\ 3.11\\ .00\\ .00\\ .00\\ .00\\ .00\\ .00\\ .00\\ $	JUL 93 JUL94 - JUL18 JUL94 - JUL18 JUL94 - JUL18 JUL94 - JUL18 JUL94 - JUL18 JUL94 - JUL18 JUL94 - JUL18 JAN 09 JAN 09 JAN 09 JAN 09 JAN 00 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 10 JAN 12 JAN 17 JAN 17 JAN 12 JAN 17 JAN 18 JAN 10 JAN 10 JA

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-07-92 14:30:13 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. K; TITLE: 3 - 1100KW GAS TURBINES NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS		8989.
ENERGY COSTS:		
ELECTRICITY NATURAL GAS	10776. 52543.	
TOTAL ENERGY COSTS		63319.
RECURRING M&R/CUSTODIAL COSTS		12764.
MAJOR REPAIR/REPLACEMENT COSTS		605.
OTHER O&M COSTS & MONETARY BENEFITS		0.
DISPOSAL COSTS/RETENTION VALUE		0.
LCC OF ALL COSTS/BENEFITS (NET PW)		85677.

*NET PW EQUIVALENTS ON OCT92; IN 10**3 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-09-92 10:50:56 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. L; TITLE: 3500 KW GAS TURBINE NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20.5	.00	JAN 10	
SZSOFT	363.3	.00	JAN 09	
	================			÷.

OTHER KEY INPUT DATA

LOCATION	 PENNSYLVANNI 	A CEN	SUS REGION: 1	
RATES FOR	INDUSTRIAL SE	CTOR. TABLES	FROM OCT 90	

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**3 DOLLARS
ENERGY	TYPE	\$/M8TU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	24432.7		.0	JAN94-JAN19
NAT G		4.95	485022.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 INSTALLATION & LOCATION: DPSC DESIGN FEATURE: STATQUO ALT. ID. L; TITLE: 3500 KW GAS TURBINE NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 6874. ENERGY COSTS: ELECTRICITY 9746. NATURAL GAS 50630. TOTAL ENERGY COSTS 60376. RECURRING M&R/CUSTODIAL COSTS 12764. MAJOR REPAIR/REPLACEMENT COSTS 605. OTHER O&M COSTS & MONETARY BENEFITS 0. DISPOSAL COSTS/RETENTION VALUE 0. LCC OF ALL COSTS/BENEFITS (NET PW) 80619.

*NET PW EQUIVALENTS ON OCT92; IN 10**3 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:13:31 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. D; TITLE: ALTERNATIVE #3 - OPTION } NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE:Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT	92
MIDPOINT OF CONSTRUCTION (MPC)	JUL	93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN	94
ANALYSIS END DATE (AED)	JAN	-19

		EQUIVALENT	
COST / BENEFIT	COST	UNIFORM	TIME(S)
		DIFFERENTIAL	COST INCURPED
DESCRIPTION	IN DUS D	RATE	COST INCORACD
	(\$ X 10**0)	(% PER YEAR)	
±=====================================	================	========================	==========================
INVESTMENT COSTS	11833500.0	.00	JUL 93
ELECTRICITY	1536936.0	.66	
ELECT DEMAND	.0	.00	JUL94-JUL18
NATURAL GAS	2429480.0	3.11	JUL94-JUL 18
MAINT LABOR	230000.0	.00	
MAINT SERV	479420.0	.00	
MAINT SUPPLY	200000.0	.00	JUL94-JUL10
F_FAN	118/5.0	.00	
RELVALVE	1232.0	.00	
RELVALVE	7000.0	.00	
RELVALVE	3280.0		
RELVALVE	200.0	.00	JAN 10
RELVALVE	2025.0	.00	IAN 10
	2043.0	.00	10 JAN 10
RELVALVE	2040.0	.00	IAN 10
KELVALVE	725000 0	.00	
WIBUILER	57000.0	.00	.IAN 17
WIBURNER	3000.0	.00	JAN 12
	500.0		JAN 12
	5000.0	.00	JAN 07
BUILMASIER	10000.0	.00	JAN 07
	3/ 800 0	.00	JAN 07
	174000 0	.00	JAN 08
TRANSDOR	32500.0	.00	JAN 18
	18750 0	.00	JAN 11
SUDIDINGVAL	7800.0	00	JAN 05
NEATED	8000 0	.00	JAN 16
	14400 0	00	JAN 06
DIMO	10200 0	.00	JAN 09
	5400 0	.00	JAN 04
UNLOADFOMP	1 1400.0	1	1 0.00 0.0

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:13:31 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. D; TITLE: ALTERNATIVE #3 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

	HEATEXCH SZSOFT	20500.0 363334.0	.00 .00	JAN 10 JAN 09	
-					= =

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY USAGE: 10**6 BTUS ENERGY TYPE \$/MBTU AMOUNT ELECT 26.21 58639.3 NAT G 4.95 490804.0	ELECTRIC DEMAND: ELECT. DEMAND .0	10**0 DOLLARS PROJECTED DATES JAN94-JAN19 JAN94-JAN19
--	---	--

.

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:13:31 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. D; TITLE: ALTERNATIVE #3 NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS

11432820.

ENERGY COSTS:

ELECTRICITY 23389760. NATURAL GAS 51233710. TOTAL ENERGY COSTS 74623460. RECURRING M&R/CUSTODIAL COSTS 12764400. MAJOR REPAIR/REPLACEMENT COSTS 605310. OTHER O&M COSTS & MONETARY BENEFITS 0. DISPOSAL COSTS/RETENTION VALUE ٥. LCC OF ALL COSTS/BENEFITS (NET PW) 99425980.

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90

LIFE CYCLE COST ANALYSIS LCCID 1.065 PROJECT NO., FY, & TITLE: 1 FY 1993 INSTALLATION & LOCATION: DPSC DESIGN FEATURE: STATQUO ALT. ID. L; TITLE: 3500 KW GAS TURBINE NAME OF DESIGNER: SCI ALTERNATIVE 3- OPTION 2

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT	92
MIDPOINT OF CONSTRUCTION (MPC)	JUL	93
BENEFICIAL OCCUPANCY DATE (800)	JAN	94
ANALYSIS END DATE (AED)	JAN	19

######################################	=========================		
COST / BENEFIT	cost	EQUIVALENT UNIFORM	TIME(S)
DESCRIPTION	IN DOS S	ESCALATION	COST INCURRED
 	(\$ X 10**3)	(% PER YEAR)	
INVESTMENT COSTS	7083 8	00	
ELECTRICITY	467 3		
ELECT DEMAND			
NATURAL GAS	2655 4	3 11	
MAINT LABOR	230.0	00	UII 0/- BII 18
MAINT SERV	479.4	.00	
MAINT SUPPLY	200.0	.00	
F_FAN	11.9	.00	JAN 17
RELVALVE	1.2	.00	JAN 00
RELVALVE	1.2	.00	JAN 08
RELVALVE	3.3	.00	JAN 08
RELVALVE	3.3	.00	JAN 09
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
RELVALVE	2.0	.00	JAN 10
WIBOILER	725.0	.00	JAN 17
WIBURNER	57.0	.00	JAN 17
PUMPSIMPLEX	3.0	.00	JAN 12
IANKSIEEL	5	.00	JAN 12
BUILMASTER	5.0	.00	JAN 07
FLAMESAFE	10.0	.00	JAN 07
AIRCOMPLENTR	54.8	.00	JAN 07
TRANSOCR	1/4.0	.00	JAN 08
CONDRING	32.5	.00	JAN 18
	10.8	.00	JAN 11
HEATED	1 2.0	.00	JAN US
OTIPTPERFLOW	0.0	.00	JAN 16
PUMP	10.2	.00	JAN UG
	5 /	.00	JAN UY
	J		JAN U4

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-09-92 11:08:49 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. L; TITLE: 3500 KW GAS TURBINE NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

HEATEXCH	20.5	.00	JAN	10	
SZSOFT	363.3	.00	JAN	09	
			.==========	====	==

OTHER KEY INPUT DATA

LOCATION	- PENNSYLVA	NNIA	CENSUS	REGION:	1
RATES FOR	INDUSTRIAL	SECTOR.	TABLES FR	OM OCT 90	

ENERGY ENERGY	USAGE: TYPE	10**6 \$/MBTU	BTUS	ELECTRIC	DEMAND: DEMAND	10**3 DOLLARS
ELECT NAT G		26.21 4.95	17828.5 536454.0		.0	JAN94-JAN19 JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: PRP LCCID 1.065 DATE/TIME: 12-09-92 11:08:49 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. 1D. L; TITLE: 3500 KW GAS TURBINE NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS

ENERGY COSTS.

7713.

ENERGT CUSTS:		
ELECTRICITY NATURAL GAS	7111. 55999.	
TOTAL ENERGY COSTS		63110.
RECURRING M&R/CUSTODIAL COSTS		12764.
MAJOR REPAIR/REPLACEMENT COSTS		605.
OTHER O&M COSTS & MONETARY BENEFITS		0.
DISPOSAL COSTS/RETENTION VALUE		0.
LCC OF ALL COSTS/BENEFITS (NET PW)		84192.

*NET PW EQUIVALENTS ON OCT92; IN 10**3 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:16:10 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. E; TITLE: ALTERNATIVE #4 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT 92
MIDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
ANALYSIS END DATE (AED)	JAN 19

=======================================	====================		
COST / BENEFIT DESCRIPTION	COST IN DOS \$ (\$ X 10**0)	EQUIVALENT UNIFORM DIFFERENTIAL ESCALATION RATE (% PER YEAR)	TIME(S) COST INCURRED
INVESTMENT COSTS ELECTRICITY ELECT DEMAND NATURAL GAS MAINT LABOR MAINT SERV MAINT SUPPLY DRUMCTL F_FAN F_FAN F_FAN RELVALVE RELVE TANKSTEEL BOILMASTER BOILMASTER FLAMESAFE AIRCOMPCENTR EMERGENCTGEN TRANSPCB	2452500.0 2839518.0 205977.0 205977.0 178294.0 10000.0 11875.0 44000.0 50000.0 1235.0 1175.0 3280.0 2045.0 2045.0 2045.0 2045.0 2045.0 2045.0 2045.0 2045.0 2040.0 725000.0 57000.0 57000.0 5000.0 10000.0 5000.0 10000.0 5000.0 174000.0 32500.0	-00 -66 -00 3.11 -00 -00 -00 -00 -00 -00 -00 -00 -00 -	JUL 93 JUL 94-JUL 18 JUL94-JUL 18 JUL94-JUL 18 JUL94-JUL 18 JUL94-JUL 18 JUL94-JUL 18 JUL94-JUL 18 JUL94-JUL 18 JAN 01 JAN 01 JAN 01 JAN 01 JAN 01 JAN 00 JAN 08 JAN 08 JAN 08 JAN 08 JAN 00 JAN 10 JAN 07 JAN 07 JAN 07 JAN 07 JAN 07 JAN 08 JAN 08 JAN 08 JAN 08

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:16:10 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. E; TITLE: ALTERNATIVE #4 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CONDPUMP FWPIPINGVAL	18750.0 7800.0	.00	JAN 11 JAN 05
HEATER	8000.0	.00	JAN 16
OILPIPEBELOW	14400.0	.00	JAN 06
PUMP	10200.0	.00	JAN 09
UNLOADPUMP	5400.0	.00	JAN 04
HEATEXCH	20500.0	.00	JAN 10
SZSOFT	363334.0	.00	JAN 09

OTHER KEY INPUT DATA

LOCATION	- PENNSYLVA	NNIA	CENS	SUS REGION: 1
RATES FOR	INDUSTRIAL	SECTOR.	TABLES	FROM OCT 90

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**0 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	108337.2		.0	JAN94 - JAN 19
NAT G		4.95	29 065 8.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:16:10 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. E; TITLE: ALTERNATIVE #4 NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	2369458.	
ENERGY COSTS:		
ELECTRICITY NATURAL GAS	43213020. 30341000.	
TOTAL ENERGY COSTS	73554020.	
RECURRING M&R/CUSTODIAL COSTS	12122550.	
MAJOR REPAIR/REPLACEMENT COSTS	2604812.	
OTHER O&M COSTS & MONETARY BENEFI	TS 0.	
DISPOSAL COSTS/RETENTION VALUE	0.	
LCC OF ALL COSTS/BENEFITS (NET PW	90650840.	

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:18:11 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. F; TITLE: ALTERNATIVE #5 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

DATE OF STUDY (DOS)	OCT	92
MIDPOINT OF CONSTRUCTION (MPC)	JUL	93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN	94
ANALYSIS END DATE (AED)	JAN	19

1	1	EQUIVALENT	
COST / RENEFIT	7200	LINTEORM	TIME(S)
COST / DENETTI		DIECEDENTIAL	(Inclust
DECODIDITION	111 000 0		COST INCIDATA
DESCRIPTION	ע בטט או ן	ESCALATION	LUST INCORRED
		RATE	
	(\$ X 10**0)	(% PER YEAR)	
*=====================================	================	=================	=================
LINVESTMENT COSTS	9369900.0	.00	່ ມີ 93
FIECTRICITY	1563778 0	~~~	.111 94111 18
ELECT DEMAND			111 0/ - 111 18
	2014/12 0	7 11	
NATURAL GAS	2010412.0	3.11	JUL94-JUL 10
MAINT LABOR	230000.0	.00	JUL94-JUL18
MAINT SERV	479420.0	.00	JUL94-JUL18
MAINT SUPPLY	200000.0	.00	JUL94-JUL18
DRUMCTL	10000.0	.00	JAN 01
F FAN	11875.0	.00	JAN 17
FFAN	44000.0	.00	JAN 01
1 FAN	50000 0	00	
DELVALVE	1275 0	.00	
	1175 0	.00	
RELVALVE	7000.0	.00	JAN UO
RELVALVE	3200.0	-00	JAN UO
RELVALVE	3280.0	.00	JAN UY
RELVALVE	2025.0	.00	JAN 10
RELVALVE	2045.0	.00	JAN 10
RELVALVE	2048.0	.00	JAN 10
RELVALVE	2040.0	.00	JAN 10
WTBOILER	725000.0	.00	JAN 17
WTROLLER	2600000.0	.00	JAN 01
WTBURNER	57000 0	iñi	JAN 17
UTRIDNED	204444 0	.00	
	200000.0	.00	
PUMPSIMPLEX	3000.0	.00	JAN 12
TANKSTEEL	500.0	.00	JAN 12
BOILMASTER	10000.0	.00	JAN 01
BOILMASTER	5000.0	.00	JAN 07
FLAMESAFE	10000.0	.00	JAN 07
AIRCOMPCENTR	34800.0	.00	JAN 07
EMERGENCYGEN	174000.0	.00	JAN 08
TRANCOCO	32500 0	00	IAN 18
Innarub	22200.0		
.

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:18:11 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. F; TITLE: ALTERNATIVE #5 NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CONDPUMP FWPIPINGVAL HEATER OILPIPEBELOW PUMP UNLOADPUMP HEATEXCH	18750.0 7800.0 8000.0 14400.0 10200.0 5400.0 20500.0	.00 .00 .00 .00 .00 .00	JAN 11 JAN 05 JAN 16 JAN 06 JAN 09 JAN 04 JAN 10
HEATEXCH	20500.0	.00	JAN 10
SZSOFT	363334.0	.00	JAN 09

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY US	SAGE: 10**6	BTUS	ELECTRIC DEMAND	: 10**0 DOLLARS
ENERGY T	YPE \$/MBTU	AMOUNT	ELECT. DEMAND	PROJECTED DATES
ELECT	26.21	59663.4	.0	JAN94-JAN19
NAT G	4.95	407356.0		JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 11-18-92 14:18:11 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. F; TITLE: ALTERNATIVE #5 NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS

9052634.

ENERGY COSTS:

ELECTRICITY NATURAL GAS	23798250. 42522790.	
TOTAL ENERGY COSTS		66321030.
RECURRING M&R/CUSTODIAL COSTS		12764400.
MAJOR REPAIR/REPLACEMENT COSTS		2604812.
OTHER O&M COSTS & MONETARY BENEFI	TS	0.
DISPOSAL COSTS/RETENTION VALUE		0.
LCC OF ALL COSTS/BENEFITS (NET PW)	90742870.

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS STUDY: BRENT LCCID 1.065 DATE/TIME: 11-18-92 14:21:47 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. K; TITLE: ALTERNATIVE #6-REVISED NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

KEY PROJECT-CALENDAR INFORMATION

DATE OF STUDY (DOS)	OCT 92
MIDPOINT OF CONSTRUCTION (MPC)	JUL 93
BENEFICIAL OCCUPANCY DATE (BOD)	JAN 94
ANALYSIS END DATE (AED)	JAN 19

COST / BENEFIT	COST	EQUIVALENT UNIFORM DIFFERENTIAL	TIME(S)
DESCRIPTION	IN DOS S	ESCALATION	COST INCURRED
	(\$ X 10**0)	(% PER YEAR)	
	10279700 0	00	111 07
	1536036 0	.00	.111 94111 18
	0.00000	.00	JUL94-JUL18
NATURAL CAS	2429480 0	3.11	JUI 94-JUL 18
MATNT LABOR	230000.0	.00	JUL94-JUL18
MAINT SERV	479420.0	.00	JUL94-JUL18
MAINT SUPPLY	200000.0	.00	JUL94-JUL18
DRUMCTI	10000.0	.00	JAN 01
F FAN	11875.0	.00	JAN 17
FFAN	44000.0	.00	JAN 01
TEAN	50000.0	.00	JAN 01
REI VALVE	1235.0	.00	JAN 09
RELVALVE	1175.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 09
RELVALVE	2025.0	.00	JAN 10
REIVALVE	2045.0	.00	JAN 10
RELVALVE	2048.0	.00	JAN 10
RELVALVE	2040.0	.00	JAN 10
WTBOILER	725000.0	.00	JAN 17
WTBOILER	2600000.0	.00	JAN 01
WTBURNER	57000.0	.00	JAN 17
WTBURNER	206666.0	.00	JAN 01
PUMPSIMPLEX	3000.0	.00	JAN 12
TANKSTEEL	500.0	.00	JAN 12
BOILMASTER	10000.0	.00	
BOILMASTER	5000.0	.00	JAN U/
FLAMESAFE	10000.0	.00	
AIRCOMPCENTR	34800.0	.00	JAN U/
EMERGENCYGEN	174000.0	.00	JAN US
TRANSPCB	32500.0	.00	JAN 18

LIFE CYCLE COST ANALYSIS STUDY: BRENT LCCID 1.065 DATE/TIME: 11-18-92 14:21:47 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. K; TITLE: ALTERNATIVE #6-REVISED NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CONDPUMP FWPIPINGVAL HEATER OLIDISEPELOU	18750.0 7800.0 8000.0	.00 .00 .00	JAN 11 JAN 05 JAN 16
PUMP UNLOADPUMP HEATEXCH SZSOFT	10200.0 5400.0 20500.0 363334.0	.00 .00 .00 .00	JAN 09 JAN 04 JAN 10 JAN 10 JAN 09

OTHER KEY INPUT DATA

LOCATION - PENNSYLVANNIA CENSUS REGION: 1 RATES FOR INDUSTRIAL SECTOR. TABLES FROM OCT 90

ENERGY	USAGE:	10**6	BTUS	ELECTRIC	DEMAND:	10**0 DOLLARS
ENERGY	TYPE	\$/MBTU	AMOUNT	ELECT.	DEMAND	PROJECTED DATES
ELECT		26.21	58639.3		.0	JAN94-JAN19
NAT G		4.95	490804.0			JAN94-JAN19

LIFE CYCLE COST ANALYSIS STUDY: BRENT LCCID 1.065 DATE/TIME: 11-18-92 14:21:47 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. K; TITLE: ALTERNATIVE #6-REVISED NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS	9892016.	
ENERGY COSTS:		
ELECTRICITY NATURAL GAS	23389760. 51233710.	
TOTAL ENERGY COSTS	74623460.	
RECURRING M&R/CUSTODIAL COSTS	12764400.	
MAJOR REPAIR/REPLACEMENT COSTS	2604812.	
OTHER O&M COSTS & MONETARY BENEFI	uts 0.	
DISPOSAL COSTS/RETENTION VALUE	0.	
LCC OF ALL COSTS/BENEFITS (NET PW	1) 99 884690.	

*NET PW ÉQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90 LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 10-23-92 11:34:41 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. A; TITLE: STATUS QUO NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

CRITERIA REFERENCE: Tri-Service MOA for Econ Anal/LCC (Energy)

DISCOUNT RATE: 4.7%

KEY PROJECT-CALENDAR INFORMATION

88353535255222223333222552333			
1	1	FOLITVALENT	1 1
COST / RENEFIT	TZOD	LINTFORM	TIME(S)
		DIFFERENTIAL	
DESCRIPTION		ESCALATION	COST INCURRED
DESCRIPTION	14 003 0	DATE	COST THEORRED
	1/e v 10++01	ANIE ANIE	
	(\$ X 100)	(A PER TEAR)	
INVESTMENT CUSTS	2070510.0	.00	
	2039310.0	.00	JUL94-JULIB
ELECT DEMAND	157/(77 0	.00	
NATURAL GAS	1534073.0	3.11	JUL94-JUL 10
MAINI LABOR	205977.0	.00	JUL94-JUL18
MAINT SERV	479420.0	.00	JUL94-JUL18
MAINI SUPPLY	1/8294.0	.00	JUL94-JUL18
BREECHING	20000.0	.00	JAN UT
STACK	20000.0	.00	JAN 01
AIRPHEAT	8570.0	.00	JAN 93
DRUMCTL	10000.0	.00	JAN 01
DRUMCTL	5000.0	.00	JAN 97
F_FAN	11875.0	.00	JAN 17
F_FAN	44000.0	.00	JAN 01
IFAN	50000.0	.00	JAN 01
RELVALVE	1235.0	.00	JAN 09
RELVALVE	1175.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 08
RELVALVE	3280.0	.00	JAN 09
RELVALVE	2025.0	.00	JAN 10
RELVALVE	2045.0	00	JAN 10
REI VAL VE	2048.0	.00	JAN 10
RELVALVE	204.0 0	.00	IAN 10
UTROTIER	725000 0		JAN 17
UTBOLLER	2600000 0		
UTOUDNED	57000.0		
UTRIDNED	204444	· • • • • • • • • • • • • • • • • • • •	
DIMOSTMOLEV	200000.0	.00	
TANKOTCEL	5000.0	.00	
DOLLMASTED	10000 0	.00	JAN 12
BUILMASIER	10000.0	.00	
BUILMASIEK	2000-0	.00	JAN U7

LIFE CYCLE COST ANALYSIS LCCID 1.065 DATE/TIME: 10-23-92 11:34:41 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATQUO ALT. ID. A; TITLE: STATUS QUO NAME OF DESIGNER: SCI

BASIC INPUT DATA SUMMARY

ELAMEGAEE	10000.0	.00	JAN 07
ALDCONDCENTR	34800.0	.00	JAN 07
AIRCOMPLEATA	600.0	.00	JAN 93
ENERGENCYCEN	174000.0	.00	JAN 08
CUTCH	48000 0	.00	JAN 93
SWITCH	14667 0	-00	JAN 93
SWITCH	54500 0	00	JAN 93
SWITCH	32500.0	.00	JAN 18
TRANSPLB	19750.0	.00	JAN 11
CONDPUMP	54000 0	.00	JAN 93
CONDREC	.30000.0	.00	
EXPTANK	30300.0	.00	
FEEDPUMP	43000.0	.00	
FWPIPINGVAL	7800.0	.00	
WATERSTOR	27600.0	.00	JAN 95
HEATER	8000.0	.00	JAN IO
OILPIPEBELOW	14400.0	.00	JAN UO
PUMP	10200.0	.00	JAN UY
TANKABOVE	245400.0	.00	JAN 95
TANKBELOW	170000.0	.00	JAN 93
UNI GADPUMP	5400.0	.00	JAN 04
FLASHTANK	2675.0	.00	JAN 93
HEATEXCH	20500.0	.00	JAN 10
SZSOFT	363334.0	.00	JAN 09

OTHER KEY INPUT DATA

LOCATION	- PENNSYLVANNIA	CENSUS REGION: 1
RATES FOR	INDUSTRIAL SECTOR.	TABLES FROM OCT 90

ENERGY ENERGY ELECT	USAGE: TYPE	10**6 \$/MBTU 26.21 4 95	BTUS AMOUNT 108337.2 310035.0	ELECTRIC ELECT.	DEMAND: DEMAND .0	10**0 DOLLARS PROJECTED DATES JAN94-JAN19 JAN94-JAN19
NAT G		4.95	210022.0			JAA74 JAATJ

LIFE CYCLE COST ANALYSIS STUDY: DPSC LCCID 1.065 DATE/TIME: 10-23-92 11:34:41 PROJECT NO., FY, & TITLE: 1 FY 1993 CENTRAL HEATING PLANT MOD INSTALLATION & LOCATION: DPSC PENNSYLVANNIA DESIGN FEATURE: STATUDO ALT. ID. A; TITLE: STATUS QUO NAME OF DESIGNER: SCI

LIFE CYCLE COST TOTALS*

INITIAL INVESTMENT COSTS 0. ENERGY COSTS: 43213020. ELECTRICITY NATURAL GAS 32363710. TOTAL ENERGY COSTS 75576730. RECURRING M&R/CUSTODIAL COSTS 12122550. MAJOR REPAIR/REPLACEMENT COSTS 2655780. OTHER O&M COSTS & MONETARY BENEFITS 0. DISPOSAL COSTS/RETENTION VALUE 0. LCC OF ALL COSTS/BENEFITS (NET PW) 90355060.

*NET PW EQUIVALENTS ON OCT92; IN 10**0 DOLLARS; IN CONSTANT OCT92 DOLLARS *ENERGY ESCALATION RATES FROM NIST HANDBOOK 135 SUPPLEMENT DATED OCT 90

Appendix G: STOFEAS Analysis

Data Input Descriptions

Array 1. PROJECT DESCRIPTION - contains information that identifies the project when the program generates its output.

Array 2. ECONOMIC PARAMETERS - contains the elements "STUDY LIFE" which is needed to calculate the SIR and "INTEREST RATE" which is used to calculate the compensated rate of actual saving.

Array 3. ELECTRIC UTILITY RATE - used to calculate the annual demand charge savings per kW shifted.

Array 4. WINDOW SIZE - contains information for the shifted power percentage and is used to calculate the cost of demand shifting.

Array 5. ELECTRIC UTILITY DATA - contains the elements "PEAK DEMAND" (in kW) and "UTILITY INCENTIVE" (\$/kW)(in 1000 kWh).

Array 6. SYSTEM FIRST COST - the cost of an SCS is one of the critical factors in determining the payback period (PBP).

Array 7. SCALE OF ECONOMY FOR FIRST COST - specifies the costs of installment for the three different types of applications: new/replacement, retrofit, and upper limit.

Array 8. The data in this array are required by the "SYSTEM OPERATION" and "MAINTENANCE COST" model. The costs for system operation and maintenance can be interpreted as the extra differential cost for a new SCS.

Array 9. ANNUAL DEMAND CHARGE ESCALATION RATE - allows for specification of the projected escalation rate of the demand charge in upcoming years.

Report Column Descriptions

- 1. Percentage peak power shifted by the SCS.
- 2. Corresponding shifted power (in kW) by SCS with respect to the percentage given in column 1.
- 3. Required storage capacity (or size) in terms of ton-hours for the specified shifted power in column 2.
- 4. System First Cost in terms of thousands of dollars for the corresponding storage capacity in column 3.
- 5. First Year Savings in terms of thousands of dollars for the corresponding shifted power in column 2.
- 6. Simple payback period based on the nondiscounted interest rate for the corresponding shifted power.
- 7. Discounted payback period based on the specified discounted interest rate (similar to column 6).
- 8. Savings and Investment Ratio (SIR), a valuable economic parameter for the feasibility study.
- 9. Net Savings in thousands of dollars under the specified percentage peak power shifted, the input Electric Demand Charge, and the System First Cost Model.

***** PROJECT DESCRIPTION ***** PROJECT TITLE: DPSC Modernization PROJECT LOCATION: Philadelphia, PA PROJECT YEAR: FY92 PROJECT NUMBER: N/A CAT CODE: N/A DESIGNER: M. Savoie DATE: 12-04-1992 ***** INPUT DATA ***** STUDY LIFE : 25yrs DISCOUNT RATE : 5% ***** ELECTRIC UTILITY RATE STRUCTURE ***** --- STRAIGHT DEMAND (TWO DEMAND CHARGES) ---DEMAND CHARGE (\$/kW) IN SUMMER: 13.00000 DEMAND CHARGE (\$/kW) IN WINTER: 8.00000 ***** WINDOW SIZE FOR SHIFTED POWER PERCENTAGE **** 1- 3% 4- 6% 7- 9% 10- 12% 13- 15% 16- 18% 19- 21% 22- 24% 7 hr 8 hr 8 hr 8 hr 8 hr 8 hr 8 hr ***** ELECTRIC UTILITY DATA ***** YEARLY PEAK DEMAND (kW): 7,500.00 0.00 UTILITY INCENTIVE (\$/kW): ***** SYSTEM FIRST COST MODEL ***** UPPER LIMIT NEW/REPLACEMENT RETROFIT (\$/ton-hr) (\$/ton-hr) (\$/ton-hr) 150 300 80 ***** ECONOMY OF SCALE FOR FIRST COST ***** Small(<1000 t-h) Medium Large(>10kt-h)

.87

1

.77

FEASIBILITY REPORT ON STORAGE COOLING SYSTEMS

192

	**** SI	YSTEM O&M	COST MODEL	」 * * * * *	
	PERCEN'	r of syste	EM FIRST CO)ST(%)	
			0		
**** EXP	ECTED ANNU	AL DEMAND	CHARGE ESC	CALATION	RATE ****
1	2	3	4	5	(YEAR)
065	1.3639	.7049	2549	.9573	(%)
6	7	8	9	10	(YEAR)
1.0104	1.1256	1.8555	1.7	.4775	(%)
11	12	13	14	15	(YEAR)
.7133	.9436	1.2852	.8083	.9729	(%)
16	17	18	19	20	(YEAR)
.0568	.3964	1.7497	.6103	.6142	(%)
21	22	23	24	25	(YEAR)
.6163	.6201	.623	.6257	.6293	(%)

193

****	New/Replacement	* * * *
------	-----------------	---------

*

Shift	Shifted	Storage	System 1st	lst yr	Payl	back	SIR	Net Svng
(%)	(kW)	Sz(ton-hr)	Cst(1000\$)	Svns(1000\$)	Smpl	Dsct		(1000\$)
1	75	525	42	8	5.0	6.0	3.1	87
2	150	1,050	73	17	4.4	5.0	3.5	185
3	225	1,575	110	25	4.4	5.0	3.5	277
4	300	2,400	167	33	5.0	6.0	3.1	349
5	375	3,000	209	42	5.0	6.0	3.1	436
6	450	3,600	251	50	5.0	6.0	3.1	523
7	525	4,200	292	58	5.0	6.0	3.1	610
8	600	4,800	334	67	5.0	6.0	3.1	697
9	675	5,400	376	75	5.0	6.0	3.1	785
10	750	6,000	418	83	5.0	6.0	3.1	872
11	825	6,600	459	92	5.0	6.0	3.1	959
12	900	7,200	501	100	5.0	6.0	3.1	1,046
13	975	7,800 ·	543	108	5.0	6.0	3.1	1,133
14	1,050	8,400	585	117	5.0	6.0	3.1	1,220
15	1,125	9,000	626	125	5.0	6.0	3.1	1,308
16	1,200	9,600	668	133	5.0	6.0	3.1	1,395
17	1,275	10,200	628	142	4.4	6.0	3.5	1,564
18	1,350	10,800	665	150	4.4	6.0	3.5	1,656
19	1,425	11,400	702	158	4.4	6.0	3.5	1,747
20	1,500	12,000	739	167	4.4	6.0	3.5	1,839
21	1,575	12,600	776	175	4.4	6.0	3.5	1,931
22	1,650	13,200	813	183	4.4	6.0	3.5	2,023
23	1,725	13,800	850	191	4.4	6.0	3.5	2,115
24	1,800	14,400	887	200	4.4	6.0	3.5	2,207
25	1,875	15,000	924	208	4.4	6.0	3.5	2,299

* Annual O&M Cost is assumed to be 0% of system cost.

Shift	Shifted	Storage	System 1st	1st yr	Pay	back	SIR	Net Svng
(웅)	(kW)	Sz(ton-hr)	Cst(1000\$)	Svns(1000\$)	Smpl	Dsct		(1000\$)
1	75	525	 79	<u>-</u> 8	9.5	13.0	1.6	50
2	150	1,050	137	17	8.2	11.0	1.9	121
3	225	1,575	206	25	8.2	11.0	1.9	181
4	300	2,400	313	33	9.4	12.0	1.6	203
5	375	3,000	392	42	9.4	12.0	1.6	253
6	450	3,600	470	50	9.4	12.0	1.6	304
7	525	4,200	548	58	9.4	12.0	1.6	354
8	600	4,800	626	67	9.4	12.0	1.6	405
9	675	5,400	705	75	9.4	12.0	1.6	456
10	750	6,000	783	83	9.4	12.0	1.6	506
11	825	6,600	861	92	9.4	12.0	1.6	557
12	900	7,200	940	100	9.4	12.0	1.6	608
13	975	7,800	1,018	108	9.4	12.0	1.6	658
14	1,050	8,400	1,096	117	9.4	12.0	1.6	709
15	1,125	9,000	1,175	125	9.4	12.0	1.6	75 9
16	1,200	9,600	1,253	133	9.4	12.0	1.6	810
17	1,275	10,200	1,178	142	8.3	11.0	1.9	1,014
18	1,350	10,800	1,247	150	8.3	11.0	1.9	1,073
19	1,425	11,400	1,317	158	8.3	11.0	1.9	1,133
20	1,500	12,000	1,386	167	8.3	11.0	1.9	1,193
21	1,575	12,600	1,455	175	8.3	11.0	1.9	1,252
22	1,650	13,200	1,525	183	8.3	11.0	1.9	1,312
23	1,725	13,800	1,594	191	8.3	11.0	1.9	1,372
24	1,800	14,400	1,663	200	8.3	11.0	1.9	1,431
25	1,875	15,000	1,733	208	8.3	11.0	1.9	1,491

***** Retrofit Case *****

* Annual O&M Cost is assumed to be 0% of system cost.

Shift	Shifted	Storage	System 1st	lst yr	Pay	back	SIR	Net Svng
(%)	(kW)	Sz(ton-hr)	Cst(1000\$)	Svns(1000\$)	Smpl	Dsct		(1000\$)
1	75	525	158	8 1	8.9	**.*	0.8	-29
2	150	1,050	274	17 1	6.5	**.*	0.9	-16
3	225	1,575	411	25 1	6.5	**.*	0.9	-24
4	300	2,400	626	33 1	8.8	**.*	0.8	-111
5	375	3,000	783	42 1	8.8	**.*	0.8	-138
6	450	3,600	940	50 1	8.8	***	0.8	-166
7	525	4,200	1,096	58 1	8.8	**.*	0.8	-194
8	600	4,800	1,253	67 1	8.8	**.*	0.8	-221
9	675	5,400	1,409	75 1	8.8	**.*	0.8	-249
10	750	6,000	1,566	83 1	8.8	**.*	0.8	-277
11	825	6,600	1,723	92 1	8.8	**.*	0.8	-304
12	900	7,200	1,879	100 1	8.8	**.*	0.8	-332
13	975	7,800	2,036	108 1	8.8	**.*	0.8	-360
14	1,050	8,400	2,192	117 1	8.8	**.*	0.8	-387
15	1,125	9,000	2,349	125 1	8.8	**.*	0.8	-415
16	1,200	9,600	2,506	133 1	8.8	**.*	0.8	-443
17	1,275	10,200	2,356	142 1	6.6	**.*	0.9	-164
18	1,350	10,800	2,495	150 1	6.6	**.*	0.9	-174
19	1,425	11,400	2,633	158 1	6.6	**.*	0.9	-184
20	1,500	12,000	2,772	167 1	6.6	**.*	0.9	-193
21	1,575	12,600	2,911	175 1	6.6	**.*	0.9	-203
22	1,650	13,200	3,049	183 1	6.6	**.*	0.9	-213
23	1,725	13,800	3,188	191 1	.6.6	**.*	0.9	-222
24	1,800	14,400	3,326	200 1	6.6	**.*	0.9	-232
25	1,875	15,000	3,465	208 1	6.6	**.*	0.9	-242

***** Upper Limit Case *****

* Annual O&M Cost is assumed to be 0% of system cost.

Appendix H: Monthly Electric Load Curves for Alternative 2, Option 6







DPSC LOAD DURATION CURVE 3500 KW GAS TURBINE APRIL





















DPSC LOAD DURATION CURVE 3500 KW GAS TURBINE DECEMBER



Appendix I: DD 1391 and Project Development Brochure Forms

1391 PROCESSOR DATA INPUT

SECTION NUMBER 1

- 1A PROGRAM TYPE (Enter one of the following: MCA, PBS, NAF, CFF, S6S, BCA, MR, AFH, COMM, AAFES, MED, DLA, SOP, MCON, SES, RB, DS) = MCA
- 1B COMPONENT = DLA
- 1C FISCAL YEAR = 1995
- 1D1 CONSTRUCTION START DATE ASSUMPTION = 04/1995
- 1D2 CONSTRUCTION END DATE ASSUMPTION = 04/1996

CONSTRUCTION MIDPOINT = 10/1995

- 1E1 INSTALLATION NAME = Defense Personnel Support Center
- 1F LOCATION = Philadelphia

1G CATEGORY CODE = 80000

- 1H PROJECT TITLE = ECIP New Boiler & Gas Turbine Cogeneration
- 1I TYPE OF WORK: MULTIPLE CHOICE 2 ENTRIES ALLOWED SEPARATED BY A COMMA (New, Addition, Alteration, Conversion, Modernization, Repair, or Other) = MODERNIZATION
- 1J1 MOBILIZATION/EMERGENCY (Y/N) = N
- 1K TYPE OF CONSTRUCTION (T = Temporary, P = Permanent, S = Semi-Permanent) = P
- 1L PROGRAM ELEMENT

1M PERMANENT PROJECT NUMBER

- 1N TEMPORARY PROJECT NUMBER
- 10 PREPARATION DATE = 12/30/1992

206

ENTER SECTION NUMBER 2 2A1 GENERAL PRIMARY FACILITIES 01.00)811 Steam Boilers MBtu 2 991,500 1,983 02.00)811 Gas Turbine KW 1 3,482,000 3,482 SUBTOTAL FOR BLOCK 2A1 = 5,4652A2 INFORMATION SYSTEMS PRIMARY FACILITIES SUBTOTAL FOR BLOCK 2A2 TOTAL PRIMARY FACILITIES COST = 5,465 2B SUPPORT FACILITIES 2B1 ELECTRIC SERVICE SUBTOTAL FOR BLOCK 2B1 2B2 WATER, SEWER, GAS SUBTOTAL FOR BLOCK 2B2 2B3 STEAM AND/OR CHILLED WATER DISTRIBUTION SUBTOTAL FOR BLOCK 2B3 2B4 PAVING, WALKS, CURBS AND GUTTERS SUBTOTAL FOR BLOCK 2B4 2B5 STORM DRAINAGE SUBTOTAL FOR BLOCK 2B5 2B6 SITE IMPROVEMENT/DEMOLITION 397,500 2 01.00) Coal Boilers 795 SUBTOTAL FOR BLOCK 2B6 = 795

2B7 INFORMATION SYSTEMS SUBTOTAL FOR BLOCK 2B7 2B8 OTHER SUBTOTAL FOR BLOCK 2B8 TOTAL SUPPORTING FACILITIES COST = 795 PERCENT OF SUPPORTING COSTS TO PRIMARY COSTS = .16 ESTIMATED CONTRACT COST = 6,260 2C CONTINGENCY FACTOR = 6.0000 CONTINGENCY FACTOR = 6.0000 CONTINGENCY AMOUNT = 376 SUBTOTAL = 6,636 2D SIOH PERCENT = 7.0000 SIOH AMOUNT = 464 TOTAL REQUEST = 7,100 2F ESTIMATED PROJECT COST (ROUNDED) = 7,100

2G INSTALLED EQUIPMENT - OTHER APPROPRIATIONS (\$000)

SECTION NUMBER 3

3A DESCRIPTION OF PROPOSED CONSTRUCTION

The recommended alternative is based on the lowest net present worth (NPW) of all life cycle costs (LCC) associated with each of the alternatives examined. The suggested proposal consists of installing two new gas/oil boilers and a natural gas turbine generator with a heat recovery steam generator (HRSG) in the existing central heating plant.

3B REMARKS

The central heating plant (CHP) at the Defense Personnel Support Center (DPSC), Philadelphia, PA, consists of five steam boilers, of which four are 50 years old and one is 14 years old. Boilers 1 to 4 are Edge Moore Iron Works water tube boilers, which were installed in 1941-42. Boilers No. 1 and 2 are coal-fired dump grate spreader stokers, rated at 75,000 lb/hr steam at 180 psi, 435 °F. However, these boilers operated only for a few years and have not operated for at least 25 years. Current air pollution regulations will not allow coal to be burned.

208

Boiler Nos. 3 and 4 are dual fuel (natural gas and No. 6 oil), rated at 100,000 lb/hr steam at 180 psi, 435 °F. These two boilers are used for heating all buildings, most of the domestic hot water, and process steam at the clothing factory. One boiler is large enough to supply the maximum loads that occur in the winter. The other boiler is operated on a stand-by basis.

Boiler No. 5 is a Cleaver Brooks packaged dual-fuel boiler installed in 1977. It has a rating of 30,000 lb/hr at 180 psi, 550 °F. Boiler No. 5 typically operates in the summer to provide steam for hot water and process loads.

The age of this equipment and high electric costs (\$26/MBtu) warranted an investigation of alternatives for providing thermal and electrical energy to the installation.

3C PROJECT DESCRIPTION

This project will allow DPSC not only to improve fuel efficiency by replacing 50-year-old boilers with high-efficiency, low-polluting boilers, it also will substantially lower total energy costs through cogeneration. Boilers No. 1 and 2 would be demolished to make room for cogeneration equipment. Boilers No. 3 and 4 would be replaced by two packaged gas/oilfired 50,000 lb/hr boilers (sized to more efficiently meet steam demands). The No. 6 fuel oil system would be replaced by No. 2 oil as the backup fuel for the boilers. This will allow the replacement of the failing No. 6 oil system and meet air pollution regulations that restrict heavy oil burning.

A new natural gas Solar Centaur Type H single-shaft industrial gas turbine with a solar heat recovery steam generator (HRSG) will be installed to generate 3.5 MW of electricity. The actual rating is 3.88 MW but has been derated to more accurately reflect expected production capacity at local operating conditions. This generating equipment will produce about 75 percent of all the electricity needed and reduce the peak electrical demand by about 50 percent. The HRSG will produce a maximum of 18,000 lb/hr at 125 psig when the turbine is operating at 100 percent capacity.

3D REQUIREMENT (Why is it needed now?)

The primary boilers are 50 years old. They are inefficient and maintenance parts are difficult to obtain. This project will reduce energy costs, saving \$1,000,000 per year. DPSC does not have a backup electrical generating system to supply minimum base needs during interruptions from PECO. 3E CURRENT SITUATION (How is the need currently being met?)

The CHP currently provides steam for heating and process loads to 15 buildings via steam lines that measure about 33,500 linear feet. The maximum winter load is about 50,000 lb/hr and the summer demand averages about 7,000 lb/hr with peaks near 10,000 lb/hr. All electricity is supplied by Philadelphia Electric Company (PECO). DPSC electrical usage and demand peaks are fairly constant during the noncooling season, averaging about 2.2 million kWh per month and 5100 kW, respectively. The highest daily use is about 135,000 kWh and the peak demand is just below 7,500 kW, occurring in the cooling season. DPSC does not have a backup electrical generating system to supply minimum base needs during interruptions from PECO.

3F IMPACT IF NOT PROVIDED

DPSC will lose about \$1,000,000 per year. DPSC will not have a backup electrical generating system to supply minimum base needs during interruptions from PECO.

3G ADDITIONAL

This ECIP project was developed through a comprehensive study performed by the U.S. Army Construction Engineering Research Laboratories, Energy & Utilities Division. The study is documented in a technical report titled "Central Heating Plant Modernization Study for the Defense Personnel Support Center." DPSC measures savings from the project by comparing the costs of steam, generated electricity, and purchased electricity to the costs of steam produced by the CHP and electricity purchased from the utility company. This will be done for a minimum of 1 year to document savings. Calculations will be made using a PC spreadsheet program.

31 RELATED PROJECTS

1

ENTER SECTION NUMBER 11

- 11 ECONOMIC ANALYSIS DATA
- 11A IS PROJECT EXEMPT FROM ECONOMIC ANALYSIS (Y/N)? = N
- 11B RETRIEVE DATA FROM ECONPACK (Y/N) ? = N
- 11C CONSIDERATION OF ALTERNATIVES

)) New Boilers		10752	Ν
	2) New Boilers/Absorption Ch	iller	10752	N
	3) New Boilers/Cogen		10752	N
	4) New Boilers/Cogen/Absorpt	ion Chiller	10752	N

210

5)	Refurbish	Plant	10752	Ν
6)	Refurbish	Plant/Absorption Chiller	10752	N
7)	Refurbish	Plant/Cogen/Absorption Chiller	10752	Ν

11D ECONOMIC JUSTIFICATION SUMMARY

To provide an equitable comparison for the proposed ECIP project, a baseline or status quo scenario was developed that accounts for the annual CHP operation and maintenance cost including labor, maintenance, and fuel use, and the annual installation electrical use. Table 1 shows the LCC summary for the status quo. Costs are net present worth (Oct 1992 basis). The life cycle cost was analyzed using the methods required by 10 CFR, Part 436, Subpart A, and the "Energy Prices and Discount Factors for Life-Cycle Cost Analysis 1992," NISTIR 85-3273-6.

Table 1. Status quo cost summary.

Initial Investment Costs	0
Energy Costs:	
Electricity \$43,213,000	
Natural Gas \$32,364,000	
Total Energy Costs	\$ 75,577,000
Recurring M&R/Custodial Costs	\$12,123,000
Major Repair/Replacement Costs	\$2,656,000
LCC of all Costs/Benefits (Net PW)	\$90,355,000

Similarly, costs were developed for the suggested alternative. Table 2 summarizes these costs. Based on LCC the project will be \$10 million less than maintaining the status quo.

Table 2. ECIP project cost summary.

Initial Investment Costs	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Energy Costs:	
Electricity \$9,746,000	
Natural Gas \$50,630,000	
Total Energy Costs \$60,376,000	
Recurring M&R/Custodial Costs \$12	2,764,000
Major Repair/Replacement Costs	\$605,000
LCC of all Costs/Benefits (Net PW) \$80	0,619,000

11E ECONOMIC ANALYSIS

INS PRO FIS ANA	LII ENERGY (TALLATION JECT NO. 4 CAL YEAR 1 LYSIS DATI	FE CYCLE COST CONSERVATION & LOCATION: & TITLE: 1 1993 DISCI E: 01-07-93	F ANALYSIS SU INVESTMENT P DPSC CENTRAL HEAT RETE PORTION N ECONOMIC LI	MMARY ROGRAM (ECIP) REGION NOS. ING PLANT MOI NAME: ALT 2 C FE 25 YEARS F	STUDY: LCCID 3 CENSUS:)) PT 6 PREPARED BY:	DPSC 1.062 1 TLM
1.	INVESTMENT A. CONSTI B. SIOH C. DESIGI D. SALVAC E. TOTAL	F RUCTION COST N COST GE VALUE COS' INVESTMENT	r (1A + 1B + 1C	- 1D)		\$ 6165022. \$ 339077. \$ 369902. \$ 0. \$ 6874001.
2.	ENERGY SAV ANALYSIS	VINGS (+) / (DATE ANNUAL	COST (-) SAVINGS, UNI	r cost & disc	COUNTED SAVI	NGS
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUNT FACTOR (4)	DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 26.21 \$.00 \$.00 \$ 3.41 \$.00	83905. 0. 0. 174987. 0.	\$ 2199137. \$ 0. \$ 0. \$ -596706. \$ 0.	15.11 21.31 25.22 20.70 15.93	33228960. 0. 0. -12351810. 0.
	F. TOTAL		-91083.	\$ 1602431.		\$ 20877150.
3.	NON ENERG	Y SAVINGS(+)	/ COST(-)			
	A. ANNUAL (1) D (2) D	RECURRING (ISCOUNT FACTO ISCOUNTED SA	+/-) OR (TABLE A) VING/COST (3A	X 3A1)	14.53	\$ -641450.\$ -9320268.
	<pre>B. NON REG 1. MR/RC</pre>	CURRING SAVI	NGS(+) / COST SAVINGS(+ COST(-) (1) \$2050780.	S(-)) YR DISC OC FAC (2) (3) 0 1.0	CNT DISC TR SAVI COST 00 205	OUNTED NGS(+)/ (-)(4) 0780.
	d. TOTAL		\$2050780.		205	0780.
	C. TOTAL	NON ENERGY D	ISCOUNTED SAV	INGS(+)/COST	(-) (3A2+3Bd4)\$ -7269488.
	D. PROJEC (1) 2	T NON ENERGY 5% MAX NON E A IF 3D1 IS B IF 3D1 IS C IF 3D1B IS D IF 3D1B IS	QUALIFICATIO NERGY CALC (2 = OR > 3C GO < 3C CALC = > 1 GO TO < 1 PROJECT	N TEST F5 X .33) TO ITEM 4 SIR = (2F5+31 ITEM 4 DOES NOT QUAN	\$ 688945 D1)/1F)	9.
4.	FIRST YEA	R DOLLAR SAV	INGS 2F3+3A+(3B1D/(YRS EC	ONOMIC LIFE))\$ 1043012.
5.	TOTAL NET	DISCOUNTED	SAVINGS (2F5+	3C)		\$ 13607660.
6.	DISCOUNTE (IF < 1	D SAVINGS RA PROJECT DOES	TIO NOT QUALIFY)	(SIR)=(5 /	1F)= 1.9	8
7.	SIMPLE PA	YBACK PERIOD	(ESTIMATED)	SPB=1F/4	6.5	9

11F NUMBER OF ADDITIONAL OPERATIONAL PERSONNEL = 1

Project Development Brochure Checklists

<u> </u>		A B C		Į				
<u> </u>	ITEM	80	-0	4 ± 0 ₹	Ý. V			
Į	the second for such of many and supporting facility	R						
A ·1	Cost estimates for well printing and supporting terms	NR						
<u></u>	Conclusion with mate and local advernmental requirements (blind venders, medical fectifiles,							
~	Converties and exercise semility clearinghouse coordination, etc.)	R	D					
		NR						
	A with analysis of alternetives	R	D					
		NR						
	Investigated belance of payments (ISOP) operatingtion with U.S. Europeen semmend and							
.~ ′	NATO everyges cert estimates and comparables (include rate of exchange used in estimates)	NR						
	the to determine the survey by suther lied archeologist and coordination with man							
A4	impect on nation plant and advisory council an historic preservation	NR	i .		·			
		NR						
A-0	Exceptions to entropy and Threat Statement prenared by Provent Mershel/Physical Security	100-2-						
L10	Physical becufity Analysis and Threat Statement proposed by the set	NR						
	Officer	NR						
TIT	Coordination with other versous user start agencies (u/a-2 interigence restarting)	ALR						
¥13	[dentification of related or support projects (so projects can be countineted)	R	B					
A-13	Required completion det	NR						
A-H	Other Special Considerations (list and number items)	100						
REQUI Mun Entr TO BE Entr COMME and d DOCUM	IEDUIRED OR NOT REQUIRED - Net relevant or no information to com- municate. Enter "R" if item is relevant and is required for this project. Enter "NR" if item is irrelevant and is not required for this project. TO BE DETERMINED - Information needed but not currently evaluable. Enter code for information source. TOMMENT ATTACHED - Significant information is in an ealering docu- bocument ATTACHED - Significant information is in an ealering docu-							
	documentation check	lis	t]	ιđ	-c			
A FO	RM 6023-A-R. Jan 87 EDITION OF FEB 82 IS OBSOLETE.							

~

8,	SITE DEVELOPMENT	3 2 2	• •	ĪJ	
	ITEM		7 • 8 •	Conn	
8-1	Consultation with the District Office to determine and evaluate flood plain hazards	NR			
8-2	Preparation, submission, and/or approval of new -				
IN	General She Plan	R	B		
(0)	Annometed General Site Plan	K	Б		
(C)	Shotoh She Plan	R	B		
(0)	Facilities Requirements Sketch	R	B		
	Preparation of				
IAI	Site Survey	R	ں ا		
(8)	Subsoli Information	NR			
8-4.	Approval by Department of Defense Explosive Safety Board (DDESB) for Safety Site Plan	NR			
1.5	Approval of site plan by Provost Marshal/Physical Security (Comparisons with Terrorist Threat				
ł	Assessment)	NR			
	Other Site Development Considerations (list and number Items)	NR			
EQUIA munkc Enter D BE E Enter DMMEN and at DCUME	ED OR NOT REQUIRED - Not relevant or no information to com- tate. Enter "R" if item is relevant and is required for this project. "NR" if item is irrelevant and is not required for this project. DETERMINED - Information needed but not currently available. code for information source. WT ATTACHED - Significant information summarized or explained iteched. INT ATTACHED - Significant information is in an existing docu- which is statched	nd Insert Service Comman	8001801	hed and)r)
	documentation check	lis	t	2 œ	6

	·		_				
1	C. ARCHITECTURAL & STRUCTURAL		• <u>y</u>	EP	=,		
		\] [128	ĘŢ	Ēž		
	ITEM	20	10		N N		
C-1	Reconciliation with troop housing programs and requirements	NR		L			
C 2	Evoluation of existing facilities fincluding degree of utilization)	R	B	L			
<u>c.</u> 2	Approvel for removal and relocation of existing useable facilities	NR					
C-4	Evaluation of off-post community facilities	NR					
C4	Storege and maintenance facilities (including nuclear weapons)	NR					
CA	Coordination hospitals, medical and dental facilities with Surgeon General	NR					
C7	Coordination of eviation facilities with FAA	JR	<u> </u>				
1 24	Coordination air staffic control and navigational aids with USACC	NR					
C.0	Tabulation of types and numbers of aircraft	NR					
C 10	Evaluation of laboratory, research and development, and technical maintenance facilities	JR					
1 211	Coordination chepels with Chief of Chapteins	AR.					
C12	Beview food service facilities by USATSA	NR					
C-13	Automated data processing system or equipment approvals-cost analysis when ADP and/or communication centers not co-located with related facilities	NR					
1	Construction postal facilities with U.S. Postal Service Regional Director	JR					
	Laundry and day cleaning facilities coordination with ASO(IAL)						
1	Carroly and dry creating recently coordination where hited	JR					
1	Feriling for an appendix a supprise to a chamical and empiritude my by DDESB (See						
C.17	also item 8-4)	NR.					
C-18	Analyse of deficiencies	Mrz		}			
C-19	Consideration of alternatives	R	<u>_</u>]			
<u>C-20</u>	Determination whether occupants will include physically handicapped or disabled persons	K	2-				
C-21	As build drawings for alterations or additions	R					
C-22	Availability of Standard Design or site adaptable designs	NK		·			
C23	Evaluation of facilities with Provost Marshel/Physical Security Officer (Installation Terrorist						
	Threet Assument)	NR					
	Other Architectural and Structural (list and number itema)	R	Þ				
					-		
REQUI MUN Ente TO BE Enter COMME and a DOCUM	NED OA NOT REQUIRED — Not relevant or no information to com- cate. Enjor "A" II item is relevant and is not required for this project. r"NA" If item is kreiwant and is not required for this project. DETERMINED — Information needed but not currently available. r cade for information source. NT ATTACHED — Significant information is in an existing docu- tioched. ENT ATTACHED — Significant information is in an existing docu- which is attached.	nd Inters Service Comm in	6001601i N A 116ch	ata kattar ad and	1		
	documentation checklist						

DA FORM 5023-C-R, Jan 87

EDITION OF FEB 82 IS OBSOLETE.

D.	MECHANICAL, ELECTRICAL, & UTILITY SYSTEMS		Required or Not Required	To 8	Comment Attached	Devenui		
			R	D				
0.1	Fuel considerations and cost comparison analysis		R	D				
0.2	Energy requirements appreisel (ERA)		R	D				
0.3	Centermence with DOD Energy Reduction requirements		R	D				
04	Evaluation of existing and/or proposed utility systems							
04	Évaluation of systems with Provost Marshal/Physical Security (Installation	on Terrocht Linnes	112					
	Assessment)		1					
	Other Mechanical and Utility Systems (list and number items)		12	<u> </u>				
ALOU	RED OR NOT REQUIRED - Net relevant or no information to com-	Y WHOM ICheck	end insel	1 00010	priate Het			
mu	nicete. Enter "R" if item is relevant and is required for this project.	A - DFAE						
En	er "NR" if item is irrelevent and is not require the currently evaluable.	B - Using Service	•					
TO BE	er code for information source.	C - Construction	Service					
COMM	COMMENT ATTACHED - Significant Information summarized or explained D - Designer							
end	atisched	E - Other (Chec)	Comm	nii Aili	sched and			
DOCU	MENT ATTACHED - Significant information is in an asisting docu-	explain)						
documentation checklist								
FORM 5023-D-R, Jan 87 EDITION OF FEB &2 IS OBSOLETE.								
			r		r			
---------------------------------------	---	-----------	------------------	-------------------	----------			
	E ENVIRONMENTAL CONSIDERATIONS	1.1	• •	-	-			
				1 E	11			
	ITEM			₹ <u>₹</u>	S S			
	11 E M	R	0	ب	<u> </u>			
E-1	Environmensel Impect assessment	10	<u> </u>					
E-2	EIA conclusions require Environmental Impect Statement							
6.3	Determinetion of nosion, environmental of restrict instruction of the Aberdeen Proving Ground, MD 21010.	-						
	the Office of the Surgeon General, Agr.: DASG-HON (Army Environmental hyginia agency)	K						
14	Air/water pollution permit, coordination with egencies and compliance with standards at a word, state and local level	R	<u>D</u> .					
1.4	Corrective measures associated with Environmental Impect Statements or	JR						
	seeses ment liet separatory and evaluate.	NR						
	Other environmental considerations (list and number Rema)		1					
l								
			ļ					
			1					
		1	1					
		1						
		1			ł			
REOL	JIRED OR NOT REQUIRED - Net relevant ar no information to com-	and inser		riase iem	•r)			
e e e e e e e e e e e e e e e e e e e	micate. Enter "R" If them is relevant and is required for this project. A - DFAE							
TO 8	E DETERMINED - Information needed but not currently available.	Service						
En	ser code for information source.							
COM	d attached.	Cemme	111 A 114	ched and				
Doci	MENT ATTACHED - Significant information is in an existing docu-							
	nt which is ertached.				_			
	documentation check	lic	•	5~~				
	uocumentation check	113	5	2 9				
	ORM 5023-E-R. Feb 82		_					

-		-	- <u>1</u>	T	<u> </u>		
F .	PHYSICAL SECURITY ENHANCEMENT AGAINST TERRORIST THREAT		•	Į Į J	ĒŢ		
	ITEM		- 0	Aller	Aller		
F -1	Properation of the Physical Socurity Survey and Threat Analysis propered by Provest Marshel/ Physical Security	JR					
F-3	Preperation, submission, and/or approval of site pion by Provost Marshel/Physical Security	UR					
13	Evaluation of mission essential project by Prevoit Marshal/Physical Security	NR					
74	Tebulation of America to be protected	NR					
F-8	Evaluation of Ingress/egress time by insuder and security response time	NR					
P-0	Evaluation of Project by G/S-2 Intelligence Personnel	NR					
REQUIR muni Enam TO BE Enam COMME and e DOCUMI mon1	AEQUIAED OA NOT AEQUIAED - Not relevant or no information to camp municate. Enter "A" if item is relevant and is neutred for this project. Enter "NA" if item is irrelevant and is net required for this project. TO BE DETERMINED - Information needed but not currently available. Enter cade for information source. COMMENT ATTACHED - Significant information is in an ealiting docu- ment which is ettached						
	documentation checklist						

D^ FORM 5023-F-R, Jan 87

	A. SPECIAL CONSIDERATIONS	36	• •	ŢŢ	ĪŢ
	ITEM	2 8 2 8 2 9	To 8.	Cont	A H
A-1	Factors of risk, restriction or unusual circumstance expected to increase costs beyond applicable area averages	NR			
	Construction physics requirements	R	D		
1 	Eventional autopart equipment (mechanical, electrical, structural, and security) to be built in	R	D		
	Fouroment in place and justification	R	D		
	Other actingment and furniture (OAMA, OPA) and corts	R	D		
-	Second and the rest (harach analyses, compatibility testing, new technology testing, etc.)	JR			
	Tues of contraction (nermonent, temporary, temporary)	R	B		
A-7 A-8	Government furnished equipment (quentities, procurement time, evailability	R	Ð		
	and special handling and scorage requiremental, runne date to productions	R	D		
TO BE Ente COMME and C DOCUM	icate. Enter "A" if item is relevant and is required for this project. r "NR" if item is irrelevant and is not required for this project. DETERMINED — information needed but not currently evaluable. r code for information source. INT ATTACHED — Significant information summarized or explained istrached. ENT ATTACHED — Significant information is in an existing docu- which is attached.	Service Commen	n Attaci	hed end	
	technical data check	lis	t	1071	r)

DA FORM 5024-A-R, Feb 82

	3. SITE DEVELOPMEN I	quirad a	Be termined	internal Tik Ned	
	ITEM	å ž	۴å	ٽ∢	٥₹
8-1 (A)	Construction restrictions or guidelines pertaining to site access and preferred construction routes	R	в		
(1)	Airfield clearance, explosive storage, working hours, safety, etc.	NR.	ļ		
(c)	Facilities and/or functions or adjoining areas (structures, materials, impact)	R	в		
8-2	Real estate actions (acquisition, disposal, lease, right-of-way)	NR			ļ
8-3	Demolition/relocation required (data)				
. (A)	Special considerations due to explosives/radioactivity/ chemical contamination/asbestos emissions/toxic gases	R	P		
(=)	Restrictions on disposal of demolished/relocated material including hazardous waste	R	в		
8-4	Pavement types and requirements (including traffic surveys and MTMC coordination)	UR			
8-5	Landscape considerations	1.10			
(A)	Protection of existing vegetation		+ - ·		
(8)	Stockpile topsoil	NR			
REQU mu En TO BI En COMM and DOCU me	IRED OR NOT REQUIRED - Not relevant or no information to com- nicate. Enter "R" if item is relevant and is required for this project. The "NR" if item is irrelevant and is not required for this project. EDETERMINED - Information needed but not currently available. The code for information source. IENT ATTACHED - Significant information summarized or explained I attached. MENT ATTACHED - Significant information is in an existing docu- nt which is attached.	ce on Service ck Comm	ents Att	priate le	ττα ²) νσ
	technical data chec	klis	st	2	0F7
DA F	ORM 5024-B-R, Feb 82				

C	ARCHITECTURAL & STRUCTURAL		ad or equired	• 1	Į.	Ę
	ITEM		Requi	To Be Deterr	Aller	000
C-1	Vibration producing equipment requiring isolation		NR			
C-2	Seismic zone and other design load criteria (typhoon, hurricane, earthqui loss potential)	eke loads, high or low	R	D		
<u>c.</u> 3	Protective shelter evaluation and resistant design criteria (conventional/ni tion, chemical/biological)	uclear blast and radia-	JR			
c - 4	Unusual foundation requirements (pier, pile, carison, deep foundations, m permatrost areas, soil bearing)	st, speciel treatment,	UR			
	Designation and strength of units to be accommodated		K	D		
	Persiver and data for backel design or persit		R	B		
				. <u> </u>		
C•/			LID			
<u><u> </u></u>	Security features terms rooms, vauits, interior secure areas		10			
	· · · · · · · · · · · · · · · · · · ·					
			1	ł		
EQUIR munic Enter D BE I Enter DMMEN and at	ED OR NOT REQUIRED - Not relevant or no information to com- cate. Enter "R" if item is relevant and is required for this project. "NR" if item is irrelevant and is not required for this project. DETERMINED - Information needed but not currently available. code for information source. NT ATTACHED - Significant information summarized or explained tucched. ENT ATTACHED - Significant information is in an existing docu-	* BY WHOM (Check and A - DFAE B - Using Service C - Construction Se D - Designer E - Other (Check C explain)	rvice	opropri	ate letter	r)
	technical data	check	is	t	3 GF :	

DA FORM 5024-C-R, Feb 82

	D. MECHANICAL, ELECTRICAL, & UTILITY SYSTEMS	To be	• •		ĘĮ
	ITEM	Regu	4 ° 8 € • 1 € • 1	¥ ¥C	Atte
D-1	Special mechanical requirements or considerations (elevator, crane, hoist, etc.)	UR			ļ
D-2	Special peek usage periods and peak leveling techniques	<u>P</u>	P_		<u> </u>
t.a	Meinwhance considerations (accessibility of equipment, compatibility with existing equipment)	R	<u>P</u>		
D-4	Plumbing-availability, general system type and characteristics (proposed and/or existing, incl. compressed air and gas)	R	D		
D-5	Heating-aveilability, general system type and characteristics (proposed and/or existing)	<u>R</u>	LD_		
D-4	Ventilating, er condition/refrigeration-availability, general system type and characteristics (pro- posed and/or existing)	R	D		
D-7	Electrical-availability, general system type and characteristics incl. airfield lighting, communica- tion, etc. (proposed and/or existing)	R	Ð		
D-8	Water supply/wests treatment-availability, general system type and characteristics (proposed and/or existing)	R	D		
D-1	Energy requirements/fuel conversion (sources, availability, loads, types of fuel, etc.)	R	D		
D-10	Solar energy evaluation	NR			
IEQUI Mun Ente O BE Ente OMME and O OCUM	RED OR NOT REQUIRED - Not relevant or no information to com- licate. Enter "R" if item is relevant and is required for this project. The "NR" if item is irrelevant and is not required for this project. DETERMINED - Information needed but not currently available. In code for information source. INT ATTACHED - Significant information is unmarized or explained attached. EENT ATTA JHED - Significant information is in an existing docu-	Service Commer	approp	rlate latt	•r}
11 91	technical data check	lis	t		

DA FORM 5024-D-R, Feb 82

E1 Wate water treatment, air quality, and solid wate disposed criteria Other Environmental Considerations (List end number teens)			Tran Days	The m
E-1 Waste water treatment, air quality, and solid watte disposel Criteria Other Environmental Considerations (List and number items)	Roz	No. T	E E	N N
Other Environmental Considerations (List and number items)	K	K D	-	
	HR	12		
EQUIRED OR NOT REQUIRED - Not relevant or no information to com- municate. Enter "R" if item is relevant and is nequired for this project. Enter "NR" if item is irrelevant and is not required for this project. O BE DETERMINED - Information needed but not currently available. Enter code for information source. OMMENT ATTACHED - Significant information summarized or explained and statched. OCUMENT ATTACHED - Significant information is in an existing docu- ment which is statched.	and Inser Service	insers appro vice mments Ass	priate lett	•r)

DA FORM 5024-E-R, Feb 82

	F. FIRE PROTECTION	urad or Required	Be ermined	nment sched	turnin tu
	ITEM	R or	T.º 1	¥it ¥it	N N
6.1	Special fire protection systems or features (detection and suppression equipment, hazards, etc.)	R	D		
	Other Fire Protection Considerations (List and number items)	NF-			
REQU m Er TO B COM	URED OR NOT REQUIRED – Not relevant or no information to com- unicate. Enter "A" if item is relevant and is required for this project. Ther "AR" if item is information needed but net currently available. Ther code for information needed but net currently available. Ther code for information needed but net currently available. Ther code for information needed but net currently available. Ther that TACHED – Significant information summarized or explained of attached.	ce ck Comm		spriate H	nd
	technical data chec	kli	st	6	œ₹

DA FORM 5024-F-R, Feb 82

G.	PHYSICAL SECURITY ENHANCEMENT AGAINST TERRORIST THREAT	quind et Requind		Internal Internal	xument Inched
, 	ITEM		۴å	ບິ₹	ŏ₹
0.1	Site Considerations Related to Physical Security Enhancements	NR.			
0-2	She Protective Berriere				
IAI	Active	NK	<u> </u>		
(8)	Pamiro		-2-		
	Architectural and Structural Considerations				
	Protoctive shalters and accure areas	NR			
	Passive Design factures	NR.			
10	Lock and key systems	NR			
<u> </u>					
0-4	Mechanical, Electrical, Utility Systems				
w	Security lighting	1-12-	-2-1		
(8)	801	NR			
707	Communications	M			
10	EMP Protection	14R			
10	Personnel Identification Systeme	INR			
mt	Biological and Chemical Protection for Utilities	INK			
		1 116			
G-5	Other Special Security Features (arms rooms, vaults, nuclear storage, etc.)	1			
IEQUIR munic Enter O BE C Enter OMMEN and at	ED OR NOT REQUIRED - Not relevant or no information to com- am. Ensor "R" If from is relevant and is required for this project. "NR" if item is irrelevant and is not required for this project. DETERMINED - Information needed but not currently available. code for information source. IT ATTACHED - Significant information summarized or explained techod. NT ATTACHED - Significant information is in an existing docu- outs is attached.	nd Insert d Service Commenc	a A tuch	ate lotto	()
	technical data check	lis	t	FOF	7-

DA FORM 5024-G-R, Jan 87



USACERL DISTRIBUTION

Chief of Engineers ATTN: CEHEC-IM-LH (2) ATTN: CEHEC-IM-LP (2) ATTN: CECG ATTN: CECC-P ATTN: CECC-R ATTN: CECW ATTN: CECW-O ATTN: CECW-P ATTN: CECW-PR ATTN: CEMP ATTN: CEMP-E ATTN: CEMP-C ATTN: CEMP-M ATTN: CEMP-B ATTN: CERD-C ATTN: CERD-ZA ATTN: CERD-L ATTN: CERD-M ATTN: CERM ATTN: DAEN-ZC ATTN: DAIM-FDP CECPW 22310-3862 ATTN: CECPW-E ATTN: CECPW-FT ATTN: CECPW-ZC ATTN: DET III 79906 US Army Engr District ATTN: Library (40) US Army Engr Division ATTN: Library (12) INSCOM ATTN: IALOG-I 22060 ATTN: IAV-DPW 22186 USA TACOM 48397-5000 ATTN: AMSTA-XE Defense Distribution Region East ATTN: DDRE-WI 17070 HQ XVIII Airborne Corps 28307 ATTN: AFZA-DPW-EE 4th Infantry Div (MECH) 80913-5000 ATTN: AFZC-FE US Army Materiel Command (AMC) Alexandria, VA 22333-0001 ATTN: AMCEN-F Installations: (19) FORSCOM Forts Gillem & McPherson 30330 ATTN: FCEN Installations: (23) 6th Infantry Division (Light) ATTN: APVR-DE 99505 ATTN: APVR-WF-DE 99703 TRADOC Fort Monroe 23651 ATTN: ATBO-G Installations: (20) Fort Belvoir 22060 ATTN: CETEC-IM-T ATTN: Engr Strategic Studies Ctr ATTN: Water Resources Support Ctr ATTN: Australian Liaison Office USA Natick RD&E Center 01760 ATTN: STRNC-DT ATTN: DRDNA-F

US Army Materials Tech Lab ATTN: SLCMT-DPW 02172

USARPAC 96858 ATTN: DPW ATTN: APEN-A

SHAPE 09705 ATTN: Infrastructure Branch LANDA

Area Engineer, AEDC-Area Office Arnold Air Force Station, TN 37389

HQ USEUCOM 09128 ATTN: ECJ4-LIE

AMMRC 02172 ATTN: DRXMR-AF ATTN: DRXMR-WE

CEWES 39180 ATTN: Library

CECRL 03755 ATTN: Library

USA AMCOM ATTN: Facilities Engr 21719 ATTN: AMSMC-EH 61299 ATTN: Facilities Engr (3) 85613

USAARMC 40121 ATTN: ATZIC-EHA

Military Traffic Mgmt Command ATTN: MTEA-GB-EHP 07002 ATTN: MT-LOF 20315 ATTN: MTE-SU-FE 28461 ATTN: MTW-IE 94626

Fort Leonard Wood 65473 ATTN: ATSE-DAC-LB (3) ATTN: ATZA-TE-SW ATTN: ATSE-CFLO ATTN: ATSE-DAC-FL

Military Dist of WASH Fort McNair ATTN: ANEN 20319

USA Engr Activity, Capital Area ATTN: Library 22211

US Army ARDEC 07806 ATTN: SMCAR-ISE

Engr Societies Library ATTN: Acquisitions 10017

Defense Nuclear Agency ATTN: NADS 20305

Defense Logistics Agency ATTN: DLA-WI 22304

Walter Reed Army Medical Ctr 20307

National Guard Bureau 20310 ATTN: NGB-ARI

US Military Academy 10996 ATTN: MAEN-A ATTN: Facilities Engineer ATTN: Geography & Envr Engrg Naval Facilities Engr Command ATTN: Facilities Engr Command (8) ATTN: Division Offices (11) ATTN: Public Works Center (8) ATTN: Naval Constr Battalion Ctr. 93043 ATTN: Naval Facilities Engr Service Center 93043-4328

416th Engineer Command 60623 ATTN: Gibson USAR Ctr

US Army HSC Fort Sam Houston 78234 ATTN: HSLO-F Fitzsimons Army Medical Ctr ATTN: HSHG-DPW 80045

Tyndall AFB 32403 ATTN: HQAFCESA Program Ofc ATTN: Engrg & Srvc Lab

USA TSARCOM 63120 ATTN: STSAS-F

American Public Works Assoc. 64104-1806

US Army Envr Hygiene Agency ATTN: HSHB-ME 21010

US Gov't Printing Office 20401 ATTN: Rec Sec/Deposit Sec (2)

Nat'l Institute of Standards & Tech ATTN: Library 20899

Defense Personnel Support Center ATTN: DPSC-WI (8) ATTN: DPSC-YE

US Army Engr District, Philadelphia ATTN: CENAP-EN-MM (5)

Defense Tech Info Center 22304 ATTN: DTIC-FAB (2)

> 251 2/95