DEDODTDOCID		Form At	Form Approved		
REPORT DOCUN	VIENIATION PAGE	OMB No.	OMB No. 0704-018		
existing data sources, gathering and maintair burden estimate or any other aspect of this co Directorate for Information and Reports, 1215	niormation is estimated to average 1 nour p ning the data needed, and completing and re ollection information, including suggestion 5 Jefferson Davis Highway, Suite 1204, Arlin	er response, including the time for reviewi sviewing the collection of information. Sen s for reducing this burden, to Washington I igton, VA 22202-4302, and to the Office of	ng instructions, searching Id comments regarding this Headquarters Services, Management and Budget,		
Paperwork Reduction Project (0704-0188), W	ashington, DC 20503.				
1. KOLNOT OGL ONLT (Leave blank)	July 1995	S. REPORT TYPE AND	JATES COVERED		
4 TITLE AND SUBTITLE		5 FUNDING NUMBÉRS	TIT		
Solid State Frequency Conver	rters				
6. AUTHOR(S) Art Leitherer			B		
	NAME(S) AND ADDRESSE(S)	8 REPEORMING ORGAN			
Noval Engilities Engineering Ser	vice Center	NUMBER	NUMBER		
Port Hueneme, CA 93043-4328	vice Center	TDS-2019-E&U			
9. SPONSORING/MONITORING AGE	NCY NAME(S) AND ADDRESSE	S 10. SPONSORING/MONITO NUMBER	10. SPONSORING/MONITORING AGENCY REPORT NUMBER		
			•		
12a. DISTRIBUTION/AVAILABILITY	Y STATEMENT	12b. DISTRIBUTION COD	12b. DISTRIBUTION CODE		
Approved for public releas	se; distribution is unlimited.				
13. ABSTRACT (Maximum 200 words)					
New solid-state static freque produce 400-Hertz (Hz) por electronic components for a percent of the required inpu- generation. In most cases, existing MG sets.	uency converters (SSC) can b ower more efficiently. All gove aircraft or ships use 400-Hz p ut power for existing motor-ge SSCs are cost effective in bo	e used in place of motor-gene ernment installations that use, ower. Overall, SSCs can sav enerator (MG) sets used for 4 th new installations and in the	erator sets to repair, or build e 20 to 25 00-Hz power e replacement of		
	· · · ·				
	· .	DTIC QUALITY IN	SPECTED &		
			T		
14. SUBJECT TERMS Solid state frequency converters (SSC), motor-generator (MG), rectifier, inverter			15. NUMBER OF PAGES		
	Benerino (1120), 100		16. PRICE CODE		
17. SECURITY CLASSIFICATION	18. SECURITY CLASSIFICATION	19. SECURITY CLASSIFICATION	20. LIMITATION OF		
Unclassified	Unclassified	Unclassified	UL		

NSN 7540-01-280-5500

4

Standard Form 298 (Rev. 2-89) Prescribed by ANSI Std. 239-18



TechData Sheet

Naval Facilities Engineering Service Center Port Hueneme, California 93043-4328

TDS-2019-E&U

July 1995

Solid State Frequency Converters

New solid-state static frequency converters (SSC) can be used in place of motor-generator sets to produce 400-Hertz (Hz) power more efficiently. All government installations that use, repair, or build electronic components for aircraft or ships use 400-Hz power. Overall, SSCs can save 20 to 25 percent of the required input power for existing motor-generator (MG) sets used for 400-Hz power generation. In most cases, SSCs are cost effective in both new installations and in the replacement of existing MG sets.

MG sets consist of two main components: the motor and the generator. The conversion process starts with 60-Hz AC input power to a motor. The motor converts electrical energy to mechanical energy via the shaft, which turns a generator. The generator then converts the mechanical energy back to

electrical energy but at 400 Hz; this power is finally supplied to the load. Energy losses occur in both the motor and generator due to heat, windage, and friction.

The SSC is an electronic device and has no moving parts. The main components are the **rectifier** and the **inverter**. The rectifier converts 60-Hz AC input power to DC and then the inverter delivers 400-Hz AC power to the load. This electronic design is inherently more efficient than the mechanical process used by MG sets.

Most SSCs are approximately 20 percent more efficient than equivalent MG sets. SSC full load efficiencies range from 90 percent for units rated less than 50 kVA to over 95 percent for units over 100 kVA. Synchronous MG sets have an average full load efficiency in the range of 70 to 80 percent, while induction MG sets have full load efficiencies in the 65 to 75 percent range. Like SSCs, an MG set's efficiency decreases when the percent load decreases. Figure 1 shows typical efficiency versus percent load curves for all three types of converters.

The savings from an MG set to SSC change-out can be calculated from the output power requirements and the percent load on the existing MG sets. The Naval Facilities Engineering Service Center (NFESC) has developed a spreadsheet to calculate the energy savings, the dollar savings, the savings to investment ratio (SIR) and the simple payback of an SSC retrofit. Figure 2 shows sample output from the spreadsheet using 120-kVA data.

Calculations are based on input from the user or default values in the spreadsheet. Required data includes:



Figure 1. Efficiency versus percent load for MG sets and SSCs.

Approved for public release; distribution is unlimited.

- Operating hours
- MG output size
- Converter output size
- Load efficiencies for both the MG set and the static converter
- Utility rates
- Maintenance costs
- Percent load information

A survey sheet supplied with the spreadsheet can be used to collect data while at the MG set location.

Figure 3 shows the typical payback periods for converting a 120-kVA synchronous MG set and a 120-kVA induction MG set with a 120-kVA SSC. Figure 3 was made assuming 4,160 annual operating hours (two 8-hour shifts for 52 weeks), default maintenance values, and no demand savings. For higher capacity (higher kVA units) retrofits will generally yield shorter payback periods. Figure 3 is a useful "first-run" analysis to see if you should investigate the retrofit further. Keep in mind that rebates or incentives from utility companies will lower initial costs and decrease the payback. Contact your local utility company for more information.

If after reviewing the above information you feel you have a feasible project and would like to investigate the subject further, contact the NFESC, Code ESC22, for a copy of the spreadsheet. If you choose to submit a project for funding, the NFESC can also supply a sample project submittal for converting MG sets to SSCs. If you have further questions regarding the project submission process, contact your local EFD.

More information on SSCs can also be found in NFGS-16306 and MIL-HDBK-1028/6. These specifications are particularly useful when procuring an SSC.

MG/Static Converter Replacement (V	'3.2)	Site:	Sample	Converter
Assumptions		Detail:		Costs
1 MG Output Size, KVA	120		11 Converter Size, KVA	120
2 MG Full Load Eff. %	63		12 Converter Full Load Eff. %	92
3 MG 80% Load Efficiency	60		13 Converter 80% Load Efficiency	91
4 MG 60% Load Efficiency	53		14 Converter 60% Load Efficiency	90
5 MG 40% Load Efficiency	47		15 Converter 40% Load Efficiency	88
6 MG 20% Load Efficiency	40		16 Converter 20% Load Efficiency	86
7 MG NL Losses%FLKVA	28		17 Converter NL Losses %	S
8			18 Converter Cost	\$51,800
9			19 Converter Installation Cost	\$3,626
10			20 Converter Engineering cost	\$3,326
	MG			
21 Annual Operation Hours	4160		31 Converter Life Veers	20
22 % Time at 100% I and	4100		32 STP Evaluation wars	70
22 % Time at 100% Load	10		33 Discount rate %	
24 % Time at 60% Load			34 Electrical Energy Rate (\$/KWH)	0.07
25 % Time at 40% Load	30		35 Investment IIPW	0.98
25 % Time at 20% Load			36 Annual Savings IIPW	14 88
27 % Time at 0% Load	25		37 Electrical Demand Rate (\$/KW)	\$8.00
28 Annual MG Maintenance (\$)	*< <a>		38 Annual Converter Maintenance (s) <u>\$216</u>
			30	
30			40	
Calculations	KWH	\$\$\$	Summary	
41 KWH Savings @100%	12489	\$874	51 Annual Energy/Demand Savings	\$17,782
42 KWH Savings @80%	22674	\$1,587	52 Annual Maintenance (+/-)	\$343
43 KWH Savings @60%	34850	\$2,439	53 Investment Cost	\$58,752
44 KWH Savings @40%	39588	\$2,771	54 Investment Present Worth	\$57,577
45 KWH Savings @20%	33377	\$2,336	55 Savings Present Worth	\$269,696
46 KWH Savings @0%	28704	\$2,009	56	
47 Annual SavingsTotals (KWH)	171682	\$12,018	57 SIR:	4.68
48 KW Savings (KW)	60	\$5,764	58 Simple Payback (Years)	3.24

Figure 2. Sample output from NFESC 400 Hz MG/Static Converter Spreadsheet Version 3.2.





Figure 3. Payback for 120-kVA SSC retrofits.

