ENERGY SURVEY FOR THE UNITED STATES DISCIPLINARY BARRACKS (USDB)

AT

FORT LEAVENWORTH, KANSAS

DEPARTMENT STUTZENES A


Appensed for public colours Distribution Valianied

FINAL SUBMITTAL

ENERGY ENGINEERING ANALYSIS PROGRAM

CONTRACT NUMBER DACA41-89-C-D197

JUNE 25, 1991



KANSAS CITY DISTRICT

CORPS OF ENGINEERS

VOLUME 1

CLARK, RICHARDSON AND BISKUP

Consulting Engineers, Inc., P.C.

UNIVERSAL PLAZA · 6900 NORTH EXECUTIVE DRIVE · KANSAS CITY, MISSOURI 64120

^CR_B

DEPARTMENT OF THE ARMY



CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS P.O. BOX 9005 CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited. Distribution A. Approved for public release.

Marie Wakeffeld, Librarian Engineering

VOLUME 1 - FINAL SUBMITTAL

INTRODUCTION

ENERGY TYPES

19971017 170

COMPUTER SIMULATIONS

	RVATION OBSERVATION (ECO) LISTING
	REDUCE INFILTRATION
	WINDOW REPLACEMENT
	ATTIC INSULATION
	DOCK DOOR REPLACEMENT
ECO-A5	VESTIBULES AND
	SOLAR WINDOW SHADING
	EXTERIOR WALL INSULATION
	ARCHITECTURAL REPAIRS
ECO-M1	SCHEDULE AIR HANDLING EQUIPMENT
	DRY-BULB ECONOMIZER CONTROLS
ECO-M3	SERVICE STEAM PIPING AND TRAPS
ECO-M5	EXHAUST HEAT RECOVERY
ECO-M6	INSULATE DUCTWORK
ECO-M10	CENTRAL PLANT COOLING
ECO-M11	CASTLE AIR SYSTEM REPAIR
ECO-M12	REDUCE STEAM DISTRIBUTION PRESSURE
ECO-M14	SERVICE CONDENSATE RETURN SYSTEM
ECO-M15	BOILER PLANT MODIFICATIONS
ECO-M24	CONVERT FROM STEAM TO HOT WATER
ECO-M25	CONVERT FROM STEAM TO COGENERATION
ECO-M26	REDUCE HOT WATER TEMPERATURE
ECO-M29	DECENTRALIZE HOT WATER SYSTEM
ECO-M30	DOMESTIC WATER PIPE INSULATION
ECO-M31	HEAT RECOVERY FOR LAUNDRY
ECO-M39	WATER HEATING HEAT PUMPS
ECO-E1	LIGHTING LEVELS LIGHTING SYSTEME
ECO-E2	ENERGY EFFICIENT LIGHTING SYSTEMS
	ENERGY EFFICIENT MOTORS

APPENDIX

REFERENCES SCOPE OF WORK MEETING MINUTES

DIAG QUALITY HISPECTED 8



INTRODUCTION

Fort Leavenworth is a government owned and operated armed forces military base located in Leavenworth, Kansas. Located within the Fort Leavenworth jurisdiction is the United States Disciplinary Barracks (USDB). The USDB is located at the northeast corner of the base. The USDB was originally constructed around 1900, and houses military inmates from all military installations across the United States and in foreign countries. The main structure, called the Castle, contains the majority of the inmates and is located within the walls at the north end of the USDB. Originally the compound included the walls and 10 buildings. Since the original construction, 10 additional buildings have been constructed within the walls of the USDB. Over the years the general use of many of the buildings has changed. Because of these changes, many buildings were remodeled to accommodate their new functions.

Purpose of this Study


The main purpose of this study was to investigate Energy Conserving Opportunities (ECO's) for energy projects. An energy conserving opportunity is any change in the existing physical construction or operating practices of the USDB that can lessen the amount of energy utilized in the form of water, electricity, fuel oil, and natural gas. Any of the individual ECO projects studied can be merged to form a larger project with discrete parts. The main funding group is the Energy Conservation Investment Program (ECIP) for projects with a construction cost exceeding \$200,000, a Savings to Investment Ratio (SIR) of greater than one, and a simple payback period of less than 10 years. The second funding group is the Military Construction Army (MCA) for projects with a construction cost exceeding \$200,000 and a SIR of greater than one. In addition, to qualify for the MCA funding, all of the discrete parts of the project have to have a SIR greater than one. The third funding group is the Non-ECIP for projects that do not meet ECIP criterion but have an overall SIR greater than one.

Scope of this Study

The scope of this study was to survey the buildings of the USDB for energy conservation opportunities. The study was limited to a number of buildings located within the walls of the USDB. The following table displays the buildings studied by number, the approximate square footages, and the general use of each building.

Building Number	Square Footage	General Use of the Building by the USDB
450	9,200	Mental Hygiene Clinic
463	7,700	Command Group, South Gate, Visitors Room
464	6,700	Office, Barber Shop
465	34,500	Inside Barber Shop, Minimum Security
466	22,300	Minimum Security, Carpentry, Masonry
472	19,300	Vocation Printing, Education
473	12,400	Classification
474	7,800	Pope Hall
475	90,981	Rotunda, Control, Laundry Issue
475A	17,900	DOC, Investigations, Chapel
475B	11,100	Dining Facility, Chapel, Library, Band Room
475C	46,800	3-Wing, Housing Unit, Reception, ID
475D	54,400	4-Wing, Housing Unit, 4 Base
475E	91,000	Dining Facility, DLS, Gym, Mail Room, Property
475F	54,400	6-Wing, Housing Unit
475G	46,800	7-Wing, Housing Unit, Officer/Female Housing
475H	11,100	MSA, D & A Board, TDS, DMH

The locations of the various buildings displayed in the previous table are shown in figure 1.1 which is a general map of the USDB.



The scope of work for this project as presented by the Corps of Engineers is located in the Appendix.

All of the ECO considered fit into three categories; architectural, mechanical, and electrical. The architectural ECO's considered were projects that changed the construction of the buildings. The mechanical ECO's were projects that changed the space air conditioning equipment and auxiliary equipment or the operation of equipment. The electrical ECO's were projects that changed the lighting or motor equipment or the operation of these systems.

Work Performed

A complete list of feasible ECO's to be studied in this project was compiled using; the list presented in the "General Scope of Work" by the Corps of Engineers, and meetings with the Director of Engineering and Housing (DEH) at Fort Leavenworth. A comprehensive list of the ECO's studied in this report is located in the ECO listing section of this Volume. Any of the ECO's listed in the "General Scope of Work" for this project that were not studied were considered not feasible. These are also shown behind the tab "ECO Listing". The ECO's were numbered relating to the discipline of the ECO, starting with an "A" for architectural, "M" for mechanical type, and "E" for electrical. The numbers of the ECO's are not consecutive because they were numbered from the "General Scope of Work", and some of the ECO's were combined or were not studied. A method for calculating the energy associated with the ECO project was determined next. Some of the energy calculations were completed using a computer simulation model of the buildings. A description of the computer simulations is located in the computer simulations section in this Volume. Other ECO's not evaluated with a computer simulation were studied with energy calculations located in each ECO section in this Volume.

The evaluation of the ECO's started with a number of field trips to the Fort Leavenworth. During each field trip, detailed field sheets were filled out containing the majority of information used to build computer models of each of the buildings to be studied for energy conservation. The field sheets contain information relating the number of people, lights and equipment located in a space and the schedule with which each occurred during a typical day. The field sheets also encompassed the physical construction of the building, the exterior wall construction, the number and types of doors and windows, and the type and structure of the roof. The field sheets are located in Volume 5 of this report. A valuable part of the field trip was conversations with the Officers or maintenance personnel located in or in charge of the operation of the equipment and the building. All the facts about the buildings were collected and used in building the computer models and calculating the energy used for each of the ECO's.

The majority of the building information aided in developing a computer model of each of the buildings. The models were built to run a computer simulation to evaluate the energy used by the building in its existing condition and with the ECO project completed. All of the information used to build the models was taken during a field trip or was determined by an ASHRAE¹ typical average. One instance where the ASHRAE methodology was used, was building 475E, where the building at the present time is vacant waiting to be remodeled. In that case, no information could be obtained by a field trip therefore, a set of plans for the remodel was studied and averages were considered for the models. With the models built, a base load was executed to obtain an existing energy use for each building. After the base energy use for the building was determined to be reasonably accurate, the computer model was changed to reflect the construction of the ECO project.

The computer model was changed to reflect the ECO implementation and was executed to determine the energy use by the building if the ECO project were completed. The base energy use and all of the various energy uses for the ECO projects studied are located in Volumes 2, 3, and 4 of this report. Some of the ECO energy savings were not determined using the computer simulations but formula calculations. These calculations are located with each ECO section.

Existing Building Conditions

Besides a few individual cases as detailed in section ECO-A9 of this report, the buildings were in fair shape architecturally. The majority of the buildings have had insulated glass installed within the past 10 years. Although the window itself in most cases was in good shape the fit of the window in the exterior wall

INTRODUCTION

was terrible. Some of the exterior doors to the buildings lacked adequate weatherstripping. Over half of the buildings studied in this report had their roofs replaced recently and good insulation was incorporated.

The general condition of mechanical heating and cooling equipment was poor. The majority of the controls that operate the equipment did not function and the controls that did function were not operating correctly to make the equipment perform. Many of the air handling units were altered to, what looked like, suffice for the present situation. When the season changes outdoors the air handling units are fixed to accommodate the new heating or cooling function required. All of the air handling units and auxiliary heating and cooling equipment should be cleaned to allow them to function better. During several of the field trips, personnel working in the spaces complained about the room uncomfortable conditions.

Electrically, all of the lighting systems functioned and were fluorescent. Only a few incandescent lights exist and their replacement was considered in ECO-E1.

Facility Maintenance

The maintenance personnel for the USDB is not a large work force. The work force is divided into the major types of maintenance to be performed; mechanical, electrical, and plumbing. In a discussion with the maintenance department, it was determined that their number of personnel is only enough to keep up with the repair work to be performed due to a failure. In many cases inmates lacking skills are utilized to work on the equipment. A large amount of energy is lost from the equipment not being maintained. An energy savings could be recovered by repairs of existing equipment, but actually, the energy savings is false because the piece of equipment should have been maintained. For the size of work force available to maintain the entire USDB, many energy saving plans are already in place. The personnel are energy minded and seem to know of many cases where a repair could save energy. A sizeable amount of pipe insulation has been done because bare steam piping was exposed. A regular routine of checking steam traps for bypassed steam is enabled when possible. The number one maintenance item to be considered is the controls for all the equipment. In almost every case the controls were in place but not functioning or calibrated, therefore overheating or cooling. A one time contract

with an outside control service to check for repair and calibration is a strong suggestion.

The notable exception, is the boiler plant where full time boiler operators are employed to take care of the equipment.

Previous Studies of the USDB

In 1980 the entire Fort Leavenworth Post was studied for energy savings. An "Integrated Energy Master Plan" was developed. This study is a detailed portion of the original master plan for energy savings and takes into account any additional energy conserving opportunities that have become evident since the submitted master plan. Since the earlier master plan dealt with Fort Leavenworth on a global scale, a detailed analysis was not presented for the part of Fort Leavenworth studied in this report, the USDB.

The ECO's that were developed in the Energy Evaluation Anticipated Program (EEAP) were studied in detail in this report. A complete and comprehensive ECO listing for the USDB as part of this report is located in this Volume under, ECO listing. Some ECO's were presented in the EEAP but are not feasible at this time due to physical construction or operating procedures. The reasons for not considering some of the ECO's established in the EEAP are defined in the same section.





ENERGY TYPES

The present utilities used at the USDB are; natural gas, fuel oil, water, and electricity. The amount of energy used by the boilers for the production of steam is converted to natural gas for the purpose of calculating energy costs in this report. All of the costs in dollars per unit of energy were calculated from information gathered from the DEH located at Fort Leavenworth.

The USDB is located in and falls under the jurisdiction of the Fort Leavenworth Military Base and receives it's electricity from the main Post feed. The electricity for the USDB is not metered separately. The Fort Leavenworth Military Base purchases electrical power from Kansas Power and Light (KPL) at a racheted rate depending on the amount of power being used at any one time by the entire base. For the purposes of this report and to simplify the calculations of dollars expended for a unit of electricity, the cost for a unit of electricity will be a set amount. The cost in dollars per KWh paid by the base was calculated to be \$0.0425/KWh.

The USDB utilizes high pressure steam boilers to heat the buildings located within the walls and for the laundry located within the walls. The boilers are esentially the only equipment using natural gas. Therefore, instead of calculating a utility cost of natural gas to be used in calculating the energy usage for each building, a cost for a therms per hour (therms/hr) was calculated. A therm/hr of energy is equal to 100,000 pounds of steam/hr. The cost of steam used in this report was calculated to be \$0.0534/MBTUh. The calculation for the cost of steam was:

Natural Gas Cost:	\$4.00/MCF (1000 ft. ³)
Energy per ft ³ :	1,000 Btu/ft.3
Boiler Efficiency:	80%
Boiler Make-up:	6%

(\$4.08/MCF)(1 MCF/1000 CF)(1 CF/1000 BTU)(1,000,000 BTU/MBTU) =\$4.08 / MBTU With a global steam production efficiency of 74%, energy cost is \$5.51/MBTU





Fort Leavenworth Military Base has a water treatment plant. None of the ECO's studied in this report consider the reduction in the amount of cold water received from Fort Leavenworth's water treatment system.

The energy consumption for the buildings studied as a total is shown per month in Table 1.1 and graphed in Figures 1.1 and 1.2.

MONTH	STEAM CONSUMPTION (therms)	ELECTRICITY CONSUMPTION (KWh)
January	38,691	184,945
February	35,643	165,192
March	33,399	189,410
April	10,596	168,277
May	87	163,499
June	12	238,151
July	0	268,027
August	0	260,588
September	113	195,114
October	235	155,269
November	19,550	168,693
December	46,196	173,686

Table 1.1

1-64,522

2,330,651









Figure 1.1

ENERGY TYPES



Month of Year (January - January)

Figure 1.2

ENERGY TYPES

COMPUTER SIMULATIONS

The computer program allows the user to physically model a building by inputting known dimensions and capacities of the building and equipment. The parameters the program uses to calculate the energy usage include; occupant load, equipment load, and weather conditions. Changes in the weather bring about changes to interior space conditions and therefore increase and decrease the energy consumed by the building for heating and cooling the space.

Energy Program

The computer program used for the majority of the energy calculations for this report, was "Trace Ultra ". This computer program was developed and is serviced by the Trane Company in LaCrosse, Wisconsin. The program allows the user, to model the building using the through menu driven screen displays. The program has several calculation alternatives available to the user once the model is input. The program allows the user to execute a "load" run, which calculates the largest amount of air conditioning needed to satisfy space conditions within the building. With the largest amount of air conditioning load known, a piece of HVAC equipment can be sized for the spaces. In most cases, the building equipment size was known by site observation, but where a nameplate or records were unavailable, equipment was sized for the model using the "load" calculation part of the program. Another calculation utilized in the program, was the energy simulation which calculated the energy consumed by the HVAC equipment to satisfy the space conditions on an hourly basis for an entire year. The energy simulation takes into account people and equipment moving in and out of a space and the changing conditions of the weather outside.

Program Schedules

The program utilizes schedules to know when equipment and lights are on and off, know when people are in and out of spaces, and know when the conditions of the space need to be satisfied. The schedules utilized for the models executed in this report are located in the Volume 2, Program Schedules.

Wall and Roof Types

The heat transfer to and from the interior spaces of the buildings through the exterior walls and roofs constitutes a major source of energy consumption. The heat transfer coefficient of the wall or roof, known as the "R" or "U" factor, is used to determine the amount of energy transferred through the wall or roof. The "U" factor is the inverse of the "R" factor or, U=1/R. The program accepts the "U" factor as input for the wall and roof coefficients and assigns it units of BTUh/Sq.Ft.•Hr.•°F. The wall and roof coefficients used for the buildings studied in this report were determined using a computer calculation available within the "*Trace Ultra*" program. All of the wall and roof coefficients used are located in Volume 2, Program "U" Values.

Computer Model Input

The computer models representing the buildings studied in the USDB were entered in the computer using a screen menu penetration scheme. The "*Trace Ultra*" program prompts the user for input on a fill in the blank basis. The program prompting the user for all of the input insures that none of the input necessary and relevant to computing the energy consumed by the building was left unentered.

Computer Model Output

The program calculates the energy consumed by the HVAC and auxiliary equipment in the building and creates an output file to be printed on the screen or a line printer. The output file contains many forms of the energy information about the building. The energy consumption for the building can be printed off in several different forms using the same values. One of the outputs allows the user to compare the overall wall, roof, and building "U" values to the ASHRAE 90 guidelines. The table, on the following page, displays the base load of the buildings in their existing condition.

æ, [:]

BASE LC	AD BUILDING SIN	IULATIONS
Building	Electrical	Steam
Number	(KWh/yr)	(therms/yr)
450	135,466	3,629
463	80,795	1,481
464	84,234	822
465	228,068	35,995
466	208,461	1,103
472	234,490	15,515
473	148,420	2,407
475	58,399	13,619
475A	146,357	12,773
475B	95,207	8,477
475C	45,478	13,472
475D	53,358	15,188
475E	611,712	21,657
475F	53,357	15,926
475G	45,481	12,853
475H	87,858	8,137
Totals	2,317,141	183,054

Table 1.1

But 1000 1010 = 280

The computer simulation printout for the base load, reflected in the proceeding table, and all of the ECO alternate executions are located in Volumes 2, 3, and 4.

ENERGY CONSERVATION OPPORTUNITIES LISTING

This section lists the Energy Conservation Opportunities (ECO's) that were studied as part of this report and also ECO's that were considered, but not studied because it was considered not to be feasible at this time. Along with the ECO's considered feasible, a brief description of the opportunity for energy savings is included.

Feasible ECO's

<u>Reduce Infiltration (ECO-A1)</u>: This opportunity for energy conservation deals with the reduction in the amount of outside air infiltrating into the building. At the present time, most of the windows and doors for the buildings located in the USDB have large cracks that allow outside air to infiltrate into the building. If an excess amount of outside air is infiltrating into the space through windows and doors, an excess amount of energy is consumed.

Window Replacement (ECO-A2): This ECO studied the installation of double glazed windows anywhere single glazed windows exist. The replacement of any window with a window having a smaller "U" value decreases the amount of heat transferred to and from the space. Infiltration into the building is also usually decreased because the new windows seal the opening better.

Attic Insulation (ECO-A3): This ECO studied the addition of insulation to the attic. The additional insulation in the attic increases the "R" value for the attic and roof and decreases the "U" value. The decreased "U" value relates a decreased amount of heat transferred to and from the interior spaces of the building.

<u>Dock Door Replacement (ECO-A4)</u>: This opportunity for energy conservation is relevant to a dock door located in building 470. The present overhead dock door needs to be replaced. The energy savings associated with a new door is derived from a reduction in heat transferred to and from interior spaces, and from decreased infiltration.

<u>Vestibules (ECO-A5)</u>: This ECO studied the installation of vestibules for the southgate, building 463. At the present time, no vestibules exist at the entrance

or exit of this building. Especially during the heating season, the heating equipment runs non stop to try and satisfy the space conditions. Most of the time the temperature conditions are not met. The installation of a revolving door on the south entrance and a vestibule on the north will reduce the amount of outside air infiltrating into the space. The existing vestibule leading into rotunda of the castle is considered for service in ECO-A9.

Solar Window Shading (ECO-A6): This energy conserving opportunity was studied for all the buildings having cooling. The reduction in solar gain to a building from the sun through an unshaded window is beneficial during the cooling season but not during the heating season. The solar shading reflects the sunlight from heating an interior space during the cooling season, but also reduces the solar gain in the winter when it is beneficial.

Exterior Wall Insulation (ECO-A7): This ECO studied the addition of wall insulation to exterior walls. This ECO is difficult to implement in a facility of this nature. The materials necessary for the addition of wall insulation, have a reasonable resistance to damage, and have sizable material and labor costs.

Architectural Repairs (A9): This section is not an ECO, but a study of any architectural repairs for the buildings located within the USDB. Many of the items considered do not have a direct relationship to an energy savings, therefore the items listed in this section are recommended service items for the USDB.

<u>Schedule Air Handling Equipment (ECO-M1)</u>: This ECO studied the scheduling of HVAC equipment to shut down or setback any equipment because the space is not being utilized and space temperatures do not need to be met.

<u>Dry-Bulb Economizer Controls (ECO-M2)</u>: This ECO studied the service or addition of economizer controls and dampers to air handling units utilizing outside air at the present time. Most of the air handling units studied had or have economizer controls and dampers but do not function properly.</u>

<u>Service Steam Piping and Traps (ECO-M3)</u>: This ECO studied the addition of pipe insulation and steam trap replacement. Energy savings are shown in a reduction of steam use if the piping is insulated and failed traps are repaired so they do not pass steam into the condensate piping.

Exhaust Heat Recovery (ECO-M5): This ECO studied the addition of a heat recovery system for the exhausted air from the cell barracks in the castle. The location of the heat recovery system is ideal because the exhaust air is directly adjacent to the intake air to be preheated.

Insulate Ductwork (ECO-M6): This ECO studied the addition of insulation to ductwork located off of air handling units. The heat transferred from inside the ductwork to outside the ductwork is a function of the heat transfer coefficient of the ductwork material. Adding insulation to the ductwork improves the heat transfer resistance and therefore limits the amount of energy lost.

<u>Central Plant Cooling (ECO-M10)</u>: This ECO studied the replacement of all the package air cooling equipment to a central plant chiller producing chilled water for cooling coils. In almost all of the cases where a space is being cooled a package direct expansion type of cooling is utilized. The cost per BTUh of cooling by a direct expansion type of machine is greater than the cost per BTUh of chilled water system cooling.

<u>Castle Air System Repair (ECO-M11)</u>: This ECO studied the energy savings associated with properly heating and ventilating the cell barracks of the castle. At the present time, the air within the cell barracks is stratified and the amount of heating that is applied does not reach the bottom floors.

<u>Reduce Steam Distribution Pressure (ECO-M12)</u>: This energy conserving opportunity deals with reducing the steam pressure needed for the USDB. The needs of the laundry are 120 psi steam, but the rest of the steam is used for heating and can be at a lower pressure. A lower pressure steam costs less to generate.</u>

<u>Service Condensate Return System (ECO-M14)</u>: This ECO studied the condensate system. Much of the condensate system needs to be insulated and repaired. By insulating the condensate piping, the condensate returns to the boiler plant at a higher temperature thus requiring the boilers to do less work to produce steam.

Boiler Plant Modifications (ECO-M15): This ECO studied the boiler plant and any modifications that could save energy. The energy lost during a blowdown

of a boiler can be recovered and used to preheat the boiler feedwater. Installing a boiler stack economizer is also another possible method of heat recovery off of the boilers. Preheating the combustion air to the boilers will save boiler energy. Oxygen trim control will help improve the operating efficiency of the boilers.

<u>Convert From Steam to Hot Water (ECO-M24)</u>: This ECO studied the conversion of the existing steam system to a hot water system. The cost per BTUh for heating using steam is larger than the cost per BTUh for heating with hot water.

<u>Convert From Steam to Cogeneration (ECO-M25)</u>: This ECO studied the conversion of the existing steam system to cogeneration. Cogeneration is possible if a large heat energy and cooling energy occur at the same time for a long period of time.

<u>Reduce Hot Water Temperature (ECO-M26)</u>: This opportunity studied the energy savings associated with a reduction of the domestic hot water temperature used for restrooms and showers. An energy savings can be realized by lower heat losses from the water lines.

<u>Decentralize Hot Water System (ECO-M29)</u>: This ECO studied the breakup of the domestic hot water system. At the present time several buildings are served from a hot water tank located in one building. By decentralizing the hot water system, the heat loss can be decreased.

<u>Domestic Water Pipe Insulation (ECO-M30)</u>: This energy conserving opportunity evaluated the installation of pipe insulation on the domestic hot water piping. Energy is saved by reducing the amount of heat loss.

<u>Heat Recovery for Laundry (ECO-M31)</u>: This ECO studied the addition of heat recovery units for the laundry wash water, dryers, and steam irons to recover water heat.

<u>Water Heating Heatpumps (ECO-M39)</u>: This ECO studied the replacement of the existing heating and cooling equipment with a heatpump. In general heatpumps have a greater efficiency than the types of heating and cooling in the USDB buildings.

Lighting Levels (ECO-E1): This ECO studied the reduction in lighting levels in areas where the existing lighting was considered to be more than necessary.

<u>Energy Efficient Lighting Systems (ECO-E2)</u>: This ECO studied the replacement of existing lighting systems with more efficient lighting systems of the same light level. The replacement of lights would reduce the electrical consumption of the lighting system.

<u>Energy Efficient Motors (ECO-E3)</u>: This ECO studied the replacement of existing motors that operate fans and pumps with high efficient motors that have a higher KWh per horsepower rating. The increase in motor efficiency will decrease the amount of electrical energy used by the motors.

Non-Feasible ECO's

<u>Prevent Air Stratification</u>: This opportunity for energy savings is only feasible where stratification can occur. The only places that were evident of air stratification was the tall ceilings located in the cell barracks of the castle. The solution to the air stratification was studied in ECO-M11, which looked at repairing the castle's air handling systems.

Install Electrical Capacitors: This opportunity for energy savings is only feasible where a power factor less than 1.0 occurs. Based on a telephone conversation with the electrical utility for the USDB within Fort Leavenworth, no power factor charge has been charged to the USDB.

Install Flow Restrictors: This opportunity for energy savings occurs in a facility where a large amount of water is consumed by faucets in restrooms. The USDB does not have an extreme number of restrooms utilized on a regular basis. The only place where an extreme amount of water could be used, due to the number of people, would be the cell barracks where the cells are already designed for limited use.

Install Automatic Shutoff Valves: This opportunity for energy savings is similar to the flow restriction in that not an exceedingly amount of water is consumed by the restrooms within the USDB.

Laundry Heat Recovery: The opportunity for energy savings for the laundry was studied as one ECO because the laundry facility was relocated, due to a present project, into the boiler plant.

<u>Kitchen Heat Recovery</u>: This opportunity for energy savings was limited because the kitchen was remodeled, due to a present project. Some of the possible energy saving opportunities were considered in other global ECO's. The exhaust air and make-up air systems were retrofitted under the current project. Shutting off appliances when not being utilized is an operational consideration and not something that can be addressed in an energy study.

<u>Reduce Outside Air Intake</u>: This opportunity for energy savings was incorporated into ECO-A1, a reduction in infiltration. The energy savings associated with heating or cooling outside air before it's use is encompassed in reducing the amount of outside air infiltrating through window and door cracks.

<u>Maintain Equipment</u>: The energy associated with maintaining equipment is difficult to show in a calculation for savings of equipment repair. To recover an energy savings due to a maintenance item, the work was encompassed in various ECO's where savings could be shown.

<u>Boiler Plant Efficiencies</u>: The energy conserving opportunities for the boiler plant were all combined into one ECO. Many of the ECO's relied on another ECO to show a savings. For instance, the energy recovered from a boiler blowdown has to be utilized somewhere else to show a savings. Therefore the feedwater preheat was combined with the blowdown recovery.

ECO LISTING

ECO-A1

REDUCE INFILTRATION





ENERGY CONSERVATION OPPORTUNITY: ECO-A1

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-A1) analyzes the energy savings associated with reducing the amount of infiltration into the majority of the buildings located in the USDB. The implementation of this project will not change any of the existing window or door arrangements for any of the buildings.

SCOPE:

The ECO simulation (ECO-A1) adds additional weatherstripping and caulking to the existing windows and doors of the buildings to seal the cracks that are letting through outside air. The application of this project was considered for the following buildings:



Building 463 Building 464 Building 465 Building 466 Building 472 Building 473 Building 475 Building 475A

Building 475B Building 475C Building 475D Building 475E Building 475F Building 475G Building 475H

MODELING TECHNIQUES:

The modeling technique used to calculate the present infiltration rate for the windows and doors was determined using an infiltration calculation method as described the ASHRAE load calculation handbook¹. All of the exterior windows and doors for the buildings being considered are shown in the schedules for each building, Volume 3. The windows and doors were then fit into one of several categories describing the free area to the outside. The categories that the windows fit into were based on the crack width around the windows and the doors. A loose fitting window was considered to have a small or 1/4" crack. A medium fitting window was considered to have a 1/8" crack and a tight fitting window would have a 1/16" crack. With the tightness and the crack length a free area was determined. A differential pressure chart¹, was used to find the driving force, based on a wind speed of 10 mph, for the air to be infiltrated. Using the differential pressure and the free area of the crack, an amount of infiltration was determined. ASHRAE guidelines for general constructed buildings state that the infiltration total for the building is about 1.5 air changes per hour. The infiltration from



window and door cracks should be approximately 10% of the total infiltration for the buildings. The amount is infiltration calculated for the buildings considered fell into this guideline. This infiltration amount was entered into the computer simulation models to calculate the energy usage of the building. Using the same electronic spreadsheet, as shown in for each building in Volume 3, a new window and door infiltration value was determined based on the windows and doors having a tight fit, with the addition of new weatherstripping and caulking. The ECO infiltration value was entered into the same computer simulation model and executed for an energy usage. The calculation procedure for this ECO is displayed under ECO-A1, Volume 3. The difference in the energy usage before and after the implementation of the ECO was the energy savings from the ECO.

ECO IMPLEMENTATION:

The method of implementing this ECO is not difficult and could be completed by the maintenance staff with the walls of the USDB. In most cases, each of the window or door frames needs to have a bead of caulk placed between the wall and window or door frame. Almost all of the double hung windows need to have the seal between the sashes replaced with a new thicker seal with new rubber. To install new rubber seal, the upper and lower sash need to be separated and old seal removed from the track that it sits in. With the old seal removed the new seal can be fed into the channel from one of the ends. The cost estimate displays the windows in which of the buildings needs to be weatherstripped.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown in Table A1.1 in million BTU's per year savings as determined using the computer simulation model located in Volume 2.

The project cost is the construction cost as determined in this section plus 6% SIOH.

Many of the buildings show a poor energy return on the investment of weatherstripping the windows and doors because the buildings are heating only. This ECO does not show a good payback because many of the buildings are heating only building. Another reason for the poor payback is that some of the buildings have at the present time, no means of bringing in outside air for current ventilation standards of 15 CFM per person. The standard 15 CFM per person was used for the computer simulations after the windows and doors are sealed. Building 466 shows as unusually low energy savings due to the fact that the building has a base board radiant heating system and no other energy using systems.



ECO-A1



Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
463	12	\$49	\$11,254	163.91	0.10
464	9	\$42	\$5,882	97.68	0.15
465	256	\$1058	\$65,089	11.22	1.44
466	1	\$8	\$19,199	4544.0	0.00
472	62	\$265	\$26,516	72.34	0.22
473	12	\$54	\$12,985	168.40	0.09
475	15	\$59	\$8,337	96.26	0.17
475A	93	\$399	\$10,074	17.83	0.89
475B	16	\$65	\$10,380	109.2	0.15
475C	42	\$171	\$33,721	137.01	0.12
475D	48	\$195	\$40,013	142.94	0.11
475E	53	\$146	\$44,628	168.33	0.11
475F	89	\$365	\$40,269	77.80	0.21
475G	41	\$169	\$34,670	146.53	0.11
475H	20	\$85	\$8,017	69.00	0.23

Table A1.1





ECO-A1

LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGION N PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: 463A1 ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YEARS PRI	IOS. 7 EPARED E	CE	USDBAE D 1.035 NSUS: 2
 INVESTMENT CONSTRUCTION COST SIOH DESIGN COST ENERGY CREDIT CALC (1A+1B+1C)X.9 SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E) 		\$ \$ \$ \$ \$ • • \$	10617. 637. 584. 10654. 0. 10654.
2. ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAV	INGS		
	COUNT TOR(4)	DISCO SAVIN	UNTED GS(5)
A. ELECT\$12.440.\$0.B. DIST\$.000.\$0.C. RESID\$.000.\$0.D. NAT G\$4.0816.\$65.E. COAL\$.000.\$0.	11.16 17.19 17.12 16.15 13.92		0. 0. 0. 1050. 0.
F. TOTAL 16. \$ 65.		\$	1050.
3. NON ENERGY SAVINGS(+) / COST(-)			
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) 11.65		\$	0.
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3A2+3B	d4)	\$	0.
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) \$ A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = (2F5+3D1)/1F)= C IF 3D1B IS = > 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY	347.		
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOMIC LIF	Έ))	\$	65.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)		\$	1050.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= (IF < 1 PROJECT DOES NOT QUALIFY)	0.10		
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4	163.91		



PAGE A1-4

PROJECT N FISCAL YEA	Energy Conserva Ion & Location: Fo Io, & Title: 1496	OST ANALYSIS TION INVESTMI RT LEAVENWO SCRETE PORTI ECONOMIC I	ENT PROG ORTH - US ON NAME:	RAM (EC DB REG 464A1	CIP) NON NOS. 7 PREPARED	LC	/: USDBAE CID 1.035 CENSUS: 2
B. SIOH C. DESI D. ENEF E. SALV	MENT STRUCTION COST GN COST GY CREDIT CALC (1 /AGE VALUE COST NL INVESTMENT (1D-1					\$ \$ \$ \$ \$ \$ \$ \$ \$ \$	5549. 333. 305. 5568. 0. 5568.
2. ENERGY ANALYS	/ SAVINGS (+) / COST IS DATE ANNUAL SAV	(-) /INGS, UNIT CC	OST & DISC) SAVINGS		
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		IAL \$ IGS(3)	DISCOUNT FACTOR(4)		COUNTED 'INGS(5)
A. ELEC B. DIST C. RESII D. NAT (E. COAL	\$.00 D \$.00 G \$ 4.08	1. 0. 0. 11. 0.	\$ \$ \$ \$ \$	12. 0. 0. 45. 0.	11.16 17.19 17.12 16.15 13.92		134. 0. 0. 727. 0.
F. TOTAL	-	12.	\$	57.		\$	861.
3. NON EN	ERGY SAVINGS(+) / C	OST(-)					
A. ANNU (1) DI	JAL RECURRING (+/-) ISCOUNT FACTOR (T/			11.65		\$	0.
(2) DI	SCOUNTED SAVING/	COST (3A X 3A	A1)	11.05		\$	0.
C. TOTA	L NON ENERGY DISC	OUNTED SAVIN	NGS(+) /CC	DST(-) (3/	A2+3Bd4)	\$	0.
(1) 25 A B C	ECT NON ENERGY QI 3% MAX NON ENERGY IF 3D1 IS = OR > 3C G IF 3D1 IS < 3C CALC IF 3D1B IS = > 1 GO T IF 3D1B IS < 1 PROJEC	' CALC (2F5 X O TO ITEM 4 SIR = (2F5+3D O ITEM 4	.33) 1)/1F)=	\$	5 284.		
4. FIRST YE	AR DOLLAR SAVINGS	S 2F3+3A+(3B1[D/(YEARS I	ECONOM	IIC LIFE))	\$	57.
	ET DISCOUNTED SAV					\$	861.
6. DISCOUN (IF < 1 PR	ITED SAVINGS RATIO	JALIFY)	(SIR)=((5 / 1F)=	0.15		
7. SIMPLE P	AYBACK PERIOD (ES	TIMATED) SF	PB=1F/4		97.68		



۶ F	ENER NSTALLATION & ROJECT NO. & 1 ISCAL YEAR 199 NALYSIS DATE:	DIS	TON INVES RT LEAVEN CRETE PO	TMENT PRO)GRAM (EC JSDB REG E: 465A1	CIP) NON NOS. 7 PREPARED	L	DY: USDBAE CCID 1.035 CENSUS: 2
	E. SALVAGE F. TOTAL INV	CTION COST OST CREDIT CALC (1/ VALUE COST ESTMENT (1D-1	E)	9			\$ \$ \$ \$ - \$	61405. 3684. 3377. 61619. 0. 61619.
۷.	ANALYSIS DA	INGS (+) / COST TE ANNUAL SAV	(-) INGS, UNIT	COST & DIS	SCOUNTE	D SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		NUAL \$ /INGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 2.00 \$.00 \$.00 \$ 343.24 \$.00	0. 0. 0. 16. 0.	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	0. 0. 0. 5492. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 88696. 0.
	F. TOTAL		16,	\$	5492.		\$	88696.
3.	NON ENERGY	SAVINGS(+) / CO	DST(-)					
	(1) DISCOL	ECURRING (+ <i>!-)</i> JNT FACTOR (TA			11.65		\$	0.
	(2) DISCOL	JNTED SAVING/C	COST (3A X	•			\$	0.
		NENERGY DISCO			COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% MA A IF 3D1 B IF 3D1 C IF 3D ⁻	ION ENERGY QL X NON ENERGY IS = OR > 3C G(IS < 3C CALC S IS = > 1 GO T(B IS < 1 PROJEC	CALC (2F5 D TO ITEM 4 SIR = (2F5+ D ITEM 4	X .33) I 3D1)/1F)=		\$ 29270.		
4.	FIRST YEAR DO	OLLAR SAVINGS	2F3+3A+(3	B1D/(YEAR	S ECONON	1IC LIFE))	\$	5492.
5.	TOTAL NET DIS	SCOUNTED SAVI	NGS (2F5+3	BC)			\$	88696.
6.	DISCOUNTED S (IF < 1 PROJEC	SAVINGS RATIO T DOES NOT QU	IALIFY)	(SIR)	=(5 / 1F)=	1.44		
7.	SIMPLE PAYBA	CK PERIOD (ES	FIMATED)	SPB=1F/4		11.22		



)	P FI Al	ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY LO TITI 90 : 0	LE: 1496 DIS	TION INVES		r proc H - U: Name	GRAM (EC SDB REG :: 466A1	IP) ION NOS. 7 PREPARE		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
	1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	ICTI OS CRE VAI	T DIT CALC (1, LUE COST		.9				\$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	18112. 1087. 996. 18176. 0. 18176.
	2.	ENERGY SAV ANALYSIS DA		iS (+) / COST ANNUAL SAV	(-) /INGS, UNIT	⁻ COST	& DIS	COUNTED	SAVINGS		
		FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR			UAL \$ NGS(3)	DISCOUNT FACTOR(4		DISCOUNTED SAVINGS(5)
		A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 1. 0.	99 99 99 99 99 99 99 99 99 99 99 99 99	6666	0. 0. 0. 4. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 65. 0.
		F. TOTAL			1.	\$	\$	4.		\$	65.
	3.	NON ENERGY	' SA	VINGS(+) / C	OST(-)						
		A. ANNUAL R	ECI	JRRING (+/-) FACTOR (TA						\$	0.
		(2) DISCO		ED SAVING/	COST (3A X	(3A1)		11.65		\$	0.
		C. TOTAL NO	ΝE	NERGY DISC	OUNTED S	AVINGS	S(+) /C	OST(-) (34	\2+3Bd4)	\$	0.
		A IF 3D B IF 3D C IF 3D	AX 1 1 IS 1 IS 1 IS	N ENERGY QU NON ENERGY = OR > 3C GU < 3C CALC IS = > 1 GO T S < 1 PROJEC	' CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33 4 +3D1)/1) F)=	\$	21.		
	4.	FIRST YEAR D	OLI	AR SAVINGS	3 2F3+3A +(3	B1D/(Y	'EARS	ECONOM	IC LIFE))	\$	4.
		TOTAL NET DI								\$	65.
4	6.	DISCOUNTED (IF < 1 PROJEC					(SIR)=	=(5 / 1F)=	0.00		
•	7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=	1F/4		4544.00		

•

P F	ISTALLATION & ROJECT NO. & ISCAL YEAR 19		TION INVEST	MENT PRO VORTH -	ogram (ec USDB reg IE: 472A1	IP) ION NOS. 7 PREPARED	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
1.	B. SIOH C. DESIGN (D. ENERGY E. SALVAGE	UCTION COST)			\$\$ \$\$ \$\$ \$\$ \$ \$	25015. 1501. 1376. 25103. 0. 25103.
2.	ENERGY SAV	VINGS (+) / COST ATE ANNUAL SA\	(-) /INGS, UNIT (COST & DI	SCOUNTEE	SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS	AN	NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	1. 0. 0. 82. 0.	\$ \$ \$ \$ \$ \$ \$ \$	12. 0. 0. 335. 0.	11.16 17.19 17.12 16.15 13.92		134. 0. 0. 5410. 0.
	F. TOTAL		83.	\$	347.		\$	5544.
3.	NON ENERGY	Y SAVINGS(+) / C	OST(-)					
	A. ANNUAL F	RECURRING (+/-) DUNT FACTOR (T/			11.65		\$	0.
	(2) DISCO	DUNTED SAVING	COST (3A X	3A1)	60.11		\$	0.
	C. TOTAL NC	ON ENERGY DISC	OUNTED SAV	VINGS(+) /	COST(-) (3,	A2+3Bd4)	\$	0.
	(1) 25% M A IF 3D B IF 3D C IF 3I	NON ENERGY Q IAX NON ENERGY 01 IS = OR > 3C G 01 IS < 3C CALC D1B IS = > 1 GO T 01B IS < 1 PROJE	' CALC (2F5 O TO ITEM 4 SIR = (2F5+: O ITEM 4	X .33) 3D1)/1F)=	۹	1830 .		
4.	FIRST YEAR [DOLLAR SAVINGS	3 2F3+3A+(3E	31D/(YEAR	S ECONON	IIC LIFE))	\$	347.
5.	TOTAL NET D	SCOUNTED SAV	'INGS (2F5+3	C)			\$	5544.
6.) SAVINGS RATIO ECT DOES NOT Q		(SIF	l)=(5 / 1F)=	0.22		
7.	SIMPLE PAYB	BACK PERIOD (ES	TIMATED)	SPB=1F/4		72.34		





LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGION NOS. 7 PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: 473A1 ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YEARS PREPARED BY: CRB									
1.	B. SIOH C. DESIGN C D. ENERGY E. SALVAGE	UCTION COST	· ·	.9			\$\$ \$\$ \$\$ \$\$	12250. 735. 674. 12293. 0. 12293.	
2.	ENERGY SAV	VINGS (+) / COS ATE ANNUAL SA	T (-) AVINGS, UNIT	COST & D	ISCOUNTE) SAVINGS			
×	FUEL	UNIT COST \$/MBTU(1)	- SAVINGS MBTU/YR		INUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		COUNTED VINGS(5)	
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	1. 0. 0. 15. 0.	\$ \$ \$ \$ \$ \$ \$	12. 0. 0. 61. 0.	11.16 17.19 17.12 16.15 13.92		134. 0. 985. 0.	
	F. TOTAL		16.	\$	73.		\$	1119.	
3.	NON ENERGY	Y SAVINGS(+) /	COST(-)						
	(1) DISCO	RECURRING (+/- OUNT FACTOR (TABLE A)		11.65		\$	0.	
		UNTED SAVING	•	•			\$	0.	
		N ENERGY DIS			/COST(-) (3/	A2+3Bd4)	\$	0.	
	(1) 25% M/ A IF 3D B IF 3D C IF 3E	NON ENERGY (AX NON ENERG 01 IS = OR > 3C 01 IS < 3C CALC 01B IS = > 1 GO 01B IS < 1 PROJ	GO TO ITEM A SIR = (2F5- TO ITEM 4	X .33) 4 ⊦3D1)/1F)=		3 69.			
4.	FIRST YEAR D	OOLLAR SAVING	GS 2F3+3A+(3	B1D/(YEAF	RS ECONOM	IIC LIFE))	\$	73.	
5.	TOTAL NET D	ISCOUNTED SA	VINGS (2F5+	3C)			\$	1119.	
6.	DISCOUNTED (IF < 1 PROJEC	SAVINGS RATI	O QUALIFY)	(SIF	R)=(5 / 1F)=	0.09			
7.	SIMPLE PAYB	ACK PERIOD (E	STIMATED)	SPB=1F/4	Ļ	168.40			

-



•

PI FI	ENEF STALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY CO LOCA TITLE: 90	ONSERVAT TION: FOI 1496 DIS	CRETE PO	TMENT P WORTH RTION N/	Rogram (E - USDB Re	GIOŃ NO			Y: USDBAE CCID 1.035 CENSUS: 2 B
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	ICTION OST CREDIT VALUE	T CALC (1. E COST		9				\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	- 7865. 472. 433. 7893. 0. 7893.
2.	ENERGY SAV ANALYSIS DA	INGS (TE AN	(+) / COST INUAL SAV	(-) 'INGS, UNIT	COST &	DISCOUNTI	ED SAVIN	GS		
	FUEL		NIT COST MBTU(1)	SAVINGS MBTU/YR		NNUAL \$ AVINGS(3)		OUNT OR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 20. 0.	\$ \$ \$ \$ \$ \$	0. 0. 0. 82. 0.		11.16 17.19 17.12 16.15 13.92		0. 0. 1324. 0.
	F. TOTAL			20.	\$	82.			\$	1324.
3.	NON ENERGY	SAVI	NGS(+) / C(OST(-)						
	A. ANNUAL R (1) DISCO		RING (+/-) ACTOR (TA			11.65			\$	0.
	(2) DISCO	UNTED	SAVING/	COST (3A X	(3A1)	11.05			\$	0.
	C. TOTAL NO	N ENE	RGY DISC	OUNTED SA	AVINGS(+) /COST(-) ((3A2+3Bd	4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX NOI 1 IS = (1 IS < ()1B IS :	N ENERGY OR > 3C G 3C CALC = > 1 GO T	′ CALC (2F5 O TO ITEM 4 SIR = (2F54	X .33) 4 ⊦3D1)/1F)		\$	437.		
4.	FIRST YEAR D	OLLAF	R SAVINGS	3 2F3+3A+(3	B1D/(YE	ARS ECONC	MIC LIFE))	\$	82.
5.	TOTAL NET DI	SCOU	NTED SAV	INGS (2F5+	3C)				\$	1324.
6.	DISCOUNTED (IF < 1 PROJEC	SAVIN CT DOI	GS RATIO ES NOT QU	JALIFY)	(S	IR)=(5 / 1F)=	-	0.17		
7.	SIMPLE PAYB	ACK PE	ERIOD (ES	TIMATED)	SPB=1F	/4	9	6.26		



,

P F	ENEF ISTALLATION 8 ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	990 DIS	FION INVESTM	IENT PRO DRTH - U ION NAM	DGRAM (EC JSDB REG E: 475AA1	ION NOS. 7	LC	7: USDBAE CID 1.035 CENSUS: 2
1	B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE	UCTION COST					\$ \$ \$ \$ \$ \$	9504. 570. 523. 9537. 0. 9537.
2.	ENERGY SAV ANALYSIS DA	VINGS (+) / COST ATE ANNUAL SAV	(-) 'INGS, UNIT CO	OST & DI	SCOUNTED) SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		NUAL \$ /INGS(3)	DISCOUNT FACTOR(4)		COUNTED 'INGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	3. 0. 0. 122. 0.	\$ \$ \$ \$ \$ \$ \$ \$ \$	37. 0. 0. 498. 0.	11.16 17.19 17.12 16.15 13.92		413. 0. 0. 8043. 0.
	F. TOTAL		125.	\$	535.		\$	8456.
3.	NON ENERGY	Y SAVINGS(+) / CO	OST(-)					
	A. ANNUAL R	RECURRING (+/-)			11.65		\$	0.
	(1) DISCOUNT FACTOR (TABLE A) 11.65 (2) DISCOUNTED SAVING/COST (3A X 3A1)						\$	0.
	C. TOTAL NO	ON ENERGY DISCO	OUNTED SAVI	NGS(+) /(COST(-) (3/	A2+3Bd4)	\$	0.
	(1) 25% M/ A IF 3D B IF 3D C IF 3D	NON ENERGY QU AX NON ENERGY 01 IS = OR > 3C GO 01 IS < 3C CALC $\stackrel{(1)}{\underset{()}{3}}$ 01 IS = > 1 GO TO 01B IS < 1 PROJEC	CALC (2F5 X O TO ITEM 4 SIR = (2F5+3E O ITEM 4	.33))1)/1F)=		2790.		
4.	FIRST YEAR D	DOLLAR SAVINGS	3 2F3+3A+(3B1	D/(YEAR	S ECONOM	IIC LIFE))	\$	535.
5.	TOTAL NET DI	SCOUNTED SAV	INGS (2F5+3C))			\$	8456.
6.		SAVINGS RATIO	JALIFY)	(SIR)=(5 / 1F)=	0.89		
7.	SIMPLE PAYB	ACK PERIOD (ES	TIMATED) S	PB=1F/4		17.83		



ECO-A1

·

LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGION NO PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: 475BA1 ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YEARS PREP		CUDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1. INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E)	\$ \$ \$ \$ \$ \$	9793. 588. 539. 9828. 0. 9828.
2. ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAVIN	GS	
UNIT COST SAVINGS ANNUAL \$ DISCO FUEL \$/MBTU(1) MBTU/YR(2) SAVINGS(3) FACT		DISCOUNTED SAVINGS(5)
B. DIST \$.00 0. \$ 0. C. RESID \$.00 0. \$ 0. D. NAT G \$ 4.08 22. \$ 90.	11.16 17.19 17.12 16.15 13.92	0. 0. 0. 1454. 0.
F. TOTAL 22. \$ 90.	\$	1454.
3. NON ENERGY SAVINGS(+) / COST(-)		
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) 11.65	\$	0.
(2) DISCOUNTED SAVING/COST (3A X 3A1)	\$, 0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3A2+3Bd4	1) \$	0.
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) \$ A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = (2F5+3D1)/1F)= C IF 3D1B IS < 3 FO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY	480.	
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOMIC LIFE))) \$	90.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)	\$	1454.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= (IF < 1 PROJECT DOES NOT QUALIFY)	0.15	
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4 10	9.20	



,

PRC FISC	ENER TALLATION & DJECT NO. & ⁻ CAL YEAR 199 LYSIS DATE:	GY C LOCA FITLE 90	ONSERVAT ATION: FOI : 1496 DIS	RT LEAVEN		IT PF TH - N NAI	OGRAM (EC	ION NOS		·	DY: USDBAE LCCID 1.035 CENSUS: 2
	NVESTMENT A. CONSTRUG 3. SIOH C. DESIGN CO 0. ENERGY C 5. SALVAGE V 5. TOTAL INV	OST REDI VALUI	T CALC(1) E COST		.9					\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	31812. 1909. 1750. 31924. 0. 31924.
2. E A	ENERGY SAVI	NGS TE AN	(+) / COST INUAL SAV	(-) INGS, UNIT	COST	T & C	ISCOUNTE) SAVING	S		
F	UEL		NIT COST MBTU(1)	SAVINGS MBTU/YR			NUAL \$ VINGS(3)	DISCOU FACTO			ISCOUNTED AVINGS(5)
B C D	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 57. 0.		***	0. 0. 233. 0.	17 17 16	1.16 7.19 7.12 5.15 3.92		0. 0. 0. 3763. 0.
F	. TOTAL			57.		\$	233.			\$	3763.
3. N	ION ENERGY	SAVI	NGS(+) / C(OST(-)							
A	. ANNUAL RE (1) DISCOL		RING (+/-) ACTOB (TA				11.65			\$	0.
	(2) DISCOL	INTE) SAVING/(COST (3A X	(3A1))	60.11			\$	0.
С	. TOTAL NOM	I ENE	RGY DISC	OUNTED SA	AVING	S(+)	/COST(-) (3	A2+3Bd4)		\$	0.
D	B IF 3D1 C IF 3D	X NO IS = IS < 1B IS	N ENERGY OR > 3C G(3C CALC \$ = > 1 GO T	CALC (2F5 D TO ITEM SIR = (2F5-	5 X .3: 4 ⊧3D1)/	3) 1F)=		\$ 12	.42.		
4. FI	RST YEAR DO	OLLAI	R SAVINGS	2 F3+3A +(3	B1D/(YEA	RS ECONOM	IC LIFE))		\$	233.
5. TC	OTAL NET DIS	scou	NTED SAV	NGS (2F5+	3C)					\$	3763.
	ISCOUNTED S = < 1 PROJEC			JALIFY)		(SII	R)=(5 / 1F)=	0	.12		
7. SI	MPLE PAYBA	CK P	ERIOD (ES	TIMATED)	SPB⊧	=1F/4	1	137.	.01		



1

INSTALLAT PROJECT N FISCAL YEA	LIFE CYCLE CO ENERGY CONSERVAT ION & LOCATION: FOI IO. & TITLE: 1496 AR 1990 DIS DATE: 03-30-90	FION INVESTM	IENT PRO ORTH - U TON NAME	GRAM (EC SDB REG E: 475DA1	ION NOS. 7	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
B. SIOH C. DESI D. ENEI E. SALV	MENT STRUCTION COST GN COST RGY CREDIT CALC (1, /AGE VALUE COST AL INVESTMENT (1D-1	-				\$\$ \$\$ \$\$ \$ \$	37748. 2265. 2076. 37880. 0. 37880.
2. ENERGY ANALYS	/ SAVINGS (+) / COST IS DATE ANNUAL SAV	(-) 'INGS, UNIT CO	OST & DIS	COUNTED) SAVINGS		
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		UAL \$ INGS(3)	DISCOUNT FACTOR(4)		COUNTED /INGS(5)
A. ELEC B. DIST C. RESI D. NAT E. COAL	\$.00 D\$.00 G\$4.08	0. 0. 0. 65. 0.	\$ \$ \$ \$ \$ \$	0. 0. 265. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 4280. 0.
F. TOTAI	-	65.	\$	265.		\$	4280.
3. NON EN	ERGY SAVINGS(+) / C(OST(-)					
A. ANNU (1) D	JAL RECURRING (+/-) ISCOUNT FACTOR (TA			11.65		\$	0.
(2) D	SCOUNTED SAVING/C	COST (3A X 3)	A1)	11.00		\$	0.
C. TOTA	L NON ENERGY DISC	OUNTED SAVI	NGS(+) /C	OST(-) (3/	A2+3Bd4)	\$	0.
(1) 25 A B C	ECT NON ENERGY QU 5% MAX NON ENERGY IF 3D1 IS = OR > 3C G IF 3D1 IS < 3C CALC IF 3D1 B IS < 3C CALC IF 3D1B IS < 1 PROJEC	' CALC (2F5 X O TO ITEM 4 SIR = (2F5+3D O ITEM 4	∷.33) D1)/1F)=	4	1412 .		
4. FIRST YE	AR DOLLAR SAVINGS	3 2F3+3A+(3B1	D/(YEARS	ECONOM	IIC LIFE))	\$	265.
5. TOTAL N	ET DISCOUNTED SAV	INGS (2F5+3C))			\$	4280.
6. DISCOUN (IF < 1 PF	ITED SAVINGS RATIO ROJECT DOES NOT QU	JALIFY)	(SIR)=	=(5 / 1F)=	0.11		
7. SIMPLE F	AYBACK PERIOD (ES	TIMATED) S	PB=1F/4		142.94		



PR(FIS	ENER TALLATION & DJECT NO. & CAL YEAR 199 ALYSIS DATE:	GY C LOCA FITLE 90	TION: FOF 1496 DIS	TON INVES RT LEAVEN CRETE PO	TMENT WORTH RTION I	PROGRAM (EGIOŃ N A1	OS. 7 PARED	I	DY: USDBAE LCCID 1.035 CENSUS: 2 RB
	INVESTMENT A. CONSTRU B. SIOH C. DESIGN CO D. ENERGY C E. SALVAGE F. TOTAL INV	OST REDI VALU	T CALC (14 E COST	-	9				\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	42102. 2526. 2316. 42250. 0. 42250.
2.	ENERGY SAVI ANALYSIS DA	NGS TE AN	(+) / COST (INUAL SAVI	(-) INGS, UNIT	COST	& DISCOUNT	ED SAVI	NGS		
I	FUEL		NIT COST MBTU(1)	SAVINGS MBTU/YR		ANNUAL \$ SAVINGS(3)		COUNT TOR(4)		SCOUNTED AVINGS(5)
 (A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	-8. 0. 0. 86. 0.	\$\$ \$\$ \$\$ \$\$ \$ \$	-100. 0. 0. 351. 0.		11.16 17.19 17.12 16.15 13.92		-1116. 0. 5669. 0.
F	F. TOTAL			78.	\$	251.		•	\$	4553.
3. 1	NON ENERGY	SAVII	NGS(+) / CC	DST(-)						
ļ	A. ANNUAL RE (1) DISCOL		RING (+/-) ACTOR (TA	RIFA)		11.65			\$	0.
	(2) DISCOL	INTE	SAVING/C	OST (3A X	3A1)	11.05			\$	0.
C	C. TOTAL NOM	I ENE	RGY DISCO	DUNTED SA	VINGS	(+) /COST(-)	(3A2+3B	d4)	\$	0.
C	B IF 3D1 C IF 3D	X NO IS = IS < 1B IS	NERGY QU N ENERGY OR > 3C GC 3C CALC & = > 1 GO TC < 1 PROJEC	CALC (2F5) TO ITEM 4 SIR = (2F5+) ITEM 4	X .33) 4 -3D1)/1F	-)=	\$	1502.		
4. F	IRST YEAR D	OLLAI	R SAVINGS	2F3+3A+(3	B1D/(YE	EARS ECONO	OMIC LIF	E))	\$	251.
5. T	OTAL NET DIS	scou	NTED SAVI	NGS (2F5+:	3C)				\$	4553.
6. D (1	F < 1 PROJEC	SAVIN T DO	IGS RATIO ES NOT QU	IALIFY)	(SIR)=(5 / 1F)	=	0.11		
7. S	IMPLE PAYBA	CK P	ERIOD (EST	(IMATED)	SPB=1	F/4	1	68.33		



.

ENERG INSTALLATION & L PROJECT NO. & TI FISCAL YEAR 1990 ANALYSIS DATE:	ITLE: 1496)	ION INVESTM	ENT PRC DRTH - L ON NAMI	OGRAM (EC JSDB REG E: 475FA1	ION NOS. 7	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
1. INVESTMENT A. CONSTRUC B. SIOH C. DESIGN CO D. ENERGY CF E. SALVAGE V F. TOTAL INVE	ST REDIT CALC (1/ ALUE COST					\$\$ \$\$ \$\$ \$ \$	37990. 2279. 2089. 38122. 0. 38122.
2. ENERGY SAVIN ANALYSIS DAT	IGS (+) / COST E ANNUAL SAV	(-) INGS, UNIT CC	DST & DIS	SCOUNTED	SAVINGS		
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		IUAL \$ 'INGS(3)	DISCOUNT FACTOR(4)		COUNTED /INGS(5)
A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	0. 0. 120. 0.	\$ \$ \$ \$	0. 0. 0. 490. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 0. 7914. 0.
F. TOTAL		120.	\$	490.		\$	7914.
3. NON ENERGY S	SAVINGS(+) / CO	DST(-)					
A. ANNUAL REG (1) DISCOU	CURRING (+/-) NT FACTOR (TA			11.65		\$	0.
(2) DISCOU	NTED SAVING/C	OST (3A X 34	41)	11.00		\$	0.
C. TOTAL NON				OST(-) (3/	A2+3Bd4)	\$	0.
A IF 3D1 B IF 3D1 C IF 3D1	DN ENERGY QU (NON ENERGY IS = OR > 3C G(IS < 3C CALC 8 IS = > 1 GO T(8 IS < 1 PROJEC	CALC (2F5 X D TO ITEM 4 SIR = (2F5+3D D ITEM 4	.33) 1)/1F)=	\$			
4. FIRST YEAR DO	LLAR SAVINGS	2F3+3A+(3B1[D/(YEARS	S ECONOM	IC LIFE))	\$	490.
5. TOTAL NET DISC						\$	7914.
6. DISCOUNTED SA (IF < 1 PROJECT	AVINGS RATIO DOES NOT QL	IALIFY)	(SIR)	=(5 / 1F)=	0.21		
7. SIMPLE PAYBAC	K PERIOD (ES	TIMATED) SF	PB=1F/4		77.80		



P F A	ISTALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY C LOCA TITLE 90 : 03-:	ONSERVA ⁻ ATION: FO : 1496 DIS	SCRETE PO	iworth -	ROGRAM (E USDB RE .ME: 475GA	GION NOS. 7	L	DY: USDBAE CCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	JCTION COST CREDI VALUI	T CALC (1) E COST	-	.9			\$\$ \$\$ \$\$ \$ \$ \$	32708. 1962. 1799. 32822. 0. 32822.
2.	ENERGY SAV ANALYSIS DA	/INGS	(+) / COST INUAL SAV	(-) /INGS, UNIT	COST & I	DISCOUNTE	D SAVINGS		
	FUEL		NIT COST MBTU(1)	SAVINGS MBTU/YR		NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 55. 0.	\$ \$ \$ \$ \$	0. 0. 0. 224. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 0. 3618. 0.
	F. TOTAL			55.	\$	224.		\$	3618.
3.	NON ENERGY	Y SAVI	NGS(+) / C	OST(-)					
	A. ANNUAL R (1) DISCO		RING (+/-)			11.65		\$	0.
	(2) DISCO	UNTE	D SAVING/	COST (3A >	(3A1)	11.05		\$	0.
	C. TOTAL NO	N ENE	RGY DISC	OUNTED SA	AVINGS(+)	/COST(-) (3A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX NO 1 IS = 1 IS < 01B IS	N ENERGY OR > 3C G 3C CALC = > 1 GO T	CALC (2F5) O TO ITEM SIR = (2F5-	5 X .33) 4 +3D1)/1F)=		\$ 1194.		
4.	FIRST YEAR D	OLLA	R SAVINGS	6 2F3+3A+(3	B1D/(YEA	RS ECONO	MIC LIFE))	\$	224.
5.	TOTAL NET D	ISCOU	NTED SAV	INGS (2F5+	3C)			\$	3618.
6.	DISCOUNTED (IF < 1 PROJEC				(SI	R)=(5 / 1F)=	0.11		
7.	SIMPLE PAYB	ACK P	ERIOD (ES	TIMATED)	SPB=1F/	4	146.53		



LIFE C ENERGY CON INSTALLATION & LOCATI PROJECT NO. & TITLE: 1 FISCAL YEAR 1990 ANALYSIS DATE: 03-30	496 DISCRETE PO	TMENT PROGR	AM (ECIP) B REGION NO 475HA1		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1. INVESTMENT A. CONSTRUCTION (B. SIOH C. DESIGN COST D. ENERGY CREDIT (E. SALVAGE VALUE (F. TOTAL INVESTMEN	CALC (1A+1B+1C)X	.9		\$ \$ \$ \$ \$ \$ \$ \$ \$	7563. 454. 416. 7590. 0. 7590.
2. ENERGY SAVINGS (+) ANALYSIS DATE ANN	/ COST (-) UAL SAVINGS, UNIT	COST & DISCO	UNTED SAVIN	GS	
	COST SAVINGS TU(1) MBTU/YR				DISCOUNTED SAVINGS(5)
B. DIST \$ C. RESID \$	2.44 0. .00 0. .00 0. 4.08 27. .00 0.	\$ \$ \$ \$	0. 0. 110.	11.16 17.19 17.12 16.15 13.92	0. 0. 1777. 0.
F. TOTAL	27.	\$	110.	\$	1777.
3. NON ENERGY SAVING	iS(+) / COST(-)				
A. ANNUAL RECURRI (1) DISCOUNT FAC	NG (+/-) TOB (TABLE A)		1.65	\$	0.
(2) DISCOUNTED S	SAVING/COST (3A)	(3A1)	1.00	\$	0.
C. TOTAL NON ENERG	BY DISCOUNTED SA	AVINGS(+) /COS	3T(-) (3A2+3Bd4	4) \$	0.
B IF 3D1 IS < 3C C IF 3D1B IS = :	ERGY QUALIFICATION ENERGY CALC (2F5 R > 3C GO TO ITEM CALC SIR = (2F5- > 1 GO TO ITEM 4 PROJECT DOES N	5 X .33) 4 ⊦3D1)/1F)=	\$	586.	
4. FIRST YEAR DOLLAR	SAVINGS 2F3+3A+(3	B1D/(YEARS E)) \$	110.
5. TOTAL NET DISCOUNT				\$	1777.
6. DISCOUNTED SAVING (IF < 1 PROJECT DOES		(SIR)=(5	/ 1F)=	0.23	
7. SIMPLE PAYBACK PEF	IOD (ESTIMATED)	SPB=1F/4	6	9.00	





)

CONSTRUCTION COST ESTIMATE			DATE PR	EPARED	4/2/90))	SHEET	OF 1
PROJECT USDB ENERGY STUDY			L	BASIS FOR			L	
LOCATION FORT LEAVENWORTH, KS				x	CODE A	(NO DESIGN (PRELIMINAR	COMPLET	ED)
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS					CODEC	(FINAL DESIG	BN)	,
DRAWING NO.		ESTIM	ATOR	L	UINER	SPECIFY)	Ŷ	
NONE ECO-A1		ANTITY	м	DLS ATERIAL	1	ABOR		DTAL
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL		OST
BUILDING 463								
REMOVE OLD SEALANT INSTALL NEW SEALANT	830	FT	0.60	498	1.40	1,162		¢-1
REMOVE OLD CAULKING/ INSTALL NEW CAULKING	830		0.60		1.40			<u>\$1,0</u> \$1,0
WEATHERSTRIP WINDOWS	239	FT	1.40	335	2.60	621		\$
REMOVE DOOR/FRAME	2	EA			100.00			\$
NEW DOOR/FRAME	2	EA	420.00	840	80.00			\$1,0
FINISH HARDWARE	2	EA	510.00	1,020	90.00	180		\$1,2
PAINT	2	EA	5.00	10	35.00	70		
SEALANT/CAULK	34	FT	0.60	20	1.40	48		ę
MOBILIZATION	2	EA			140.00	280		\$2
-								
							· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·
·								
SUBTOTAL				\$3,221		\$3,883		\$7,1
CONTINGENCY 10%			10%	\$322	10%	\$388		\$7
SUBTOTAL	+			\$3,543		\$4,271		\$7,8
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$124	13.0%	\$555		\$6
DIRECT COST	<u> </u>			\$3,667		\$4,826		\$8,4
VERHEAD AND PROFIT			25%	\$917	25%	\$1,207		\$2,12
SUBTOTAL				\$4,584		\$6,033		\$10,61
CONSTRUCTION COST								\$10,61



•

CONSTRUCTION COST ESTIMATE			DATE PF	IEFARED	4/2/90	h	SHEET OF
PROJECT USDB ENERGY STUDY				BASIS FOR	ESTIMATE		2
LOCATION	······································			x			
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODEB	(PRELIMINAR	
CLARK RICHARDSON & BIS	סווא				CODEC	(FINAL DESIG	N)
DHAWING NO.		ESTIM	ATOR	L	OTHER	(SPECIFY)	
NONE ECO-A1				DLS		CHECKED B	Y TOL
REDUCE INFILTRATION		ANTITY		ATERIAL		ABOR	TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 464							
REMOVE OLD SEALANT							
NSTALL NEW SEALANT	697	FT	0.60	418	3 1.40	976	6 4
REMOVE OLD CAULKING/ INSTALL NEW CAULKING					1	3/0	\$1.
	697	FT	0.60	418	3 1.40	976	\$1,
NEATHERSTRIP WINDOWS	220	FT	1.40	308	2.60	572	
	+			<u> </u>			
		T					
	++						
	╉╌╌┼						
		T					
	++					·	
	+						
	╉╼╼╌┠						
SUBTOTAL	╂───╂			\$1,144		\$2,524	\$3,60
DNTINGENCY 10%	<u> </u>		10%	\$114	10%	\$252	\$30
SUBTOTAL				\$1,258			
DRK COMP, TAX, SOC. SEC., INS			3.50%	1		\$2,776	\$4,03
DIRECT COST	1		3.30%	\$44	13.0%	\$361	\$40
ERHEAD AND PROFIT	+			\$1,302		\$3,137	\$4,43
	┟───┼─		25%	\$326	25%	\$784	\$1,11
SUBTOTAL	┟───┤─			\$1,628		\$3,921	\$5,54
CONSTRUCTION COST	1						



1.00	
3	

CONSTRUCTION COST ESTIMATE				EPARED	4/2/90		SHEET OF 3
PROJECT USDB ENERGY STUDY			•	BASIS FOR			1 3
LOCATION FORT LEAVENWORTH, KS				x		(NO DESIGN (PRELIMINAR	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISK	(UP				CODEC	(FINAL DESIG	
DRAWING NO. NONE		ESTIM	ATOR	DLS	UTIEN	CHECKED B	•
ECO-A1	QU	ANTITY	M	IATERIAL	1	LABOR	TOL TOTAL
REDUCE INFILTRATION	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	COST
BUILDING 465							
INSTALL NEW SEALANT REMOVE OLD CAULKING/	5272		0.60	3,163	1.40	7,381	\$10,5
INSTALL NEW CAULKING	5272	FT	0.60	3,163	1.40	7,381	\$10,5
WEATHERSTRIP WINDOWS	1850	FT	1.40	2,590	2.60	4,810	\$7,4
WEATHERSTRIP DOORS	120	FT	1.40	168	2.60	312	\$4
INSTALL NEW THRESHOLD AT DOORS (03, 05, 102, 202, AND 302)	6	EA	40.00	240	10.00	60	\$3
REPLACE ENTRY (06 AND 104)							ψυ
REMOVE DOOR/FRAME	2	EA			150.00	300	\$3
NEW DOOR/FRAME	2	EA	600.00	1.200		300	\$1,5
FINISH HARDWARE	2	EA	510.00	1,020	90.00	180	\$1,20
PAINT	2	EA	10.00	20	50.00	100	\$12
SEALANT/CAULK	80	FT	0.60	48	1.40	112	\$16
MOBILIZATION	2	EA			160.00	320	\$32
NSTALL NEW HALLOW METAL DOOR AND FRAME (01, 08, 103, AND 301)							
REMOVE DOOR/FRAME	4	EA			100.00	400	\$40
NEW DOOR/FRAME	4	EA	420.00	1,680	80.00	320	\$2,00
	4	EA	510.00	2,040	90.00	360	\$2,40
PAINT	4	EA	\$5	20	35.00	140	\$16
SEALANT/CAULK	136	FT	\$1	82	1.40	190	\$27
MOBILIZATION	4	EA			140.00	560	\$56
REPLACE PAIR OF DOORS (04)							
REMOVE DOOR/FRAME	1	EA			150.00	150	\$15
EW DOOR/FRAME	1	EA	\$840	840	160.00	160	\$1,00
INISH HARDWARE	1	EA	\$680	680	120.00	120	\$80
AINT	1	EA	\$20	20	80.00	80	\$10
							φιο

ENG. FORM



a se

CONSTRUCTION COST ESTIMATE			DATE PR	IEPARED	4/2/90		SHEET OF 4
PROJECT	······································			BASIS FOR			4
USDB ENERGY STUDY				x	CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODE B	(PRELIMINAR	Y DESIGN)
CLARK RICHARDSON & BI	SKUP			<u> </u>		(FINAL DESIG (SPECIFY)	iN)
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	
ECO-A1		ANTITY		IATERIAL		ABOR	TOL TOTAL
REDUCE INFILTRATION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 465 CONTINUED							
SEALANT/CAULK	40	FT	0.60	24	1.40	56	
OBILIZATION	1	EA			160.00		\$
					00.00	100	¥
							·
							· · · · · · · · · · · · · · · · · · ·
SUBTOTAL				\$16,998		\$23,952	\$40,9
ONTINGENCY 10%			10%	\$1,700	10%	\$2,395	\$4,0
SUBTOTAL				\$18,698		\$26,347	\$45,0
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$654	13.0%	\$3,425	\$4,0
DIRECT COST				\$19,352		\$29,772	\$49,1
/ERHEAD AND PROFIT			25%	\$4,838	25%	\$7,443	<u>\$49,1</u> \$12,2
SUBTOTAL				\$24,190		\$37,215	\$61,4
CONSTRUCTION COST						\ \\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	
NG. FORM 150 NC-59			I	1			\$61,4



CONSTRUCTION COST ESTIMATE				REPARED	4/2/90		SHEET	OF 5
PROJECT USDB ENERGY STUDY		BASIS FOR	•••••••••••••••••••••••••••••••••••••••	<u> </u>				
LOCATION FORT LEAVENWORTH KS	X	CODE B	(NO DESIGN (PRELIMINAR		(ED)			
ARCHITECT/ENGINEER CLARK RICHARDSON & BI			_CODE C	(FINAL DESIG	SN)	*)		
DRAWING NO.		ESTIM	ATOR	I	OTHER	SPECIFY)	Y	
ECO-A1		ANTITY		DLS	·		TOL	
REDUCE INFILTRATION	NO.	UNIT MEAS.		TOTAL	PER UNIT	ABOR TOTAL		OTAL OST
BUILDING 466								
REMOVE OLD SEALANT INSTALL NEW SEALANT								
REMOVE OLD CAULKING/	1520	FT	0.60	912	1.40	2,128		\$3,0
INSTALL NEW CAULKING	1520	FT	0.60	912	1.40	2,128		\$3,0
WEATHERSTRIP WINDOWS	275	FT	1.40	385	2.60	715		\$1,1
WEATHERSTRIP DOORS	37	FT	1.40		2.60	96		\$1
INSTALL THRESHOLD DOOR (102)	1	EA	40.00	40	10.00	10		\$
INSTALL THRESHOLD DOOR (201)	1	EA	80.00	80	20.00	20		\$1
REPLACE DOORS (101 AND 105)								
REMOVE DOOR/FRAME	2	EA			150.00	300		\$3
NEW DOOR/FRAME	2	EA	550.00	1,100	100.00	200		<u></u> \$1,3
FINISH HARDWARE	2	EA	510.00	1,020	90.00	180		\$1,2
PAINT	2	EA	8.00	16	42.00	84	· · · · · · · · · · · · · · · · · · ·	\$1
SEALANT/CAULK	72	FT	0.60	43	1.40	101		\$1
MOBILIZATION	1	EA			140.00	140		<u> </u>
REPLACE OVERHEAD DOOR (103)								φι
REMOVE DOOR/TRACK	1	EA			150.00	150		\$1
NEW INSULATED DOOR/TRACK	1	EA	850.00	850	250.00	250		\$1,10
OBILIZATION	1	EA			200.00	200		\$20
SUBTOTAL				\$5,410		\$6,702		\$12,11
CONTINGENCY 10%			10%	\$541	10%	\$670		\$1,21
SUBTOTAL				\$5,951		\$7,372	·····	\$13,32
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$208	13.0%	\$958	<u></u>	\$1,16
DIRECT COST				\$6,159		\$8,330		\$14,48
VERHEAD AND PROFIT			25%	\$1,540	25%	\$2,083		\$3,62
SUBTOTAL				\$7,699		\$10,413		\$18,11
CONSTRUCTION COST								
NG. FORM 150 NC-59	··· •		I		l_	l_		\$18,11



همتندا

CONSTRUCTION COST ESTIMATE DATE PR								
LOCATION FORT LEAVENWORTH KS					4/2/90 ESTIMATE		6	
							NO DESIGN COMPLETED) PRELIMINARY DESIGN)	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKUP					CODEC	(FINAL DESIG	SN)	
DRAWING NO.				L	OTHER	SPECIFY)	v	
ECO-A1		ANTITY		DLS	T		TOL	
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	ABOR TOTAL	COST	
BUILDING 472					1			
REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/	2745	FT	0.60	1,647	1.40	3,843	\$5,4	
	2745	FT	0.60	1,647	1.40			
WEATHERSTRIP WINDOWS	833	FT	1.40	1,166			\$5,4 \$3,3	
REPLACE PAIR DOORS (105)				•				
REMOVE DOOR/FRAME	11	EA			150.00	150	\$1	
NEW DOOR/FRAME	1	EA	840.00	840	160.00	160	\$1,0	
INISH HARDWARE	11	EA	680.00	680	120.00	120	\$8	
AINT	1	EA	20.00	20	80.00	80	\$1	
EALANT/CAULK	42	FT	0.60	25	1.40	59	\$	
OBILIZATION	1				160.00	160	\$1	
	<u> </u>							
	<u> </u>							
SUBTOTAL				£6.005				
ONTINGENCY 10%		+-	10%	\$6,025		\$10,581	\$16,60	
SUBTOTAL				\$603 \$6,628	10%	\$1,058	\$1,66	
DRK COMP,TAX,SOC.SEC.,INS			3.50%	\$232	12.00	\$11,639	\$18,26	
DIRECT COST				\$6,860	13.0%	\$1,513	\$1,74	
ERHEAD AND PROFIT			25%	\$1,715	25%	\$13,152 \$3,288	\$20,01	
SUBTOTAL				\$8,575		\$3,288 \$16,440	\$5,000	
CONSTRUCTION COST						φ+0,440 [\$25,015	



CONSTRUCTION COST ESTIMATE				REPARED	4/2/90	 1	SHEET OF
USDB ENERGY STUDY					ESTIMATE		7
LOCATION							
FORT LEAVENWORTH, KS		_		<u> </u>	CODE A	(NO DESIGN (PRELIMINAF	COMPLETED)
ARCHITECT/ENGINEER						(FINAL DESIG	SN)
CLARK RICHARDSON & BISKL	JP	1			OTHER	(SPECIFY)	
NONE		ESTIM	ATOR	D! O		CHECKED B	Y
ECO-A1	OU	ANTITY	N.	DLS		1.000	TOL
REDUCE INFILTRATION	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
BUILDING 473							
REMOVE OLD SEALANT							
INSTALL NEW SEALANT	975	FT	0.60	585	1.40	1,365	61
REMOVE OLD CAULKING/ INSTALL NEW CAULKING						1,003	\$1,
	975	FT	0.60	585	1.40	1,365	\$1,
WEATHERSTRIP WINDOWS	047						
NSTALL NEW HOLLOW METAL DOOR AND FRAME DOORS (104 AND 105)	347		1.40	486	2.60	902	\$1,
REMOVE DOOR/FRAME	2	EA			100.00	200	
NEW DOOR/FRAME	2	EA	420.00	840	80.00	160	<u> </u>
INISH HARDWARE	2	EA	510.00	1,020	90.00	180	\$1,1
PAINT	2	EA	5.00	10	35.00	70	\$1,:
EALANT/CAULK	68	FT	0.60	41	1.40	95	\$1
OBILIZATION	2	EA			140.00	280	\$2
							φε
SUBTOTAL			<u> </u> -	<u> </u>			
DNTINGENCY 10%				\$3,567		\$4,617	\$8,18
SUBTOTAL			10%	\$357	10%	\$462	\$81
ORK COMP, TAX, SOC.SEC., INS				\$3,924		\$5,079	\$9,00
DIRECT COST			3.50%	\$137	13.0%	\$660	\$79
ERHEAD AND PROFIT			25%	\$4,061		\$5,739	\$9,80
SUBTOTAL			2%	\$1,015	25%	\$1,435	\$2,45
CONSTRUCTION COST				\$5,076		\$7,174	\$12,25
G. FORM 150							\$12,250



Ĵ

CONSTRUCTION COST ESTIMATE	EPARED	SHEET OF					
PROJECT USDB ENERGY STUDY					4/2/90		8 1
LOCATION					CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISKUP				X	CODE B	(PRELIMINAR	Y DESIGN)
						(FINAL DESIG	iN)
DRAWING NO.		ESTIM	ATOR		UTHER	CHECKED B	Y
NONE ECO-A1				DLS			TOL
REDUCE INFILTRATION	NO.	ANTITY UNIT	PER	ATERIAL TOTAL	PER	ABOR TOTAL	TOTAL COST
		MEAS.	UNIT			IOTAL	CUST
BUILDING 475							
REMOVE OLD SEALANT							
INSTALL NEW SEALANT	850	FT	0.60	510	1.40	1,190	\$1,70
REMOVE OLD CAULKING/ INSTALL NEW CAULKING							
	<u>· 850</u>		0.60	510	1.40	1,190	\$1,70
WEATHERSTRIP WINDOWS	450	FT	1.40	630	2.60	1,170	\$1,80
	_						
							••••••••••••••••••••••••••••••••••••••
SUBTOTAL				\$1,650		\$3,550	\$5,20
CONTINGENCY 10%			10%	\$165	10%	\$355	
SUBTOTAL				\$1,815		\$3,905	\$52
VORK COMP, TAX, SOC.SEC., INS			3.50%		12.0%		\$5,720
			0.00%	\$64	13.0%	\$508	\$572
VERHEAD AND PROFIT			050/	\$1,879		\$4,413	\$6,292
SUBTOTAL	++		25%	\$470	25%	\$1,103	\$1,573
	+			\$2,349		\$5,516	\$7,865
CONSTRUCTION COST NG. FORM 150 AVC-59	<u> </u>	L					\$7,865



CONSTRUCTION COST ESTIMATE DATE PRE			EPARED	SHEET OF 9				
				BASIS FOR	4/2/90 BASIS FOR ESTIMATE			
				x	CODE A	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODEB	(PRELIMINAR (FINAL DESIG	Y DESIGN)	
CLARK RICHARDSON & BISKUP						(FINAL DESIG	2N)	
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B		
ECO-A1	QU	ANTITY	M	IATERIAL		ABOR	TOL TOTAL	
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 475A								
REMOVE OLD SEALANT INSTALL NEW SEALANT								
REMOVE OLD CAULKING/	883		0.60	530	1.40	1,236	\$1,5	
NSTALL NEW CAULKING	883	FT	0.60	530	1.40	1,236	\$1,7	
WEATHERSTRIP WINDOWS	674	FT	1.40	944	2,60	1,752	\$2,6	
ASTRAGAL DOOR (30A)	7	FT	6.80	48	1.92	13		
······							•••• •	
SUBTOTAL				\$2,051		\$4,238	\$6,2	
ONTINGENCY 10%			10%	\$205	10%	\$424	\$6	
SUBTOTAL				\$2,256		\$4,662	\$6,9	
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$79	13.0%	\$606	\$6	
DIRECT COST				\$2,335		\$5,268	\$7,60	
VERHEAD AND PROFIT			25%	\$584	25%	\$1,317	\$1,9	
SUBTOTAL				\$2,919		\$6,585	\$9,50	
CONSTRUCTION COST					†	+0,000		
IG. FORM 150 VC-59			<u>_</u>			L	\$9,50	



- Switter

CONSTRUCTION COST ESTIMATE			DATE PR	CPARED	4/2/90)	SHEET	0F 10
PROJECT USDB ENERGY STUDY	BASIS FOR ESTIMATE							
LOCATION FORT LEAVENWORTH, KS		x		(NO DESIGN (PRELIMINAR		red)		
ARCHITECT/ENGINEER					CODEC	(FINAL DESIG	N)	N)
CLARK RICHARDSON & BIS DRAWING NO.	KUP	ESTIM	ATOR		OTHER	SPECIFY)	v	
NONE ECO-A1				DLS			TOL	
REDUCE INFILTRATION	NO.	<u>antity</u> I unit	PER	ATERIAL TOTAL	PER	ABOR TOTAL		OTAL OST
	UNITS	MEAS.	UNIT		UNIT			
BUILDING 475B								
REMOVE OLD SEALANT INSTALL NEW SEALANT	696	FT	0.60	440	1.10			
REMOVE OLD CAULKING/	000		0.60	412	1.40	960		\$1,3
INSTALL NEW CAULKING	686	FT	0.60	412	1.40	960		\$1,3
WEATHERSTRIP WINDOWS	310	FT	1.40	434	2.60	806		\$1,2
INSTALL NEW DOOR (101)								
REMOVE DOOR/FRAME	1	EA			100.00	100		\$1
NEW DOOR/FRAME	1	EA	420.00	420	80.00	80		\$5
FINISH HARDWARE		EA	510.00	510	90.00	90		\$6
PAINT	1	EA	5.00	5	35.00	35		\$
SEALANT/CAULK	34	FT	0.60	20	1.40	48		\$
MOBILIZATION	1	EA			140.00	140		\$1
INSTALL NEW DOOR (201)								
REMOVE DOOR/FRAME	1	EA			100.00	100		\$1
NEW DOOR/FRAME	1	EA	336.00	336	64.00	64		\$4
FINISH HARDWARE	1	EA	340.00	340	60.00	60		\$40
PAINT	1	EA	5.00	5	35.00	35		\$4
SEALANT/CAULK	28	FT	0.60	17	1.40	39		\$5
OBILIZATION	1	EA			120.00	120		\$12
SUBTOTAL				\$2,910		\$3,638		\$6,54
CONTINGENCY 10%			10%	\$291	10%	\$364		\$65
SUBTOTAL				\$3,201		\$4,002		\$7,20
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$112	13.0%	\$520	• <u> </u>	\$63
DIRECT COST				\$3,313		\$4,522		\$7,83
VERHEAD AND PROFIT			25%	\$828	25%	\$1,130		\$1,95
SUBTOTAL	┼──┤			\$4,141		\$5,652		\$9,79
CONSTRUCTION COST NG. FORM 150								\$9,79



CONSTRUCTION COST ESTIMATE DATE PR			EPARED)	SHEET OF		
LOCATION FORT LEAVENWORTH, KS				BASIS FOR E	11		
				x	CODEB	(PRELIMINAR	COMPLETED) Y DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS	KUP				CODEC	(FINAL DESIG	iN)
DRAWING NO. NONE		ESTIM	ATOR		OTTLA	CHECKED B	
ECO-A1	QUA		м	DLS ATERIAL		ABOR	TOL TOTAL
	NO. UNITS	UNIT	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475C							
REMOVE OLD SEALANT INSTALL NEW SEALANT	2244	ET .	0.60	1.046	4.40		• • •
REMOVE OLD CAULKING/ INSTALL NEW CAULKING					1.40		\$4,4
WEATHERSTRIP WINDOWS	2244		0.60		1.40		\$4,4
WEATHERSTRIP WINDOWS	3020	<u>FT</u>	1.40	4,228	2.60	7,852	\$12,0
							<u></u>
							······
	_						
							·
SUBTOTAL	╉╼╾╋			\$6,921		\$14,135	\$21,05
ONTINGENCY 10%	+		10%	\$692	10%	\$1,414	\$2,10
SUBTOTAL	╉╾╌┠		<u> </u>	\$7,613		\$15,549	\$23,16
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$266	13.0%	\$2,021	\$2,28
DIRECT COST				\$7,879		\$17,570	\$25,44
VERHEAD AND PROFIT	<u> </u>		25%	\$1,970	25%	\$4,393	\$6,36
SUBTOTAL	\downarrow			\$9,849		\$21,963	\$31,81
CONSTRUCTION COST							\$31,81



/	

PROJECT USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU DRAWING NO. NONE ECO-A1 REDUCE INFILTRATION BUILDING 475D REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING WEATHERSTRIP WINDOWS	QU/ NO. UNITS 2547	ESTIM, ANTITY UNIT MEAS.	M PER		CODE A CODE B CODE C		L 12 1 COMPLETED) Y DESIGN) iN)
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU DRAWING NO. NONE ECO-A1 REDUCE INFILTRATION BUILDING 475D REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING	QU/ NO. UNITS 2547		M PER	DLS	CODE B CODE C	(PRELIMINAR (FINAL DESIG (SPECIFY)	Y DESIGN)
CLARK RICHARDSON & BISKU DRAWING NO. NONE ECO-A1 REDUCE INFILTRATION BUILDING 475D REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING	QU/ NO. UNITS 2547		M PER	DLS	CODEC	(FINAL DESIG (SPECIFY)	N)
DRAWING NO. NONE ECO-A1 REDUCE INFILTRATION BUILDING 475D REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING	QU/ NO. UNITS 2547		M PER	DLS		CHECKED BY	
ECO-A1 REDUCE INFILTRATION BUILDING 475D REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING	NO. UNITS 2547	UNIT	PER				
BUILDING 475D REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING	<u>UNITS</u> 2547					ABOR	TOL TOTAL
REMOVE OLD SEALANT INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING			UNIT	TOTAL	PER UNIT	TOTAL	COST
INSTALL NEW SEALANT REMOVE OLD CAULKING/ INSTALL NEW CAULKING							
REMOVE OLD CAULKING/ INSTALL NEW CAULKING		ET	0.60	1 500			
					1.40		
WEATHERSTRIP WINDOWS	2547		0.60	1,528	1.40	3,566	\$5,094
	3700	FT	1.40	5,180	2.60	9,620	\$14,800
							
							· · · · · · · · · · · · · · · · · · ·
							<u> </u>
SUBTOTAL				\$8,236		\$16,752	\$24,988
CONTINGENCY 10%			10%	\$824	10%	\$1,675	\$2,499
SUBTOTAL				\$9,060		\$18,427	\$27,487
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$317	13.0%	\$2,395	\$2,712
DIRECT COST				\$9,377		\$20,822	\$30,199
VERHEAD AND PROFIT			25%	\$2,344	25%	\$5,205	\$7,549
SUBTOTAL				\$11,721		\$26,027	\$37,748
CONSTRUCTION COST NG. FORM 150 AVC-59							\$37,748

ECO-A1

CONSTRUCTION COST ESTIMATE			DATE PF	REPARED	4/2/90)	SHEET OF 13	
PROJECT USDB ENERGY STUDY			A	BASIS FOR			13	
LOCATION FORT LEAVENWORTH, KS				x		(NO DESIGN (PRELIMINAR		
ARCHITECT/ENGINEER CLARK RICHARDSON & BISK	UP	·····			_CODE C	(FINAL DESIG	N)	
DRAWING NO. NONE		ESTIM	ATOR	DLS	UTTER	CHECKED B	ED BY	
ECO-A1	QU.	ANTITY	M	IATERIAL		ABOR	TOL TOTAL	
REDUCE INFILTRATION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 475E REMOVE OLD SEALANT								
INSTALL NEW SEALANT REMOVE OLD CAULKING/	2800	FT	0.60	1,680	1.40	3,920	\$5,60	
	2800	FT	0.60	1,680	1.40	3,920	\$5,60	
WEATHERSTRIP WINDOWS	2407	FT	1.40	3,370	2.60	6,258	\$9,62	
REPLACE PAIR DOORS (40A)								
REMOVE DOOR/FRAME	1	EA			150.00	150	\$15	
NEW DOOR/FRAME	1	EA	840.00	840	160.00	160	\$1,00	
FINISH HARDWARE	1	EA	680.00	680	120.00	120	\$80	
PAINT	1	EA	20.00	20	80.00	80	\$10	
SEALANT/CAULK	42	FT	0.60	25	1.40	59	\$84	
MOBILIZATION	1	EA			160.00	160	\$160	
REPLACE PAIR DOORS (40A)								
REMOVE DOOR/FRAME	1	EA			150.00	150	\$150	
NEW DOOR/FRAME	1	EA	935.00	935	165.00	165	\$1,100	
	1	EA	680.00	680	120.00	120	\$800	
PAINT		EA	25.00	25	95.00	95	\$120	
SEALANT/CAULK	44		0.60	26	1.40	62	\$88	
	1	EA			160.00	160	\$160	
REPLACE PAIR DOORS (40A)								
					150.00	150	\$150	
			1020.00	1,020	180.00	180	\$1,200	
	18		680.00	680	120.00	120	\$800	
	1		30.00			110	\$140	
	46 F		0.60	28	1.40	64	\$92	
OBILIZATION	1 E	A			160.00	160	\$160	

CONSTRUCTION COST ESTIMATE			DATE PF	REPARED		SHEET OF	
PROJECT USDB ENERGY STUDY	···		I	BASIS FOR	4/2/9 ESTIMAT		14
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				X	CODE B	(NO DESIGN (PRELIMINA) (FINAL DESI	COMPLETED) RY DESIGN)
CLARK RICHARDSON & BIS				OTHER (SPE		(SPECIFY)	
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	TOL
ECO-A1		ANTITY		ATERIAL		LABOR	TOTAL
REDUCE INFILTRATION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475E CONTINUED							
				•			
	_						
	_						
SUBTOTAL				\$11,719		\$16,363	\$28,082
CONTINGENCY 10%	_		10%	\$1,172	10%	\$1,636	\$2,808
SUBTOTAL	_			\$12,891		\$17,999	\$30,890
VORK COMP, TAX, SOC. SEC., INS			3.50%	\$451	13.0%	\$2,340	\$2,791
DIRECT COST				\$13,342		\$20,339	\$33,681
VERHEAD AND PROFIT			25%	\$3,336	25%	\$5,085	\$8,421
SUBTOTAL				\$16,678		\$25,424	\$42,102
CONSTRUCTION COST NG. FORM 150							\$42,102



الحف

CONSTRUCTION COST ESTIMATE			IDATE PF	REPARED			SHEET OF
PROJECT		··		BASIS FOR	4/2/90		15
USDB ENERGY STUDY]			
FORT LEAVENWORTH, KS				X CODE A (NO DESIGN COMPLI CODE B (PRELIMINARY DESIG			
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS							N)
DRAWING NO.		ESTIM	ATOP		OTHER	(SPECIFY)	
NONE			ATON	DLS		CHECKED B	
ECO-A1 REDUCE INFILTRATION		ANTITY		ATERIAL	L	ABOR	TOL TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475F							
REMOVE OLD SEALANT							
NSTALL NEW SEALANT REMOVE OLD CAULKING/	2587	FT	0.60	1,552	1.40	3,622	\$5,
NSTALL NEW CAULKING	2587	_	0.00				φ0,
			0.60	1,552	1.40	3,622	\$5,
NEATHERSTRIP WINDOWS	3700	FT	1.40	5,180	2.60	9,620	\$14,
							·····
							<u></u>
	++						
	╉╾╾╋						
	╉╾╾┥						
SUBTOTAL	++			\$8,284		\$16,864	\$25,14
DNTINGENCY 10%			10%	\$828	10%	\$1,686	
SUBTOTAL		_ T		\$9,112			\$2,51
DRK COMP, TAX, SOC. SEC., INS			3.50%		10.00	\$18,550	\$27,66
DIRECT COST			0.00 /0	\$319	13.0%	\$2,411	\$2,73
ERHEAD AND PROFIT	<u>†</u> ── <u>†</u>			\$9,431		\$20,961	\$30,39
	┼┼-		25%	\$2,358	25%	\$5,240	\$7,59
SUBTOTAL	┼───┤-			\$11,789		\$26,201	\$37,99
CONSTRUCTION COST G. FORM 150							\$37,99



CONSTRUCTION COST ESTIMATE			DATE PF					
PROJECT			L	BASIS FOR			16	
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS		••• <u></u> ,		 x		(NO DESIGN (PRELIMINAR		
ARCHITECT/ENGINEER CLARK RICHARDSON & BISH	KUP				CODEC	(FINAL DESIG	SN)	
DRAWING NO. NONE		ESTIM	ATOR	L	UTHER	CHECKED B	-	
ECO-A1		ANTITY	M	DLS ATERIAL		ABOR	TOL	
REDUCE INFILTRATION	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST	
BUILDING 475G								
REMOVE OLD SEALANT INSTALL NEW SEALANT	2392	FT	0.60	1,435	1.40	3,349	\$4,78	
REMOVE OLD CAULKING/ INSTALL NEW CAULKING	2392		0.60					
WEATHERSTRIP WINDOWS	3020				1.40		\$4,78	
	3020		1.40	4,228	2.60	7,852	\$12,08	
							·	
							· · · · · · · · · · · · · · · · · · ·	
	<u> </u>							
SUBTOTAL				\$7,098		\$14,550	\$21,648	
CONTINGENCY 10%			10%	\$710	10%	\$1,455	\$2,165	
SUBTOTAL				\$7,808		\$16,005	\$23,813	
VORK COMP, TAX, SOC. SEC., INS			3.50%	\$273	13.0%	\$2,081	\$2,354	
DIRECT COST				\$8,081		\$18,086	\$26,167	
VERHEAD AND PROFIT			25%	\$2,020	25%	\$4,521	\$6,541	
SUBTOTAL				\$10,101		\$22,607	\$32,708	
CONSTRUCTION COST					-		ψυζ,700	



and the second

CONSTRUCTION COST ESTIMATE			DATE PR	EPARED	`	SHEET OF	
PROJECT			1	BASIS FOR E	4/2/90		17
				x		(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS					CODE B	(PRELIMINAR	Y DESIGN)
					CODE C	(FINAL DESIG	iN)
CLARK RICHARDSON & BIS DRAWING NO.	KUP	ESTIM	ATOP	L	OTHER	SPECIFY)	
NONE		ESTIM	AION	DLS		CHECKED BY	TOL
ECO-A1	QU	ANTITY		ATERIAL	L	ABOR	TOTAL
REDUCE INFILTRATION	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475H							
REMOVE OLD SEALANT							
INSTALL NEW SEALANT REMOVE OLD CAULKING/	900	FT	0.60	540	1.40	1,260	\$1,8
INSTALL NEW CAULKING		FT	0.60	540	1.40	1,260	\$1,8
WEATHERSTRIP WINDOWS	350		1.40		2.60		
		· · ·	1.40	490	2.60	910	\$1,4
	_						
SUBTOTAL				\$1,570		\$3,430	\$5,0
ONTINGENCY 10%			10%	\$157	10%	\$343	\$50
SUBTOTAL				\$1,727		\$3,773	\$5,50
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$60	13.0%	\$490	\$55
DIRECT COST	_			\$1,787		\$4,263	\$6,05
VERHEAD AND PROFIT			25%	\$447	25%	\$1,066	\$1,51
SUBTOTAL				\$2,234		\$5,329	\$7,56
CONSTRUCTION COST	I T						T. 100



ECO-A2

WINDOW REPLACEMENT

DOUBLE GLAZED WINDOWS

ENERGY CONSERVATION OPPORTUNITY: ECO-A2

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-A2) analyzed the energy savings associated with reducing the amount of heat transfer to and from the buildings by conduction through the glass or plastic in the windows. The implementation of this ECO will not change the number or location of any of the windows.

SCOPE:

The ECO simulation (ECO-A2) changed the windows in some of the buildings from a single paned plastic or glass to double glazed. The application of this project was considered for the following buildings:

Building 450 Building 465 Building 475 Building 475C Building 475D Building 475E Building 475F Building 475G

MODELING TECHNIQUES:

The amount of heat loss or gain through the existing windows was simulated using the "Trace Ultra" computer program. All of the exterior windows considered for replacement are shown in the window schedules for each building, Volume 5. The windows to be replaced have a coefficient of heat transfer (U-value) associated with the heat conduction through the window material. This U-value was entered into the computer program and used to calculate the amount of energy used by the building. The new double glazed windows have a new U-value that was used in the computer program to calculate the amount of energy used if the windows were replaced. Table A2.1 displays the U-values used for the existing single glazed windows. All of the windows being replaced will be replaced with double glazed windows with the Uvalues shown in the Table A2.1. If the windows were replaced the tightness of the window would increase, thus a reduction in infiltration would occur. The reduction in infiltration due to weatherstripping and caulking as calculated in ECO-A1 of this report would be valid for this ECO also. The new infiltration as calculated in ECO-A1 will be entered into the computer model for the ECO-A2 execution. The difference in the energy usage before and after the implementation of the ECO was the energy savings from the ECO.



Building Number	Existing Window Type	Existing U-value	New U-value
450	Single Plastic	0.81	0.52
465	Single Plastic	0.81	0.52
475	Single Pane Glass	0.81	0.52
475C	Single Pane Glass	0.81	0.52
475D	Single Pane Glass	0.81	0.52
475F	Single Pane Glass	0.81	0.52
475G	Single Pane Glass	0.81	0.52

Table A2.1

ECO IMPLEMENTATION:

The implementation of this ECO would not change the physical appearance of any of the buildings being considered for the window replacement. The windows that would be replaced are listed in the cost estimate in this section of the report. To remove the existing window in most cases a skilled carpenter can remove the majority of the windows from outside the building with a ladder. The entire window would be removed and a new double glazed window of the same size would be installed and weatherstripped around the casing on the inside and outside. The new double glazed windows would be the same in size, function, and operation. This ECO would need to be implemented during seasonally adequate times, possibly in the spring or fall. The replacement of the windows in the castle cell barracks would have to be scheduled so as not to have the building unsecured for any long periods of time.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown below in Table A2.2 in million BTU's per year as determined using the computer simulation model.

The project cost is the construction cost as determined in the following pages plus 6% SIOH is shown in Table A2.2.

The only buildings considered for this energy saving opportunity were buildings where the windows have not already been replaced with insulated windows. Buildings 450 and 465 are cooling buildings but have a tremendous amount of windows. The rest of the buildings considered were heating only buildings and a payback is not feasible.



Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
450	104	\$455	\$36,091	74.60	0.21
465	217	\$892	\$391,395	414.93	0.04
475	78	\$317	\$111,196	331.03	0.05
475C	161	\$658	\$640,908	318.52	0.05
475D	237	\$967	\$755,356	254.16	0.06
475F	186	\$761	\$755,356	323.81	0.05
475G	164	\$671	\$640,908	312.81	0.05

Table A2.2

ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGION NOS. 7 PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: 450A2	CENSUS: 2
ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YEARS PREPARED B	T. CRD
 INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E) 	\$ 34048. \$ 2043. \$ 1873. \$ 34168. -\$ 0. \$ 34168.
 ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAVINGS 	
UNIT COST SAVINGS ANNUAL \$ DISCOUNT FUEL \$/MBTU(1) MBTU/YR(2) SAVINGS(3) FACTOR(4)	DISCOUNTED SAVINGS(5)
A. ELECT\$12.444.\$50.11.16B. DIST\$.000.\$0.17.19C. RESID\$.000.\$0.17.12D. NAT G\$4.08100.\$408.16.15E. COAL\$.000.\$0.13.92	558. 0. 0. 6589. 0.
F. TOTAL 104. \$ 458.	\$ 7147.
3. NON ENERGY SAVINGS(+) / COST(-)	
A. ANNUAL RECURRING (+/-)	\$ 0.
 (1) DISCOUNT FACTOR (TABLE A) (2) DISCOUNTED SAVING/COST (3A X 3A1) 	\$ 0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3A2+3Bd4)	\$0.
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) 2359. A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = (2F5+3D1)/1F)= C IF 3D1B IS = > 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY	
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOMIC LIFE))	\$ 458.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)	\$ 7147.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= 0.21 (IF < 1 PROJECT DOES NOT QUALIFY)	
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4 74.60	



LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGION I PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: 465A2	NOS. 7	LC	: USDBAE CID 1.035 CENSUS: 2
FISCAL YEAR 1990 DISCRETE PORTION NAME: 465A2 ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YEARS PR	EPARED	BY: CRB	
 INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E) 		\$ \$ \$ \$ \$ \$ -\$	369241. 22154. 20308. 370533. 0. 370533.
 ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAV 	VINGS		
	SCOUNT CTOR(4)		COUNTED 'INGS(5)
A. ELECT\$ 12.441.\$ 12.B. DIST\$.000.\$ 0.C. RESID\$.000.\$ 0.D. NAT G\$ 4.08216.\$ 881.E. COAL\$.000.\$ 0.	11.16 17.19 17.12 16.15 13.92		134. 0. 0. 14228. 0.
F. TOTAL 217. \$ 893.		\$	14362.
3. NON ENERGY SAVINGS(+) / COST(-)			
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) 11.65		\$	0.
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3A2+3	3Bd4)	\$	0.
 D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = (2F5+3D1)/1F)= C IF 3D1B IS = > 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY 	4739.		
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOMIC)	_IFE))	\$	893.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)		\$	14362.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= (IF < 1 PROJECT DOES NOT QUALIFY)	0.04		
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4	414.93		

	ENE STALLATION &	RGY C & LOC	ONSERVAT	OST ANALYS TION INVEST RT LEAVENW	MENT PR	OGRAM (E	CIP) GION NOS	. 7	L(Y: USDBAE CCID 1.035 CENSUS: 2
FIS	SCAL YEAR 19 IALYSIS DATE	990	DIS	CRETE POR ECONOMI			PREPA	RED	BY: CR	В
1.	INVESTMEN A. CONSTRU B. SIOH C. DESIGN (D. ENERGY E. SALVAGE F. TOTAL IN	UCTIO COST CRED E VALL	DIT CALC (1. JE COST)				\$\$ \$\$ \$\$ \$\$ \$\$ \$	104902. 6294. 5770. 105269. 0. 105269.
2.	ENERGY SA ANALYSIS D	VINGS ATE A	S (+) / COST NNUAL SAV	(-) /INGS, UNIT	COST & E	ISCOUNTE	ED SAVINO	SS		
	FUEL		JNIT COST 5/MBTU(1)	SAVINGS MBTU/YR(NUAL \$ AVINGS(3)	DISCO FACTO			SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 78. 0.	\$ \$ \$ \$ \$ \$ \$	0. 0. 318. 0.	1 1 1	1.16 7.19 7.12 6.15 3.92		0. 0. 5136. 0.
	F. TOTAL			78.	\$	318.			\$	5136.
3.	NON ENERG	GY SAN	/INGS(+) / C	OST(-)						
	A. ANNUAL		RRING (+/-) FACTOR (T			11.65			\$	0.
				COST (3A X	3A1)				\$	0.
	C. TOTAL N	ON EN	NERGY DISC	OUNTED SA	VINGS(+)	/COST(-)	(3A2+3Bd4	4)	\$	0.
	(1) 25% I A IF 3 B IF 3 C IF 3	MAX N D1 IS D1 IS 3D1B I	ION ENERG = OR > 3C C < 3C CALC IS = > 1 GO	UALIFICATIO Y CALC (2F5 GO TO ITEM 4 SIR = (2F5+ TO ITEM 4 ECT DOES NO	X .33) 4 -3D1)/1F):		\$ 1 	695.		·
4.	FIRST YEAF		AR SAVING	S 2F3+3A+(3	B1D/(YEA	ARS ECONO	OMIC LIFE))	\$	318.
5.	TOTAL NET	DISCO	DUNTED SA	VINGS (2F5+	3C)				\$	5136.
6.	DISCOUNTE (IF < 1 PROJ				(S	ilR)=(5 / 1F))=	0.05		
7.	SIMPLE PAY	BACK	PERIOD (E	STIMATED)	SPB=1F	/4	33	31.03		

	•		-							
PF FIS	ENER STALLATION & OJECT NO. & 1 SCAL YEAR 199 IALYSIS DATE:	GY CONS LOCATIC TITLE: 14 90	SERVATION: FORT 96 DISC	RETE POR	AENT PRO ORTH - U FIQN NAMI	GRAM (EC SDB REG E: 475CA2	CIP) SION NOS.	7	LCC C	USDBAE XID 1.035 [.] ENSUS: 2
1.	INVESTMENT A. CONSTRUE B. SIOH C. DESIGN CO D. ENERGY C E. SALVAGE F. TOTAL INV	CTION CO OST CREDIT C VALUE C	ALC (1A- OST						\$\$ \$ \$ \$\$ \$ \$ \$	208538. 12512. 11470. 209268. 0. 209268.
2.	ENERGY SAV ANALYSIS DA	INGS (+) . TE ANNU	/ COST (- IAL SAVII) NGS, UNIT (COST & DIS	SCOUNTE	D SAVINGS	6		
	FUEL			SAVINGS MBTU/YR(2		IUAL \$ 'INGS(3)				OUNTED NGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ 4	2.44 .00 .00. 4.08 .00	0. 0. 0. 161. 0.	\$ \$ \$ \$ \$	0. 0. 657. 0.	17 17 16	.16 .19 .12 .15 :92		0. 0. 0. 10611. 0.
	F. TOTAL			161.	\$	657.			\$	10611.
3.	NON ENERGY	(SAVING	S(+) / CO	ST(-)						
	A. ANNUAL R					11.65			\$	0.
	(1) DISCO (2) DISCO			OST (3A X	3A1)	11.00			\$	0.
	C. TOTAL NO	N ENERC	AY DISCO	DUNTED SA	VINGS(+) /	COST(-) (3A2+3Bd4)		\$	0.
	A IF 3D B IF 3D C IF 3I	AX NON I)1 IS = OF)1 IS < 3C D1B IS = :	ENERGY R > 3C GC CALC S > 1 GO TC	CALC (2F5 0 TO ITEM 4 SIR = (2F5+)	X .33) 3D1)/1F)=	Y	\$ 35	02.		
4.	FIRST YEAR I	DOLLAR	SAVINGS	2F3+3A+(31	B1D/(YEAF	S ECONO	MIC LIFE))		\$	657.
5.	TOTAL NET D	ISCOUNT	TED SAVI	NGS (2F5+3	3C)				\$	10611.
6.	DISCOUNTED (IF < 1 PROJE			JALIFY)	(SIF	R)=(5 / 1F)=	= 0	.05		
7.	SIMPLE PAYE	BACK PEF	RIOD (ES	TIMATED)	SPB=1F/4		318	.52		

· · · · · ·			
LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGIO PROJECT NO. & TITLE: 1496) N NOS. 7	LC	': USDBAE CID 1.035 CENSUS: 2
FISCAL YEAR 1990 DISCRETE PORTION NAME: 475DA2	PREPARED	BY: CRE	3
 INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E) 		\$ \$ \$ \$ \$ \$ \$ \$ \$ \$	244911. 14695. 13470. 245768. 0. 245768.
 ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED S 	SAVINGS		
	DISCOUNT FACTOR(4)		COUNTED /INGS(5)
A. ELECT\$ 12.440.\$ 0.B. DIST\$.000.\$ 0.C. RESID\$.000.\$ 0.D. NAT G\$ 4.08237.\$ 967.E. COAL\$.000.\$ 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 15617. 0.
F. TOTAL 237. \$ 967.		\$	15617.
3. NON ENERGY SAVINGS(+) / COST(-)			
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) 11.65		\$	0.
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3A2	2+3Bd4)	\$	0.
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) \$ A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = (2F5+3D1)/1F)= C IF 3D1B IS = > 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY	5154.		
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOMI	C LIFE))	\$	967.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)		\$	15617.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= (IF < 1 PROJECT DOES NOT QUALIFY)	0.06		
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4	254.16		

						DV		STUD	Y: USDBAE
	STALLATION &	GY C	ONSERVAT ATION: FOF	OST ANALYSI ION INVEST RT LEAVENW	MENT PRO	GRAM (EC	IP) ION NOS. 7	L	CCID 1.035 CENSUS: 2
FIS	OJECT NO. & 1 SCAL YEAR 199 ALYSIS DATE:	0	DIS	CRETE POR ECONOMIC	TION NAM	E: 475FA2 /EARS	PREPARED	BY: CR	В
1.	INVESTMENT A. CONSTRUC B. SIOH C. DESIGN CO D. ENERGY C E. SALVAGE F. TOTAL INV	OST RED VALL	IT CALC(1) JE COST					\$\$ \$\$ \$\$ \$ \$ \$\$	244911. 14695. 13470. 245768. 0. 245768.
2.	ENERGY SAV ANALYSIS DA	INGS TE A	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT (COST & D	SCOUNTE) SAVINGS		
	FUEL		INIT COST /MBTU(1)			NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$	12.44 .00 .00 4.08 .00	0. 0. 186. 0.	\$\$ \$\$ \$\$ \$\$	0. 0. 0. 759. 0.	17.12		0. 0. 12258. 0.
	F. TOTAL			186.	\$	759.		\$	12258.
3.	NON ENERGY	SAV	/INGS(+) / C	OST(-)					
	A. ANNUAL R					11.65		\$	0.
			FACTOR (T) ED SAVING/	COST (3A X	3A1)	11.05		\$	0.
	C. TOTAL NO	N EN	IERGY DISC	OUNTED SA	VINGS(+)	/COST(-) (3	3A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3I	AX N 1 IS 1 IS 21 B I	ON ENERG` = OR > 3C G < 3C CALC S = > 1 GO ⁻	Y CALC (2F5 30 TO ITEM 4 SIR = (2F5+	X .33) 3D1)/1F)=	-7	\$ 4045.		
4.	FIRST YEAR I		AR SAVING	S 2F3+3A+(3	B1D/(YEA	RS ECONO	MIC LIFE))	\$	759.
5.	TOTAL NET D	ISCO	OUNTED SA	VINGS (2F5+	3C)			\$	12258.
6.	DISCOUNTED (IF < 1 PROJE				(SI	R)=(5 / 1F)=	≖ 0.05		
7.	SIMPLE PAYE	BACK	PERIOD (E	STIMATED)	SPB=1F	4	323.81		

	STALLATION &	GY CONS LOCATIC	SERVATIO N: FORT	T ANALYSI N INVESTN LEAVENW	MENT PF	OGRAM (EC	CIP) SION NOS.		LCCI	USDBAE D 1.035 NSUS: 2
FIS	OJECT NO. & T SCAL YEAR 199 ALYSIS DATE:	0	DISCF			ME: 475GA2 YEARS		ED BY	: CRB	
1.	INVESTMENT A. CONSTRUC B. SIOH C. DESIGN CO D. ENERGY C E. SALVAGE F. TOTAL INV	OST REDIT C VALUE C	ALC (1A+ OST						6 6 6 6 6 6 6	208538. 12512. 11470. 209268. 0. 209268.
2.	ENERGY SAV	INGS (+) TE ANNU	/ COST (-) IAL SAVIN	GS, UNIT (COST & I	DISCOUNTE	D SAVINGS	5		
	FUEL			SAVINGS MBTU/YR(2		NNUAL \$ AVINGS(3)	DISCOU FACTOF		DISCO	DUNTED IGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$	2.44 .00 .00 4.08 . .00	0. 0. 0. 164. 0.	\$\$ \$\$ \$\$ \$\$	0. 0. 669. 0.	17. 17. 16.	.16 .19 .12 .15 [.] .92		0. 0. 0. 10804. 0.
	F. TOTAL			164.	\$	669.			\$	10804.
3.	NON ENERGY	SAVING	iS(+) / COS	ST(-)						
	A. ANNUAL R					14.05			\$	0.
	(1) DISCO (2) DISCO			DST (3A X	3A1)	11.65			\$	0.
	C. TOTAL NO	N ENER	GY DISCO	UNTED SA	VINGS(+)/COST(-) (3A2+3Bd4)	:	\$	0.
	A IF 3D B IF 3D C IF 3I	AX NON 01 S = OF 01 S < 30 01B S = :	ENERGY (R > 3C GO ; CALC S > 1 GO TO	CALC (2F5 TO ITEM 4 IR = (2F5+	X .33) 3D1)/1F)		\$ 35	65.		
4.	FIRST YEAR (DOLLAR	SAVINGS	2F3+3A+(3	B1D/(YE	ARS ECONC	MIC LIFE))	;	\$	669.
5.	TOTAL NET D	ISCOUN	TED SAVIN	NGS (2F5+3	3C)			:	\$	10804.
6.	DISCOUNTED (IF < 1 PROJE			ALIFY)	()	SIR)=(5 / 1F)=	= 0	.05		
7.	SIMPLE PAYE	BACK PE	RIOD (EST	IMATED)	SPB=1	F/4	312	.81		

.

. .

PAGE A2-10

CONSTRUCTION COST ESTIMATE	DATE PR	EPARED	SHEET OF				
PROJECT USDB ENERGY STUDY	4/2/90 1 BASIS FOR ESTIMATE						
LOCATION FORT LEAVENWORTH, KS			X	CODE B	(NO DESIGN (PRELIMINAR	Y DESIGN)	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	Р			OTHER	(FINAL DESIG	iN)	
DRAWING NO.		ESTIM	ATOR			CHECKED B	Y TOL
NONE ECO-A2	QUA	ANTITY		DLS ATERIAL	l	ABOR	TOTAL
	NO. UNITS	UNIT MEAS.		TOTAL	PER UNIT	TOTAL	COST
BUILDING 450						-	
INSTALL ALUMINUM DOUBLE PANE INSULATED PROJECTION/FIXED WINDOWS	555	SQ FT	37.20	20,646	4.41	2,448	\$23,094
MOBILIZATION	555	SQ FT			1.00	555	\$555
	<u> </u>						
SUBTOTAL				\$20,646		\$3,003	\$23,649
CONTINGENCY 10%			10%	\$2,065	10%	\$300	\$2,365
SUBTOTAL				\$22,711		\$3,303	\$26,014
WORK COMP, TAX, SOC. SEC., INS			3.50%	\$795	13.0%	\$429	\$1,224
DIRECT COST				\$23,506		\$3,732	\$27,238
OVERHEAD AND PROFIT			25%	\$5,877	25%	\$933	\$6,810
SUBTOTAL				\$29,383		\$4,665	\$34,048
CONSTRUCTION COST ENG. FORM 150							\$34,048
1AVC-59							

CONSTRUCTION COST ESTIMATE	DATE PR	EPARED	SHEET OF				
PROJECT	L	4/2/90 BASIS FOR ESTIMATE			2		
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS			X	CODEA	(NO DESIGN	O DESIGN COMPLETED) RELIMINARY DESIGN)	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL				(FINAL DESIG	SN)		
DRAWING NO.	JE	ESTIM	ATOR	!	UTHER	SPECIFY)	Y
ECO-A2		ANTITY	M	DLS IATERIAL	1 1	ABOR	TOL
WINDOW REPLACEMENT	NO.	UNIT MEAS.	PER	TOTAL		TOTAL	TOTAL COST
BUILDING 465							
INSTALL ALUMINUM DOUBLE PANE INSULATED PROJECTION/FIXED WINDOWS	6019	SO FT	37.20	223,907	4.41	26,544	\$250,4
MOBILIZATION	6019	SQ FT			1.00	6,019	\$6,0
							<u> </u>
							•
							····
SUBTOTAL				\$223,907		\$32,563	\$256,47
ONTINGENCY 10%			10%	\$22,391	10%	\$3,256	\$25,64
				\$246,298		\$35,819	\$282,11
ORK COMP,TAX,SOC.SEC.,INS			3.50%	\$8,620	13.0%	\$4.656	\$13,27
DIRECT COST				\$254,918		\$40,475	\$295,39
SUBTOTAL			25%	\$63,729	25%	\$10,119	\$73,84
				\$318,647		\$50,594	\$369,24
NG. FORM 150		l.	l				\$369,24

CONSTRUCTION COST ESTIMATE			DATE PR	4/2/90 3				
PROJECT USDB ENERGY STUDY				BASIS FOR	ESTIMATE		3	
LOCATION FORT LEAVENWORTH, KS				x	CODE B	(PRELIMINAR	COMPLETED) Y DESIGN)	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL	P				CODE C	(FINAL DESIG	GN)	
DRAWING NO.	<u> </u>	ESTIM	ATOR	1	UINER	CHECKED B	Υ	
ECO-A2			м	DLS ATERIAL	<u> </u>	ABOR	TOL TOTAL	
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 475								
INSTALL ALUMINUM DOUBLE PANE								
INSULATED PROJECTION/FIXED WINDOWS	1710	SQ FT	37.20	63,612	4.41	7,541	\$71,1	
MOBILIZATION	1710	<u>SQ FT</u>			1.00	1,710	\$1,71	

							•	
SUBTOTAL				\$63,612		\$9,251	\$72,863	
ONTINGENCY 10%			10%	\$6,361	10%	\$925	\$7,286	
SUBTOTAL				\$69,973		\$10,176	\$80,149	
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$2,449	13.0%	\$1,323	\$3,772	
DIRECT COST				\$72,422		\$11,499	\$83,921	
VERHEAD AND PROFIT			25%	\$18,106	25%	\$2,875	\$20,981	
SUBTOTAL				\$90,528		\$14,374	\$104,902	
CONSTRUCTION COST							\$104,902	

.

CONSTRUCTION COST ESTIMATE				EPARED	SHEET OF			
PROJECT			<u></u>	BASIS FOR	ESTIMATE			
USDB ENERGY STUDY				x	CODEA	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS						(PRELIMINAR (FINAL DESIG	Y DESIGN)	
CLARK RICHARDSON & BISKU	P					(SPECIFY)	114)	
DRAWING NO.		ESTIM	ATOR			CHECKED B		
NONE ECO-A2			M	DLS IATERIAL	1 1	ABOR	TOL TOTAL	
WINDOW REPLACEMENT	NO. UNITS	UNIT	PER UNIT	TOTAL	PER	TOTAL	COST	
BUILDING 475C								
INSTALL ALUMINUM DOUBLE PANE INSULATED PROJECTION/FIXED WINDOWS	4323	SQ FT	27.99	121,001	4,41	19,064	\$140,0	
MOBILIZATION	4323	SQ FT			1.00	4,323	\$4,3	
			_					
· · · · · · · · · · · · · · · · · · ·								
		. <u>.</u>						
							•	
							· · · · · · · · · · · · · · · · · · ·	
							· · · · · · · · · · · · ·	
SUBTOTAL				\$121,001		\$23,387	\$144,38	
CONTINGENCY 10%			10%	\$12,100	10%	\$2,339	\$14,43	
SUBTOTAL				\$133,101		\$25,726	\$158,82	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$4,659	13.0%	\$3,344	\$8.00	
DIRECT COST				\$137,760		\$29,070	\$166,83	
VERHEAD AND PROFIT			25%	\$34,440	25%	\$7,268	\$41,70	
SUBTOTAL				\$172,200		\$36,338	\$208,53	
CONSTRUCTION COST		l	1	I			\$208,53	

			DATE P		4/2/90)	SHEET OF
PROJECT				BASIS FOR	ESTIMATE		· · · · · · · · · · · · · · · · · · ·
USDB ENERGY STUDY				×	CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS					CODE B	(PRELIMINAR	Y DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	D					(FINAL DESIG	BN)
DRAWING NO.	1	ESTIM	TOR	I	OTHER	SPECIFY)	Υ
NONE ECO-A2	011			DLS	,		TOL
	NO.	ANTITY UNIT	PER	ATERIAL	PER	ABOR TOTAL	TOTAL COST
		MEAS.	UNIT		UNIT		0031
BUILDING 475D							
INSTALL ALUMINUM DOUBLE PANE							
INSULATED PROJECTION/FIXED WINDOWS	5077	SQ FT	27.99	142,105	4.41	22,390	\$164
MOBILIZATION	5077	SQ FT			1.00	5,077	\$5
			•				
			i				
							·····
		ł					
				1			
-							
SUBTOTAL				A1 10 105			
				\$142,105		\$27,467	\$169,
ONTINGENCY 10%			10%	\$14,211	10%	\$2,747	\$16,9
SUBTOTAL				\$156,316		\$30,214	\$186,
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$5,471	12.05/		
			3.30%		13.0%	\$3,928	\$9,3
DIRECT COST				\$161,787		\$34,142	\$195,9
VERHEAD AND PROFIT			25%	\$40,447	25%	\$8,535	\$48,9
SUBTOTAL				\$202,234		\$42,677	\$244,9
1				4242,204		<u> </u>	
CONSTRUCTION COST	1				1		\$244.9





CONSTRUCTION COST ESTIMATE				IEPARED	SHEET OF	•		
PROJECT			£	BASIS FOR E	4/2/90		<u> </u>	
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS		<u> </u>		x		(NO DESIGN ((PRELIMINAR	COMPLETED)	
ARCHITECT/ENGINEER			<u></u>		CODEC	(FINAL DESIG	iN)	
CLARK RICHARDSON & BISKU DRAWING NO.	P	ESTIM	ATOR		OTHER	SPECIFY)	Y	
NONE ECO-A2	011			DLS			TOL	
WINDOW REPLACEMENT	NO.	UNIT MEAS.	PER UNIT	ATERIAL TOTAL		TOTAL	TOTAL COST	
BUILDING 475F								
INSTALL ALUMINUM DOUBLE PANE INSULATED PROJECTION/FIXED WINDOWS	5077	SQ FT	27.99	142,105	4.41	22,390	\$16	4.4
MOBILIZATION	5077	SQ FT			1.00	5,077	\$	5,0
								·
							<u> </u>	
·····		·						
· ·			<u> </u>					
SUBTOTAL				\$142,105		\$27,467	\$169	
CONTINGENCY 10%			10%	\$14,211	10%	\$2,747	\$16	
SUBTOTAL				\$156,316		\$30.214	\$186	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$5,471	13.0%	\$3,928	\$9.	.39
DIRECT COST				\$161,787		\$34,142	\$195	,92
VERHEAD AND PROFIT			25%	\$40,447	25%	\$8,535	\$48.	.98
SUBTOTAL				\$202,234		\$42,677	\$244,	<u>,91</u>
CONSTRUCTION COST							\$244.	.91

•

.

.

PROJECT	· · · ·				4/2/90		7	
USDB ENERGY STUDY				BASIS FOR E	STIMATE			
LOCATION				<u> </u>		(NO DESIGN		
FORT LEAVENWORTH, KS						(PRELIMINAR		
CLARK RICHARDSON & BISKL	P					(FINAL DESIG (SPECIFY)	iGN)	
DRAWING NO.		ESTIM	ATOR			CHECKED BY	/	
ECO-A2		ANTITY	M	DLS IATERIAL	r	ABOR	TOL TOTAL	
WINDOW REPLACEMENT	NO.	UNIT	PER	TOTAL	PER	TOTAL	COST	
	UNITS	MEAS.	UNIT		UNIT			
BUILDING 475G								
INSTALL ALUMINUM DOUBLE PANE								
INSULATED PROJECTION/FIXED WINDOWS	4323	SQ FT	27.99	121,001	4.41	19,064	\$140,0	
MOBILIZATION	4222	SQ FT			1.00	4,323	\$4.3	
MOBILIZATION	4323	SUFI			1.00	4,323	54,3	
				······				
		· ·	·					
· · · · · · · · · · · · · · · · · · ·								
		1						
SUBTOTAL				\$121 001		\$22.207	£144.00	
				\$121,001		\$23,387	\$144.38	
CONTINGENCY 10%			10%	\$12,100	10%	\$2,339	\$14,43	
SUBTOTAL	1	1		\$133,101		\$25,726	\$158,82	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$4,659	13.0%	\$3,344	\$8,00	
DIRECT COST	1			\$137,760		\$29,070	\$166,83	
					t			
OVERHEAD AND PROFIT			25%	\$34,440	25%	\$7,268	\$41,70	
SUBTOTAL				\$172,200		\$36,338	\$208,53	
							φ200,00	
CONSTRUCTION COST	1	1					\$208,53	

ECO-A3 ECONOMIC ANALYSIS

	STEAM CONS	SUMPTION	e en terre de la	ELECTRIC CONSUMPTION					
BUILDING NUMBER	BASE ENERGY (THERMS)	ECO-A3 LOAD (THERMS)	ENERGY SAVINGS (MBTU)	BASE LOAD (KW)	ECO-A3 LOAD (KW)	ENERGY SAVINGS (MBTU)	TOTAL SAVINGS (\$)		
			••						
463	1.577	1,379	20	83,903	82,814	4	\$127		
464	2,195	1,311	88	91,802	86,441	18	\$588		
472	15,515	15,241	27	234.490	232,543	7	\$194		
475	13,619	12,203	142	58,399	58.386	0	\$578		
475E	21.657	21,253	40	611,712	611.617	0	\$169		
							\$1,657		

ECO-A3

-

ATTIC INSULATION



ATTIC INSULATION

ENERGY CONSERVATION OPPORTUNITY: ECO-A3

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-A3) analyzes the energy savings associated with reducing the amount of heat transferred through the attic and roof of a building. The implementation of this ECO will not change the appearance of any of the buildings being considered.

SCOPE:

The ECO simulation (ECO-A3) adds additional attic insulation to decrease the heat transfer rate into or out of the building. The increased insulation can be added in the attics of the buildings be considered. The application of this project was considered for the buildings listed in Table A3.1.

Building Number	Insulated Section
463	Entire Attic
464	Entire Attic
472	North End of Attic
475	Entire Attic
475E	Stage Area Attic

Table A3.1

MODELING TECHNIQUES:

The heat transfer rate through the attic were simulated using the "Trace Ultra" computer program. The coefficient of heat transfer (U-value) for the existing roof was determined using the ASHRAE load calculation handbook¹. The U-value for the entire roof is the sum of the U-values for each of the materials that make up the attic and roof construction. The calculation of each U-value is located in the appendix with the base load run for each building. Next, the U-value for the attic with additional insulation was determined and entered into the computer model of the building. The existing and new U-values calculated in the appendix are summarized in Table A3.2 along with a description of the method of insulation. The difference in the energy usage before and after the implementation of the ECO was the energy savings from the ECO.



Building Number	Existing U-Value	New U-Value	Insulation Description
463	0.104	0.025	Addition of 10" batt insulation in the attic between the joist.
464	0.342	0.030	Addition of 10" batt insulation in the attic between the joist.
472	0.134	0.027	Addition of 10" batt insulation in the attic between the joist.
475	0.240	0.029	Addition of 10" batt insulation in the attic under plywood between the joist.
475E	0.488	0.030	Addition of 10" batt insulation in new furring channels in the attic.

Table A3.2

ECO IMPLEMENTATION:

The implementation of this ECO in all but one of the buildings is not difficult and can be completed by the maintenance staff within the walls of the USDB. In all of the cases for the different buildings, the addition of insulation is in the attic of the buildings between the joists or roof rafters. The batt insulation, is delivered in plastic wrapped rolls. The insulation is moved to the attic unwrapped and stapled between the joists or roof rafters with a standard staple gun using 1/2" staples.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown below in Table A3.3 in million BTU's per year savings as determined using the computer simulation model.

The project cost is the construction cost as determined in this section plus 6% SIOH.

Building 475E does not show as well a payback as the other buildings because of the areas adjacent to the newly insulated section are heating only and the installation cost is relatively high.



ECO-A3

Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
463	51	\$462	\$3484	7.05	1.71
464	80	\$267	\$3143	12.18	1.48
472	34	\$194	\$886	0.09	178.57
475	142	\$578	\$4868	7.96	2.03
475E	40	\$169	\$32316	187.69	0.09

Table A3.3





.

P F	ENEI STALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	990 DI	TION INVES ORT LEAVEN SCRETE PO	TMENT PR WORTH -	ogram (eg USDB Reg /ie: 463A3	CIP) NON NOS. 7 PREPARED	Ľ	DY: USDBAE CCID 1.035 CENSUS: 2
1	B. SIOH C. DESIGN C D. ENERGY E. SALVAGE	IUCTION COST	-	9			\$\$ \$\$ \$\$ \$\$ \$\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	3287. 197. 181. 3299. 0. 3299.
2.	ENERGY SAV ANALYSIS DA	VINGS (+) / COST ATE ANNUAL SA	/INGS, UNIT	COST & D	ISCOUNTEI	D SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	31. 0. 0. 20. 0.	\$ \$ \$ \$ \$ \$	386. 0. 0. 82. 0.	11.16 17.19 17.12 16.15 13.92		4308. 0. 0. 1324. 0.
	F. TOTAL		51.	\$	468.		\$	5632.
3.	NON ENERGY	Y SAVINGS(+) / C	OST(-)					
	(1) DISCO	RECURRING (+/-) OUNT FACTOR (T	ABLE A)		11.65		\$	0.
	(2) DISCO	OUNTED SAVING	COST (3A X				\$	0.
		ON ENERGY DISC			COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% M/ A IF 3D B IF 3D C IF 3I	「NON ENERGY Q MAX NON ENERG` D1 IS = OR > 3C G D1 IS < 3C CALC BD1B IS = > 1 GO T D1B IS < 1 PROJE	Y CALC (2F5 iO TO ITEM 4 SIR = (2F5+ IO ITEM 4	X .33) 4 ⊦3D1)/1F)=		\$ 1859.		
4.	FIRST YEAR	DOLLAR SAVING	S 2F3+3A+(3	B1D/(YEAF	RS ECONON	(IC LIFE))	\$	468.
5.	TOTAL NET D	DISCOUNTED SAV	/INGS (2F5+;	3C)			\$	5632.
6.	DISCOUNTED (IF < 1 PROJE	D SAVINGS RATIC ECT DOES NOT Q) UALIFY)	(SIF	R)=(5 / 1F)=	1.71		
7.	SIMPLE PAYB	BACK PERIOD (ES	STIMATED)	SPB=1F/4		7.05		



.

P F	ENERG ISTALLATION & Lu ROJECT NO. & TI ISCAL YEAR 1990 NALYSIS DATE:	TLE: 1496 DIS	ION INVESTM	ENT PR ORTH -	OGRAM (EC USDB REG /IE: 464A3	CIP) NON NOS. 7 PREPARED	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
1.	INVESTMENT A. CONSTRUCT B. SIOH C. DESIGN COS D. ENERGY CR E. SALVAGE VA F. TOTAL INVES	ST EDIT CALC(1/ ALUE COST					\$\$ \$\$ \$ \$ \$	3143. 189. 173. 3155. 0. 3155.
2.	ENERGY SAVIN ANALYSIS DATE	GS (+) / COST (E ANNUAL SAV	(-) INGS, UNIT CC	DST & D	ISCOUNTEE) SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	AN	NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL		- 8 . 0. 0. 88. 0.	\$ \$ \$ \$ \$ \$	-100. 0. 0. 359. 0.	11.16 17.19 17.12 16.15 13.92		-11+6. 0. 0. 5798. 0. 3 3 6
	F. TOTAL		80.	\$	259.		\$	4682.
3.	NON ENERGY S	AVINGS(+) / CC	DST(-)		-11			
	A. ANNUAL REC (1) DISCOUN	URRING (+/-) IT FACTOR (TA			11.65		\$	0.
	(2) DISCOUN	ITED SAVING/C	OST (3A X 3A	A1)	11.00		\$	0.
	C. TOTAL NON I	ENERGY DISCO	DUNTED SAVIN	NGS(+) /	COST(-) (3/	A2+3Bd4)	\$	0.
	A IF 3D1 I B IF 3D1 I C IF 3D1E	N ENERGY QL NON ENERGY S = OR > 3C GC S < 3C CALC $S = > 1 GO TCS < 1 PROJEC$	CALC (2F5 X D TO ITEM 4 SIR = (2F5+3D) D ITEM 4	.33) 1)/1F)=	۹ ۲	2/52 5 1545 .		_
4.	FIRST YEAR DOI	LAR SAVINGS	2F3+3A+(3B1[D/(YEAF	IS ECONOM	IC LIFE))	\$	587 -259 .
5.	TOTAL NET DISC	OUNTED SAVI	NGS (2F5+3C)			2.64	\$	4336 4682.
6.	DISCOUNTED SA (IF < 1 PROJECT	VINGS RATIO DOES NOT QL	IALIFY)	(SIF	?)=(5 / 1F)=	1.48		
7.	SIMPLE PAYBAC	k period (es ⁻	FIMATED) SF	PB=1F/4		12.18	5.4	



LIFE CYCLE COST ANALYSIS SUMMAR ENERGY CONSERVATION INVESTMENT PROC INSTALLATION & LOCATION: FORT LEAVENWORTH - US PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YE	GRAM (ECIP) LCCID 1.03 SDB REGION NOS. 7 CENSUS:	35
1. INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E)	\$ 830 \$ 50 \$ 46 \$ 839 -\$ 0 \$ 839). 6. 9.).
2. ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISC	COUNTED SAVINGS	
FUEL \$/MBTU(1) MBTU/YR(2) SAVI	JAL \$ DISCOUNT DISCOUNTED NGS(3) FACTOR(4) SAVINGS(5))
A. ELECT $$ 12.94$ B. DIST $$.00$ $$ $$.00$ C. RESID $$.00$ $0.$ $$.00$ D. NAT G $$.343.24$ $27.$ $$.5$ E. COAL $$.00$ $0.$ $$.5$	0. 17.19 0 0. 17.12 0	
F. TOTAL 34. \$	9281. \$ 149818	
3. NON ENERGY SAVINGS(+) / COST(-)	197.24	2750.89
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) (2) DISCOUNTED SAVING/COST (3A X 3A1)	11.65 \$ 0. \$ 0.	
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /CC		
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = $(2F5+3D1)/1F$)= C IF 3D1B IS = > 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY	\$ -49440. 908'	
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS I	/ <i>97</i> ECONOMIC LIFE)) \$ _ 9281.	
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)		50.85
6. DISCOUNTED SAVINGS RATIO (SIR)=((IF < 1 PROJECT DOES NOT QUALIFY)	(5/1F)= 178.57 3.28.	
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4	09 4.25	



•

INSTALLATION PROJECT NO. FISCAL YEAR 1	ERGY CONSERVA & LOCATION: FO & TITLE: 1496	RT LEAVENWO	ENT PROG PRTH - US ON NAME:	RAM (EC DB REG 475A3	IP) ION NOS. 7 PREPARED	LC	: USDBAE CID 1.035 CENSUS: 2
B. SIOH C. DESIGN D. ENERGY E. SALVAG	RUCTION COST	·				\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	4592. 276. 253. 4609. 0. 4609.
2. ENERGY SA ANALYSIS [AVINGS (+) / COST DATE ANNUAL SAV	(-) 'INGS, UNIT CC	OST & DISC	OUNTED	SAVINGS		
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNU SAVIN		DISCOUNT FACTOR(4)		COUNTED INGS(5)
A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	0. 0. 0. 142. 0.	\$ \$ \$ \$ \$ \$ \$	0. 0. 579. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 9351. 0.
F. TOTAL		142.	\$	579.		\$	9351.
3. NON ENERG	GY SAVINGS(+) / C	OST(-)					
A. ANNUAL (1) DISC	RECURRING (+/-) OUNT FACTOR (T/			11.65		\$	0.
(2) DISC	OUNTED SAVING/	COST (3A X 3A	A1)	11.00		\$	0.
	ON ENERGY DISC			ST(-) (3A	(2+3Bd4)	\$	0.
(1) 25% M A IF 3 B IF 3 C IF 3	T NON ENERGY QU MAX NON ENERGY D1 IS = OR > 3C G D1 IS < 3C CALC 3D1B IS = > 1 GO T D1B IS < 1 PROJEC	CALC (2F5 X O TO ITEM 4 SIR = (2F5+3D O ITEM 4	.33) 1)/1F)=	\$	3086.		
4. FIRST YEAR	DOLLAR SAVINGS	2F3+3A+(3B1[D/(YEARS E		IC LIFE))	\$	579.
5. TOTAL NET I	DISCOUNTED SAV	INGS (2F5+3C)				\$	9351.
6. DISCOUNTE (IF < 1 PROJI	D SAVINGS RATIO ECT DOES NOT QU	JALIFY)	(SIR)=(5 / 1F)=	2.03		
7. SIMPLE PAY	BACK PERIOD (ES	TIMATED) SF	PB=1F/4		7.96		



ĺ

	INSTALLATION & PROJECT NO. & FISCAL YEAR 19 ANALYSIS DATE	990 DIS E: 03-30-90	FION INVEST RT LEAVENV SCRETE POF	MENT PR VORTH -	ogram (eo USDB Reg	NOS. 7	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
	B. SIOH C. DESIGN (D. ENERGY E. SALVAGE	UCTION COST		9			\$\$ \$\$ \$\$ \$\$ \$\$ \$\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	30487. 1829. 1677. 30594. 0. 30594.
2	2. ENERGY SAV ANALYSIS D/	VINGS (+) / COST ATE ANNUAL SAV	(-) 'INGS, UNIT	COST & D	ISCOUNTE	D SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	0. 0. 0. 40. 0.	\$ \$ \$ \$	0. 0. 0. 163. 0.	11.16 17.19 17.12 16.15 13.92		0. 0. 2632. 0.
	F. TOTAL		40.	\$	163.		\$	2632.
з	8. NON ENERGY	Y SAVINGS(+) / C(OST(-)					
	A. ANNUAL F (1) DISCO	RECURRING (+/-) DUNT FACTOR (TA			11.65		\$	0.
	(2) DISCO	DUNTED SAVING/C	COST (3A X	3A1)	11.00		\$	0.
	C. TOTAL NC	ON ENERGY DISC	OUNTED SA	VINGS(+) /	COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% M A IF 3D B IF 3D C IF 3I	NON ENERGY QU IAX NON ENERGY D1 IS = OR > 3C G0 D1 IS < 3C CALC D1B IS = > 1 GO T D1B IS < 1 PROJEC	′ CALC (2F5 O TO ITEM 4 SIR = (2F5+: O ITEM 4	X .33) 3D1)/1F)=		\$ 869.		
4	FIRST YEAR [DOLLAR SAVINGS	3 2F3+3A+(3E	B1D/(YEAR	S ECONON	IIC LIFE))	\$	163.
5.	TOTAL NET D	SCOUNTED SAV	INGS (2F5+3	C)			\$	2632.
6.		SAVINGS RATIO	JALIFY)	(SIR	l)=(5 / 1F)=	0.09		
7.	SIMPLE PAYB	BACK PERIOD (ES	TIMATED)	SPB=1F/4		187.69		



1



CONSTRUCTION COST ESTIMATE			DATE PF	REPARED	400	· · ·	SHEET OF
PROJECT			L	BASIS FOR E	4/2/90	; ;	11
USDB ENERGY STUDY				x			
FORT LEAVENWORTH, KS					CODE A	(PRELIMINAR	COMPLETED)
ARCHITECT/ENGINEER CLARK RICHARDSON & BI					CODE C	(FINAL DESIG	aN)
DRAWING NO.	SKUP	ESTIM	ATOR	l	OTHER	SPECIFY)	v
NONE ECO-A3				DLS			TOL
ATTIC INSULATION	NO.	ANTITY UNIT	PER M	ATERIAL TOTAL		ABOR	TOTAL
		MEAS.		TOTAL	PER UNIT	TOTAL	COST
BUILDING 463							
10" BATT INSULATION	2375	SQ FT	0.70	1,663	0.15	356	\$2,
MOBILIZATION	2375	SQ FT			0.10	000	
					0.10	238	\$
			<u> </u>				
		ſ					
SUBTOTAL				\$1,663		\$594	\$2,2
ONTINGENCY 10%			10%	\$166	10%	\$59	\$2
SUBTOTAL				\$1,829		\$653	\$2,4
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$64	13.0%	\$85	\$1
DIRECT COST				\$1,893		\$738	\$2,6
VERHEAD AND PROFIT			25%	\$473	25%	\$184	\$6
SUBTOTAL				\$2,366		\$922	\$3,2
		ĺ					
NG. FORM 150 NC-59	_4						\$3,2





CONSTRUCTION COST ESTIMATE			DATE PF	EPARED	1/0/0		SHEET OF
PROJECT USDB ENERGY STUDY	<u> </u>		L	BASIS FOR	4/2/90		2
LOCATION				x			
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				^	CODE B	(PRELIMINAR	COMPLETED)
CLARK RICHARDSON & RIS	KIIP				_CODE C	(FINAL DESIG	SN)
DRAWING NO.		ESTIM	ATOR		OTHER	(SPECIFY)	v
ECO-A3				DLS			TOL
ATTIC INSULATION	NO.	ANTITY UNIT	PER	ATERIAL TOTAL		ABOR	TOTAL
		MEAS.		IOIAL	PER UNIT	TOTAL	COST
BUILDING 464							
10" BATT INSULATION	2271	SQ FT	0.70	1,590	0.15		
MOBILIZATION		SQ FT	0.70	1,590			\$1,9
		SUFI			0.10	227	\$2
							· · · · · · · · · · · · · · · · · · ·
	+						
	╉╼╼╌╂						
	┥───┤						
	<u></u>						
	1		+			<u> </u>	
SUBTOTAL	 						
ONTINGENCY 10%	<u>†</u> ──†			\$1,590		\$568	\$2,157
SUBTOTAL			10%	\$159	10%	\$57	\$216
ORK COMP, TAX, SOC.SEC., INS	├			\$1,749		\$625	\$2,373
	┼──┼		3.50%	\$61	13.0%	\$81	\$142
	┠──┼	<u> </u>		\$1,810		\$706	\$2,515
VERHEAD AND PROFIT	┠───┼-		25%	\$452	25%	\$176	\$628
SUBTOTAL	┝			\$2,262		\$882	\$3,143
CONSTRUCTION COST				1			



	Å
3	فتغنظ

CONSTRUCTION COST ESTIMATE DATE PR					4/2/90)	SHEET OF
PROJECT USDB ENERGY STUDY	BASIS FOR I			<u> </u>			
LOCATION	<u>x</u>	CODE A	(NO DESIGN	COMPLETED)			
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODE B	(PRELIMINAR	Y DESIGN)
CLARK RICHARDSON & BIS	KUP				OTHER	(FINAL DESIG (SPECIFY)	in)
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	
ECO-A3 ATTIC INSULATION		NTITY		IATERIAL		ABOR	TOL TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 472							
10" BATT INSULATION	604	SQ FT	0.70	423	0.15	91	\$!
MOBILIZATION	604	SQ FT			0.10		
							······································
							••••••••••••••••••••••••••••••••••••••
	1						
	-						
SUBTOTAL	++			\$423		\$151	\$5
ONTINGENCY 10%			10%	\$42	10%	\$15	\$!
SUBTOTAL				\$465		\$166	\$6
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$16	13.0%	\$22	\$:
DIRECT COST				\$481		\$188	\$66
VERHEAD AND PROFIT			25%	\$120	25%	\$47	\$16
SUBTOTAL	<u> </u>			\$601		\$235	\$83
CONSTRUCTION COST			1				\$83

CONSTRUCTION COST ESTIMATE			DATE PF	EPARED	4/2/90)	SHEET OF	
PROJECT USDB ENERGY STUDY					BASIS FOR ESTIMATE			
LOCATION				x	CODEA	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODE B	(PRELIMINAF (FINAL DESIC	IY DESIGN)	
CLARK RICHARDSON & BI	SKUP				OTHER	(SPECIFY)		
NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL	
ECO-A3 ATTIC INSULATION		ANTITY		IATERIAL	l	ABOR	TOTAL	
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 475								
10" BATT INSULATION	3316	SQ FT	0.70	2,321	0.15	497	\$2,	
MOBILIZATION	3316	SQ FT			0.10		\$	
							Ψ	
	_							
							·····	
SUBTOTAL				£0.001				
ONTINGENCY 10%			10%	\$2,321		\$829	\$3,1	
SUBTOTAL			10%	\$232	10%	\$83	\$3	
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$2,553 \$89	13.0%	\$912	\$3,4	
DIRECT COST			0.00 %		13.0%	\$119	\$2	
VERHEAD AND PROFIT			25%	\$2,642		\$1,031	\$3,6	
SUBTOTAL			20%	\$661	25%	\$258	\$9	
	++			\$3,303		\$1,289	\$4,59	
NG. FORM 150							\$4,59	





CONSTRUCTION COST ESTIMATE			DATE PP	REPARED	AIDIO)	SHEET OF
PROJECT		4/2/90 BASIS FOR ESTIMATE				5	
				x			
FORT LEAVENWORTH, KS				^	CODE B	(PRELIMINAR	COMPLETED) Y DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS	SKI ID				CODEC	(FINAL DESIG	GN)
DRAWING NO.	SNOP	ESTIM	ATOR	L	OTHER	SPECIFY)	Υ
ECO-A3				DLS IATERIAL	· · · · ·	ABOR	TOL
ATTIC INSULATION	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
BUILDING 475E	_						
7/8" FURRING CHANNEL	4575	SQ FT	0.20	915	0.65	2,974	\$3,8
10" BATT INSULATION	4575	SQ FT	0.70	3,203	0.20	915	\$4,1
5/8" FIRECODE GYP. BD.	4575	SQ FT	0.50	2,288	0.85	3,889	\$6,1
PAINT	4575	SQ FT	0.25	1,144	0.65	2,974	
6 MIL. VAPOR BARRIER	4575	SQ FT	0.03	137	0.10	458	\$5
MOBILIZATION	4575	SQ FT			0.30	1,373	\$1,3
· · · · · · · · · · · · · · · · · · ·							
······································							
							······
							•
SUBTOTAL				\$7,686		\$12,581	\$20,20
SUBTOTAL			10%	\$769	10%	\$1,258	\$2,02
VORK COMP,TAX,SOC.SEC.,INS				\$8,455		\$13,839	\$22,29
DIRECT COST	+		3.50%	\$296	13.0%	\$1,799	\$2,09
VERHEAD AND PROFIT			25%	\$8,751	050/	\$15,638	\$24,38
SUBTOTAL			23%	\$2,188 \$10,939	25%	\$3,910	\$6,09
CONSTRUCTION COST				<u>\$39</u>		\$19,548	\$30,48
NG. FORM 150 AVC-59		<u>I</u>			l.	I	\$30,48

ECO-A4

DOCK DOOR REPLACEMENT

DOCK DOOR REPLACEMENT

ENERGY CONSERVATION OPPORTUNITY: ECO-A4

PURPOSE:


This Energy Conservation Opportunity (ECO-A4) analyzes the energy savings associated with reducing the amount of heat transferred from within building 470 to the change the size or shape of the existing door but will not change the general appearance of the existing door to a new door. outdoors during the winter months alone. The implementation of this project will not

The ECO simulation (ECO-A4) replaces the load dock door on the south end of the building. The replacement of the door will reduce infiltration into the building and thus reduce the amount of energy used to heat and cool the building. The method of construction for this ECO is not difficult and amounts to replacement of an overhead door.

MODELING TECHNIQUES:

The modeling technique used to calculate the heat transfer and infiltration rates for the door was determined using the U-value for the door and an infiltration calculation method as described the ASHRAE load calculation handbook¹. The U-value of the existing door was determined from a field survey to be approximately 1.28 Btu/hr/ft²/°F. A new rolling overhead door for the opening would have a U-value equal to 0.17 Btu/hr/ft2/°F notho Barwa.

The heat loss calculation due to infiltration around the casement of the door is calculated using a method described in the ASHRAE Load Calculation Manual¹. The door was fit into one of several categories describing there amount of crack area open to the outside. The category that the door fit into was based on crack width around the door. The door was fit into the loose category with an average crack width of 1/2" and the crack factor equal to 4.46. The door is 8' by 8' in size with 4 panels, which calculates out to a crack length of 56'. The ASHRAE¹ differential pressure chart, was used to find the driving force, based on a wind speed of 10 mph, for the air to be infiltrated. Using the differential pressure and the crack free area an infiltration value for the door was determined. With the amount of unconditioned air entering the building, the infiltration can be determined. The infiltration was calculated by:



ECO-A4

Infiltration = $Q = (Crack Length)^*(Differential Pressure)^{0.5*}(Crack Factor)$ Existing Infiltration = 52.98 CFM THE 106 2. -0 New Infiltration = 7.96 CFM H A ັ√0[¶]

With the U-values and infiltration calculated, the total heat transfer for a year was calculated using an electronic spreadsheet and the bin method of energy analysis as shown in Table A4.2. Not ALLOWED

ECO IMPLEMENTATION:

To implement this ECO, the existing overhead door would have to be removed and the new overhead door, of the same size, installed in the same place. The new door would be opened with a new chain hoist on one end. The new door would be an insulated metal door with no windows.

SUMMARY:

The energy savings associated with the implementation of this ECO is shown in million BTU's in Table A4.1 as determined from the calculations as previously outlined .

The project cost is the construction cost as determined in the following pages plus 6% SIOH.



The new door as considered in the ECO section was not part of the original study but was looked at because the existing overhead door is in poor shape and could be replaced with a considerable energy savings. The USDB carpentry shop could install a new overhead door. If an outside contractor were hire for this installation, the energy savings would not pay for the door.

	Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
L	470	16	\$67	\$870	9.70	1.67

Table A4.1

Ĵ.	

ENERGY USING ASHRAE I	ANAL YSI MODIFIEI	ENERGY ANALYSIS WORKSHEET USING ASHRAE MODIFIED BIN METHOD	HEET HOD						
BIN	AVG. DB TEMP	BIN TEMP BELOW 68°F	BIN HOURS PER YEAR	EXIST Q1 U=1.28 A=64	NEW Q2 U=0.17 A=64	EXIST Q3 INFILT. CFM= 52 08	NEW Q4 INFILT. CFM= 7 06	EXIST (Q1+Q3) * (BIN HRS)	NEW Q2+Q4 * (BIN HRS)
100/104	102		e			05.30	02.1		
95/99	97		41						
90/94	92		197						
85/89	87		436						
80/84	82		638						
75/79	77		788						•
70/74	72		710						
65/69	67	-	717	81.92	10.88	57.48	8.64	99952	13003
60/64	62	9	681	491.52	65.28	344.90	51.82	569602	79745
55/59	57	11	587	901.12	119.68	632.32	95.00	900127	126019
50/54	52	16	584	1310.72	174.08	919.73	138.19	1302584	182362
45/49	47	21	539	1720.32	228.48	1207.15	181.37	1577906	220908
40/44	42	26	580	2129.92	282.88	1494.57	224.55	2102202	294310
35/39	37	31	678	2539.52	337.28	1781.98	267.73	9799979	410200
30/34	32	36	589	2949.12	391.68	2069.40	310.92	2955908	413830
25/29	27	41	347	3358.72	446.08	2356.82	354.10	1983291	277663
20/24	22	46	296	3768.32	500.48	2644.23	397.28	1898115	265738
15/19		51	153	4177.92	554.88	2931.65	440.47	1087764	152288
10/14	21	9 6	11	4587.52	609.28	3219.06	483.65	601107	84156
5/9		61	67	4997.12	663.68	3506.48	526.83	569741	79764
0/4	~	66	47	5406.72	718.08	3793.90	570.02	432429	60540
				TOTAL T(TOTAL YE	TOTAL EXISTING YEARLY LOAD IN BTU'S TOTAL NEW YEARLY LOAD IN BTU'S TOTAL YEARLY LOAD DIFFERENCE IN BTU'S	EARLY LOA EARLY LOA DIFFERENC	D IN BTU'S D IN BTU'S E IN BTU'S	19,010,707	2,661,518 16,349,189

Table A4.1

P Fl A	ISTALLATION & ROJECT NO. & ISCAL YEAR 199 NALYSIS DATE:	IGY LOC TITL 90 03	E: 1496 DIS	FION INVES	TMENT WORTH	PROGR I - USDI NAME: 4	B REGI	IP) ION NOS. PREPAI	7	L	DY: USDBAE CCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	CTIC OST CREI VAL	DIT CALC (1)		9					\$\$ \$\$ \$\$ \$\$	870. 52. 48. 873. 0. 873.
2.	ENERGY SAV ANALYSIS DA	INGS TE A	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT	COST	& DISCO	UNTED	SAVING	5		
	FUEL		JNIT COST S/MBTU(1)	SAVINGS MBTU/YR		ANNUAI SAVING		DISCOU FACTOR			SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 22. 0.	\$ \$ \$ \$ \$		0. 0. 0. 90. 0.	17 17 16	.16 .19 .12 .15 .92		0. 0. 0. 1454. 0.
	F. TOTAL			22.	\$		9 0.			\$	1454.
3.	NON ENERGY	SA\	/INGS(+) / C	OST(-)							
	A. ANNUAL R	ECU JNT	RRING (+/-) FACTOR (TA			11	1.65			\$	0.
	(2) DISCO	JNTI	ED SAVING/(COST (3A X	(3A1)	• •				\$	0.
	C. TOTAL NO	N EN	IERGY DISC	OUNTED SA	AVINGS	(+) /COS	T(-) (34	A2+3Bd4)		\$	0.
	A IF 3D [.] B IF 3D [.] C IF 3D	X N 1 IS 1 IS 1 B I	ENERGY QU ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJEC	' CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	X .33) 4 ⊦3D1)/1I	⁼)=	\$	4	80.		
4.	FIRST YEAR D	OLL	AR SAVINGS	8 2F3+3A +(3	B1D/(YI	EARS EC	ONOM	IC LIFE))		\$	90.
5.	TOTAL NET DI	sco	UNTED SAV	INGS (2F5+	3C)					\$	1454.
6.	DISCOUNTED (IF < 1 PROJEC	SAV ST D	INGS RATIO OES NOT QU	JALIFY)	((SIR)=(5	/ 1F)=	1.	67		
7.	SIMPLE PAYBA	CK	PERIOD (ES	TIMATED)	SPB=1	F/4		9.	70		



-
1

CONSTRUCTION COST ESTIMATE			DATE PR	EPARED			SHEET OF
PROJECT					4/2/90)	1 1
USDB ENERGY STUDY				BASIS FOR E	STIMATE		
LOCATION				X	CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS					CODE B	(PRELIMINAR	Y DESIGN)
CLARK RICHARDSON & BISI	KUP				OTHER	(FINAL DESIG	in)
DRAWING NO. NONE		ESTIMA	TOR	DI O		CHECKED B	
ECO-A4	QU	ANTITY	М	DLS ATERIAL		ABOR	TOL TOTAL
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 470							
DEMOLITION	1	EA			50.00	50	\$5
ROLLING DOOR/HARDWARE	1	EA	745.00	745	75.00		
							ψ02
	_						
							·····
	+						
	1						
	<u> </u>						
		Τ					······································
							· · · · · · · · · · · · · · · · · · ·
	┼┼						
CONSTRUCTION COST	L				L		\$870



ECO-A5 ECONOMIC ANALYSIS

		STEAM CONS	UMPTION		ELECTRIC (CONSUMPTI	ON	
n ya An Maria Maria Maria	BUILDING NUMBER	BASE ENERGY (THERMS)	ECO-A5 LOAD (THERMS)	ENERGY SAVINGS (MBTU)	BASE LOAD (KW)	ECO-A5 LOAD (KW)	ENERGY SAVINGS (MBTU)	TOTAL SAVINGS (\$)
1	463	1.577	1,453	12	83,903	83,775	0	\$56
1			1,-700					\$56

ECO-A5

VESTIBULES



<u>VESTIBULES</u>


ENERGY CONSERVATION OPPORTUNITY: ECO-A5

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-A5) analyzes the energy savings associated with installation of vestibules on the high traffic entrances and exits of the buildings located in the USDB. The implementation of this project will change the exterior appearance of buildings being considered for vestibules.

The ECO simulation (ECO-A5) adds and repairs the vestibules on the entrances and exits of building 463 (the south gate) and the castle. At the present time building 463 does not have any type of vestibules on the north or south doorways. This building

SCOPE:



MODELING TECHNIQUES:

The energy savings for this ECO gained by reducing the large amount of infiltration being induced into the building by the large cracks in the existing doors and the opening and closing the doors to allow people to enter and exit. The addition of a vestibule contains the outside air in a finite space reducing the amount allowed into the building. The addition of a vestibule also prevents the wind from penetrating into the interior spaces. The ASHRAE load calculation handbook¹ covers in detail how to determine the amount of outside air entering through doors with a known amount of traffic. The following data was used in calculating the existing and new infiltration rates:

Differential Pressure = 0.045" Average Number of People Through Door per Hour = 200 Existing CFM per Door = 1100 CFM New CFM per Door = 200 CFM Reduction in Infiltration = 900 CFM

The base load computer run contains a large amount of infiltration and the ECO run for the buildings contains the reduced amount of infiltration.



ECO-A5

ECO IMPLEMENTATION:

To implement this ECO the complete south door opening will be removed and a revolving door with standard door will be installed. The new doors and glass for the south opening will have bullet proof glass to be resistant of a .38 cal. fire at close range. The north door for the south gate will have a vestibule added on to the outside of the building. The addition of the vestibule will not be permanently attached to the existing building and could possibly be removed if necessary. Neither the addition of the revolving door on the south or the vestibule on the north will change the visibility or operation of the southgate. Figures A5.1 thru A5.3 show a revolving door and vestibule for this building.

SUMMARY:

Although the addition of the revolving door and vestibule may not be feasible to consider from a payback stand point due to the fact that the comfort levels of the southgate area are not being met with the existing heating cooling equipment. If the heating and cooling equipment were sized adequately for the existing load on the southgate, a return on investment due to energy savings would appear more feasible.

The energy savings associated with the implementation of this ECO is shown in Table A5.1 in million BTU's per year savings as determined using the computer simulation model.

The project cost is the construction cost as determined in the appendix plus 6% SIOH.

Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
463	39	\$391	\$88,238	341.88	0.04

Table A5.2



Building 463 South Gate




Figure A5.1

ECO-A5

PAGE A5-3

Building 463 South Gate South Elevation





Figure A5.2

ECO-A5

PAGE A5-4






Figure A5.3

ECO-A5

	P F	ENER NSTALLATION & I ROJECT NO. & T ISCAL YEAR 199 NALYSIS DATE:	GY CONS LOCATIO ITLE: 149 0	ERVAT N: FOF 96 DIS	OST ANALY ION INVES RT LEAVEN CRETE PO ECONOM	STMEN WORT	t pro 'H - U Name	GRAM (EC SDB REG E: 463A5	CIP) HON NOS. 7 PREPARE	7	TUDY: USDBAI LCCID 1.03 CENSUS: CRB	5
	1	INVESTMENT A. CONSTRUC B. SIOH C. DESIGN CC D. ENERGY CI E. SALVAGE V F. TOTAL INVE	OST REDIT CA ALUE CO	LC (1A		(.9				97 97 97 97 97 97 97 97 97 97	88238 5294 4853 88547 0. 88547	•
	2.	ENERGY SAVII ANALYSIS DAT	NGS (+) / TE ANNUA	COST (AL SAV	(-) INGS, UNIT	r cost	& DIS	COUNTEE	SAVINGS			
·		FUEL	UNIT C \$/MBTI		SAVINGS MBTU/YF			UAL \$ NGS(3)	DISCOUNT FACTOR(4		DISCOUNTED SAVINGS(5)	
		A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$.(\$4.(00 00	12. 0. 0. 27. 0.		6666	149. 0. 0. 110. 0.	11.16 17.19 17.12 16.15 13.92) 2 5	1663. 0. 0. 1777 <i>.</i> 0.	
		F. TOTAL			39.	9	5	259.		\$	3440.	
	3.	NON ENERGY	SAVINGS	(+) / CC	DST(-)							
		A. ANNUAL RE (1) DISCOU		Э (+/-) Эв (та				11.65		\$	0.	
		(2) DISCOU	NTED SA	VING/C	OST (3A)	< 3A1)		11.00		\$	0.	
		C. TOTAL NON	ENERGY	DISCO	DUNTED SA	AVINGS	S(+) /C	OST(-) (3/	A2+3Bd4)	\$	0.	
		B IF 3D1 C IF 3D1	K NON EN IS = OR > IS < 3C C B IS = > 1	IERGY 3C GC ALC S GO TC	CALC (2F5) TO ITEM SIR = (2F5)	5 X .33 4 +3D1)/1) F)=	\$	5 1135. 			
	4.	FIRST YEAR DC	LLAR SA	VINGS	2F3+3A+(3	3B1D/(Y	'EARS	ECONOM	IC LIFE))	\$	259.	
	5.	TOTAL NET DIS	COUNTE	D SAVII	NGS (2F5+	-3C)				\$	3440.	
	6.	DISCOUNTED S (IF < 1 PROJECT			ALIFY)		(SIR)=	=(5 / 1F)=	0.04			
	7.	SIMPLE PAYBAC	CK PERIO	D (EST	IMATED)	SPB=	1F/4		341.88			



ECO-A5

CONSTRUCTION COST ESTIMATE			DATE PF	REPARED	4000	\ \	SHEET OF
PROJECT				BASIS FOR	4/2/90		11
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS				x	CODE B	(PRELIMINAR	COMPLETED) IY DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS	KUP				CODE C	(FINAL DESIG	GN)
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	-
ECO-A5		ANTITY		IATERIAL	L	ABOR	TOL TOTAL
VESTIBULES	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 463 SOUTH DOORWAY							
DEMOLITION	1	EA			500.00	500	\$5
	1	EA	21000	21,000	2400.00	2,400	\$23,4
MAGNETIC BREAKOUTS	1	EA	2400.00	2,400	200.00	200	\$2,6
BATTERY BACK UP	1	EA	1100.00	1,100	200.00	200	\$1,3
ENTRANCE DOOR	1	EA	4300.00	4,300	515.00	515	\$4,8
POLYCARBONATE GLAZING	271	SQ FT	4.85	1,314	2.28	618	\$1,9
METAL FRAME	105	FT	6.50	683	4.16	437	\$1,1
	_						
, 	+						
SUBTOTAL	† †			\$30,797		\$4.970	
CONTINGENCY 10%			10%	\$3,080	10%	<u>\$4,870</u> \$487	\$35,66
SUBTOTAL				\$33,877	1076	\$487	\$3,56
VORK COMP, TAX, SOC. SEC., INS			3.50%	\$1,186	13.0%	\$696	\$39,23 \$1,88
DIRECT COST				\$35,063		\$6,053	\$1,002
VERHEAD AND PROFIT			25%	\$8,766	25%	\$1,513	\$10,279
SUBTOTAL				\$43,829		\$7,566	\$51,395
CONSTRUCTION COST							\$51,395



-	
	-
	- S-
	1. 10
_	1.0

CONSTRUCTION COST ESTIMATE			DATE PF	EPARED	410/02	\	SHEET OF
PROJECT				BASIS FOR	4/2/90 ESTIMATE		2 2
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				X	CODE B	(PRELIMINAR	COMPLETED)
CLARK RICHARDSON & BIS	KUP					(FINAL DESIG	iN)
DRAWING NO. NONE		ESTIN	ATOR	DLS		CHECKED B	-
ECO-A5		ANTITY		ATERIAL	Į į	ABOR	TOL TOTAL
VESTIBULES	NO.	UNIT MEAS		TOTAL	PER UNIT	TOTAL	COST
BUILDING 463 NORTH DOORWAY							
EXCAVATE/DISPOSAL/TRIM	38	FT	0.63	24	2.12	81	\$10
CONC. FTG. W/REBAR	38	IFT	15	570	7.25	276	\$84
MOBILIZATION	38	FT			2.50	95	\$9
PREP EARTH BASE	180	SQ FT			0.15	27	\$2
6" CRUSHED ROCK	180	SQ FT	0.20	36	0.10	18	\$5
6 MIL. VAPOR BARRIER	180	SQ FT	0.05	9	0.02	4	\$1
6 X 6 - 10/10 W.W.F.	180	SQ FT	0.08	14	0.12	22	\$3
3500 PSI FINISH	180	SQ FT	0.94	169	0.81	146	\$31
CURING	180	SQ FT	. 0.05	9	0.02	4	\$1
JOINTS	180	SQ FT			0.04	7	\$
MOBILIZATION	180	SQ FT			0.24	43	\$4:
RIGID STL. FRAME/GLASS	180	SQ FT	67.50	12,150	22.50	4,050	\$16,200
MOBILIZATION	180	SQ FT			0.50	90	\$90
DOOR/LAMINATED GLASS	2	EA	3200.00	6,400	550.00	1,100	\$7,500
SUBTOTAL				* +0.000			
CONTINGENCY 10%			10%	\$19,382 \$1,938	100	\$5,961	\$25,343
SUBTOTAL				\$21,320	10%	\$596 [°] \$6,557	\$2,534
VORK COMP, TAX, SOC. SEC., INS			3.50%	\$746	13.0%	\$852	\$27,877 \$1,598
DIRECT COST				\$22,066		\$7,409	\$29,475
VERHEAD AND PROFIT			25%	\$5,516	25%	\$1,852	<u>\$29,475</u> \$7,368
SUBTOTAL				\$27,582		\$9,261	\$36,843
		T					\$36,843

ECO-A6 ECONOMIC ANALYSIS

	STEAM CON	SUMPTION		ELECTRIC	CONSUMPTI	ON	
BUILDING NUMBER	BASE ENERGY (THERMS)	ECO-A6 LOAD (THERMS)	ENERGY SAVINGS (MBTU)	BASE LOAD (KW)	ECO-A6 LOAD (KW)	ENERGY SAVINGS (MBTU)	TOTAL SAVINGS (\$)
450	0.000	0.400	00	405 400	404 700	10	\$251
450	3,629	3,403	23	135,466	131,720	13	and the second se
463	1,577	1,796	-22	83,903	82,425	5	(\$27)
464	2,195	2,352	-16	91,802	90,467	5	(\$7)
472	15,515	15,515	0	234,490	229,344	18	\$218
473	2,407	2,609	-20	148,420	145,653	9	\$35
475A	12,773	12,773	0	146,357	136,920	32	\$401
475B	8,477	8,477	0	95,207	93,496	6	\$73
475H	8,137	8,137	0	87,858	86,474	5	\$59
		· · · · · · · · · · · · · · · · · · ·	4 <u></u>				\$1,003


ų,





ECO-A6

SOLAR WINDOW SHADING



ENERGY CONSERVATION OPPORTUNITY: ECO-A6

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-A6) analyzes the energy savings associated with reducing the amount of solar gain on the buildings with cooling with the addition of a solar shading added to the windows. The addition of the solar shading would change the appearance of the exterior window facing to the south, east, and west. The window would have a dark brown tint.

SCOPE:

The ECO simulation (ECO-A6) adds solar shading film to existing windows to lessen the amount of sunlight that is allowed to pass through the window and heat up the interior. The application of this project was considered for the following buildings:



Building 450 Building 463 Building 464 Building 472

Building 473 Building 475A Building 475B Building 475H

MODELING TECHNIQUES:

The present solar gain on the buildings due to the lack of exterior shading was estimated by the *"Trace Ultra"* computer program simulation of the building. All of the exterior shading coefficients for the windows on the south, east, and west surfaces of the buildings were changed in the model and then an alternate run was completed to evaluate the new energy usage. The existing and ECO shading coefficients are shown in Table A6.1 The difference in the energy usage before and after the installation of the exterior shading is the energy savings for this ECO. Both the computer simulation run for the base load and the ECO are located in the appendix.



Building Number	Existing Window Type	Existing Shading Coefficient	ECO Shading Coefficient
450	Single Glazed	0.95	(0.36 2
463	Double Glazed	0.85	0.43
464	Double Glazed	0.85	0.43
472	Double Glazed	0.85	0.43
473	Double Glazed	0.85	0.43
475A	Double Glazed	0.85	0.43
475B	Double Glazed	0.85	0.43
475H	Double Glazed	0.85	0.43

Table A6.1

ECO IMPLEMENTATION:

The implementation of this ECO is not difficult and can be completed in a relatively short period of time. In the buildings being considered for the solar shading, a film is attached to the inside of the window. The film is held in place with a sticky backing.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown below in Table A6.2 in million BTU's per year savings as determined using the computer simulation model.

The project cost is the construction cost as determined in the appendix plus 6% SIOH.

Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
450	80	\$498	\$2001	5.00	2.96
463	~(17)	-(\$53)	\$2056	<i>+</i> (73.68)	-(0.37)
464	-(11)	(\$26)	\$1782	-(596.00)	(0.20)
472	18	\$74	\$8350	37.41	0.30
473	~(11)	\$7430	\$2565	85.80	~(0.03)
475A	32	\$406	\$8020	20.22	0.55
475B	6	\$74	\$2774	37.12	0.30
475H	5	\$60	\$2610	42.26	0.26

Table A6.2



Some of the buildings listed in Table A6.2 show a negative energy savings, which means that the building for the energy year used more energy after the implementation of the solar shading. The reason for this is those buildings are only partially cooled. Only specific zones of the entire building are cooled and the rest of the building is heated only. The solar shading will typically increase the heating costs because the building does not experience a solar gain in the winter season to help with heating. Building 450 shows a good payback for the solar shading because of the number of windows in the building. The summer season solar gain for building 450 is large relative to the other buildings.



P Fl	ENE ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY (& LOC TITLE 990	CONSERVA [®] ATION: FO E: 1496 DIS	OST ANALYS TION INVESTI RT LEAVENW SCRETE POR ECONOMIC	Ment Pr /Orth - Tion Nam	OGRAM (EC USDB REG /IE: 450A6	CIP) SION NOS. 7 PREPARED	LO	Y: USDBAE CCID 1.035 CENSUS: 2 B
1.	INVESTMEÑ A. CONSTRU B. SIOH C. DESIGN (D. ENERGY E. SALVAGE F. TOTAL IN	JCTIC COST CREE	IT CALC (1 JE COST					\$\$ \$\$ \$\$ \$ \$ \$ \$	2001. 120. 110. 2008. 0. 2008.
2.	ENERGY SAV ANALYSIS DA	/INGS ATE A	(+) / COST NNUAL SAV	(-) /INGS, UNIT (COST & D	ISCOUNTEI	D SAVINGS		
	FUEL		INIT COST /MBTU(1)	SAVINGS MBTU/YR(2		NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		COUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	9. 0. 0. 71. 0.	\$\$ \$\$ \$\$ \$\$	112. 0. 0. - 290. 0.	11.16 17.19 17.12 16.15 13.92		1250. 0. 0. 4684. 0.
	F. TOTAL			80.	\$	402.		-\$	5934.
3.	NON ENERG	Y SAV	'INGS(+) / C	OST(-)		112			1250
	A. ANNUAL F (1) DISCC (2) DISCC	UNT	FACTOR (Ť/	ABLE A) COST (3A X	3A1)	11.65		\$ \$	0.
	C. TOTAL NO			-	•	COST(-) (3	A2+3Bd4)	Ψ \$	0.
	D. PROJECT (1) 25% M A IF 3D B IF 3D C IF 3I	NON AX N()1 IS =)1 IS <)1 IS <	ENERGY QI DN ENERGY OR > 3C G 3C CALC S = > 1 GO T	UALIFICATION CALC (2F5) O TO ITEM 4 SIR = (2F5+3	N TEST X .33) 3D1)/1F)=		\$1958. _%		0.
4.	FIRST YEAR [DOLLA	R SAVINGS	5 2F3+3A+(3B	1D/(YEAF	RS ECONON	/IC LIFE))	\$	11 2- 402.
5.	TOTAL NET D	ISCO	JNTED SAV	INGS (2F5+30	C)		10 102	\$	-5934.
6.	DISCOUNTED (IF < 1 PROJE	SAVI CT DO	NGS RATIO DES NOT QU	JALIFY)	(SIF	R)=(5 / 1F)=	2.96 17.9	/	1250
7.	SIMPLE PAYB	ACK F	PERIOD (ES	TIMATED)	SPB=1F/4		5.00		



ECO-A6

)	Pi Fi Al	ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY & LO TITI 990 E: 0	.E: 1496 DIS	TION INVES RT LEAVEN SCRETE PO	iworth -	Rogram (e USDB re ME: 463A6	GION NOS.	7	TUDY: USDI LCCID 1. CENSU	.035
	1.	INVESTMEN A. CONSTRI B. SIOH C. DESIGN (D. ENERGY E. SALVAGE F. TOTAL IN	UCTI COS ⁻ CRE E VAL	F DIT CALC(1 .UE COST		.9				5 20 5 1 5 20 5 20	256. 23. 13. 63. 0.
	2.	ENERGY SAV ANALYSIS D	VING ATE	S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST & I	DISCOUNTE	D SAVINGS			
		FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		NNUAL \$ AVINGS(3)	DISCOUI FACTOR		DISCOUNT SAVINGS(5	
		A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$\$ \$\$ \$\$ \$\$ \$\$ \$\$	12.44 .00 .00 4.08 .00	5. 0. 0. -22. 0.	\$\$ \$ \$ \$ \$ \$ \$	62. 0. 0. -90. 0.	11. 17. 17. 16. 13.9	19 12 15	6 -14	92. 0. 0. 54. 0.
		F. TOTAL			-17.	\$	-28.		\$	-7	62.
	3.	NON ENERG			OST(-)						
		A. ANNUAL F (1) DISCO)UNT	FACTOR (TA	ABLE A)		11.65		\$	i	0.
				ED SAVING/	•	•			\$		0.
		C. TOTAL NO					/COST(-) (3A2+3Bd4)	\$		0.
		A IF 30 B IF 30 C IF 31	AX N 01 IS 01 IS 01 B	I ENERGY QI ION ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T S < 1 PROJEG	' CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1F)=		\$-25	1. 		
	4.	FIRST YEAR I	DOLL	AR SAVINGS	3 2F3+3A+(3	B1D/(YEA	RS ECONO	MIC LIFE))	\$	-2	28.
	5.	TOTAL NET D	ISCO	OUNTED SAV	INGS (2F5+	3C)			\$	-76	62.
	6.	DISCOUNTED (IF < 1 PROJE	SAN CT E	/INGS RATIO OOES NOT QU	JALIFY)	(SI	R)=(5 / 1F)=	-0.3	7		
	7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F/	4	-73.6	8		



P F	ENEF ISTALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY CC LOCA TITLE: 90	NSERVAT TION: FOI 1496 DIS	RT LEAVEN	STMENT PI	Rogram (EG USDB REC ME: 464A6	CIP) GION NOS. 7 PREPAREE	L	DY: USDBAE CCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	OST OST CREDIT VALUE	CALC (1,		.9			\$\$ \$\$ \$\$ \$\$	1782. 107. 98. 1788. 0. 1788.
2.	ENERGY SAV ANALYSIS DA	INGS (- TE ANI	+) / COST NUAL SAV	(-) 'INGS, UNIT	COST & I	DISCOUNTE	D SAVINGS		
	FUEL		IT COST IBTU(1)	SAVINGS MBTU/YR		NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	5. 0. 0. -16. 0.	\$ \$ \$ \$ \$	62. 0. -65. 0.	11.16 17.19 17.12 16.15 13.92		692. 0. 0. -1050. 0.
	F. TOTAL			-11.	\$	-3.		\$	-358.
3.	NON ENERGY	SAVIN	GS(+) / C(OST(-)					
	A. ANNUAL R (1) DISCO	ECURF	ING (+/-) CTOR (TA			11.65		\$	0.
	(2) DISCO	UNTED	SAVING/C	COST (3A X	(3A1)	11.00		\$	0.
	C. TOTAL NO					/COST(-) (3	A2+3Bd4)	\$	0.
	B IF 3D [.] C IF 3D	AX NON 1 IS = C 1 IS < 3 01B IS =	I ENERGY)R > 3C G(C CALC = > 1 GO T	CALC (2F5 O TO ITEM SIR = (2F5-	5 X .33) 4 +3D1)/1F)=	:	\$-118.		
4.	FIRST YEAR D	OLLAR	SAVINGS	5 2F3+3A+(3	B1D/(YEA	RS ECONON	AIC LIFE))	\$	-3.
5.	TOTAL NET DI							\$	-358.
6.	DISCOUNTED (IF < 1 PROJEC			JALIFY)	(SI	R)=(5 / 1F)=	-0.20		
7.	SIMPLE PAYBA	ACK PE	RIOD (ES	TIMATED)	SPB=1F/	4	-596.00		



LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REGION NOS. 7 PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: 472A6 ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 25 YEARS PREPARE		IDY: USDBAE LCCID 1.035 CENSUS: 2 RB
 INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E) 	\$\$ \$\$ \$\$ \$ • •	8350. 501. 459. 8379. 0. 8379.
 ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAVINGS 		
UNIT COST SAVINGS ANNUAL \$ DISCOUNT FUEL \$/MBTU(1) MBTU/YR(2) SAVINGS(3) FACTOR(4		DISCOUNTED AVINGS(5)
A. ELECT\$12.4418.\$224.11.16B. DIST\$.000.\$0.17.19C. RESID\$.000.\$0.17.12D. NAT G\$4.080.\$0.16.15E. COAL\$.000.\$0.13.92		2500. 0. 0. 0. 0.
F. TOTAL 18. \$ 224.	\$	2500.
3. NON ENERGY SAVINGS(+) / COST(-)		
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) 11.65	\$	0.
(2) DISCOUNTED SAVING/COST (3A X 3A1)	\$	0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3A2+3Bd4)	\$	0.
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) $\$$ 825. A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = (2F5+3D1)/1F)= C IF 3D1B IS < 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY		
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOMIC LIFE))	\$	224.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)	\$	2500.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= 0.30 (IF < 1 PROJECT DOES NOT QUALIFY)		
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4 37.41		



PI FI	ENE ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	990 DI	TION INVEST RT LEAVENV SCRETE POF	MENT PRO VORTH - 1	DGRAM (EC USDB REG IE: 473A6	IP) ION NOS. 7 PREPARED	LC	Y: USDBAE CID 1.035 CENSUS: 2
1.	B. SIOH C. DESIGN (D. ENERGY E. SALVAGE	UCTION COST)			\$ \$ \$ \$ \$ \$ \$	2565. 154. 141. 2574. 0. 2574.
2.	ENERGY SAY ANALYSIS D	VINGS (+) / COST ATE ANNUAL SAV	'(-) /INGS, UNIT	COST & DI	SCOUNTE) SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS	AN	NUAL \$ /INGS(3)	DISCOUNT FACTOR(4)		COUNTED /INGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	9. 0. 0. -20. 0.	\$ \$ \$ \$	112. 0. 0. -82. 0.	11.16 17.19 17.12 16.15 13.92		1250. 0. 0. -1324. 0.
	F. TOTAL		-11.	\$	30.		\$	-74.
3.	NON ENERG	Y SAVINGS(+) / C	OST(-)					
	A. ANNUAL F	RECURRING (+/-) DUNT FACTOR (T/			11.65		\$	0.
	(2) DISCO	DUNTED SAVING	COST (3A X	3A1)	11.05		\$	0.
	C. TOTAL NO	ON ENERGY DISC	OUNTED SA	VINGS(+) /	COST(-) (3/	A2+3Bd4)	\$	0.
	(1) 25% M A IF 3D B IF 3D C IF 31	NON ENERGY Q IAX NON ENERGY D1 IS = OR > 3C G D1 IS < 3C CALC D1B IS = > 1 GO T D1B IS < 1 PROJE	(CALC (2F5 O TO ITEM 4 SIR = (2F5+) O ITEM 4	X .33) 3D1)/1F)=		. -24.		
4.	FIRST YEAR I	DOLLAR SAVING	S 2F3+3A+(3l	31D/(YEAR	S ECONON	IIC LIFE))	\$	30.
5.	TOTAL NET D	DISCOUNTED SAV	/INGS (2F5+3	C)			\$	-74.
		D SAVINGS RATIC		(SIR)=(5 / 1F)=	-0.03		
7.	SIMPLE PAYE	BACK PERIOD (ES	STIMATED)	SPB=1F/4		85.80		



۲ F	ENEI NSTALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	rgy (& Loc Titli 90	ATION: FOI E: 1496 DIS	TON INVES RT LEAVEN CRETE PO	STMENT PE	ROGRAM (EC USDB REG ME: 475AA6	ION NOS. 7	L	DY: USDBAE CCID 1.035 CENSUS: 2
1	. INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY E. SALVAGE F. TOTAL INV	JCTIC COST CREE VALU	DIT CALC (1) JE COST	·	.9			\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	8020. 481. 441. 8048. 0. 8048.
2.	ENERGY SAV	INGS	S (+) / COST NNUAL SAV	(-) INGS, UNIT	۲ COST & I	DISCOUNTE	* SAVINGS		
	FUEL		JNIT COST //MBTU(1)	SAVINGS MBTU/YR		NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$	12.44 .00 .00 4.08 .00	32. 0. 0. 0.	\$ \$	398. 0. 0. 0. 0.	11.16 17.19 17.12 16.15 13.92		4442. 0. 0. 0. 0.
	F. TOTAL			32.	\$	398.		\$	4442.
3.	NON ENERGY	SAV	'INGS(+) / C(DST(-)					
	A. ANNUAL R (1) DISCO	ECUI UNT	RRING (+/-) FACTOR (TA	BLE A)		11.65		\$	0.
	(2) DISCO	UNTE	ED SAVING/C	OST (3A)	(3A1)	11.00		\$	0.
	C. TOTAL NO					/COST(-) (3/	A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX N(1 IS = 1 IS <)1B IS	ENERGY QU DN ENERGY OR > 3C GO 3C CALC \$ \$ = > 1 GO TO < 1 PROJEC	CALC (2F5 D TO ITEM SIR = (2F5- D ITEM 4	5 X .33) 4 +3D1)/1F)=		5 1466.		
4.	FIRST YEAR D	OLLA	AR SAVINGS	2F3+3A+(3	BB1D/(YEA	RS ECONOM	IIC LIFE))	\$	398.
5.	TOTAL NET DI	SCO	UNTED SAVI	NGS (2F5+	3C)			\$	4442.
6.	DISCOUNTED (IF < 1 PROJEC	SAVI CT DO	NGS RATIO DES NOT QL	IALIFY)	(SI	R)=(5 / 1F)=	0.55		
7.	SIMPLE PAYB	ACK I	PERIOD (ES	TIMATED)	SPB=1F/	4	20.22		





CONSTRUCTION COST ESTIMATE	DATE PR	EPARED	4/2/90	<u> </u>	SHEET OF		
PROJECT USDB ENERGY STUDY			L	BASIS FOR			1 8
LOCATION FORT LEAVENWORTH, KS				COMPLETED) IY DESIGN)			
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS	SKUP				_CODE C	(FINAL DESIG	AN)
DRAWING NO. NONE		ESTIM	ATOR	DLS	<u>ornen</u>	CHECKED B	Y TOL
ECO-A6		ANTITY		IATERIAL		ABOR	TOTAL
SOLAR WINDOW SHADING	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 450							
SOLAR FILM	488	SQ FT	1.30	634	1.30	634	\$1,269
MOBILIZATION	488	SQ FT			0.15	73	
-							
							······································
							······································
							······
							* <u></u> ********************************
SUBTOTAL				\$634		\$708	\$1,342
CONTINGENCY 10%			10%	\$63	10%	\$71	\$134
SUBTOTAL				\$697		\$779	\$1,476
WORK COMP, TAX, SOC. SEC., INS			3.50%	\$24	13.0%	\$101	\$125
DIRECT COST				\$721		\$880	\$1,601
OVERHEAD AND PROFIT			25%	\$180	25%	\$220	\$400
SUBTOTAL				\$901		\$1,100	\$2,001
CONSTRUCTION COST							
NG. FORM 150		L		L			\$2,001

ECO-A6





CONSTRUCTION COST ESTIMATE			DATE PP	EPARED	4/2/90	`	SHEET OF
PROJECT		·	<u>_</u>	BASIS FOR			2
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS				x	CODE A	(NO DESIGN (PRELIMINAR	COMPLETED) Y DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS	מוואי				CODE C	(FINAL DESIG	iN)
DRAWING NO.		ESTIM	ATOR		OTHER	SPECIFY)	v
NONE ECO-A6				DLS			TOL
SOLAR WINDOW SHADING	NO. UNITS	UNIT MEAS.	PER UNIT	ATERIAL TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
BUILDING 463							
SOLAR FILM	501	SQ FT	1.30	651	1.30	651	\$1,3
MOBILIZATION	501	SQ FT			0.15	75	
			·····				
			<u></u>				
······································							
	_						
	_						
SUBTOTAL				\$651		\$726	\$1,3
ONTINGENCY 10%			10%	\$65	10%	\$73	\$1
				\$716		\$799	\$1,5
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$25	13.0%	\$104	\$1
	┼──┼			\$741		\$903	\$1,64
	╉╼╌╂		25%	\$185	25%	\$226	\$4
				\$926		\$1,129	\$2,0
CONSTRUCTION COST NG. FORM 150 NC-59	_1	L					\$2,0



CONSTRUCTION COST ESTIMATE			DATE PF	EPARED	· · · · ·	······	SHEET OF	
PROJECT					4/2/90		3 8	
USDB ENERGY STUDY				BASIS FOR I				
LOCATION FORT LEAVENWORTH, KS				X		(NO DESIGN		
ARCHITECT/ENGINEER				CODE B (PRELIM			SN)	
CLARK RICHARDSON & BIS DRAWING NO.		ESTIM	ATOR	L	OTHER	SPECIFY) CHECKED BY		
NONE				DLS ATERIAL	,		TOL	
SOLAR WINDOW SHADING	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST	
BUILDING 464								
SOLAR FILM	434	SQ FT	1.30	564	1.30	564	\$1,128	
MOBILIZATION	434	SQ FT			0.15	65		
	_							
······								
SUBTOTAL				\$564		\$629	\$1,194	
CONTINGENCY 10%			10%	\$56	10%	\$63	\$119	
SUBTOTAL				\$620		\$692	\$1,313	
WORK COMP, TAX, SOC.SEC., INS			3.50%	\$22	13.0%	\$90	\$112	
DIRECT COST	\downarrow			\$642		\$782	\$1,425	
OVERHEAD AND PROFIT			25%	\$161	25%	\$196	\$357	
SUBTOTAL	<u> </u>			\$803		\$978	\$1,782	
CONSTRUCTION COST							\$1,782	

.

CONSTRUCTION COST ESTIMATE DATE								OF
PROJECT	BASIS FOR	4/2/90 ESTIMATE		<u> </u>	4 8			
USDB ENERGY STUDY				x		(NO DESIGN		
FORT LEAVENWORTH, KS	^	CODE B	(PRELIMINAR	Y DESIGN)	:0)			
CLARK RICHARDSON & BISK					CODE C	(FINAL DESIG	SN)	
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL	
ECO-A6 SOLAR WINDOW SHADING		ANTITY	N	IATERIAL		ABOR	TOT	
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	co	ST
BUILDING 472								
SOLAR FILM	2035	SQ FT	1.30	2,646	1.30	2,646		\$5,29
MOBILIZATION	2035	SQ FT			0.15			\$30
					· · ·			
								···
			-					
SUBTOTAL				\$2,646		\$2,951		\$5,596
CONTINGENCY 10%			10%	\$265	10%	\$295		\$560
SUBTOTAL	┟───┤			\$2,911		\$3,246		\$6,156
WORK COMP, TAX, SOC.SEC., INS	<u> </u>		3.50%	\$102	13.0%	\$422		\$524
DIRECT COST	<u> </u>			\$3,013		\$3,668		\$6,680
OVERHEAD AND PROFIT			25%	\$753	25%	\$917		\$1,670
SUBTOTAL	↓ ↓			\$3,766		\$4,585		\$8,350
CONSTRUCTION COST]				\$8,350

•



CONSTRUCTION COST ESTIMATE			DATE PR	EPARED	4/2/90	·	SHEET OF	
PROJECT USDB ENERGY STUDY				BASIS FOR	58			
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				X	CODE B	(PRELIMINAF	COMPLETED) RY DESIGN)	
CLARK RICHARDSON & BISKUP						(FINAL DESIC (SPECIFY)	3N)	
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL	
ECO-A6 SOLAR WINDOW SHADING	QU/ NO.	ANTITY	PER N	ATERIAL TOTAL	PER	ABOR TOTAL	TOTAL COST	
		MEAS.	UNIT		UNIT			
BUILDING 473					ļ	<u> </u>		
SOLAR FILM	625	SQ FT	1.30	813	1.30	813	\$1,62	
MOBILIZATION	625	SQ FT			0.15	94	\$94	
				······································				
							· · · · · · · · · · · · · · · · · · ·	
SUBTOTAL				\$813		\$906	\$1,719	
CONTINGENCY 10%			10%	\$81	10%	\$91	\$172	
SUBTOTAL				\$894	10,0	\$997	\$1,891	
WORK COMP, TAX, SOC. SEC., INS			3.50%	\$31	13.0%	\$130	\$161	
DIRECT COST				\$925		\$1,127	\$2,052	
OVERHEAD AND PROFIT			25%	\$231	25%	\$282	<u>42,032</u> \$513	
SUBTOTAL				\$1,156		\$1,409	\$2,565	
CONSTRUCTION COST ENG. FORM 150							\$2,565	



_

(

ESTIM NTITY UNIT MEAS.		BASIS FOR E	CODE A CODE B CODE C	(NO DESIGN ((PRELIMINAR) (FINAL DESIG (SPECIFY)	Y DESIGN)
	M	DLS	CODE B	(PRELIMINAR (FINAL DESIG (SPECIFY)	Y DESIGN)
	M	DLS	CODE B	(PRELIMINAR (FINAL DESIG (SPECIFY)	Y DESIGN)
	M	DLS	OTHER	(SPECIFY)	•NN
	M	DLS			437
UNIT		ULS		CHECKED BY	
	PER	ATERIAL	l	ABOR	TOL TOTAL
	UNIT	TOTAL	PER UNIT	TOTAL	COST
SQ FT	1.30	2,542	1.30	2,542	\$5,0
SQ FT			0.15		\$2
					¥
			-		······
					<u> </u>
		\$2.540			
	1.0%		100/		\$5,3
			10%		\$5:
	3,50%		13.0%		\$5,9
			10.078		\$50
	25%		25%		\$6,41
			2376		\$1,60
				<u></u>	\$8,02 \$8,02
			SQ FT	SQ FT 0.15	SQ FT 0.15 293

CONSTRUCTION COST ESTIMATE DATE PR			EFARED	4/2/90)	SHEET OF	
PROJECT USDB ENERGY STUDY					ESTIMATE		/
LOCATION	x	CODE A	(NO DESIGN	COMPLETED)			
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER		CODE B	(PRELIMINAR	Y DESIGN)			
CLARK RICHARDSON & BI	SKUP					(FINAL DESIG	iN)
DRAWING NO. NONE		ESTIM	ATOR			CHECKED B	
ECO-A6	QU/	ANTITY	N	DLS IATERIAL	T 1	ABOR	TOL TOTAL
SOLAR WINDOW SHADING	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475B							
SOLAR FILM	676	SQ FT	1.30	879	1.30	879	\$1,7
MOBILIZATION	676	SQ FT			0.15		\$1, \$
				<u> </u>			
	_						
							······
SUBTOTAL				\$879		\$980	\$1,8
ONTINGENCY 10%			10%	\$88	10%	\$98	
SUBTOTAL				\$967		\$1,078	\$2,04
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$34	13.0%	\$140	\$17
DIRECT COST				\$1,001		\$1,218	\$2,21
VERHEAD AND PROFIT			25%	\$250	25%	\$305	\$55
SUBTOTAL				\$1,251		\$1,523	\$2,77
CONSTRUCTION COST							
NG. FORM 150 NVC-59		L_		<u> </u>			\$2,7





CONSTRUCTION COST ESTIMATE	REPARED	SHEET OF						
PROJECT					4/2/90 BASIS FOR ESTIMATE			
					_CODE A	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER		CODE B	(PRELIMINAR (FINAL DESIG	Y DESIGN)				
CLARK RICHARDSON & BIS DRAWING NO.	KUP					(SPECIFY)	,	
NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL	
ECO-A6 SOLAR WINDOW SHADING		ANTITY		IATERIAL		ABOR	TOTAL	
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 475H								
SOLAR FILM	636	SQ FT	1.30	827	1.30	827	\$1,0	
MOBILIZATION	636	SQ FT			0.15			
			***		0.10	90		
								
	+						·····	
							·····	
······································							·······	
SUBTOTAL	╉╼╍╂							
				\$827		\$922	\$1,7	
ONTINGENCY 10%			10%	\$83	10%	\$92	\$1	
SUBTOTAL	╉╼╾╋			\$910		\$1,014	\$1,9	
ORK COMP, TAX, SOC.SEC., INS	╉──┨		3.50%	\$32	13.0%	\$132	\$1	
DIRECT COST	++			\$942		\$1,146	\$2,0	
VERHEAD AND PROFIT	╉───╂		25%	\$235	25%	\$287	\$5	
SUBTOTAL	╉──┤			\$1,177		\$1,433	\$2,61	
CONSTRUCTION COST							\$2,61	



Product Performance Guide

IN30BR Bronze

IN30BR Scotchtint[™] Plus All Season Window Film


Description

IN30BR Scotchtint Plus All Season Window Film is designed for application to the inside of existing glass windows. Its function is to reduce the solar heat gain, ultra-violet light and glare that normally would enter through the windows. The film also reduces heat loss through the windows to the outside during the cooler months. The film remains transparent while performing these functions.

Benefits



In addition to the typical benefits on 1/4" (6 mm) clear glass shown at right, the film provides increased shatter resistance.



📕 ¼″ (6 mm) Clear Glass

With IN30BR

Performance Data											
Glan Typ		Applied Product	Shading Total Solar Energy Visible Light Coefficient Reflected Absorbed Transmitted Reflected Transmitted				e Light Transmitted	UV Light	Emissivity	"U" Value	
	Clear	None	.94	8%	15%	77%	8%	88%	< 68%	.84	1.06
Single		IN30BR	1990anii -	34%	43%	23%	25%	34%	< 1%	.23	.69
Pane	Tinted	None	.69	5%	50%	45%	5%	50%	< 29%	.84	1.06
 .		INGOBR	.31	15%	72%	13%	11%	18%	< 1%	.23	.69
	Clear	None	.81	14%	26%	60%	14%	78%	< 46%	.84	.50
Insulated		IN30BR		29%	53%	18%	28%	31%	< 1%	.23	.39
Pane	Tinted	None	.55	8%	54%	38%	8%	45%	<21%	.84	.50
	D-A6	IN30BR	.31	12%	77%	11%	11%	17%	< 1%	.23 PAGE A6-	

ECO-A6

SOLAR WINDOW SHADING

BUILDING 450



********	***************************************	******
******	********************	****
**		**
**	TRACE ULTRA ANALYSIS	**
**		**
**	by CLARK RICHARDSON BISKUP	**
**		**
***********	***************************************	******
**********	*********************	******

USDB ENERGY STUDY LEAVENWORTH, KANSAS USDB RUSSELL G. BAEHR

Weather File Code:	FTLVNW	TH
Location:	LEAVEN	WORIH, KANSAS (USDB)
Latitude:	39.4	(deg)
Longitude:	94.9	(deg)
Time Zone:	6	
Elevation:	770	(ft) .
Barometric Pressure:	29.1	(in. Hg)
Summer Clearness Number:	0.95	
Winter Clearness Number:	0,95	
Summer Design Dry Bulb:	96	(F)
Summer Design Wet Bulb:		(F)
Winter Design Dry Bulb:	3	• •
Summer Ground Relectance:	0.20	
Winter Ground Relectance:	0.20	
Air Density:	0.0739	(Ibm/cuft)
Air Specific Heat:	0.2444	(Btu/lbm/F)
Density-Specific Heat Prod:	1.0837	(Btu-min./hr/cuft/F)
Latent Heat Factor:		(Btu-min./hr/cuft/lbm)
Enthalpy Factor:	4.4333	(Btu-min./hr/cuft)
Design Simulation Period: May	То	October
System Simulation Period: Jam		
Cooling Load Methodology:	and/ar	
- 51		·

3

.

Time/Date Program was Run:	3:47:50	1/11/90
Dataset Name:	450A26 .	M

V 600 PAGE 1



AIRFLOW - ALTERNATIVE 3 ECO-A6 WINDOW SCH-.36

System System Number Type	Ortside Airflow (Cfm)	Cooling Airflow (Cfm)	Main Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Auxil. Supply Airflow (Cfm)	Room Exhaust Airflow (Cfm)
1 MZ	870	8,764	8,764	8,764	8,764	0	670
2 FC	0	407	407	407	0	0	0
3 FC	0	147	147	147	0	0	0
Totals	870	9,318	9,318	9,318	8,764	0	670

CAPACITY - ALTERNATIVE 3 ECO-A6 WINDOW SCH-.36

- SYSTEM SUMMARY ---(Design Capacity Quantities)

System Syst Number Ty	-	Aux. Sys.	ling Opt, Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Heating Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Vent Capacity (Btuh)	Heating Totals (Btuh)
1 MZ	30.5	0.0	0.0	30.5	-665,959	0	0	0	0	0	-665,959
2 FC	0.0	0.0	0.0	0.0	-27,351	0	0	0	0	0	-27,351
3 FC	0.0	0.0	0.0	0.0	-9,869	0	0	0	0	0	-9,869
Totals	30.5	0.0	0.0	30.5	-703,178	0	0	0	0	0	-703,178

ENGINEERING CHECKS - ALTERNATIVE 3 ECO-A6 WINDOW SCH=.36

----- ENGINEERING CHECKS

			Percent		Coo	ling		Heat	ing	
System	Main/	System	Outside	Cfm/	Cfm/	Sq Ft	Btuh/	Cfm/	Btuh/	Floor Area
Number	Auxiliary	Type	Air	Sq Ft	Tan	/Tan	Sq Ft	Sq Ft	Sq Ft	Sq Ft
-						_				
7	Main	MŻ	9.93	0.91	287.4	315.2	38.07	0.91	-69.29	9,611
2	Main	FC	0.00	2.87	*******	*******	0.01	2.87	-192.75	142
3	Main	FC	0.00	0.54	*******	*******	0.00	0.54	-36.55	270



V 600 PAGE 2

System 1 Block MZ - MULTIZONE

******	******** 🕫	XLING COLL	PEAK ******	******	******	***	**** CLG SPAC	E PEAK ***	***	***** HEATING	COIL PEAK	******
Peaked at Time	=>		7/15			*	Mo/Hr:	7/16	*		/Hr: 13/ 1	
Outside Air ==>	OAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	c	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Percnt	*	Space	Percnt	*	Space	Total	Percnt
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	. 0	0	0.00
Roof Cond	22,575	21,512		44,087	12.05	*	22,293	10.21	*	-19,865	-19,865	0.00
Glass Solar	12,755	0		12,755	3.49	*	13,642	6.25	*	0	0	0.00
Glass Cond	7,011	0		7,011	1.92	*	6,947	3.18	*	-30,975	-30,975	5.13
Wall Cond	11,126	1,625		12,750	3.48	*	11,650	5.33	*	-30,336	-35,487	5.88
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	-8,929	-8,929	1.48
Infiltration	80,527			80,527	22.01	*	31,225	14.29	*	-114,593	-114,593	18.98
Sub Total=>	133,994	23,136		157,130	42.95	*	85,757	39.26	*	-204,699	-209,850	34.76
Internal Loads				,		*			*	,		
Lights	64,850	14,646		79,496	21.73	*	65,153	29.83	*	0	0	0.00
People	33,610			33,610	9.19	*	17,165	7.86	*	0	0	0.00
Misc	45,103	0	0	45,103	12.33	*	45, 459	20.81	*	0	0	0.00
Sub Total==>	143,563	14,646	0	158,209	43.24	*	127,778	58.50	*	0	0	0.00
Ceiling Load	4,888	-4,888		. 0	0.00	*	4,902	2.24	*	-3,119	0	0.00
Outside Air	` 0	0	0	43,064	11.77	*	0	0.00	*	. 0	-61,281	10,15
Sup. Fan Heat				10,745	2.94	*		0.00	*		0	0.00
Ret. Fan Heat		0		. 0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	*	-333, 525	-333,525	55.24
Exhaust Heat		-3,282	0	-3,282	-0.90	*		0.00	*		891	-0.15
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
						*			*			
Grand Total=>	282,444	29,612	0	365, 865	100.00	*	218,437	100.00	*	-541,343	-603,766	100.00

				ING COIL SEI	ECTION-							ARE	AS		
	Total C	apacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross I	'otal	Glass	(sf)	(욱)
	(Tons)	(Mch)	(Moh)	(cím)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	9,611			
Main Clg	30.5	365.9	274.4	8,764	83.3	66.3	72.4	54.4	52.4	57.2	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	225			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	5,180		0	0
Totals	30.5	365.9									Wall	6,156		566	ັ 9

	-HEATING CO	OIL SELECTION	F		AJ	RFLOWS (cfm)	ENGINEERING C	HECKS	TEMPERAT	URES	(F) —
	Capacity	Coil Airfl	Ent	Lvg	Туре	Cooling	Heating	Clg & OA	9.9	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	870	870	Clg Cfm/Sqft	0.91	SADB	55.0	125.0
Main Htg	-666.0	8,764	55.0	125.0	Infil	1,627	1,627	Clg Cfm/Tan	287.45	Plenum	81.5	65.8
Aux Htg	0.0	0	0.0	0.0	Supply	8,764	8,764	Clg Sqft/Tan	315.24	Return	81.5	67.2
Preheat	0.0	8,764	60.8	53.9	Mincfm	870	370	Clg Btuh/Sqft	38.07	Ret/OA	82.9	60.9
Reheat	0.0	0	0.0	0.0	Return	8,505	8,764	No. People	87	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	8,764	870	Htg 3 QA	9.9	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	670	0	Htg Cfm/Saft	0.91	Fn BldID	0.2	0.0
Total	-666.0				Auxil	0	0	Htg Btuh/SqFt	-69.29	Fn Frict	0.7	0.0

V 600

System 2 Block FC - FAN COIL

Peaked at Time				******	******	***						******
			7/10			*	Mo/Hr:	7/10	*		/Hr: 13/ 1	
Outside Air =>	QAD	B/WB/HR: 8	36/ 72/ 98.0			*	QADB:	86	*	a	ADB: 3	
	_					*			*			
	Space	Ret. Air	Ret. Air	Net	Percnt	*	Space	Percnt	-	Space	Total	Percnt
Emmlese Teeds	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	01 100	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(욱)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00		0	0	0.00
Roof Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Solar	4,680	0		4,680	63.51	*	4,680	70.66		0	0	0.00
Glass Cond	671	0		671	3.14	*	671	10.13	*	-6,571	-6,571	24.02
Wall Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Partition	0			0	0.00	*	0	0.00		0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	-397	-397	1.45
Infiltration	965			965	13.10	*	344	5.20	*	-2,665	-2,665	9.75
Sub Total=>	6,316	0		6,316	85.71	*	5,695	85.98	*	-9,633	- 9,633	35.22
Internal Loads						*			*			
Lights	557	371		928	12.60	*	557	8.41	*	0	0	0.00
People	0			0	0.00	*	0	0.00	*	0	0	0.00
Misc	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total=>	557	371	0	928	12.60	*	÷ 557	. 8.41	*	0	0	0.00
Ceiling Load	371	-371		0	0.00	*	371	5.61	*	0	0	0.00
Outside Air	0	0	0	0	0.00	*	0	0.00	*	·. 0	0	0.00
Sup. Fan Heat				125	1.69	*		0.00	*		0	0.00
Ret. Fan Heat		0		0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	*	-17,718	-17,718	64.78
Exhaust Heat		0	0	0	0.00	*		0.00	*	•	. 0	0.00
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
						*			*			
Grand Total=>	7,245	0	0	7,369	100.00	*	6,623	100.00	*	-27,351	-27,351	100.00

				LING COIL SEI	ECTION-							AREAS		
	Total C	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross To	tal Glass	s (sf)	(%)
	(Tons)	(Moh)	(Moh)	(cím)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	142		
Main Clg	0.0	0.0	0.0	407	78.1	64.9	73.9	62.8	62.6	87.7	Part	0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	10		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Rcof	0	0	- 0
Totals	0.0	0.0									Wall	120	120	100

	-HEATING 🛛	OIL SELECTION			AI	RFLOWS (cfm)	ENGINEERING C	HECKS	-TEMPERAT	URES (F) ——
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % CA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	ō	0	Clg Cfm/Sqft	2.87	SADB	63.0	130.0
Main Htg	-27.4	407	68.0	130.0	Infil	38	38	Clg Cfm/Ton	******	Plenum	86.3	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	407	407	Clg Sqft/Tan	******	Return	78.0	68.0
Preheat	0.0	407	68.0	62.7	Mincim	0	0	Clg Btuh/Sqft	0.01	Ret/QA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	407	407	No. People	0	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	38	0	Htg & OA	0.0	En MtrID	0.0	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg Cfm/SqFt	2.87	Fn BldID	0.1	0.0
Total	-27.4				Auxil	0	0	Htg Btuh/Soft	-192.75	Fn Frict	0.2	0.0



V 600

PAGE 4

System 3 Block FC - FAN COIL

************	************ 📿	XLING COIL	PEAK *******	******	******	***	**** CLG SPAC	e peak ***	***	***** HEATING	COIL PEAK	******
Peaked at Time :	>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/16	*	Mo	/Hr: 13/ 1	
Outside Air =>	QAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Percnt	*	Space	Percnt	: *	Space	Total	Percnt
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	С	0.	0.00
Roof Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Solar	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Wall Cond	246	47		293	6.16	*	268	7.94	*	-1,005	-1,466	14.86
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	-793	-793	8.04
Infiltration	2,455			2,455	51.53	*	1,024	30.39	*	-3,804	-3,804	38.54
Sub Total==>	2,701	47		2,748	57.68	*	1,292	38.33	*	-5,602	-6,063	61.43
Internal Loads						*			*			
Lights	1,183	788		1,971	41.37	*	1,213	36.01	*	0	0	0.00
People	0			0	0.00	*	0	0.00	*	0	0	0.00
Misc	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total=>	1,183	- 788	0	1,971	41.37	*	1,213	. 36.01	*	0	0	0.00
Ceiling Load	836	-836		0	0.00	*	865	25.66	*	-461	0	0.00
Outside Air	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sup. Fan Heat				45	0.95	*		0.00	*		0	0.00
Ret. Fan Heat		0		0	0.00	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	*	-3,806	-3,806	38.57
Exhaust Heat		0	0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
						*			*			
Grand Total=>	4,719	0	0	4,764	100.00	*	3, 369	100.00	*	-9,869	-9,869	100.00

				ING COIL SEI	ECTION-							AREA	<u></u>		
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross 1	Total	Glass	(sî)	(웅)
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Flœr	270			
Main Clg	0.0	0.0	0.0	147	78.1	64.9	73.9	57.0	56.3	68.9	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	20			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0	٩.
Totals	0.0	0.0									Wall	240		0	0

	-HEATING CO	DIL SELECTION	}		AI	RFLOWS (cfm)	ENGINEERING C	HECKS	-TEMPERAT	URES (F) —
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & CA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	0.54	SADB	56.8	130.0
Main Htg	-9.9	147	68.0	130.0	Infil	54	54	Clg Cfm/Ton	******	Plenum	87.8	62.6
Aux Htg	0.0	0	0.0	0.0	Supply	147	147	Clg Saft/Tan	******	Return	78.0	68.0
Preheat	0.0	147	68.0	56.5	Mincfm	0	0	Clg Btuh/Sqft	0.00	Ret/OA	78.0	68.0
Rebeat	0.0	0	0.0	0.0	Return	147	147	No. People	0	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	54	0	Htg 3 QA	0.0	Fn MtriD	0.0	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	0	0	Htg Cfm/SqFt	0.54	Fn BldID	0.1	0.0
Total	-9.9				Auxil	0	0	Htg Btuh/Soft	-36.55	Fn Frict	0.2	0.0

.



PAGE 5



:

۰.

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

-

	ELEC	DEMAND	
	On Peak	On Peak	STEAM
Month	(kwh)	(kw)	(Therm)
Jan	9,846	51	65 0
		51	652
Feb	8,722	51	585
March	10,321	51	606
April	9,280	51	304
May	10,268	51	0
June	13,790	80 -	· 0
July	15,630	87	0
Aug	15,336	79	0
Sept	10,517	73	0
0ct	9,829	51	0
Nov	9,297	51	530
Dec	8,884	51	726
Total	131,720	87	3,403

Building Energy Consumption = 78,804 (Btu/Sq Ft/Year) Source Energy Consumption = 179,838 (Btu/Sq Ft/Year)

Floor'Area =

10,023 (Sq Ft)

V 600 PAGE 6



÷

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

EQUIEMENT ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

Ref	Equip -					Mont	hly Cons							
Nam	Code	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	Total
0	LIGHTS													
	ELEC	5454	4813	5775	5133	5775	5454	5133	6096	4813	5454	51.33	4813	63,847
	PK	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9
1	MISC LD													
	ELEC	2682	2366	2839	2524	2839	2682	2524	2997	2366	2682	2524	2366	31,392
	PK	15.2	15.2	15.2	15.2	15.2	15.2	15.2	15.2	15.2	15.2	15.2	15.2	15.2
2	MISC ID													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	<u>`</u> 0	0	0	0	0	0
•	PK .	0.0	0.0	0.0	0.0	0.0	0.0.	0.0	°0.0	. 0.0	0.0	0.0	0.0	0.0
4	MISC LD													
	P SIEAM PK	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD PHOTH20		•								_	_		-
	P HOLHZO PK	0 0.0	0	0	0	0	0	0	0	0	0	0	0	0
	FR	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	٥	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ1170L			OND COMP		-								
	ELEC	0	0	0	0	0	3533	5510	3996	1486	0	0	0	14,525
	PK	0.0	0.0	0.0	0.0	0.0	24.9	31.3	24.8	19.2	0.0	0.0	0.0	31.3 -
1	EQ5200			ENSER FA										
	ELEC	0	0	0	0	0	428	716	491	182	0	0	0	1,817
	PK	0.0	0.0	0.0	0.0	0.0	3.2	3.7	3.1	2.5	0.0	0.0	0.0	3.7
1	EQ5313		CONI	ROLS										
	ELEC	0	0	0	0	0	95	102	100	79	0	0	0	377
	PK	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.0	0.0	0.0	0.3
1	EQ4002			ENIRIF.	FAN C.V.									
	ELEC	1587	1433	1587	1536	1587	1536	1587	1587	1536	1587	1536	1587	18,686
	PK	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9
1	EQ4381			ELLER FA										
	ELEC	33	29	35	31	35	33	31	37	29	33	31	29	389
	PK	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
2	EQ4371		FAN	COIL SUP	PLY FAN									

V 600 PAGE 7

.



	ELEC	28	26	28	22	23	21	20	23	20	65	24	28	327
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
3	EQ4371		FAN	COIL SUPP	PLY FAN									
	ELEC	10	9	10	7	8	7	7	8	7	7	8	10	100
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ2101		PURCE	ASED DIS	SIRICT S	TEAM								
	P STEAM	621	556	581	299	0	0	0	0	0	0	516	687	3,260
	PK	4.6	4.5	4.3	2.1	0.0	0.0	0.0	0.0	0.0	0.0	3.2	4.7	4.7
1	EQ5020		UFAT	WATER C		PCV								
-	ELEC	5	5	5	4	0	•	•	•	•	•	-	F	30
	PK	0.0	0.0	0.0	0.0		0	0	0	0	0	5	5	
		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	EQ5061		CONDE	NSATE R	ETURN PU	ΥP								
	ELEC	11	10	11	8	0	0	0	0	0	0	10	11	60
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	CONVERTR		SULAN	1 TO HOT										
-	P STEAM	31	28	25			•	•	•	0	•	14	20	140
	PK	0.1	0.1		5	. 0	0	0	0	0	0.	14	39	. 143
	· ·	0.1	0.1	0.1	0.0	0.0	0.0	0.0	`0.O	0.0	0.0	0.0	0.1	0.1
2	EQ5020	•	HEAT	WATER CI	RC. PUM	2 C.V.								
	ELEC	1	1	1	0	0	0	. 0	0	0	0	0	1	3
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
														0.0
2	EQ5060		CONDE	NSATE RE	TURN PUR	P								
	ELEC	35	31	29	14	0	0	0	0	0	0	25	35	168
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
							0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

V 600

PAGE 3



,





۰.

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

UTILITY PEAK CHECKSUMS - ALTERNATIVE 3 BASE LOAD V 600 PAGE 9

Utility ELECTRIC DEMAND

Peak Value 86.6 (kW) Yearly Time of Peak 15 (hr) 7 (mo)

Hour 15 Month 7

Eqp. Ref. Num.	Equipment Code Name	Equipment Description	Utility Demand (kW)	
Cooling E	quipment			
1	EQ1170L	AC COND COMP <20 TONS	35.3	40.80
Sub Total	L		35.3	40.80
Sub Total	L		0.0	0.00
Air Movir	ng Equipment			1
1		SUMMATION OF FAN ELECTRICAL DEMAND	5.1	5.86
2		SUMMATION OF FAN ELECTRICAL DEMAND	0.1	0.13
3		SUMMATION OF FAN ELECTRICAL DEMAND	0.0	0.05
Sub Total			5.2	6.03
Sub Total			0.0	0.00
Miscellan	ecus			
Lights			30.9	35.64
Base Uti	lities			0.00
Misc Equ	-		15.2	
Sub Total			46.0	53.17
Grand Tot	al		86.6	100.00

UTILITY PEAK CHECKSUMS





CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 3 BASE LOAD

Weather Name	FTLVNWIH
Gross Conditioned Floor Area (soft)	10,023
ACM Multiplier	1.008

ENERGY USE SUMMARY

CALIFORNIA TITLE 24 COMPLIANCE REPORT

	ELEC (KWh/yr)	DISTRICT STEAM (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	228.2	340,320.1	43.2	456,097.0	45.9
Primary Cooling					
Compressor	14,524.5	0.0	6.3	148,731.5	15.0
Tower/Cond Fans	1,817.0	0.0	0.8	18,606.2	1.9
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	376.8	0.0	0.2	3,858.4	0.4
Auxiliary					
Supply Fans	19,501.6	0.0	8.4	199,697.0	20.1
Circulation Pumps	32.7	0.0	.0.0	334.5	0.0
Base Utilities	. 0.0	0.0	0.0	.0.0	0.0
Subtotal	19,534.3	• 0.0	. 8.4	200,031.5	20.1
Lighting	63,847.1	0.0	27.6	653,796.2	65.7
Receptacle	31,391.7	0.0	13.6	321,451.6	32.3
Domestic Hot Water	0.0	0.0	0.0	0.0	. 0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	131,719.6	340,320.1	100.0	1,802,572.4	181.3





ECO-A7

EXTERIOR WALL INSULATION





EXTERIOR WALL INSULATION

ENERGY CONSERVATION OPPORTUNITY: ECO-A7

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-A7) analyzes the energy savings associated with reducing the amount of heat transfer through the walls of the buildings located in the USDB. Energy savings can be accomplished by adding wall insulation to the exterior walls to decrease the heat transfer coefficient (U-value) of the walls.

SCOPE:

The ECO simulation (ECO-A7) adds additional insulation to the existing exterior walls of the buildings to reduce the amount of heat transfer through outside walls. The application of this project was considered for the following buildings:

Building 472 Building 475C

If the energy savings were better and showed a feasible payback for funding, more of the buildings would have been considered. However, because of the expense of adding insulation to existing walls, this ECO was not feasible.

MODELING TECHNIQUES:

The modeling technique used to calculate the energy savings associated with the implementation of this ECO was completed using the "*Trace Ultra*" computer simulation program. The existing wall U-value is entered to calculate the amount of energy used by the building at the present time. With the additional wall insulation added, a new U-value is calculated and entered into the computer model and a new energy usage is found. The difference in energy usage from the two computer runs is the energy savings that can be obtained by implementing this ECO. The two different construction methods were considered, represented two typical buildings where a payback was most probable. The building representing the standard gypboard construction was building 472. The building representing the metal clad gypboard construction was building 475C.

ECO IMPLEMENTATION:



To implement this ECO for the buildings listed above, the existing exterior wall would have to be furred out with 2X4's or 2X2's. Insulation would be added in between the furred out studs and a gypboard would be used to cover the insulation and studs. The gypboard would be painted and trimmed out to match the existing conditions. For the exterior walls in the cell barracks of the castle, where the wall are accessible to

ECO-A7

unsupervised inmates, a metal stud would be attached to the existing concrete walls, then insulated. A metal clad gypboard would be used to cover the metal studs from the floor to a height of 10'. The metal clad gypboard would be attached to the metal studs with a non-visible and non-removable fastener. Above the 10' border a standard gypboard would be used to save on some costs.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown below in Table A7.1 in million of BTU's per year savings as determined using the computer simulation model located in Volume 3.

The project cost is the construction cost as determined in this section plus 6% SIOH.

Building Number	Energy Savings (MBTU)	Cost Savings	Project Costs	Simple Payback	Savings to Invest Ratio
472	229	\$1,507	\$61,391	54.83	0.28
475C	154	\$628	\$168,196	253.55	0.06

Table A7.1

This ECO project is clearly not feasible from the paybacks and savings to investment ratios seen in Table A7.1. The project costs were high relative to average structures due to the nature of the occupants of this facility. Building 475C has a higher number of payback years because the building is heated only.



P F A	ISTALLATION & ROJECT NO. & ISCAL YEAR 199 NALYSIS DATE:	IGY LC TIT 90	LE: 1496 DI	TION INVES RT LEAVEN SCRETE PO	TMENT	PROGRAM	EGIC	P) DN NOS. 7 PREPARED		CEN	SDBAE 1.035 ISUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	OS OS RE	T DIT CALC(1 LUE COST		.9				\$\$ \$\$ \$\$ \$ \$		57916. 3475. 3185. 58118. 0. 58118.
2.	ENERGY SAV ANALYSIS DA	ING TE	IS (+) / COST ANNUAL SA\	(-) /INGS, UNIT	COST	& DISCOUNT	TED \$	SAVINGS			
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		ANNUAL \$ SAVINGS(3)		DISCOUNT FACTOR(4)		DISCOU SAVING	
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	15. 0. 0. 214. 0.	\$ \$ \$ \$			11.16 17.19 17.12 16.15 13.92			2087. 0. 0. 14099. 0.
	F. TOTAL			229.	\$	1060.			\$. I	16186.
3.	NON ENERGY			OST(-)							
	A. ANNUAL RI (1) DISCOU	JNJ	FACTOR (Ť	ABLE A)		11.65			\$		0.
			ED SAVING/						\$		0.
	C. TOTAL NOI						(3A2	2+3Bd4)	\$		0.
	A IF 3D ⁻ B IF 3D ⁻ C IF 3D	I IS I IS I IS	N ENERGY Q ION ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T S < 1 PROJE	/ CALC (2F5 O TO ITEM / SIR = (2F5⊣ O ITEM 4	i X .33) 4 ⊧3D1)/1∣	F)=	\$ -	5341.			
4.	FIRST YEAR D	OLI	AR SAVING	S 2F3+3A+(3	B1D/(Y	EARS ECON	OMIC	CLIFE))	\$		1060.
5.	TOTAL NET DI	sco	OUNTED SAV	'INGS (2F5+	3C)				\$	1	6186.
6.	DISCOUNTED (IF < 1 PROJEC	SA\ CT [/INGS RATIO	UALIFY)		(SIR)=(5 / 1F))=	0.28			
7.	SIMPLE PAYBA	\CK	PERIOD (ES	TIMATED)	SPB=	IF/4		54.83			

)	P Fi	ENE ISTALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY & LO(TITL 990	CATION: FOI E: 1496 DIS	FION INVES RT LEAVEN SCRETE PO	TMENT F	PROGRAM (E	GION NC	PS. 7 PARED		DY: USDBAE LCCID 1.035 CENSUS: 2 RB
	1.	INVESTMEN A. CONSTRU B. SIOH C. DESIGN (D. ENERGY E. SALVAGE F. TOTAL IN	JCTIC COST CREI VAL	DIT CALC (1, UE COST		.9				\$\$ \$\$ \$\$ \$\$ \$	158675. 9521. 8727. 159231. 0. 159231.
	2.	ENERGY SAV	/ING: ATE /	S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST &	DISCOUNTE	ED SAVIN	GS		
		FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR	-	ANNUAL \$ SAVINGS(3)		OUNT OR(4)		ISCOUNTED AVINGS(5)
		A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 154. 0.	\$ \$ \$ \$ \$	0. 0. 628. 0.		11.16 17.19 17.12 16.15 13.92		0. 0. 0. 10142. 0.
l		F. TOTAL			154.	\$	628.			\$	10142.
	3.	NON ENERGY	Y SAN	/INGS(+) / C(OST(-)						
		A. ANNUAL F (1) DISCO	UNT	FACTOR (TA	ABLE A)		11.65			\$	0.
				ED SAVINĠ/(\$	0.
		C. TOTAL NC						3A2+3Bd	4)	\$	0.
		A IF 3D B IF 3D C IF 31	AX N 01 IS 01 IS 01 B I	ENERGY QU ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJEC	′ CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 ⊧3D1)/1Fj)=	\$:	3347.		
	4.	FIRST YEAR [DOLL	AR SAVINGS	6 2F3+3A+(3	B1D/(YE	ARS ECONO	MIC LIFE	;))	\$	628.
	5.	TOTAL NET D	ISCO	UNTED SAV	INGS (2F5+	3C)				\$	10142.
	6.	DISCOUNTED (IF < 1 PROJE	SAV CT D	INGS RATIO OES NOT QU	JALIFY)	(5	SIR)=(5 / 1F)=	:	0.06		
	7.	SIMPLE PAYB	АСК	PERIOD (ES	TIMATED)	SPB=1	F/4	25	53.55		



о



CONSTRUCTION COST ESTIMATE			DATEPH	EPARED	4/2/90)	SHEET	OF 1
PROJECT USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER			BASIS FOR		L	1		
				x	CODE B	(NO DESIGN (PRELIMINAR	Y DESIGN	red) ∛)
CLARK RICHARDSON & BIS	KUP					(FINAL DESIG	GN)	
DRAWING NO. NONE		ESTIM	ATOR		011127	CHECKED B		
ECO-A7	QU	ANTITY	M	DLS ATERIAL	<u>т</u>	ABOR		DTAL
EXTERIOR WALL INSULATION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL		OST
BUILDING 472								
2-1/2" METAL STUDS	10382	SQ FT	0.30	3,115	0.45	4,672		\$7,7
2" ISOCYANURATE INSULATION	10382	SQ FT	1.00	10,382	0.30	3,115		\$13,4
5/8" FIRECODE GYP. BD.	10382	SQ FT	0.28	2,907	0.47			\$7,
VINYL BASE	10382	SQ FT	0.07	727	0.08	831		\$1,
PAINT	10382	SQ FT	0.22	2,284	0.48	4,983		\$7,2
6 MIL. VAPOR BARRIER	10382	SQ FT	0.03	311	0.07	727		\$1,0
SUBTOTAL				\$19,726		\$19,207		\$38,9
ONTINGENCY 10%	4		10%	\$1,973	10%	\$1,921		\$3,8
SUBTOTAL	<u> </u>			\$21,699		\$21,128		\$42,8
ORK COMP, TAX, SOC.SEC., INS	+		3.50%	\$759	13.0%	\$2,747		\$3,50
DIRECT COST	+			\$22,458		\$23,875		\$46,33
VERHEAD AND PROFIT			25%	\$5,614	25%	\$5,969		\$11,58
SUBTOTAL	++			\$28,072		\$29,844		\$57,91
CONSTRUCTION COST								\$57,91





CONSTRUCTION COST ESTIMATE			DATE PR	IEPARED	4/0/00		SHEET OF
PROJECT			I	BASIS FOR E	4/2/90		2 2
USDB ENERGY STUDY		·		x		NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODE B	(PRELIMINAR	Y DESIGN)
CLARK RICHARDSON & BIS	KUP				CODEC	(FINAL DESIG	iN)
DRAWING NO.		ESTIM	ATOR	1	Unich	CHECKED B	Y
ECO-A7		1 ANTITY	M	DLS		ABOR	TOL
EXTERIOR WALL INSULATION	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	TOTAL COST
BUILDING 475C							
METAL CLAD GYP. BD. AND TRACK	10529	SQ FT	4.60	48,433	1.00	10,529	\$58,96
2-1/2" THERMAL INSULATION	10529	SQ FT	0.25	2,632	0.10	1,053	\$3,68
6 MIL. VAPOR BARRIER	10529	SQ FT	0.03	316	0.07	737	\$1,05
CAULK	10529	SQ FT	0.06	632	0.14	1,474	\$2,10
MOBILIZATION	10529	SQ FT			0.30	3,159	\$3,15
2-1/2" METAL STUDS	11359	SQ FT	0.30	3,408	0.60	6,815	\$10,22
2-1/2" BATT INSULATION	11359	SQ FT	0.25	2,840	0.10	1,136	\$3,97
5/8" FIRECODE GYP. BD.	11359	SQ FT	0.28	3,181	0.57	6,475	\$9,65
CAULK	11359	SQ FT	0.06	682	0.14	1,590	\$2,27
PAINT	11359	SQ FT	0.22	2,499	0.48	5,452	\$7,95
6 MIL. VAPOR BARRIER	11359	SQ FT	0.03	341	0.07	795	\$1,136
MOBILIZATION	11359	SQ FT			0.30	3,408	\$3,408
	┽──┤			\$64,963		\$42,623	\$107,586
CONTINGENCY 10%	╉──╉		10%	\$6,496	10%	\$4,262	\$10,758
VORK COMP, TAX, SOC.SEC., INS	+			\$71,459		\$46,885	\$118,344
DIRECT COST	╉╼╍╌┼		3.50%	\$2,501	13.0%	\$6,095	\$8,596
DIRECT COST	┼──┼			\$73,960		\$52,980	\$126,940
SUBTOTAL	╉╼╼╼╉		25%	\$18,490	25%	\$13,245	\$31,735
	┼╴╸┥			\$92,450		\$66,225	\$158,675
NG. FORM 150 AVC-59	<u> </u>	L		l			\$158,675



s

A9

ARCHITECTURAL REPAIRS





ARCHITECTURAL REPAIRS - A9

PURPOSE:

The architectural repair section (A9) studied any repairs that might improve the energy efficiency of the buildings architecturally. Although these projects are small in nature, their completion may help the buildings save energy. The energy savings associated with these opportunities are difficult to calculate, therefore this section serves as recommended repairs.

SCOPE:

The architectural repairs encompassed many of the buildings and are as follows:

Building 463 Building 464 Building 465 Building 466 Building 472

Building 473 Building 475 Building 475A Building 475E

Repairs are located in different areas of each of the buildings.

SUMMARY:

To summarize, a listing of the various architectural repairs is listed and description of the repair. Following the list are cost estimates for each of the repairs.

- 1. In building 450 a condensate line is presently routed through the door on the first floor. The door is (108) as shown on the building plan in the field data for the building in Volume 4. The pipe needs to be re-routed through the masonry wall adjacent to the door. A hole will need to be drilled through the masonry and the piping installed through the wall. The estimated cost to complete this repair is \$424.
- 2. In building 464 a light fixture is located directly in the way of the attic access for the building. The light fixture can be relocated to the side of the access hole to the attic. This project needs to be completed before the attic insulation project could be implemented. The estimated cost to relocate the light is \$73.
- 3. The vestibule doors for the entrance of building 465 need to be relocated. One of the doors is located on the ground floor and needs to be moved back. The side light also needs to be moved back in conjunction with the door. The swing of the door needs to be reversed to the present swing to ensure correct people



movement. The other door that needs to be relocated is for the entrance to the first floor. To relocate the vestibule doors, the estimated cost is \$1,671.

- 4. On the third floor of building 466, the metal ceiling panels need to be repaired. The metal panels for the area need to be demolished and metal panels are available from another area to replace the ones removed. The estimated cost to repair the ceiling is \$582.
- 5. Building 472 needs to have an attic access in a classroom on the third floor and have door (106) on the first floor adjusted and a new lock installed. The location of the door can be seen in the field notes located under the building in Volume 4. The estimated cost for these items is \$1,219.
- 6. A door in building 473 needs to replaced with a new metal hollow core door. The door to be replaced is (106) as seen on the first floor plan located in the field notes, Volume 4. The replacement of this door has an estimated cost of \$2,132.
- 7. Several doors located in the rotunda (building 475) need to be replaced. The doors are seen on the building floor plans located in the field notes, Volume 4. The doors are (30A, 30C, 30E, and 30H). The estimated cost to replace these doors is \$13,727.
- 8. Adjacent to window (201) the masonry needs to be repaired in building 475A and the vestibule door (30B) needs to be moved back to ensure a proper flow of people. The locations of the above numbered window and door can be seen in the field notes for this building, Volume 4. The estimated cost for this work is \$1,221.
- 9. Building 475E has several plywood covered accesses that need to be replaced with a standard door. The plywood needs to be removed and a framed door installed. The estimated cost to repair the 15 places is \$50,302.

All of the above stated items have included in the estimated cost finishing of any walls, doors and frames with filling and painting to match the existing surrounding walls and doors.





and the second

CONSTRUCTION COST ESTIMATE			DAIEPF	REPARED	4/2/90)	SHEET OF	
PROJECT USDB ENERGY STUDY				BASIS FOR	ESTIMATE		<u></u>	
LOCATION				x	CODE A	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER			······		CODE B	(PRELIMINAR (FINAL DESIG	IY DESIGN)	
CLARK RICHARDSON & BI	SKUP	1			OTHER	(SPECIFY)		
NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL	
A9 ARCHITECTURAL REPAIRS		ANTITY		IATERIAL		ABOR	TOTAL	
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 463								
DEMOLITION	1	EA			20.00	20		-
DRILL 3/4" HOLE	5	HR	5.00	25				\$
CHECK SWING VALVE	1	EA	10.90		9.90			د.
3/4" COPPER PIPE	18	FT	1.90	34	3.00			
SEALANT	5	FT	0.60	3				
OBILIZATION	1	EA			15.00	15		
					10.00	1		-
			·					-
						i i		
								-
								-
								-
								_
			T					
		T						
	_							
								-
SUBTOTAL				\$73		\$206	\$	-
ONTINGENCY 10%			10%	\$7	10%	\$21		9
SUBTOTAL				\$80		\$227	\$	
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$3	13.0%	\$29		\$
DIRECT COST				\$83		\$256	\$	
/ERHEAD AND PROFIT	_		25%	\$21	25%	\$64		\$
SUBTOTAL				\$104		\$320	\$4	
CONSTRUCTION COST			l l					
NG. FORM 150 NC-59			L		l		\$4	4





PROJECT USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISKUP DRAWING NO. ASP QUANTITY ARCHITECTURAL REPAIRS QUANTITY NO. UNIT UNITS MEAS. BUILDING 464 IEA MOVE LIGHT FIXTURE 1 EA MOBILIZATION 1 EA IIII IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII			4/2/90 ESTIMATE		2		
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISKUP DRAWING NO. NONE A9 AP ARCHITECTURAL REPAIRS BUILDING 464 MOVE LIGHT FIXTURE 1 EA			BASIS FOR ESTIMATE				
CLARK RICHARDSON & BISKUP DRAWING NO. ESTIM/ NONE QUANTITY A9 QUANTITY ARCHITECTURAL REPAIRS NO. UNIT BUILDING 464 MOVE LIGHT FIXTURE 1 EA		X	CODE B	(NO DESIGN ((PRELIMINAR	COMPLETED)		
DRAWING NO. NONE A9 A9 ACHITECTURAL REPAIRS NO. UNIT UNITS MEAS. BUILDING 464 MOVE LIGHT FIXTURE 1 EA			CODEC	(FINAL DESIG SPECIFY)	iN)		
A9 ARCHITECTURAL REPAIRS BUILDING 464 MOVE LIGHT FIXTURE 1 EA	TOR			CHECKED BY			
UNITS MEAS. BUILDING 464 MOVE LIGHT FIXTURE 1 EA	М	DLS ATERIAL	T L	ABOR	TOL TOTAL		
MOVE LIGHT FIXTURE 1 EA	PER UNIT	TOTAL	PER UNIT	TOTAL	COST		
MOBILIZATION 1 EA			31.00	31	\$		
			15.00	15			
				•			
Image: Sector of the sector							
					· · · · · · · · · · · · · · · · · · ·		
SUBTOTAL CONTINGENCY 10%				\$46	\$2		
SUBTOTAL	10%		10%	\$5			
WORK COMP, TAX, SOC.SEC., INS	3.50%		40.00	\$51			
DIRECT COST	3.50%		13.0%	\$7	\$		
OVERHEAD AND PROFIT	25%		25%	\$58 \$15	\$5		
SUBTOTAL				\$73	\$1 \$7		
CONSTRUCTION COST					\$7		

		1		4/2/90	1	
PROJECT USDB ENERGY STUDY			BASIS FOR			3
			- v		(NO DESIGN	
				CODE B	(PRELIMINAR	Y DESIGN)
KUP					(FINAL DESIG	iN)
	ESTIM	ATOR		UTILA	CHECKED B	Y
	ANTITY	M		,		TOL TOTAL
NO.	UNIT	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
_						
1	EA			150.00	150	\$1
1	EA			200.00	200	\$2
17	FT	1.40	24	2.60	44	\$
1	EA	40.00	40	10.00	10	\$
<u> </u>	EA			50.00		\$
-						
1	EA			150.00	150	\$15
1	EA			200.00		\$20
17	FT	1.40	24	2.60	44	\$6
1	EA	40.00	40	10.00	10	\$5
1	EA			50.00	50	\$5
1	EA			50.00	50	\$5
						· · · · · · · · · · · · · · · · · · ·
					· · · · ·	
						\$1,08
	†	10%		10%	\$96	\$10
		3 50%		12.0%		\$1,19
		5.50%		13.0%		\$14:
		25%		25%		\$1,33
				20 /6		\$334
			\			\$1,67
	NO. UNITS	ESTIM QUANTITY NO. UNIT UNITS MEAS. 1 EA 1 EA 1 EA 1 EA 1 EA 1 EA 1 EA 1 EA	ESTIMATOR QUANTITY N NO. UNIT PER UNITS MEAS. UNIT 1 EA 1 1 EA 40.00 1 EA 1 1 EA 40.00 1 EA 40.00	ESTIMATOR DLS QUANTITY MATERIAL NO. UNIT MEAS. UNIT I EA 1 EA 1	CODE B CODE C ESTIMATOR DLS QUANTITY MATERIAL I NO. UNIT PER TOTAL PER UNITS MEAS. UNIT PILS UNIT I EA UNIT PER UNIT I EA 150.00 1 EA 200.00 1 EA 40.00 40 10.00 1 EA 40.00 40 10.00 1 EA 50.00 1 EA 200.00 1 EA 40.00 40 10.00 1 EA 40.00 40 10.00 1 EA 50.00 1 EA 50.00 1 EA 40.00 40 10.00 10.00 1 EA 50.00 1 EA 50.00 1 EA 50.00 1 EA 50.00 1 EA 50.00	CODE B (PRELIMINAR CODE C KUP OTHER CODE C QUANTITY MATERIAL LABOR NO. UNIT PER TOTAL UNITS MEAS. UNIT TOTAL IEA 150.00 150 1 EA 200.00 200 1 EA 50.00 50 1 EA 150.00 150 1 EA 200.00 200 1 EA 50.00 50 1 EA 50.00 50 1 EA 50.00 50 1 EA 50.00 50 1 EA



A9

PROJECT			L		4/2/90		SHEET	OF
USDB ENERGY STUDY				BASIS FOR	ESTIMATE			
FORT LEAVENWORTH, KS				X	CODE B	(NO DESIGN (PRELIMINAR	Y DESIGN)))
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	D				_CODE C	(FINAL DESIG	N)	
DRAWING NO.	<u> </u>	ESTIM	ATOR	L	OTHER	SPECIFY)	Y	
A9		ANTITY		DLS IATERIAL	 -7		TOL	
ARCHITECTURAL REPAIRS	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	ABOR TOTAL	TOT	
BUILDING 466								
REPAIR DAMAGED METAL CEILING PANELS								
DEMOLITION	75	SQ FT			1.00	76		
INSTALL METAL PANELS TAKEN FROM OTHER LOCATIONS		SQ FT			2.00			\$ \$1
PAINT	200	SQ FT	0.10	20				<u> </u>
MOBILIZATION	1	EA			50.00			\$
								X
SUBTOTAL								
ONTINGENCY 10%			100	\$20		\$355		\$37
SUBTOTAL			10%	\$2	10%	\$36		\$3
ORK COMP, TAX, SOC.SEC., INS			3.50%	<u>\$22</u> \$1	13.0%	\$391		\$41
DIRECT COST			0.0070	\$23	10.0%	\$51 \$442		\$5
VERHEAD AND PROFIT			25%	\$6	25%	\$111		\$46 \$11
SUBTOTAL				\$29		\$553		<u>\$11</u> \$58
CONSTRUCTION COST								
NG. FORM 150 NC-59						<u>l</u>		<u>\$58</u>



Ì

CONSTRUCTION COST ESTIMATE DA			DATE PR	EPARED)	SHEET OF		
PROJECT	· · · · · · · · · · ·			BASIS FOR E	4/2/90		5	
USDB ENERGY STUDY				x	CODE A	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODE B	(PRELIMINAR	Y DESIGN)	
CLARK RICHARDSON & BIS					OTHER	(FINAL DESIG		
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL	
A9 ARCHITECTURAL REPAIRS	QU, NO,	ANTITY	M PER	ATERIAL		ABOR	TOTAL	
		MEAS.		TOTAL	PER UNIT	TOTAL	COST	
BUILDING 472								
INSTALL ACCESS HOLE								
DEMOLITION	1	EA	-		125.00	125	\$	
ACCESS FRAME AND COVER	1	EA	419.00	419			\$4	
PAINT	1	EA	5.00	5	15.00		¥	
MOBILIZATION	1	EA			75.00	75		
······································								
REPAIRS TO DOOR (106)								
REPLACE LOCK	1	EA	102.00	102	20.00	20	\$1	
ADJUST DOOR	1	EA			20.00	20	9	
MOBILIZATION	1	EA			25.00	25	9	
· · · · · · · · · · · · · · · · · · ·	_							
SUBTOTAL				\$526		\$303	\$8	
CONTINGENCY 10%			10%	\$53	10%	\$30	\$	
SUBTOTAL				\$579		\$333	\$9	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$20	13.0%	\$43	\$	
DIRECT COST				\$599		\$376	\$97	
VERHEAD AND PROFIT	_		25%	\$150	25%	\$94	\$24	
SUBTOTAL				\$749		\$470	\$1,21	
CONSTRUCTION COST							\$1,21	



Α9



CONSTRUCTION COST ESTIMATE			DATE PF	REPARED	4/2/90	·	SHEET OF
PROJECT	PROJECT USDB ENERGY STUDY			BASIS FOR			6
				x			COMPLETED)
FORT LEAVENWORTH, KS				<u> </u>	CODE B	(PRELIMINAR	Y DESIGN)
CLARK RICHARDSON & BISI	KUP					(FINAL DESIG	iN)
DRAWING NO.		ESTIM	ATOR	1	UTHEN	CHECKED B	Y
A9 NONE		ANTITY		DLS			TOL
ARCHITECTURAL REPAIRS	NO.	UNIT MEAS.	PER UNIT	ATERIAL TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
BUILDING 473 INSTALL NEW HALLOW METAL DOOR IN (106)							
REMOVE DOOR/FRAME	1	EA			100.00	100	\$1
NEW DOOR/FRAME	1	EA	420.00	420	80.00	80	\$5
FINISH HARDWARE	1	EA	510.00	510	90.00	90	\$6
PAINT	11	EA	5.00	5	35.00	35	
SEALANT/CAULK	36	FT	0.60	22	1.40	50	
OBILIZATION	1	EA			140.00	140	\$1
·							
						-	
							<u></u>
							·
SUBTOTAL				\$957		\$495	\$1,4
ONTINGENCY 10%			10%	\$96	10%	\$50	\$1
SUBTOTAL				\$1,053		\$545	\$1,5
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$37	13.0%	\$71	\$1
DIRECT COST	<u> </u>			\$1,090		\$616	\$1,7
VERHEAD AND PROFIT	$\left \right $		25%	\$272	25%	\$154	\$4
SUBTOTAL				\$1,362		\$770	\$2,1
CONSTRUCTION COST				1			\$2,13



CONSTRUCTION COST ESTIMATE			DATE PR	EPARED	4/2/90		SHEET OF
PROJECT USDB ENERGY STUDY			L	BASIS FOR E			7
LOCATION FORT LEAVENWORTH, KS			<u></u>	x		(NO DESIGN	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL	IP				CODEC	(PRELIMINAR (FINAL DESIG (SPECIFY)	Y DESIGN) iN)
DRAWING NO. NONE		ESTIM	ATOR	DLS	UTHEN	CHECKED BY	
A9	QU.	ANTITY	M	ATERIAL	1	ABOR	TOL TOTAL
ARCHITECTURAL REPAIRS	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475 INSTALL NEW HALLOW METAL DOORS IN (30A, 300, 30E, AND 30H)							
REMOVE DOOR/FRAME	4	EA			200.00	800	\$
NEW DOOR/FRAME	4	EA	840.00	3,360	160.00	640	\$4,
FINISH DOOR	4	EA	680.00	2,720	120.00	480	\$3,
PAINT	4	EA	20.00		80.00	320	\$
SEALANT/CAULK	160	FT	0.60	96	1.40	224	\$
MOBILIZATION	4	EA			160.00	640	\$
							· · · · · · · · · · · · · · · · · · ·
SUBTOTAL				\$6,256		\$3,104	\$9,3
ONTINGENCY 10%			10%	\$626	10%	\$310	\$9
SUBTOTAL				\$6,882		\$3,414	\$10,2
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$241	13.0%	\$444	\$6
DIRECT COST				\$7,123		\$3,858	\$10,9
VERHEAD AND PROFIT			25%	\$1,781	25%	\$965	\$2,7
SUBTOTAL				\$8,904		\$4,823	\$13,7
CONSTRUCTION COST							\$13,7



CONSTRUCTION COST ESTIMATE			DATE PF	REPARED	4/2/90	.	SHEET OF 8
PROJECT USDB ENERGY STUDY			.	BASIS FOR			18
LOCATION				X	CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER	······	· · · · · ·			_CODE B	(PRELIMINAF	Y DESIGN
CLARK RICHARDSON & BIS	KUP				OTHER	(FINAL DESIG	áN)
DRAWING NO. NONE		ESTIM	ATOR	DLS		CHECKED B	Y TOL
A9 ARCHITECTURAL REPAIRS		ANTITY		ATERIAL		ABOR	TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475A							
REPAIR MASONRY WALL AT WINDOW (201)							
	20	SQ FT			1.50	30	9
TOOTH-IN NEW BRICK		SQ FT	2.09	63	3.67	110	\$1
MOBILIZATION	1	EA			75.00		Ŷ
MOVE VESTIBULE DOOR (30B) AND SIDE LIGHTS BACK							
DEMOLITION	1	EA			150.00	150	\$1
INSTALLATION	1	EA			200.00	200	\$2
WEATHERSTRIP DOOR	17	FT	1.40	24	2.60	44	\$
NSTALL THRESHOLD	1	EA	40.00	40	10.00	10	
MOBILIZATION	1	EA			50.00	50	
							· · · · · · · · · · · · · · · · · · ·
SUBTOTAL				\$127		\$669	\$79
ONTINGENCY 10%			10%	\$13	10%	\$67	\$
SUBTOTAL	┦──┤			\$140		\$736	\$87
ORK COMP, TAX, SOC.SEC., INS	<u> </u>		3.50%	\$5	13.0%	\$96	\$10
DIRECT COST				\$145		\$832	\$97
VERHEAD AND PROFIT	+		25%	\$36	25%	\$208	\$24
SUBTOTAL				\$181		\$1,040	\$1,22
CONSTRUCTION COST					T		\$1,22

PREVIOUS EDITION MAY BE USED

ł

(

CONSTRUCTION COST ESTIMATE			DATE PR	EPARED	4/2/90		SHEET OF
PROJECT			1	BASIS FOR			9
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS		<u>.</u>		x		(NO DESIGN (PRELIMINAR	
ARCHITECT/ENGINEER CLARK RICHARDSON & BIS	מווא				CODE C	(FINAL DESIG	SN)
DRAWING NO. NONE		ESTIM	ATOR	L	UTHER	SPECIFY)	-
A9			M	DLS IATERIAL	<u> </u>	ABOR	TOL TOTAL
ARCHITECTURAL REPAIRS	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 475E							
REPLACE PLYWOOD WITH WORKING DOORS							
REMOVE DOOR/FRAME	15	EA			150.00	2,250	\$2,2
NEW DOOR/FRAME	15	EA	840.00	12,600	160.00	2,400	\$15,0
FINISH HARDWARE	15	EA	680.00	10,200	120.00	1,800	\$12,0
PAINT	15	EA	20.00	300	80.00	1,200	\$1,5
8" LIGHTWEIGHT C.M.U.	40	SQ FT	1.60	64	2.20		\$1
SEALANT/CAULK	600	FT	0.60	360	1.40	840	\$1,2
MOBILIZATION	15	EA			150.00	2,250	\$2,2
	_						
······································	_						
							-
	_						
SUBTOTAL				\$23,524		\$10,828	\$34,35
CONTINGENCY 10%			10%	\$2,352	10%	\$1,083	\$3,43
SUBTOTAL	╉╾╌╌┨			\$25,876		\$11,911	\$37,78
VORK COMP, TAX, SOC. SEC., INS			3.50%	\$906	13.0%	\$1,548	\$2,45
DIRECT COST				\$26,782		\$13,459	\$40,24
VERHEAD AND PROFIT			25%	\$6,696	25%	\$3,365	\$10,06
SUBTOTAL	+	—		\$33,478		\$16,824	\$50,30
CONSTRUCTION COST							\$50,30

ī,



ECO-M1

SCHEDULE AIR HANDLING EQUIPMENT







SCHEDULE AIR HANDLING EQUIPMENT

ENERGY CONSERVATION OPPORTUNITY: ECO-M1

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M1) analyzes the energy savings associated with controlling HVAC systems using Night Setback. Energy saving can be accomplished by turning down AHU's during times when spaces are unoccupied.

SCOPE:

The ECO simulation (ECO-M1) includes expanding the existing EMS system located at the USDB. Three AHU's in building 465 and eleven units located in building 464 can be added to the EMS network. This will allow these AHU's to be set back when they are not needed. Buildings 450, 463, and 473 are already controlled by the EMS system and take advantage of Night Setback. The Chilled Water and Heating Hot Water Pumps that serve buildings 463, 472 and parts of 464 and 473 are not on the EMS system and continue to run at night even though the air handlers are turned off. These pumps will show an energy savings when added to the EMS system. Buildings such as the Castle, 466, and floors 2 and 3 of 465 are domiciles and require space conditioning 24 hours a day. The air handler in the print room in building 472 is used for dehumidification and must run continuously. Therefore buildings 466, 472 and 475 A-H are not included as part of this ECO.

MODELING TECHNIQUES:

The modeling techniques used to calculate the energy saving associated with implementation of this ECO were completed using the Trace Ultra computer simulation models developed as a base load on the facility. The existing HVAC systems were scheduled to run constantly throughout the heating and cooling seasons. Then an alternative run was done scheduling the air handlers to be shut off or turned down at times when heating or cooling were not required. The difference in the energy usage for these two computer runs is the energy saving from ECO-M1. Hand calculation were done to calculate the energy saving obtained when adding the pumps in buildings The cost of implementing this ECO was calculated using an electronic spreadsheet .



ECO IMPLEMENTATION:

The Air Handling Unit in building 464 and 465 have the capability of connecting to the existing EMS system located on the USDB. These unit will require new relays located at the units and control wiring to connect them to the EMS system. The Chilled Water and Heating Hot Water pumps serving buildings 463, 472 and parts of 464 and 473 can be connected to the existing relays which control the air handlers already in these buildings.

SUMMARY:

The project cost to implement this ECO shown Table M1-1are construction costs +6% SIOH.


The energy savings associated with the implementation of this ECO by building is shown below in Table M1-1. A dollars per year savings as determined using the computer simulation model along with hand calculation for pump energy savings.





Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
463	10	\$127	\$491	3.76 🔨	2.31
464	45	\$396	\$9,255	21.85	.42
465	280 🗡	\$891	\$9,972	10.57 🗸	1.03
472	20	\$248	\$5,932	22.5	.39

Table M1-1










BUILDING 463 FIRST FLOOR






PAGE M1-5

ECO-M1




BUILDING 464 THIRD FLOOR





ECO-M1

PAGE M1-6



PAGE M1-7

ECO-M1

	PF FI	ENER STALLATION 8 ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	rgy Lo Titi 90	.E: 1496 DIS	FION INVES RT LEAVEN SCRETE PO	TMENT I WORTH RTION N	PROGRAM (I	GION NOS			JDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
	1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV		r DIT CALC (1, .UE COST	-	9				0000000000000000000000000000000000000	464. 28. 26. 466. 0. 466.
	2.	ENERGY SAV ANALYSIS DA		S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST &		ED SAVING	S		
		FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		ANNUAL \$ SAVINGS(3)	DISCO FACTO			SCOUNTED
		A. ELECT B. DIST C. RESID D. NAT G E. COAL	****	12.44 .00 .00 4.08 .00	10. 0. 0. 0.	\$ \$ \$ \$ \$	124. 0. 0. 0. 0.	12 12 11	8.69 2.42 2.21 1.67 0.36		1078. 0. 0. 0. 0.
		F. TOTAL			10.	\$	124.			\$	1078.
	3.	NON ENERGY	' SA	VINGS(+) / CO	OST(-)						
		A. ANNUAL R (1) DISCO		JRRING (+/-) FACTOR (TA			9.11			\$	0.
		(2) DISCO	UNT	ED SAVING/	COST (3A X	(3A1)	9.11			\$	0.
		C. TOTAL NO	N EI	NERGY DISC	OUNTED SA	VINGS(+) /COST(-) ((3A2+3Bd4)		\$	0.
		A IF 3D B IF 3D C IF 3D	AX N 1 IS 1 IS 1 IS 01B	I ENERGY QU ION ENERGY = OR > 3C GG < 3C CALC IS = > 1 GO T S < 1 PROJEC	' CALC (2F5 O TO ITEM 4 SIR = (2F5⊣ O ITEM 4	X .33) 4 ⊦3D1)/1F)=	\$3			
	4.	FIRST YEAR D	OLL	AR SAVINGS	3 2F3+3A+(3	B1D/(YE	ARS ECONC	MIC LIFE))		\$	124.
	5.	TOTAL NET DI	sco	OUNTED SAV	INGS (2F5+	3C)				\$	1078.
ł	6.	DISCOUNTED (IF < 1 PROJEC	SA\ CT E	INGS RATIO	JALIFY)	(\$	SIR)=(5 / 1F)=	= 2	.31		
	7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1	F/4	3	.76		



P Fl	ENERC ISTALLATION & I ROJECT NO. & T ISCAL YEAR 1990 NALYSIS DATE:	TITLE: 1496 90 · DIS	TION INVES RT LEAVEN SCRETE POI	TMENT PRO WORTH - U	DGRAM (EC JSDB REG E: ECOM1	ION NOS. 7		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1.	E. SALVAGE V	CTION COST OST CREDIT CALC (1		9			\$ \$ \$ \$ \$ \$ \$	8731. 524. 480. 8762. 0. 8762.
2.	ENERGY SAVII ANALYSIS DAT	INGS (+) / COST TE ANNUAL SA\	'(-) /INGS, UNIT	COST & DR	SCOUNTER) SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(NUAL \$ /INGS(3)	DISCOUNT FACTOR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	26. 0. 0. 19. 0.	\$ \$ \$ \$ \$ \$ \$	323. 0. 0. 78. 0.	8.69 12.42 12.21 11.67 10.36		2807. 0. 0. 910. 0.
	F. TOTAL		45.	\$	401.		\$	3717.
3.	NON ENERGY	SAVINGS(+) / C	OST(-)					
	(1) DISCOU	ECURRING (+/-) UNT FACTOR (T/	ABLE A)		9.11		\$	0.
	(2) DISCOU	UNTED SAVING	COST (3A X	3A1)			\$	0.
	C. TOTAL NON	N ENERGY DISC	OUNTED SA	VINGS(+) /	COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% MAX A IF 3D1 B IF 3D1 C IF 3D1	NON ENERGY Q XX NON ENERGY 1 IS = OR > 3C G 1 IS < 3C CALC 11B IS = > 1 GO T 1B IS < 1 PROJE	Y CALC (2F5 iO TO ITEM 4 SIR = (2F5+ IO ITEM 4	X .33) 4 -3D1)/1F)=		\$		
4.	FIRST YEAR DO	OLLAR SAVING	S 2F3+3A+(3	B1D/(YEAR	S ECONON	(IC LIFE))	\$	401.
5.	TOTAL NET DIS	SCOUNTED SAV	/INGS (2F5+:	3C)			\$	3717.
6.	DISCOUNTED S (IF < 1 PROJEC	SAVINGS RATIC CT DOES NOT Q		(SIR)=(5 / 1F)=	0.42		
7.	SIMPLE PAYBA	ACK PERIOD (ES	STIMATED)	SPB=1F/4		21.85		



۲ F	ENEF ISTALLATION & ROJECT NO. & ISCAL YEAR 199 NALYSIS DATE:	IGY C LOCA TITLE 90	ONSERVAT ATION: FOI : 1496 DIS	RT LEAVEN	STMENT I IWORTH	PROGRAM (EGION NOS		LC	7: USDBAE CID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	CTION OST CREDI VALU	T CALC(1) E COST		.9				\$	9408. 564. 517. 9440. 0. 9440.
2.	ENERGY SAV ANALYSIS DA	INGS	(+) / COST INUAL SAV	(-) INGS, UNIT	COST 8		ED SAVING	S	•	
	FUEL		NIT COST MBTU(1)	SAVINGS MBTU/YR	-	ANNUAL \$ SAVINGS(3)	DISCOU FACTO			COUNTED 'INGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	19. 0. 0. 161. 0.	\$ \$	236. 0. 0. 657. 0.	12 12 11	3.69 2.42 2.21 1.67 0.36		2051. 0. 0. 7667. 0.
	F. TOTAL			180.	\$	893.			\$	9718.
3.	NON ENERGY	SAVI	NGS(+) / C(OST(-)						
	A. ANNUAL RI (1) DISCOU	JNT F.	ACTOR (TA	BLE A)	.	9.11			\$	0.
	(2) DISCOU								\$	0.
	B IF 3D1 C IF 3D	NON E XX NO I IS = 1 I IS < 1 I IS < 1 I B IS	ENERGY QU N ENERGY OR > 3C GO 3C CALC = > 1 GO TO	JALIFICATIO CALC (2F5 D TO ITEM 4 SIR = (2F54	ON TEST 5 X .33) 4 +3D1)/1F;)=		07.	\$	0.
4.	FIRST YEAR D	OLLAI	R SAVINGS	2F3+3A+(3	B1D/(YE	ARS ECONC	MIC LIFE))		\$	893.
	TOTAL NET DI						.,		\$	9718.
6.	DISCOUNTED : (IF < 1 PROJEC	SAVIN T DO	IGS RATIO ES NOT QL	IALIFY)	(\$	SIR)=(5 / 1F):	= 1.	.03		
7.	SIMPLE PAYBA		ERIOD (EST	FIMATED)	SPB=1	=/4	10.	57		



1

	ENE INSTALLATION PROJECT NO. & FISCAL YEAR 1 ANALYSIS DAT	=HG & LC & TIT 990	LE. 1496	TION INVE RT LEAVE SCRETE P	STME NWOI	ent f rth on n		NOS. 7		JDY: USDBAE LCCID 1.035 CENSUS: 2
	E. SALVAGE	UCT COS CRE E VA	T EDIT CALC (1		X.9				\$ \$ \$ \$ \$	5596. 336. 308. 5616. 0. 5616.
2	2. ENERGY SA ANALYSIS D		SS (+) / COST ANNUAL SAV	(-) 'INGS, UNI	TCOS	ST &	DISCOUNTE) SAVINGS	·	
	FUEL		UNIT COST \$/MBTU(1)	SAVING: MBTU/YI			NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)	D S	ISCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	20 0. 0. 0. 0.	•	\$ \$ \$ \$ \$	249. 0. 0. 0. 0.	8.69 12.42 12.21 11.67 10.36		2164. 0. 0. 0. 0.
	F. TOTAL			20.		\$	249.		\$	0. 2164.
3.	NON ENERG	Y SA	VINGS(+) / CC	DST(-)						
	A. ANNUAL F (1) DISCO (2) DISCO	DUNT	JRRING (+/-) FACTOR (TA ED SAVING/C	BLE A) OST (3A)	X 3A1	1)	9.11		\$	0.
	C. TOTAL NO						COST(-) (34	2.3044)	\$	0.
	D. PROJECT (1) 25% M. A IF 3D B IF 3D C IF 3D	NON AX N 11 IS 11 IS 01 IS		ALIFICATION CALC (2F5) TO ITEM SIR = (2F5) D ITEM 4	ON TE 5 X .3 4 +3D1)/	EST 33) /1F)=	\$		\$	0.
4.	FIRST YEAR D							C LIFE))	\$	249.
								//	\$	249. 2164.
6.	DISCOUNTED (IF < 1 PROJEC	SAV CT D	INGS RATIO OES NOT QU	ALIFY)		(SI	R)=(5 / 1F)=	0.39	-	
7.	SIMPLE PAYBA	ACK	PERIOD (EST	IMATED)	SPB	=1F/	4	22.55		



PAGE M1-11

CONSTRUCTION COST ESTIMA	AIE		DATE PR	EPARED	4/2/90	`	SHEET OF	
PROJECT USDB ENERGY STUDY		**************************************	·····	BASIS FOR			11	
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				X CODE A (NO DESIGN COMPLETED) CODE B (PRELIMINARY DESIGN)				
CLARK RICHARDSON & BISKL	IP				CODEC	(FINAL DESIG	iN)	
DRAWING NO.		ESTIM	ATOR	I	UTTER	CHECKED B	Y	
NONE				MJM		<u>i .</u>	MAW	
ECO-M1	NO.	UNIT	PER	ATERIAL TOTAL	PER	ABOR TOTAL	TOTAL	
		MEAS.	UNIT	TOTAL	UNIT	IUTAL	COST	
BUILDING 463 FIRST FLOOR START/STOP THE HOT/CHILLED								
WATER PUMP								
WIRE FROM EXISTING CONTROL PANEL								
18 GA. TWISTED PAIR WIRE	85	FT	0.10	\$9	0.31	\$26		
1/2" CONDUIT	85	FT	0.77	\$65	1.95		\$	
EQUIPMENT MOUNTED CONTROL RELAY	4	EA	10.00					
LOS MELLAY		<u>=A</u>	18.00	\$18	22.00	\$22		
				-				
· · · · · · · · · · · · · · · · · · ·								
							- <u>1</u>	
SUBTOTAL								
ONTINGENCY 10%			10%	\$92	1.00/	\$214	\$3	
SUBTOTAL			10%	\$9 \$101	10%	\$21	\$	
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$4	12.00/	\$235	\$3	
DIRECT COST			0.00 /0	\$105	13.0%	\$31	\$	
VERHEAD AND PROFIT			25%	\$26	25%	\$266	\$3	
SUBTOTAL				\$20 \$131	20%	\$67	\$!	
CONSTRUCTION COST				 		\$333	\$46	
IG. FORM 150	L		l				\$46	



					4/2/90		
PROJECT USDB ENERGY STUDY	BASIS FOR			2			
FORT LEAVENWORTH, KS	×	CODE B	(NO DESIGN (PRELIMINAF				
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL	1D				CODEC	(FINAL DESIG	aN)
DRAWING NO.				OTHER (SPECI			v
NONE				MJM IATERIAL	1		MAW
	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
BUILDING 464 THIRD FLOOR START/STOP THE FAN COIL UNITS							
EXTEND TRUNK TO NEW CONTROL PANEL							
CONTROL PANEL (JOHNSON FPU)	1	EA	3280.00	\$3,280	450.00	\$450	\$3,7
18 GA. TWISTED PAIR WIRE	570	FT	0.10	\$57	0.31	\$177	\$2
1/2" CONDUIT	570	FT	0.77	\$439	1.95	\$1,112	\$1,5
EQUIPMENT MOUNTED CONTROL RELAY	11	EA	18.00	\$198	22.00		\$4
SUBTOTAL				\$3,974		\$1,980	
ONTINGENCY 10%			10%	\$397	100/		\$5,9
SUBTOTAL					10%	\$198	\$5
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$4,371		\$2,178	\$6,54
DIRECT COST			3.30%	\$153	13.0%	\$283	\$4:
			25%	\$4,524		\$2,461	\$6,98
SUBTOTAL			23%	\$1,131	25%	\$615	\$1,74
CONSTRUCTION COST				\$5,655		\$3,076	\$8,73
NG. FORM 150	L	L	<u>l</u>				\$8,73



CONSTRUCTION COST ESTIMATE					SHEET OF		
USDB ENERGY STUDY		BASIS FOR E	STIMATE				
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER	CODE B (PRELIN			SIGN COMPLETED) /INARY DESIGN)			
CLARK RICHARDSON & BISKU			(FINAL DESIG	SN)			
DRAWING NO.			ATOR	ł	OTTIEN	CHECKED B	Y
NONE			M	MJM ATERIAL			MAW
ECO-M1	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
BUILDING 465 START/STOP THE FAN COIL UNITS							
START/STOP HOT/CHILLED WATER PUMP EXTEND TRUNK TO NEW CONTROL PANEL							
CONTROL PANEL (JOHNSON FPU)	1	EA	2380.00	\$2,380	450.00	\$450	\$2,
18 GA. TWISTED PAIR WIRE	1070	FT	0.10	\$107	0.31	\$332	\$
1/2" CONDUIT	1070	FT	0.77	\$824	1.95	\$2,087	\$2,
EQUIPMENT MOUNTED RELAY	4	EA	18.00	\$72	22.00	\$88	\$
SUBTOTAL				\$3,383		\$2,956	\$6,3
ONTINGENCY 10%			10%	\$338	10%	\$296	\$6
SUBTOTAL				\$3,721		\$3,252	\$6,9
/ORK COMP,TAX,SOC.SEC.,INS			3.50%	\$130	13.0%	\$423	\$5
DIRECT COST				\$3,851		\$3,675	\$7,5
VERHEAD AND PROFIT			25%	\$963	25%	\$919	\$1,8
SUBTOTAL				\$4,814		\$4,594	\$9,4
CONSTRUCTION COST							\$9,40



CONSTRUCTION COST ESTIMA	TE		DATE PR	EPARED	4/2/90)	SHEET OF
PROJECT USDB ENERGY STUDY		BASIS FOR			4		
FORT LEAVENWORTH, KS		CODE A (NO DESIGN COMP CODE B (PRELIMINARY DES			IY DESIGN)		
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL	CODE C (FINAL DESIGN)						
DRAWING NO.	ATOR		OTHER	SPECIFY)	v		
NONE	1 011		r	MJM	·····		MAW
ECO-M1	NO.	ANTITY UNIT		ATERIAL TOTAL	PER	ABOR	TOTAL
		MEAS.	UNIT	TOTAL		TOTAL	COST
BUILDING 472 BASEMENT START/STOP THE HOT WATER	[
RADIANT HEAT PUMP							
EXTEND TRUNK TO NEW CONTROL PANEL							
CONTROL PANEL (JOHNSON FPU)	1	EA	1930.00	\$1,930	450.00	\$450	\$2,3
18 GA. TWISTED PAIR WIRE	· 440	FT	0.10	\$44	0.31	\$136	\$1
1/2" CONDUIT	440	FT	0.77	\$339	1.95		\$1,1
EQUIPMENT MOUNTED CONTROL RELAY	1	EA	18.00	\$18	22.00		\$
							¥
							······
					·		
SUBTOTAL				\$2,331		\$1,466	\$3,79
ONTINGENCY 10%			10%	\$233	10%	\$147	\$38
SUBTOTAL				\$2,564		\$1,613	\$4,17
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$90	13.0%	\$210	\$30
DIRECT COST				\$2,654		\$1,823	\$4,47
VERHEAD AND PROFIT			25%	\$663	25%	\$456	\$4,47 \$1,11
SUBTOTAL				\$3,317		\$2,279	\$5,59
CONSTRUCTION COST							
G. FORM 150 VC-59		••••••••••••••••••••••••••••••••••••••	····	I_	I	<u>t</u>	\$5,59



ECO-M1

SCHEDULE AIR HANDLING EQUIPMENT

BUILDING 463

ECO-M1 ECONOMIC ANALYSIS

	STEAM CONS	SUMPTION		ELECTRIC (
BUILDING NUMBER	BASE ENERGY (THERMS)	ECO-M1 LOAD (THERMS)	ENERGY SAVINGS (MBTU)	BASE LOAD (KW)	ECO-M1 LOAD (KW)	ENERGY SAVINGS (MBTU)	TOTAL SAVINGS (\$)
463	1,577	1,577	0	83,903	82,711	4	\$51
464	2,195	2,006	19	91,802	84,278	26	\$396
465	35,995	34,388	161	231,123	225,586	19	\$891
			•	····			\$1,338

3

	CALCULATION SHEET	DATE	SHEET OF			
		Oct-90				
PROJECT	USDB ENERGY SAVINGS OPPORTUNITY SURVEY	BASIS FOR CALCU	JLATION			
LOCATION		COMPUTER				
ARCHITECT/	ENGINEER	CONTRACTOR BID				
	CLARK RICHARDSON & BISKUP	OTHER (SPECIFY)				
ECO MEASU		COMPUTED BY	CHECKED BY			
	ECO-M1	RGB	MAW			

HAND CALCULATION OF ENERGY SAVINGS ASSOCIATED WITH NIGHT SHUT DOWN OF CHILLED WATER PUMPS

BUILDING 463

3 HP. MOTOR 1 HP = 74,600 WATTS PER HOUR ESTIMATED PUMP SAVINGS % BASED ON COMPUTER SIMULATIONS OF BUILDINGS 465 AND 464

ENERGY = HP X 74,600 WATTS/HR X 12 HR

BUILDING	PUMP	ENERGY	SAVINGS	SAVINGS	SAVINGS	SAVINGS
NUMBER	TYPE	KW / YR	%	KW / YR	MBTU / YR	\$ / YR
463	CHILLER	3612	0.33	1192	4.07	\$51

ECO-M2

DRY-BULB ECONOMIZER CONTROLS

DRY-BULB ECONOMIZER CONTROLS ENERGY CONSERVATION OPPORTUNITY: ECO-M2

PURPOSE:

This Energy Conservation Opportunity (ECO-M2) analyzes the energy savings associated with repairing and maintaining existing dry bulb economizer systems. Energy savings can be accomplished by turning off or cycling refrigeration systems and using outside air as a cooling source when outdoor temperatures are at or below 68° F. This outdoor air is then mixed with room air and cooled, if necessary, to obtain the design supply air temperature. These systems monitor and respond to dry bulb temperatures only. The implementation of this project will not include the addition of any new economizer units because all building systems compatible with air side economizers currently have that equipment installed.

SCOPE:

The ECO simulation (ECO-M2) includes the reconnecting of the economizer linkage and the replacement of controls for the existing dry bulb economizers. The application of this project was considered for 6 air handling units: building 463 (second and third floors), building 464 (first and second floors) and building 473 (second and third floors). Building 450 was not considered because it already has an operable dry bulb economizer system. The rest of the buildings have operable windows and their HVAC systems are not compatible with dry bulb economizers.

MODELING TECHNIQUES:

The modeling techniques used to calculate the energy savings associated with implementation of this ECO were completed using the "Trace" computer simulation. The existing HVAC system was set up without a dry bulb economizer. The computer model was then run with the economizer activated at or below 68° F, during the cooling season only, and a new energy usage was found. The difference in energy usage from the two computer runs is the energy savings that can be obtained by implementing ECO-M2.

ECO IMPLEMENTATION:

The Air Handling Units in buildings 463, 464 and 473 have existing dry bulb economizer capabilities. The controls to these systems are inoperable and the linkages have been disconnected. In order to implement this ECO, the old controls must be removed and replaced and linkages must be reconnected. Also, the return and outside air dampers on the air handling unit in building 463, third floor, need to be replaced.





A means of air relief may also need to be provided. Possible choices are partially open windows, exhaust dampers or exhaust fans. For this ECO simulation, it is assumed that the excess air can escape the buildings.

SUMMARY:

The project cost, energy savings, simple payback, and savings to investment ratio (S.I.R.) for implementation of this ECO by building is shown in Table M2-1. This project cost is the construction cost as determined on the Cost Estimate Form plus 6% SIOH.

Building Number	Electric Energy Savings (MBTU/yr.)	Cost Savings	Project Cost	Simple Payback	S.I.R.
463	2.155	\$27	\$1,547	57.3	0.15
464	15.46 JH	\$193	\$1,413	7.3	1.20
473	5.609 🗸	\$70	\$1,413	20.2	0.45

Table M2-1

Sey te



P Fl	ENEF ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY LOC TITL 90	E: 1496 DIS	FION INVES RT LEAVEN SCRETE PO	TMENT P WORTH RTION N	ROGRAM (F	GION NC	S. 7 PARED		IDY: USDBAE LCCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV		DIT CALC(1) UE COST	A+1B+1C)X.					\$ \$ \$ \$ \$ \$	1459. 88. 80. 1464. 0. 1464.
2.	ENERGY SAV ANALYSIS DA		S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST &	DISCOUNT	ED SAVIN	GS		
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		NNUAL \$ SAVINGS(3)		OUNT OR(4)		DISCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$\$\$\$	12.44 .00 .00 4.08 .00	2.155 0. 0. 0. 0.	\$\$ \$\$ \$ \$ \$	27. 0. 0. 0. 0.		8.69 12.42 12.21 11.67 10.36		235. 0. 0. 0. 0.
	F. TOTAL			2.	\$	27.			\$	235.
3.	NON ENERGY	' SA'	VINGS(+) / Co	OST(-)						
	A. ANNUAL R (1) DISCO	ECU	RRING (+/-) FACTOR (TA			9.11			\$	0.
	(2) DISCO	UNT	ED SAVING/	COST (3A X	(3A1)	3.11			\$	0.
	C. TOTAL NO	NE	NERGY DISC	OUNTED SA	AVINGS(+	-) /COST(-) (3A2+3Bd	4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX N 1 IS 1 IS 1 IS	ENERGY QI ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJE(′ CALC (2F5 O TO ITEM 4 SIR = (2F5₁ O ITEM 4	5 X .33) 4 ⊦3D1)/1F)		\$	78.		
4.	FIRST YEAR D	OLL	AR SAVINGS	\$ 2F3+3A+(3	B1D/(YE	ARS ECONC	MIC LIFE	:))	\$	27.
5.	TOTAL NET DI	sco	UNTED SAV	INGS (2F5+	3C)				\$	235.
6.	DISCOUNTED (IF < 1 PROJEC	SAV CT D	INGS RATIO	JALIFY)	(5	8IR)=(5 / 1F)=	=	0.16		
7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F	-/4	ę	54.22		



,

FI Al	ROJECT NO. 8 SCAL YEAR 19 NALYSIS DATE	RGY (& LOC TITLE 990 E: 03	ONSERVA ATION: FO E: 1496 DIS	SCRETE PO	TMENT PF WORTH - RTION NAI	OGRAM (E USDB REC ME: ECOM2	GION NOS. 7		DY: USDBAE LCCID 1.035 CENSUS: 2 RB
1.	INVESTMEN A. CONSTRI B. SIOH C. DESIGN (D. ENERGY E. SALVAGE F. TOTAL IN	UCTIO COST CRED E VALL	IT CALC(1 JE COST		9			\$\$ \$\$ \$\$ \$ \$ \$	1333. 80. 73. 1337. 0. 1337.
2.	ENERGY SAY ANALYSIS D	VINGS ATE A	(+) / COST NNUAL SAV	(-) 'INGS, UNIT	COST & D	ISCOUNTE	D SAVINGS		
	FUEL		NIT COST /MBTU(1)	SAVINGS MBTU/YR		INUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		ISCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	15.46 0. 0. -1.114 0.	\$\$ \$\$ \$\$ \$ \$	192. 0. -5. 0.	8.69 12.42 12.21 11.67 10.36		1668. 0. -58. 0.
	F. TOTAL			14.	\$	187.		\$	1610.
3.	NON ENERG	Y SAV	INGS(+) / C	OST(-)					
	A. ANNUAL F		RRING (+/-) FACTOR (TA			9.11		\$	0.
	(2) DISCO	UNTE	D SAVING/	COST (3A X	3A1)	9.11		\$. 0.
	C. TOTAL NO	N ENI	ERGY DISC	OUNTED SA	VINGS(+)	/COST(-) (3	3A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 31	AX NC)1 IS =)1 IS < D1B IS	ON ENERGY OR > 3C G 3C CALC = > 1 GO T	′ CALC (2F5 O TO ITEM 4 SIR = (2F5+	X .33) 4 ·3D1)/1F)=		\$ 531.		
4.	FIRST YEAR [R SAVINGS	5 2F3+3A+(3	B1D/(YEA	RS ECONON	AIC LIFE))	\$	187.
	TOTAL NET D							\$	1610.
6.	DISCOUNTED (IF < 1 PROJE	SAVII CT DC	NGS RATIO DES NOT QU	JALIFY)	(SII	R)=(5 / 1F)=	1.20		
7.	SIMPLE PAYB	ACK F	PERIOD (ES	TIMATED)	SPB=1F/4	1	7.15		



....

ECO-M2

P F	ENEI ISTALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	rgy C Loc Title 90	ONSERVA ⁻ ATION: FOI E: 1496 DIS	SCRETE PO	TMENT WORTH RTION N	PROGRAM (- USDB R	EGION M2473	NOS. 7 REPARED	I	DY: USDBAE LCCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY E. SALVAGE F. TOTAL IN	JCTIO COST CRED VALL	IT CALC (1 JE COST		9				\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	1333. 80. 73. 1337. 0. 1337.
2.	ENERGY SAV ANALYSIS DA	/INGS	(+) / COST NNUAL SAV	(-) /INGS, UNIT	COST 8			/INGS		
	FUEL		NIT COST /MBTU(1)			ANNUAL \$ SAVINGS(3)		SCOUNT CTOR(4)		ISCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$\$ \$\$ \$\$ \$ \$	12.44 .00 .00 4.08 .00	5.609 0. 0. 0. 0.	\$ \$ \$ \$ \$	70. 0. 0. 0.		8.69 12.42 12.21 11.67 10.36		608. 0. 0. 0. 0.
	F. TOTAL			6.	\$	70.			\$	608.
3.	NON ENERGY	(SAV	INGS(+) / C	OST(-)						
	A. ANNUAL F		RRING (+/-) FACTOR (TA			9.11			\$	0.
	(2) DISCO	UNTE	D SAVING/	COST (3A X	3A1)	9.11			\$	0.
	C. TOTAL NC	N EN	ERGY DISC	OUNTED SA	VINGS(+) /COST(-)	(3A2+3	Bd4)	\$	0.
	A IF 3D B IF 3D C IF 31	AX NC 1 IS = 1 IS < 01B IS	DN ENERGY • OR > 3C G • 3C CALC • = > 1 GO T	′ CALC (2F5 O TO ITEM 4 SIR = (2F54	X .33) 4 -3D1)/1F	;)=	\$	201.		
4.	FIRST YEAR (OLLA	AR SAVINGS	6 2F3+3A+(3	B1D/(YE	ARS ECON		FE))	\$	70.
5.	TOTAL NET D	ISCO	UNTED SAV	'INGS (2F5+	3C)				\$	608.
6.	DISCOUNTED (IF < 1 PROJE	SAVI CT DC	NGS RATIO DES NOT QI) UALIFY)	(SIR)=(5 / 1F)=	0.45		
7.	SIMPLE PAYB	ACK F	PERIOD (ES	TIMATED)	SPB=1	F/4		19.10		



ECO-M2

3

CONSTRUCTION COST ESTIMATE		DATE PR	EFARED)	SHEET	OF		
PROJECT USDB ENERGY STUDY				BASIS FOR	L			
FORT LEAVENWORTH KS				X		(NO DESIGN		D)
ARCHITECT/ENGINEER					CODE C	(PRELIMINAR (FINAL DESIG	Y DESIGN) iN)	
CLARK RICHARDSON & BISKL	JP	FOTH	1700			(SPECIFY)	•	
NONE		ESTIM	ATOR	МЈМ		CHECKED BY MAW		
ECO-M2 DRY-BULB ECONOMIZER		ANTITY		ATERIAL		ABOR	TOT	· · -
CONTROLS	NO.	MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	co	ST
BUILDING 463 ECONOMIZER CONTROLS FOR AHU LOCATED				·····				
ON SECOND FLOOR NORTHEAST ENTRY	<u> </u>							
ELECTRIC CONTROLLER	1	EA	104.00	\$104	24.00	\$24		\$1
MIXED AIR TEMPERATURE SENSOR		EA	60.00	\$60	19.40			<u>\$</u>
OUTSIDE AIR TEMPERATURE SENSOR	1	EA	60.00	\$60	19.40			
MIXED AIR ELECTRIC DAMPER MOTOR	1	EA	148.00	\$148	25.00	\$25		\$1
BUILDING 463 ECONOMIZER CONTROLS FOR AHU LOCATED ON THIRD FLOOR ABOVE STAIRS								
		EA	104.00					
MIXED AIR TEMPERATURE SENSOR		EA	60.00	\$104 \$60	<u>24.00</u> 19.40	\$24 \$19		<u>\$1</u>
OUTSIDE AIR TEMPERATURE SENSOR		EA	60.00	\$60	19.40	\$19		\$
IXED AIR ELECTRIC DAMPER MOTOR	1	EA	148.00	\$148	25.00	\$25		¥ \$1
8 X 28 RETURN AIR DAMPER	1	EA	24.00	\$24	19.25	\$19		\$
8 X 28 OUTSIDE AIR DAMPER	1	EA	24.00	\$24	19.25	\$19		\$
SUBTOTAL				\$792		\$214		\$1,0
ONTINGENCY 10%			10%	\$79	10%	\$21		\$1
SUBTOTAL				\$871		\$235		\$1,1
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$30	13.0%	\$31		\$
DIRECT COST				\$901		\$266		\$1,10
			25%	\$225	25%	\$67		\$29
SUBTOTAL				\$1,126		\$333		\$1,45
CONSTRUCTION COST								\$1,45

\sim	
	ι.
1. 1. 1. 1.	Ł
1.1.1	ŗ.,
a line of the second	

CONSTRUCTION COST ESTIMATE			DATE PF	REPARED	4/2/9		SHEET OF
PROJECT			1	BASIS FOR	2		
				DAGIS FUR	ESTIMATI	2	
FORT FAVENIMORTH KO				X	_CODE A	(NO DESIGN	COMPLETED)
ARCHITECT/ENGINEER	·····				CODE B	(PRELIMINAR	IY DESIGN
CLARK RICHARDSON & BISK						(FINAL DESIG	BN)
NONE		ESTIM	ATOR		UTILA	CHECKED B	Y
ECO-M2		JANTITY	r	MJM		1	MAW
DRY-BULB ECONOMIZER	NO.	TUNIT	PER	ATERIAL TOTAL		ABOR	TOTAL
CONTROLS BUILDING 464 ECONOMIZER		MEAS.	UNIT	TOTAL	PER UNIT	TOTAL	COST
CONTROLS FOR AHU LOCATED					UINI		
ON FIRST FLOOR IN BARBERSHOP		+			ļ		
ELECTRIC CONTROLLER		EA	104.00	¢104			
MIXED AIR TEMPERATURE SENSOR				\$104	24.00	\$24	\$
	¹	EA	60.00	\$60	19.40	\$19	
DUTSIDE AIR TEMPERATURE SENSOR	1	EA	60.00	\$60	19.40	\$19	
/IXED AIR ELECTRIC DAMPER MOTOR		EA	148.00				
	1			\$148	25.00	\$25	\$1
		┟───┟					
	<u> </u>						
UILDING 464 ECONOMIZER							
CONTROLS FOR AHU LOCATED							
IN SECOND FLOOR IN BREAKROOM							
LECTRIC CONTROLLER	1	EA	104.00	C101			
IXED AIR TEMPERATURE SENSOR			104.00	\$104	24.00	\$24	\$1
	1	EA	60.00	\$60	19.40	\$19	\$
UTSIDE AIR TEMPERATURE SENSOR	1	EA	60.00	\$60	19.40	\$19	\$
IXED AIR ELECTRIC DAMPER MOTOR	1	EA	148.00	\$148	25.00		
			140.00		25.00	\$25	\$17
SUBTOTAL				\$744		\$176	
DNTINGENCY 10%			10%				\$92
SUBTOTAL				\$74	10%	\$18	
DRK COMP, TAX, SOC.SEC., INS				\$818	—— <u> </u> -	\$194	\$1,01
			3.50%	\$29	13.0%	\$25	\$5
DIRECT COST				\$847		\$219	\$1,06
ERHEAD AND PROFIT			25%	\$212	25%	\$55	
SUBTOTAL	Γ	T					\$267
CONSTRUCTION COST				\$1,059		\$274	\$1,333
A. FORM 150 C-59				l			\$1,333

1AVC-59



•

CONSTRUCTION COST ESTIMATE	UATE PH	EPARED	4/2/90)	SHEET OF		
PROJECT		····	4	BASIS FOR		<u> </u>	
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS			<u> </u>	x			
ARCHITECT/ENGINEER	·					(PRELIMINAR (FINAL DESIG	
CLARK RICHARDSON & BISKU DRAWING NO.	P	COTIAN	ATOD			SPECIFY)	,
NONE		ESTIMATOR		MJM		CHECKED BY MAW	
ECO-M2 DRY-BULB ECONOMIZER		ANTITY		ATERIAL		ABOR	TOTAL
CONTROLS	NO.	UNIT	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 473 ECONOMIZER CONTROLS FOR AHU LOCATED							
ON SECOND FLOOR HALLWAY SOUTH END							
ELECTRIC CONTROLLER	1	EA	104.00	\$104	24.00	\$24	\$1
MIXED AIR TEMPERATURE SENSOR	1	EA	60.00		19.40	\$19	\$
OUTSIDE AIR TEMPERATURE SENSOR	1	EA	60.00	\$60	19.40	\$19	\$
MIXED AIR ELECTRIC DAMPER MOTOR	1	EA	148.00	\$148	25.00	\$25	\$1
BUILDING 473 ECONOMIZER CONTROLS FOR AHU LOCATED ON THIRD FLOOR HALLWAY SOUTH END							
ELECTRIC CONTROLLER		EA	101.00			•••	•
MIXED AIR TEMPERATURE SENSOR		EA	<u>104.00</u> 60.00	<u>\$104</u> \$60	24.00	\$24	\$12
OUTSIDE AIR TEMPERATURE SENSOR		EA	60.00	\$60 \$60	<u>19.40</u> 19.40	\$19 \$19	\$7
MIXED AIR ELECTRIC DAMPER MOTOR		EA	148.00	\$148	25.00	\$25	پ \$15
					20.00	φ23	φ.
SUBTOTAL				\$744		\$176	\$92
CONTINGENCY 10%			10%	\$74	10%	\$18	\$9
SUBTOTAL				\$818		\$194	\$1,01
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$29	13.0%	\$25	\$5
				\$847		\$219	\$1,06
			25%	\$212	25%	\$55	\$26
				\$1,059		\$274	\$1,33
CONSTRUCTION COST							\$1,33



ECO-M2

DRY-BULB ECONOMIZER CONTROLS

BUILDING 463



ECO-M2 ECONOMIC ANALYSIS

	STEAM CON	SUMPTION		ELECTRIC	ON		
BUILDING NUMBER	BASE ENERGY (THERMS)	ECO-M2 LOAD (THERMS)	ENERGY SAVINGS (MBTU)	BASE LOAD (KW)	ECO-M2 LOAD (KW)	ENERGY SAVINGS (MBTU)	TOTAL SAVINGS (\$)
	1. (. <u> </u>				
463	1,577	1,577	0	83.903	83,831	0	\$3
	the second s	2,206		91,802	88,123	13	\$152
464	2,195	the second s	0	148,420	148,250	1	\$7
473	2,407	2,407	<u> </u>	1 140,420	140,200		\$162

** ** ** TRACE ULTRA ANALYSIS ** ** ** ** ** by CLARK RICHARDSON BISKUP ** **

USDB ENERGY STUDY LEAVENMORTH, KANSAS USDB ERIAN SCOTT

Weather File Code:	FILVNW	
Location:		WORTH, KANSAS (USDB)
Latitude:	39.4	
Longitude:	94.9	(deg)
Time Zone:	6	
Elevation:	770	(ft)
Barcmetric Pressure:	29.1	(in. Hg)
·		·
Summer Clearness Number:	0.95	
Winter Clearness Number:	0.95	
Summer Design Dry Bulb:	96	(F)
Summer Design Wet Bulb:	77	(F)
Winter Design Dry Bulb:	3	(F)
Summer Ground Relectance:	0.20	
Winter Ground Relectance:	0.20	
Air Density:	0.0739	(Ibm/cuft)
Air Specific Heat:	0.2444	(Btu/lbm/F)
Density-Specific Heat Prod:	1.0837	(Btu-min./hr/cuft/F)
Latent Heat Factor:	4,770.2	(Btu-min./hr/cuit/lbm)
Enthalpy Factor:	4.4333	(Btu-min./hr/cuft)
Design Simulation Period: May	To	October
System Simulation Period: Jam	ary To I	December
Cooling Load Methodology:	am/ar	(TFM)
Time/Date Program was Run:	15:11:2	4 9/19/90
Dataset Name:	463-AI	MI. M

V600 PAGE 1

.

•



AIRFLOW - ALTERNATIVE 3 ECO M2: DRY-BULB ECONOMIZER CONTROLS

System System Number Type	Outside Airflow (Cfm)	Ccoling Airflow (Cfm)	Main Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Anxil. Supply Airflow (Cfm)	Room Exhaust Airflow (Cfm)
1 FC	0	200	200	200	0	0	58
2 FC	0	630	630	630	٥	0	45
3 FC	0	1,580	1,580	1,580	0	0	265
4 FC	0	600	600	600	0	0	45
5 FC	0	300	300	300	0	0	99
6 SZ	0	2,280	2,280	2,280	2,280	0	559
7 SZ	0	2,690	2,690	2,690	2,690	0	673
Totals	0	8,280	8,280	8,280	4,970	0	1,743

CAPACITY - ALTERNATIVE 3 ECO M2: DRY-BULB ECONOMIZER CONTROLS

.

-- SYSTEM SUMMARY ---(Design Capacity Quantities)

		Cool	Ling					Heating			
System System Number Type	n Capacity	Aux. Sys. Capacity (Tons)	•	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Vent Capacity (Btuh)	Heating Totals (Btuh)
1 FC	0.4	0.0	0.0	0.4	-10,000	0	0	0	0	. 0	-10,000
2 FC	0.8	0.0	0.0	0.8	0	0	-2,561	0	0	0	-2,561
3 FC	3.7	0.0	0.0	3.7	-66,910	0	0	0	0	0	-66,910
4 FC	1.3	0.0	0.0	1.3	-30,000	0	0	0	0	0	-30,000
5 FC	0.7	0.0	0.0	0.7	-15,000	0	0	0	0	0	-15,000
6 SZ	6.8	0.0	0.0	6.8	-130,000	0	0	٥	0	0	-130,000
7 SZ	8.8	0.0	0.0	8.8	-165,000	0	0	0	0	0	-165,000
Totals	22.5	0.0	0.0	22.5	-416,910	0	-2,561	0	0	0	-419,471



ENGINEERING CHECKS - ALTERNATIVE 3 ECO M2: DRY-BULB ECONOMIZER CONTROLS

			E N	GINEE	RING	снеск	s			
			Percent		Cool-	ing		Heat	ing	
System	Main/	System	Outside	Cfm/	Cfm/	Sq Ft	Btuh/	Cfm/	Btuh/	Floor Area
Number	Auxiliary	Туре	Air	Sq Ft	Ton	/Tan	Sq Ft	Sq Ft	Sq Ft	Sq Ft
1	Main	FC	0.00	1.02	480.0	470.4	25.51	1.02	-51.02	196
2	Main	FC	0.00	1.76	794.1	450.0	26.67	1.76	-7.17	357
3	Main	FC	0.00	1.76	429.3	244.0	49.18	1.76	-74.51	898
4	Main	FC	0.00	1.13	450.0	396.7	30.25	1.13	-56.71	529
5	Main	FC	0.00	0.90	450.0	502.5	23.88	0,90	-44.78	335
6	Main	SZ	0.00	1.00	336.6	336.7	35.64	1.00	-56.99	2,281
7	Main	SZ	0.00	1.18	305.1	258.7	46.38	1.18	-72.34	2,281

.

3

V 600 PAGE 3

.



.

System 1 Block FC - FAN COIL

**************** Peaked at T				7/15			*				*		Hr: 13/ 1	
Outside Air	: =>	OAE	B/WB/HR:	96/ 77/112.	0		*	CA			*	QA	DB: 3	
							*				*			
		Space		Ret. Air		: Perant	*	-	ace	Perant		pace	Total	Pera
		s.+Lat.	Sensible	Latent	Total		*	Sensi		Of Tot		ible	Sensible	of T
Envelope Lo		(Btuh)	(Btuh)	(Btuh)	(Btuh)		*	(Bt	uh)	(.5)		tun)	(Btuh)	(*
Skylite S		0	0		C		*		0		*	0	- 0	0.0
Skylite C		0	0		(*		0	0.00	*	G	0	٥.
Roof Cond	-	0	0		(*		0	0.00	*	0	0	٥.
Glass Sol		1,666	0		1,666		*		666	21.65		0	. 0	٥.
Glass Con		444	0		444		*		444	5.77		,943	-1,943	10.
Wall Cond		3,265	470		3,736	5 36.48	*	3,	265	42.44	* -9	,032	-10,548	58.
Partition	-	0			C		*		0	0.00	k l	0	0	0.
Exposed F		0			(0.00	*		0	0.00	* -1	,404	-1,404	7.
Infiltrat		3,349			3,349		*	-,	131	14.70	* -4	,085	-4,085	22.
Sub Total	-	8,725	470		9,195	5 89.79	*	6,	507	84.57	* -16	,464	-17,980	100.
internal Lo	ads						*				ł			
Lights		311	208		519	5.07	*		311	4.05	k	0	0	٥.
People		388			388	3.79	*		198	2.57	*	0	0	٥.
Misc		0	0	0	C	0.00	*		0	0.00	ł	0	0	٥.
Sub Total	>	699	208	0	907	8.85	*		509	6.62	ĸ	0	0	٥.
eiling Loa	d	678	-678		C	0.00	*		.678	8.81	* -1	,516	0	0.
utside Air		0	0	0	C	0.00	*		0	0.00	ł	0	0	٥.
Sup. Fan He	at				123	3 1.20	*			0.00	۲		0	٥.
let. Fan He	at		16		16	5 0.16	*			0.00	*		0	0.
uct Heat P	kup		0		C	0.00	*			0.00	۲		0	٥.
N/UNDR Siz	ing	0			C	0.00	*		0	0.00	*	0	0	٥.
xhaust Hea	t		0	0	C	0.00	*			0.00	r i		0	٥.
'eminal By	pass		0	0	C	0.00	*			0.00	۲		0	٥.
							*			,				
rand Total	>	10,102	16	0	10,240	100.00	*	7,	694	100.00	-17	, 980	-17,980	100.
				LING COIL SI	ELECTION							AI	EAS	
	Total Ca	pacity		Coil Airfl		ng DB/WB/	HR/	Leav	ring Di	B/WB/HR	Gross T	otal	Glass (s	f) (%
(*	Tons)	(Moh)	(Moh)	(ເວລີກ,)	Dear F De	o F Grai	ns			Grains	Floor	196	5	
in Clg	0.4	5.0	3.8	200	78.2 6	a.2 55	5.9	42.1	41.1		Part	C)	
x Clg	0.0	0.0	0.0	0	0.0	0.0 0	0.0	0.0	0.0	0.0	ExFlr	27	7	
t Vent	0.0	0.0	0.0	0	0.0	0.0 0	0.0	0.0	0.0	0.0	Roof	()	0
tals	0.4	5.0									Wall	393	3	48
	HEATTNG	COIL SELE	CTTCN		AT	RELOWS (c	- ۲۰۰۰ ۱ _			ENGINEERIN	·		MPERATURE	S (F)-
	apacity	Coil Ai		Lva	Type	Cooling		eating		g % QA	0.0		pe Clg	• •
-	(Mbh)	(cfm		Deg F	Vent	0	1.	0		g 3 GA g Cfm/Saft	1.02	SADE		
in Htg	-10.0		00 68.0	151.0	Infil	58		58		g Clin/SqlC g Cfm/Ton	480.00	Pler		
	0.0	4	0 0.0	0.0	Supply	200		200		g Chillion g Saft/Ton	470.40	Retu		
x Hto	0.0	2	0 68.0	41.9	Mincén	200		200		g Sqrt/Ton g Btuh/Saft		ret. Ret/		
2				74.7						-				
eheat			0 0 0	0.0	Detrans	200								
x Htg reheat heat midif	0.0		0 0.0	0.0	Return	200		200		. People	1		arnd 78.0	
reheat			0 0.0 0 0.0 0 0.0	0.0 0.0 0.0	Return Exhaust Rm Exh	200 58 58		200 0 0	Hte	. People g % QA g Cfm/Soft	1 0.0 1.02	En M	arnd 78.0 frrID 0.1 aldID 0.1	1 0







.

System 2 Block FC - FAN COIL

eaked at Time =	=>	Mo/Hr:	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
utside Air =>>	OAD	B/WB/HR: 9	96/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perat		Space	Total	Perch
_	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	01 100	*	Sensible	Sensible	Of To
nvelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(ક)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	- 0	0.0
Skylite Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Roof Cand	0	0		0	0.00	×	0	0.00	*	0	0	0.0
Glass Solar	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Cond	0	0		0	0.00	*	0	0.00	*	. 0	0	0.0
Wall Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Infiltration	2,786			2,786	51.33	*	2,054	52,95	*	-7,418	-7,418	132.0
Sub Total=>	2,786	0		2,786	51.33	*	2,054	52.95	*	-7,418	-7,418	132.6
nternal Loads				•		*			*			
Lights	819	546		1,365	25.15	*	819	21.11	*	819	1,365	-24.4
People	840			840	15.48	*	460	11.86	*	460	460	-8.2
Misc	0	0	0	. 0	0.00	*	0	0.00	*	0	0	0.0
Sub Total=>	1,659	546	0.	2,205	40.63	*	· 1,279	32,97	*	1,279	. 1,825	-32.6
ailing Load	546	-546		0	0.00	*	546	14.08	*	546	0	0.0
utside Air	· 0	0	0.	0	0.00	*	0		*	0	0	0.0
up. Fan Heat		•	·	386	7.12	*	-		*		0	0.0
et. Fan Heat		50		50	0.93	*		0.00	*		0	0.0
uct Heat Pkup		0		0	0.00	*			*		0	0.0
V/UNDR Sizing	0	J		ő	0.00	*	0		*	0	0	0.0
xhaust Heat	5	0	0	ő	0.00	*	v		*		0	0.0
erminal Bypass		0	0	0	0.00	*			*	-	ů 0	0.0
and and all and a		0	0	U	0.00	*		0.00	*		Ŭ	
rand Total->	4,991	50	0	5,428	100.00	*	3,879	100.00	*	-5,593	-5,593	100.0

													-			
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DE	3/WB/HR	Gross To	tal (Glass	(sf)	(%)	
•	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	357				
Main Clg	0.8	9.5	7.6	630	78.2	70.2	101.9	71.9	66.1	89.8	Part	0				
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0				
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0		0
Totals	0.8	9.5									Wall	0		0		0

	HEATING (DIL SELECTIO	N		A	JRFLOWS (cfi	n)	ENGINEERING	HECKS-	TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.76	SADB	72.3	76.2
Main Htg	0.0	630	71.8	76.2	Infil	105	105	Clg Cfm/Ton	794.12	Plenim	82.9	72.8
Aux Htg	0.0	0	0.0	0.0	Supply	630	630	Clg Sqft/Ton	450.00	Return	78.0	68.0
Preheat	-2.6	630	68.0	71.8	Mincim	630	630	Clg Btuh/Saft	26.67	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	630	630	No. People	2	Runarnd	78.0	68.0
Hmidif	0.0	0	0.0	0.0	Exhaust	105	0	Htg 총 QA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Ra Exh	45	0	Htg Cfm/SqFt	1.76	Fn BldID	0.1	0.0
Total	-2.6				Auxil	0	0	Htg Btuh/Saft	-7.17	Fn Frict	0.4	0.0



•

System 3 Block FC - FAN COIL

Peaked at		******* G		7/15			*		/Hr:	7/15	*		vo/Hr: 1		
Outside A				96/ 77/112.	0		*		ADB:		*	1	OADB:	.3/ 1	
		un	55/NG/AR.	50/ ///112.	0		*	ů	AUD:		ŕ.			5	
		Space	Ret. Air	Ret. Air	Net	t Percnt	*	9	oace	Perant	*	Space	1	otal	Peran
		Sens.+Lat.	Sensible	Latent	Total			Sens.		Of Tot		Sensible		ible	Of To
Envelape	Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)		*		tuh)		*	(Btuh)	(E	Stuh)	(%
Skylite		0	((2021)		0.00	*	(12)	0	0.00	*	()	·-	- 0	0.0
Skylite	Cand	0	0			0.00			ŏ	0.00	*	ů.		ō	0.0
Roof Co		0	0			0.00			õ		*	ō		ō	0.0
Glass S	olar	5.753	0		5,75			5	.753	14.94	*	o o		ō	0.0
Glass (lond	1,451	0		1,451			_	,451	3.77	ł.	-6,346	-4	5,346	6.5
Wall Co	nd	3,260	412		3,673				,260	8.47	•	-13,163		, 719	17.1
Partiti	.on	0			•	0.00	*		0	0.00	*	0		0	0.0
Exposed	Floor	0				0.00	*		õ	0.00	r	-3.120	-3	.120	3.2
Infiltz		42,738			42,738		*	21	. 457	55.71	*	-77,482		, 482	79.4
Sub Tot		53,203	412		53,616		*		,922			100.111		, 667	106.3
Internal		,	144		33, 61	5 07.24	*		,		r i	100,111	200	,	20010.
Lights		3,276	2,184		5,461	L 8.89	*	3	.276	8.51	*	3,276	-	.461	-5.6
People		1,288	2,101		1,288		*	J.	718	1.86		690	-	690	-0.7
Misc		2,200	0	٥	1,200		*		0	0.00		0_0		0	0.0
Sub Tot		4.564	2,184	0	6.748		*	2	.994	10.37		3.966	G	. 151	-6.3
Ceiling I		2,597	-2,597	0	0,140		*		, 597 . 597	6.74 "		-1,372	c.	0	0.00
Outside A		2,337	-2,397	٥	(*	2,	, 25,	0.00 *		-1,3/2		õ	0.00
Sup. Fan		0	0	ŭ	969		*		0	0.00 7		0		ŏ	0.00
Ret. Fan			126		126		*			0.00 *				ŏ	0.00
Duct Heat			120		126		*			0.00 7				ő	0.00
OV/UNDR S	+	0	Ŭ		0		*		0	0.00 *		0		ŏ	0.00
Exhaust H	-	0	0	0	(*		0	0.00 *		v		ő	0.00
Terminal			0	0	(*			0.00 *				ŏ	0.00
	orpana		0	0	ι.	0.00	*			0.00 -				Ŭ	0.00
Grand Tot	al=>	60,364	126	0	61,459	100.00		38,	,512	100.00 *	•	-97,517	-97	, 517	100.00
	Total	Capacity		LING COIL SE Coil Airfl		ng DB/WB	/HR	leat	zina ī	B/WB/HR	Gros	s Total	-AREAS- Gla	ss (si	E) (%)
	(Tons)	(Moh)	(Moch)	(cîm)		or F Grai			Deg E		Floor		898		-, (.,
ain Clg	3.7	44.2	28.5	1,580	-	-	3.6	55.1	54.4		Part		0		
ux Clq	0.0	0.0	0.0	0	0.0		0.0	0.0	0.0		ExFlr	•	60		
pt Vent	0.0	0.0	0.0	0	0.0		0.0	0.0	0.0		Roof		0		0 0
otals	3.7	44.2		-		,					Wall		885	1	156 18
		NG COIL SELE	CTTON			RELOWS (d	- <i>e</i> >			ENGINEERING		· .	-TEMPER	7.77.77.77.7	· (E)
	Capacit					- · · · ·		······································		a 3 OA		<u> </u>		Clq	Htq
	(Moh)	•		Lvg Dog F	Type	Ccoling 0	1	Heating 0					Type ADB	55.5	-
ain Hto	-66	(Deg F	Vent	•		-		.g Cfm/Sqft				87.1	
in Rug ix Hta		.9 1,5	0 0.0	125.0	Infil	1,100		1,100		g Cim/Ton			lemm	78.0	
ix Htg cebeat				0.0	Supply	1,580		1,580		g Sqft/Ton			etum		
		.0 1,5			Mincfm	1,580		1,580		.g Btuh/Sqft	. 49		et/OA	78.0	
eheat 	0.		0 0.0	0.0	Return	1,580		1,580		. People			unamd	78.0	
midif		.0	0 0.0	0.0	Exhaust	1,100		0		ig ∛ OA			h MrrID		
ot Vent	0.		0 0.0	0.0	Rm Exh	265		0		g Cfm/SqFt			n BldID		
otal	-66	. 4			Auxil	0		0	174	a Btuh/Saft	74	.51 F	n Frict	0.4	1 0.0

V 600 PAGE 6

System 4	Block	FC	-	FAN COIL
----------	-------	----	---	----------

.

Peaked at Time =	>	Mo/Hr:	7/16			*	Mo/Hr:	7/16	*	Mo	/Hr: 13/ 1	
Outside Air =>			6/ 75/105.0			*	OADB:	96	*	0	ADB: 3	
	~		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perant	*	Space	Total	Perat
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(욱)	*	(Btuh)	(Btuh)	(ક)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	- 0	0.00
Skylite Cond	0	- 0		0	0.00	*	0	0.00	*	C	0	0.00
Roof Cand	0	0		0	0.00	*	0	0.00	*	. 0	0	0.00
Glass Solar	5,933	0		5,933	25.14	*	5,933	32.71	*	0	0	0.00
Glass Cond	1,058	0		1,058	4.48	*	1,058	5.83	*	-4,656	-4,656	15.08
Wall Cond	3,010	532		3,542	15.01	*	3,010	16.60	*	-10,752	-13,300	43.06
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	-1,872	-1,872	6.06
Infiltration	7,647			7,647	32.40	*	2,977	16.41	*	-11,059	-11,059	35.80
Sub Total==>	17,649	532		18,180	77.02	*	12,979	71.55	*	-28,339	-30,887	100.00
Internal Loads						*			*			
Lights	1,167	778		1,945	8.24	*	1,167	6.44	*	0	0	0.00
People	785			785	3.32	*	405	2.23	*	0	0	0.00
Misc	2,278	0	0	2,278	9.65	*	2,278	12.56	*	0	0	0.00
Sub Total=>	4,230	778	0	5,008	21.22	*	. 3,850	21.23	*	0	0	0.00
Ceiling Load	1,310	-1,310		. 0	0.00	*	1,310	7.22	*	-2,548	. 0	0.00
Outside Air	0	0	0	0	0.00	*	0	0.00	*	0	. 0	0.00
Sup. Fan Heat				368	1.56	*		0.00	*		0	0.00
Ret. Fan Heat		48		48	0.20	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat	-	0	0	0	0.00	*			*		0	0.00
Terminal Bypass		0	õ	ō	0.00	*		0.00	*		٥	0.00
		•	· ·	•		*			*			
Grand Total=>	23,189	48	0	23 604	100.00	*	18,139	100.00	*	-30,887	-30,887	100.00

	·····			DLING COIL SE	LECTION									
	Total C	apacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross To	tal Glass	: (sf)	(%)
	(Tons)	(Mbh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	529		
Main Clg	1.3	16.0	12.6	600	78.2	62.4	61.4	49.7	48.6	50.7	Part	0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	36		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0	0	0
Totals	1.3	16.0									Wall	538	114	21

.

		DIL SELECTIO	N		A	IRFLOWS (cfi	(m	ENGINEERING	HECKS-	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Mbh)	(cím)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	1.13	SADB	50.1	115.5
Main Htg	-30.0	600	68.0	115.5	Infil	157	157	Clg Cfm/Ton	450.00	Plenm	85.8	52.8
Aux Htg	0.0	0	0.0	0.0	Supply	600	600	Clg Sqft/Ton	396.75	Return	78.0	68.0
Preheat	0.0	600	68.0	49.5	Mincfin	600	600	Clg Btuh/Sqft	30.25	Ret/CA	78.0	68.0
Reneat	0.0	0	0.0	0.0	Return	600	600	No. People	2	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	157	0	Htg % QA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rn Exh	45	0	Htg Cfm/SqFt	1.13	Fn BldID	0.1	0.0
Total	-30.0				Auxil	0	0	Htg Btuh/SqFt	-56.71	Fn Frict	0.4	0.0



.

V 600

System 5 Block FC - FAN COIL

Peaked at	: Time ==)		Mo/Hr:	7/14			*	3/-	/Hr:	7/14	*		Ma /17-	:: 13/ 1	
Outside A				96/ 77/112.	0		÷			96	*		OADE		
		U.S.		<i>50/ ///1122</i> .	0		÷	C	ADB:	ספ	Ĵ		CHUE	5: 5	
		Space	Ret Air	Ret. Air	Not	Perant	*		pace	Perant	*	50	ace	Total	Perch
	Se	ans.+Lat.	Sensible		Total		*		ible	Of Tot	*	Sensil		ensible	Of Tot
Envelope		(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%) (%)	*		tuh)	(%)	*	Bt:		(Btuh)	(%
Skylite		,,	(12241)		(BCOIL)		*	(=	0	0.00	*	(BC	0	(BCUII)	0.0
Skylite		0 0	Ő		0		*		0	0.00	*		ů ů	0	0.0
Roof Co		õ	0		0		*		0	0.00	*		0	0	0.0
Glass S		1,699	0				*	1	-		*		0	0	
Glass C		315	0		1,699		*	1	, 699	23.06	*		-	•	0.0
Wall Co	-	915	123		. 315		*		315	4.28		1,4		-1,445	10.6
Partiti		0	123		1,038				915	12.42	*	-3,3		-4,162	30.5
Exposed		0			C		*		0	0.00			0	0	0.0
Infiltr		-			0		*	_	0	0.00	*	-1,(-1,040	7.6
		4,402			4,402		*		,877	25.48	*	-6,9		-6,973	51.2
Sub Tot Internal		7,332	123		7,455	71.12	*	4	,807	65.24	*	-12,8	320	-13,620	100.00
_	Loads						*				*				
Lights		1,229	819		2,048		*	1	,229	16.67	*		0	0	0.00
People		771			771	7.36	*		391	5.31	*		0	0	0.00
Misc		0	0	•	0		*		0	0.00	*		0	0	0.00
Sub Tot		- 2,000	81,9	-	2,819		*	1	,620	21.98	*		0	0	0.00
Ceiling L		942	-942		0	0.00	*		942	12.78	*	· -8	300	0	0.00
Outside A		0	. 0	0	0	0.00	*	·	Ò	0.00	*		0	0	0.00
Sup. Fan					184	1.75	*			0.00	*			0	0.00
Ret. Fan			24		24	0.23	*			0.00	*			0	0.00
Duct Heat	•		0		0	0.00	*		•	0.00	*			0	0.00
OV/UNDR S	-	0			0	0.00	*		0	0.00	*		0	0	0.00
Exhaust H			0	0	0	0.00	*			0.00	*			C	0.00
Terminal	Bypass		0	0	0	0.00	*			0.00	*			0	0.00
Grand Tot	-1	10 070	24				*	-			*				
GLANG TOU	a1=>	10,273	24	0	10,481	100.00	*	7	, 369	100.00	*	-13,6	520	-13,620	100.00
				LING COIL SI									ARE		
		apacity	Sens Cap.	Coil Airfl		ng DB/WB/			2	DB/WB/HR		Gross Tot		G las s (s	f) (%)
	(Tons)	(Mbh)	(Mbh)	(cím)	-	g F Grai		Deg F	Deg 1			Floor	335		
bin Clg	0.7	8.0	5.8	300			.6	55.0	54.2			Part	0		
ux Clg	0.0	0.0	0.0	0			0.0	0.0	0.0	0.0		ExFlr	20		
pt Vent	0.0	0.0	0.0	0	0.0	0.0 0	.0	0.0	0.0	0.0		Roof	0		0 0
otals	0.7	8.0										Wall	290		35 12
	HEATING	COIL SELE	CIION	<u> </u>	AI	RELOWS (c	:ím) -			ENGINEERII	G	CHECKS	TEM	PERATURE	S (F)
	Capacity	Coil Ai	rfl Ent	Lvg	Type	Cooling	F	leating	c	lg 3 QA		0.0	Тур	e Clg	Htg
	(Mbh)	(c <u>f</u> n	i) Deg F	Deg F	Vent	ō		Ō	C	lg Cfm/Sqft	:	0.90	SADB	55.	
ain Htg	-15.0	3	68.0	109.9	Infil	99		99		lg Cfm/Ton		450.00	Plenu	n 86.	9 60.5
ix Htg	0.0		0 0.0	0.0	Supply	300		300		g Sqft/Tor	h	502.50	Return	n 78.	0 68.0
reheat	0.0	3	68.0	54.8	Mincín	300		300		g Btuh/Sq		23.88	Ret/Q	A 78.	0 68.0
eheat	0.0		0 0.0	0.0	Return	300		300		. People		2	Runar		
midif	0.0		0 0.0	0.0	Exhaust	99		0		cg ≹ QA,		0.0	Fn Mt		
pt Vent	0.0		0 0.0	0.0	Rm Exh	99		ō		ig Cfm/SaFt	:	0.90	Fn Blo		
otal	-15.0				Auxil	0		0		g Btuh/Sat		-44.78	Fn Fr		



:

V 600 PAGE 8

Peaked at Time	>	Mo/Hr:	7/15			*	MO/	/Hr:	7/15	×	M	o/Hr: 13/ 1	
Outside Air =>	> 04	DB/WB/HR:	96/ 77/112.0			*	07	DB:	96	*	C	ADB: 3	
						*				*			
	Space		Ret. Air	Net			•	pace	Perat		Space	Total	Perc
.	Sens.+Lat.	Sensible	Latent	Tota			Sensi		01 100	*	Sensible	Sensible	Of T
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	•	·	(Bt	cuh)	(%)	*	(Btuh)	(Btuh)	(
Skylite Solr	0	0			0.0	-		0	0.00	*	0	- 0	0.
Skylite Cand	0	0				0 *		0	0.00	*	0	0	0.
Roof Cand	0	0) 0.0	-		0	0.00	*	0	0	0.
Glass Solar	18,068	0		18,068	3 27.7	7 *	18,	.068	39.69	*	0	0	٥.
Glass Cond	4,015	0		4,01	5 6.1	7 *	4,	015	8.82	* .	-17,556	-17,556	24.
Wall Cond	2,711	975		3,681	7 5.6	7 *	2,	711	5.96	*	-9,374	-15,511	21.
Partition	0			(0.0	0 *		0	0.00	*	0	0	٥.
Exposed Floor	-			(0.0	0 *		0	0.00	*	0	0	0.
Infiltration	25,366			25,366	5 38.9	9 *	10,	884	23.91	*	-39,305	-39,305	54.
Sub Total=>	50,160	975		51,136	5 78.5	9 *	35,	679	78.37	*	-66,234	-72,372	100.
Internal Loads						*				*			
Lights	9,182	6,122		15,304	23.5	2 *	9,	182	20.17	*	0	0	0.
People	3,878			3,878	5.9	6 *	1,	978	4.34	*	0	. 0	0.
Misc	7,818	0	0	7,818	3 12.0	2 *	7,	818	17.17	*	0	0	0.
Sub Total=>	20,878	6,122	0	27,000	41.5	0 *	18,	978	41.69	*	0	0	0.
Ceiling Load	7,097	-7,097		(0.0	0 *	7,	097	15.59	*	-6,137	0	0:
Outside Air	0	0	0	(0.0	0 *		0	0.00	*	0	0	· 0.
Sup. Fan Heat				2,79	5 4.3	0 *			0.00	*		0	٥.
Ret. Fan Heat		363		363	3 0.5	6 *			0.00	*		0	٥.
Duct Heat Phup		0		() 0.0	0 *			0.00	*		0	٥.
OV/UNDR Sizing	-16,230			-16,230) -24.9	5 *	-16,	230	-35,65	*	0	0	٥.
Exhaust Heat		0	0	(,		0.00	*		0	٥.
Terminal Bypass	5	0	Ó	(*		0	0.
**		-	•	•		*				*		-	
Grand Total=>	61,905	363	0	65,064	100.0	0 *	45,	524	100.00	*	-72,372	-72,372	100.
			ING COIL SEI	FOTTON-								AREAS	
Tota	l Capacity		Coil Airfl		ng DB/W	B/HR	Leav	ring D	B/WB/HR	Gr	oss Total	Glass (s	£) (9
(Tons	· ·	(Moh)	(cfm)		2	ains			Grains	Flo			
ain Clg 6.		64.9	2,280	-	-	73.9	58.4	53.0		Par		0	
ux Clq 0.		0.0	0	0.0	0.0	0.0	0.0	0.0		ExF	-	0	
pt Vent 0.		0.0	0	0.0	0.0	0.0	0.0	0.0		Roo		0	0
•	8 81.3									Wal			430

	HEATING (DIL SELECTIO	N		A	IRFLOWS (cf	m)	ENGINEERING	THECKS	• •		
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & QA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.00	SADB	59.6	97.3
Main Htg	-130.0	2,280	68.0	97.3	Infil	558	558	Clg Cfm/Ton	336.55	Plenum	87.8	59.5
Aux Htg	0.0	0	0.0	0.0	Supply	2,280	2,280	Clg Sqft/Ton	336.70	Return	78.0	68.0
Preheat	0.0	2,280	68.0	58.4	Mincfm	2,280	2,280	Clg Btuh/Sqft	35.64	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	2,279	2,280	No. People	10	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	2,280	0	Htg 🗄 OA	0.0	Fn MtriD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	559	0	Htg Cfm/SqFt	1.00	Fn BldID	0.2	0.0
Total	-130.0				Auxil	0	0	Htg Btuh/Soft	-56.99	Fn Frict	0.7	0.0

.

V 600 PAGE 9

System 7 Peak SZ - SINGLE ZONE

Peaked at Time =	•>	Mo/Hr:	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air =>	QAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perat	*	Space	Total	Perat
9	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	- O	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Roof Cand	20,531	0		20,531	24.54	*	20,531	37.88	*	-20,375	-20,375	0.00
Glass Solar	9,108	0 [`]		9,108	10.89	*	9,108	16.81	*	0	0	0.00
Glass Cond	2,361	0		2,361	2.82	*	2,361	4.36	*	-10,325	-10,325	9.88
Wall Cond	7,560	0		7,560	9.04	*	7,560	13.95	*	-26,278	-26,278	25.14
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	30,684			30,684	36.68	*	13,167	24.30	*	-47,546	-47,546	45.49
Sub Total=>	70,245	0		70,245	83.98	*	52,727	97.29	*	-104,523	-104,523	100.00
Internal Loads						*			*			
Lights	12,451	4,980		17,431	20.84	*	12,451	22.97	*	0	0	0.00
People	6,593			6,593	7.88	*	3,363	6.20	*	0	0	0.00
Misc	7,800	0	0	7,800	9.32	*	7,800	14.39	*	0	0	0.00
Sub Țotal==>	26,843	4,980	0	31,823	38.04	*	23,613	43.57	*	0	. 0	0.00
Ceiling Load	0	· 0	•	0	0.00	*	0	0.00	*	0 .	0	0_00
Outside Air	0	0	0	. 0	0.00	*	0	0.00	· *	0	0	0.00
Sup. Fan Heat				3,298	3.94	*		0.00	*		0	0.00
Ret. Fan Heat		429		429	0.51	*		0.00	*		0	0.00
Duct Heat Phup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	-22,146			-22,146	-26.48	*	-22,146	-40.87	*	0	0	0.00
Exhaust Heat		0	0	. 0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
						*			*			
Grand Total=>	74,942	5,409	0	83,649	100.00	*	54,194	100.00	*	-104,523	-104,523	100.00

				LING COIL SE	LECTION	Į						ARE	AS		
	Total (Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross (Fotal	Glass	(sf)	(ક)
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	2,281			
Main Clg	8.8	105.8	85.0	2,690	78.0	64.9	73.9	58.3	51.6	47.9	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	3,014		0	0
Totals	8.8	105.8									Wall	2,112		253	12

	HEATING (DIL SELECTIO	N		A	JRFLOWS (cf	(m	ENGINEERING	HECKS-			(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % QA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Saft	1.18	SADB	59.4	103.9
Main Htg	-165.0	2,690	68.0	103.9	Infil	675	675	Clg Cfm/Ton	305.12	Plenm	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	2,690	2,690	Clg Sqft/Ton	258.73	Return	78.0	68.0
Preheat	0.0	2,690	68.0	58.3	Mincfin	2,690	2,690	Clg Btuh/Sqft	46.38	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	2,690	2,690	No. People	17	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	2,690	0	Htg & OA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	673	0	Htg Cfm/Saft	1.18	Fn BldID	0.2	0.0
Total	-165.0				Auxil	0	0	Htg Btuh/SqFt	-72.34	Fn Frict	0.7	0.0

.

V 600 PAGE 10

Month	ELEC On Peak (kWh)	DEMAND On Peak (KW)	STEAM (Therm)
Jan	6,235	26	374
Feb	5,554	26	334
March	6,324	26	261
April	5,332	26	9
May	5,819	25	0
June	9,000	44	0
July	11,452	49	0
Aug	10,183	45	0
Sept	6,813	41	0
Oct	5,604	25	0
Nov	5,598	26	96
Dec	5,918	26	503
Total	83, 831	49	1,577

Building Energy Consumption =	. 64,532 (Btu/Sq Ft/Year)	Floor Area =	6,877 (Sq Ft)
Source Energy Consumption =	155,397 (Btu/Sq Ft/Year)	•	•

.

V 600 PAGE 11

.

•



EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

	Equip -	_					-	unption						_
m	Code	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	Total
0	LIGHIS													
	ELEC	3689	3286	3819	3512	3819	3641	3560	3948	3382	3689	3512	3430	43,287
	PK	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5
1	MISC LD											•		
	ELEC	1030	909	1090	969	1090	1046	984	1169	923	1030	969	909	12,118
	PK	5.8	5.8	5.8	5.8	5.8	5.9	5.9	5.9	5.9	5.8	5.8	5.8	5.9
2	MISC LD													
	GAS	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MISC LD					•								
	OIL	0	0	0	0	0	0	0	0	0	0	0	0	I
	PK	0.0	0.0	0.0	0.0	0.0 .	0:0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MISC LD	_												
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	1
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	MISC LD	_												
	P HOTH20	0	0	0	0	0	0	0	0	0	0	0	0	
	PK	0.0.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.
	MISC LD	•	•	•			_	_	_					
	P CHILL PK	0 0.0	0	0	0	0	0	0	0	0	0	0	0	0
	PA	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	EQ1121S			ECIP CHI								_		
	ELEC PK	0 0.0	0	0	0	0	2088	3731	2568	917	0	0	0	9,30
	rk.	0.0	0.0	0.0	0.0	0.0	12.7	16.1	13.4	10.8	0.0	0.0	0.0	16.3
	EQ5200			ENSER FA							_	_		
	ELEC PK	0 0.0	0	0	0	0	254	491	317	107	0	0	0	1,16
	FN	0.0	0.0	0.0	0.0	0.0	1.6	2.4	1.7	1.5	0.0	0.0	0.0	2.4
	EQ5001			LED WATE							_	_		
	ELEC PK	0 0.0	0	0	0	0	168	180	176	94	0	0	0	61
	PK	0.0	0.0	0.0	0.0	0.0	0.5	0.5	0.5	0.5	0.0	0.0	0.0	0.5
	EQ5313		CONT											
	ELEC	0	0	0	0	0	95	102	100	53	0	٥	0	35
	PK	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.0	0.0	0.0	0.3
	EQ1170S			OND COMP										
	ELEC	0	0	0	0	0	547	878	594	382	0	0	0	2,400
	PK	0.0	0.0	0.0	0.0	0.0	3.5	3.7	3.5	3.1	0.0	0.0	0.0	3.1

EQUIPMENT ENERGY CONSUMPTION

2 EQ5200 CONDENSER FANS

.

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

EQUIEMENT ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

	elec Pk	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	61 0.4	116 0.4	69 0.4	36 0.3	0 0.0	0 0.0	0 0.0	283 0.4
2	EQ5313 ELEC PK	0 0.0	0.0	ROLS 0 0.0	0 0.0	0 0.0	97 0.3	102 0.3	101 0.3	88 0.3	0 0.0	0 0.0	0 0.0	388 0.3
1	eq4371 Elec PK	18 0.1	FAN (16 0.1	DIL SUPE 17 0.1	PLY FAN 10 0.1	10 0.1	13 0.1	18 0.1	16 0.1	8 0.1	13 0.1	14 0.1	18 0.1	170 0.1
2	eq4371 Elec PK	56 0.2	FAN 0 50 0.2	XXII. SUPP 56 0.2	PLY FAN 54 0.2	56 0.2	54 0.2	56 0.2	56 0.2	54 0.2	56 0.2	54 0.2	56 0.2	658 0.2
2	EQ4381 ELEC	0	0	iller fan O	0	0	0	0	0	0	٥	0	0	0
3	PK EQ4371	0.0	0.0 FAN C	0.0 DIL SUPP	0.0 PLY FAN	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	ELEC PK	140 0.4	127 0.4	140 0.4	136 0.4	140 0.4	136 0.4	140 0.4	140 0.4	136 0.4	140 0.4	1 36 0.4	140 0.4	1,650 0.4
4	EQ4371 ELEC PK	45 0.2	FAN 0 41 0.2	011 SUPE 43 0.2	LY FAN 28 0.2	29 0.2	32 0.2	48 0.2	36 0.2	25 0.2	38 0.2	37 0.2	48 0.2	451 0.2
4	EQ4381 ELEC	0	PROPE 0	LLER FAN O	1 0	0	0	0	0	0	0	0	0	0
5	PK EQ4371	0.0	0.0 FAN C	0.0 XXIL SUPE	0.0 Ly fan	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	ELEC PK	19 0.1	18 0.1	19 0.1	13 0.1	15 0.1	15 0.1	24 0.1	19 0.1	14 0.1	14 0.1	13 0.1	20 0.1	203 0.1
6	EQ4003 ELEC PK	409 1.7	FC CE 365 1.7	NIRIF. E 377 1.7	AN C.V. 269 1.7	303 1.7	341 1.7	443 1.7	399 1.7	278 1.7	286 1.7	272 1.7	444 1.7	4,185 1.7
7	EQ4003 ELEC PK	538 2.0	FC CE 481 2.0	NTRIF. F 509 2.0	AN C.V. 322 2.0	357 2.0	412 2.0	579 2.0	476 2.0	314 2.0	337 2.0	391 2.0	564 2.0	5,281 2.0
1	convertr P steam PK	341 2.5	STEAN 304 2.5	1 TO HOT 237 2.5	WATER CC 9 1.2	NVERIER 0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	96 2.1	456 2.6	1,443 2.6
1	EQ5020 ELEC	138		WATER CI 121		• c.v.	0	0	0	٥	0	96 .	138	628
1	PK	0.4	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4
T	EQ5060 ELEC PK	150 0.4	0.4	NSATE RE 132 0.4	IURN PUN 10 0.4	12 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	104 0.4	150 0.4	683 0.4

•

2 EQ2101

) • • FURCHASED DISTRICT STEAM

V 600

PAGE 13

EQUIPMENT ENERGY CONSUMPTION - ALIERNATIVE 3 BASE LOAD

	p steam PK	33 0.4	30 0.4	24 0.3	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	47 0.5	134 0.5
2	EQ5020		HEAT	WATER C	IRC. PUM	? c.v.								
	ELEC	0	0	0	0	0	0	0	0	0	٥	٥	1	2
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	EQ5061		CONDE	INSATE RI	ETURN PUR	P	,							
	ELEC	1	1	1	0	0	0	0	0	0	0	0	1	3
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
												• ·		

V 600

PAGE 14

UTILITY PEAK CHECKSUMS - ALTERNATIVE 3 BASE LOAD

UTILITY PEAK CHECKSUMS

Utility ELECTRIC DEMAND

Peak Value 48.7 (kW) Yearly Time of Peak 15 (hr) 7 (mo)

Hour 15 Month 7

.

Eqp. Ref. Num. Cooling E	Equipment Code Name quipment	Dema	•	Perant Of Tot (%)
2	* 1			
1	EQ1121S	AC RECIP CHILLER 20-60 T 19	9.3	39.56
2	EQ1170S	AC COND COMP <20 TONS	1.5	9.22
Sub Total		23	3.8	48.78
Sub Total		c	0.0	*****
Air Movin	g Equipment			
l		SUMMATION OF FAN ELECTRICAL DEMAND).1	0.11
2		SUMMATION OF FAN ELECTRICAL DEMAND).2	0.35
3		SUMMATION OF FAN ELECTRICAL DEMAND).4	0.88
4).2	0.34
5).1	0.17
6			7	3.45
7		SUMMATION OF FAN ELECTRICAL DEMAND 2	2.0	4.07
Sub Total		4	1.6	.9.38
Sub Total		c	0.0	0.00
Miscelland	eous			
Lights		14	1.5	29.66
Base Util	lities	C	0.0	0.00
Misc Equi	•	5	5.9	12.19
Sub Total		20	.4	41.84
Grand Tota	<u>al</u>	48	1.7	100.00

V 600 PAGE 15

. ·

••

.

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 3 BASE LOAD

		~ .			
 CALIFORNIA	TITLE	24	COMPLIANCE	REPORT	

Weather Name	FTLVNWIH
Gross Conditioned Floor Area (soft)	6,877
ACM Multiplier	1.008

ENERGY USE SUMMARY

	ELEC (KWh/yr)	DISTRICT STEAM (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	IOTAL SOURCE ENERGY (KBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)	. ·
Primary Heating	686.1	157,672.9	36.1	217,256.3	31.8	
Primary Cooling						
Compressor	11,703.4	0.0	9.0	119,843.2	17.6	
Tower/Cond Fans	1,451.1	0.0	1.1	14,859.2	2.2	
Condenser Pump	0.0	0.0	0.0	0.0	0.0	
Other Accessories	739.2	0.0	0.6	7,569.4	1.1	
Auxiliary						
Supply Fans	12,598.3	0.0	9.7	129,007.3	18.9	
Circulation Pumps	1,248.4	0.0	1.0	12,783.8	1.9	
Base Utilities	0.0	0.0	0.0	· 0.0	0.0	
Subtotal	13,846.7	0.0	10.6	141,791.0	20.8	
Lighting	43,286.5	0.0	33.3	443,255.1	65.0	
Receptacle	12,118.2	0.0	9.3	124,091.0	18.2	
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	
Cogeneration	0.0	0.0	0.0	0.0	0.0	
Totals	83,831.3	157,672.9	100.0	1,068,665.3	156.6	

V 600 PAGE 16

-

.

۰.

...

ECO-M2

DRY-BULB ECONOMIZER CONTROLS

BUILDING 464



N.

*****	***	n in i	***	*****	***	***	**	**	**	***	**	***	**	*	**	**	nkri	n h:	**:	***	****	****	****	**
*****	***	**	***	*****	****	e ste st	***	**	**	***	ersterst	***	**	*	**	**	nkr i	**	**	***	****	****	****	**
**																							,	**
**	T	R	A	CE	σ	L	т	R	А		A	A N	I A	. 1	<u>.</u>	Y	s	I	s				1	**
**																							,	**
**		ь	,	CLARK	RIC	HZ	R	sc	N	BI	SF	Œ)										,	**
**																							,	**
*****	***	ntri	***	*****	****	rsk s	**	**	**	**	t fr	**	**	*	**	**	ntri	r x n	**	***	****	****	*****	**
*****	***	***	***	*****	****	**	**	**	**	***	**	**	**	*	**	**	r k r	c i n	**	***	****	****	****	**

•

USDB ENERGY STUDY LEAVENWORTH, KANSAS USDB BRIAN SCOTT

Weather File Code:	FILVNW	
Location:		WORTH, KANSAS (USDB)
Latitude:	39.4	(
Longitude:	94.9	(deg)
Time Zone:	6	
Elevation:	770	(ft)
Barometric Pressure:	29.1	(in. Hg)
Summer Clearness Number:	0.95	
Winter Clearness Number:	0.95	
Summer Design Dry Bulb:	96	(F)
Summer Design Wet Bulb:	77	(F)
Winter Design Dry Bulb:	3	(F)
Summer Ground Relectance:	0.20	
Winter Ground Relectance:	0.20	
Air Density:	0.0739	(Lbm/cuft)
Air Specific Heat:	0.2444	()
Density-Specific Heat Prod:		(Btu-min./hr/cuft/F)
Latent Heat Factor:	4,770.2	•
Enthalpy Factor:	• • • •	(Btu-min./hr/cuft)
F1F1		
Design Simulation Period: May	To	October
System Simulation Period: Jan	ary To I	December
Cooling Load Methodology:	am/ar	(TFM)
Time/Date Program was Run:	17:11:2	5 9/24/90
Dataset Name:	464-1	MI. M

. ·

•

.

• •



AIRFLOW - ALIEPNATIVE 3 ECO M2: DRY-BULB ECONOMIZER CONTROLS

			Main			Auxil.	Roam
System System Number Type	Outside Airflow (Cfm)	Cooling Airflow (Cfm)	Heating Airflow (Cfm)	Return Airflow (Cfm)	Exhaust Airflow (Cfm)	Supply Airflow (Cfm)	Exhaust Airflow (Cfm)
1 SZ	0	2,027	1,110	2,027	2,027	0	495
2 SZ	0	300	232	300	0	0	124
3 FC	0	4,373	1,620	4,373	4,373	0	100
4 FC	0	300	301	300	0	0	50
5 FC	0	300	155	300	0	0	37
6 FC	0	300	200	299	0	0	48
7 FC	0	300	157	300	0	0	37
8 FC	0	893	299	893	0	0	78
9 FC	0	656	216	655	0	0	35
10 FC	0	300	230	300	0	0	55
11 FC	0	646	207	646	0	0	49
12 FC	0	300	204	299	0	0	49
13 FC	0	581	226	581	0	. 0	37
Totals	0	11,275	5,158	11,273	6,400	0	1,191

SYSTEM SUMMARY

CAPACITY - ALIERNATIVE 3 ECO M2: DRY-BULB ECONOMIZER CONTROLS

- SYSTEM SUMMARY ----(Design Capacity Quantities)

			Cool	Ling					Heating			
System	System		Aux. Sys. Capacity	-	Cooling Totals	Main Sys. Capacity	Aux. Sys. Capacity	Preheat Capacity	Reheat Capacity	Humidif. Capacity	Opt. Vent Capacity	Heating Totals
Number	Type	(Tans)	(Tons)	(Tons)	(Tons)	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(Btuh)
1	sz	5.2	0.0	0.0	5.2	-68,559	0	0	0	0	0	-68,559
2	SZ	1.6	0.0	0.0	1.6	-14,302	0	0	0	0	0	-14,302
3	FC	8.1	0.0	0.0	8.1	-100,085	0	0	0	0	0	-100,085
4	FC	1.5	0.0	0.0	1.5	-18,589	0	0	0	0	0	-18,589
5	FC	0.9	0.0	0.0	0.9	-9,595	0	0	0	0	0	-9,595
6	FC	0.9	0.0	0.0	0.9	-12,373	0	0	0	0	0	-12,373
7	FC	0.7	0.0	0.0	0.7	-9,674	0	0	0	0	0	-9,674
8	FC	1.5	0.0	0.0	1.5	-18,449	0	0	0	0	0	-18,449
9	FC	1.0	0.0	0.0	1.0	-13,357	0	0	0	0	0	-13,357
10	FC	1.4	0.0	0.0	1.4	-14,226	0	0	0	0	0	-14,226
11	FC	1.0	0.0	0.0	1.0	-12,772	0	0	0	0	0	-12,772
12	FC	1.0	0.0	0.0	1.0	-12,618	0	0	0	0	0	-12,618
13 :	FC	0.9	0.0	0.0	0.9	-13,987	0	0	0	0	0	-13,987
Totals		25.8	0.0	0.0	25.8	-318,586	0	0	0	0	0	-318,586

V 600 PAGE 2

.

. . .

ENGINEERING CHECKS - ALTERNATIVE 3 ECO M2: DRY-BULB ECONOMIZER CONTROLS

.

			Percent		Cool	ing		Heat	ing	
System	Main/	System	Outside	Cfm/	Cfm/	Sq Ft	Btuh/	Cfm/	Btuh/	Floor Area
Number	Auxiliary	Type	Air	Sq Ft	Tan	/Ton	Sq Ft	Sq Ft	Sq Ft	Sq Ft
1	Main	SZ	0.00	1.03	3 9 0.0	377.2	31.82	0.57	-34.98	1,960
2	Main	SZ	0.00	0.61	184.7	301.6	39.78	0.47	-29.19	490
3	Main	FC	0.00	2.03	538.8	264.9	45.30	0.75	-46.55	2,150
4	Main	FC	0.00	0.98	196.7	200.0	59.99	0.99	-60.95	305
5	Main	FC	0.00	1.88	348.1	185.7	64.63	0.97	-59.97	. 160
6	Main	FC	0.00	1.45	334.4	230.7	52.01	0.97	-59.78	207
7	Main	FC	0.00	1.88	409.2	218.2	54.99	0.98	-60.46	160
8	Main	FC	0.00	2.64	576.8	218.4	54.96	0.88	-54.58	338
9	Main	FC	0.00	4.37	688.1	157.5	76.21	1.44	-89.05	150
10	Main	FC	0.00	1.26	208.3	165.2	72.63	0.97	-59.77	238
11	Main	FC .	0.00	3.06	643.3	210.1	57.12	0.98	-60.53	211
12	Main	FC	0,00	1.42	288.5	202.9	59.13	0.97	-59,80	211
13	Main	FC	0.00	3.63	668.2	184.1	65.17	1.42	-87.42	160

----- ENGINEERING CHECKS-----

V 600

PAGE 3

• .

.

System 1 Peak SZ - SINGLE ZONE

Peaked a	t Time =>		Mo/Hr: 7	//15			*	Mo	/Hr:	7/15	*	Mo/	Hr: 13/ 1	
Outside	Air ==>	QAD	B/WB/HR: 9	6/ 77/112.0)		*		ADB:	96	*	QA	DB: 3	
		_					*				*			_
		Space	Ret. Air	Ret. Air	Net		erant *		pace	Percnt		pace	Total	Perch
- ,		ns.+Lat.	Sensible	Latent	Tota		Tot *	Sens			* Sens		Sensible	Of To
Envelope		(Btuh)	(Btuh)	(Btuh)	(Btuh		(%) *	(B	tuh)	(•)	•	tuh)	(Btuh)	(%
Skylit		0	0				0.00 *		0		*	0	0	0.0
Skylit		0	0				0.00 *		0		*	0	0	0.0
Roof C		0	0				0.00 *		0		*	0	0	0.0
Glass		5,746	0		5,74		9.21 *		,746		*	0	0	0.0
Glass		1,449	0		1,44	9	2.32 *	1	,449	3.18		, 338	-6,338	9.2
Wall C		4,788	341		5,12	9	8.22 *	4	,788	10.49	* -18	,094	-20,383	29.7
Partit		0				0	0.00 *		0	0.00	*	0	0	0.0
Expose	d Floor	0				0	0.00 *		0	0.00	* -6	,760	-6,760	9.8
Infilt	ration	22,638			22,63	83	6.30 *	9	,714	21.28		,078	-35,078	51.1
Sub To	tal=>	34,622	341		34,96	35	6.06 *	21	,697	47.54	* -66	, 270	-68,559	100.0
Internal	Loads						*				*			
Lights		7,003	4,669		11,67	21	8.72 *	7	,003	15.35	*	0	0	0.0
People		7,756			7,75	61	2.44 *	3	,956	8.67	*	0	0	0.0
Misc		7,971	0	0	7,97	1 1	2.78 *	7	,971	17.47	*	0	0	0.0
Sub To	al⇒>	22,731	4,669	0	27,400	04	3.94 *	18	, 931	41.48	*	0	0	0.0
Ceiling	Load	5,010	-5,010		. (0.	0.00 *	• 5	,010	10.98	* -2	, 290	0	0.0
Outside !	Air	0	· 0	0	(0	0.00 *		ō	0.00	*	0	0	. 0.0
Sup. Fan	Heat				(0	0.00 *			0.00	*		0	0.0
Ret. Fan	Heat		0		(0	0.00 *			0.00	*		0	0.0
Duct Hea	t Pkup		0		(0	0.00 *			0.00	*		0	0.0
OV/UNDR	Sizing	0			(0.00 *		0		*	0	0	0.0
Exhaust 1	Heat		0	0	(0.00 *		-		*		0	0.0
Terminal	Bypass		0	0	(0.00 *				*		0	0.0
			_	•		•	*				*			
Grand To	al=>	62,362	0	0	62,36	2 10	0.00 *	45	, 638	100.00	* -68	, 559	-68,559	100.0
				ING COIL SE	IECTION-							AI	ÆAS	
	Total Ca	apacity		Coil Airfl		ing D	B/WB/HR	Lear	vina [B/WB/HR	Gress T	otal	Glass (s	sf) (%)
	(Tons)	(Moh)	(Moh)	(cfm)		eq F	Grains	Deg F	Deg I		Floor	1,960		
Main Clg	5.2	62.4	45.6	2,027	-		73.9	56.1	54.7		Part		5	
Aux Clq	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0		ExFlr	130	-	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0		Roof)	0
Totals	5.2	62.4		· ·					•••		Wall	1,519	9	155 1
		COIL SELE	CITION			IRFLO	WS (cfm)			ENGINEERIN	G CHECKS-	13	MPERATURE	S (F) —
	Capacity	Coil Ai		Lvq	Туре			Heating		lg % QA	0.0	-	pe Clo	
	(Mbh)	(cfm		Deg F	Vent		0	0		lg oʻun lg Cfm/Sqft		SADE		2 125.
Main Uta	-69 6			105 0			400	400			200.00	້າງ		

	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.03	SADB	57.2	125.0
Main Htg	-68.6	1,110	68.0	125.0	Infil	498	498	Clg Cfm/Ton	389.99	Plenum	86.1	64.3
Aux Htg	0.0	0	0.0	0.0	Supply	2,027	1,110	Clg Sqft/Ton	377.15	Return	78.0	68.0
Preheat	0.0	2,027	68.0	56.1	Mincfm	0	0	Clg Btuh/Sqft	31.82	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	2,027	1,110	No. People	20	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	2,027	٥	Htg % OA	0.0	Fn MiriD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	495	0	Htg Cfm/SaFt	0.57	Fn BldID	0.2	0.0
Total	-68.6				Anxil	0	0	Htg Btuh/SqFt	-34.98	Fn Frict	0.7	0.0



V 600

PAGE 4

System 2 Peak SZ - SINGLE ZONE

Peaked at Time	==>	Mo/Hr:	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air =>	- QAE	B/WB/HR:	96/ 77/112.0			*	OADB:	96	*	c	ADB: 3	
						*			*			
	Space	Ret. Air		Net	Perant	*	Space	Perant	*	Space	Total	Perc
	Sens.+Lat.	Sensible		Total	Of Tot	*	Sensible	45 100	*	Sensible	Sensible	Of T
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(೪)	*	(Btuh)	(Btuh)	(
Skylite Solr	0	0		0	0.00	*	0	0.00		0	0	٥.
Skylite Cand	0	0		0	0.00	*	0	0.00	*	O	0	٥.
Roof Cand	0	2,601		2,601	28.45	*	0	0.00	*	0	-2,966	0.
Glass Solar	6,867	0		6,867	75.11	*	6,867	120.68	*	0	0	0.
Glass Cond	1,364	0		1,364	14.92	*	1,364	23.96	*	-5,962	-5,962	41.
Wall Cond	1,015	-34		981	10.73	*	1,015	17.84	*	-3,665	-4,125	28.
Partition	0			0	0.00	*	0	0.00	*	0	0	٥.
Exposed Floor	• 0			0	0.00	*	0	0.00	*	-1,248	-1,248	8.
Infiltration	5,682			5,682	62.16	*	2,438	42.85	*	0	0	0.
Sub Total=>	14,928	2,567		17,495	191.37	*	11,683	205.33	*	-10,875	-14,302	100.
Internal Loads				,		*			*			
Lights	1,075	717		1,792	19.60	*	1,075	18,89	*	0	0	0.
People	0			0	0.00	*	0	0.00	*	0	0	ο.
Misc	0	0	0	0	0.00	*	0		*	0	0	٥.
Sub Total=>	1,075	717	0	1,792	19.60	*	1,075		*	0	0	0.
Ceiling Load	3,284	-3,284	-	0		*	3,284	57.71	*	-3,426	Ő	0
Dutside Air	0	0	ò	0		*	0,101		*		0	0.
Sup. Fan Heat			-	184	2.01	*	•		*	•	0	0.
Ret. Fan Heat		24		24	0.26	*		-	*		0	0.
Juct Heat Phup		0	•	0		*			*		õ	0.
W/UNDR Sizing	-10,352	•		-10,352		*	-10,352	*****	*	0	ő	0.
Exhaust Heat	,	0	0	-10,332	0.00	*	-10, 332	0.00	*	Ŭ	ŏ	0. 0.
Cerminal Bypass		0	ŏ	Ő	0.00	*			*		ő	0.
		v	v	U	0.00	*		0.00	*		v	0.
Grand Total=>	8,934	24	0	9,142	100.00	*	5,690	100.00	*	-14,302	-14,302	100.
							,				-	

	Total C	apacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total	Glass (sî)	(%)
	(Tons)	(Moh)	(Mch)	(cīm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	490			
Main Clg	1.6	19.5	16.3	300	78.0	64.9	73.9	59.9	41.3	10.0	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	24			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	202		0	0
Totals	1.6	19.5									Wall	436		146	34

HEATING COIL SELECTION					P	IRFLOWS (cf	m)	ENGINEERING (HECKS-	TEMPERATURES (F)			
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % QA	0.0	Type	Clg	Htg	
	(Moh)	(cím)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	0.61	SADB	60.5	125.0	
Main Htg	-14.3	2 32	68.0	125.0	Infil	125	0	Clg Cfm/Ton	184.67	Plenum	99.2	45.9	
Aux Htg	0.0	0	0.0	0.0	Supply	300	232	Clg Soft/Ton	301.63	Return	78.0	68.0	
Preheat	0.0	300	68.0	59.9	Mincím	300	0	Clg Btuh/Sqft	39.78	Ret/OA	78.0	68.0	
Reheat	0.0	0	0.0	0.0	Return	300	232	No. People	0	Runarnd	78.0	68.0	
Humidif	0.0	0	0.0	0.0	Exhaust	125	0	Htg & OA	0.0	Fn MariD	0.1	0.0	
Opt Vent	0.0	0	0.0	0.0	Rm Exh	124	0	Htg Cfm/SqFt	0.47	Fn BldID	0.1	0.0	
Total	-14.3				Auxil	0	0	Htg Btuh/Soft	-29.19	Fn Frict	0.4	0.0	

V 600

.

_



System 3 Block FC - FAN COIL

eaked at Time =	=>	Mo/Hr:	7/15			*	Mo/Hr:	7/16	*	Me	/Hr: 13/ 1	
Outside Air ==>	QAD	B/WB/HR:	6/ 77/112.0			*	OADB:	96	*	c	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air		Perant	*	Space	Perant	*	Space	Total	Perc
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	02 100	*	Sensible	Sensible	of 1
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0
Skylite Cand	0	0		0	0.00	*	0	0.00	*	G	0	0
Roof Cand	0	0		0	0.00	*	0	0.00	*	0	0	0
Glass Solar	9,844	0		9,844	10.11	*	9,604	11.88	*	0	0	0.
Glass Cond	2,241	0		2,241	2.30	*	2,226	2.75	*	-9,798	- 9,798	9
Wall Cond	13,534	1,046		14,580	14.97	*	14,104	17.44	*	-46,301	-51,827	51
Partition	0			0	0.00	*	0	0.00	*	0	0	0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0
Infiltration	24,820			24,820	25.49	*	10,354	12.81	*	-38,459	-38,459	38
Sub Total=>	50,439	1,046		51,485	52.87	*	36,289	44.88	*	-94,558	-100,085	100
internal Loads				-		*			*		-	
Lights	6,848	4,565		11,413	11.72	*	6,848	8.47	*	0	0	0
People	5,817			5,817	5.97	*	3,036	3.76	*	0	0	0
Misc	28,671	0	0	28,671	29.44		28,997	35.87		0	0	0
Sub Total=>	41,336	4,565	0	45,901	47.13	*	38,880	48.09	*	0	0	0
Ceiling Load	5,611	-5,611		. 0	0.00	*	5,679	7.02	*	-5,527	0	0
utside Air	0	0	0	0		*	0	•	*	0	0	0
Sup. Fan Heat				Ó	0.00	*	-	0.00	*		0	0
et. Fan Heat		0		Ő	0.00	*			*		0	0
uct Heat Pkup		Ő		Ō		*			*		0	0
W/UNDR Sizing	0	-		0	0.00	*	0	-	*	0	0	0
xhaust Heat		0	0	0	0.00	*	-		*		0	0
Terminal Bypass		0	0	. 0	0.00	*			*		0	0
Frand Total=>	97,386	٥	0	97,386	100.00	* *	80,848	100.00	*	-100,085	-100,085	100
			ING COIL SELF	······							AREAS	
Total	Capacity		Coil Airfl		g DB/WB/	170	Leaving I	מען מאל מר		Gross Total	Glass (s:	Í) (

	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total	Glass	(sí)	(%)
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	2,150			
Main Clg	8.1	97.4	80.4	4,373	78.2	65.0	73.9	60.7	57.8	69.2	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0	0
Totals	8.1	97.4									Wall	2,085		240	12

	HEATING (COLL SELECTIC	N		A	IRFLOWS (cf	m)	ENGINEERING (CHECKS-	-TEMPERA	TURES	(F) —
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	2.03	SADB	60.9	125.0
Main Htg	-100.1	1,620	68.0	125.0	Infil	546	546	Clg Cfm/Ton	538.83	Plenum	86.2	59.9
Aux Htg	0.0	0	0.0	0.0	Supply	4,373	1,620	Clg Sqft/Ton	264.93	Return	78.0	68.0
Preheat	0.0	4,373	68.0	60.4	Mincim	0	0	Clg Btuh/Sqft	45.30	Ret/QA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	4,373	1,620	No. People	15	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	4,373	0	Htg 3 QA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	100	0	Htg Cfm/SqFt	0.75	In BlaD	0.1	0.0
Total.	-100.1				Auxil	0	0	Htg Btuh/SqFt	-46.55	Fn Frict	0.4	0.0



)

System 4 Block FC - FAN COIL

Peaked at Time =	>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/15	*	Ma	/Hr: 13/ 1	
Dutside Air ⇒>	QAL	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	c	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perant	*	Space	Total	Perch
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of To
Invelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(9
Skylite Solr	` 0	0		0	0.00	*	0	0.00	*	0	- 0	0.0
Skylite Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Roof Cand	7,581	0		7,581	41.43	*	7,581	53.53	*	-8,381	-8,381	0.0
Glass Solar	602	0		602	3.29	*	602	4.25	*	0	0	0.0
Glass Cond	234	0		234	1.28	*	234	1.65	*	-1,024	-1,024	5.5
Wall Cond	910	0		910	4.97	*	910	6.42	*	-4,254	-4,254	22.8
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Infiltration	4,985			4,985	27.24	*	1,365	9.64	*	-4,931	-4,931	26.5
Sub Total=>	14,312	0		14,312	78.22	*	10,693	75.49	*	-18,589	-18,589	100.0
Internal Loads						*	,		*			
Lights	768	307		1,075	5.88	*	768	5.42	*	0	0	0.0
People	0			0	0.00	*	0	0.00	*	0	0	0.0
Misc	2,703	0	0	2,703	14.77	*	2,703	19.08	*	0	0	0.0
Sub Total=>	3,471	307	0	3,778	20.65	*	3,471	24.51	*	0	0	0.0
Ceiling Load	0	0		0	0.00	*	. 0	0.00	*	0	0	0.0
utside Air	• 0	0	0	. 0	0.00	*	0	0.00	*	0	0	0.0
Sup. Fan Heat				184	1.01	*		0.00	*		0	0.0
Ret. Fan Heat		24		24	0.13	*		0.00	*		0	0.0
uct Heat Pkup		0		0	0.00	*		0.00	*		0	0.0
W/UNDR Sizing	0			0	0.00	*	0	0.00	*	0	0	0.0
xhaust Heat		0	0	0	0.00	*		0.00	*		0	0.0
Cerminal Bypass		0	0	0	0.00	*		0.00	*		0	0.0
						*			*			
rand Total->	17,783	331	0	18,298	100.00	*	14,164	100.00	*	-18,589	-18,589	100.0
			ING COIL SEL	ECITION					-		AREAS	
Total	Capacity		Coil Airfl		g DB/WB/	uD	Leaving	מנו/ בוגו/ בו	(Gross Total	Glass (s:	£) (%)

	Total C	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total (Glass	(sf)	(%)
	(Tons)	(Moh)	(Mch)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	305			
Main Clg	1.5	18.3	14.7	300	78.2	56.7	36.1	34.1	28.8	16.2	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	377		0	0
Totals	1.5	18.3									Wall	174		25	14

	HEATING (DIL SELECTIO	N		A	JRFLOWS (cfi	m) (m	ENGINEERING	HECKS-	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & OA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	0.98	SADB	34.4	125.0
Main Htg	-18.6	301	68.0	125.0	Infil	70	70	Clg Cfm/Ton	196.74	Plenum	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	301	Clg Sqft/Ton	200.02	Return	78.0	68.0
Preheat	0.0	300	68.0	33.9	Mincfm	300	0	Clg Btuh/Sqft	59.99	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	300	301	No. People	0	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	70	0	Htg 3 OA	0.0	Fn MirID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	50	0	Htg Cfm/SaFt	0.99	Fn BldID	0.1	0.0
Total	-18.6				Auxil	0	0	Htg Btuh/SqFt	-60.95	Fn Frict	0.4	0.0

V 600 PAGE 7



System 5 Block FC - FAN COIL

.

Peaked at Time		Mo/Hr: 7	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air >	QAL	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perat	: *	Space	Total	Pera
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of To
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(욱)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(१
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	- O	0.0
Skylite Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Roof Cand	3,982	0		3,982	38.51	*	3,982	48.41	*	-4,402	-4,402	0.0
Glass Solar	302	0		302	2.92	*	302	3.68	*	0	0	0.0
Glass Cond	118	0		118	1.14	*	118	1.43	*	-514	-514	5.3
Wall Cond	443	0		443	4.29	*	443	5.39	*	-2,073	-2,073	21.6
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Infiltration	2,024			2,024	19.57	*	722	8.77	*	-2,606	-2,606	27.1
Sub Total=>	6,869	0		6,869	66.43	*	5,567	எ .எ	*	-9, 595	-9,595	100.0
Internal Loads						*			*			
Lights	1,038	415		1,453	14.05	*	1,038	12.61	*	0	0	0.0
People	388			388	3.75	*	198	2.40	*	0	0	0.0
Misc	1,424	0	0	1,424	13.77	*	1,424	17.31	*	0	0	0.0
Sub Total=>	2,849	415	0	3,264	31.56	*	2,659	'32.33	*	. 0	0	.0.0
Ceiling Load	0	0		0	0.00	*	0	0.00	*	0	0	0.0
lutside Air	0	· 0	0	0	. 0.00	*	0	0.00	*	0	0	0.0
Nup. Fan Heat				184	1.78	*		0.00	*		0	0.0
Ret. Fan Heat		24		24	0.23	*		0.00	*		0	0.0
Juct Heat Phip		0		0	0.00	*		0.00	*		0	0.0
W/UNDR Sizing	0			0	0.00	*	0	0.00	*	0	0	0.0
xhaust Heat		0	0	0	0.00	*	-	0.00	*	-	. 0	0.0
erminal Bypass		0	0	0	0.00	*		0.00	*		0	0.0
			-	·		*			*		•	
Frand Total=>	9,718	439	0	10,341	100.00	*	8,226	100.00	*	-9,595	-9,595	100.0
			ING COIL SEL	ECTTON					_		AREAS	
Total	L Capacity		Coil Airfl		g DB/WB/			DB/WB/HR		Gross Total	Glass (s	Î) (%)

	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering [B/WB/HR	Lea	wing DE	3/WB/HR	Gross	Total	Glass ((sî)	(୫)
	(Tons)	(Moh)	(Mbh)	(cím)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	160			
Main Clg	0.9	10.3	8.8	300	78.2	62.2	60.4	52.3	49.8	50.9	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	198		0	0
Totals	0.9	10.3									Wall	85		13	15

	HEATING (COLL SELECTIO	N	<u> </u>	A	IRFLOWS (cf	m)	-ENGINEERING	HECKS	-TEMPERA	TURES	(F) —–
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	1.88	SADB	52.7	125.0
Main Htg	-9.6	155	68.0	125.0	Infil	37	37	Clg Cfm/Ton	348.14	Plenum	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	155	Clg Sqft/Ton	185.67	Return	78.0	68.0
Preheat	0.0	300	68.0	52.1	Mincfm	300	0	Clg Btuh/Sqft	64.63	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	300	155	No. People	1	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	37	0	Htg & OA	0.0	Fn MerID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Ra Exh	37	0	Htg Cfm/SqFt	0.97	Fn BldID	0.1	0.0
Total	-9.6				Auxil	0	0	Htg Btuh/SqFt	-59.97	Fn Frict	0.4	0.0



•

)

· V 600

System 6 Block FC - FAN COIL

Peaked at T	ime ==>		Mo/Hr:	7/15			*	Mc	/Hr:	7/15	*	Mo/H	hr: 13/ 1	
Outside Air	==>	OAD	B/WB/HR:	96/ 77/112.	0		*	c	ADB:	96	*	OAL	DB: 3	
		Space	Ret. Air	r Ret. Air	Ne	t Peran	* :: *	q	cace	Perant	* <	pace	Total	Perc
	Ser	ns.+Lat.	Sensible		Tota				ible	Of Tot		ible	Sensible	Of T
Envelope Lo		(Btuh)	(Btuh)		(Btub				Stuh)			stuh)	(Btuh)	
Skylite S	olr	0)	•	0 0.00		(0	0.00	, _	0		0.
Skylite C	and	0		2		0 0.00			ŏ	0.00		ů	o o	0.
Roof Cond	L	5,148	(5	5,14			5	5,148	a.79	* -5	691	-5,691	0.
Glass Sol	ar	302	(2	30		-	-	302	3.63		0	0	0.
Glass Con	d	118	(2	11				118	1.41	۲	-514	-514	4.
Wall Cond		611	()	ส				611	7.34	•	, 858	-2,858	23.
Partition	L	0				0 0.00			0	0.00 7		0	0	0.
Exposed F.	lœr	0				0 0.00			õ	0.00 ,	۲	õ	ō	0.
Infiltrat		2,539			2,53				917	11.00		, 311	-3,311	26.
Sub Total		8,718	()	8,71			7	,096	85.17		, 373	-12,373	100.0
Internal Lo	ads	-,	•	•	0, 1		*	,	,050	,		,	12,070	2007
Lights		1,038	415	5	1,45	3 13.49		1	,038	12.45 '	*	0	0	0.
People		388	11.		38			-	198	2.37		å	0	0.
Misc	·	0	C) 0		0 0.00			190	0.00 *		õ	0	0.
Sub Total	>	1,425	415	•	1,84	-		1	,235	14.83 *		õ	ő	0.
Ceiling Load		-,		-	•	0 0.00		-	0	0.00 *		· 0	ő	0.
utside Air		· 0	0			0 0.00			õ	0.00 *		õ	ő	0.0
Sup. Fan Hea		•		- 0	18				0	0.00 *		v	ő	0.0
Ret. Fan He			24	1		4 0.22				0.00 *			o o	0.0
Juct Heat Pl						0 0.00				0.00 *			ŏ	0.0
W/UNDR Siz	+	0		-		0 0.00	-		0	0.00 *		0	õ	0.0
Exhaust Heat	-	-	c) o		0 0.00			v	0.00 *		J.	0	0.0
eminal By			0	-		0 0.00				0.00 *	,		Ő	0.0
	•		,	. .		- 0.00	- *			*			Ŭ	•••
rand Total=		10,143	439	• 0	10,76	6 100.00) *	8	,331	100.00 *	-12	, 373	-12,373	100.
				LING COIL SI	ELECTION-								EAS	
2	Total Ca	pacity	Sens Cap.	Coil Airfl		ing DB/WE	3/HR	Lea	ving I)B/WB/HR	Gross To	,	Glass (s	f) (*
(1	Tons)	(Moh)	(Moh)	(cfm)	Deg F D	eg F Gra	uins	Deg F	Deg I	Grains	Floor	207		
uin Clg	0.9	10.8	9.0	300	78.2	62.4 6	51.4	52.0	49.6	5 50.3	Part	0		
x Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0		
ot Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	256	i	0
tals	0.9	10.8									Wall	113	;	13 :
I	HEATING	COIL SELEC	CITION		A	IRFLOWS ((cfm)	**		ENGINEERING	: CHECKS	TE	MPERATURE	S (F)-
Ca	apacity	Coil Ai	rfl Ent	Lvg	Type	Cooling	Ŧ	Heating	C	Lg % QA	0.0	Ty	pe Clg	Hta
	(Mbh)	(cfm) Deg F	Deg F	Vent	č)	Ō	C	Lg Cfm/Sqft	1.45	SADB	52.	4 125
in Htg	-12.4	2	00 68.0	125.0	Infil	47	7	47		lg Cfm/Ton	334.38	Plen	um 78.	0 68
x Htg	0.0		0 0.0	0.0	Supply	300)	200		lg Sqft/Ton	230.72			0 68
eheat	0.0	3	68.0	51.8	Mincim	300		0		lg Btuh/Sqft		Ret/	OA 78.	0 68
heat	0.0		0 0.0	0.0	Return	299		200		. People	1			0 68
midif	0.0		0 0.0		Exhaust	47		0		cq % OA	0.0			
t Vent	0.0		0 0.0		Rn Exh	48		Ō		g Cfm/SqFt	0.97	Fn B		1 0.
tal	-12 4				3			v		a Dhah (Cath	-50 79			

Auxil

0



-

Total

-12.4

V 600 PAGE 9

0 Htg Btuh/SqFt -59.78 Fn Frict 0.4 0.0

System 7 Block FC - FAN COLL

Peaked at	t Time ==>		Mo/Hr:	7/15			*	Mo	/Hr:	7/15	×	M	o/Hr: 13	3/1	
Jutside A	Air ==>	QAE	B/WB/HR:	96/ 77/112.	0		*		ADB:		*		DADB:	3	
		_					*				*				
	0.	Space	Ret. Air		Net		*		pace	Perat		Space		tal	Perc
		ns.+Lat.	Sensible		Total	Of Tot	*		ible		*	Sensible	Sensi		of :
Invelope		(Btuh) 0	(Btuh)	(Btuin)	(Btuh)	(%)	*	(B	ituh)	(•)	*	(Btuh)	(Bt	uh)	
Skylite		•	0		0	0.00	*		0		*	0		0	0
Skylite		0	0		0	0.00	*		0	0.00	*	0		0	0
Roof Co Glass S		3,982	0		3,982	45.26	*	3	,982	30.10	*	-4,402	-4,	402	0
		302	0		302	3.44	*		302		k r	0		0	0
Glass (118	0		118	1.34	*		118		* .	-514		51.4	5
Wall Co		460	0		460	5.23	*		460	6.44		-2,152	-2,	152	22
Partiti		0			0	0.00	*		0	0.00		0		0	0
Exposed		0			0	0.00	*		0	0.00		0		0	0
Infiltr		1,861	_		1,861	21.15	*		722	10.10		-2,606		606	26
Sub Tot		6,722	0		6,722	76.41	*	5	,584	78.15		-9,674	-9,	674	100
nternal	Loads						*								
Lights		768	307		1,075	12.22	*		768	10.75		0		0	G
People		0			0	0.00	*		0	0.00		0		0	C
Misc	•	793	0	•	793	9.01	*		793	11.10		0		0	0
Sub Tot		1,561	307	-	1,868	21.23	*•	. 1	,001	· 21.85		0		0	0
eiling I		0	0		. 0	0.00	*		0	0.00	۲	ò		0	. 0
utside A		0	0	0	0	0.00	*		0	0.00	*	0		0	0
up. Fan					184	2.09	*			0.00	*			0	0
et. Fan			24		24	0.27	*			0.00	r			0	0
uct Heat	•		0		0	0.00	*			0.00	r			0	0
V/UNDR S	,	0			0	0.00	*		0	0.00	r	0		0	0
xhaust H			0	-	0	0.00	*			0.00	•			0	0
eminal	Bypass		0	0	0	0.00	*			0.00	٢			0	0
rand Tot	al=>	8,283	331	0	8,798	100.00	*	7	,144	100.00	r r	-9,674	-9,	674	100
				LING COIL SI	FT FCTTCN								AREAS		
	Total Ca	pacity	Sens Cap.	Coil Airfl		g DB/WB	'HR	Leav	ving [B/WB/HR	Gre	ss Total		s (sf) (
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F Dec	-		Deg F	Deg E		Flœ	r 1	.60		
in Clg	0.7	8.8	7.7	300		.5 66	5.8	55.7	53.6		Part		0		
c Clg	0.0	0.0	0.0	0			0.0	0.0	0.0		ExFl		0		
t Vent	0.0	0.0	0.0	0			0.0	0.0	0.0		Roof		98		0
als	0.7	8.8						•••			Wall		88		13
	HEATING	COIL SELE	CTION		AIF	FLOWS (c	:fm) -			ENGINEERIN	CHEC	xs	TEMPERA	IURES	(F)
	Capacity	Coil Ai	rfl Ent	Lvg	Type	Cooling	F	leating	C	g * QA		0.0	Type	Clg	Н
	(Mch)	(cfm) Deg F	Deg F	Vent	ō		Ō	Cl	.g Cfm/Sqft		1.88 SA	DB	56.0	12
in Htg	-9.7	1	57 68.0	125.0	Infil	37		37	Cl	g Cfm/Ton	40	9.18 Pl	enum	78.0	6
(Htg	0.0		0 0.0	0.0	Supply	300		157		g Sqft/Tan	21	8.23 Re	tum	78.0	6
eheat	0.0	3	00 68.0	55.5	Mincfm	300		0		g Btuh/Sqft			t/OA	78.0	6
leat	0.0		0 0.0	0.0	Return	300		157		. People		0 Ru	namd	78.0	6
nidif	0.0		0 0.0	0.0	Exhaust	37		0		a * OA			MeriD	0.1	
t Vent	0.0		0 0.0	0.0	Rm Exh	37		0		g Cfm/SaFt			BLCID	0.1	
al	-9.7				Auxil			-							

.



/

V 600 PAGE 10

System 8 Block FC - FAN COIL

**********	************ @	XOLING COIL	PEAK *******	*******	*******	***	**** CLG SPAC	E PEAK ***	***	****** HEATING	COIL PEAK	******
Peaked at Time :	>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air =>	QAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perat	*	Space	Perant	*	Space	Total	Perat
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(웅)	*	(Btuh)	(Btuh)	(%)
Skylite Salr	0	0		0	0.00	*	0	0.00	*	0	^ O	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	G	٥	0.00
Roof Cand	9,407	0		9,407	50.64	*	9,407	ഖ.39	*	-9,292	-9,292	0.00
Glass Solar	36	0		36	0.19	*	36	0.23	*	0	0	0.00
Glass Cond	118	0		118	0.63	*	118	0.77	*	-508	-508	2.75
Wall Cond	1,169	0		1,169	6.30	*	1,169	7.63	*	-3,154	-3,154	17.10
Partition	0			0	0.00	×	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	3,546			3,546	19.09	*	1,521	9.93	*	-5,494	-5,494	29.78
Sub Total=>	14,275	0		14,275	76.85	*	12,251	79.95	*	-18,449	-18,449	100.00
Internal Loads						*			*			
Lights	3,072	1,229		4,300	23.15	*	3,072	20,05	*	0	0	0.00
People	0			0	0.00	*	0	0.00	*	0	0	0.00
Misc	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total=>	3,072	· 1,229	0	4,300	23.15	*	3,072	20.05	*	0	0	0.00
Ceiling Load	0	0		0	0.00	*	0	0.00	*	0	. 0	0.00
Outside Air	0	0	· 0	0	0.00	*	0	0.00	*	0	0	0.00
Sup. Fan Heat				0	0.00	*		0.00			0	0.00
Ret. Fan Heat		0		0	0.00	*		0.00	*		0	0.00
Duct Heat Plup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0		*	0	0	0.00
Exhaust Heat		0	0	Ő	0.00	*	, i		*	·	0	0.00
Terminal Bypass		0	0	Ő	0.00	*			*		0 0	0.00
44		· ·	÷	Ŭ		*			*		·	
Grand Total=>>	17,347	1,229	0	18,576	100.00	*	15,323	100.00	*	-18,449	-18,449	100.00

										AREAS					
	Total Capacity		Sens Cap.	Coil Airfl	Entering DB/WB/HR		Leaving DB/WB/HR			Gross Total		lass (sf) ((%)	
	(Tons)	(Moh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	338			
Main Clg	1.5	18.6	16.6	893	78.2	65.0	73.9	61.8	58.3	69.5	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	418		0	0
Totals	1.5	18.6									Wall	128		18	14

HEATING COIL SELECTION					A	JRFLOWS (cfr	n)					
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	2.64	SADB	62.2	125.0
Main Htg	-18.4	299	68.0	125.0	Infil	78	78	Clg Cfm/Ton	576.76	Plenim	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	893	299	Clg Sqft/Ton	218.35	Return	78.0	68.0
Preheat	0.0	893	68.0	61.6	Mincfin	0	0	Clg Btuh/Sqft	54.96	Ret/CA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	893	299	No. People	0	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	78	0	Htg 3 QA	0.0	Fn MerID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	78	0	Htg Cfm/SqFt	0.88	Fn BldID	0.1	0.0
Total	-18.4				Auxil	0	0	Htg Btuh/SqFt	-54.58	Fn Frict	0.4	0.0



:

•

.



.



V 600 PAGE 11

System 9 Block FC - FAN COIL

Peaked at Time =	=>	Mo/Hr: 7	//15			*	Mo/Hr:	7/16	*	Mo	/Hr: 13/ 1	
Outside Air =>	OAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	٥	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Percnt	*	Space	Perant	*	Space	Total	Perch
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(ક
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Skylite Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Roof Cand	4,568	0		4,568	39.96	*	4,442	42.68	*	-4,113	-4,113	0.0
Glass Solar	1,588	٥		1,588	13.89	*	1,688	16.23	*	0	0	0.0
Glass Cond	235	0		235	2.06	*	234	2.25	*	-1,028	-1,028	7.7
Wall Cond	1,684	0		1,684	14.73	*	1,755	16.87	*	-5,821	-5,821	43.5
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Infiltration	1,546			1,546	13.52	*	645	6.20	*	-2,395	-2,395	17.9
Sub Total=>	9,620	0		9,620	84.15	*	8,764	84.22	*	-13,357	-13,357	100.0
Internal Loads						*	•		*			
Lights	0	0		0	0.00	*	0	0.00	*	0	0	0.0
People	388			388	3.39	*	202	1.95	*	0	0	0.0
Misc	1,424	0	0	1,424	12.45	*	1,440	13.84	*	0	0	0.0
Sub Total==>	1,811	· · 0	0	1,811	15.85	*	1,642	15.78	*	· 0	0 ·	0.0
Ceiling Ioad	0	0		0	0.00	*	. 0	0.00	*	. 0	0	0.0
Outside Air	0	0	0	0	0.00	* `	• 0	0.00	*	0	0	0.0
Sup. Fan Heat				0	0.00	*		0.00	*		0	0.0
Ret. Fan Heat		0		0	0.00	*			*		0	0.0
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.0
OV/UNDR Sizing	0			Ó	0.00	*	0		*	0	0	0.0
Exhaust Heat		0	0	0	0.00	*			*	-	0	0.0
Terminal Bypass		0	0	0	0.00	*			*		0	0.0
Grand Total->	11,432	0	0	11,432	100.00	*	10,406	100.00	*	-13,357	-13,357	100.0

			u	DEING COIL, SE	ILCLICK							AR	ZAS		
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total	Glass	(sf)	(ક)
	(Tons)	(Mbh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	150			
Main Clg	1.0	11.4	10.4	656	78.2	65.0	73.9	63.0	59.4	72.5	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Rcof	185		0	0
Totals	1.0	11.4									Wall	229		25	11

	HEATING (COLL SELECTIO	N		P	JRFLOWS (cf	m)	ENGINEERING (HECKS	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Mbh)	(cím)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	4.37	SADB	63.4	125.0
Main Htg	-13.4	216	68.0	125.0	Infil	34	34	Clg Cfm/Ton	688.12	Plenum	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	656	216	Clg Sqft/Ton	157.46	Return	78.0	68.0
Preheat	0.0	656	68.0	62.8	Mincín	0	0	Clg Btuh/Sqft	76.21	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	655	216	No. People	1	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	34	0	Htg % CA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	35	0	Htg Cfm/SqFt	1.44	Fn BlcID	0.1	0.0
Total	-13.4				Auxil	0	0	Htg Btuh/Saft	-89.05	Fn Frict	0.4	0.0

V 600





System 10 Block FC - FAN COIL

********		XILING COIL	PEAK *******	*******	*******	***	**** CLG SPAC	E PEAK ***	****	****** HEATING	COIL PEAK	******
Peaked at Time	=>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air ==>	QAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						×			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perat	: *	Space	Total	Percnt
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Roof Cand	7,260	0		7,260	42.00	*	7,260	51.26	*	-6,536	- 6,536	0.00
Glass Solar	529	. 0		529	3.06	*	529	3.74	*	0	0	0.00
Glass Cond	118	0		118	0.68	*	118	0.83	*	-514	-514	3.61
Wall Cond	889	0		889	5.14	*	889	6.28	*	-3,302	-3,302	23.21
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	3,987			3,987	23.06	*	1,073	7.57	*	-3,874	-3,874	27.23
Sub Total->	12,782	0		12,782	73.95	*	9,868	69.68	*	-14,226	-14,226	100.00
Internal Loads						*	·		*			
Lights	0	0		0	0.00	*	0	0.00	*	0	0	0.00
People	. 0			0	0.00	*	0	0.00	*	0	0	0.00
Misc	4,295	0	0	4,295	24.85	*	4,295	30.32	*	0	0	0.00
Sub Total=>	4,295	0	0	4,295	24.85	*	4,295	30.32	*	0	0	0.00
Ceiling Load	0	0		0	0.00	*	0	0.00	*	• 0	0	0.00
Outside Air	• 0	0	0	0	0.00	*	0	0.00	*	. 0	0	0.00
Sup. Fan Heat				184	1.06	*		0.00	*		0	0.00
Ret. Fan Heat		24		24	0.14	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0	0.00	×	-	0.00	*		٥	0.00
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
				-		*			*			
Grand Total=>	17,077	24	0	17,285	100.00	*	14,163	100.00	*	-14,226	-14,226	100.00

				LING COIL SE	LECTION							ARE	AS		
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross To	tal (Glass (s	f) ((%)
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	238			
Main Clg	1.4	17.3	14.4	300	78.2	56.2	34.3	34.1	30.0	19.2	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	294		0	0
Totals	1.4	17.3									Wall	128		13	10

	HEATING	DIL SELECTIO	N		A	IRFLOWS (cf	m)	ENGINEERING	HECKS	TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % CA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.26	SADB	34.4	125.0
Main Htg	-14.2	230	68.0	125.0	Infil	55	55	Clg Cfm/Ton	208.27	Plenum	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	230	Clg Sqft/Tan	165.23	Return	78.0	68.0
Preheat	0.0	300	68.0	33.9	Mincim	300	0	Clg Btuh/Sqft	72.63	Ret/QA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	300	230	No. People	0	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	55	0	Htg 3 QA	0.0	Fn MariD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	55	0	Htg Cfm/SqFt	0.97	Fn BldID	0.1	0.0
Total	-14.2				Auxil	0	0	Htg Btuh/SqFt	-59.77	Fn Frict	0.4	0.0



System 11 Block FC - FAN COIL

•

Peaked at Time	=>	Mo/Hr:	7/15			*	M	o/Hr:	7/15	*	M	o/Hr: 13/ 1		
Outside Air ==>	04	DB/WB/HR: 9	6/ 77/112.0			*	· .	OADB:	96	*	Ċ	CADB: 3		
						*				*				
	Space		Ret. Air	Ne	t Pe	rant *		Space	Perant	*	Space	Total	Pe	era
	Sens.+Lat.	Sensible	Latent	Tota	l of	Tot *	Sen	sible	Of Tot	*	Sensible	Sensible	Of	ΕT
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%) *	(1	Btuh)	(%)	*	(Btuh)	(Btuh)		(*
Skylite Solr	0	0			0	0.00 *		0	0.00	*	0	0		0.0
Skylite Cand	0	0			0	0.00 *		0	0.00	*	C	0		0.0
Roof Cond	6,445	0		6,44	5 5	3.47 *		6,445	59.63	*	-5,802	-5,802		0.0
Glass Solar	1,054	0		1,05	4	8.75 *		1,054	9.75	*	0	0		0.0
Glass Cond	234	0		23	4	1.94 *		234	2.17	* .	-1,024	-1,024		8.0
Wall Cond	690	0		69	0 3	5.73 *		690	6.39	*	-2,564	-2,564	2	20.0
Partition	0				0 (0.00 *		0	0.00	*	0	0		0.0
Exposed Floor	0				0 (0.00 *		0	0.00	*	0	0		0.0
Infiltration	2,182			2,18	2 1	8.10 *		936	8.66	*	-3,381	-3,381	2	26.4
Sub Total=>	10,606	0		10,60	6 8	7.99 *	9	9,360	86.61	*	-12,772	-12,772	10	0.0
Internal Loads						*		•		*				
Lights	0	0			0 (0.00 *		0	0.00	*	0	0		0.0
People	0			1	0 0	0.00 *		0	•	*	0	0		0.0
Misc	1,448	0	0	1,44	8 12	2.01 *		L.448		*	0	0		0.0
Sub Total=>	1,448	0	0	1,44		2.01 *		1,448		*	0	0		0.0
Ceiling Load	Q	0				0.00 *		0.		*	0	0		0.0
Dutside Air	0	0	0			0.00 *		0	-	*	0	0		0.0
Sup. Fan Heat						0.00 *		-		*		0		0.0
Ret. Fan Heat		0		1		0.00 ×				*		0		0.0
Juct Heat Phip		0				0.00 ×				*		0		0.0
W/UNDR Sizing	0			(2.00 *		0		*	0	0		0.0
Exhaust Heat		0	0			0.00 ×		•		*	•	0 0		0.0
Cerminal Bypass		0	0	(0.00 ×				*		0		0.0
						*				*		-		
Grand Total->	12,053	0	0	12,05	3 100	0.00 *	10	,808	100.00	*	-12,772	-12,772	10	0.0
			ING COIL SEI	ECIION								AREAS		
	Capacity	Sens Cap.	Coil Airfl	Enter	ing DE	3/WB/HR			B/WB/HR	Gre	ss Total	Glass (s	;f)	(%)
(Tans)		(Mbh)	(cím)	Deg F De	eg F	Grains	Deg F	Deg F	Grains	Flœ	r 2	11		
in Clg 1.0		10.8	646	78.2	55.0	73.9	62.2	59.0	72.0	Part	:	0		
x Clg 0.0		0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFl	r	0		
ot Vent 0.0		0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	2	61	0	
tals 1.0	12.1									Wall	. 1	15	25	2

Capacity (Mbh) Coil Airfl Ent Lvg Type Cooling Heating Clg % OA 0.0 Type Clg Htg (Mbh) (cfm) Deg F Deg F Vent 0 0 Clg % OA 0.0 Type Clg Htg Main Htg -12.8 207 68.0 125.0 Infil 48 48 Clg Cfm/Sqft 3.06 SADB 62.6 125.0 Aux Htg 0.0 0 0.0 Supply 646 207 Clg Sqft/Ton 210.07 Return 78.0 68.0 Preheat 0.0 646 68.0 62.0 Mincfm 0 0 Clg Sqft/Ton 210.07 Return 78.0 68.0 Preheat 0.0 646 68.0 62.0 Mincfm 0 0 Clg Sqft/Ton 210.07 Return 78.0 68.0 Reheat 0.0 0.0 Return 646 207 No. People 0 Rurand <						- 6							(L) ———
Main Htg -12.8 207 68.0 125.0 Infil 48 48 Clg Cfm/Ton 643.30 Plenum 78.0 68.0 Aux Htg 0.0 0 0.0 0.0 Supply 646 207 Clg Saft/Tan 20107 Return 78.0 68.0 Preheat 0.0 646 68.0 62.0 Mincfm 0 0 Clg Saft/Tan 210.07 Return 78.0 68.0 Preheat 0.0 646 68.0 62.0 Mincfm 0 0 Clg Btuh/Saft 57.12 Ret/QA 78.0 68.0 Reheat 0.0 0 0.0 Return 646 207 No. People 0 Runarnd 78.0 68.0 Humidif 0.0 0 0.0 Exhaust 48 0 Htg % QA 0.0 Fn MtrTD 0.1 0.0 Qpt Vent 0.0 0.0 0.0 Rm Exh 49 0 Htg Cfm/Saft 0.98 Fn BldTD 0.1 0.0		Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & OA	0.0	Type	Clg	Htg
Aux Htg 0.0 0 0.0 0.0 Supply 646 207 Clg Saft/Tan 210.07 Return 78.0 68.0 Preheat 0.0 646 68.0 62.0 Minafm 0 0 Clg Saft/Tan 210.07 Return 78.0 68.0 Preheat 0.0 0 0.0 0.0 Return 646 207 No. People 0 Runarnd 78.0 68.0 Humidif 0.0 0 0.0 Return 646 207 No. People 0 Runarnd 78.0 68.0 Humidif 0.0 0 0.0 Return 646 207 No. People 0 Runarnd 78.0 68.0 Opt Vent 0.0 0 0.0 Rm Exh 48 0 Htg % QA 0.0 Fn MtrTD 0.1 0.0 Opt Vent 0.0 0.0 Rm Exh 49.0 Htg Cfm/SqFt 0.98 Fn BldTD 0.1 0.0		(Mbh)	(cfm)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	3.06	SADB	62.6	125.0
Preheat 0.0 646 68.0 62.0 Mincfm 0 0 Clg Btuh/Sqft 57.12 Ret/QA 78.0 68.0 Reheat 0.0 0 0.0 0.0 Return 646 207 No. People 0 Runarnd 78.0 68.0 Humidif 0.0 0 0.0 Exhaust 48 0 Htg % QA 0.0 Fn MtrTD 0.1 0.0 Opt Vent 0.0 0.0 Rm Exh 49.0 Htg % Gft 0.98 Fn BldTD 0.1 0.0	Main Htg	-12.8	207	68.0	125.0	Infil	48	48	Clg Cfm/Ton	643.30	Plenum	78.0	68.0
Reheat 0.0 0 0.0 0.0 Return 646 207 No. People 0 Rinarnd 78.0 68.0 Humidif 0.0 0 0.0 0.0 Exhaust 48 0 Htg % QA 0.0 Fn MtrTD 0.1 0.0 Opt Vent 0.0 0 0.0 Rm Exh 49 0 Htg Cfm/SqFt 0.98 Fn BldTD 0.1 0.0	Aux Htg	0.0	0	0.0	0.0	Supply	646	207	Clg Saft/Ton	210.07	Return	78.0	68.0
Humidif 0.0 0 0.0 0.0 Exhaust 48 0 Htg % QA 0.0 Fn MtrTD 0.1 0.0 Opt Vent 0.0 0 0.0 Rm Exh 49 0 Htg Cfm/SqFt 0.98 Fn BldTD 0.1 0.0	Preheat	0.0	646	68.0	62.0	Mincím	0	0	Clg Btuh/Sqft	57.12	Ret/OA	78.0	68.0
Opt Vent 0.0 0 0.0 Rm Exh 49 0 Htg Cfm/SqFt 0.98 Fn BldID 0.1 0.0	Reheat	0.0	0	0.0	0.0	Return	646	207	No. People	0	Runamd	78.0	68.0
	Humidif	0.0	0	0.0	0.0	Exhaust	48	0	Htg & OA	0.0	Fn MtrID	0.1	0.0
Total -12.8 Auxil 0 0 Htg Btuh/Soft -60.53 Fn Frict 0.4 0.0	Opt Vent	0.0	0	0.0	0.0	Rm Exh	49.	0	Htg Cfm/SqFt	0.98	Fn BldID	0.1	0.0
	Total	-12.8				Anxil	0	0	Htg Btuh/SqFt	-60.53	Fn Frict	0.4	0.0



V 600





System 12 Block FC - FAN COIL

Peaked at Time	>	Mo/Hr: 7	//15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air ==>	OAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*			*			
	Space		Ret. Air	Net	Perant	*	Space	Percnt	*	Space	Total	Perch
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Skylite Cond	0	0		0	0.00	*	0	0.00	*	C	0	0.0
Roof Cand	6,445	0		6,445	51.66	*	6,445	62.49	*	-5,802	-5,802	0.0
Glass Solar	529	0		529	4.24	*	52 9	5.13	*	0	0	0.0
Glass Cond	118	0		118	0.94	*	118	1.14	*	-514	-514	4.0
Wall Cond	786	0.		786	6.30	*	786	7.63	*	-2,921	-2,921	23.1
Partition	0			0	0.00	×	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Infiltration	2,892			2,892	23.18	*	936	9.08	*	-3,381	-3,381	26.80
Sub Total=>	10,770	0		10,770	86.32	*	8,814	85.47	*	-12,618	-12,618	100.00
Internal Loads						*			*			
Lights	0	0		0	0.00	*	0	0.00	*	0	0	0.0
People	0			0	0.00	*	0	0.00	*	0	0	0.00
Misc	1,499	0	0	1,499	12.01	*	1,499	14.53	*	0	0	0.00
Sub Total=>	1,499	. 0	. 0	1,499	12.01	*	1,499	14.53	*	0	0	0.0
Ceiling Load	0	0		0	0.00	*	. 0	0.00	*	0	0	0.0
Outside Air ·	0	0	0	0		*	0	0.00	*	0	0	0.00
Sup. Fan Heat				184		*			*		0	0.00
Ret. Fan Heat		24		24		*		0.00	*		0	0.00
Duct Heat Phup		0		0	0.00	*		0.00	*		0	0.00
W/UNDR Sizing	0			0		*	0		*	0	0	0.00
Exhaust Heat		0	0	õ	0.00	*	ů	0.00	*	Ŭ	õ	0.00
ferminal Bypass		0	ō	Ő	0.00	*		0.00	*		0	0.00
						*			*			
Grand Total=>	12,268	24	0	12,476	100.00	*	10,313	100.00	*	-12,618	-12,618	100.00
			ING COIL SELE								AREAS	

						•										
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total	Glass	(sf)	(%)	
	(Tons)	(Moh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	211				
Main Clg	1.0	12.5	10.5	300	78.2	60.4	52.2	45.9	44.5	42.3	Part	0				
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0				
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	261		0	0	
Totals	1.0	12.5									Wall	115		13	11	

	HEATING (DIL SELECTIO	N	•••••	A	IRFLOWS (cf	m)	ENGINEERING	HECKS-	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & OA	0.0	Type	Clg	Htg
	(Mbh)	(cím)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	1.42	SADB	46.3	125.0
Main Htg	-12.6	204	68.0	125.0	Infil	48	. 48	Clg Cfm/Ton	288.55	Plenim	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	204	Clg Sqft/Ton	202.95	Return	78.0	68.0
Preheat	0.0	300	68.0	45.7	Mincim	300	0	Clg Btuh/Sqft	59.13	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	299	204	No. People	0	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	48	0	Htg * OA	0.0	Fn MariD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	49	0	Htg Cfm/SqFt	0.97	Fn BldID	0.1	0.0
Total	-12.6				Auxil	0	0	Htg Btuh/SqFt	-59.80	Fn Frict	0.4	0.0

V 600 PAGE 15

System 13 Block FC - FAN COIL

eaked at Time	am>	Mo/Hr:	7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Autside Air >	OAD	B/WB/HR:	96/ 77/112.0			*	OADB:	96	*	a	ADB: 3	
						*	-		*			
	Space	Ret. Air		Net	Percnt	*	Space	Perant		Space	Total	Pera
	Sens.+Lat.	Sensible		Total	Of Tot	*	Sensible	01 100	*	Sensible	Sensible	of T
invelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.
Skylite Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Roof Cand	4,889	0		4,889	46.89	*	4,889	51.64	*	-4,402	-4,402	0.0
Glass Solar	1,109	0		1,109	10.63	*	1,109	11.71	*	0	0	0.0
Glass Cond	235	0		235	2.26	*	235	2.48	*	-1,028	-1,028	7.
Wall Cond	2,179	0		2,179	20.90	*	2,179	23.02	*	-5,951	-5,951	42.
Partition	0			0	0.00	*	0	0.00	*	0	0	0.
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.
Infiltration	1,682			1,682	16.13	*	722	7.62	*	-2,606	-2,606	18.
Sub Total=>	10,094	0		10,094	96.80	*	9,134	96.48	*	-13,987	-13,987	100.
nternal Loads						*			*			
Lights	0	0		0	0.00	*	0	0.00	*	0	0	0.
People	0			0	0.00	*	0	0.00	*	0	0	0.
Misc	334	0	0	334	3.20	*	334	3.52	*	0	0	٥.
Sub Total=>	334	0	0	334	3.20	*	334	3.52	*	0	.0	٥.
eiling Load	0	0	•	0	0.00	*	0	0.00	*	0	0	0.
utside Air	0	Ó	0	0	0.00	*	0	0.00	*	. 0	- 0	0.
up. Fan Heat				0	0.00	*	-	0.00	*		0	0.
et. Fan Heat		0		0	0.00	*		0.00	*		0	0.0
uct Heat Pkup		0		0	0.00	*		0.00	*		0	0.
V/UNDR Sizing	0	-		õ	0.00	*	0	0.00	*	0	õ	0.0
xhaust Heat	-	0	0	0 0		*	Ŭ	0.00	*	•	ő	0.
erminal Bypass		0	0	0	0.00	*		0.00	*		0 0	0.0
		v	v	0	0.00	*		0.00	*		0	0.
rand Total=>	10,428	0	0	10,428	100.00	*	9,467	100.00	*	-13,987	-13,987	100.

	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DE	/WB/HR	Gross To	tal	Glass	(sf)	(ક)
	(Tons)	(Mbh)	(Moh)	(cím)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	160			
Main Clg	0.9	10.4	9.5	581	78.2	65.0	73.9	62.6	59.3	72.4	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	198		0	0
Totals	0.9	10.4									Wall	234		25	11

	HEATING COIL SELECTION					IRFLOWS (cf	π)	-ENGINEERING	-TEMPERATURES (F)			
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg & CA	0.0	Type	Clg	Htg
	(Mbh)	(cím)	Deg F	Deg F	Vent	Ō	Ō	Clg Cfm/Sqft	3.63	SADB	63.0	125.0
Main Htg	-14.0	226	68.0	125.0	Infil	37	37	Clg Cfm/Ton	668.18	Plenm	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	581	226	Clg Saft/Ton	184.13	Return	78.0	68.0
Preheat	0.0	581	68.0	62.4	Mincfm	0	0	Clg Btuh/Saft	65.17	Ret/CA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	581	226	No. People	0	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	37	0	Htg & OA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	37	0	Htg Cfm/SqFt	1.42	Fn BldID	0.1	0.0
Total	-14.0				Auxil	0	0	Htg Btuh/Soft	-87.42	Fn Frict	0.4	0.0



•

V 600 PAGE 16



MONTHLY ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

------ MONTHLY ENERGY CONSUMPTION ------

Month	ELEC On Peak (kMh)	DEMAND On Peak (kW)	STEAM (Therm)
Jan	6,250	32	533
Feb	5, 533	32	471
March	6,435	32	341
April	5,196	31	9
May	6,032	32	0
June	10,028	58	0
July	13,143	65	0
Aug	11,418	59	0
Sept	6,997	51	0
Oct	5,756	33	0
Nov	5,652	32	150
Dec	5,683	32	702
Total	88,123	65	2,206

Building Energy Consumption = 77,355 (Btu/Sq Ft/Year) Source Energy Consumption = 177,527 (Btu/Sq Ft/Year)

.

. Floor Area =

6,740 (Sq Ft)

•



.



· .

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

EQUIPMENT ENERGY CONSUMPTION-

Ref	Equip					Mont	hly Cons	umption						
Num	Code	Jan	Feb	Mar	Apr	May	June	July	Aug	Sep	Oct	Nov	Dec	. Total
0	LIGHTS													
	ELEC	2157	1903	2284	2030	2284	2157	2030	2411	1903	2157	2030	1903	25, 249
	PK .	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2
1	MISC LD													
	ELEC	2959	2611	3133	2785	31.33	2972	2797	3322	2622	2959	2785	2611	34,691
	PK	16.7	16.7	16.7	16.7	16.7	16.8	16.8	16.8	16.8	16.7	16.7	16.7	16.8
2	MISC LD													
	GAS	0	0	0	0	0	. 0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	MISC LD													
	OIL	0	0	0	0	0	0	0	0	0	· 0	0	0	٥.
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0.	0.0	0.0	0.0
4	MISC ID													
	P STEAM	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	MISC LD													
	P HOTH20	0	0	0	0	0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	MISC LD													
	P CHILL	0	0	0	0	. 0	0	0	0	0	0	0	0	0
	PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	E01121S		AC R	ECIP CHI	LLER 20-	60 T								
	ELEC	0	0	0	0	0	3090	5720	3608	1367	0	0	0	13,785
	PK	0.0	0.0	0.0	0.0	0.0	21.4	27.5	22.5	15.0	0.0	0.0	0.0	27.5
1	EQ5200			ENSER FAI	NS.									
	ELEC	0	0	0	0	0	382	735	449	162	0	0	0	1,728
	PK	0.0	0.0	0.0	0.0	0.0	2.6	3.2	2.7	2.0	0.0	0.0	0.0	3.2
1	EQ5001		CHILI	LED WATE	R PUMP C	.v.								
	ELEC	0	0	0	0	0	415	541	468	237	0	0	0	1,660
	PK	0.0	0.0	0.0	0.0	0.0	0.7	0.7	0.7	0.7	0.0	0.0	0.0	0.7
1	EQ5313		CONT											
	ELEC	0	0	0	0	0	171	223	193	98	0	٥	0	685
	PK	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.0	0.0	0.0	0.3
1	EQ4003			INIRIF. I										
	ELEC	203	183	192	131	147	285	362	330	224	227	131	207	2,622
	PK	0.8	0.8	0.8	0.8	0.8	1.5	1.5	1.5	1.5	1.5	0.8	0.8	1.5

2 EQ4371

FAN COIL SUPPLY FAN



.

	ELEC PK	23 0.1	20 0.1	18 0.1	11 0.1	13 0.1	32 0.1	46 0.1	37 0.1	20 0.1	13 0.1	14 0.1	26 0.1	272 0.1
			•	0.1	0.1	U.	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
3	EQ4371		FAN	con. sup	PLY FAN									
	ELEC	116	104	105	71	214	235	289	268	189	173	74	123	1,961
	PK	0.4	0.4	0.4	0.4	1.2	1.2	1.2	1.2	1.2	1.2	0.4	0.4	1.2
4	EQ4371		FAN	COIL SUP	PLY FAN									
	ELEC	33	30	30	16	16	20	25	21	14	43	25	36	309
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
5	EQ4371		FAN	COIL SUP	PLY FAN							• `		
	ELEC	17	15	15	8	16	19	25	20	10	20	13	18	197
	PK	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.1
6	EQ4371		FAN	con sup	PLY FAN									
	ELEC	22	20	20	11	15	19	27	20	9	32	17	24	235
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
7	EQ4371		FAN	COIL SUP	PLY FAN									
	ELEC	17	16	16	8	.16	18	. 26	20	9	23	13	19	200
	PK	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	· 0.0	0.0	• 0.0	0.1
8	EQ4371		FAN	COIL SUP!	PLY FAN									
	ELEC	31	27	27	15	48	55	78	61	28	27	22	33	453
	PK	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.2
9	E04371		FAN	COIL SUP	PLY FAN									
-	ELEC	21	19	18	10	35	45	60	53	28	17	14	23	343
	PK	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.2
10	EQ4371		FAN (COIL SUP										
	ELEC	20	17	17	12	16	19	24	23	15	14	13	23	213
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
11	EQ4371 ELEC	10		COLL SUPP		~~		-						
	PK	19 0.1	17 0.1	16 0.1	10 0.1	35 0.2	36 0.2	54 0.2	46 0.2	26 0.2	28 0.2	12 0.1	21 0.1	320 0.2
		0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.2
12	EQ4371		FAN C	XIL SUPP	PLY FAN		•							
	ELEC	19	17	16	10	16	18	26	22	14	12 .	12	21	204
	PK	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
13	EQ4371		FAN C	DIL SUPP	PLY FAN									
	ELEC	23	20	20	11	26	39	56	47	23	12	15	25	316
	PK	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.2
1	CONVERIR		STEAN	n to hot	WATER CO	WERIER								
	P STEAM	533	471	341	9	0	0	0	0	0	0	150	702	2,206
	PK	2.5	2.5	2.4	0.2	0.0	0.0	0.0	0.0	0.0	0.0	1.4	2.6	2.6
1	EQ5020		HEAT	WATER CI	RC. PUMP	c.v.								
	ELEC	273	246	244	27	0	0	0	0	0	0	221	273	1,284
	PK	0.4	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4

)

1 EQ5060 CONDENSATE RETURN FUMP



:

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 3 BASE LOAD

ELEC	296	268	265	29	0	0	0	0	0	0	241	296	1,395
PK	0.4	0.4	0.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.4

V 600 PAGE 20



UTILITY PEAK CHECKSUMS - ALTERNATIVE 3 BASE LOAD V 600 PAGE 21

•

Utility ELECTRIC DEMAND

Peak Value 64.8 (kW) Yearly Time of Peak 15 (hr) 7 (mo)

Hour 15 Month 7

Ecp. Ref. Num. Cooling E	Equipment Code Name	Equipment Description	Utility Demand (KW)	Perant Of Tot (%)
	dorbuearc			
1	E011215	AC RECIP CHILLER 20-60 T	31.7	49.00
Sub Total			31.7	49.00
Sub Total			0.0	*****
Air Movin	g Equipment .	•		
1 2		SUMATION OF FAN ELECTRICAL DEMAND	1.5	2.31
3		SUMATION OF FAN ELECTRICAL DEMAND SUMATION OF FAN ELECTRICAL DEMAND	0.1	0.13
4		SUMATION OF FAN ELECTRICAL DEMAND	1.2 0.1	1.84 0.13
5		SUMATION OF FAN ELECTRICAL DEMAND	0.1	0.13
6		SUMATION OF FAN ELECITICAL DEMAND	0.1	0.13
7		SUMMATION OF FAN ELECTRICAL DEMAND	0.1	0.13
8		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.38
9		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.28
10		SUMMATION OF FAN ELECTRICAL DEMAND	0.1	0.13
11		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.27
12		SUMMATION OF FAN ELECTRICAL DEMAND	0.1	0.13
13		SUMMATION OF FAN ELECTRICAL DEMAND	0.2	0.24
Sub Total			4.0	6.20
Sub Total			0.0	0.00
Miscellane	eous			
Lights			12.2	18.83
Base Util				0.00
Misc Equi	pment		16.8	
Sub Total			29.0	44.81
Grand Tota	<u>1</u>		64.8	100.00



CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 3 BASE LOAD

 Weather Name
 FTLVNWIH

 Gross Conditioned Floor Area (sqft)
 6,740

 ACM Multiplier
 1.008

ENERGY USE SUMMARY

----- CALIFORNIA TITLE 24 COMPLIANCE REPORT ----

.

	ELEC (KWh/yr)	DISTRICT STEAM (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (kBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)	• *
Primary Heating	1,395.4	220,607.6	43.2	308,432.5	46.1	
Primary Cooling				,		
Campressor	13,784.9	0.0	9.0	141,157.5	21.1	
Tower/Cond Fans	1,727.7	0.0	1.1	17,692.0	2.6	
Condenser Pump	0.0	0.0	0.0	0.0	0.0	
Other Accessories	685.5	0.0	0.4	7,019.5	1.0	
Auxiliary						
Supply Fans	7,645.7	0.0	5.0	78,292.1	11.7	
Circulation Pumps	2,943.8	0.0	1.9	30,144.7	4.5	
Base Utilities	. 0.0	· 0.0	0.0	0.0	0.0	•
Subtotal	10,589.5	0.0	6.9	108,436.8	16.2	
Lighting	25,249.1	0.0	16.5	258,551.6	38.7	
Receptacle	34,691.2	0.0	22.7	355,238.9	53.1	
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0	
Cogeneration	0.0	0.0	0.0	0.0	0.0	
Totals	88,123.4	220,607.6	100.0	1,196,528.9	178.9	

ECO-M2

DRY-BULB ECONOMIZER CONTROLS

BUILDING 473



- Partie a strate was a strategy

******	*****	*****	********	**********	*****	********		
**						**		
**	TRA	CE	ULTRA	ANALY	SIS	**		
**						**		
**	bv	CLARK	RICHARDSON	BISKUP		**		
**	-					**		
*****	*****	*****	*****	********	****	*******		
*****	*****	*****	******	******	*****	******		

USDB ENERGY STUDY LEAVENWORTH, KANSAS USDB ERLAN SCOTT

Weather File Code:	FILVNW	77R 1
Location:	-,	
Latitude:		WORTH, KANSAS (USDB)
Longitude:		(deg)
Time Zone:		(deg)
Elevation:	6	
		(ft)
Barcmetric Pressure:	29.1	(in Hg) ·
Summer Clearness Number:	0.95	·
Winter Clearness Number:	0.95	
Summer Design Dry Bulb:	96	(F)
Summer Design Wet Bulb:	77	
Winter Design Dry Bulb:		(E)
Summer Ground Relectance:	0.20	<i>(</i> , <i>)</i>
Winter Ground Relectance:	0.20	
Air Density:		(Lbm/cuft)
Air Specific Heat:		(Btu/lbm/F)
Density-Specific Heat Prod:		
Latent Heat Factor:		(Btu-min./hr/cuft/lbm)
Enthalpy Factor:	4.4333	(Btu-min./hr/cuft)
Design Simulation Period: May	To (October
System Simulation Period: Jan		
Cooling Load Methodology:		
		\ ** * *
Time/Date Program was Run:	9:58:4	5 9/25/90
Dataset Name:	473-1	M.IM

V600 PAGE 1

.

.

AIRFLOW - ALTERNATIVE 2 BASE LOAD

			(Des:	ign Airflow (Quantities)			
				Main			Auxil.	Room
		Outside	Ccoling	Heating	Return	Exhaust	Supply	Exhaust
System Sys	sten	Airflow	Airflow	Airflow	Airflow	Airflow	Airflow	Airflow
Number 1	Type	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)	(Cfm)
1 FC		0	400	304	400	0	. 0	50
2 FC		0	300	0	300	0	0	17
3 FC		0	800	0	800	0	0	137 .
4 FC		0	300	0	300	0	0	51
5 FC		0	300	53	300	0	0	23
6 FC		0	300	79	300	0	0	37
7 FC		0	300	0	300	0	0	30
8 FC		0	200	0	200	0	0	34
9 SZ		0	1,600	669	1,599	0	0	434
10 FC		0	600	209	600	0	0	98
11 sz		0	4,910	2,541	4,910	4,910	0	1,037
12 SZ		0	5,900	2,929	5,900	5,900	0	1,183
Totals		0	15,910	6,783	15,908	10,810	0	3,132

-- SYSTEM SUMMARY -----

CAPACITY - ALTERNATIVE 2 BASE LOAD

(Design Capacity Quantities)

			cooi	ling					Heating			
System Number	System Type	Capacity		Opt. Vent Capacity (Tons)	Cooling Totals (Tons)	Main Sys. Capacity (Btuh)	Aux. Sys. Capacity (Btuh)	Preheat Capacity (Btuh)	Reheat Capacity (Btuh)	Humidif. Capacity (Btuh)	Opt. Vent Capacity (Btuh)	Heating Totals (Btuh)
1	FC	0.9	0.0	0.0	0.9	-18,767	0	0	0	0	0	-18,767
2	FC	0.6	0.0	0.0	0.6	0	0	-22,807	0	0	0	-22,807
3	FC	2.2	0.0	0.0	2.2	0	0	-47,137	0	0	0	-47,137
4	FC	0.8	0.0	0.0	0.8	0	0	-17,446	0	0	0	-17,446
5	FC	0.2	0.0	0.0	0.2	-3,024	0	-1,300	0	0	0	-4,325
6	FC	0.6	0.0	0.0	0.6	-4,858	0	0	0	0	0	-4,858
7	FC	0.4	0.0	0.0	0.4	0	0	-21,779	0	0	· 0	-21,779
8	FC	0.7	0.0	0.0	0.7	0	٥	-9,923	0	0	0	-9,923
9	SZ	1.5	0.0	0.0	1.5	-40,932	٥	-955	0	0	0	-41,887
10	FC	1.3	0.0	0.0	1.3	-12,027	0	-2,589	0	0	0	-14,616
11	SZ	13.7	0.0	0.0	13.7	-156,944	0	0	0	0	0	-156,944
12	SZ	16.0	0.0	0.0	16.0	-180,898	0	0	0	0	0	-180,898
Totals		38.9	0.0	0.0	38.9	-417,451	0	-123,936	0	0	0	-541,386

V 600 PAGE 2

. .



ENGINEERING CHECKS - ALTERNATIVE 2 BASE LOAD

			Percent		coo.	Ling		Heat	ting	
System	Main/	System	Outside	Cfm/	Cfm/	Sq Ft	Stuh/	Cfm/	Btuh/	Floor Area
Number	Auxiliary	Type	Air	Sq Ft	Tan	/Ton	Sq Ft	Sq Ft	Sq Ft	Sq Ft
1	Main	FC	0.00	0.69	444.4	643.3	18.65	0.52	-32.41	579
2	Main	FC	0.00	3.85	486.5	126.5	94.87	0.00	-292.39	78
3	Main	FC	0.00	1.30	371.0	286.1	41.94	0.00	-76.40	617
4	Main	FC	0.00	1.32	375.5	285.4	42.05	0.00	-76.52	228
5	Main	FC	0.00	2.88	1,420.3	492.4	24.37	0.51	-41.58	104
6	Main	FC	0.00	1.79	495.2	277.3	43.27	0.47	-28.92	168
7	Main	FC	0.00	2.19	837.8	382.6	31.36	0.00	-158.97	137
8	Main	FC	0.00	1.31	286.0	218.8	54.84	0.00	-64.86	153
9	Main	SZ	0.00	0.82	1,035.6	1,262.1	9.51	0.34	-21.48	1,950
10	Main	FC	0.00	1.36	464.5	340.6	35.23	0.48	-33.22	440
11	Main	SZ	0.00	1.17	359.0	306.2	39.19	0.61	-37.47	4,188
12	Main	SZ	0.00	1.41	368.7	261.7	45.85	0.70	-43.19	4,188

------ ENGINEERING CHECKS -----

V 600 PAGE 3

٠

System 1 Block FC - FAN COIL

Peaked a	t Time =		Mo/Hr:	7/15			* *	ю/Hr:	7/16	*	Mo/Hr: 13/	1
Outside .	Air =>	QA		96/ 77/112.)		*	OADB:	,	*	OADB: 3	-
					-		*			*		
		Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perant	* Spac	e Tota	1 Perant
	S	ens.+Lat.	Sensible	Latent	Total	Of Tot	* Ser	nsible	Of Tot	- -		
Envelope	Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)		(Btuh)		* (Btuh		
Skylit	e Solr	Ō	Ó	, ,	0	0.00	*	,		•	· · · · · · · · · · · · · · · · · · ·	0 0.00
Skylit	e Cand	0	0		0	0.00	*	ō	0.00	*	c	0 0.00
Roof C	and	0	0		0	0.00	*	0	0.00	*	0	0 0.00
Glass	Solar	2,402	0		2,402	11.47	*	2,402	16.47		•	0 0.00
Glass	Cond	732	0		732	3.49	*	727		*3,19	•	
Wall C	and	642	155		797	3.80	*	649	4.45	. 0,15	-	
Partit		0	100		0	0.00	*	0	0.00			0 0.00
	d Floor	0			0	0.00	*	0	0.00		-	
Infilt	-	7,057			-		*	-		,		
Sub To			155		7,057	33.70		2,427	20101	-,-=		
Internal		10,833	155		10,988	52.47	*	6,206	42.53	1,,00	6 -18,76	7 100.00
	LOads						*			*	-	
Lights		2,117	1,411		3,528	16.85	*	2,117	14.51		-	0 0.00
People		3,102			3,102	14.82	*	1,619	11.10		-	0 0.00
Misc	•	3,045	0	0	3,045	14.54	*	3,080	21.11		-	0 0.00
Sub To		8,264	1,411	0	9,676	46.20	*	6,816	46.72	•	-	0 0.00
Ceiling 1		1,566	-1,566		0	0.00	* •	1,569	10.75	* -93		0 0.00
Outside i		0	0	0	0	0.00	*	0	0.00	*	0	0 0.00
Sup. Fan					245	1.17	*		0.00	*	1	0 0.00
Ret. Fan			32		32	0.15	*		0.00	*	•	0 0.00
Duct Heat	-		0		0	0.00	*		0.00	*	1	0.00
OV/UNDR S	Sizing	0			0	0.00	*	0	0.00	*	0	0.00
Exhaust I	le at		0	٥	0	0.00	*		0.00	*	-	0.00
Terminal	Bypass		0	0	0	0.00	*		0.00	*		0.00
							*		,	*		
Grand Tot	al=>	20,664	32	0	20,941	100.00	* 1	.4,590	100.00	* -18,76	7 -18,76	7 100.00
		·		LING COIL SI							AREAS	
	Total (Capacity		Coil Airfl		ng DB/WB/	HR Le	aving	DB/WB/HR	Gress Tota		(sf) (%)
	(Tons)	(Moh)	(Mohi)	(cfm)	Deg F Dec	F Grai	ns Deg B	Decr	F Grains	Floor	579	
fain Clg	0.9	10.8	7.7	400			.7 44.0	-		Part	0	
ux Clg	0.0	0.0	0.0	0			.0 0.0			ExFlr	65	
pt Vent	0.0	0.0	0.0	0			.0 0.0			Rœf	0	0 0
otals	0.9	10.8		Ū	5.0 (, .	• •.•	Wall	805	86 11
		G COIL SEL			× ••	ELOWS (c	fm)		-ENGINEERIN	CIECYS		RES (F)
	Capacity			T T T C		•						
	(Mbh)	cfi		Lvg Dog F	Type	Cooling	Heating	,	lg % QA la CÉ (Cat	0.0		lg Htg 4.3 125.0
ain Htg	-18.8	-	n) DegF 304 68.0	Deg F 125.0	Vent	120			lg Cfm/Sqft	0.69		
	-10.0		304 68.0	125.0	Infil	128	12	.a C	lg Cfm/Ton	444.44		6.5 62.9

	(Mon)	(cim)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	0.69	SADB	44.3	125.0
Main Htg	-18.8	304	68.0	125.0	Infil	128	128	Clg Cfm/Ton	444.44	Plenm	86.5	62.9
Aux Htg	0.0	0	0.0	0.0	Supply	400	304	Clg Sqft/Ton	643.33	Return	78.0	68.0
Preheat	0.0	400	68.0	43.8	Mincfin	400	0	Clg Btuh/Sqft	18.65	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	400	304	No. People	8	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	1.28	0	Htg & OA	0.0	Fn MerID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	50	0	Htg Cfm/Saft	0.52	Fn BldID	0.1	0.0
Total	-18.8				Auxil	0	0	Htg Btuh/SqFt	-32.41	Fn Frict	0.4	0.0

.

System 2 Block FC - FAN COIL

Peaked at Time :	⇒>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/16	*	Mo/H	br: 0/0	
Outside Air =>	OAD	B/WB/HR: 9	96/ 77/112.0			*	OADB:	96	*	OAD	B: 0	
						*			*			
	Space		Ret. Air	Net	Percnt	*	Space	Perant	5 * 3	Space	Total	Perant
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(୫)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(୫)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	С	0	0.00
Roof Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Solar	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Cond	0	0		0	0.00	*	0	0.00	*	. 0	0	0.00
Wall Cond	112	32		145	4.89	*	111	4.70	*	0	0	0.00
Partition	0			0	0.00	*	0	0.00		0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	532			532	18.01	*	322	13.62	*	0	0	0.00
Sub Total->	644	32		677	22.90	*	434	18.32	*	0	Ō	0.00
Internal Loads						*			*			
Lights	156	104		259	8.78	*	156	6.57	*	0	0	0.00
People	388			388	13.12	*	202	8.55		0	0	0.00
Misc	1,424	0	0	1,424	48.17	*	1,440	60.82	*	0	Ō	0.00
Sub Total=>	1,967	104	0	2,071	70.07		1,798		*	۰ ۵	0	0.00
Ceiling Load	136	-136		. 0	0.00	*	136		*	0	0	0.00
Outside Air	0	0	0	0		*	0		*	0	0	
Sup. Fan Heat			-	184		*	÷	0.00	*	-	0	0.00
Ret. Fan Heat		24		24	0.81	*		0.00	*		õ	0.00
Juct Heat Pkup		0		0		*		0.00	*		ő	0.00
W/UNDR Sizing	0	•		ő		*	0		*	0	õ	0.00
Exhaust Heat		0	0	õ	0.00	*		0.00	*	·	ů	0.00
Cerminal Bypass		0	0	ő		*			*		Ő	0.00
44		•		v	0.00	*		0.00	*		v	0.00
Grand Total->	2,748	24	0	2 955	100.00	*	2,367	100.00	*	0	0	0.00

				DLING COIL SE	LECIION	I						AREAS			
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross Tot	al Glas	s (sî)	(%)	ļ.
	(Tons)	(Mbh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Grains	Floor	78					
Main Clg	0.6	7.4	6.4	300	78.2	68.9	94.7	70.4	61.8	71.3	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	8			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0	0)	0
Totals	0.6	7.4									Wall	99	0	I	0

	HEATING (DIL SELECTIO	N		A	IRFLOWS (cfs	m) (m	ENGINEERING	CHECKS-	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	3.85	SADB	70.7	0.0
Main Htg	0.0	0	0.0	0.0	Infil	17	0	Clg Cfm/Ton	486.49	Plenum	83.5	0.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	0	Clg Sqft/Ton	126.49	Return	78.0	0.0
Preheat	-22.8	300	0.0	70.2	Mincfm	300	0	Clg Btuh/Sqft	94.87	Ret/OA	78.0	0.0
Reheat	0.0	0	0.0	0.0	Return	300	0	No. People	1	Runarnd	78.0	0.0
Hamidif	0.0	0	0.0	0.0	Exhaust	17	0	Htg % OA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rn Exh	17	0	Htg Cfm/SqFt	0.00	Fn BldID	0.1	0.0
Total	-22.8				Auxil	0	0	Htg Btuh/Saft	-292.39	Fn Frict	0.4	0.0



V 600 PAGE 5

System 3 Block FC - FAN COIL

Space Ret. Air Net Percnt * * * * Space Total Percnt * Space Total Of Space Total Of * Space Total Of Space Total Space Total Space Total Space Total <	Peaked at Time :		Mo/Hr: 7	//15			*	Mo/Hr:	7/15	*	Ma	/Hr: 0/0	
Sens.+Lat. Sensible Total Of Tot * Sensible Sensi	Outside Air =>	CAE	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	a	ADB: 0	
Sens.+Lat. Sensible Total Of Tot * Sensible Sensi							*			*			
Envelope Loads (Btuh) (Btuh) <t< td=""><td></td><td>•</td><td></td><td>Ret. Air</td><td>Net</td><td></td><td>*</td><td>÷.</td><td>Perant</td><td>: *</td><td>Space</td><td>Total</td><td>Perch</td></t<>		•		Ret. Air	Net		*	÷.	Perant	: *	Space	Total	Perch
Skylite Salr 0 0 0.00 * 0 0.00 * 0 0.00 Skylite Cand 0 0 0.00 * 0 0.00 * 0 0.00 Roof Cand 0 0 0.00 * 0 0.00 * 0 0.00 Glass Solar 2,001 0 2,001 7.73 * 2,001 0					Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of To
Skylite Cond 0 <t< td=""><td>-</td><td>(Btuh)</td><td>(Btuh)</td><td>(Btuh)</td><td>(Btuh)</td><td>(%)</td><td>*</td><td>(Btuh)</td><td>(୫)</td><td>*</td><td>(Btuh)</td><td>(Btuh)</td><td>(*</td></t<>	-	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(୫)	*	(Btuh)	(Btuh)	(*
Roof Cond 0	-	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Solar 2,001 0 2,001 7.73 * 2,001 10.01 * 0 0.00 Glass Cond 406 0 406 1.57 * 406 2.03 * 0 0.00 Wall Cond 343 95 439 1.70 * 343 1.72 * 0 0 0.00 Partition 0 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 0 0.00 * 0 0.00 * 0 0.00 0 0.00 * 0 0 0.00	-	0	0		0	0.00	*	0	0.00	*	C	0	0.0
Glass Cond 406 0 406 1.57 * 406 2.03 * 0 0.00 Wall Cond 343 95 439 1.70 * 343 1.72 * 0 0 0.00 Partition 0 0 0.00 * 0 0.00 * 0 0.00 Infiltration 6,672 25.78 * 2,672 13.37 * 0 0 0.00 Sub Total=> 9,422 95 9,518 36.78 * 5,423 27.12 * 0 0 0.00 Internal Loads * * * * * * * * 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 <td></td> <td>0</td> <td>0</td> <td></td> <td>0</td> <td>0.00</td> <td>*</td> <td>0</td> <td>0.00</td> <td>*</td> <td>0</td> <td>0</td> <td>0.0</td>		0	0		0	0.00	*	0	0.00	*	0	0	0.0
Wall Cond 343 95 439 1.70 * 343 1.72 * 0 0 0.00 Partition 0 0 0.00 * 0 0.00 * 0 0 0.00 Exposed Floor 0 0 0.00 * 0 0.00 * 0 <	Glass Solar	2,001	0		2,001	7.73	*	2,001	10.01	*	0	0	0.0
Partition 0	Glass Cond	406	0		406	1.57	*	406	2.03	*	. 0	0	0.0
Partition 0 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0 0.00 0 0 0.00 0 0 0.00 0 0 0.00 0 0 0.00 0 </td <td>Wall Cond</td> <td>343</td> <td>95</td> <td></td> <td>439</td> <td>1.70</td> <td>*</td> <td>343</td> <td>1.72</td> <td>*</td> <td>0</td> <td>0</td> <td>0.0</td>	Wall Cond	343	95		439	1.70	*	343	1.72	*	0	0	0.0
Exposed Floor 0 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 0.00 * 0 0.00 0.00 * 0 0.00 0.00 * 0 0.00 0.00 * 0 0.00 0.00 * 0 0.00 0.00 0.00 0.00 * 0 0.00	Partition	0			0	0.00	*	0	0.00	*	0	٥	0.0
Infiltration $6,672$ $6,672$ 25.78 $*$ $2,672$ 13.37 $*$ 0 0 0.00 Sub Total=> $9,422$ 95 $9,518$ 36.78 $*$ $5,423$ 27.12 $*$ 0 0 0.00 Internal Loads * * * * * * $*$ * $*$ $*$ Lights $2,801$ $1,868$ $4,669$ 18.04 $*$ $2,801$ 14.01 $*$ 0 0 0.00 Misc $8,422$ 0 0 $8,422$ 0 0 0.00 0.00 0.00 Sub Total=> $13,938$ $1,868$ 0 $15,805$ 61.08 $12,608$ 63.06 $*$ 0 0 0.00	Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Sub Total=> 9,422 95 9,518 36.78 $5,423$ 27.12 $*$ 0 0 0.0 Internal Loads * </td <td>Infiltration</td> <td>6,672</td> <td></td> <td></td> <td>6.672</td> <td></td> <td>*</td> <td>2.672</td> <td></td> <td>*</td> <td>0</td> <td>0</td> <td>0.00</td>	Infiltration	6,672			6.672		*	2.672		*	0	0	0.00
Internal Loads * * * Lights 2,801 1,868 4,669 18.04 2,801 14.01 * 0 0 0.0 People 2,715 2,715 10.49 1,385 6.93 * 0 0 0.0 Misc 8,422 0 0 8,422 32.54 * 8,422 42.12 * 0 0 0.0 Sub Total=> 13,938 1,868 0 15,805 61.08 * 12,608 63.06 * 0 <td>Sub Total=></td> <td>9,422</td> <td>95</td> <td></td> <td></td> <td></td> <td>*</td> <td></td> <td></td> <td>*</td> <td>0</td> <td>0</td> <td>0.0</td>	Sub Total=>	9,422	95				*			*	0	0	0.0
People 2,715 2,715 10.49 * 1,385 6.93 * 0 0 0.00 Misc 8,422 0 0 8,422 32.54 * 8,422 42.12 * 0 0 0.00 Sub Total=> 13,938 1,868 0 15,805 61.08 * 12,608 63.06 * 0 0 0.00 Ceiling Load 1,963 -1,963 0 0.00 * 1,963 9.82 * 0 0 0.00 Cutside Air 0 0 0.00 * 0.00 * 0 0.00 0 0.00 Sup. Fan Heat 490 1.90 * 0.00 * 0 0.00 0 0.00 Sup. Fan Heat 64 64 0.25 * 0.00 * 0 0.00 OV/UNDR Sizing 0 0 0.00 * 0.00 * 0 0.00 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0.00 * 0.00 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0.00 0.00 0.00 <td>Internal Loads</td> <td></td> <td></td> <td></td> <td>-,</td> <td></td> <td>*</td> <td>-,</td> <td></td> <td>*</td> <td>-</td> <td>-</td> <td></td>	Internal Loads				-,		*	-,		*	-	-	
People 2,715 2,715 10.49 * 1,385 6.93 * 0 0.00 Misc 8,422 0 0 8,422 32.54 * 8,422 42.12 * 0 0 0.00 Sub Total=> 13,938 1,868 0 15,805 61.08 * 12,608 63.06 * 0 0 0.00 Cailing Load 1,963 -1,963 0 0.00 * 0 0.00 * 0 0 0.00 Cailing Load 1,963 -1,963 0 0.00 * 0 0.00 * 0 0.00 Cailing Load 1,963 -1,963 0 0.00 * 0 0.00	Lights	2,801	1,868		4,669	18.04	*	2,801	14.01	*	0	0	0.0
Misc $8,422$ 0 0 $8,422$ 32.54 $8,422$ 42.12 ∞ 0 0	People	2,715			•						0	-	0.00
Sub Total=> 13,938 1,868 0 15,805 61.08 * 12,608 63.06 * 0<	Misc	8,422	٥	0	•			•		*	0	0	0.00
Ceiling Load 1,963 -1,963 0 0.00 * 1,963 9.82 * 0 0 0.00 Cutside Air 0 0 0 0.00 * 0 0.00 <td>Sub Total=></td> <td>13,938</td> <td>1,868</td> <td>-</td> <td></td> <td></td> <td>*</td> <td></td> <td></td> <td>*</td> <td>Ő</td> <td>-</td> <td>0.0</td>	Sub Total=>	13,938	1,868	-			*			*	Ő	-	0.0
Dutside Air 0 0 0 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0	Ceiling Load	•	•	-			*			*		•	0.0
Sup. Fan Heat 490 1.90 * 0.00 * 0.00 Ret. Fan Heat 64 64 0.25 * 0.00 * 0 0.00 Duct Heat Pkup 0 0 0.00 * 0 0.00 * 0 0.00 DV/UNDR Sizing 0 0 0.00 * 0 0.00 * 0 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0 0.00 0 0.00 Terminal Bypass 0 0 0.00 * 0.00 * 0.00 * 0 0.00	Outside Air	•	•	0	-		*			*	•	-	
Ret. Fan Heat 64 64 0.25 * 0.00 * 0 0.00 Duct Heat Pkup 0 0 0.00 * 0.00 * 0 0.00 DV/UNDR Sizing 0 0 0.00 * 0 0.00 * 0 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0 0.00 * 0 0.00 Ferminal Bypass 0 0 0.00 * 0.00 * 0 0.00 * 0	Sup. Fan Heat		-	Ū	•			0			v	•	
Duct Heat Pkup 0 0 0 0.00 * 0.00 * 0 0.00 DV/UNDR Sizing 0 0 0.00 * 0 0.00 * 0 0 0.00 Exhaust Heat 0 0 0 0.00 * 0 0.00 * 0 0 0.00 Erminal Bypass 0 0 0 0.00 * 0.00 * 0 0.00	Ret. Fan Heat		64						- · ·			-	
DV/CNDR Sizing 0												•	
Exhaust Heat 0 <t< td=""><td>•</td><td>0</td><td>Ŭ</td><td></td><td>•</td><td></td><td></td><td>0</td><td></td><td></td><td>0</td><td>•</td><td></td></t<>	•	0	Ŭ		•			0			0	•	
Cerminal Bypass 0		0	0	0	•			U			U	-	
* *			•	-	•							•	
	olbroo		0	0	U	0.00			0.00			0	0.00
	Grand Total=>	25,323	64	0	25,877	100.00		19,993	100.00		0	٥	0.0

			~									- Act			
		Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DE	8/WB/HR	Gross To	otal	Glass	(sí)	(욱)
	(Tons)	(Moh)	(Moh)	(cím)	Deg F Deg F Grains Deg F Deg F Grains						Floor	617			
Main Clg	2.2	25.9	20.5	800	78.2	64.0	69.2	54.6	53.0	59.3	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	ExFlr	41				
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0	0
Totals	2.2	25.9									Wall	333		43	13

	HEATING (DIL SELECTIO	<u>N</u>		A	IRFLOWS (cfs	m)	ENGINEERING	HECKS	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & OA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.30	SADB	54.9	0.0
Main Htg	0.0	0	0.0	0.0	Infil	137	0	Clg Cfm/Ton	370.99	Plenum	88.0	0.0
Aux Htg	0.0	0	0.0	0.0	Supply	800	0	Clg Sqft/Ton	286.12	Return	78.0	0.0
Preheat	-47.1	800	0.0	54.4	Mincfm	800	0	Clg Btuh/Sqft	41.94	Ret/QA	78.0	0.0
Reheat	0.0	0	0.0	0.0	Return	800	0	No. People	7	Runamd	78.0	0.0
Humidif	0.0	0	0.0	0.0	Exhaust	137	٥	Htg & OA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	137	0	Htg Cfm/SqFt	0.00	Fn BldID	0.1	0.0
Total	-47.1				Auxil	0	0	Htg Btuh/SqFt	-76.40	Fn Frict	0.4	0.0



V 600

System 4 Block FC - FAN COIL

.

Peaked at Time =	>	Mo/Hr: 7	7/16			*	Mo/Hr:	7/16	*	Mo,	/Hr: 0/0	
Outside Air =>	QAD	B/WB/HR: 9	6/ 75/105.0			*	OADB:	96	*	a	ADB: 0	
						*			*			
	Space	Ret. Air		Net	Perant	*	Space	Perant	*	Space	Total	Percn
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible		*	Sensible	Sensible	Of To
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(*
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Skylite Cond	0	0		0	0.00	*	0	0.00	*	С	0,	0.0
Roof Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Solar	2,136	0		2,136	22.29	*	2,136	27.64	*	0	0	0.0
Glass Cond	202	0		202	2.11	*	202	2.62	*	. 0	0	0.0
Wall Cond	230	. 46		276	2.88	*	230	2.98	*	0	0	0.0
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	0	0	0.0
Infiltration	2,047			2,047	21.36	*	967	12.51	*	0	0	0.0
Sub Total=>	4,616	46		4,662	48.63	*	3,536	45.75	*	0	0	0.0
Internal Loads						*			*			
Lights	1,245	830		2,075	21.65	*	1,245	16.11	*	0	0	0.0
People	1,177			1,177	12.28	*	607	7.86	*	0	0	0.0
Misc	1,464	0	0	1,464	15.27	*	1,464	18.95	*	0	0	0.0
Sub Total=>	3,886	830	. 0	4,716	49.20	*	3,316	42.91	*	0	0	0.0
Ceiling Load	876	-876	•	. 0		*	876	11.34	*	· 0	0	0.0
Outside Air	0	0	0	0	0.00	*	0	0.00	*	• • •	0	0.0
Sup. Fan Heat				184	1.92	*		0.00	*		0	0.0
Ret. Fan Heat		24		24	0.25	*		0.00	*		0	0.0
Duct Heat Pkup		0		0		*		0.00	*		0	0.0
OV/UNDR Sizing	0			0		*	٥	0.00	*	0	0	0.0
Exhaust Heat		0	0	0	0.00	*	•		*	-	0	0.0
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.0
		-	•	•		*		5100	*		·	
Grand Total=>	9,378	24	0	9,586	100.00	*	7,728	100.00	*	0	0	0.0
			ING COIL SELE								REAS	

	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DE	3/WB/HR	Gross	Total	Glass	(sf)	(%)	
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	228	3			
Main Clg	0.8	9.6	7.9	300	78.2	65.0	73.9	53.9	53.0	60.3	Part	C)			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	19)			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	C)	0	0	
Totals	0.8	9.6									Wall	234	Į	22	9	

	HEATING (DIL SELECTIO	N		————P	IRFLOWS (cf	m)	ENGINEERING (HECKS-	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & QA	0.0	Type	Clg	Htg
	(Mbh)	(cím)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	1.32	SADB	54.2	0.0
Main Htg	0.0	0	0.0	0.0	Infil	51	0	Clg Cfm/Ton	375.54	Plenum	90.1	0.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	0	Clg Saft/Ton	285.41	Return	78.0	0.0
Preheat	-17.4	300	0.0	53.7	Mincim	300	0	Clg Btuh/Sqft	42.05	Ret/QA	78.0	0.0
Reheat	0.0	0	0.0	0.0	Return	300	0	No. People	3	Runamd	78.0	0.0
Amidif	0.0	0	0.0	0.0	Exhaust	51	0	Htg 3 QA	0.0	Fn MerID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	51	0	Htg Cfm/SqFt	0.00	Fn BldID	0.1	0.0
Total	-17.4				Auxil	0	0	Htg Btuh/SqFt	-76.52	Fn Frict	0.4	0.0





System 5 Block FC - FAN COIL

******	********* @	OLING COIL	PEAK *******	*******	*******	***	**** CLG SPAC	e peak ***	***	****** HEATING	COIL PEAK	******
Peaked at Time :			7/15			*	Mo/Hr:	7/15	*	Mo	/Hr: 13/ 1	
Outside Air =>	OAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	96	*	Q	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perant	*	Space	Total	Perat
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of Tot
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Bṛuh)	(%)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Skylite Cond	0	0		0	0.00	*	0	0.00	*	С	0	- 0.00
Roof Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Solar	0	0		0	0.00	*	0	0.00	*	0	0	0.00
Glass Cond	191	0		191	7.55	*	191	10.83	*	-837	-837	25.72
Wall Cond	84	19		103	4.06	*	84	4.76	*	-243	-364	11.20
Partition	0			0	0.00	*	0	0.00	*	0	0	0.00
Exposed Floor	0			0	0.00	*	0	0.00	*	-432	-432	13.27
Infiltration	1,009			1,009	39.79	*	449	25.39	*	-1,620	-1,620	49.81
Sub Total=>	1,284	19		1,303	51.40	*	724	40.98	*	-3,131	-3,253	100.00
Internal Loads						*			*			
Lights	614	410		1,024	40.40	*	614	34.77	*	0	0	0.00
People	0			0	0.00	*	0	0.00	*	0	0	0.00
Misc	0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sub Total=>	. 614	41.0	0	1,024	40.40	*	614	34.77	*	0	0	0.00
Ceiling Load	428	-428		0	0.00	*	· 428	24.24	*	-121	0	0.00
Outside Air	• 0	0	0	0	0.00	*	0	0.00	*	0	0	0.00
Sup. Fan Heat				184	7.26	*		0.00	*		0	0.00
Ret. Fan Heat		24		24	0.94	*		0.00	*		0	0.00
Duct Heat Pkup		0		0	0.00	*		0.00	*		0	0.00
OV/UNDR Sizing	0			0	0.00	*	0	0.00	*	0	0	0.00
Exhaust Heat		0	0	0	0.00	*		0.00	*		0	0.00
Terminal Bypass		0	0	0	0.00	*		0.00	*		0	0.00
						*			*			
Grand Total=>	2,327	24	0	2,535	100.00	*	1,767	100.00	*	-3,253	-3,253	100.00

				LING COIL SE	IECTION	}						AREAS		
	Total C	apacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	ving DB	/WB/HR	Gross To	tal Glass	(sf)	(%)
	(Tons)	(Moh)	(Mbh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	104		
Main Clg	0.2	2.5	2.0	300	78.2	65.4	76.3	72.2	62.9	73.5	Part	0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	8		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0	0	0
Totals	0.2	2.5									Wall	102	20	20

	HEATING (COLL SELECTIO	N		———A	IRFLOWS (cfi	m)	ENGINEERING	CHECKS	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	2.88	SADB	72.6	125.0
Main Htg	-3.0	53	72.0	125.0	Infil	23	23	Clg Cfm/Ton	1420.35	Plenum	91.0	64.3
Aux Htg	0.0	0	0.0	0.0	Supply	300	53	Clg Sqft/Ton	492.39	Return	78.0	68.0
Preheat	-1.3	300	68.0	72.0	Mincfm	300	0	Clg Btuh/Sqft	24.37	Ret/CA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	300	53	No. People	0	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	23	0	Htg % OA	0.0	Fn MariD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	23	0	Htg Cfm/SqFt	0.51	Fn BldID	0.1	0.0
Total	-4.3				Auxil	0	0	Htg Btuh/SqFt	-41.58	Fn Frict	0.4	0.0



V 600



.

.

System 6 Block FC - FAN COIL

Peaked at Time =	** >	Mo/Hr: 7	7/14			*	Mo/Hr:	7/10	*	Mo	/Hr: 13/ 1	
Outside Air ==>	OAD	B/WB/HR: 9	6/ 77/112.0			*	OADB:	86	*	a	ADB: 3	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perant	*	Space	Total	Percn
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of To
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(ક)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Skylite Cand	0	0		0	0.00	*	0	0.00	*	C	0	0.0
Roof Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Solar	1,090	0		1,090	14.99	*	1,875	31.85	*	0	0	0.0
Glass Cond	194	0		194	2.67	*	97	1.65	*	890	-890	18.3
Wall Cond	164	26		190	2.61	*	154	2.61	*	-440	-634	13.0
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	*	0	0.00	*	-728	-728	14.9
Infiltration	1,746			1,746	24.03	*	337	5.72	*	-2,606	-2,606	53.6
Sub Total=>	3,194	26		3,221	44.31	*	2,462	41.83	*	-4,664	-4,858	100.0
Internal Loads				,		*	-,		*			
Lights	1,229	819		2,048	28.17	*	1,180	20.04	*	0	0	0.0
People	385			385		*	173	2.93	*	0	0	0.0
Misc	1,407	0	0	1,407	19.36	*	1,262	21.44	*	0	0	0.0
Sub Total=>	3,022	819	0	3,841	52.84	*	2,614	44.41	*	• 0	0	0.0
Ceiling Load	845	-845		. 0	0.00	*	810	13.76	*	-194	0	0.0
Outside Air	0	0	0	0	0.00	*	0	0.00	*	0	0.	
Sup. Fan Heat				184		*	-	0.00	*		0	0.0
Ret. Fan Heat		24		24	0.33	*		0.00	*		0	0.0
Juct Heat Pkup		0		0		*		0.00	*		0	0.0
W/UNDR Sizing	0	•		0		*	0	0.00	*	0	Ő	0.0
Exhaust Heat	-	0	0	õ		*	v	0.00	*	· ·	0	0.0
Cerminal Bypass		õ	ő	0 0	• • • •	*		0.00	*		ů	0.0
		Ű	Ŭ	Ŭ	0.00	*		0.00	*		v	0.0
Frand Total=>	7,061	24	0	7,269	100.00	*	5,886	100.00	*	-4,858	-4,858	100.0
			ING COIL SELE	~~~~							AREAS	

	Total (Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total	Glass	(sf)	(%)
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	168			
Main Clg	0.6	7.3	6.0	300	78.2	64.3	70.6	59.7	56.3	64.5	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	14			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0	0
Totals	0.6	7.3									Wall	164		22	13

	HEATING (DIL SELECTIO	N		P	IRFLOWS (cfi	m)	ENGINEERING	HECKS	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg & OA	0.0	Type	Clg	Htg
	(Mch)	(cfm)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	1.79	SADB	59.9	125.0
Main Htg	-4.9	79	68.0	125.0	Infil	37	37	Clg Cfm/Ton	495.24	Plenm	93.9	64.4
Aux Htg	0.0	0	0.0	0.0	Supply	300	79	Clg Sqft/Ton	277.33	Return	78.0	68.0
Preheat	0.0	300	68.0	59.3	Mincfin	300	0	Clg Btuh/Sqft	43.27	Ret/QA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	300	79	No. People	1	Runamd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	37	0	Htg % QA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	37	0	Htg Cfm/Saft	0.47	Fn BldID	0.1	0.0
Total	-4.9				Auxil	0	0	Htg Btuh/SqFt	-28.92	Fn Frict	0.4	0.0



•

V 600

•

System 7 Block FC - FAN COIL

eaked at Time =	=>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/16	*	Mo	/Hr: 0/ 0	
lutside Air =>	OAL	B/WB/HR: 9	6/ 77/112.0			*	CADB:	96	*	a	ADB: 0	
						*			*			
	Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Percht		Space	Total	Pera
	Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	02 200	*	Sensible	Sensible	Of To
Invelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	⁹)
Skylite Solr	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Skylite Cond	0	0		0	0.00	*	0	0.00	*	C	0	0.0
Roof Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Solar	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Cond	0	0		0	0.00	*	0	0.00	*	. 0	0	0.0
Wall Cond	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0			0	0.00	×	0	0.00	*	0	0	0.0
Infiltration	1,114			1,114	25.93	*	578	17.03	*	0	0	0.0
Sub Total=>	1,114	0		1,114	25.93	*	578	17.03	*	0	0	0.0
internal Loads						*		•	*			
Lights	663	442		1,106	25.74	*	672	19.78	*	0	0	0.0
People	397			397	9.24	*	209	6.16	*	0	0	0.0
Misc	1,472	0	0	1,472	34.26	*	1,488	43.84	*	0	0	0.0
Sub Total=>	2,533	442	0	2,975	69.24	*	2,369	69.78	*	0	0	. 0.0
eiling Load	442	-442		0	0.00	*	448	13.19	*	0	0	. 0.0
utside Air	0	. 0	0	0	0.00	*	0	0.00	*	0	0	0.0
up. Fan Heat				184	4.28	*		0.00	*		0	0.0
et. Fan Heat		24		24	0.56	*		0.00	*		0	0.0
uct Heat Pkup		0		0	0.00	*		0.00	*		0	0.0
V/UNDR Sizing	0			Ō	0.00	*	0	0.00	*	0	0	0.0
xhaust Heat	-	0	0	õ	0.00	*	J. J	0.00	*	·	0	0.0
erminal Bypass		0	0	0		*		0.00	*		0	0.0
		Ū.	Ū	, v	0.00	*		0.00	*		·	•••
rand Total=>	4,089	24	0	4,297	100.00	*	3,395	100.00	*	0	0	0.0
			ING COIL SELE	CTTICAT							REAS	

Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DE	/WB/HR	Gross	Total G	lass (sf)	(8))
(Tons)	(Moh)	(Moh)	(cím)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	137			
0.4	4.3	3.6	300	78.2	67.5	87.0	67.2	63.3	83.5	Part	0			
0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0	C)	0
0.4	4.3									Wall	0	c)	0
	(Tons) 0.4 0.0 0.0	0.4 4.3 0.0 0.0 0.0 0.0	(Tons) (Moh) (Moh) 0.4 4.3 3.6 0.0 0.0 0.0 0.0 0.0 0.0	(Tons) (Moh) (Moh) (cfm) 0.4 4.3 3.6 300 0.0 0.0 0.0 0 0.0 0.0 0.0 0 0.0 0.0 0.0 0	(Tons) (Moh) (Moh) (cfm) Deg F 0.4 4.3 3.6 300 78.2 0.0 0.0 0.0 0 0.0 0.0 0.0 0.0 0 0.0 0.0 0.0 0.0 0 0.0	(Tons) (Moh) (Moh) (cfm) Deg F Deg F 0.4 4.3 3.6 300 78.2 67.5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	(Tons) (Mbh) (Mbh) (cfm) Deg F Deg F Grains 0.4 4.3 3.6 300 78.2 67.5 87.0 0.0 0.0 0.0 0 0.0 0.0 0.0 0.0 0.0 0.0 0 0.0 0.0 0.0	(Tons) (Moh) (Moh) (cfm) Deg F Deg F Grains Deg F 0.4 4.3 3.6 300 78.2 67.5 87.0 67.2 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0 0.0 0.0 0.0	(Tons) (Moh) (Moh) (cfm) Deg F Deg F Grains Deg F Deg F 0.4 4.3 3.6 300 78.2 67.5 87.0 67.2 63.3 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	(Tons) (Mbh) (Mbh) (cfm) Deg F Deg F Grains Deg F Deg F	(Moh) (Moh) (cfm) Deg F Deg F Grains Deg F Deg F Grains Floor 0.4 4.3 3.6 300 78.2 67.5 87.0 67.2 63.3 83.5 Part 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 ExFlr 0.0 0.0 0.0 0.0 0.0 0.0 0.0 Roof	(Tons) (Moh) (cfm) Deg F Deg F Grains Deg F Deg F Grains Floor 137 0.4 4.3 3.6 300 78.2 67.5 87.0 67.2 63.3 83.5 Part 0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 ExFlr 0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 ExFlr 0	(Tons) (Mbh) (cfm) Deg F Deg F Grains Deg F <	(Tons) (Moh) (cfm) Deg F Deg F Grains Deg F Deg F Deg F Deg F Deg F Grains Floor 137 0.4 4.3 3.6 300 78.2 67.5 87.0 67.2 63.3 83.5 Part 0 0.0 <t< th=""></t<>

	HEATING (DIL SELECTIO	XV		A	IRFLOWS (cf	m)	-ENGINEERING	CHECKS	-TEMPERA	TURES	(F) —–
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	Ō	0	Clg Cfm/Sqft	2,19	SADB	67.6	0.0
Main Htg	0.0	0	0.0	0.0	Infil	30	0	Clg Cfm/Ton	837.83	Plenum	88.2	0.0
Aux Htg	0.0	0	0.0	0.0	Supply	300	0	Clg Sqft/Ton	382.61	Return	78.0	0.0
Preheat	-21.8	300	0.0	67.0	Mincim	300	0	Clg Btuh/Sqft	31.36	Ret/CA	78.0	0.0
Reheat	0.0	0	0.0	0.0	Return	300	0	No. People	1	Runamd	78.0	0.0
Humidif	0.0	0	0.0	0.0	Exhaust	30	0	Htg % OA	0.0	Fn MariD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rm Exh	30	0	Htg Cfm/SqFt	0.00	Fn BldID	0.1	0.0
Total	-21.8				Auxil	0	0	Htg Btuh/Saft	-158.97	Fn Frict	0.4	0.0

V 600

PAGE 10



System 8 Block FC - FAN COIL

Peaked at Time		Mo/Hr:	//16			*	M	o/Hr:	7/16	*	M	o/Hr: 0/ 0		
Outside Air —	> 04	DB/WB/HR: 9	6/ 75/105.0			*	c	DADB:	96	*		CADB: 0		
						*				*				
	Space	Ret. Air	Ret. Air	Net				Space	Perant		Space	Total		eran
.	Sens.+Lat.	Sensible	Latent	Tota				sible	Of Tot	*	Sensible	Sensible	o d	f To
Envelope Loads	(Btuh)	(Btuh)	(Btuh)	(Btuh	, ,		(E	Stuh)	(%)	*	(Btuh)	(Btuh)		(3
Skylite Solr	0	0		(0.00) *		0	0.00	*	0	0		0.0
Skylite Cond	0	0		(0.00	*		0	0.00	*	0	0		0.0
Roof Cand	0	0		(0.00	*		0	0.00	*	0	0		0.0
Glass Solar	2,136	0		2,13	5 25.46	; *	2	2,136	31.15	*	0	0		0.0
Glass Cond	202	0		202	2 2.41	*		202	2.95	*	0	0		0.0
Wall Cond	144	15		159	9 1.89) *		144	2.10	*	0	0		0.0
Partition	0			(0.00) *		0	0.00	*	0	0		0.0
Exposed Floor	- 0			(0.00	*		0	0.00	*	0	0		0.0
Infiltration	1,847			1,84	7 22.02	*		645	9.40	*	0	0		0.0
Sub Total=>	4,330	15		4,34	4 51.78	*	3	3,127	45.59	*	0	0		0.0
Internal Loads				·		*				*				
Lights	1,245	830		2,07	5 24.73	*	1	.245	18.15	*	0	0		0.0
People	392			392		*		202	2,95	*	0	0		0.0
Misc	1,440	0	0	1,440) 17.16	*	1	. 440	20,99	*	0	0		0.0
Sub Total=>	3,077	830	0	3,90				2,887 .	42.09	*	0	0		0.0
Ceiling Load	845	-845			0.00			845	12.32	*	Ō	0		0.0
Dutside Air	0	0	0 -	(0.00	* *		0	0.00	*	0	0		0.0
Sup. Fan Heat				12			•		0.00	*		0		0.0
Ret. Fan Heat		16		10					0.00	*		0		0.0
Duct Heat Phup		0		(0.00				0.00	*		0		0.0
W/UNDR Sizing	0			(0.00			0	0.00	*	0	0		0.0
Exhaust Heat		0	0	ć	0.00			-	0.00	*	-	0		0.0
Cerminal Bypass	5	0	0 0		0.00				0.00	*				0.0
		•	•		/ 0.00	*			0.00	*		Ŭ		
Frand Total=>	8,252	16	0	8,390	100.00	*	6	5.859	100.00	*	0	0		0.0
	-,		•	0,000	100.00			.,	200700		•	•		
			ING COIL SE	LECTION								AREAS		•
	l Capacity	-	Coil Airfl		ing DB/WE				B/WB/HR		Gross Total	Glass (sf)	(%)
(Tons		(Mbh)	(cfm)		eg F Gra		Deg F	Deg F			Floor 1	.53		
un Clg 0.		7.0	200	78.2 6	50.6 5	3.1	46.0	44.6			Part	0		
x Clg 0.		0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		ExFlr	14		
nt Vent 0.	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Roof	0	0	
stals 0.	7 8.4										Wall 1	.58	22	1

	HEATING (XIL SELECTIO	N		A	IRFLOWS (cfi	m)	ENGINEERING	HECKS-	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % QA	0.0	Type	Clg	Htg
	(Moh)	(cím)	Deg F	Deg F	Vent	0	0	Clg Cfm/Saft	1.31	SADB	46.4	0.0
Main Htg	0.0	0	0.0	0.0	Infil	34	0	Clg Cfm/Ton	286.04	Plenum	95.4	0.0
Aux Htg	0.0	0	0.0	0.0	Supply	200	0	Clg Sqft/Ton	218.82	Return	78.0	0.0
Preheat	-9.9	200	0.0	45.8	Mincón	200	0	Clg Btuh/Sqft	54.84	Ret/OA	78.0	0.0
Reheat	0.0	0	0.0	0.0	Return	200	0	No. People	1	Runamd	78.0	0.0
Humidif	0.0	0	0.0	0.0	Exhaust	34	٥	Htg & OA	0.0	Fn MerID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Ra Exh	34	0	Htg Cfm/SqFt	0.00	In BlaD	0.1	0.0
Total	-9.9				Auxil	0	0	Htg Btuh/SqFt	-64.86	Fn Frict	0.4	0.0



V 600



· ·

)

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

System 9 Peak SZ - SINGLE ZONE

Cutside Air => Second Envelope Loads Skylite Solr Skylite Cond Roof Cond Glass Solar Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat Ret. Fan Heat	OA Space ens.+Lat. (Btuh) 0 0 3,853 609 1,075		96/ 77/112.0 Ret. Air Latent (Btuh)) Total (Btuh) 0	Perant Of Tot (%)	* * *	OADB: Space	96 Perant	* * *	OAD Space	DB: 3 Total	Per
Envelope Loads Skylite Solr Skylite Cond Roof Cond Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	ens.+Lat. (Btuh) 0 0 0 3,853 609	Sensible (Btuh) 0 0	Latent	Total (Btuh)	Of Tot	*	-			Snace	Total	Per
Envelope Loads Skylite Solr Skylite Cond Roof Cond Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	ens.+Lat. (Btuh) 0 0 0 3,853 609	Sensible (Btuh) 0 0	Latent	Total (Btuh)	Of Tot	* *	-	Percet	* .	Snace	Total	Per
Envelope Loads Skylite Solr Skylite Cond Roof Cond Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	(Btuh) 0 0 3,853 609	(Btuh) 0 0		(Btuh)		*				Space		
Skylite Solr Skylite Cond Roof Cond Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	0 0 0 3,853 609	0 0 0	(Btuh)		(2)		Sensible	Of Tot	* Sen	sible	Sensible	Of
Skylite Cond Roof Cond Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	0 0 3,853 609	0		0	(*)	*	(Btuh)	(%)	* (1	Btuh)	(Btun)	
Roof Cond Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	0 3,853 609	0		0	0.00	*	0	0.00	*	0	0	0
Glass Solar Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	3,853 609	-		0	0.00	*	0	0.00	*	С	0	. 0
Glass Cond Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Autside Air	609	0		0	0.00	*	0	0.00	*	0	0	0
Wall Cond Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Autside Air Sup. Fan Heat		v		3,853	20.78	*	3,853	26.71	*	0	0	0
Partition Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Autside Air Sup. Fan Heat	1.075	0		609	3.29	*	609	4.23	* . : _;	2,665	-2,665	6
Exposed Floor Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat		439		1,514	8.17	*	1,075	7.45	* -:	2,911	-4,100	9
Infiltration Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Autside Air Sup. Fan Heat	0			0	0.00	*	0	0.00	*	0	0	0
Sub Total=> Internal Loads Lights People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat	0			0	0.00	×	0	0.00	*	4,066	-4,066	9
Internal Loads Lights People Misc Sub Total=> Ceiling Load Autside Air Sup. Fan Heat	10,347			10,347	55.81	*	8,446	58.56	* -3(0,500	-30,500	73
Lights People Misc Sub Total=> Ceiling Load Autside Air Sup. Fan Heat	15,884	439		16,323	88.04	*	13,983	96.96	* -40	0,142	-41,331	100
People Misc Sub Total=> Ceiling Load Dutside Air Sup. Fan Heat						*	,		*			
Misc Sub Total=> eiling Load Autside Air Sup. Fan Heat	٥.	0		0	0.00	*	0	0.00	*	0	0	0
Sub Total=> Ceiling Load Sutside Air Sup. Fan Heat	0			0	0.00	*	0	0.00	*	0	0	0
eiling Load Autside Air Sup. Fan Heat	0	0	0	0	0.00	*	0	0.00	*	0	0	0
utside Air Nup. Fan Heat	0	0	. 0	0	0.00	*	0	0.00	*	0	0	0
oup. Fan Heat	439	-439		0	0.00	*	439	3.04	* -:	1,189	0	. 0
• • • • • • • • • • • • • • • • • • • •	· 0	0	0	• 0	0.00	*	0	0.00	÷ •	• 0 •	0	0
et Fan Heat				1,962	10.58	*		0.00	*		0	0
		255		255	1.37	*		0.00	*		0	0
uct Heat Pkup		0		0	0.00	*			ĸ	-	0	0
V/UNDR Sizing	0			0	0.00	*	0		*	0	0	0
xhaust Heat		0	0	0	0.00	*		0.00	ł –		0	0
Cerminal Bypass		0	0	0	0.00	*		0.00	۲		0	0
rand Total=>	16,323	255	0	18,540	100.00	*	14,422	100.00	r r -4	1,331	-41,331	100
			LING COIL SE	LECTION						AR	EAS	
Total (Sens Cap.	Coil Airfl	Enterir	ng DB/WB/	ΉR	Leaving	DB/WB/HR	Gross 1	fotal	G lass (s	sf) (
(Tons)	(Moh)	(Moh)	(cfm)	Deg F Deg	g F Grai	ns	Deg F Deg	F Grains	Floor	1,950	I	
in Clg 1.5	18.5	16.6	1,600	78.0 70	0.8 105	6.6	68.6 67.	7 103.7	Part	0	1	
x Clg 0.0	0.0	0.0	0	0.0 0	0.0 0	0.0	0.0 0.	0.0	ExFlr	78	ł	
t Vent 0.0	0.0	0.0	0	0.0 0	0.0 0	0.0	0.0 0.	0.0	Roof	0	I	0
tals 1.5	18.5								Wall	977	r	65
HEATIN	G COIL SELF	CTION		AIF	TELOWS (c	::ím) –			; CHECKS-	TE	MPERATURE	S (F)·
Capacity			Lvq		Cooling			lg % QA	0.0			,-,

acity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg
1bh)	(cfm)	Deg F	Deg F	Vent	٥	0	Clg Cfm/Sqft	0.82	SADB	69.7	125.0
-40.9	669	68.6	125.0	Infil	433	433	Clg Cfm/Ton	1035.60	Plenum	78.7	66.1
0.0	٥	0.0	0.0	Supply	1,600	669	Clg Sqft/Ton	1262.13	Return	78.0	68.0
-1.0	1,600	68.0	68.6	Mincfm	1,600	0	Clg Btuh/Sqft	9.51	Ret/OA	78.0	68.0
0.0	0	0.0	0.0	Return	1,599	669	No. People	50	Runamd	78.0	68.0
0.0	0	0.0	0.0	Exhaust	433	0	Htg & OA	0.0	Fn MtrID	0.1	0.0
0.0	0	0.0	0.0	Rm Exh	434	0	Htg Cfm/Soft	0.34	Fn BldID	0.2	0.0
-41.9				Auxil	0	0	Htg Btuh/Saft	-21.48	Fn Frict	0.7	0.0
	15h) -40.9 0.0 -1.0 0.0 0.0 0.0	th) (cfm) -40.9 669 0.0 0 -1.0 1,600 0.0 0 0.0 0 0.0 0	th) (cfm) Deg F -40.9 669 68.6 0.0 0 0.0 -1.0 1,600 68.0 0.0 0 0.0 0.0 0 0.0 0.0 0 0.0 0.0 0 0.0 0.0 0 0.0	bh) (cfm) Deg F Deg F -40.9 669 68.6 125.0 0.0 0 0.0 0.0 -1.0 1,600 68.0 68.6 0.0 0 0.0 0.0 0.0 0 0.0 0.0 0.0 0 0.0 0.0 0.0 0 0.0 0.0 0.0 0 0.0 0.0 0.0 0 0.0 0.0	tbh) (cfm) Deg F Deg F Vent -40.9 669 68.6 125.0 Infil 0.0 0 0.0 0.0 Supply -1.0 1,600 68.0 68.6 Mincfm 0.0 0 0.0 0.0 Return 0.0 0 0.0 0.0 Return 0.0 0 0.0 0.0 Exhaust 0.0 0 0.0 0.0 Rm Exh	th) (cfm) Deg F Deg F Vent 0 -40.9 669 68.6 125.0 Infil 433 0.0 0 0.0 0.0 Supply 1,600 -1.0 1,600 68.0 68.6 Mincfin 1,600 0.0 0 0.0 0.0 Return 1,599 0.0 0 0.0 0.0 Exhaust 433 0.0 0 0.0 Rm Exh 434	th) (cfm) Deg F Deg F Vent 0 0 -40.9 669 68.6 125.0 Infil 433 433 0.0 0 0.0 0.0 Supply 1,600 669 -1.0 1,600 68.0 68.6 Mincfm 1,600 0 0.0 0 0.0 0.0 Return 1,599 669 0.0 0 0.0 0.0 Exhaust 433 0 0.0 0 0.0 Rm Exh 434 0	th) (cfm) Deg F Deg F Vent 0 0 Clg Cfm/Sqft 40.9 669 68.6 125.0 Infil 433 433 Clg Cfm/Sqft 0.0 0 0.0 0.0 Supply 1,600 669 Clg Sqft/Ton -1.0 1,600 68.0 68.6 Mincfm 1,600 0 Clg Btuh/Sqft 0.0 0 0.0 0.0 Return 1,599 669 No. People 0.0 0 0.0 0.0 Exhaust 433 0 Htg % QA 0.0 0 0.0 Rn Exh 434 0 Htg Cfm/Sqft	thi (cfm) Deg F Deg F Vent 0 0 Clg Cfm/Sqft 0.82 40.9 669 68.6 125.0 Infil 433 433 Clg Cfm/Ten 1035.60 0.0 0 0.0 0.0 Supply 1,600 669 Clg Sqft/Ten 1262.13 -1.0 1,600 68.0 68.6 Mincfm 1,600 0 Clg Btuh/Sqft 9.51 0.0 0 0.0 0.0 Return 1,599 669 No. People 50 0.0 0 0.0 Exhaust 433 0 Htg % QA 0.0 0.0 0.0 0.0 Rm Exh 434 0 Htg Cfm/Sqft 0.34	th) (cfm) Deg F Deg F Vent 0 0 Clg Cfm/Sqft 0.82 SADB 40.9 669 68.6 125.0 Infil 433 433 Clg Cfm/Sqft 0.82 SADB 0.0 0 0.0 0.0 Supply 1,600 669 clg Sqft/Ton 1035.60 Plenum -1.0 1,600 68.0 68.6 Mincfm 1,600 0 Clg Sqft/Ton 1262.13 Return -1.0 1,600 68.0 68.6 Mincfm 1,600 0 Clg Btuh/Sqft 9.51 Ret/CA 0.0 0 0.0 Return 1,599 669 No. People 50 Runamd 0.0 0 0.0 Exhaust 433 0 Htg % QA 0.0 Fn Hichth 0.0 0.0 0.0 Rm Exh 434 0 Htg Cfm/SqFt 0.34 Fn BlcdtD	tch. (cfm) Deg F Deg F Vent 0 0 Clg Cfm/Sqft 0.82 SADB 69.7 40.9 669 68.6 125.0 Infil 433 433 Clg Cfm/Ton 1035.60 Plenum 78.7 0.0 0 0.0 0.0 Supply 1,600 669 Clg Sqft/Ton 1262.13 Return 78.0 -1.0 1,600 68.0 68.6 Mincfm 1,600 0 Clg Btuh/Sqft 9.51 Ret/CA 78.0 0.0 0 0.0 0.0 Return 1,599 669 No. Feople 50 Runamd 78.0 0.0 0 0.0 0.0 Return 1,599 669 No. Feople 50 Runamd 78.0 0.0 0 0.0 0.0 Exhaust 433 0 Htg % QA 0.0 Fn MtrTD 0.1 0.0 0.0 0.0 Reth 434 0 Htg % Cfm/Sqft <td< th=""></td<>



SensLat. Sensible Latent Total Of Tot * Sensible Of Tot * Sensible Sensible	Peaked at Time	>	Mo/Hr: 7	7/15			*	Mo/Hr:	7/15	*	Ma	/Hr: 13/ 1	
Sens.*Lat. Sensible Latent Total Of Tet * Sensible Of Tet * Sensible Sensible	Outside Air —>	QAD	B/WB/HR: 9	%/ 77/112.0			*	OADB:	96	*	c	ADB: 3	
Sens.*Lat. Sensible Latent Total Of Tot * Sensible Of Tot * Sensible Sensible							*			*			
Envelope Loads (Btuh) (Btuh) (Btuh) (Btuh) (Btuh) (Btuh) (Btuh) (%) * (Btuh) (%)		Space	Ret. Air	Ret. Air	Net	Perant	*	Space	Perant	*	Space	Total	Pera
Skylite Salr 0 0 0.00 * 0 0.00 * 0 0.00 * 0		Sens.+Lat.	Sensible	Latent	Total	Of Tot	*	Sensible	Of Tot	*	Sensible	Sensible	Of To
Skylite Cond 0 <t< td=""><td>•</td><td>(Btuh)</td><td>(Btuh)</td><td>(Btuh)</td><td>(Btuh)</td><td>(%)</td><td>*</td><td>(Btuh)</td><td>(%)</td><td>*</td><td>(Btuh)</td><td>(Btuh)</td><td>(8</td></t<>	•	(Btuh)	(Btuh)	(Btuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(8
Roof Cond 0	+	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Glass Solar 610 0 610 12.94 * 610 17.20 * 0 0 0 Glass Cond 300 0 300 6.36 * 300 8.45 * -1,310 -1,310 10.1 Wall Cond 523 201 724 15.36 * 523 14.76 * -1,717 -2,377 18.1 Partition 0 0 0.00 * 0 0.00 * 0 0.00 * -1,717 -2,377 18.1 Exposed Floor 0 0.00 * 0 0.00 * 0 0.00 * -2,340 -2,340 18.1 Infiltration 2,665 56.53 * 1,912 53.92 * -6,903 -6,903 53.3 Sub Total=>> 4,097 201 4,298 91.18 * 3,344 94.33 * -12,270 -12,930 100.0 Internal Loads * * * * * * * * 0 0	-	0	0		0	0.00	*	0	0.00	*	C	0	0.0
Glass Cond 300 0 300 6.36 * 300 8.45 * -1,310 -1,310 10.1 Wall Cond 523 201 724 15.36 * 523 14.76 * -1,717 -2,377 18.1 Partition 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 Exposed Floor 0 0.00 * 0 0.00 * -2,340 -2,340 18.1 Infiltration 2,665 56.53 * 1,912 53.92 * -6,903 -6,903 53.3 Internal Loads *	Roof Cand	0	0		0	0.00	*	0	0.00	*	0	0	0.0
Wall Cond 523 201 724 15.36 * 523 14.76 * -1.717 -2.377 18.1 Partition 0 0.00 * 0 0 0 0 0 0 0 0 0 0	Glass Solar	10	0		610	12.94	*	610	17.20	*	0	0	0.0
Wall Cond52320172415.36*52314.76* $-1,717$ $-2,377$ 18.35Partition00.00*00.00*00.00*00.00Exposed Floor00.00*00.00*00.00*00.00Infiltration2,6652,66556.53*1,91253.92* $-6,903$	Glass Cond	300	0		300	6.36	*	300	8.45	*	-1,310	-1,310	10.1
Exposed Floor 0 0 0.00 * 0 0.00 * -2,340 -2,340 18.1 Infiltration 2,665 2,665 56.53 * 1,912 53.92 * -6,903 -6,903 53.1 Sub Total=> 4,097 201 4,298 91.18 * 3,344 94.33 * -12,270 -12,930 100.0 Internal Loads * </td <td>Wall Cond</td> <td>523</td> <td>201</td> <td></td> <td>724</td> <td>15.36</td> <td>*</td> <td>523</td> <td>14.76</td> <td>*</td> <td>-1,717</td> <td>-2,377</td> <td>18.3</td>	Wall Cond	523	201		724	15.36	*	523	14.76	*	-1,717	-2,377	18.3
Infiltration 2,665 2,665 56.53 * 1,912 53.92 * -6,903 -6,903 53.1 Sub Total=> 4,097 201 4,298 91.18 * 3,344 94.33 * -12,270 -12,930 100.0 Internal Loads *<	Partition	0			0	0.00	*	0	0.00	*	0	0	0.0
Sub Total=> 4,097 201 4,298 91.18 3,344 94.33 -12,270 -12,930 100.00 Internal Loads *	Exposed Floor	0			0	0.00	*	0	0.00	*	-2,340	-2,340	18.1
Internal Loads *	Infiltration	2,665			2,665	56.53	*	1,912	53.92	*	-6,903	-6,903	53.3
Internal Loads * * Lights 0 0 0.00 * 0 0.00 * 0 0.00 0 0 0.00 * 0	Sub Total=>	4,097	201		4,298	91.18	*	3.344	94.33	*	-12,270	-12,930	100.0
People 0 0 0.00 * 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 <th< td=""><td>Internal Loads</td><td></td><td></td><td></td><td></td><td></td><td>*</td><td></td><td></td><td>*</td><td></td><td></td><td></td></th<>	Internal Loads						*			*			
Misc 0 0 0 0 0.00 * 0 0.00 * 0 0.00 * Sub Total=> 0 0 0 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0 0.00 * 0 0 0.00 * 0	Lights	0	0		0	0.00	*	. 0	0.00	*	0	0	0.0
Misc 0 0 0 0 0.00 * 0 0.00 * 0 0.00 * Sub Total=> 0 0 0 0 0.00 * 0 0.00 * 0 0.00 * Ceiling Load 201 -201 0 0.00 * 201 5.67 * -660 0 0.00 Cutside Air 0 0 0 0.00 * 0 0.00 * 0 0.00 0 0.00 Sup. Fan Heat 368 7.80 * 0.00 * 0 0.00 * 0 0.00 Sup. Fan Heat 48 48 1.01 * 0.00 * 0 0.00 Duct Heat 48 48 1.01 * 0.00 * 0 0.00 CV/UNDR Sizing 0 0 0.00 * 0 0.00 * 0 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0 0.00 * 0 0.00 Terminal Bypass 0 0 0.00 * 0.00 * 0 0.00 0 0.00 0 0.00 0 0	People	0			0	0.00	*	0	0.00	*	0	0	0.0
Cailing Load 201 -201 0 0.00 * 201 5.67 * -660 0 0.00 Outside Air 0 0 0 0.00 * 0 0.00 * 0 0.00 0 0.00 0 0.00 0 0.00 0 0.00 0	Misc	0	0	0	0	0.00	*	0	0.00	*	0	0	0.0
Outside Air 0 0 0 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0.00 * 0 0 0.00 * 0 0 0.00 * 0 0 0.00 * 0	Sub Total=>	0	0	. O	0	0.00	*	0	0.00	*	• 0	. 0	0.0
Sup. Fan Heat 368 7.80 * 0.00 * 0<	Ceiling Load	201	-201		0	0.00	*	201	5.67	*	-660	0	0.0
Sup. Fan Heat 368 7.80 * 0.00 * 0.00 * 0.00 Ret. Fan Heat 48 48 1.01 * 0.00 * 0.00 * 0.00 Duct Heat Pkup 0 0 0.00 * 0.00 * 0.00 * 0.00 CV/UNDR Sizing 0 0 0.00 * 0.00 * 0 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0 0.00 Terminal Bypass 0 0 0.00 * 0.00 * 0 0.00	Outside Air	0	0	0	0	0.00	*	0		*	0	0	0.0
Ret. Fan Heat 48 48 1.01 * 0.00 * 0 0.00 Duct Heat Pkup 0 0 0.00 * 0.00 * 0 0.00 OV/UNDR Sizing 0 0 0.00 * 0 0.00 * 0 0 0.00 Exhaust Heat 0 0 0.00 * 0.00 * 0 0.00 0 0.00 Terminal Bypass 0 0 0.00 * 0.00 * 0 0.00 0 0.00	Sup. Fan Heat				368		*			*		0	0.0
Duct Heat Planp 0	Ret. Fan Heat		48		48		*			*		0	0.0
OV/UNDR Sizing 0 0 0.00 * 0	Duct Heat Pkup		0		0		*			*		0	0.0
Exhaust Heat 0 <t< td=""><td>OV/UNDR Sizing</td><td>0</td><td></td><td></td><td>0</td><td></td><td>*</td><td>0</td><td></td><td>*</td><td>0</td><td>0</td><td>0.0</td></t<>	OV/UNDR Sizing	0			0		*	0		*	0	0	0.0
Terminal Bypass 0 0 0 0.00 * 0.00 * 0 0.0 * *	Exhaust Heat		0	0	0		*	•		*	-	0	0.0
* *	Terminal Bypass		-	-	ñ		*			*		0	0.0
Grand Total=> 4,298 48 0 4,714 100.00 * 3,545 100.00 * -12,930 -12,930 100.0			·	· ·	v	0.00			0.00	*		•	
	Grand Total==>	4,298	48	0	4,714	100.00	*	3,545	100.00	*	-12,930	-12,930	100.0

													~			
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DE	/WB/HR	Gross (Total	Glass	(sf)	(%)	
	(Tons)	(Moh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	440				
Main Clg	1.3	15.5	13.0	600	78.2	70.0	100.7	72.2	62.8	72.9	Part	0				
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	45				
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0	C)
Totals	1.3	15.5									Wall	567		32	6	;

	HEATING (OIL SELECTIO	N		A	IRFLOWS (cf	m)	ENGINEERING (HECKS-	TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg % CA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.36	SADB	72.5	125.0
Main Htg	-12.0	209	72.0	125.0	Infil	98	98	Clg Cfm/Ton	464.32	Plenm	79.4	63.3
Aux Htg	0.0	0	0.0	0.0	Supply	600	209	Clg Sqft/Ton	340.65	Return	78.0	68.0
Preheat	-2.6	600	68.0	72.0	Mincfin	600	0	Clg Btuh/Sqft	35.23	Ret/CA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	600	209	No. People	8	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	98	0	Htg % OA	0.0	Fn MariD	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Ra Exh	98	0	Htg Cfm/SqFt	0.48	Fn BldID	0.1	0.0
Total	-14.6				Auxil	0	0	Htg Btuh/SqFt	-33.22	Fn Frict	0.4	0.0

-

)

V 600 PAGE 13

System 11 Peak SZ - SINGLE ZONE

Peaked at Time => Mo/Hr: 7/15 * Mo/Hr: 7/16 * Mo/Hr: 13/ 1 Outside Air => QADB/WB/HR: 96/ 77/112.0 × OADB: 96 * OADB: 3 * Space Ret. Air Ret. Air Space Net Perant * Perant * Space Total Percet Sens.+Lat. Sensible Latent Total Of Tot * Sensible Of Tot * Sensible Sensible Of Tot Envelope Loads (Btuh) (Btuh) (Btuh) (%) * (Btuh) (Btuh) (%) * (Btuh) (Btuh) (ક) 0 0 Skylite Solr 0 0.00 * 0.00 * 0 0.00 0 0 Skylite Cand 0 Roof Cand 0 0 0 0 C 0 0 0 0.00 * 0 0.00 * 0 0.00 Roof Cand 0 0 0 0.00 * 0 0.00 * 0.00 Glass Solar 24,134 Glass Cond 3,883 28.06 * 24,134 18.97 * 25,382 0.00 24,134 0 3,883 0 18,061 2,420 4.26 * -16,981 -16,981 3.05 * 3,883 10.82 3,858 Wall Cond 18,061 18,310 20.24 * -53,853 -66,849 20,482 16.10 * 42.59 Partition 0 0 0 0 0 0 0.00 * 0.00 * 0.00 Exposed Floor 0 0 0 0.00 * 0.00 * 0 0.00 -73,115 -73,11 47,186 93,265 Infiltration 47,186 37.08 * 95,685 75.19 * 19,685 21.76 * -143, 948 2,420 Sub Total=> 74.33 * 67,235 Internal Loads 19,298 12,866 8,919 20,547 0 Lights 32,164 25.28 * 19,298 21.33 * 0 0 0.00 People 8,919 7.01 * 4,655 5.15 * 0 0 0.00 0 Misc 20,547 Ω 22.98 * 0 20,547 16.15 * 20,792 0 0.00 . 48,765 Sub Total=> 44,745 49.46 * 12,866 0 61,631 48.43 * 0 0.00 0 Ceiling Load 15,286 -15,286 0 0.00 * 0 0.00 * 0.00 * -12,996 · 0.00 15,346 16.96 * 0 Outside Air 0 0 0 0 0.00 * 0 0 0.00 Sup. Fan Heat 6,020 4.73 * 0.00 * 0 0.00 Ret. Fan Heat 783 783 0.61 * 0.00 * 0.00 0 Duct Heat Pkup 0 0.00 * 0.00 * 0 0 0.00 OV/UNDR Sizing -36,866 -36,866 -28,97 * -36,866 -40.75 * 0 0 0.00 Exhaust Heat 0 0.00 * ٥ 0 0.00 0.00 * 0 Terminal Bypass 0 0.00 * 0.00 * 0 0 0 0.00 783 Grand Total=> 120,449 127,252 100.00 * 90,460 100.00 * -156,944 -156,944 100.00 0 200220

												AK	EAS		
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross	Total	Glass	(sf)	(웅)
	(Tons)	(Mbh)	(Moh)	(cfm)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	4,188			
Main Clg	13.7	164.1	132.8	4,910	78.0	64.9	73.9	60.1	53.8	53.6	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	0		0	0
Totals	13.7	164.1									Wall	3,521		416	12

	HEATING (OIL SELECTIO	N		A	IRFLOWS (cfi	m)	ENGINEERING	HECKS	-TEMPERA	TURES	(F)
	Capacity	Coil Airfl	Ent	Lvg	Type	Ccoling	Heating	Clg & OA	0.0	Type	Clg	Htg
	(Mbh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.17	SADB	61.0	125.0
Main Htg	-156.9	2,541	68.0	125.0	Infil	1,038	1,038	Clg Cfm/Ton	359.01	Plenum	89.5	58.2
Aux Htg	0.0	0	0.0	0.0	Supply	4,910	2,541	Clg Sqft/Ton	306.22	Return	78.0	68.0
Preheat	0.0	4,910	68.0	59.9	Mincfm	4,910	0	Clg Btuh/Sqft	39.19	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	4,910	2,541	No. People	23	Runarnd	78.0	68.0
Amidif	0.0	0	0.0	0.0	Exhaust	4,910	0	Htg & OA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Rn Exh	1,037	0	Htg Cfm/Saft	0.61	Fn BldID	0.2	0.0
Total	-156.9				Auxil	0	0	Htg Btuh/Saft	-37.47	Fn Frict	0.7	0.0







System 12 Peak SZ - SINGLE ZONE

eaked at Time =	=>	Mo/Hr: 7	7/15				*	Mo/Hr:	7/16	*	Ma	/Hr: 13/ 1	
)utside Air =>	QAI	DB/WB/HR: 9	36 7 77	/112.0			*	OADB:	96	*	C	ADB: 3	
							*			*			
	Space				Net	Perant	*	Space	Peran	: *	Space	Total	Peran
	Sens.+Lat.	Sensible		tent	Total		*	Sensible	Of Tot	*	Sensible	Sensible	Of To
invelope Loads	(Btuh)	(Btuh)	(B	tuh)	(Btuh)	(%)	*	(Btuh)	(%)	*	(Btuh)	(Btuh)	(%
Skylite Solr	0	0			0	0.00	*	0	0.00	*	0	0	0.0
Skylite Cand	0	0			0	0.00	*	0	0.00	*	C	0	0.0
Roof Cand	17,656	0			17,656	10.74	*	17,387	15.68	*	-17,495	-17,495	0.0
Glass Solar	24,192	0			24,192	14.72	*	25,443	22.94	*	0	0	0.0
Glass Cond	3,893	0			3,893	2.37	*	3,867	3.49	*	17,021	-17,021	9.4
Wall Cond	21,053	0			21,053	12.81	*	21,342	19.25	*	-62,772	-62,772	34.70
Partition	0				0	0.00	*	0	0.00	*	0	0	0.0
Exposed Floor	0				0	0.00	*	0	0.00	*	0	0	0.00
Infiltration	53,959				53,959	32.82	*	22,510	20.30	*	-83,610	-83,610	46.2
Sub Total=>	120,753	0			120,753	73.46	*	90,551	81.66	*	-180,898	-180,898	100.00
internal Loads							*			*			
Lights	24,382	9,753			34,135	20.77	*	24,382	21.99	*	0	0	0.0
People	11,634				11,634	7.08	*	6,072	5.48	*	0	0	0.0
Misc	17,309	0		0	17,309	10.53	*	17,506	15.79	*	0	0	0.00
Sub Total=>	53, 325	9,753		0	63,078		*	47,960	43.25	*	0	• 0	0.0
eiling Load	0	0			. 0	0.00	*	0	0.00	*	0	0	0.00
utside Air	0	· 0	• ·	0	0	0.00	*	0	0:00	*	0	0	0.00
up. Fan Heat					7,234		*		0.00	*		0	0.00
et. Fan Heat		940			940		*		0.00	*		0	0.0
uct Heat Phup		0			0		*		0.00	*		0	0.0
V/UNDR Sizing	-27,619	÷			-27.619		*	-27,619	-24.91	*	0	ů.	0.0
xhaust Heat		0		0	27,013		*	2.,010	0.00	*	Ŭ	õ	0.0
'eminal Bypass		ő		õ	Ő		*		0.00	*		0	0.0
		0		v	U	0.00	*		0.00	*		Ŭ	0.0
rand Total=>	146,460	10.693		0	164,387	100.00	*	110,892	100.00	*	-180,898	-180,898	100.00

	*****			DLING COIL SE	LECTION	}				~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		AR	EAS		
	Total	Capacity	Sens Cap.	Coil Airfl	Ent	ering D	B/WB/HR	Lea	wing DB	/WB/HR	Gross (fotal	Glass	(sf)	(%)
	(Tons)	(Moh)	(Moh)	(cfin)	Deg F	Deg F	Grains	Deg F	Deg F	Grains	Floor	4,188			
Main Clg	16.0	192.0	155.5	5,900	78.0	64.9	73.9	5 9 .7	54.1	55.5	Part	0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Roof	5,176		0	. 0
Totals	16.0	192.0									Wall	3,236		417	13

	HEATING (DIL SELECTIO	N		A	IRFLOWS (cfi	m)	ENGINEERING	HECKS-	TEMPERA	TURES	(F) —
	Capacity	Coil Airfl	Ent	Lvg	Type	Cooling	Heating	Clg % OA	0.0	Type	Clg	Htg
	(Moh)	(cfm)	Deg F	Deg F	Vent	0	0	Clg Cfm/Sqft	1.41	SADB	60.7	125.0
Main Htg	-180.9	2,9 29	68.0	125.0	Infil	1,187	1,187	Clg Cfm/Tan	368.74	Plenum	78.0	68.0
Aux Htg	0.0	0	0.0	0.0	Supply	5,900	2,929	Clg Sqft/Ton	261.74	Return	78.0	68.0
Preheat	0.0	5,900	68.0	59.5	Mincîn	5,900	0	Clg Btuh/Sqft	45.85	Ret/OA	78.0	68.0
Reheat	0.0	0	0.0	0.0	Return	5,900	2,929	No. People	30	Runarnd	78.0	68.0
Humidif	0.0	0	0.0	0.0	Exhaust	5,900	0	Htg 3 OA	0.0	Fn MtrID	0.1	0.0
Opt Vent	0.0	0	0.0	0.0	Ra Exh	1,183	0	Htg Cim/Saft	0.70	Fn BldID	0.2	0.0
Total	-180.9				Auxil	0	0	Htg Btuh/Saft	-43.19	Fn Frict	0.7	0.0

.



۰.

· .



Month	ELEC On Peak (kWh)	DEMAND On Peak (kW)	STEAM (Therm)
Jan	10,633	53	611
Feb	9,547	54	532
March	10,846	54	374
April	8,658	54	6
May	10,038	54	0 .
June	17,624	91	0
July	20,992	99	0
Aug	19, 393	92	0
Sept	12,050	84	0
Oct	9,581	54	0
Nov	8,926	53	70
Dec	9,962	54	814
Total	148,250	99	2,407

Building Energy Consumption	=	58,199	(Btu/Sq Ft/Year)
Source Energy Consumption	-	143, 339	(Btu/Sq Ft/Year)

.

.

Floor Area = 12,830 (Sq Ft)

.





.

-

Trane Air Conditioning Economics By: CLARK RICHARDSON BISKUP

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 2 BASE LOAD .

m Code Jan Feb Max Apr May June July Jung Sep Occ Nov Dec Total 0 Lights ELEC 28.3															
0 LIGENS 5281 4672 5554 987 5554 28.3 2	Ref Num	Equip - Code	Jan	Feb	Mar	Apr		-	-		Seo	Oct.	Nov	Dec	Total
EZC 5281 4672 5554 997 5524 28.3 2							1		1		2015				
PK 28.3 2	0		5001	4070		4007				~~~~					~ ~ ~
MISC ID EXEC ID EXEC ID GRS ID GRS ID GRS ID EXEC ID EX															
1 MSC DD ELEX 2947 2601 3121 2774 3121 3260 3069 3644 2977 2947 2601 16.7 16.7 18.9		PR	28.3	28.3	28.3	28.3	28.3	28.3	28.3	28.3	28.3	28.3		28.3	28.3
PK 16.7 16.7 16.7 16.7 16.7 18.9 1	1														
2 MISC LD GRS 0															-
GRS 0		PK	16.7	16.7	16.7	16.7	16.7	18.9	18.9	18.9	18.9	16.7	16.7	16.7	18.9
FX 0.0 0.	2	MISC LD													
3 MTSC LD 0 </td <td></td> <td>GAS</td> <td>0</td>		GAS	0	0	0	0	0	0	0	0	0	0	0	0	0
OTL 0		PK	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
• FK 0.0	з	MISC LD													
FR 0.0 0.		OIL	0	0	0	0	0	0	0	٥	0	0	0	0	0
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$		PK	0.0							•					
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	4	MISC ID													
FX 0.0 0.	•		0	0	٥	n	0	n	0	n	٥	0	0	0	0
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$															
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	5	MISC ID													
FK 0.0 0	5		٥	٥	٥	0	٥	0	0	0	0	0	0	0	0
6 MISC ID P CHILL 0													-		
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$				0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
FK 0.0 <td>6</td> <td></td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>•</td> <td>•</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td>	6		0	0	0	0	0	0	•	•	0	0	0	0	0
1 EQ1121S ELEC AC RECIP CHILLER 20-60 T 0 0															
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$			0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FK 0.0 0.0 0.0 0.0 28.1 32.1 27.0 20.7 0.0 0.0 0.0 32.1 1 EQ5200 CONDENSER FANS ELEC 0 0 0 0 0 2,528 FK 0.0 0.0 0.0 0.0 0.0 3.6 4.7 3.4 2.8 0.0 0.0 0.0 4.7 1 EQ5001 CHILLED WATER POMP C.V. ELEC 0 0 0 0 3.6 4.7 3.4 2.8 0.0 0.0 0.0 4.7 1 EQ5001 CHILLED WATER POMP C.V. ELEC 0 0 0 3.6 3.0 3.0 3.0 0.0 0.0 0.0 3.6 FK 0.0 0.0 0.0 0.0 3.0 3.0 3.0 0.0 0.0 0.0 3.6 1 EQ5011 CHILLED WATER POMP C.V. ELEC 0 0 0 3.0 3.0 3.0 0.0 0.0 3.6 1 EQ5313 CONTROLS <t< td=""><td>1</td><td>_</td><td>•</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>	1	_	•												
1 EQ5200 CONDENSER FAINS ELEC 0 0 0 0 645 967 671 244 0 0 0 2,528 FK 0.0 0.0 0.0 0.0 3.6 4.7 3.4 2.8 0.0 0.0 0.0 4.7 1 EQ5001 CHILLED WATER POMP C.V. ELEC 0 0 0 0 3.6 1017 1017 594 0 0 0 3.6 3.6 PK 0.0 0.0 0.0 0.0 3.0 3.0 3.0 0.0 0.0 0.0 3.6 I EQ5001 CHILLED WATER POMP C.V. ELEC 0 0 0 3.6 3.0 3.0 3.0 0.0 0.0 3.0 I EQ5313 CONTROLS ELEC 0 0 0 0 3.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3															
ELEC 0 0 0 0 645 967 671 244 0 0 0 2,528 PK 0.0 0.0 0.0 0.0 3.6 4.7 3.4 2.8 0.0 0.0 0.0 4.7 1 EQ5001 CHILLED WATER PCMP C.V. ELEC 0 0 0 0 3.6 117 1017 594 0 0 0 3.6 12.8 100 0.0 0.0 3.6 14.7 PK 0.0 0.0 0.0 0.0 984 1017 1017 594 0 0 0 3.6 PK 0.0 0.0 0.0 0.0 3.0 3.0 3.0 3.0 0.0 0.0 0.0 3.63 PK 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0		PK	0.0	0.0	0.0	0.0	0.0	28.1	32.1	27.0	20.7	0.0	0.0	0.0	32.1
PK 0.0 0.	1														
1 EQ5001 CHILLED WATER POMP C.V. ELEC 0 0 0 0 984 1017 1017 594 0 0 0 3,612 PK 0.0 0.0 0.0 0.0 0.0 3.0 3.0 3.0 3.0 0.0 0.0 0.0 3.0 1 EQ5313 CONTROLS ELEC 0 0 0 0 99 102 102 60 0 0 3.0 1 EQ5313 CONTROLS ELEC 0 0 0.0 0.0 0.0 0.0 0.0 3.63 PK 0.0 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.0 0.0 0.3 2 EQ1170S AC COND COND COND 0.0															
ELEC 0 0 0 0 0 0 984 1017 1017 594 0 0 0 3,612 PK 0.0 0.0 0.0 0.0 3.0 3.0 3.0 3.0 0.0 0.0 0.0 3.0 1 EQ5313 CONTROLS ELEC 0 0 0 0 99 102 102 60 0 0 0.363 PK 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.		PK	0.0	0.0	0.0	0.0	0.0	3.6	4.7	3.4	2.8	0.0	0.0	0.0	4.7
PK 0.0 0.0 0.0 0.0 0.0 3.0 3.0 3.0 0.0 0.0 0.0 3.0 1 EDEC 0 0 0 0 99 102 102 60 0 0 0 363 PK 0.0 0.0 0.0 0.0 0.0 0.0 0.0 363 PK 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.0 0.0 0.3 2 EQ1170S AC COND COMP <20 TONS	1	EQ5001		CHIL	LED WATE	R PUMP C	.v.								
1 EQ5313 CONTROLS ELEC 0 0 0 0 99 102 102 60 0 0 363 PK 0.0							0	984				0			•
ELEC 0 0 0 0 0 99 102 102 60 0 0 0 363 PK 0.0 0.0 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.0 0.0 0.3 2 EQ1170S AC COND COMP <20 TONS ELEC 0 0 0 0 439 195 33 0 0 0 668 PK 0.0 0.0 0.0 0.0 0.0 1.6 1.4 1.3 0.0 0.0 1.6		PK	0.0	0.0	0.0	0.0	0.0	3.0	3.0	3.0	3.0	0.0	0.0	0.0	3.0
ELEC 0 0 0 0 0 99 102 102 60 0 0 0 363 PK 0.0 0.0 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.0 0.0 0.3 2 EQ1170S AC COND COMP <20 TONS ELEC 0 0 0 0 439 195 33 0 0 0 668 PK 0.0 0.0 0.0 0.0 0.0 1.6 1.4 1.3 0.0 0.0 1.6	1	EQ5313		CONT	ROLS										
PK 0.0 0.0 0.0 0.0 0.3 0.3 0.3 0.3 0.0 0.0 0.0 0.3 2 EQ1170S AC COND COMP <20 TONS			0			0	0	99	102	102	60	0	0	0	363
ELEC 0 0 0 0 0 0 439 195 33 0 0 0 668 PK 0.0 0.0 0.0 0.0 1.6 1.4 1.3 0.0 0.0 1.6		PK		0.0											
ELEC 0 0 0 0 0 0 439 195 33 0 0 0 668 PK 0.0 0.0 0.0 0.0 1.6 1.4 1.3 0.0 0.0 1.6	2	E01170S		AC O	OND COMP	<20 TON	s								
PK 0.0 0.0 0.0 0.0 0.0 1.6 1.4 1.3 0.0 0.0 0.0 1.6	-	-	0					0	439	195	33	0	٥	٥	668
						• -			2						

EQUIPMENT ENERGY CONSUMPTION

2 EQ5200 CONDENSER FANS





EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 2 BASE LOAD

	elec PK	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	58 0.2	24 0.2	4 0.2	0 0.0	0 0.0	0 0.0	86 0.2
2	EQ5313 ELEC PK	0 0.0	0.0	ROLS 0 0.0	0 0.0	0 0.0	0 0.0	102 0.3	86 0.3	21 0.3	0 0.0	0 0.0	0 0.0	209 - 0.3
1	EQ4371 ELEC PK	20 0.1	FAN (18 0.1	0011. SUP 18 0.1	PLY FAN 13 0.1	15 0.1	28 0.1	35 0.1	35 0.1	21 0.1	17 0.1	13 0.1	13 0.1	246 0.1
2	EQ4371 ELEC PK	0 0.0	FAN (1 0.1	2011. SUP 15 0.1	PLY FAN 13 0.1	15 0.1	24 0.1	18 0.1	18 0.1	13 0.1	14 0.1	13 0.1	12 0.1	157 0.1
3	EQ4371 ELEC PK	12 0.2	FAN 0 33 0.2	COIL SUP 39 0.2	PLY FAN 35 0.2	39 0.2	69 0.2	48 0.2	48 0.2	35 0.2	37 0.2	35 0.2	33 0.2	462 0.2
4	EQ4371 ELEC PK	0 0.0	FAN 0 0 0.0	2011. SUP 15 0.1	PLY FAN 13 0.1	15 0.1	25 0.1	· 17 0.1	18 0.1	13 0.1	14 0.1	13 · 0.1	12 0.1	154 0.1
5	EQ4371 ELEC PK	4 0.0	FAN (3 0.0	0.0	PLY FAN 2 0.0	3 0.0	10 0.1	19 0.1	18 0.1	10 0.1	4 0.1	2 0.0	4 0.0	83 0.1
6	EQ4371 ELEC PK	4 0.0	FAN (3 0.0	OIL SUP 4 0.0	PLY FAN 3 0.0	15 0.1	23 0.1	19 0.1	18 0.1	13 0.1	14 0.1	13 0.1	10 0.1	140 0.1
7	eq4371 Elec Pk	14 0.1	FAN 0 12 0.1	2011. SUPP 15 0.1	PLY FAN 13 0.1	15 0.1	15 0.1	16 0.1	17 0.1	13 0.1	14 0.1	13 0.1	12 0.1	169 0.1
8	EQ4371 ELEC PK	0 0.0	FAN 0 7 0.1	0.1 00000000000000000000000000000000000	PLY FAN 9 0.1	10 0.1	17 0.1	11 0.1	12 0.1	9 0.1	9 0.1	9 0.1	8 0.1	110 0.1
9	EQ4003 ELEC PK	95 0.5	FC CE 85 0.5	MIRIF. 1 87 0.5	EAN C.V. 36 0.5	26 0.5	26 0.5	364 1.2	189 1.2	55 1.2	28 0.5	31 0.5	108 0.5	1,130 1.2
10	EQ4371 ELEC PK	11 0.1	FAN (10 0.1	DIL SUPP 10 0.1	PLY FAN 4 0.1	3 0.1	3 0.1	10 0.2	28 0.2	6 0.2	3 0.1	3 0.1	11 0.1	102 0.2
11	EQ4003 ELEC PK	503 1.9	FC CE 448 1.9	NIRIF. 1 456 1.9	FAN C.V. 300 1.9	579 3.6	878 3.6	1094 3.6	959 3.6	573 3.6	546 3.6	303 1.9	533 1.9	7,172 3.6
12	EQ4003 ELEC PK	590 2.2	FC 05 527 2.2	NTRIF. 1 552 2.2	AN C.V. 346 2.2	630 4.4	916 4.4	1226 4.4	1030 4.4	637 4.4	652 4.4	402 2.2	624 2.2	8,133 4.4

1 CONVERIR

STEAM TO HOT WATER CONVERTER



•

•

EQUIPMENT ENERGY CONSUMPTION - ALTERNATIVE 2 BASE LOAD

	p steam Pk	611 4.4	532 4.4	374 4.4	6 1.7	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	0 0.0	70 3.7	814 4.4	2,407 4.4
1	EQ5020		HEAT	WATER CI	RC. PUM	e.v.								
	ELEC	940	919	773	89	0	0	0	0	0	0	257	1017	3, 994
	PK	3.0	3.0	3.0	3.0	0.0	0.0	0.0	0.0	0.0	0.0	3.0	3.0	3.0
1	EQ5060		CONDE	INSATE RE	IURN PU	P								
	ELEC	213	208	175	20	0	0	0	0	0	0	58	231	906
	PK	0.7	0.7	0.7	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.7	0.7

V 600 PAGE 19



UTILITY PEAK CHECKSUMS - ALTERNATIVE 2 BASE LOAD

UTILITY PEAK CHECKSUMS

Utility ELECTRIC DEMAND

Peak Value 99.2 (kW) Yearly Time of Peak 15 (hr) 7 (mo)

Hour 15 Month 7

Ecp. Ref. Num. Cooling 1	Equipment Code Name Equipment	Equipment Description	Utility Demand (KW)	
1 2		AC RECIP CHILLER 20-60 T AC COND COMP <20 TONS		40.36 2.08
Sub Tota	1		42.1	42.44
Sub Tota	1		0.0	*****
Air Movi	ng Equipment			
1 2 3 4 5 6 7 8 9 11 12 Sub Total Sub Total		SUMATION OF FAN ELECTRICAL DEMAND SUMATION OF FAN ELECTRICAL DEMAND	0.1 0.2 0.1 0.1 0.1 0.1 0.1 1.2 3.6 4.4 9.9	0.08 0.22 0.08 0.08 0.08 0.08 0.08 0.05 1.19 3.65
Miscellar	neous			
Lights	474 5 4		28.3	
Base Ut:				0.00
Misc Eq. Sub Total	•		18.9	
	-		47.1	47.53
Grand Tot	tal		99.2	100.00



.

•



.

CALIFORNIA TITLE 24 COMPLIANCE - ALTERNATIVE 2 BASE LOAD

 CALIFORNIA	TITLE	24	COMPLIANCE	REPORT	-

Weather Name	FTLVNWIH
Gross Conditioned Floor Area (sqft)	12,830
ACM Multiplier	1.008

ENER	lGΥ	USE	S I	имм	AF	λY
------	-----	-----	-----	-----	----	----

	ELEC (KWh/yr)	DISTRICT STEAM (kBtu/yr)	PERCENT OF TOTAL ENERGY (%)	TOTAL SOURCE ENERGY (KBtu/yr)	ADJUSTED UNIT SOURCE ENERGY (kBtu/yr-sf)
Primary Heating	906.1	240,718.4	32.7	330,236.8	25.9
Primary Cooling					
Compressor	20,900.9	0.0	9.6	214,025.3	16.8
Tower/Cond Fans	2,614.5	0.0	1.2	26,772.2	2.1
Condenser Pump	0.0	0.0	0.0	0.0	0.0
Other Accessories	572.4	0.0	0.3	5,861.4	0.5
Auxiliary					
Supply Fans	18,057.3	0.0	8.3	184,907.0	14.5
Circulation Pumps	7,606.2	0.0	3.5	77,887.2	. 6.1
Base Utilities	0.0	0.0	0.0	0.0	0.0
Subtotal	25,663.4	0.0	11.7	262,794.2	20.6
Lighting	61,856.7	0.0	28.3	633, 414.1	49.8
Receptacle	35,735.9	0.0	16.3	365,936.9	28.8
Domestic Hot Water	0.0	0.0	0.0	0.0	0.0
Cogeneration	0.0	0.0	0.0	0.0	0.0
Totals	148,250.0	240,718.4	100.0	1,839,041.0	144.5

V 600 PAGE 21

. .



ECO-M3

<u>.</u>

SERVICE STEAM PIPING AND TRAPS





STEAM PIPING AND TRAPS ENERGY CONSERVATION OPPORTUNITY: ECO-M3

PURPOSE:

The purpose of this Energy Conservation Opportunity (ECO-M3) is to calculate the savings realized by servicing the steam piping and the steam traps. Steam traps are designed to hold steam in the heating device until it gives up its latent heat, and to separate condensate from the steam supply. The steam trap then allows the liquid condensate to discharge and return to the boilers where it is reheated into steam.

Steam traps are mechanical devices that wear with time, and eventually fail. Steam trap failure can occur in the open position, or in the closed position. When a trap fails in the closed position it is usually noticed and repaired quickly. This is because condensate backs up into the heating device, reducing the efficiency of the heat transfer surface, and the heating device can no longer function properly.

More commonly, steam traps fail in the open position, and trap failure is not as readily apparent. An open steam trap needlessly wastes energy by allowing steam to escape through a vent line to the atmosphere, or by condensing in the condensate piping. Condensate piping is normally installed in chases, tunnels, mechanical rooms or other unconditioned spaces. When condensate is allowed to give up its latent heat to these areas, it translates into increased energy costs.

Steam traps must also vent air from the piping system to the atmosphere to prevent the corrosive effects of oxygen on the pipe, which will eventually lead to the premature failure of the piping system.

Steam trap, and steam piping maintenance and repair are vital to the control of energy usage. The frequency of steam trap inspection depends on the steam supply pressure, and the type of trap. Steam traps operating at pressures between 30 psig and 120 psig, should be inspected monthly. Steam traps operating at pressures below 30 psig should be inspected on a semi-annual basis. When faulty steam traps are discovered they should be repaired, or replaced with a new steam trap.

There are three methods available for the inspection of steam traps as follows:

- 1) Temperature Testing.
- 2) Sonic Testing.
- 3) Manual Inspection.

Due to the cost of the temperature and sonic testing equipment, the specialized training required for their operation, and the changing maintenance personnel at the USDB, the first two methods are not advisable "in house". Temperature and sonic testing can be performed reliable by a trap testing service. Manual inspection involves



the installation of a test valve downstream from each steam trap, to observe the steam and condensate as they escape the test valve.

The following is a guideline of what to look for when manually testing steam traps:

Condensate Discharge

- 1) Intermittent condensate discharge from disc traps indicates normal operation.
- 2) Thermostatic traps can have a continuous discharge under heavy load, or an intermittent discharge of condensate under light load.
- 3) The inverted bucket trap can also have a continuous, or intermittent discharge of condensate depending upon the load. When an inverted bucket trap operates under a **very** small load, it can have a continuous condensate discharge, and will display a "dribbling effect".

Flash Steam

Condensate under pressure is able to hold more heat (BTU's) per pound than condensate at atmospheric pressure. When the condensate is discharged from the steam trap, this extra heat is re-evaporated into steam (flash steam).

- 1) Flash steam should not be mistaken for steam leakage through the steam trap.
- 2) Flash steam "floats" out intermittently (each time condensate discharges) as a "whitish cloud".
- 3) A leaking steam trap, manifests a continuous "blue" stream blowing out of the steam trap.

SCOPE:

Steam is delivered to the various buildings by a system of insulated high pressure steam pipes located in tunnels. Condensate is returned through piping located in the same system of tunnels by gravity to the boilers located in the boiler plant.

MODELING TECHNIQUES:

Table M3-1 below indicates the amount of steam lost through various steam traps when the trap has failed. These losses are based on total steam trap failure.







Type of Steam Trap	Condensate Capacity Lbs./Hr.	Steam Loss Lbs./Hr.
Disc	300-900	55-170
Float & Thermostatic	350-650	65-170
Thermostatic	600-1900	110-350
Inverted Bucket:		
With 5/16" orifice	350	35
With restricted orifice	350	35

A steam trap can fail in the wide open position, but it will not waste live steam 24 hours a day, 365 days a year. The trap will still handle the condensate load for which it was selected, and will also only pass live steam when the steam to the device is turned on, and then somewhat proportional to the degree of opening of the control valve.

Energy lost through leaking steam traps must be adjusted for seasonal usage. The following two examples are given for 350 lbs./hr. capacity steam traps.

EXAMPLE #1

A bucket trap serving a steam main that is operational for the entire year would waste:

35 lbs./hr. X 8760 hrs./yr. X \$5.75/1000 lbs. of steam) = \$1763 a year.

EXAMPLE #2

A float and thermostatic trap serving a heating coil operating only during the heating months would lose:

65 lbs./hr. X 4380 hrs./yr. X 0.5 (system modulation factor) X (\$5.75/1000 lbs. of steam) = \$819 a year.

ECO IMPLEMENTATION:

The figures above demonstrate the economic loss that can be experienced because of steam trap failure. If only ten steam traps within a facility failed, the cost for the wasted steam could be \$10,000 per year.

Calculation Sheet M3-1 shows the cost of installing test valves on steam traps, and the money saved assuming a 10% failure rate, and the cost of inspecting the traps.





Calculation Sheet M3-2 shows the cost of having an outside service inspection performed on the steam traps. The prices were obtained from Hughes Machinery Company, the local representative of Armstrong steam traps. The life cycle cost analysis summary sheet indicates the cost of inspection, and dollar savings from replacing traps based on a 100 trap system.

SUMMARY:

The life cycle cost summary sheet indicates the cost to install the trap testing valves, the cost of inspection, and the dollar savings from replacing the steam traps based on a 100 trap system.


A construction cost of \$15,738 for in-house steam trap testing gives a 4.55 savings to investment ratio, and a 2.56 year simple payback.


An outside testing service is recommended at a cost of \$16,150. The payback and SIR are essentially the same as in-house testing.

The graph of steam trap comparison is published by Armstrong Machine Works.



TRAP COMPARISON - STEAM LOSS VS SERVICE LIFE





PAGE M3-5

CONSTRUCTION COST ESTIN	AIE		DATE PF	REPARED		SHEET OF			
PROJECT				BASIS FOR E	STIMATE	<u>,</u>	1		
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISH				x		A (NO DESIGI B (PRELIMINA C (FINAL DES (SPECIFY)	IGN COMPLETED) INARY DESIGN) ESIGN) 1		
DRAWING NO.		ESTIM	ATOR	· · · · ·	Offici	CHECKED B	1		
	QU		N	TGD IATERIAL	L	LABOR	TOTAL		
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST		
INSTALL TEST VALVE (PER TRAP)									
CREW 1 STEAM FITTER, 1 APPRENTICE	_								
	1.00	мн	\$22.27	\$22	\$20.00	\$20	\$4		
INSTALL TEE AND TEST LINE	0.75	MH	\$22.27	\$17	\$5.40	\$4	\$2		
INSTALL GLOBE VALVE	0.75	мн	\$22.27	\$17	\$17.10	\$13	\$3		
· · · · · · · · · · · · · · · · · · ·									
							·····		
SUBTOTAL				\$56		\$37	\$93		
CONTINGENCY 10%			10%	\$6	10%	\$4	\$10		
SUBTOTAL				\$62		\$41	\$10		
WORK COMP, TAX, SOC.SEC., INS			3.50%	\$2	13.0%	\$5	\$		
DIRECT COST				\$64		\$46	\$110		
OVERHEAD AND PROFIT			25%	\$16	25%	\$11	\$2		
SUBTOTAL				\$80		\$57	\$137		
CONSTRUCTION COST PER TRAP ENG. FORM 150							\$137		

.

1AVC-59



-

	CALCUL	ATION SHE	ET			DATE March.1987		SHEET	0F	1
PROJECT	USDB					BASIS FOR CA	LCULA			1
LOCATION	ENERGY	SAVINGS	OPPORTUNITY SUP	RVEY		х на	ND			
						co	MPUTE			
ARCHITECT			N & BISKUP		-			TOR BID SPECIFY)		
ECO MEASU	RE				c	OMPUTED BY		CHECKEL	BY	
	STEAM T	RAP PROG	RAM - OWNER TES	STING		TGD				
COST OF	STEAM AT I	ORT LEAV	ENWORTH - USDE	<u>l</u>						
ENTHALP		R AT 160° F	. =		128	BTU/LBM				
	Y OF STEAN FICIENCY =		SIG =		1,192	2 BTU/LBM 74%				
STEAMER		•				/4%				
	GAS COST ITENT OF N			1 000		\$4.00 MCF BTU/MCF				
HEAT OUT		A1. GA3 =		1.000.	000	DIUMOF				
((1192-128)*\$4.00)/0.74	1*1,000)		\$5.75 I	PERT	HOUSAND LB	STEAM			
COST OF	NSPECTIN	TRAPS A	FTER TEST VALVE	S ARE INST	ALLE	<u>D.</u>				
ASSUMING	AN AVERA	GE OF 50	TRAPS PER DAY 8	HOURS PE	R DAY	<i>(</i> .				
8 M	н	x	\$36.75 PER HOU	R =	\$	294 PER DAY				
\$29	4	1	50 TRAPS PER D	AY =	\$	5.88 PER TRA	Р			
COST OF	NSTALLING	TEST VAL	VES ON EACH TRA	P =	\$	137				
SAVINGS		NSPECTI	ON							
USING 100	TRAPS AS	A BASE W	TH A 10% FAILURE	RATE; 350	LB/HI	R F&T TRAP				
	NSPECTING		NCE DURING		10	00 X \$5.88	= \$	588/YEAR		
	DF TRAPS F				11	00 X 10%	_	10 TRAPS		
	REPAIRING				1(,450/YEAR		
			ID REPAIRING TRA	PS			<u>\$2.038</u> /			
65 lbs/hr x	1380 hrs/yr x	: 0.5 (sys. m	odulation factor) =	142,350) LBS	OF STM/YEAF	R/TRAP			
# of steam	x (1192-128)	/1,000,000		=	15	1 MBTU/YEAF	R/TRAP			
@ \$5.75/10	00 # steam			=	\$8	368/YEAR/PER	RTRAP			
ENERGY L	OST DUE TO	O FAILED T	RAPS	10 X	151 =	1510 MBTU/Y	EAR			
COST OF S	TEAM LOS	T DUE TO F	AILED TRAPS	10 X \$8	868 =	\$8,680/YEAR	, 			
INITIAL INV	ESTMENT F	OR TEST	/ALVES	100 X \$	37 =	\$13,700				

P	ISTALLATION ROJECT NO. 8	RGY & LOC TITL	E: 1496	TION INVES RT LEAVEN	TMENT F WORTH	PROGRAM (I - USDB RE	EGION I			OY: USDBAE CCID 1.035 CENSUS: 2
FI Al	SCAL YEAR 19 NALYSIS DATE	990 E: 03	DIS 3-23-90		-	AME: ECON 15 YEARS		EPARED	BY: CF	RB
1.	INVESTMEN A. CONSTR B. SIOH C. DESIGN D. ENERGY E. SALVAGE F. TOTAL IN	UCTIC COST CREI E VAL	DIT CALC (1 UE COST		.9				\$ \$ \$ \$ \$	15738. 944. 866. 15793. 0. 15793.
2.	ENERGY SA ANALYSIS D		S (+) / COST NNUAL SA	(-) /INGS, UNIT	COST &	DISCOUNT	ED SAV	/INGS		
	FUEL		JNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		ANNUAL \$ SAVINGS(3)		SCOUNT CTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 1510. 0.	\$ \$ \$ \$ \$	0. 0. 0. 6161. 0.		8.69 12.42 12.21 11.67 10.36		0. 0. 0. 71899. 0.
	F. TOTAL			1510.	\$	6161.			\$	71899.
3.	NON ENERG	Y SA	VINGS(+) / C	OST(-)						
	A. ANNUAL I		RRING (+/-) FACTOR (T			9.11			\$	0.
			ED SAVING/		(3A1)	3.11			\$	0.
	C. TOTAL NO	ON EN	IERGY DISC	OUNTED SA	AVINGS(-	+) /COST(-)	(3A2+3	Bd4)	\$	0.
	A IF 31 B IF 31 C IF 3	IAX N D1 IS D1 IS ID1B I	ENERGY Q ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJE	CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1F)=	\$	23727.		
4.	FIRST YEAR	DOLL	AR SAVING	S 2F3+3A+(3	BB1D/(YE	ARS ECONO	DMIC LI	FE))	\$	6161.
5.	TOTAL NET [DISCO	UNTED SAV	/INGS (2F5+	-3C)	/	,		\$	71899.
6.	DISCOUNTEI (IF < 1 PROJE				(\$	SIR)=(5 / 1F)	=	4.55		
7.	SIMPLE PAY	BACK	PERIOD (ES	TIMATED)	SPB=1	F/4 .		2.56		



•

CALCULATION SHEET	DATE March,1987	SHEET OF
PROJECT USDB	BASIS FOR CALC	
ENERGY SAVINGS OPPORTUNITY SUR	X HAND	
	СОМР	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKUP		RACTOR BID
ECO MEASURE STEAM TRAP PROGRAM - OWNER TES	COMPUTED BY	
COST OF STEAM AT FORT LEAVENWORTH - USDB		L
ENTHALPY OF WATER AT 160° F. = ENTHALPY OF STEAM AT 120 PSIG = STEAM EFFICIENCY =	128 BTU/LBM 1,192 BTU/LBM 74%	
NATURAL GAS COST = HEAT CONTENT OF NAT. GAS =	\$4.00 MCF 1.000,000 BTU/MCF	
((1192-128)*\$4.00)/0.74*1,000)	\$5.75 PER THOUSAND LB ST	EAM
COST OF INSTALLING TEST VALVES ON EACH TRAF	P = \$137	
SAVINGS FROM TRAP INSPECTION USING 100 TRAPS AS A BASE WITH A 10% FAILURE		
COST OF INSPECTING TRAPS ONCE DURING THE HEATING SEASON		= \$1,000/YEAR
NUMBER OF TRAPS FAILED	100 X 10%	= 10 TRAPS
COST OF REPAIRING TRAPS	10 X \$145 =	\$1,450/YEAR
TOTAL COST OF TESTING AND REPAIRING TRAPS	<u>= \$2.</u>	<u>450</u> /YEAR
65 lbs/hr x 4380 hrs/yr x 0.5 (sys. modulation factor) =	142,350 LBS OF STM/YEAR/TR	AP
# of steam x (1192-128)/1,000,000	= 151 MBTU/YEAR/TR	AP
@ \$5.75/1000 # steam	= \$868/YEAR/PER TR	AP
ENERGY LOST DUE TO FAILED TRAPS	10 X 151 = 1510 MBTU/YEA	R
=		
COST OF STEAM LOST DUE TO FAILED TRAPS	10 X \$868 = \$8,680/YEAR	
COST OF STEAM LOST DUE TO FAILED TRAPS	10 X \$868 = \$8,680/YEAR 100 X \$137 = \$13,700	



PF	STALLATION ROJECT NO. 8	RGY & LO TITI	E: 1496	FION INVEST	TMENT PI	ROGRAM (E	CIP) GION NOS. 7		IDY: USDBAE LCCID 1.035 CENSUS: 2
FI AN	SCAL YEAR 1 NALYSIS DATE	990 E: C	DIS 3-23-90	ECONOM			3 PREPARED	BY: C	RB
1.	E. SALVAGE	UCTI COS CRE E VAI	T DIT CALC (1		9			\$ \$ \$ \$ \$ \$	16150. 969. 888. 16206. 0. 16206.
2.	ENERGY SA ANALYSIS D		S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST & I	DISCOUNTE	D SAVINGS		
	FUEL		UNIT COST \$/MBTU(1)			NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		ISCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 1510. 0.	\$ \$ \$ \$ \$	0. 0. 0. 6161. 0.	8.69 12.42 12.21 11.67 10.36		0. 0. 0. 71899. 0.
	F. TOTAL			1510.	\$	6161.		\$	71899.
З.	NON ENERG	IY SA	VINGS(+) / C	OST(-)					
	A. ANNUAL		JRRING (+/-) FFACTOR (T/			9.11		\$	0.
	(2) DISCO	DUNT	ED SAVING/	COST (3A X	(3A1)	3.11		\$	0.
	C. TOTAL N	ON E	NERGY DISC	OUNTED SA	VINGS(+)	/COST(-) (3	3A2+3Bd4)	\$	0.
	(1) 25% N A IF 3I B IF 3I C IF 3	AAX I D1 IS D1 IS BD1B	N ENERGY Q NON ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T IS < 1 PROJE	' CALC (2F5 O TO ITEM 4 SIR = (2F5+ O ITEM 4	X .33) 4 -3D1)/1F)₌		\$ 23727.		
4.	FIRST YEAR	DOL	LAR SAVING	S 2F3+3A+(3	B1D/(YEA	RS ECONO	MIC LIFE))	.\$	6161.
5.	TOTAL NET I	DISC	OUNTED SAV	'INGS (2F5+	3C)			\$	71899.
6.	DISCOUNTEI (IF < 1 PROJI				(S	IR)=(5 / 1F)=	4.44		
7.	SIMPLE PAY	BACł	K PERIOD (ES	TIMATED)	SPB=1F	/4	2.63		

.



PAGE M3-10

ECO-M5

EXHAUST HEAT RECOVERY



ENERGY CONSERVATION OPPORTUNITY: ECO-M5

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M5) analyzes the energy savings associated with the installation of heat recovery units to preheat outside air. Energy savings can be accomplished by using exhaust air to preheat outside air used for ventilation. Heat recovery coils can be used to transfer heat energy from the exhaust air to the ventilation air stream.

SCOPE:

The ECO simulation (ECO-M5) includes the installation of heat recovery units in the exhaust air stream and the outside air intake air stream. The application of this ECO was considered for the following buildings.

Building	475C	Building 475D
Building	475G	Building 475F

Heat recovery units were also considered for reclaiming heat from steam tunnel vents but there was not a viable use for the heat energy. None of the other buildings in the USDB have a substantial amount of exhaust air which could be used for heat recovery.

MODELING TECHNIQUES:

The total energy savings associated with ECO-M5 was calculated using computer models of Q-Dot air to air units, Z-Duct air to air heat pipe units and Run Around Coil Loop heat recovery units. The Q-Dot unit had the best payback because of it's low maintenance and high energy savings. The Run Around Coil Loop system has a high efficiency but it's high operation and maintenance costs reduce it's energy savings. The Z-Duct system, like the Q-Dot units are somewhat maintenance free, but for this application the Q-Dot unit was more efficient. The installed cost estimates for all the systems were done using manufacture quotes along with Means Mechanical Cost Data. Table M5-1 compares all three heat recovery systems on a one building bases.



ECO IMPLEMENTATION:

The implementation of this ECO will include the installation of heat recovery units in buildings 475C, 475D, 475G, and 475F. The energy savings in BTU's per year were taken directly from the computer models and were converted manually into a dollar per year value. A difficulty factor of 2 was added to the installation cost of each unit because of the height at which the systems are to be installed. The repair and maintenance of the rest of the air handling equipment in these buildings are not included in this project but must be done before this ECO is valid.

SUMMARY:

This project cost is the construction cost is 6% SIOH.

The energy savings associated with the implementation of this ECO by building is shown below in Table M5-1. A MBTU's per year savings as determined using the computer simulation model.




			Dentonee		
System Type	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
Q-Dot	453.2	\$2,130	\$12,908	6.66	1.76
Z-Duct	293.7	\$1,568	\$13,563	10.81	1.08
Coil Loop	300.9	\$953	\$16,273	12.81	0.92

Table M5-1



ECO-M5



)	PI FI	HOL SC/	JEC AL `	EI ATIC T NC YEAF IS DA)N &). & ` ? 199	IGY LO TITI 30	COI CAT LE:	NSE ION 1496	i Dis	FION RT L SCR	N IN LEA ETE	VES	TME WOF	NT P RTH DN N/	ROC - US	GRA SDB : EC		310i 5Q	ΝN	OS.			LCC	CID	DBAE 1.035 US: 2
	1.	A. B. C. D. E.	C SI D E S	STM ONS OH ESIG NERC ALVA DTAL	TRU N C GY C GE '	CTI OS ⁻ RE VAL	T DIT LUE (C (1/		B+1	C)X.	.9									\$ \$ \$ \$ \$ \$ \$		12	2178. 731. 670. 221. 0. 221.
	2.	en An	NEF NAL	rgy (Ysis	SAV 5 DA	ING TE	iS (+ ANN) / C UAL	OST . SAV	(-) 'ING	is, l	JNIT	COS	ST &	DIS	cou	NTE	D S.	AVI	NG	S				
		FL	Jel)ST (1)			NGS J/YR(JAL NGS					INT R(4)		DISC SAVI		
		В. С. D.	Di Ri N/	LECT ST ESID AT G DAL		\$ \$ \$ \$ \$ \$		2.44 .00 .00 4.08)) 3		2	1. 0. 0. \$53. 0.		\$ \$ \$ \$ \$		1 184	2. 0. 0. 8. 0.			12 12 11	.69 .42 .21 .67 .36				104. 0. 0. 566. 10.
		F.	то	TAL							4	154.		\$		186	60.					\$		21	670.
	3.	NC	DN	ENEF	RGY	SA	VINC	38(+	-) / CO	OST	(-)														
		Α.	AN (1)	INUA DIS		ECU		NG	(+/-) D (TA		= .					•						\$			0.
			(2)	DIS	col	JNT	ED	SAV	ING/C	COS	5T (3	BA X	(3A	1)		9.	11					\$			0.
		C.	тс	DTAL	NOI	N E	NER	GYI	DISC	OUN	NTE	D SA	AVIN	GS(+) /C(OST	(-) (3	3A2-	+3B	d4)		\$			0.
		D.	PF (1)	BIF	6 MA 3D1 3D1 3D1 - 3D	IX N I IS I IS 1B	10N = 0 < 30 IS =	ENE R > () CA > 1 (ay Ql Rgy BC Go LC GO T OJEC	' CA O T(SIR O IT	LC 0 IT = (1 EM	(2F5 'EM 4 2F5+ 4	- X . 4 ⊦3D1	33))/1F)				\$ 		71	51.				
	4.	FIF	ST	YEA	R D	OLI	AR	SAV	INGS	5 2F	3+3	A+(3	B1D	/(YE/	ARS	ECC	NON	ліс	LIF	E))		\$		18	860.
!	5.	то	TAI	LNE	r dis	SCO	DUN	ΓED	SAV	ING	S (2	2F5+3	3C)									\$		216	570 .
e	5.	dis (IF	SCC < 1)UNT PRC	ED (SA\ ;T [/ING OES	SR/ SNC	ATIO DT QL	JALI	IFY))		(S	IR)=	(5 / 1	1F)=			1.	77				
7	7.	SIN	IPL	E PA	YBA	CK	PEF	RIOE) (ES ⁻	TIM	ATE	D)	SP	B=1F	/4					6.	57				



F	ENEF NSTALLATION & PROJECT NO. & FISCAL YEAR 19 NALYSIS DATE	RGY LO TITI 90	-E: 1496 DIS	TION INVES	STMEN WOR NOR	IT PR TH - N NAM	OGRAM (E USDB RE ME: ECOM	igion i 15z	NOS. 7 EPARED		TUDY: USDBAE LCCID 1.035 CENSUS: 2 : CRB
1	. INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	OST OST CRE VAL	- DIT CALC(1 .UE COST		(.9					49 49 49 49 49 49 49 49 49 49	12795. 768. 704. 12840. 0. 12840.
2	. ENERGY SAV ANALYSIS DA	ING TE J	S (+) / COST ANNUAL SAV	(-) /INGS, UNIT	r cos [.]	Г & D	ISCOUNTE	ED SAV	INGS		
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR			NUAL \$ VINGS(3)		COUNT CTOR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$\$\$\$	12.44 .00 .00 4.08 .00	-1. 0. 0. 294. 0.		\$ \$ \$ \$ \$ \$ \$ \$ \$	-12. 0. 0. 1200. 0.		8.69 12.42 12.21 11.67 10.36		-104. 0. 0. 14004. 0.
	F. TOTAL			293.		\$	1188.			\$	
3.	NON ENERGY	SA	/INGS(+) / C(OST(-)							
	A. ANNUAL RE (1) DISCOU	JNT	RRING (+/-) FACTOR (TA ED SAVING/((0.44)		9.11			\$	0.
										\$	0.
	A IF 3D1 B IF 3D1 C IF 3D	ION X N IS IS 1B I		JALIFICATIO CALC (2F5 O TO ITEM 4 SIR = (2F5+ O ITEM 4	ON TE: 5 X .30 4 ⊦3D1)/1	ST 3) 1F)=		3A2+3E \$ 	3d4) 4587.	\$	0.
4.	FIRST YEAR D	OLL	AR SAVINGS	2F3+3A+(3	B1D/(`	/EAR	S ECONO	MIC LIF	⁼ E))	\$	1188.
5.	TOTAL NET DIS	sco	UNTED SAVI	NGS (2F5+	3C)					\$	13900.
6.	DISCOUNTED ((IF < 1 PROJEC	SAV T D	INGS RATIO OES NOT QL	JALIFY)		(SIR	l)=(5 / 1F)=	:	1.08		
7.	SIMPLE PAYBA	СК	PERIOD (ES ⁻	TIMATED)	SPB=	=1F/4			10.81		



(2)

P F	ENER ISTALLATION & ROJECT NO. & ISCAL YEAR 199 NALYSIS DATE:	GY LO(TITL 10	E: 1496 DIS	FION INVES RT LEAVEN CRETE POI	TMENT WORTH RTION	PROGRAM	RÉGION I M5CL	NOS. 7 REPARED		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1.	INVESTMENT A. CONSTRUC B. SIOH C. DESIGN CO D. ENERGY C E. SALVAGE F. TOTAL INV	DST REI	DIT CALC (1) UE COST		9				\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	15352. 921. 844. 15405. 0. 15405.
2.	ENERGY SAV	NG: TE A	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT	COST	& DISCOUN	TED SAV	/INGS		
	FUEL		JNIT COST VMBTU(1)	SAVINGS MBTU/YR(ANNUAL \$ SAVINGS(3		SCOUNT CTOR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$	12.44 .00 .00 4.08 .00	-2. 0. 0. 301. 0.	\$ \$ \$ \$ \$	-25 0. 0. 1228. 0.	• •	8.69 12.42 12.21 11.67 10.36		-217. 0. 0. 14331. 0.
	F. TOTAL			299.	\$	1203.			\$	14114.
3.	NON ENERGY	SA\	/INGS(+) / CC	OST(-)						
	A. ANNUAL RE		RRING (+/-) FACTOR (TA			9.11			\$	0.
	(2) DISCOL	INTI	ED SAVING/C	COST (3A X	3A1)	5.11			\$	0.
	C. TOTAL NON	I EN	ERGY DISCO	OUNTED SA	VINGS	(+) /COST(-)	(3A2+3	Bd4)	\$	0.
	A IF 3D1 B IF 3D1 C IF 3D	XN IS IS IS	ENERGY QU ON ENERGY = OR > 3C G(< 3C CALC \$ = > 1 GO T(\$ < 1 PROJEC	CALC (2F5 TO ITEM 4 SIR = (2F5+ O ITEM 4	X .33) ! .3D1)/1I	⁻)=	\$	4658.		
4.	FIRST YEAR D	OLL.	AR SAVINGS	3 2F3+3A+(3	81D/(Y	EARS ECON		FE))	\$	1203.
5.	TOTAL NET DIS	sco	UNTED SAV	INGS (2F5+3	3C)				\$	14114.
6.	DISCOUNTED S (IF < 1 PROJEC	SAV T D	INGS RATIO OES NOT QL	JALIFY)		(SIR)=(5 / 1F	⁻)=	0.92		
7.	SIMPLE PAYBA	СК	PERIOD (ES	TIMATED)	SPB=	1F/4		12.81		



CONSTRUCTION COST ESTIM	ATE		DATE PF	EPARED		··· ·	SHEET OF			
PROJECT USDB ENERGY STUDY				BASIS FOR E	STIMATE		11			
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISKI				x	CODE (CODE (B (PRELIMINA C (FINAL DES	DESIGN COMPLETED) ELIMINARY DESIGN) IAL DESIGN)			
DRAWING NO. ECO-M5	<u>or</u>	ESTIM	ATOR	1	UTHEN	(SPECIFY)				
	QU/		M	RGB ATERIAL	L	ABOR	MAW TOTAL			
Q-Dot Air to Air Heat Recovery System	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST			
Q-Dot Air to Air Units	1	EA	\$3,467	\$3,467	\$2,000	\$2,000	\$5,46			
MISC. CONTROLS	1	EA	\$400	\$400	\$100	\$100	\$500			
SEALED SHEET METAL BLOCK OFF	63	SQ. FT	\$2	\$126	\$12		\$882			
PROP. FAN W/ SHEET METAL HOUSING	1	EA	\$900	\$900	\$500	\$500	\$1,400			
SUBTOTAL				\$4,893		\$3,356	\$8,249			
CONTINGENCY 10%			10%	\$489	10%	\$336	\$825			
SUBTOTAL				\$5,382	, , , , , , , , , , , , , , , , , , , ,	\$3,692	\$9,074			
WORK COMP, TAX, SOC. SEC., INS			3.50%	\$188	13.0%	\$480	\$9,074 \$668			
DIRECT COST				\$5,570		\$4,172	\$9,742			
OVERHEAD AND PROFIT			25%	\$1,393	25%	\$1,043	\$9,742			
SUBTOTAL				\$6,963		\$5,215	\$2,438			
CONSTRUCTION COST				+0,000		ψυ,ειυ	\$12,178			



CONSTRUCTION COST ESTIM				EPARED			SHEET OF
PROJECT USDB ENERGY STUDY	BASIS FOR E	·					
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER		x	3 (PRELIMINA C (FINAL DES	N COMPLETED) NRY DESIGN) IGN)			
CLARK RICHARDSON & BISKI	UP	ESTIM	TOR		OTHER	(SPECIFY)	
ECO-M5				RGB			MAW
Z-Duct Air to Air Heat Recovery System	NO.	UNIT MEAS.	PER UNIT	ATERIAL TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
Z-Duct Air to Air Units	1	EA	\$3,900	\$3,900	\$2,000	\$2,000	\$5,90
MISC. CONTROLS	1	EA	\$400	\$400	\$100	\$100	\$50
SEALED SHEET METAL BLOCK OFF	63	SQ. FT	\$2	\$126	\$12	\$756	\$88
PROP. FAN W/ SHEET METAL HOUSING	1	EA	\$900	\$900	\$500	\$500	. \$1,40
SUBTOTAL CONTINGENCY 10%			1.0%	\$5,326	1.00/	\$3,356	\$8,682
SUBTOTAL			10%	\$533	10%	\$336	\$869
VORK COMP,TAX,SOC.SEC.,INS				\$5,859		\$3,692	\$9,551
			3.50%	\$205	13.0%	\$480	\$685
				\$6,064		\$4,172	\$10,236
VERHEAD AND PROFIT			25%	\$1,516	25%	\$1,043	\$2,559
SUBTOTAL				\$7,580		\$5,215	\$12,795
CONSTRUCTION COST							\$12,795



CONSTRUCTION COST ESTIM	ATE	DATE PF	REPARED			SHEET OF	
PROJECT	1	BASIS FOR E	STIMATE		11		
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS				x		A (NO DESIGI B (PRELIMINA	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISK			· · · · · · · · · · · · · · · · · · ·		CODE	C (FINAL DES	IGN)
DRAWING NO. ECO-M5		ESTIM	ATOR	L	OTHER	(SPECIFY)	Y
	QU.	ANTITY	M	RGB ATERIAL		ABOR	MAW TOTAL
Exhaust Run Around Heat Recovery Loop	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
GLYCOL COILS	2	EA	\$1,910	\$3,820	\$270	\$540	\$4,36
GLYCOL PUMP	1	EA	\$370	\$370	\$132	\$132	\$50
PUMP SUPPORT	1	EA	\$500	\$500	\$300	\$300	\$80
EXPANSION TANK	1	EA	\$710	\$710	\$120	\$120	\$83
	25	LF	\$4	\$100	\$8	\$200	\$30
PIPE INSULATION	25	LF	\$2	\$53	\$2	\$42	\$9
TEES	2	EA	\$3	\$6	\$24	\$48	\$5
ELLBOWS	4	EA	\$2	\$8	\$15	\$60	\$6
BUTTERFLY VALVES	2	EA	\$54	\$108	\$44	\$88	\$19
	1	EA	\$152	\$152	\$55	\$55	\$20
HERMOMETER	3	EA	\$6	\$18	\$19	\$57	<u>\$23</u>
EMPERATURE TRANSMITTER	1	EA	\$216	\$216	\$44	\$44	\$26
DIFF. PRESS. SWITCH W/ INDICATOR	1	EA	\$403	\$403	\$28	\$28	\$43
RESSURE GAUGES	3	EA	\$12	\$36	\$6	\$18	\$5
EALED SHEET METAL BLOCK OFF	63	SQ. FT	\$2	\$126	\$12	\$756	\$88
ROP. FAN W/ SHEET METAL HOUSING	1	EA	\$900	\$900	\$500	\$500	\$1,40
							······
SUBTOTAL				\$7,525		\$2,988	\$10,51
ONTINGENCY 10%			10%	\$753	10%	\$299	\$1,052
SUBTOTAL	 			\$8,278		\$3,287	\$11,565
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$290	13.0%	\$427	\$717
DIRECT COST				\$8,568		\$3,714	\$12,282
VERHEAD AND PROFIT			25%	\$2,142	25%	\$928	\$3,070
SUBTOTAL				\$10,710		\$4,642	\$15,352
CONSTRUCTION COST							\$15,352



ECO-M6

INSULATE DUCTWORK



DUCTWORK INSULATION

ENERGY CONSERVATION OPPORTUNITY: ECO-M6

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M6) analyzes the energy savings associated with reducing the amount of heat transfer through the walls of the ductwork that carries air from the air handling equipment to the space being conditioned. The ductwork can lose or gain heat from the unconditioned spaces through which it is routed, thus not providing the required air temperature at the air outlet.

SCOPE:

The implementation of this ECO simulation (ECO-M6) would have to be to ductwork that exists that is routed in unconditioned spaces. The only buildings that contain central air handling equipment with ductwork to the space to be conditioned are:

> Building 463 Building 465 Building 472 Building 473 Building 475

Building 475C Building 475D Building 475E Building 475F Building 475G

MODELING TECHNIQUE:

The modeling technique used to calculate the energy savings associated with insulating the ductwork located in unconditioned spaces, is a heat transfer calculation including the heat transfer coefficient of the ductwork walls and the temperature difference between the air inside and outside the ductwork. If the ductwork is located in conditioned spaces, then the addition of insulation to the ductwork will not effectively change the amount of energy used to condition the entire building because the temperature difference is zero.) bot TRUE.

SUMMARY:

The easiest method of insulating ductwork is on the outside of the metal. Another method is to insulate the ductwork on the inside of the metal. The insulation on the inside of the ductwork is typical when new ductwork is installed. To insulate the inside of existing ductwork is difficult and seldom feasible. All of the ductwork attached to air handling units, with the exception of the castle, is routed through conditioned spaces,



thus no energy savings is present. The ductwork for the air handling units located in the castle are concealed in the exterior walls of the structure. Because of changes in direction and transitions, insulating the inside of the ductwork is not feasible. The ductwork would have to be removed and re-installed with interior insulated ductwork, which is not cost effective. This ECO is not feasible under the present conditions.

ECO-M10

CENTRAL PLANT COOLING





CENTRAL CHILLER PLANT:

ENERGY CONSERVATION OPPORTNITY: ECO-M10

PURPOSE:

The purpose of this Energy Conservation Opportunity (ECO-M10) is to calculate the savings realized by installing a 400 ton centrifugal chiller to serve the air conditioning requirements for the USDB facility. The central chiller would replace the air cooled condensing units, and window mounted air conditioners that currently serve the buildings listed below.

SCOPE:

This project (ECO-M10) was considered for the following buildings:

Building 450 Building 463 Building 464 Building 465 Buildina 472 Building 473 Building 475A Building 475B Building 475H

MODELING TECHNIQUES:

The modeling technique used for ECO-M10 assumes that the existing equipment kilowatt per ton is 1.5 which is typical for air cooled condensers, and the central chiller plant kilowatt per ton is estimated at 0.95. The building energy use was calculated using the Trace Ultra energy simulation program.

ECO IMPLEMENTATION:

The removal of the existing air cooled condensing units, direct expansion cooling coils, the air cooled chiller serving the buildings at the south gate, and the window air conditioners is required to implement this ECO.

Installation of a centrifugal chiller, chilled water pump, condenser water pump, cooling tower, and accessories at building #474 is required for ECO-M10. The chilled water distribution piping will be installed in the existing piping tunnels.



ECO-M10

SUMMARY:

•

The installation of a central chiller plant will save 64,330 kWh of electrical energy per year, and will cost \$444,452 for the construction. A savings investment ratio of 0.05 disqualifies this project from consideration. The estimated simple payback is approximately 163 years.



ECO-M10

.

CALCULATION SHEET		DATE	SHEET OF
PROJECT	USDB	Apr-90	1 1
	ENERGY SAVINGS OPPORTUNITY SURVEY	BASIS FOR CALCU	LATION
LOCATION			
ARCHITECT			TER ACTOR BID
	CLARK RICHARDSON & BISKUP		
ECO MEASU		COMPUTED BY	CHECKED BY
	ECO-M10	MJM	MAW

THE CAPACITY OF COOLING PER BUILDING IS:

BUILDING	TONS CLG
450	32
463	22
464	26
465	17
472	69
473	39
475A	39
475B	28
475E	92
475H	20

TOTAL 384 TONS

INSTALL A 400 TON CENTRIFUGAL CHILLER IN THE BOILER PLANT

USING A TYPICAL DELTA TEMPERATURE OF 10°F



ENERGY = (GPM) (CP) (Δ T) ENERGY = (384 TONS) (12,000 BTUH/TON) = 4,608,000 BTUH CP = 1.0 FOR WATER Δ T = 10° F GPM = (ENERGY) / (CP) (Δ T) (500 LB MIN / GAL HOUR) GPM = 4,608,000 / 5000 GPM = 921.6

PUMP TO BE SIZED FOR 925 GPM


USING THE FOLLOWING SPREADSHEET, PIPE SIZES, NUMBER OF FITTINGS, AND FRICTION LOSS CAN BE DETERMINED.


THE PUMP WILL BE A 925 GPM, 150' HEAD END SUCTION.





л.





5

PAGE M10-5

CALCULATION SHEET		DATE	SHEET OF		
PROJECT USDB		Mar-90 BASIS FOR CALCUL			
ENERGY SAVINGS OPPORTUN	ITY SURVEY	_			
BUILDING 474			ER		
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU					
ECO MEASURE	COMEASURE				
CENTRAL PLANT COOLING EC	O-M10	TGD	MAW		
CHILLED WATER PUMP:	625 GPM @ 150 FT. H	IEAD			
	50 H.P. MOTOR - 175	0 RPM - 480/60/3 - 65 F	.L.A.		
	[(65 A.) (480 V.) (√3)] /	1,000 = 54	KW		
CONDENSER WATER PUMP:	1200 GPM @ 75 FT. H	IEAD			
•	30 H.P. MOTOR - 175	0 RPM - 480/60/3 - 40 F	L.A.		
	[(40 A.) (480 V.) (√3)] /	1,000 = 33	KW		
COOLING TOWER FAN:	20 H.P. MOTOR - 1750	0 RPM - 480/60/3 - 27 F.	.L.A.		
	[(27 A.) (480 V.) (√3)] /	1,000 = 22	KW		
(0.9 POWER FACTOR) x (0.8 MOTOR EFFICIE	ENCY) = 0.72	ELECTRICAL FACTOR	7		
(39KW + 24KW + 16KW) × (0.72) =	78	KW FOR AUXILLARY	EQUIPMENT		
400 TON CHILLER:	0.75 KW / TON				
78 KW / 400 TON =	0.20	KW / TON FOR AUXILI	LARY EQUIPMENT		
0.75 + 0.20 =	0.95	KW / TON OVERALL E 400 TON CENTRIFUG	EFFICIENCY FOR AL CHILLER SYSTEM		
EXISTING COOLING EQUIPENT:	1.5 KW / TON				
0.95 / 1.5 =	63%	FUTURE ELECTRICAL WITH CENTRAL CHI	. ENERGY USEAGE LLER PLANT:		
PRESENT ENERGY USED FOR COOLING:	173,865	кwн			
PROJECTED ENERGY USEAGE FOR COOLIN	NG: 109,535	кwн			
ANNUAL ELECTRICAL SAVINGS:	64,330	кwн			
ANNUAL ENERGY SAVINGS:	220	MBTU			

F	ENER NSTALLATION & PROJECT NO. & ISCAL YEAR 199 NALYSIS DATE:	GY LOC FITL 90	E: 1496 DIS	FION INVES	STMENT IWORTH	PROCH H - US	GRAM (EC SDB REG :: ECOM1	aion no 0	S. 7 ARED		JDY: USDBAE LCCID 1.035 CENSUS: 2 RB
1	. INVESTMENT A. CONSTRUE B. SIOH C. DESIGN CO D. ENERGY C E. SALVAGE F. TOTAL INV	OST REI	DIT CALC (1. UE COST		.9					\$\$ \$\$ \$\$ \$ 9 \$\$	444542. 26673. 24450. 446099. 0. 446099.
2	ENERGY SAV	ING: TE A	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT	r cost	& DIS	COUNTE) SAVIN	GS		
	FUEL		JNIT COST 5/MBTU(1)	SAVINGS MBTU/YR			UAL \$ NGS(3)	DISCO FACTO)UNT)R(4)		NSCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$\$ \$} \$ \$	12.44 .00 .00 4.08 .00	220. 0. 0. 0.	\$ \$ \$ \$ \$ \$		2737. 0. 0. 0. 0.		8.69 2.42 2.21 1.67 0.36		23785. 0. 0. 0. 0.
	F. TOTAL			220.	\$;	2737.			\$	23785.
3.	NON ENERGY	SA	/INGS(+) / C(OST(-)							
	A. ANNUAL RE		RRING (+/-) FACTOR (TA				0.11			\$	0.
	(2) DISCOL	INT	ED SAVING/	COST (3A X	(3A1)		9.11			\$	0.
	C. TOTAL NOM	I EN	IERGY DISC	OUNTED SA	AVINGS	6(+) /C0	OST(-) (3	A2+3Bd4	-)	\$	0.
	A IF 3D1 B IF 3D1 C IF 3D	X N IS = IS - 1B I	ENERGY QU ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJEC	CALC (2F5 TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1) F)=	:	\$ 7	849.		
4.	FIRST YEAR D	OLL	AR SAVINGS	3 2F3+3A+(3	3B1D/(Y	EARS	ECONOM	IIC LIFE))	\$	2737.
5.	TOTAL NET DIS									\$	23785.
6.	DISCOUNTED S (IF < 1 PROJEC	SAV T D	INGS RATIO OES NOT QU	JALIFY)		(SIR)=	=(5 / 1F)=		0.05		
7.	SIMPLE PAYBA	CK	PERIOD (ES	TIMATED)	SPB=	1F/4		16	2.99		



ECO-M10

J

CONSTRUCTION COST ESTIMATE			DATEPR	IEPARED	4/2/90)	SHEET	OF
PROJECT USDB ENERGY STUDY		BASIS FOR		L	1 2			
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				x	CODE B	(NO DESIGN (PRELIMINAR (FINAL DESIG	Y DESIGN	red) ∛)
CLARK RICHARDSON & BISK DRAWING NO.	UP	ESTIM	ATOP		OTHER	(SPECIFY)		
NONE ECO-M10				MJM		CHECKED B	Y MAW	
CENTRAL PLANT COOLING	NO.	ANTITY UNIT	PER	ATERIAL TOTAL	PER	ABOR TOTAL		OTAL OST
400 TON CENTRIFUGAL CHILLER		MEAS.			UNIT			
	+	<u> </u>						
EXPANSION TANK AND TOWER	400	TON	260.13	\$104,052	80.75	\$32,300		
925 GPM PUMP, 150' HEAD	<u>1</u>	EA	1650.00	\$1,650	390.00	\$390		\$2 ,04
8" BLACK STEEL PIPE, HANGERS, INSUL	160	FT	18.18	\$2,909	22.17	\$3,547		\$6,45
6" BLACK STEEL PIPE, HANGERS, INSUL	1620	FT	12.20	\$19,764	18.19	\$29,468		\$49,23
5" BLACK STEEL PIPE, HANGERS, INSUL	1400	FT	10.19	\$14,266	13.86	\$19,404		\$33,67
4" BLACK STEEL PIPE, HANGERS, INSUL	1360	FT	7.45	\$10,132	12.25	\$16,660		\$26,79
3" BLACK STEEL PIPE, HANGERS, INSUL	400	FT	5.32	\$2,128	10.84	\$4,336		\$6,46
8" BLACK STEEL ELL	13	EA	66.00	\$858	135.00	\$1,755		\$2,61
6" BLACK STEEL ELL	14	EA	37.00	\$518	110.00	\$1,540		\$2,05
5" BLACK STÊEL ELL	13	EA	37.00	\$481	110.00	\$1,430		\$1,91
4" BLACK STEEL ELL	10	EA	14.90	\$149	70.00	\$700		\$849
3" BLACK STEEL ELL	10	EA	9.00	\$90	50.00	\$500		<u>\$59</u>
3" BLACK STEEL TEE	1	EA	91.00	\$91	220.00	\$220		\$311
S" BLACK STEEL TEE	1	EA	50.00	\$50	185.00	\$185		\$235
5" BLACK STEEL TEE	3	EA	50.00	\$150	185.00	\$555	<u>.</u>	
BLACK STEEL TEE	3	EA	27.00	\$81	115.00	\$345		\$705
BUTTERFLY VALVE	4	EA	200.00	\$800	120.00		<u> </u>	\$426
BUTTERFLY VALVE	2	T	140.00	\$280	110.00	\$480 \$220		\$1,280
" BUTTERFLY VALVE	21		120.00	\$240				\$500
" BUTTERFLY VALVE	81		86.00	\$688	<u>110.00</u> 70.00	\$220		\$460
" GATE VALVE	10	Г	105.00	\$1,050	27.00	\$560		\$1,248
				Q1,000	27.00	\$270		\$1,320
								······

.



CONSTRUCTION COST EST	DATE PR	EPARED	4/2/90	\	SHEET OF				
PROJECT	I	BASIS FOR E			<u> </u>	2	2		
USDB ENERGY STUDY	*			x		(NO DESIGN			
FORT LEAVENWORTH, KS	·				CODE B	(PRELIMINAR	Y DESIGN	N)	
CLARK RICHARDSON & BIS	KUP					(FINAL DESIG	SN)		
DRAWING NO.		ESTIM	ATOR	L	UINER	CHECKED B	Ŷ		
NONE				MJM	r		MAW		
ECO-M10	NO.	UNIT MEAS.		ATERIAL TOTAL	PER UNIT	ABOR TOTAL		OTAL OST	
BUILDING 450 COOLING COIL REPLACEMENT			1100.00	.					-
BUILDING 450 REFRIGERATION		EA	1130.00	\$1,130	435.00	\$435		\$1,5	<u>56</u>
DEMOLITION	2	TON			395.00	\$790		\$7	79
BUILDING 465 REFRIGERATION									
DEMOLITION	3	TON			395.00	\$1,185		\$1,1	8
BUILDING 472 COOLING COIL REPLACEMENT									
BUILDING 472 REFRIGERATION	1	EA	440.00	\$440	88.00	\$88		\$5	528
DEMOLITION	2	TON			395.00	\$790		\$7	<u>'9(</u>
BUILDING 475A FAN COIL UNIT									
INSTALLATION	11746	SQ FT	0.74	\$8,645	0.07	\$865		\$9,5	<u>;1(</u>
BUILDING 475B FAN COIL UNIT							·····		
INSTALLATION	7400	SQ FT	0.74	\$5,446	0.07	\$545	· ·	\$5,9	91
BUILDING 475H FAN COIL UNIT	6744	SQ FT	0.74						
	0744	SUFI	0.74	\$4,964	0.07	\$496		\$5,4	60
									-
SUBTOTAL				\$181,052		\$120,279		\$301,3	<u>30</u>
CONTINGENCY 10%			10%	\$18,105	10%	\$12,028		\$30,10	<u>33</u>
SUBTOTAL				\$199,157		\$132,307		\$331,40	<u>63</u>
NORK COMP, TAX, SOC.SEC., INS			3.50%	\$6,970	13.0%	\$17,200		\$24,17	<u>70</u>
				\$206,127		\$149,507	<u> </u>	\$355,63	<u>33</u>
			25%	\$51,532	25%	\$37,377		\$88,90	<u>)9</u>
	┼──┼			\$257,659		\$186,884		\$444,54	12
CONSTRUCTION COST ENG. FORM 150								\$444,54	12

ECO-M11

CASTLE AIR SYSTEM REPAIR





CASTLE AIR SYSTEM REPAIRS

ENERGY CONSERVATION OPPORTUNITY: ECO-M11

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M5) analyzes the energy savings associated with removal of air stratification in the castle domiciles. Stratification occurs in areas with high ceilings when hot air rises to the upper levels and there is no way for it to be circulated back down. Stratification in the castle domiciles is causing the upper levels to become over heated by an estimated 10°. An energy savings can be seen by repairing the return air systems which pulls the hot air from the upper levels and circulates it down through the lower levels. The implementation of this project will not change the number or capacity of any of the existing air handling systems.

SCOPE:

The ECO simulation (ECO-M11) includes the repair and maintenance of the existing air handling systems. The application of this ECO was considered for the following buildings.

Building	475C	Building 475D
Building	475G	Building 475F

The existing AHU's in these buildings are currently operating with no return air from the space. The doors of the fan room have been removed allowing the AHUs to pull in air from the pipe tunnels, chases or from wherever it finds the least amount of resistance. Replacing the doors and sealing off the fan rooms will allow the AHU's to pull warm return air from the top levels of these buildings. This will create proper air circulation and eliminate the air stratification. An energy savings will be seen by eliminating the over heating of the top levels of these buildings.

MODELING TECHNIQUES:

The energy savings associated with this ECO was calculated using a computer simulation developed as a base load on the facility. The existing HVAC systems were simulated to heat the top three tiers of each building to 10° above the 68° setpoint. The temperature was then set to 68° and the simulation was ran again to find the difference in energy use. The difference in the energy usage for these two computer runs is the energy savings for ECO-M11. The cost repairing these AHU's were done using Means Mechanical Cost Data.



ECO-M11

ECO-M11 ECONOMIC ANALYSIS

	STEAM CONS	SUMPTION		ELECTRIC			
BUILDING NUMBER	BASE ENERGY (THERMS)	ECO-M11 LOAD (THERMS)	ENERGY SAVINGS (MBTU)	BASE LOAD (KW)	ECO-M11 LOAD (KW)	ENERGY SAVINGS (MBTU)	TOTAL SAVINGS (\$)
*							
475C	13,472	10,745	273	45,478	45,427	0	\$1,115
475D	15,188	12,422	277	53,358	53,317	0	\$1,130
475F	15,926	12,856	307	53,357	53,324	0	\$1,254
475G	12,853	10,380	247	45,481	45,427	0	\$1,011
							\$4,510





ECO IMPLEMENTATION:

The implementation of this ECO will include the installation of new doors on the fan rooms of each building. All pipe chases passing through the fan rooms will need to be sealed along with any other openings which presently exist. This will restore the return air system back to it's original design which will in turn eliminate any air stratification within these buildings.

SUMMARY:

The probable construction cost to implement this ECO by building is shown in Table M11-1. This project cost is the construction cost as determined in the appendix plus 6% SIOH.

The energy savings associated with the implementation of this ECO by building is shown below in Table M11-1 on a dollars per year savings as determined using the computer simulation model.

Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio		
475C	273	\$1,458	\$1,779	1.51	7.72		
475D	277 🗸	\$1,474	\$1,779	1.49	7.83		
475F	307 🗸	\$1,641	\$1,779	1.34	8.68		
475G	247 🗸	\$1,323	\$1,779	1.67	6.99		

Table M11-1



P Fi	LIFE CYCLE COST ANALYSIS SUMMARY STUDY: USDBAE ENERGY CONSERVATION INVESTMENT PROGRAM (ECIP) LCCID 1.035 INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB. REGION NOS. 7 CENSUS: 2 PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: ECOM11C ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 15 YEARS PREPARED BY: CRB												
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	CTIO OST CRED VALU	IT CALC (1.		9				\$\$ \$\$ \$\$ \$ \$	1678. 101. 92. 1684. 0. 1684.			
2.	2. ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTED SAVINGS												
-	FUEL		NIT COST /MBTU(1)	SAVINGS MBTU/YR				SCOUNT CTOR(4)					
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 273. 0.	\$ \$ \$ \$ \$	0. 0. 1114. 0.		8.69 12.42 12.21 11.67 10.36		0. 0. 13000. 0.			
	F. TOTAL			273.	\$	1114.			\$	13000.			
3.	NON ENERGY	SAV	INGS(+) / C	OST(-)									
	A. ANNUAL R	ECUF UNT F	RRING (+/-) FACTOR (TA			9.11			\$	0.			
	(1) DISCOUNT FACTOR (TABLE A) 9.11 (2) DISCOUNTED SAVING/COST (3A X 3A1)								\$	0.			
	C. TOTAL NO	N ENI	ERGY DISC	OUNTED SA	VINGS(+) /COST(-)	(3A2+3	Bd4)	\$	0.			
	A IF 3D B IF 3D C IF 3D	AX NC 1 IS = 1 IS < 01B IS	DN ENERGY OR > 3C G 3C CALC = > 1 GO T	′ CALC (2F5 O TO ITEM 4 SIR = (2F5+	X .33) 4 ⊦3D1)/1F	-)=	\$	4290.					
4.	FIRST YEAR D	OLLA	R SAVINGS	6 2F3+3A+(3	B1D/(YE	EARS ECON	OMIC LI	FE))	\$	1114.			
5.	TOTAL NET DI	SCOI	JNTED SAV	INGS (2F5+	3C)				\$	13000.			
6.	DISCOUNTED (IF < 1 PROJEC				(SIR)=(5 / 1F)=	7.72		Ð			
7.	SIMPLE PAYB	ACK F	PERIOD (ES	TIMATED)	SPB=1	F/4		1.51					



FISC.	ENER(ALLATION & I JECT NO. & T AL YEAR 199 JSIS DATE:	GY CO LOCA ITLE: 0	DNSERVAT TION: FOF 1496 DIS	OST ANALYS ION INVEST IT LEAVENN CRETE POF ECONOM	rment North	- Pro H - U NAME	GRAM (EC SDB REG E: ECOM1	ION NO	DS. 7 PARED		JDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
A B C D E	VESTMENT . CONSTRUC . SIOH . DESIGN CC . ENERGY C . SALVAGE V . TOTAL INVE	CTION DST REDIT (ALUE	CALC (1/		9					\$\$ \$\$ \$\$ \$\$ \$\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	1678. 101. 92. 1684. 0. 1684.
2. E A	NERGY SAVI NALYSIS DAT	NGS (FE AN	+) / COST NUAL SAV	(-) INGS, UNIT	COST	& DIS	COUNTE	D SAVII	NGS		
F	UEL		IIT COST //BTU(1)	SAVINGS MBTU/YR((2)		UAL \$ INGS(3)		OUNT FOR(4)		DISCOUNTED SAVINGS(5)
B. C. D.	ELECT DIST RESID NAT G COAL	\$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 277. 0.	99 99 99 99 99 99 99		0. 0. 0. 1130. 0.		8.69 12.42 12.21 11.67 10.36		0. 0. 0. 13187. 0.
F.	TOTAL			277.	\$	6	1130.			\$	13187.
3. N	ON ENERGY	SAVI	NGS(+) / CO	DST(-)							
A.	ANNUAL RE (1) DISCOU		RING (+/-)				9.11			\$	0.
	(2) DISCOU	NTED	SAVING/C	COST (3A X	3A1)		9.11			\$	0.
C.	TOTAL NON	IENE	RGY DISC	OUNTED SA	VINGS	6(+) /C	OST(-) (3	A2+3B	14)	\$	0.
D.	B IF 3D1 C IF 3D ⁻	X NOI IS = (IS < (IB IS	N ENERGY OR > 3C G(3C CALC = > 1 GO T	CALC (2F5 D TO ITEM 4 SIR = (2F5+	X .33 ‡ ·3D1)/1) F)=		\$	4352.		
4. Fl	RST YEAR DO	DLLAF	R SAVINGS	2F3+3A+(3	B1D/(Y	'EARS		AIC LIFI	E))	\$	1130.
5. TC	DTAL NET DIS	scou	NTED SAV	INGS (2F5+(3C)					\$	13187.
6. DI: (IF	SCOUNTED S < 1 PROJEC	SAVIN T DOI	GS RATIO ES NOT QL	JALIFY)		(SIR)	=(5 / 1F)=		7.83		
7. SII	MPLE PAYBA	CK PI	ERIOD (ES	TIMATED)	SPB=	1F/4			1.49		



LIFE CYCLE COST ANALYSIS SUMMARY ENERGY CONSERVATION INVESTMENT PROGRAM (EC INSTALLATION & LOCATION: FORT LEAVENWORTH - USDB REG PROJECT NO. & TITLE: 1496 FISCAL YEAR 1990 DISCRETE PORTION NAME: ECOM1 ANALYSIS DATE: 03-30-90 ECONOMIC LIFE 15 YEARS	NOS. 7	LC	Y: USDBAE CCID 1.035 CENSUS: 2
 INVESTMENT A. CONSTRUCTION COST B. SIOH C. DESIGN COST D. ENERGY CREDIT CALC (1A+1B+1C)X.9 E. SALVAGE VALUE COST F. TOTAL INVESTMENT (1D-1E) 		\$ \$ \$ \$ \$ \$	1678. 101. 92. 1684. 0. 1684.
2. ENERGY SAVINGS (+) / COST (-) ANALYSIS DATE ANNUAL SAVINGS, UNIT COST & DISCOUNTEI	D SAVINGS		
UNIT COST SAVINGS ANNUAL \$ FUEL \$/MBTU(1) MBTU/YR(2) SAVINGS(3)	DISCOUNT FACTOR(4)		COUNTED /INGS(5)
A. ELECT\$12.440.\$0.B. DIST\$.000.\$0.C. RESID\$.000.\$0.D. NAT G\$4.08307.\$1253.E. COAL\$.000.\$0.	8.69 12.42 12.21 11.67 10.36		0. 0. 0. 14623. 0.
F. TOTAL 307. \$ 1253.		\$	14623.
3. NON ENERGY SAVINGS(+) / COST(-)			
A. ANNUAL RECURRING (+/-) (1) DISCOUNT FACTOR (TABLE A) 9.11		\$	0.
(2) DISCOUNTED SAVING/COST (3A X 3A1)		\$	0.
C. TOTAL NON ENERGY DISCOUNTED SAVINGS(+) /COST(-) (3	A2+3Bd4)	\$	0.
D. PROJECT NON ENERGY QUALIFICATION TEST (1) 25% MAX NON ENERGY CALC (2F5 X .33) A IF 3D1 IS = OR > 3C GO TO ITEM 4 B IF 3D1 IS < 3C CALC SIR = $(2F5+3D1)/1F$)= C IF 3D1B IS = > 1 GO TO ITEM 4 D IF 3D1B IS < 1 PROJECT DOES NOT QUALIFY	\$ 4826. 		
4. FIRST YEAR DOLLAR SAVINGS 2F3+3A+(3B1D/(YEARS ECONOM	AIC LIFE))	\$	1253.
5. TOTAL NET DISCOUNTED SAVINGS (2F5+3C)		\$	14623.
6. DISCOUNTED SAVINGS RATIO (SIR)=(5 / 1F)= (IF < 1 PROJECT DOES NOT QUALIFY)	8.68		
7. SIMPLE PAYBACK PERIOD (ESTIMATED) SPB=1F/4	1.34		



ENER INSTALLATION & PROJECT NO. & 1 FISCAL YEAR 199 ANALYSIS DATE:	TTLE: 1496	TION INVESTM	IENT PR ORTH - TION NAM	OGRAM (EC USDB REG //E: ECOM1	NON NOS. 7	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
E. SALVAGE	DST REDIT CALC (1)				•	\$ \$ \$ \$ \$ \$ \$ \$	1678. 101. 92. 1684. 0. 1684.
2. ENERGY SAVI ANALYSIS DA ⁻	NGS (+) / COST FE ANNUAL SAV	(-) /INGS, UNIT C	OST & D	ISCOUNTEI	D SAVINGS		
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)	-	SCOUNTED VINGS(5)
A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	0. 0. 0. 247. 0.	\$ \$ \$ \$ \$ \$	0. 0. 0. 1008. 0.	8.69 12.42 12.21 11.67 10.36		0. 0. 0. 11763. 0.
F. TOTAL		247.	\$	1008.		\$	11763.
3. NON ENERGY	SAVINGS(+) / C	OST(-)					
A. ANNUAL RE (1) DISCOL	CURRING (+/-) INT FACTOR (TA			0.11		\$	0.
(2) DISCOL	INTED SAVING/	COST (3A X 3	A1)	9.11		\$	0.
C. TOTAL NON	I ENERGY DISC	OUNTED SAVI	NGS(+) /	COST(-) (3	A2+3Bd4)	\$	0.
(1) 25% MA A IF 3D1 B IF 3D1 C IF 3D	ION ENERGY QU X NON ENERGY IS = OR > 3C G IS < 3C CALC 1B IS = > 1 GO T B IS < 1 PROJE(' CALC (2F5 X O TO ITEM 4 SIR = (2F5+3[O ITEM 4	∷.33) D1)/1F)=		\$ 3882.		·
4. FIRST YEAR DO	OLLAR SAVINGS	8 2F3+3A+(3B1	D/(YEAF	S ECONON	/IC LIFE))	\$	1008.
5. TOTAL NET DIS	COUNTED SAV	INGS (2F5+3C)			\$	11763.
6. DISCOUNTED S (IF < 1 PROJEC	SAVINGS RATIO T DOES NOT QU	JALIFY)	(SIF	R)=(5 / 1F)=	6.99		
7. SIMPLE PAYBA	CK PERIOD (ES	TIMATED) S	SPB=1F/4		1.67		



CONSTRUCTION COST ESTI	MAIC		DATEP	EPARED			SHEET OF
				BASIS FOR E	STIMATE	· · · · · · · · · · · · · · · · · · ·	
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				×	CODE 8	A (NO DESIGI B (PRELIMINA C (FINAL DES	N COMPLETED) ARY DESIGN) IGN)
CLARK RICHARDSON & BIS DRAWING NO.	SKUP	ESTIM	ATOR			(SPECIFY)	
NONE				RGB			MAW
ECO-M11	NO.	UNIT MEAS.	PER	ATERIAL TOTAL	PER UNIT	ABOR TOTAL	TOTAL COST
METAL DOORS	2	EA	\$137	\$274	\$80	\$160	\$4
SHEET METAL ≈	50	SQ FT	\$1	\$63	\$1	\$70	\$1
CAULKING MASONRY ≈	400	LF	\$1	\$224	\$1	\$336	\$5
· · · · · ·							
			•				
SUBTOTAL				\$560		\$566	\$1,1
CONTINGENCY 10%			10%	\$56	10%	\$57	\$1
SUBTOTAL				\$616		\$623	\$1,2
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$22	13.0%	\$81	\$10
DIRECT COST				\$638		\$704	\$1,34
VERHEAD AND PROFIT			25%	\$160	25%	\$176	\$3:
SUBTOTAL				\$798		\$880	\$1,67
CONSTRUCTION COST							\$1,67




ECO-M12

REDUCE STEAM DISTRIBUTION PRESSURE







PURPOSE:

The purpose of this Energy Conservation Opportunity (ECO-M12) is to calculate the savings realized by reducing the steam pressure for the USDB facility. The laundry requires 120 psig steam, while the space heating requirements can be served by 80 psig steam.

SCOPE:

Steam is delivered to the various buildings by a system of insulated high pressure steam pipes located in tunnels. The steam pressure at the boilers is maintained at 120 psig. The steam pressure is reduced at the individual buildings to the pressure required for space heating and/or any process usage.

Steam must be delivered at a pressure high enough to overcome the system resistance losses, while maintaining sufficient pressure to equal or exceed the downstream pressure requirement.

Reducing the steam pressure for energy savings will decrease the density of the steam in the steam piping. The steam will take up more volume in the pipes, making it a tighter squeeze to pass through the orifice plates used to measure steam flow.

Because the orifice plate sees a greater pressure drop for a given flow, the signal sent to the chart recorder will be greater also, and the chart will read proportionally higher. The orifice plates will have to be replaced for each steam recorder to reflect steam flow rates, accurately at a reduced steam pressure.

Steam trap capacities will also be reduced, due to the reduced differential pressure across the steam traps orifice. The traps affected will be the traps located in the Powerhouse, and the traps serving steam mains upstream of the pressure reducing valves.

Generally traps, and drip legs serving steam mains are oversized by the design engineer, and a reduction in steam pressure will not have an adverse effect the traps performance.

Nevertheless, lowering thesteam trap condensate handling capacity could cause water to back up into the the steam mains. This could possibly result in water hammer, if a slug of condensate is picked up by fast moving steam traveling over the surface of the condensate. Since water hammer can cause extensive damage to the system, the exact capacity of each trap effected by steam pressure reduction must be determined.

MODELING TECHNIQUES:

ECO-M12

MODELING TECHNIQUES:

The modeling techniques used to calculate the energy savings for ECO-M12 were derived from "Improving Boiler Efficiency" by S. G. Dukelow. Boiler efficiency is increased by lowering the operating steam pressure, because the flue gases leave the boiler at a lower temperaure.

The saturation temperature of steam at 120 psig is 350°F., and the corresponding flue gas temperature is 450°F. Reducing the operating pressure of the boiler to 80 psig, reduces the saturation temperature of the steam to 324°F., and the corresponding flue gas temperature is reduced to 424°F.

The total heat content or enthalpy of steam at 120 psig is 1,192.4 btu/lb., while 80 psig steam has an enthalpy of 1,186.3 btu/lb. The 80 psig steam also has a higher latent heat content per pound than the 120 psig steam. While the 120 psig steam has more total heat per pound than the 80 psig steam, this heat is never fully realized at the heat exchanger.

As the steam pressure is reduced prior to delivery to the heat exchanger, the extra btu's are converted into superheated steam. This superheated steam is all sensible heat and is promptly dissipated before it can be recovered at the heat exchanger.

The modeling technique assumes that the steam consumption remains constant for the facility, and the cost of producing steam is reduced due to the increased boiler efficiency.

ECO IMPLEMENTATION:

The implementation of ECO-M12 can be accomplished when the existing boilers are replaced. The existing facility is served by three 580 H.P. steam boilers operating at 120 psig steam pressure. We recommend installing two 435 H.P., and one 870 H.P. steam boilers.

The 870 H.P., and one 435 H.P. boiler would be operated at 80 psig pressure, and would serve the space heating requirements of the facility. The remaining 435 H.P. boiler would be operated at 120 psig and would be dedicated to serving the laundry.

SUMMARY:

Since ECO-M12 can be implemented at the time the existing steam boilers are replaced, there are no associated costs for execution, and the energy savings can be realized within the next two years.



	CALCULATION SHEET		DATE Mar-90	SHEET OF
	USDB ENERGY SAVINGS OPPORTI		BASIS FOR CAI	
LOCATION	STEAM PLANT			D IPUTER
ARCHITECT/EN	GINEER CLARK RICHARDSON & BISK	UP	CON	TRACTOR BID HER (SPECIFY)
ECO MEASURE	ECO M12		COMPUTED BY TGD	
OTEAN				
STEAM PRESSURE	ENTHALPY BTU/LB. OF STEAM	SYSTEM EFFICIENCY	STEAM COST PER 1000 LBS.	ESTIMATED ANNUAL SAVINGS
120 PSIG	1,192.4	74.000%	\$5.754	NONE
115 PSIG	1,191.7	74.094%	\$5.742	\$652
110 PSIG	1,191.0	74.188%	\$5.731	\$1,249
105 PSIG	1,190.4	74.282%	\$5.721	\$1,792
100 PSIG	1,189.6	74.376%	\$5.709	\$2,443
95 PSIG	1,188.8	74.470%	\$5.698	\$3,040
90 PSIG	1,188.0	74.564%	\$5.686	\$3,692
85 PSIG	1,187.2	74.658%	\$5.675	\$4,289

AVERAGE STEAM USE 148,750 LBS PER DAY

80 PSIG

74.752%

\$5.663

SYSTEM EFFICIENCY CALCULATED FROM:

IMPROVING BOILER EFFICIENCY BY S.G. DUKELOW

1,186.3

SPONSORED BY KANSAS STATE UNIVERSITY AND KANSAS ENERGY OFFICE

CHAPTER 6: EFFECT OF BOILER STEAM PRESSURE ON FLUE GAS TEMPERATURE AND BOILER EFFICIENCY

\$4,941

ECO-M14

SERVICE CONDENSATE RETURN SYSTEM

CONDENSATE RETURN SYSTEM SERVICE: ENERGY CONSERVATION OPPORTUNITY ECO-M14

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M14) analyzes the energy savings associated with reducing the amount of heat transfer through the walls of condensate return piping. The piping transfers heat to its surroundings because of a temperature difference between the fluid, and the ambient space temperature through which it is routed. This loss of heat from the hot condensate to the ambient air in the piping tunnels causes increased use of natural gas at the boiler.

SCOPE:

This Energy Conservation Opportunity (ECO-M14) involves the condensate return piping from building #475 (Castle Building). The condensate return system for this building consists of approximately 700 feet of 6" and 8" steel piping, approximately 600 feet of this piping is uninsulated, and 100 feet of piping will need to be replaced.

MODELING TECHNIQUES:

The modeling techniques used to calculate the energy savings for ECO-M14 were derived by measuring the present condensate return temperature, and estimating the future condensate return temperature by using a computer spreadsheet.

The average daily steam consumption was derived by summing 25% of the average winter rate of 370,000 lbs. per day, and 75% of the average summer rate of 75,000 lbs. per day.

The steam tunnel that exits the west wall of the boiler plant serves the Castle Building #475, which includes the laundry facility. The estimated annual steam load served by this tunnel is 50% of the total system load.

ECO IMPLEMENTATION:

The implementation of this Energy Conservation Opportunity (ECO-M14) requires the replacement of approximately 100 feet of 8" condensate return piping installed at the floor level of the piping tunnel. Various fittings are required along with pipe racks for support of the piping.

400 feet of insulation is required for the 6" dia. piping, and 200 feet of insulation is required for the 8" dia. piping to reduce the amount of heat transfered to the tunnel air. A difficulty factor has been added to the construction cost for limited work area, and accessability.



PAGE M14-1

The existing condensate piping has holes drilled in the pipe that must be repaired prior to installation of the insulation.

SUMMARY:

The condition of the condensate piping system in the west tunnel is questionable, and may warrant replacement. Energy conservation can be realized without total replacement of this piping system.



1	Ć	

CALCU	CALCULATION SHEET	DATE	SHEET OF
		Mar-90	
PROJECT USDB		BASIS FOR CALCULATION	VTION
ENERG	ENERGY SAVINGS OPPORTUNITY SURVEY		
LOCATION		X HAND	
		COMPUTER	
ARCHITECT/ENGINEER		CONTRACTOR BID	R BID
ĊLARK	ČLARK RICHARDSON & BISKUP	OTHER (SPECIFY)	ECIEV
ECO MEASURE		COMPUTED BY	CHECKED RV
SERVICE CONDENSATE	SERVICE CONDENSATE RETURN SYSYTEM ECO-M14	TGD	MAW

			1	0.9 201.1 71 040		0.9 154 9 371 640	
	EMISS FINAL TOTAL	TEMP H		201.1		154 9	
	EMISS				- 1		
	INSULATION CHARACTERISTIC PIPE FLOW SPEC	HEAT		8.625 460 0.5 100 0.25 700 6200 1.05		8.625 460 0.5 100 0.25 700 6200 1.05	
	MOL	#/HR HEAT		6200		6200	
	PIPE	R		200		200	
	ERISTIC	CON 2 LEN		0.25		0.25	
	IARACTI	T2		100		100	
	TION CF	CON1 T2		0.5		0.5	
	INSULA	T 1		460		460	
1	ЫРЕ	DIA		8.625		8.625	
	MIND	VEL		-		L	
	INSUL	THICK	•	N		100.0	
	AMB	TEMP	1	C /	1	lc /	
		TEMP		212		212	

.

	CALCULATION SHEET		DATE Mar-90	SHEET OF			
PROJECT	USDB ENERGY SAVINGS OPPORTUR	NITY SURVEY	BASIS FOR CALCULATION				
LOCATION			X HAND COMPL	UTER			
ARCHITECT/	ENGINEER CLARK RICHARDSON & BISKU	P	CONTE	ACTOR BID			
ECO MEASU SERVICE			COMPUTED BY TGD	CHECKED BY			
120 PSIG	STEAM PRESSURE:		192.4 BTU/LB. ENTHALP	Ϋ́			
155°F CO	NDENSATE RETURN TEMPERATU	JRE:	23 BTU/LB. ENTHALPY				
201°F CO	NDENSATE RETURN TEMPERATU	JRE:	69 BTU/LB. ENTHALPY				
SYSTEM I	EFFCIENCY:	;	'4%				
AVERAGE	DAILY STEAM CONSUMPTION:		48,750 LBS.				
STEAM LC	DAD SERVED BY WEST TUNNEL:	ŧ	0%				
DAYS PER	R YEAR:	:	65				
(1192.4 - 1	23) - (1192.4 - 169) / 0.74	= 6	2.16 BTU/LB.				
(00 40 V 4	48,750 X .5 X 365)/1,000,000	= 1	,687 MBTU/YEAR				





-	

	· • •			REPARED	Mar-90		SHEET OF
PROJECT USDB ENERGY STUDY				BASIS FOR E			••••••••••••••••••••••••••••••••••••••
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				x	CODE E	A (NO DESIGI 3 (PRELIMINA 2 (FINAL DES	N COMPLETED) NRY DESIGN)
CLARK RICHARDSON & BISKU	CLARK RICHARDSON & BISKUP					(SPECIFY)	IGIN)
DRAWING NO.		ESTIM	ATOR	TGD		CHECKED BY	Y MAW
	QU	ANTITY		ATERIAL	L	ABOR	TOTAL
	NO. UNITS	UNIT MEAS.		TOTAL	PER UNIT	TOTAL	COST
6" DIA 2" THICK FIBERGLASS INSULATION	400	LF	\$5.87	\$2,348	\$3.45	\$1,380	\$3,7
ALUMINUM JACKET	400	LF	\$0.54	\$216	\$2.87	\$1,148	\$1,3
8" DIA. SCH. 80 STEEL PIPE	60	LF	\$37.66	\$2,260	\$22.00	\$1,320	\$3,5
2" THICK FIBERGLASS INSULATION	200	LF	\$7.25	\$1,450	\$4.31	\$862	\$2,3
ALUMINUM JACKET	200	LF	\$0.54	\$108	\$2.87	\$574	\$6
PIPE RACKS	6	EA	\$400	\$2,400	\$200	\$1,200	\$3,6
REPAIR HOLES IN PIPING	3	DAYS			\$252	- \$756	\$7
B" DIA. TEE	2	EA	\$71	\$142	\$71	\$142	\$2
8" DIA. 90° ELBOW	2	EA	\$100	\$200	\$140	\$280	\$4
DEMOLITION	60	LF			\$3.95	\$237	\$2
SUBTOTAL				\$9,124		\$7,899	\$17,02
DIFFICULTY FACTOR 50%					50%	\$3,950	\$3,95
SUBTOTAL						\$11,849	\$20,97
CONTINGENCY 10%			10%	\$912	10%	\$1,185	\$2,09
SUBTOTAL				\$10,036		\$13,034	\$23,07
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$351	13.0%	\$1,694	\$2,04
DIRECT COST				\$10,387		\$14,728	\$25,11
VERHEAD AND PROFIT			25%	\$2,597	25%	\$3,682	\$6,27
SUBTOTAL				\$12,984		\$18,410	\$31,39
CONSTRUCTION COST							\$31,39



PI Fi	ENEF ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY (LOC TITLI 90	E: 1496 DIS	TION INVES RT LEAVEN	TMENT PR WORTH -	OGRAM (E USDB REC ME: ECOM	GIOŃ NC 14		L	DY: USDBAE CCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	ICTIC OST CREE VALI	DIT CALC (1, JE COST		9				\$\$ \$ \$ \$\$ \$\$	31394. 1884. 1727. 31505. 0. 31505.
2.	ENERGY SAV ANALYSIS DA	INGS	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT	COST & D	ISCOUNTE	D SAVIN	IGS		
	FUEL		JNIT COST //MBTU(1)	SAVINGS MBTU/YR		INUAL \$ VINGS(3)		OUNT OR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 1687. 0.	***	0. 0. 6883. 0.		8.69 12.42 12.21 11.67 10.36		0. 0. 80325. 0.
	F. TOTAL			1687.	\$	6883.			\$	80325.
3.	NON ENERGY	(SAV	/INGS(+) / C0	OST(-)						
	A. ANNUAL R		RRING (+/-) FACTOR (TA			9.11			\$	0.
	(2) DISCO	UNTE	ED SAVING/0	COST (3A X	(3A1)	0.11			\$	0.
	C. TOTAL NO	N EN	ERGY DISC	OUNTED SA	AVINGS(+)	/COST(-) (3	3A2+3Bd	4)	\$	0.
	A IF 3D B IF 3D C IF 3I	AX N 1 IS = 1 IS - 01B IS	ENERGY QU ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJEC	' CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 ⊦3D1)/1F)=		\$2	6507.		
4.	FIRST YEAR [)oll.	AR SAVINGS	6 2F3+3A+(3	B1D/(YEA	RS ECONOI	MIC LIFE	E))	\$	6883.
5.	TOTAL NET D	ISCO	UNTED SAV	INGS (2F5+	3C)				\$	80325.
6.	DISCOUNTED (IF < 1 PROJE				(SI	R)=(5 / 1F)=		2.55		
7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F/	4		4.58	•	



ECO-M14

PAGE M14-6

ECO-M15

BOILER PLANT MODIFICATIONS





BOILER PLANT MODIFICATIONS:

ENERGY CONSERVATION OPPORTUNITY: ECO-M15

PURPOSE:

The purpose of this Energy Conservation Opportunity (ECO-M15) is to analyze the energy savings that may be realized by implementing the following:

- 1) Recover heat from the boiler flue gases, and transfer that heat to the boiler feed water.
- 2) Recover heat from the boiler blowdown cycle, and transfer that heat to the boiler feed water.
- 3) Install automatic boiler blowdown controls.
- 4) Increase the efficiency of the three high-pressure steam boilers currently serving the USDB.
- 5) Change the feedwater chemistry program of the three steam boilers currently serving the USDB.
- 6) Clean the tubes of the three steam boilers currently serving the USDB.
- 7) Install oxygen trim controls on the boilers at the USDB.

Within the next two years the (3) existing steam boilers are to be replaced with (3) new steam boilers. The existing boilers are capable of producing 20,000 lbs./hr each when burning natural gas. Using fuel oil as an energy source the boilers will produce steam at the rate of 10,000 lbs./hr. each. (2) 15,000 lb./hr. and (1) 30,000 lb./hr. boilers will provide operating flexibility to the facility. (1) 15,000 lb./hr. boiler can be operated at 120 psig pressure and dedicated to serve the laundry. The 30,000 lb./hr. and one of the 15,000 lb./hr. boilers would operate at 80 psig and serve the space heating requirements of the USDB. The total capacity of the steam generation system would not be changed, and the maximum hourly load of 30,000 lb./hr. could still be satisfied while burning fuel oil.

SCOPE:

This Energy Conservation Opportunity (ECO-M15) involves three existing forced draft type, natural gas fired, steam boilers located in the boiler plant Building #474. The boilers are capable of 20,000 lbs./hr. continuous steam production when using natural gas as an energy source.



ECO-M15



Each boilers is capable of 10,000 lbs./hr. continuous steam production when using # 6 fuel oil as an energy source. Field measurements indicate that the flue gas temperature of the boilers is 450° F using natural gas.

Steam is delivered to the various buildings by a system of insulated high pressure steam pipes located in tunnels. Generally, the steam pressure is reduced at the individual buildings and is used for space heating by one of two different means.

Some of the buildings utilize air handlers that are equipped with steam heating coils. Other buildings supply the steam to a heat exchanger where it is used to raise the temperature of the hot water, which is circulated by an electrically driven pump through terminal units. Terminal units consist of convectors, fan coils or air handlers equipped with hot water coils.

Condensate is returned through piping located in the same system of tunnels by gravity to the condensate pumps located in the boiler plant. The condensate pumps lift the condensate up to the deaerator, where it is heated to 220°F to release oxygen before being returned to the boilers. Boiler make-up water is also introduced into the system at the deaerator. The boiler feed pumps discharge the feedwater into the boilers through the boiler pump controls.

Outside air used for combustion in the boilers is introduced into the boiler plant by one or more different means as follows:

- a. Manually opening an overhead door.
- b. Manually opening windows.
- c. Airflow from the piping tunnels into the boiler plant.

The products of combustion are carried by insulated breeching to a masonry stack adjacent to the boiler plant structure, where they are discharged to the atmosphere.

- 1) Installing a boiler fuel economizer reduces fuel consumption by extracting heat from hot flue gases and transferring that heat to another source where the heat can be reclaimed in one of several different ways:
 - a. To preheat the boiler feedwater.
 - b. To preheat the make-up air used for combustion.
 - c. To heat domestic hot water.

We will consider utilizing this heat to preheat the boiler feedwater. Utilization of the extracted heat to preheat combustion air is not an option, because there is not a single fixed outside air intake duct, plenum or opening available for installation a heat exchanger coil.





Utilizing the heat for domestic water heating purposes is not viable. Domestic water heating is accomplished at the various buildings inside the USDB facility, and not at a central location such as the boiler plant.

- 2) A blowdown heat recovery unit reduces fuel consumption in two separate ways:
 - a. First, by extracting heat from the hot boiler blowdown water, and by using that energy to heat the make-up water for the boilers.
 - b. A second means by which the unit reduces fuel consumption is by capturing the flash steam which is produced when the boiler water pressure is reduced from the boiler operating pressure to atmospheric pressure and transferring that steam to the deaerator.
- 3) Installing automatic boiler blowdown controls is not a valid energy conservation opportunity. The (3) existing steam boilers are presently equipped with automatic blowdown controls. The existing blowdown system operates on an intermittent cycle controlled by a measurement of the total dissolved solids.

The existing blowdown rate for the steam boilers is approximately 0.7 gallons per minute. The existing blowdown controls are adequate, and there is not an opportunity to conserve energy by modifying, or replacing these existing controls.

- 4) An increase in boiler efficiency can be accomplished in two ways:
 - a. Reducing stack losses.
 - b. Reducing heat lost from the outside surfaces of the boilers.

Reducing stack losses means reducing flue gas temperature. This can be accomplished by controlling the amount of combustion air allowed into the combustion chamber. Any increase over the optimum air quantity for combustion will reduce not the efficiency of combustion itself, but rather the rate of heat transfer to the boiler of furnace; an increase in the stack temperatures will also occur.

The ideal amount of excess air is approximately 15%. Field measurements on boilers at the USDB indicated 37% excess air and 80% combustion efficiency. Oxygen trim controls will be discussed later. Another way to reduce flue gas temperature, which is not directly related to the boilers themselves, is to recover heat from the flue gases. This was discussed in #1.

The only way to reduce heat loss from the outside surfaces of the boilers is to apply insulation to them. Because the boilers are to be replaced soon, the cost of insulating the existing boilers would outweigh any energy savings that would be realized in the short time before they are replaced.



5) Improving the boiler feedwater chemistry program so that the boilers operate more efficiently due to cleaner tubes and less frequent blowdowns is not a valid energy conservation opportunity.

Currently, a chemical water treatment system is used that employs a polymer which attaches itself to the suspended solids and forms large "clumps". This action makes the blowdown process efficient, resulting in a minimum amount of water flow to accomplish the removal of the solids and scale from the steam system.

6) Annual cleaning of the boiler tubes in order to increase boiler efficiencies, thereby decreasing boiler energy consumption is currently a part of the maintenance of the steam system.

The water tubes for the (3) existing steam boilers are acid cleaned yearly, and a visual inspection of boiler #3 showed the tube walls to be clean and free from deposits, or scale accumulation

7) Installing oxygen trim controls on the boilers allows the quantity of air introduced with the fuel to be adjusted to its optimum operating point. This air quantity is important because too little air results in incomplete combustion and reduced efficiency.

Too much air allows complete combustion, but wastes heat up the stack by increasing the volume of exhaust. Because the inefficiency of incomplete combustion is much worse than the inefficiency of excess air, the units are adjusted to allow excess air of approximately 40% with a control error band of 35%.

The ideal amount of excess air is approximately 15%. Boiler oxygen trim controls measure the stack temperature, and the amount of excess air in the exhaust gas. The amount of excess air is directly related to these two factors. The oxygen trim control unit automatically adjusts the quantity of air or fuel to keep the excess of air to 15%.

MODELING TECHNIQUES:

Boiler stack economizer calculations were done by hand using an existing feedwater temperature of 220°F from the deaerator, and a new feedwater temperature of 232.6°F. The new feedwater temperature was determined by a manufacturer of econimizers. The savings were estimated by using the difference in enthalpy of the two feedwater temperatures.

The water meter for the make-up water system indicates approximately 3,000 gallons per day is used during the winter months to replenish the water lost due to blowdown and system leakage. We must estimate that 83% of the make-up water is blowdown, and the remaining 17% is leakage.





There is no water meter available that can measure water flow in the process of flashing off steam as its pressure is reduced from 120 psig to atmospheric pressure. Nor could a water meter withstand the 350°F saturation temperature of 120 psig steam and the solids or scale coming from a pressurized boiler for any length of time.

83% of 3,000 gallons equals approximately 2,500 gallons of blowdown per day for the winter months. The winter steam production for the USDB is 370,000 pounds per day, and using 2,500 gallons as the blowdown quanity the blowdown rate is equal to 5% of the boiler steam production.

The yearly average steam production is estimated to be 148,750 lbs./day, or 6,198 lbs./hour. This number is used for calculation of energy savings for heat recovery for the boiler blowdown.

Boiler oxygen trim control calculations were done by hand. First, field measurements of boiler combustion air were taken with a combustion analyzer. This device monitors oxygen, carbon dioxide, and percent of excess air to calculate a combustion efficiency.

Next, a new combustion efficiency was found for 15% excess air, the amount allowed into the combustion chambers by the oxygen trim controls. The difference between the two combustion efficiencies was the percentage of energy savings.

ECO IMPLEMENTATION:

The construction cost estimate for the boiler stack economizer includes the material and installation costs for the economizer coil unit, piping modifications, pipe insulation, valves and accessories.

The construction cost estimate for the blowdown heat recovery includes the material and installation costs for the packaged heat recovery unit, piping modifications, pipe insulation, valves and accessories.

Oxygen trim controls can either be purchased as part of a package with future boilers or installed (at a higher cost) on the existing boilers. For the purpose of this study, we are assuming installation of the controls on the existing boilers.

SUMMARY:

The project costs shown in Table M15-1 are the construction costs plus 6% SIOH. Each valid option in this ECO was considered as a separate project.

The energy savings associated with the implementation of this ECO is also shown in Table M15-1 on a MBTU per year and dollars per year savings as determined by hand calculations.

We recommend installing blowdown heat recovery on the (3) new boilers at the time of replacement, because the payback period does not warrant the installation on the present boilers.





We recommend using a boiler stack fuel economizer on the new 15,000 lb./hr. boiler serving the laundry with 120 psig steam. The saturated temperature for 120 psig steam is 350° F., and the flue gas must be approximately 450° F. to transfer the heat from the fuel to the water in the boiler. This flue gas temperature is higher than the temperature for the (2) 80 psig boilers. The laundry boiler also operates on a year-round basis.

The cost for blowdown heat recovery is \$24,370 and the savings to investment ratio is 1.79, and the simple payback is 6 1/2 years. The cost for the boiler stack economizer is \$22,852 with a savings to investment ratio is 1.92, and the simple payback is 6 years.

Oxygen trim controls were found to have a payback of 2.67 years. However, if the boilers are to be replaced within a period of time that is close to this, we recommend that the controls not be purchased until the new boilers are purchased. At that time, the controls can be bought as part of a package with the boilers.

Project «	Energy Savings (MBTU/yr)	Energy Savings (\$/yr)	Project Cost (\$)	Simple Payback (years)	Savings to Investment Ratio
Economizer H.R.	925	3,774	22,852	6.08	1.92
Blowdown H.R.	917	3,741	24,370	6.54	1.79
O2 Trim Controls	3,397	13,860	39,077	2.67	4.37

Table M15-1



	CALCULATION SHEET			DATE Mar 00	SHEET OF			
PROJECT	USDB ENERGY SAVINGS OPPOR			Mar-90 BASIS FOR CALCU				
LOCATION		TONITY SORVE	<u>. T</u>		TED			
ARCHITECT/E	CLARK RICHARDSON & BIS		COMPUTER CONTRACTOR BID OTHER (SPECIFY)					
ECO MEASUR	E ECONOMIZER ECO-M15			COMPUTED BY TGD	CHECKED BY			
220.0°F BO	ULER FEEDWATER TEMPER	ATURE:	188.0	BTU/LB. ENTHALPY				
232.6°F BO	ILER FEEDWATER TEMPERA	ATURE:	200.6	BTU/LB. ENTHALPY				
SYSTEM E	FFCIENCY:		74%					
	FFCIENCY: DAILY STEAM CONSUMPTIO	'N:		0 LBS.				
	DAILY STEAM CONSUMPTIO	N:		0 LBS.				
AVERAGE DAYS PER	DAILY STEAM CONSUMPTIO YEAR:		148,75 365					
AVERAGE DAYS PER (200.6 - 188	DAILY STEAM CONSUMPTIO YEAR:	9N: =	148,75 365	io LBS. BTU/LB.				



	CALCULATION SHEET	DATE	SHEET OF
PROJECT	USDB	Mar-90 BASIS FOR CALCULA	
OCATION	ENERGY SAVINGS OPPORTUNITY SURVEY		
RCHITECT/E	NGINEER	COMPU	TER ACTOR BID
	CLARK RICHARDSON & BISKUP	OTHE	R (SPECIFY)
	BLOWDOWN HEAT RECOVERY ECO-M15	COMPUTED BY TGD	CHECKED BY MAW
		*	
BLOWDOW	VN INLET TEMPERATURE:	350°F	
BLOWDOW	VN OUTNLET TEMPERATURE:	100°F	
TEMPERA	TURE DIFFERNTIAL:	250°F	
AVERAGE	STEAM PRODUCTION:	148,750 LBS./DAY	
AVERAGE	STEAM PRODUCTION PER HOUR:	6,198	
BLOWDOW	/N RATE:	5%	
SYSTEM E	FFICIENCY:	74%	
MBTU:		1,000,000	
24 HOURS	× 365 DAYS =	8760	
[(250 x 6198	8 x 0.05) / (0.74 x 1,000,000)] x 8760 =	917 Dl Cp water	=\Blue
917 MBTU \$			
	OF- X #ster /HK X MDTY	BDHAS Deter R	X HR
	Υ.		

		ATION SHEET			D	ATE Mar-90		SHEET	
PROJECT	USDB				R		R CALCUL		
		SAVINGS OP	PORTUN	ITY SURVEY					
LOCATION				· ·		X	HAND		
ARCHITECT/EI		VENWORTH	<u>, KANSA</u>	S			COMPUT		
		CHARDSON	8 BICKII	D	-		CONTRA	CTOR BID	A
ECO MEASURI						OMPUTE		(SPECIFY	
	ECO-M15	O2 TRIM COI	NTROLS				BMS		MAW
		BAL HEATING							
TEST DATA			<u>a plant</u>	_					
% OXYGEN		_	6.3 9						
STACK TEN % EXCESS		E	450 °	-					
EFFICIENC			37. ° 80.509						
%CO 2	•		8.3						
Steam Pro Summer Winter Average (75,00 370,00	LER PLANT OP 0 LBS/DAY 0 LBS/DAY 0 LBS/DAY	ERATORS:				
BOILER TRI	M CONTRO	L REDUCES	EXCESS	AIR TO 15%					
FROM "GAS KANSAS ST			NCY CH	ART" PUBLISHE	D BY COO	PERATIV	E EXTENS	SION SERV	/ICE
		non t, MANP	HAIIAN	KS.:			-		.02,
				KS.: 6 COMBUSTIOI	N EFF.		-		,
	S AIR AT 3	17°F =	84.50%						,
15% EXCES 84.50% ENTHALPY	S AIR AT 3 - OF STEAM OF CONDE	17°F = 80.50% LEAVING BO NSATE RETU	84.50% = ILEBS	6 COMBUSTION 4.00% IN		i comb. e [U/lb [U/lb			,
15% EXCES 84.50% ENTHALPY ENTHALPY ENTHALPY	S AIR AT 3 - OF STEAM OF CONDE	17°F = 80.50% LEAVING BO NSATE RETU CE	84.50% = ILEBS	6 COMBUSTION 4.00% IN FO BOILERS	CREASE IN 1192.4 BT 128 BT	i Comb. e Tu/lb Tu/lb Tu/lb	FF.		,
15% EXCES 84.50% ENTHALPY ENTHALPY ENTHALPY	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY >	17°F = 80.50% LEAVING BO NSATE RETU CE	84.509 = ILERS IRNING 1	6 COMBUSTION 4.00% IN FO BOILERS	CREASE IN 1192.4 BT 128 BT 1064.4 BT	i Comb. e Tu/lb Tu/lb Tu/lb	FF.		,
15% EXCES 84.50% ENTHALPY ENTHALPY ENTHALPY 148,750	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769	17°F = 80.50% LEAVING BO NSATE RETU CE 4,064 B	84.50% = IRNING 7 TU/LB X	& COMBUSTION 4.00% IN TO BOILERS 365 DA	CREASE IN 1192.4 BT 128 BT 1064.4 BT	i Comb. e Tu/lb Tu/lb Tu/lb	FF.		,
15% EXCES 84.50% ENTHALPY ENTHALPY ENTHALPY 148,750	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769 SLATES TO	17°F = 80.50% LEAVING BO NSATE RETU CE (1,064 B MBTU/YR.	84.509 = IRNING T TU/LB X MPTION	& COMBUSTION 4.00% IN TO BOILERS 365 DA	CREASE IN 1192.4 BT 128 BT 1064.4 BT	i Comb. e Tu/lb Tu/lb Tu/lb	FF.		,
15% EXCES 84.50% ENTHALPY ENTHALPY ENTHALPY 148,750 THIS TRANS	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769 SLATES TO	17°F = 80.50% LEAVING BO NSATE RETU CE (1,064 B MBTU/YR. GAS CONSU	84.509 = IRNING T TU/LB X MPTION	6 COMBUSTION 4.00% IN FO BOILERS 365 DA S OF	CREASE IN 1192.4 BT 128 BT 1064.4 BT	i Comb. e Tu/lb Tu/lb Tu/lb	FF.		,
15% EXCES 84.50% ENTHALPY ENTHALPY 148,750 THIS TRANS 57,769	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769 SLATES TO /	17°F = 80.50% LEAVING BO NSATE RETU CE (1,064 B MBTU/YR. GAS CONSU	84.50% = ILERS IRNING T TU/LB X MPTION =	6 Combustion 4.00% in 70 Boilers 365 DA 365 DA S OF 71,763 ME	CREASE IN 1192.4 BT 128 BT 1064.4 BT	I COMB. E TU/LB TU/LB TU/LB	FF. MBTU/BT	U =	,
15% EXCES 84.50% ENTHALPY ENTHALPY 148,750 THIS TRANS 57,769 AND	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769 SLATES TO /	17°F = 80.50% LEAVING BO NSATE RETU CE (1,064 B MBTU/YR. GAS CONSU 80.50%	84.50% = ILERS IRNING T TU/LB X MPTION =	6 Combustion 4.00% in 70 Boilers 365 DA 365 DA S OF 71,763 ME	CREASE IN 1192.4 BT 128 BT 1064.4 BT AYS/YR > C BTU/YR.	I COMB. E TU/LB TU/LB TU/LB	FF. MBTU/BT	U =	,
15% EXCES 84.50% ENTHALPY ENTHALPY 148,750 THIS TRANS 57,769 AND 57,769	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769 SLATES TO /	17°F = 80.50% LEAVING BO NSATE RETU CE (1,064 B MBTU/YR. GAS CONSU 80.50%	84.50% = ILERS IRNING T TU/LB X MPTION =	6 Combustion 4.00% in 70 Boilers 365 DA 365 DA S OF 71,763 ME	CREASE IN 1192.4 BT 128 BT 1064.4 BT AYS/YR > C BTU/YR. BTU/YR. WF	I COMB. E TU/LB TU/LB TU/LB	FF. MBTU/BT	U =	
15% EXCES 84.50% ENTHALPY ENTHALPY 148,750 THIS TRANS 57,769 AND 57,769 SAVINGS	S AIR AT 3 - OF STEAM OF CONDE DIFFERENC LBS/DAY > 57,769 SLATES TO / /	17°F = 80.50% LEAVING BO NSATE RETU CE 1,064 B MBTU/YR. GAS CONSU 80.50% 84.50%	84.50% = ILERS IRNING 7 ITU/LB X MPTION = =	68,366 ME 3,397 ME	CREASE IN 1192.4 BT 128 BT 1064.4 BT AYS/YR > C BTU/YR. BTU/YR. WF BTU/YR.	I COMB. E TU/LB TU/LB TU/LB	FF. MBTU/BT	U =	

Hughes Machinery PROPOSAL 322-00253-0-0 RUN 00

THE OF MEMORY TULSA, OKLAHOMA

PRINIED 03/08/90 TIME 18 HRS 55 MINS CUST. REFERENCE

RETROMISER FUEL ECONOMIZER

PERFORMANCE

FLUID CIRCULATED IN TUBES IS WATERHEAT EXCHANCED175591. BTUZHRU EXTERNAL6.573 BTUZHR-SOFT-FU BARE TUBE61.762 BTUZHR-SOFT-FLMTD118.1 DEE FBARE TUBE SURFACE27. SOFTMAX FIN TEME311 DEE F	COUNTER CURRENT FLOW		
HEAT EXCHANCED175591.BTUZERU EXTERNAL6.573BTUZERU BARE TUBE61.962BTUZER-SQFT-FLMTD118.1DEG 7BARE TUBE SURFACE27.SQFTMAX FIN TEME311DEG 7	FLUID CIRCULATED IN 7	UBES IS WA	TER
U BARE TUBE61.073 BTU/HR-SQFT-FLMTD61.762 BTU/HR-SQFT-FBARE TUBE SURFACE118.1 DEC TMAX FIN TEME311 DEC T	HEHI EXCHANCED	175591.	BTUZHR
LMTD BIL 762 BTU/HR-SQFT-F BARE TUBE SURFACE 27. SQFT MAX FIN TEMP 311 DEC F		6.573	BTU/HR-SOFT-F
MAX FIN TEMP 311 DER F	LMTD	51.752	BTU/HR-SQFT-F
		1 M 10-10	
	MAX TUBE WALL TEMP		
BOILER FLUID SAT TEMP 350. DEG F	BOILER FLUID SAT TEMP	a	

PERFORMANCE SPECIFICATIONS TUBE SIDE GAS SIDE

OVERALL CONSTRUCTION

HORIZONTAL GAS FLOW DIMENSIONS DEFTH 3'- 7 1/2" WIDTH 6'-11 1/2" HEIGHT 2'~ 7 5/8" NOZZLE C-C 1'- 1 1/2" DRAWING NO RA-208 NO OF SOOT BLOWER LANES 1 NOZZLE SIZE 2.0 IN., 300 RFWN EFF SURFACE AREA 252. SOFT WEIGHT OF LIQUID 86. LB WEIGHT OF UNIT(DRY) 1934. LB

CONSTRUCTION SPECIFICATIONS TUBE SIDE

DEG F	DESIGN PRESSURE TEST PRESSURE DESIGN TEMPERATL DUCT OFENING HEIGHT WIDTH	735. PSI JRE 700. DEG
LB/CUFT	NUMBER OF TUBES	12
CPS	NUMBER OF ROWS	3
BTU/LE F	TUBES FER ROW	4
_	PARALLEL STREAMS	1
OFT F/BTU	TUBE PITCH	4.500 IN (SQ)
	OUTSIDE DIA	
	MIN TUBE WAL	LL .105 IN
	LEN OVERALL	4'-10"
	LEN EFF.	4'- 3"
	MATERIAL	50-178-A
	FIN THICKNESS FITCH HEIGHT	.060 IN
	FITCH	4.00 FINS/IN
	HEIGHT	.750 IN
	MATERIAL	
	INSULATION	MIN WOOL
	SIDES	2.0 IN
	HEADER BOX	2.0 IN
	INTERMEDIATE TUBE	SUPPORTS
	QUANTITY	Q
1	TYPE Casing	LATTICE
	THICKNESS	1340 11
	MATERIAL	C.S.
-	TYPE OF RETURN	180 DEG. BEND
		THE FLOW DEND

FLUID ENTERING TEMP IN TEMP OUT PRES IN PRES DROP VELOCITY MASS VEL DEN Y VI SITY SPEC HEAT FOULING FACTOR	220.0	,23 35,4 1,7 .0477 .0202	LB/HR DEG F PSIA IN WATER FT/SEC LB/SQ FT LB/CUFT CPS BTU/LB F
--	-------	--------------------------------------	--

.0202 CPS 2703 BTU/LB F 0010 HR SOFT F/BTU



PF FK	STALLATION & ROJECT NO. & T SCAL YEAR 199		FION INVEST RT LEAVEN	TMENT PR WORTH - RTION NAM	OGRAM (EC USDB REG //E: ECOM1	10N NOS. 7	L	DY: USDBAE CCID 1.035 CENSUS: 2
1.	E. SALVAGE	CTION COST OST CREDIT CALC (1)		9			\$\$ \$\$ \$\$ \$	22852. 1371. 1257. 22932. 0. 22932.
2.	ENERGY SAVI ANALYSIS DA	INGS (+) / COST TE ANNUAL SAV	(-) 'INGS, UNIT	COST & D	ISCOUNTE	D SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)			NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	0. 0. 0. 925. 0.	\$ \$ \$ \$ \$	0. 0. 0. 3774. 0.	8.69 12.42 12.21 11.67 10.36		0. 0. 0. 44043. 0.
	F. TOTAL		925.	\$	3774.		\$	44043.
3.	NON ENERGY	' SAVINGS(+) / Co	OST(-)					
	A. ANNUAL RE (1) DISCOU	ECURRING (+/-) UNT FACTOR (TA			9.11		\$	0.
	(2) DISCOL	UNTED SAVING/	COST (3A X	3A1)	0		\$	0.
	C. TOTAL NON	N ENERGY DISC	OUNTED SA	VINGS(+)	/COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% MA A IF 3D1 B IF 3D1 C IF 3D	NON ENERGY QU AX NON ENERGY 1 IS = OR > 3C G 1 IS < 3C CALC 01B IS = > 1 GO T 1B IS < 1 PROJEC	' CALC (2F5 O TO ITEM 4 SIR = (2F5+ O ITEM 4	X .33) 4 -3D1)/1F)=		\$ 14534. 		
4.	FIRST YEAR D	OLLAR SAVINGS	5 2F3+3A+(3	B1D/(YEAF	RS ECONON	AIC LIFE))	\$	3774.
5.	TOTAL NET DI	SCOUNTED SAV	INGS (2F5+	3C)			\$	44043.
6.	DISCOUNTED (IF < 1 PROJEC	SAVINGS RATIO CT DOES NOT QI	JALIFY)	(SIF	R)=(5 / 1F)=	1.92		
7.	SIMPLE PAYBA	ACK PERIOD (ES	TIMATED)	SPB=1F/4	Ļ	6.08		



Р F	ENEF ISTALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY LOC TITL 90	E: 1496 DIS	TION INVES RT LEAVEN SCRETE PO	TMENT PENT PENT PENT PENT PENT PENT PENT P	ROGRAM (E	BION NOS.	7	LCC	USDBAE CID 1.035 ENSUS: 2
	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	- ICTIC OST CREI VAL	DN COST DIT CALC (1. UE COST	A+1B+1C)X					\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	24370. 1462. 1340. 24455. 0. 24455.
2.	ENERGY SAV ANALYSIS DA		S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST & [DISCOUNTE	D SAVINGS	;		
	FUEL		UNIT COST \$/MBTU(1)			NNUAL \$ AVINGS(3)				OUNTED NGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 917. 0.	\$ \$ \$ \$	0. 0. 0. 3741. 0.	12. 12.	69 42 21 67 36		0. 0. 0. 43657. 0.
	F. TOTAL			917.	\$	3741.			\$	43657.
3.	NON ENERGY	SAV	/INGS(+) / C0	OST(-)						
	A. ANNUAL R (1) DISCO	ECU UNT	RRING (+/-) FACTOR (TA			9.11			\$	0.
	(2) DISCO	UNT	ED SAVING/	COST (3A X	(3A1)	5.11			\$	0.
	C. TOTAL NO	N EN	IERGY DISC	OUNTED SA	AVINGS(+)	/COST(-) (3	A2+3Bd4)		\$	0.
	A IF 3D B IF 3D C IF 3D	AX N 1 IS 1 IS 1 B I	ENERGY QU ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJE(' CALC (2F5 O TO ITEM / SIR = (2F5- O ITEM 4	i X .33) 4 ⊦3D1)/1F)=		\$ 1440	7.		
4.	FIRST YEAR D	OLL	AR SAVINGS	6 2F3+3A+(3	B1D/(YEA	RS ECONON	AIC LIFE))	:	\$	3741.
5.	TOTAL NET DI							:	\$	43657.
6.	DISCOUNTED (IF < 1 PROJEC	SAV CT D	INGS RATIO OES NOT QU	JALIFY)	(SI	R)=(5 / 1F)=	1.7	79		
7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F/	4	6.5	54		

۲ F	ENE NSTALLATION ROJECT NO. 8 ISCAL YEAR 19 NALYSIS DATE	RGY C & LOC TITLE 990	ONSERVA ATION: FO : 1496 DIS	SCRETE POF		ROGRAM (E	310N NOS 1502		L	DY: USDBAE CCID 1.035 CENSUS: 2
1	INVESTMEN A. CONSTR B. SIOH C. DESIGN D. ENERGY E. SALVAGE F. TOTAL IN	UCTIO COST CRED E VALL	IT CALC(1 IE COST		Ð				\$\$ \$\$ \$\$ \$ \$ \$	36865. 2212. 2028. 36995. 0. 36995.
2.	ENERGY SA ANALYSIS D	VINGS ATE A	(+) / COST NNUAL SAV	(-) /INGS, UNIT	COST & I	DISCOUNTE	D SAVINO	S		
	FUEL	U	NIT COST /MBTU(1)	SAVINGS MBTU/YR(А	NNUAL \$ AVINGS(3)	DISCO FACTO	UNT		SCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 3397. 0.	\$ \$ \$ \$ \$ \$ \$	0. 0. 0. 13860. 0.	1 1 1	8.69 2.42 2.21 1.67 0.36		0. 0. 0. 161746. 0.
	F. TOTAL			3397.	\$	13860.			\$	161746.
3.	NON ENERG	Y SAV	INGS(+) / C	OST(-)						
	A. ANNUAL F		RRING (+/-) FACTOR (TA			9.11			\$	0.
	(2) DISCO	OUNTE	D SAVING/0	COST (3A X	3A1)	9.11			\$	0.
	C. TOTAL NO	ON ENI	ERGY DISC	OUNTED SA	VINGS(+)	/COST(-) (3	A2+3Bd4)	\$	0.
	A IF 3[B IF 3[C IF 3	IAX NC 01 IS = 01 IS < D1B IS	ON ENERGY OR > 3C G 3C CALC = > 1 GO T	′ CALC (2F5 O TO ITEM 4 SIR = (2F5+)	X .33) 3D1)/1F)₌		\$ 53	376.		
4.	FIRST YEAR	DOLLA	R SAVINGS	S 2F3+3A+(31	B1D/(YEA	RS ECONO	MIC LIFE))	\$	13860.
5.	TOTAL NET D	ISCOL	JNTED SAV	'INGS (2F5+3	BC)				\$	161746.
6.	DISCOUNTED (IF < 1 PROJE) SAVI CT DC	NGS RATIO DES NOT QI	JALIFY)	(S	IR)=(5 / 1F)=	4	4.37		
7.	SIMPLE PAYE	BACK F	PERIOD (ES	TIMATED)	SPB=1F		2	2.67		



.

CONSTRUCTION COST ESTI	EPARED	SHEET OF					
PROJECT USDB ENERGY STUDY		BASIS FOR E					
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER			x	CODE	3 (PRELIMINA	DESIGN COMPLETED) ELIMINARY DESIGN)	
CLARK RICHARDSON & BIS	KUP					C (FINAL DES (SPECIFY)	IGN)
DRAWING NO. ECONOMIZER ECO-M15		ESTIM	ATOR			CHECKED BY	7
ECONOMIZER ECO-MTS	QU			ATERIAL		ABOR	TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BOILER STACK ECONOMIZER	1	EA	\$8,345	\$8,345	\$3,500	\$3,500	\$11,8
2" BOILER FEEDWATER PIPING	200	LF	\$2.36	\$472	\$5.50	\$1,100	\$1,5
1 1/2" THICK PIPE INSULATION							
	200		\$3.21	\$642	\$1.81	\$362	\$1,0
2" BALL VALVES	8	EA	\$68	\$544	\$41	\$328	\$8
THERMOMETERS	2	EA	\$55	\$110	\$7.55	\$15	\$-
PRESSURE GAUGES	2	EA	\$70	\$140	\$6.15	\$12	\$1
	_						

SUBTOTAL				\$10,253		\$5,317	\$15,5
CONTINGENCY 10%			10%	\$1,025	10%	\$532	\$1,5
SUBTOTAL				\$11,278		\$5,849	\$17,1
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$395	13.0%	\$760	\$1,1
DIRECT COST				\$11,673		\$6,609	\$18,2
VERHEAD AND PROFIT			25%	\$2,918	25%	\$1,652	\$4,5
SUBTOTAL				\$14,591		\$8,261	\$22,8
CONSTRUCTION COST							\$22,8

.

· · · ·

5

CONSTRUCTION COST ESTIMATE DATE P			DATE PR	EPARED	Mar-90		SHEET OF	
PROJECT					STIMATE		<u> </u>	
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER			X CODE A (NO DESIGN COMPLET CODE B (PRELIMINARY DESIGN CODE C (FINAL DESIGN)					
CLARK RICHARDSON & BISK DRAWING NO.	UP	ICOTIN	ATOD			(SPECIFY)	•	
BLOWDOWN HEAT RECOVERY ECO-M15		ESTIM		TGD		CHECKED B	MAW	
	QU/ NO.	ANTITY UNIT	PER M	ATERIAL TOTAL		ABOR	TOTAL	
	UNITS			TOTAL	PER UNIT	TOTAL	COST	
BLOWDOWN RECOVERY UNIT	1	EA	\$9,900	\$9,900	\$4,950	\$4,950	\$14,85	
2" BLOWDOWN PIPING	100	LF	\$2.36	\$236	\$5.50	\$550	\$78	
1 1/2" THICK PIPE INSULATION	100	LF	\$3.21	\$321	\$1.81	\$181	\$50	
2" BALL VALVES	3	EA	\$68	\$204	\$41	\$123	\$32	
THERMOMETERS	2	EA	\$55	\$110	\$7.55	\$15	\$12	
							-t	
SUBTOTAL				\$10,771		\$5,819	\$16,59	
CONTINGENCY 10%			10%	\$1,077	10%	\$582	\$1,65	
SUBTOTAL				\$11,848		\$6,401	\$18,24	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$415	13.0%	\$832	\$1,24	
DIRECT COST			0.0070	\$12,263	.0.0 /8	\$7,233	\$1,24	
VERHEAD AND PROFIT			25%	\$3,066	25%	\$1,808	\$4,87	
SUBTOTAL				\$15,329		\$9,041	\$24,37	
CONSTRUCTION COST							\$24,370	



Ŋ

		DATE PR	DATE PREPARED Mar-90				OF	
	JECT USDB ENERGY STUDY			BASIS FOR E				
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				x	N COMPLE ARY DESIG	COMPLETED) RY DESIGN) GN)		
CLARK RICHARDSON & BIS DRAWING NO.	KUP	ICOTIN			OTHEF	(SPECIFY)		
NONE		ESTIM	ATOR	BMS		CHECKED BY	Y MAW	
ECO-M15		ANTITY		IATERIAL		ABOR	TC	TAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL •	PER UNIT	TOTAL	C	DST
OXYGEN TRIM CONTROL	3	EA	\$2,100	\$6,300	\$5,985	\$17,955		\$24,255
								····
	_				•			
•••••••••••••••••••••••••••••••••••••••								
SUBTOTAL								
				\$6,300		\$17,955		\$24,255
CONTINGENCY 10%			10%	\$630	10%	\$1,796		\$2,426
				\$6,930		\$19,751		\$26,681
NORK COMP, TAX, SOC.SEC., INS			3.50%	\$243	13.0%	\$2,568		\$2,811
				\$7,173		\$22,319		\$29,492
			25%	\$1,793	25%	\$5,580		\$7,373
SUBTOTAL				\$8,966		\$27,899		\$36,865
CONSTRUCTION COST								\$36,865



ECO-M24

CONVERT FROM STEAM TO HOT WATER





CONVERT STEAM TO HOT WATER

ENERGY CONSERVATION OPPORTUNITY: ECO-M24

PURPOSE:

The purpose of this Energy Conservation Opportunity M24 is to analyze the energy savings that may be obtained by converting the existing high pressure steam system to a hot water heating system. High temperature hot water system are desirable because of reduced thermal losses and better control. Line losses such as leaks, thermal transmission and trap blow through make steam systems less efficient. New Hot Water Boilers are more efficient at partial loads than the existing Steam Boilers located at the USDB.

SCOPE:

ECO-M24 includes replacing the portion of existing steam system used for space heating and replacing it with a hot water heating system. Some existing steam capacity will need to remain to handle the laundry and the domestic hot water system. The application of this project was considered for the following buildings:

Building Building Building Building Building Building	463 464 465 466 472 473 475	Building Building Building Building Building Building Building	475B 475C 475D 475E 475F 475G 475H
Building	475A	Dunung	4/38

New supply and return piping will be added and connected to the existing hot water systems in each building. Steam coils in Castle buildings will be removed and replaced with hot water coils, controls, and connecting piping.





MODELING TECHNIQUES:

The modeling techniques used to simulate this ECO were using the assumption that a Savings to Investment Ratio of at least 1would be required. It is difficult to estimate the exact efficiencies of both system without a complete design so an alternative approach was taken. First a cost estimate of the new hot water system was generated using the heating loads obtained by the computer models created for this study. The project cost, the yearly pumping costs and the fuel costs were entered into the Life Cycle Cost Analysis program. The energy saving in MBTU's was adjusted to obtain an SIR of 1. The existing heating loads divided by the energy saving required gives the total improved efficiency of the hot water system. This improvement in efficiency of 83% is not obtainable thus eliminating the cost effectiveness of this ECO.

ECO IMPLEMENTATION:

Because of the large construction cost and yearly operating costs involved with this ECO a payback was not obtainable.





CALCULATION SHE	ET	DATE Mar-90	SHEET	0F
PROJECT USDB		BASIS FOR CALCUL		I
LOCATION	PPORTUNITY SURVEY	X HAND		
ARCHITECT/ENGINEER		COMPUTE		
CLARK RICHARDSOI	N & BISKUP		TOR BID	
ECO MEASURE		COMPUTED BY	CHECKED	BY
ECO-M24		RGB		MAW
HAND CALCULATION OF ENERGY HOT WATER SYSTEM CALCULAT	Y SAVINGS ASSOCIATED WITH HO ED TO SERVE ALL BUILDING INCI	OT WATER HEATING S	YSTEM	
PROJECT COST = \$634,367				
PUMP ENERGY 75 HP. MOTOR				
1 HP = 746 WATTS				
75 X 746 = 55.95 KW HOT WATER PUMP RUN TIME = 4				
ENERGY = 55.95 KW X 4,380 HR	= 245,061 KW = 836.4 MBTU'S			
PUMP ENERGY = 836.4 MBTU'S P	ER YEAR			
FROM LIFE CYCLE COST ANALYS	SIS W/ SIR = 1			
REQUIRED YEARLY SAVINGS	=15,300 MBTU OF NATURAL GA = \$ 62,424 PER YEAR	S		
PRESENT HEATING ENERGY USA	GE / YR = 18,522 MBTU = \$ 98,907 PER YEAR			
INCREASED EFFICIENCY OF NEW	SYSTEM TO OBTAIN SIR = 1			
15,300 MBTU / 18,533 MBTU = 83%	· ·			
REQUIRED 83 % INCREASE IN EF	FICIENCY IS NOT POSSIBLE			

A

	CALCULATIO	N SHEET	DATE	SHEET OF
	PROJECT	USDB ENERGY SAVINGS OPPORTUNITY SURVEY	Mar-90 BASIS FOR CALCUL	ATION
)	LOCATION		X HAND COMPUTE	Ð
	ARCHITECT/E	CLARK RICHARDSON & BISKUP	CONTRAC	
	ECO MEASUR	E ECO-M24	COMPUTED BY RGB	CHECKED BY MAW

THE HEATING CAPACITY PER BUILDING IS:

0.41.411

BUILDING	MBH HTG.
450	0.817
463	0.419
464	0.319
465	2.257
466	0.795
472	0.849
473	0.541
475	1.555
475A	0.667
475B	0.464
475C	1.539
475D	1.646
475E	5.317
475F	1.648
475G	1.556
475H	0.446

TOTAL 20.835 MILLION BTUH

INSTALL 3 15 MILLION BTUH HOT WATER BOILERS

USING A HOT WATER TEMPERATURE OF 180° TO 200° USING A TYPICAL DELTA TEMPERATURE OF 10°F


ENERGY = 20,835,000 BTUH

ΔT = 20° F GPM = (ENERGY) / (ΔT) (500 LB MIN / GAL HOUR) GPM = 20,835,000 / 10,000 GPM = 2083.5

PUMP TO BE SIZED FOR 2,100 GPM

USING THE FOLLOWING SPREADSHEET, PIPE SIZES, NUMBER OF FITTINGS, AND FRICTION LOSS CAN BE DETERMINED.

THE PUMP WILL BE A 2,100 GPM, 140' HEAD END SUCTION.



PAGE M24-5

URN X (2)	138.2
URN X	(2)
FOTAL PRESSURE DROP INCLUDING RET	PRESSURE DROP INCLUDING RETURN X

G IOH	ო	320	4	40	<i>م</i>	3.4	a u	Ŧ	0		,	4			2
H TO BI DG 17EC	c	C LL T	2					-	†	4.0	-	2.X	2.8	59	2.4
	,		V	07	N	а. 4	6.8		9.4	0	2	2.8	5.6	32 4	4
H 10 BLDG 475D	~	160	2"	20	2	3.4	6.8		9.4	c	~	с С	и И И		
											1		0.0	92.4	- - -
ATOJ	ų	600	۳ ۳	610	-	5 7	1 03	ļ							
I TO BI DG AGE					<u> </u>		+. 00	-	10.0	8	-	3.2	3.2	699.6	28.0
	,	077	4	20	N	3.6	7.2		12.0	0	2	2.6	5.2	32.4	1.3
A D L	4	370	4"	190	თ	5.0	45		12.0	4 0	-	۲- ۲	+ C	1 0 2 0	
K TO BLDG 466	-	79		40	<u>م</u>	2	C F	-		! ‹	-		0	1.002	10.0
K TO I					1	2		-	n .0	٥	-	3.1	3.1	59.1	2.4
7 - C - C - C - C - C - C - C - C - C -	2	291	4	210	ი	5.0	45	-	6.6	6.6	-	1.6	+ e.	7 190	406
L 10 BLDG 450		82	5	80	2	3.4	6.8		6.0	c	0	0			2. r
LTOM	~	010	" V			4		4			4	0.7	0.0	32.4	3./
M TO DI DO 10	1		-		Ŧ	2.0	N V	7	12.0	24		а.1 .1	ю.1	147.1	5.9
M 10 DLDG 404	Э	3Z S		20	4	5.0	20	2	6.0	12	+	3 1	+ 6	<u></u> Е 4	0
MTON	2	180	* ~	100	4	5.0	00	~	99	0 0 0					7.7
N TO BI DG 463	c	01	- - -	00				4		10.5	-	<u>ي. ا</u>	с. 1	136.3	5.5
		J	4	2	ţ	0.0	2 U	N	0.0	12	-	з.1	з.1 .1	55.1	2.2
002	N	150	2"	50	4	5.0	50 50	2	6.6	13.2	÷	ب د	Ţ	0 0 0	
O TO BLDG 473		54	2"	20	4	50	00	6	90		- -			00.0	C.D
0 TO RI DG 472	-	0	= c	0					,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	y	-	<u>з. I</u>	G.1	55.1	2.2
	-	70	7	001	×	4.2	33.6	~	6.0	12	2	2.9	5.8	201.4	8
									-						

LARGE PRESSURE DROP PATH TOTAL 69.1

PUMP TO BOILER	21	2100	12"	06	10	~	70	ſ	0.00		6				
	6							<u>م</u>	Z4.U	2	٥	3.2	19.2	181.2	7.2
	-	2100	2	20	n	0./	21		24.0	24	2	3.2	6.4	111.4	4.5
A TO B	13	1330	10	200	6	5.7	51.3	-	18.0	4	-	00	0	7 020	
B TO BLDG 475E	5	530	±∞	20	~	4.2	8 4	·	10.0	2	- <	2.0	2.0 2.1	C.2.12	10.9
BTOC	a		- -		, c			ļ	2	-	J	۲.۲	Ω.Ω	34.2	1.4
C TO BI PC 17EF	•				v	4.2	8.4	-	12.0	12		2.9	2.9	473.3	18.9
0 10 BLUG 4/5F	N	160	۲ ۵	20	2	3.4	6.8		9.4	0	2	2.8	56	32 4	с Т
C TO D	9	630	- 80	40	2	4.2	8.4	-	12.0	6 -					- c
D TO BLDG 475G	2	160	2"	20	~	3.4	6.8		0 4	: -	- 0			00.00	0.7
DTOF	ч	007	= 4					Ţ		>	v	0. V	0.0	32.4	1.3
	۔ اد	400	•	4	N	4.2	8.4	-	12.0	12	-	2.9	2.9	63.3	о Л
E 10 BLDG 475H	5	160	5"	20	2	3.4	6.8		9.4	0	~	9		2.00	
ETOF	4	430	9	40	0	3 4	a g	ŀ	c	Ì	1		2	1.70	- ?
E TO BLIDG A7EA	-	r.c	, 2					-	t .n	4.6	-	2.8	2.8	59	2.4
	-	0		70	2	3.4	6.8		9.4	0	2	2.8	5.6	32.4	13
O G	4	360	4"	40	2	3.4	6.8		9.4	9.4	-	8			
G TO BLDG 475B	0	46	۳. م	20	2	3.4	6 A	T	V 0	6					i t
GTOH	e.	320			c			Ţ,			- -	0.1	0.0	32.4	1.3
					,	+ + +	0.0	-	4.9 	9.4	-	2.8	2.8	59	2.4
	N	091	N	20	2	3.4	6.8		9.4	0	6	о 8 С	л л Л	100	с т
H TO BLDG 475D	2	160	•••	20	2	3.4	6 8 1	ſ	0 A	6	10			1.10	<u>.</u>
							,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			>	4	0.7	٥.0 ا	32.4	1.3

ECO-M24

HEAD 4'/100'

VALVE FRCT/ VALVE TOTAL VALVE FRCT FEET

FIECT FIECT

FRCT/ TEE

Щ

FICT ELL

FRCT/ ELL

ΕĽ

FEET

PIPE

Mag

MILL BTUH

DESCRIPTION

PATH

HEATING HOT WATER PIPING WORKSHEET

PAGE M24-6

ENI INSTALLATION PROJECT NO. FISCAL YEAR 1 ANALYSIS DAT	ERGY CONSERVA & LOCATION: FC & TITLE: 1496 1990 DI	SCRETE PORTI	ENT DDOODAN	REGION NOS. 7 DM		IDY: USDBAE LCCID 1.035 CENSUS: 2 RB
B. SIOH C. DESIGN D. ENERGY E. SALVAG F. TOTAL IN	RUCTION COST COST Y CREDIT CALC (1 E VALUE COST NVESTMENT (1D-	1E)			\$ \$ \$ \$ \$ \$ \$	634367. 38062. 34890. 636587. 0. 636587.
ANALYSIS D	AVINGS (+) / COST DATE ANNUAL SAV	(-) /INGS, UNIT CC	ST & DISCOUN	ITED SAVINGS		
FUEL	UNIT COST \$/MBTU(1)		ANNUAL \$ SAVINGS(3	DISCOUNT		ISCOUNTED AVINGS(5)
A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	-836. 0. 0. 15300. 0.	\$-10400 \$0 \$0 \$62424 \$0	. 12.42 . 12.21 . 11.67		-90376. 0. 0. 728488. 0.
F. TOTAL		14464.	\$ 52024		\$	638112.
3. NON ENERG	Y SAVINGS(+) / C	OST(-)				
A. ANNUAL (1) DISCO	RECURRING (+/-) OUNT FACTOR (T/				\$	0.
(2) DISCO	OUNTED SAVING/	COST (3A X 3A	9.11		\$	0.
	ON ENERGY DISC			(3A2+3Bd4)	\$	0.
(1) 25% M A IF 3I B IF 3I C IF 3	「NON ENERGY QU MAX NON ENERGY D1 IS = OR > 3C GU D1 IS < 3C CALC SD1B IS = > 1 GO T D1B IS < 1 PROJEC	CALC (2F5_X D TO ITEM 4 SIR = (2F5+3D1 O ITFM 4	.33))/1F)=	\$ 210577.		
4. FIRST YEAR	DOLLAR SAVINGS	2F3+3A+(3B1D	(YEARS ECON		\$	52024.
	DISCOUNTED SAV			—,,	÷ \$	638112.
6. DISCOUNTED (IF < 1 PROJE	D SAVINGS RATIO ECT DOES NOT QU	JALIFY)	(SIR)=(5 / 1F	r)= 1.00		
7. SIMPLE PAYE	BACK PERIOD (ES	TIMATED) SP	B=1F/4	12.24		



ECO-M24

.

J

CONSTRUCTION COST ESTIMATE			DATE PR		4/30/90)	SHEET OF
PROJECT USDB ENERGY STUDY				BASIS FOR	ESTIMATE		
FORT LEAVENWORTH KS				X		(NO DESIGN (PRELIMINAR	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	JP				_CODE C	(FINAL DESIG	N)
DRAWING NO. NONE		ESTIM	ATOR	<u>ا</u>	UTHER (SPECIFY)	Y
ECO-M10	QL	I	M	<u>RGB</u> ATERIAL	<u>r</u>	ABOR	MAW
CENTRAL PLANT COOLING	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	TOTAL COST
15,000 MBTU HOT WATER BOILER		BEA	45500.00	\$136,500	10000.00	\$30,000	\$166,
BOILER START UP		BEA			3000.00	\$9,000	\$9,
2100 GPM PUMP, 140' HEAD @75 hp		EA	3300.00	\$6,600	780.00		\$8,
12" BLACK STEEL PIPE, HANGERS, INSUL-	160	FT	31.10	\$4,976	40.25	\$6,440	\$11,
10" BLACK STEEL PIPE, HANGERS, INSUL-	1300	FT	26.20	\$34,060	28.12	\$36,556	\$70,
8" BLACK STEEL PIPE, HANGERS, INSUL	1340	FT	18.18	\$24,361	22.17	\$29,708	\$70, \$54.
4" BLACK STEEL PIPE, HANGERS, INSUL~	1360	FT	12.20	\$16,592	18.19	\$24,738	\$41,
2* BLACK STEEL PIPE, HANGERS, INSUL ~	400	FT	8.60	\$3,440	10.25	\$4,100	<u> </u>
12" BLACK STEEL ELL	13	EA	120.00	\$1,560	210.00	\$2,730	<u> </u>
10" BLACK STEEL ELL	14	EA	80.00	\$1,120	160.00	\$2,240	\$3,
3" BLACK STEEL ELL	13	EA	66.00	\$858	135.00	\$1,755	\$2,6
BLACK STEEL ELL	10	EA	26.00	\$260	45.00	\$450	<u>\$7</u>
P BLACK STEEL ELL	10	EA	15.00	\$150	25.00	\$250	\$4
2" BLACK STEEL TEE	1	EA	150.00	\$150	290.00	\$290	¥\$4
0" BLACK STEEL TEE	1	EA	132.00	\$132	260.00	\$260	\$3
* BLACK STEEL TEE	3	EA	91.00	\$273	220.00	\$660	\$9
" BLACK STEEL TEE	3	EA	50.00	\$150	185.00	\$555	\$7
" BLACK STEEL TEE	3	EA	27.00	\$81	115.00	\$345	\$4
0" BUTTERFLY VALVE	4		200.00	\$800	120.00	\$480	\$1,2
BUTTERFLY VALVE	2	EA	140.00	\$280	110.00	\$220	\$5
GATE VALVE	10	EA	105.00	\$1,050	27.00	\$270	\$1,3
NG. FORM 150							
IG. FORM 150 VC-59							



Ð

CONSTRUCTION COST ESTIMATE			DATE PR	EPARED	4/30/90)	SHEET OF
PROJECT			1	BASIS FOR E			2 2
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS				x		(NO DESIGN ((PRELIMINAR)	
ARCHITECT/ENGINEER CLARK RICHARDSON & BISK					CODE C	(FINAL DESIG	N)
DRAWING NO.		ESTIM	ATOR	I	OTHER (SPECIFY)	Y
NONE ECO-M10		ANTITY	M	RGB ATERIAL	<u>г</u>	ABOR	MAW TOTAL
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDINGS 475C, D, F, G STEAM COIL REPLACEMENT	8	EA	1750.00	\$14,000	435.00	\$3,480	\$17,48
BUILDINGS 475C,D,F,G STEAM COIL DEMOLITION		EA			395.00		\$3,16
EXISTITING CONDENSATE LINE							······································
DEMOLITION PARTIAL EXISTING STEAM PIPE	2400	LF			6.60	\$15,840	\$15,84
DEMOLITION	1000	LF			6.60	\$6,600	\$6,60
	-						
							,
							· · · · · · · · · · · · · · · · · · ·
SUBTOTAL	$\left - \right $	-+					
CONTINGENCY 10%	┟──┼			\$247,393		\$181,687	\$429,080
SUBTOTAL			10%	\$24,739	10%	\$18,169	\$42,908
NORK COMP, TAX, SOC.SEC., INS			3.50%	\$272,132 \$9,525	13.0%	\$199,856	\$471,988
DIRECT COST			2.0070	\$281,657	10.0%	\$25,981 \$225,837	\$35,506
OVERHEAD AND PROFIT			25%	\$70,414	25%	\$56,459	\$126,873
SUBTOTAL				\$352,071		\$282,296	\$634,367
CONSTRUCTION COST							\$634,367

1AVC-59



ECO-M25

CONVERT FROM STEAM TO COGENERATION

COGENERATION POTENTIAL AT THE USDB

ENERGY CONSERVATION OPPORTUNITY: ECO-25

PURPOSE:

This ECO was investigated to determine the potential cost savings provided by a natural gas cogeneration system. Cogeneration is the practice of generating electricity on-site with an engine-generator set, and recovering the heat from the engine to produce steam or hot water. The steam is used for heating, or processes. At the USDB, those processes are the laundry and kitchen facilities.

SCOPE:

An analysis of the economics of a cogeneration system requiring investigation of, system configuration, fuel prices, financing, fuel availability, and energy requirements. Because of the large capital investment, (0.5 to 5 million dollars) and the impact of operating costs, a very detailed analysis must be performed before funding is considered. The scope of this study is to determine if the investment in a complete cogeneration feasibility study is justified. The cogeneration system would provide electricity for the entire Disciplinary Barracks. The system would be located in the existing boiler plant and be tied into the existing steam system.

CONSIDERATIONS:

In most cases, the feasibility of cogeneration depends on the facility electrical and thermal loads, and how they interrelate. This is especially true when the cost of both electricity and gas are moderate, as they are at the USDB. A natural gas fired system was the only system considered because of the low cost of gas compared to fuel oil or coal in this region.

The thermal load is much greater than the electrical load. A gas turbine cogeneration system would have the most desirable thermal to electrical output for this load situation. A gas turbine would be capable of generating the high pressure steam required at the USDB and providing all of the electricity for the USDB and some additional for the main Post.

Another approach would be to install a gas reciprocating engine cogeneration system. This type of system has a high electrical output compared to thermal load, but the excess power can be absorbed by the grid serving the rest of the Post. The main drawback of the reciprocating engine systems is that the majority of the thermal output is in engine jacket heat. This temperature is usually around 350°F, which results in either high temperature hot water or low pressure 15 psig steam. Because all of the steam generated at the USDB is 120 psig, there is no real use for the steam generated.

PAGE M25-1

Because the main Post is capable of using excess electricity, the major obstacle to an efficient cogeneration operation at the USDB is the variability of the thermal load. The base load that operates year-round is the laundry facility, which only operates 8 to 10 hours during the day. In the summer, the steam load drops to almost nothing at night. The most efficient system offering the best return on investment would be a cogeneration system tied into a central plant with absorption chillers using the waste heat for cooling purposes.

Table M25-1 indicates the energy use analysis for a gas turbine engine cogeneration system installed at the USDB. The system is base loaded to provide steam to the laundry facility during the day during summer and winter, and space heating during night in the winter. The KW size of the unit was changed up and down to maximize savings. An 800 KW provides the most energy savings. A Payback Analysis shown below.

PAYBACK ANALYSIS:

Assumptions

Electrical Requirements Capital Investment (\$1500/KW) Hours of Operation Natural Gas Costs Electricity Cost from Grid Heat Rate	800 KW \$1.2 Million 6570 Hours \$4.08/MBTU 4.25¢/KWH 14,000 BTU/KWH
neal hale	14,000 DTO/RWIT

Economic Analysis

Cost Item	IS		<u>Savings</u>	
Fuel O&M	\$282,950 \$20,867		Elec. Savings Thermal Savings	\$136,435 \$224,519
Total	\$303,816		Total	\$361,954
Net Savir	ngs Per Year	\$58,138		
Simple P	ayback:	21 years		

	Cogen. Elec.	Energy	Used	Kwh	595200	322560	357120	172800	178560	172800	178560	178560	172800	178560	345600	357120	3210240	
	Cogen. Theil	Energy		MBTU	5000	4516	5000	2419	2418	2250	2387	2387	2340	2449	4838	5000	41003	
	Cogen. Therm Cogen. The Cogen. Elec	Energy	ble	MBTU	5000	4516	5000	2419	2500	2419	2500	2500	2419	2500	4838	5000		\$136,435 \$225,519 \$361,954
	USDB (C	Electical	Load Kwh	4	265000	237000	270000	240000	240000	340000	384000	374000	280000	223000	240000	250000		Elec. Saved Steam Saved Total Saved
	USDB	Thermal	Load MBTU		10478	9520	9300	4500	2418	2250	2387	2387	2340	2449	6300	12028		
		Hrs/Month	Operation		744	672	744	360	372	360	372	372	360	372	720	744	6192	\$282,950 \$20,867 \$303,816
14000 Btu/Kwh 800 KW 60% \$4.08 MBTU \$5.50 MBTU 0.0425 Kwh		Days/	Month		31	28	31	30	31	30	31	31	30	31	30	31		tion Unit. 0.0065 per Kwh
÷		Hrs/Day	Operation		24	24	24	12	12	12	12	12	12	12	24	24		eneration Un 0.0065 cost
Heat Rate Cogen Size Eff. Stm Prod Cost of Fuel Cost of Exist Stm Cost of Exist Elec					January	February	March	April	May	June	July	August	September	October	November	December		Fuel Cost of Cogeneration Unit. O&M Cost = 0.0065 p Total Operating Cost

I

TABLE M25-1

\$58,138 per year

Dollar Savings Per year

PAGE M25-3

ECO-M26

REDUCE HOT WATER TEMPERATURE

REDUCE HOT WATER TEMPERATURE

ENERGY CONSERVATION OPPORTUNITY: ECO-M26

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M26) analyzes the energy savings associated with reduction of the domestic hot water temperature. The implementation of this project will not change the number or capacity of any of the hot water heating equipment.

SCOPE:

The ECO simulation (ECO-M26) makes changes only to the temperature setpoint of the existing hot water heaters and does not encompass any modification or replacement of any existing equipment. The application of this project was considered for the following buildings and their connecting tunnel:

Building	450	Building	475
Building	463	Building	475A
Building	464	Building	475C
Building	465	Building	475D
Building	466	Building	475E
Building	472	Building	475F
Building	473	Building	475G

MODELING TECHNIQUES:

The modeling techniques used to calculate the energy savings for ECO-M26 were derived from "Guidelines for Saving Energy in Existing Buildings." The domestic hot water temperatures for the above buildings were found to range between 170° and 185°. ASPE suggests a domestic hot water temperature of around 140°. Trends to reduce hot water temperature between 110° and 120° have been stopped because these temperatures have been linked to the proliferation of Legionnaires' Disease. An energy savings can be seen by reducing the domestic hot water temperature. Tables M26-1a and M26-1b show the BTUH loss per lineal foot of pipe for different water temperature of 140° to show the energy savings on a per lineal foot bases. The lineal feet of pipe for each building was field estimated to calculate the total possible energy savings in line losses because of reduced hot water temperature.





Domestic water within the USDB is always mixed to a using temperature of under 140°. The equation for mixed water temperature is:

 $t_m = (Q_1 \times t_1) + (Q_2 \times t_2) / Q_1 + Q_2$

 t_m = temperature of the mixture t1 = temperature of flow Q1 t2 = temperature of flow Q2

Using a constant (tm) and (t₂) and comparing a range of hot water temperatures (t₁) to the existing hot water temperature it can be seen that as the hot water temperature drops the flow of hot water increases while the cold water flow decreases. The energy usage stays the same because of the energy savings of not having to heat the water to as high a temperature is offset by the fact that more hot water is used. Actual calculations are shown in Table M26-3.

ECO IMPLEMENTATION:

The implementation of this ECO consists of having the USDB maintenance staff change the setpoint for all the hot water heaters within the DB to 140°. This will show an energy savings with no cost to the USDB.

SUMMARY:

Reducing the Domestic Hot Water from 180° to 140° will reduce the amount of heat energy radiating from the hot water piping to its surroundings. The reduction in temperature will also decrease the total capacity of the hot water system. This may cause problems which would call for added capacity or the return to a higher temperature. ECO-M30 also reduces radiation loss in domestic hot water piping by insulating all bare pipe within the USDB. If M30 is implemented it will reduce the effectiveness of this ECO. ECO-M26 does not effect the amount of heat energy consumption at the point of use.

Location	Cost Savings	Project Cost of Construction		
475	\$92	\$0		
Castle Domiciles	\$210	\$0		
475E	\$134	\$0		
Tunnels	\$299	\$0		



		TION SHE	6 I		DATE Mar-90	SHEET	OF
ROJECT	USDB				BASIS FOR CA	LCULATION	
OCATION	ENERGY	SAVINGS	DPPORTUN	TY SURVEY	XHAN	П	
DOUITEOT	NOWERS			· · · · · · · · · · · · · · · · · · ·	CON	IPUTER	
RCHITECT/I		CHARDSO	N & BISKUP	1		TRACTOR BID	
COMEASURE				COMPUTED BY	HER (SPECIFY) CHECKED		
	ECO-M26	······································			RGB		<u>M</u> /
TEST DAT	A, BTUH LOS	S PER LIN	IEAL FOOT				
REF: Guidi	lines for Savin	a Enerav in	n Existing Bu	ildings			
	ergy Administ	ration Omc	e of Energy	Conservation and	Environment		
Tables wer	e developed fi	rom fig. 44	of the Guidli	nes for Saving En	ergy in Existing Building	8	
					sigy in Existing Building	5	
BTUH Los	emperature 6 s per lineal for	8° F at of hare n	ino				
		st of bare p	,hc				
Bare Pipe Pipe	180°	160°	140°	1000			
Size	Water	Water	Water	120° Water			
3/4"	85	70	55	39			
1"	105	85	66	46			
1-1/4*	126	104	81	<u>40</u> 57			
1-1/2"	150	121	95				
2"	171	140		67			
2-1/2"	205		110	80			
2-112	205	169	133	94			
Table M26-1	a						
	-						
Ambient Te	mperature 68	3° F					
BTUH Loss	per lineal foo	t of insulate	ed pipe				
	ass Insulation						
1/2" Fiberala Pipe	ass Insulation 180°	160°	140°	120°			
1/2" Fibergla Pipe Size	180° Water	160° Water	Water	Water			
1/2" Fibergla Pipe Size 3/4"	180° Water 20	160° Water 15	Water 11	Water 8			
1/2" Fibergla Pipe Size 3/4" 1"	180° Water 20 21	160° Water 15 17	Water 11 12	Water 8 9			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4"	180° Water 20 21 26	160° Water 15 17 20	Water 11 12 16	Water 8 9 11			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2"	180° Water 20 21 26 30	160° Water 15 17 20 24	Water 11 12 16 19	Water 8 9 11 13			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2"	180° Water 20 21 26 30 36	160° Water 15 17 20 24 30	Water 11 12 16 19 23	Water 8 9 11 13 15			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2"	180° Water 20 21 26 30	160° Water 15 17 20 24	Water 11 12 16 19	Water 8 9 11 13			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2" 2-1/2"	180° Water 20 21 26 30 36 45	160° Water 15 17 20 24 30	Water 11 12 16 19 23	Water 8 9 11 13 15			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2"	180° Water 20 21 26 30 36 45	160° Water 15 17 20 24 30	Water 11 12 16 19 23	Water 8 9 11 13 15			
1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2" 2-1/2"	180° Water 20 21 26 30 36 45	160° Water 15 17 20 24 30	Water 11 12 16 19 23	Water 8 9 11 13 15			

	0/12002/	ATION SHE	E1			DATE Mar-90	3	HEET	0F
ROJECT	USDB	CAV/1000 0				BASIS FOR	CALCU		
OCATION	ENERGY	SAVINGS C	PPORIUN	ITY SURVE	Y	хн	AND		
	NONCER		······			c	OMPUT		
RCHITECT/E		CHARDSO	N & BISKUP)		C		CTOR BID	n
CO MEASUR	E					COMPUTED	BY	CHECKED	
	ECO-M26					I R	GB		<u>M/</u>
REF: Guidli	A, BTUH LOS nes for Savir	na Enerav in	Existing Bu	uildinas					
Federal Ene	ergy Adminis	tration Office	e of Energy	Conservatio	n and Enviro	onment			
T -1-1	. .								
l ables were	e developed	from fig. 44	of the Guidli	ines for Savi	ng Energy ir	n Existing Build	lings		
Ambient Te	mperature (68° F							
BTUH Loss	per lineal fo	ot of bare p	ipe						
Bare Pipe									
Pipe Size	Btuh loss @ 180°	Btuh loss @ 140°	Btuh Savings	Hours per					
3/4*	85	55	30	<u>Year</u> 4380	per L.F. \$0.70				
3/4			+	1	U				
<u> </u>	1	66	39	4380	\$0.01				
	105 126	66 81	<u>39</u> 45	4380 4380	\$0.91 \$1.05				
1"	105	81	45	4380	\$1.05				
<u>1"</u> <u>1-1/4"</u>	105 126	81 95	45 55	4380 4380	\$1.05 \$1.29				
1" 1-1/4" 1-1/2" 2"	105 126 150 171	81 95 110	45 55 61	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2"	105 126 150	81 95	45 55	4380 4380	\$1.05 \$1.29				
1" 1-1/4" 1-1/2" 2"	105 126 150 171 205	81 95 110	45 55 61	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2"	105 126 150 171 205	81 95 110	45 55 61	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2"	105 126 150 171 205	81 95 110	45 55 61	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter	105 126 150 171 205 a	81 95 110 133 8° F	45 55 61 72	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2"	105 126 150 171 205 a	81 95 110 133 8° F	45 55 61 72	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ten BTUH Loss	105 126 150 171 205 a nperature 6 per lineal for	81 95 110 133 8° F ot of insulate	45 55 61 72	4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe	105 126 150 171 205 a nperature 6 per lineal for ss Insulation Btuh loss	81 95 110 133 8° F ot of insulate Btuh loss	45 55 61 72 ed pipe Btuh	4380 4380 4380 4380	\$1.05 \$1.29 \$1.43				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size	105 126 150 171 205 a a nperature 6 per lineal for ss Insulation Btuh loss @ 180°	81 95 110 133 8° F Dt of insulate Btuh loss @ 140°	45 55 61 72 ed pipe	4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4"	105 126 150 171 205 a nperature 6 per lineal for ss Insulation Btuh loss	81 95 110 133 8° F ot of insulate Btuh loss	45 55 61 72 ed pipe Btuh	4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size	105 126 150 171 205 a a nperature 6 per lineal for ss Insulation Btuh loss @ 180°	81 95 110 133 8° F Dt of insulate Btuh loss @ 140°	45 55 61 72 ed pipe Btuh Savings	4380 4380 4380 4380 Hours per Year	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$Savings per L.F.				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4"	105 126 150 171 205 a nperature 6 per lineal for ss Insulation Btuh loss @ 180° 20	81 95 110 133 8° F 5t of insulate Btuh loss @ 140° 15	45 55 61 72 ed pipe Btuh Savings 5	4380 4380 4380 4380 Hours per Year 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4" 1"	105 126 150 171 205 a nperature 6 per lineal for ss Insulation Btuh loss @ 180° 20 22	81 95 110 133 8° F 5t of insulate Btuh loss @ 140° 15 17	45 55 61 72 ed pipe Btuh Savings 5 5	4380 4380 4380 4380 4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$1.68 \$0.12 \$0.12 \$0.12				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4" 1" 1-1/4"	105 126 150 171 205 a nperature 6 per lineal for Stuh loss @ 180° 20 22 26	81 95 110 133 8° F 5t of insulate Btuh loss @ 140° 15 17 20	45 55 61 72 8d pipe 8tuh Savings 5 5 6	4380 4380 4380 4380 4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68 \$1.68 \$1.05 \$1.2 \$0.12 \$0.12 \$0.14				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2"	105 126 150 171 205 a nperature 6 per lineal for ss Insulation Btuh loss @ 180° 20 22 26 30	81 95 110 133 8° F 5t of insulate Btuh loss @ 140° 15 17 20 24	45 55 61 72 ed pipe Btuh Savings 5 5 6 6	4380 4380 4380 4380 4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$1.68 \$0.12 \$0.12 \$0.12 \$0.12 \$0.14 \$0.14				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2"	105 126 150 171 205 a nperature 6 per lineal for Stuh loss @ 180° 20 22 26 30 36	81 95 110 133 8° F ot of insulate Btuh loss @ 140° 15 17 20 24 30	45 55 61 72 2 2 3 3 5 5 5 6 6 6 6 6	4380 4380 4380 4380 4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$1.68 \$0.12 \$0.12 \$0.12 \$0.12 \$0.14 \$0.14				
1" 1-1/4" 1-1/2" 2" 2-1/2" Table M26-2 Ambient Ter BTUH Loss 1/2" Fibergla Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2"	105 126 150 171 205 a nperature 6 per lineal for ss Insulation Btuh loss @ 180° 20 22 26 30 36 45	81 95 110 133 8° F ot of insulate Btuh loss @ 140° 15 17 20 24 30	45 55 61 72 2 2 3 3 5 5 5 6 6 6 6 6	4380 4380 4380 4380 4380 4380 4380 4380	\$1.05 \$1.29 \$1.43 \$1.68 \$1.68 \$1.68 \$0.12 \$0.12 \$0.12 \$0.12 \$0.14 \$0.14				

		CALCULATION SHEET	DATE	SHEET OF
	DDO IFOT	1000	Mar-90	3 5
	PROJECT	USDB ENERGY SAVINGS OPPORTUNITY SURVEY	BASIS FOR CALCUL	ATION
J	LOCATION		X HAND	
	ARCHITECT/E	NGINEER		
		CLARK RICHARDSON & BISKUP		(SPECIFY)
	ECO MEASUF		COMPUTED BY	CHECKED BY
		ECO-M26	RGB	MAW

REDUCED DOMESTIC HOT WATER TEMPERATURE

Tm= (Q1*T1) +(Q2*T2) / (Q1+Q2)

Assumption: Tm =110 T1= 40° T2= X

Tm	= mixed	water	tempera	iture	
T1=	tempera	ture of	fl (Cold	Water	Temp.)

Tm (°)	T1 (°)	Q1 (Gal.)	T2 (°)	Q2 (Gal.)
110.00	40.00	68.18	180.00	31.82
110.00	40.00	66.67	170.00	33.33
110.00	40.00	65.00	160.00	35.00
110.00	40.00	63.16	150.00	36.84
110.00	40.00	61.11	140.00	38.89
110.00	40.00	58.82	130.00	41.18
110.00	40.00	56.25	120.00	43.75
Table M26-2				

Table M26-3





		CALCUL	ATION SHE	ET		DATE Mar-90	SHEET OF
PROJ	ECT	USDB	0.0.000.000			BASIS FOR CA	4 5 ALCULATION
OCA	TION	ENERGY	SAVINGS C	PPORTUN	ITY SURVEY	Х на	
DOL							MPUTER
ARCH	IIECI/E		ICHARDSON	A & DICKI	3		NTRACTOR BID
CON	IEASUR	1E			······································		THER (SPECIFY) Y CHECKED BY
		ECO-M26				RGI	
RE Fea	F: Guidli Jeral Ene		ng Energy in stration Office	Existing Bu of Energy	Conservation and E	invironment	
Len <u>Buil</u>	igth of pi		oles M26-2a d from field ir	and M26-2t hspection ar) Id plans.		
	Pipe Size	Feet of Bare Pipe	\$ Savings per Ft.	Feet of Insulated	\$ Savings per FT.	\$ Savings Year	
	3/4"		\$0.70		\$0.12	\$0	
	_1"		\$0.91		\$0.12	\$0	
	1-1/4"	60	\$1.05		\$0.14	\$63	
	1-1/2"	20	\$1.29	20	\$0.14	\$29	
	2"		\$1.29		\$0.14	\$0	
					Energy Savings =	\$92.00	
Build	dings 47	<u>5C ,475D, 47</u>	75F, 475G				
	Pipe Size	Feet of Bare Pipe	\$ Savings per Ft.	Feet of Insulated	\$ Savings per FT.	\$ Savings	
	3/4"		\$0.70	moundled	\$0.23	Year	
	1"		\$0.91			\$0	
1	-1/4"	200	\$1.05	0	\$0.23	\$0	
	-1/2"		\$1.29	U	\$0.28	\$210	
<u> </u>	2"		\$1.29		\$0.28	\$0	
<u> </u>			<u>φ1.23</u>		\$0.28	\$0	
		<u>_</u>	<u>I</u>		Energy Savings =	\$210.00	



PROJECT	CALCULA	ATION SHEE	:T		DATE		SHEET	0F
HOULUI	USDB				Mar-90 BASIS FOI			5
OCATION	ENERGY	<u>SAVINGS O</u>	PPORTUNI	TY SURVEY				
.OCATION					X	HAND COMPUT	'ED	
ARCHITECT/E				· · · · · · · · · · · · · · · · · · ·				
	CLARK RI	CHARDSON	& BISKUP		001404175	OTHER	(SPECIFY	
	ECO-M26				COMPUTE	RGB	CHECKE	D BY MAW
REF: Guidi Federal En Tables deri	A, BTUH LOS lines for Savir ergy Adminis ived from Tab lipe estimated	ng Energy in tration Office ples M26-2a a	Existing Bu of Energy (and M26-2b	Conservation and I	Environment			
Building 47								
Size	Bare Pipe	\$ Savings per Ft.	Feet of Insulated	\$ Savings per FT.	\$ Savings Year			
3/4"		\$0.70		\$0.12	\$0			
1"		\$0.91		\$0.12	\$0			
1-1/4"	100	\$1.05		\$0.14	\$105			
1-1/2"	20	\$1.29	20	\$0.14	\$29			
2"		\$1.29		\$0.14	\$0			
				\$0 1				
				Energy Savings =	\$134.00			
Size	ween building Feet of Bare Pipe	9 468, 466, 4 \$ Savings per Ft.	67, 463, 46 Feet of Insulated	4, 472, 473 \$ Savings per FT.	\$ Savings Year			
Pipe Size 3/4"	Feet of	\$ Savings	Feet of	\$ Savings				
Size	Feet of	\$ Savings per Ft.	Feet of	\$ Savings per FT.	Year		·	
Size	Feet of	\$ Savings per Ft. \$0.70	Feet of Insulated	\$ Savings per FT. \$0.23	Year \$0			
Pipe <u>Size</u> <u>3/4"</u> 1"	Feet of Bare Pipe	\$ Savings per Ft. \$0.70 \$0.91	Feet of Insulated 180	\$ Savings per FT. \$0.23 \$0.23	Year \$0 \$41 \$88			
Pipe Size 3/4" 1" 1-1/4"	Feet of Bare Pipe	\$ Savings per Ft. \$0.70 \$0.91 \$1.05	Feet of Insulated 180 90	\$ Savings per FT. \$0.23 \$0.23 \$0.23	Year \$0 \$41 \$88 \$170			
Pipe Size 3/4" 1" 1-1/4" 1-1/2"	Feet of Bare Pipe	\$ Savings per Ft. \$0.70 \$0.91 \$1.05 \$1.29	Feet of Insulated 180 90	\$ Savings per FT. \$0.23 \$0.23 \$0.28 \$0.28	Year \$0 \$41 \$88			



ECO-M29

.

DECENTRALIZE HOT WATER SYSTEM



DECENTRALIZE HOT WATER SYSTEM

ENERGY CONSERVATION OPPORTUNITY: ECO-M29

PURPOSE:

The purpose of ECO-M29 is to analyze the energy savings associated with decentralizing the hot water heating system. A central system involves additional branch piping which is a source of heat loss. As hot water sits in the branch piping its temperature is reduced below its desired level. When hot water is needed the faucet is turned on and let run until the water increases to its desired temperature. This waste of water is reduced in a decentralized hot water system due to the fact that the hot water heater is located closer to the point of use. Decentralization of the domestic hot water system will eliminate all connecting hot water piping and the energy loss associated with it.

SCOPE:

ECO-M29 involves removal of the existing central domestic hot water heater located in building 468 and serving buildings 450, 463, 464, 466, 467, 468, 472, and 473. These building will be supplied by individual hot water heaters located in each building:

Building	450	Building	467
Building	463	Building	468
Building	464	Building	472
Building	466	Building	473

New hot water heat exchangers will be connected to the existing steam lines routed through each building. Buildings 450, 463, 473, and 472 have low hot water usage so small electric instantaneous hot water heaters were used. These units are placed at the point of use and only require energy when hot water is being used. The Castle buildings already have individual hot water heat exchangers so they were not applicable for this ECO.

MODELING TECHNIQUES:

The energy loss through branch piping was calculated in Table M29-2. The total gallons of wasted hot water was estimated in Table M29-3 and converted to dollars per year. The sum of these two calculations total the energy savings associated with ECO-M29. A cost estimate for ECO-M29 was prepared using Manufactures Data along with Means Plumbing Cost Data. The cost estimate was prepared per building, but the yearly savings is estimated on a system wide bases. Because of this, Table M29-1 compares the total cost to the total energy savings for this ECO.



ECO IMPLEMENTATION:

The Implementation of ECO-M29 includes the removal of the central hot water system located in building 468. Installation of new hot water heaters are as follows:

Building 450	4-Instantaneous Point of Use Hot Water Heaters
Building 463	5-Instantaneous Point of Use Hot Water Heaters
Building 464	Steam to Hot Water Heat Exchanger
Building 466	Steam to Hot Water Heat Exchanger
Building 467	2-Instantaneous Point of Use Hot Water Heaters
Building 468	Steam to Hot Water Heat Exchanger
Building 472	5-Instantaneous Point of Use Hot Water Heaters
Building 473	5-Instantaneous Point of Use Hot Water Heaters



SUMMARY:

The probable construction cost to implement this ECO is shown in Table M29-1. This project cost is the construction cost as determined on the ECO-M24 Cost Estimate Sheet.

The energy savings associated with the implementation of this ECO by building is shown below in Table M29-1 on a dollars per year savings as determined on ECO-M24 Calculation Sheet. This project cost is the construction cost plus 6% SIOH.

ECO-M24	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
Hot Water System	243	\$1,296	\$20,740	19.85	.59

Table M29-1

.



		TION SHEE	1			DATE Mar-90)	SHEET OF
ROJECT	USDB	0.0.000.00				BASIS FO	R CALCUL	
OCATION	ENERGY	SAVINGS OI	PORTUNI	IY SURVEY	/	x	HAND	
DAUTEAT					·····			
RCHITECT/EI		CHARDSON	& BISKUP					TOR BID (SPECIFY)
CO MEASUR	E		<u>a biortor</u>			COMPUTE		CHECKED B
	ECO-M30			T		L	RGB	MA
REF: Guidlin	nes for Savir	SS PER LINE ng Energy in tration Office	Existina Bui	ildings Conservatio	n and Enviro	nment		
Ambient Ter	nperature (om fig. 44 of t 58° F nperature 1		s for Saving	Energy in E	xisting Build	ings	
Pipe Size	Feet of Bare Pipe	BTUH Loss Bare Pipe	Feet of Insulated	BTUH Loss	Total BTUH Loss	Hours per Year	\$ Savings per Year	
3/4"	0	85	0	19	0	8760	\$0	
1"	15	105	75	23	3300	8760	\$154	
1-1/4"	15	126	75	26	3840	8760	\$180	
1-1/2"	25	150	330	31	13980	8760	\$654	-
			· · · · ·					
Table M29-2								ł
					Energy Savi	ngs =	\$988.00	
Gallons of H Estimated th BTU =Gallor	at entire line Is x 8.33 x 1	s are evacua 40°	•	-				
Pipe Size	Feet of Pipe	Gal. per Ft. of Pipe	Total Gal. per Day	Total Gal. per Year	Total MBTU per Year	Total \$ per Year		
3/4"	800	0.023	36.8	13432	15.66	\$84		
	180	0.04	14.4	5256	6.13	\$33		
1"	and the second se				4.83	\$26		
<u>1"</u> <u>1-1/4"</u>	90	0.063	11.34	4 39 1	9.(X) I			
	90 355	0.063 0.102	<u>11.34</u> 72.42	4139 26433				
<u>1-1/4"</u> 1-1/2"			<u>11.34</u> 72.42	26433	30.82	\$165		
1-1/4"				26433		\$165	\$308.00	
<u>1-1/4"</u> <u>1-1/2"</u>				26433	30.82	\$165 ngs =	\$308.00 \$1,296	

F	ENE NSTALLATION PROJECT NO. 8 ISCAL YEAR 1 NALYSIS DAT	ERG` & L(& TIT 990	LE: 1496 DIS	TION INVES RT LEAVEN SCRETE PC	STMENT PF WORTH - DRTION NA	ROGRAM (E	310N NOS. 7	ł	DY: USDBAE CCID 1.035 CENSUS: 2
1	E. SALVAG	UCT COS CRI E VA	T EDIT CALC (1		(.9			\$ \$ \$ \$ \$ • \$ \$	19599. 1176. 1078. 19668. 0. 19668.
2.	ENERGY SA ANALYSIS D		GS (+) / COST ANNUAL SAV	(-) /INGS, UNIT	r cost & e	ISCOUNTEI	D SAVINGS		
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR	• •	NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 243. 0.	\$ \$ \$	0. 0. 991. 0.	8.69 12.42 12.21 11.67 10.36		0. 0. 0. 11565. 0.
	F. TOTAL			243.	\$	991.		\$	11565.
3.	NON ENERG	iy sa	VINGS(+) / C	OST(-)					
	A. ANNUAL (1) DISCO	REC	URRING (+/-) T FACTOR (TA			9.11		\$	0.
	(2) DISCO	DUN.	TED SAVING/	COST (3A >	K 3A1)	9.11		\$	0.
	C. TOTAL NO	ON E	NERGY DISC	OUNTED SA	AVINGS(+)	/COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% M A IF 3I B IF 3I C IF 3	IAX D1 S D1 S D1 S	N ENERGY Q(NON ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T IS < 1 PROJE(′ CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1F)=		\$ 3816.		
4.	FIRST YEAR	DOL	LAR SAVINGS	6 2F3+3A+(3	BB1D/(YEA	RS ECONON	1IC LIFE))	\$	991.
5.	TOTAL NET							\$	11565.
6.	DISCOUNTED (IF < 1 PROJE	D SA' ECT I	VINGS RATIO DOES NOT QU	JALIFY)	(SII	R)=(5 / 1F)=	0.59		
7.	SIMPLE PAYE	BACK	PERIOD (ES	TIMATED)	SPB=1F/4	1	19.85		



4

Ŋ

CONSTRUCTION COST ESTIMA			DATE PREPARED Mar-90				SHEET OF
PROJECT USDB ENERGY STUDY				BASIS FOR E		, 	1
FORT LEAVENWORTH, KS				x	CODE E	3 (PRELIMINA	N COMPLETED) ARY DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	D				CODE	C (FINAL DES	IGN)
DRAWING NO.	F	ESTIM	ATOR	l	OTHER	(SPECIFY) CHECKED B	Y
NONE STEAM TO HOT WATER HEAT EXCHANGES	011	ANTITY	RGB	ATERIAL		ABOR	MAW TOTAL
AND INSTANTANEOUS ELECTRIC HOT WATER HEATERS	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
BUILDING 450							
INSTANTANEOUS HOT WATER HEATER	4	EA	\$145	\$580	\$120	\$480	\$1,0
BUILDING 463							
INSTANTANEOUS HOT WATER HEATER	5	EA	\$145	\$725	\$120	\$600	\$1,3
BUILDING 464							
STEAM TO HOT WATER HEAT EXCHANGER	1	EA	\$1,100	\$1,100	\$168	\$168	\$1,26
CONTROL VALVES, THERMOMETER, ECT.	1	EA	\$670	\$670	\$240	\$240	\$91
BUILDING 466							
STEAM TO HOT WATER HEAT EXCHANGER	1	EA	\$2,150	\$2,150	\$670	\$670	\$2,82
CONTROL VALVES, THERMOMETER, ECT.	1	EA	\$890	\$890	\$310	\$310	\$1,20
BUILDING 467							
NSTANTANEOUS HOT WATER HEATER	2	EA	\$145	\$290	\$120	\$240	\$53
BUILDING 468							
STEAM TO HOT WATER HEAT EXCHANGER	1	EA	\$700	\$700	\$134	\$134	\$83
CONTROL VALVES, THERMOMETER, ECT.	1	EA	\$520	\$520	\$260	\$260	\$78
BUILDING 472							
NSTANTANEOUS HOT WATER HEATER	5	EA	\$145	\$725	\$120	\$600	\$1,32
BUILDING 473							
NSTANTANEOUS HOT WATER HEATER	5	EA	\$145	\$725	\$120	\$600	\$1,32
SUBTOTAL				\$9,075		\$4 202	¢10.07
CONTINGENCY 10%			10%	\$9,073	10%	<u>\$4,302</u> \$430	\$13,37
SUBTOTAL				\$9,983	10 /8	\$4,732	\$1,33
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$349	13.0%	\$615	\$14,71 \$96
DIRECT COST			2.00/0	\$10,332	10.0 /8	\$5,347	\$964
VERHEAD AND PROFIT			25%	\$2,583	25%	\$1,337	\$13,87
SUBTOTAL				\$12,915	2070	\$6,684	\$3,920 \$19,599
CONSTRUCTION COST							ψ13, 3 8

1AVC-59

ECO-M30

DOMESTIC WATER PIPE INSULATION





ENERGY CONSERVATION OPPORTUNITY: ECO-M30

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M30) analyzes the energy savings associated with reducing the amount of heat transfer through the walls of domestic hot water piping. Domestic hot water piping can lose heat to its surroundings because of a temperature difference between the water and the ambient space temperature through which it is routed. A reduction in the hot water temperature at the point of use will cause an increase in hot water usage thus causing an increase in energy.

SCOPE:

The implementation of this ECO-M6 simulation includes all piping that exists without insulation and is exposed to unconditioned spaces. The piping considered in this ECO is located in the Castle and in the pipe tunnels connecting the building around the South Gate. Hot water piping contained inside the rest of the buildings considered in this study is located in concealed chases which are not accessible for insulating.

MODELING TECHNIQUES:

The modeling techniques used to calculate the energy savings associated with the addition of pipe insulation was figured on a savings per foot of pipe. Tables M30-1 and M30-2 give the BTUH per lineal foot heat loss through bare and insulated pipe. The existing hot water temperature of 185° was used along with an ambient space temperature of 68°. Table M30-3 gives the energy savings and the installed cost of the insulation on a lineal foot bases. A visual inspection was done to estimate the percentage of domestic hot water piping that was uninsulated.



ECO-M30

ECO IMPLEMENTATION:

To implement this ECO for the buildings listed above, the existing uninsulated pipe would have to be insulated using 1/2" fiberglass pipe insulation. A difficulty factor of 2 was added to the labor cost because of the confined areas at which the hot water piping is located.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown below in Table M30.1 in million BTU's savings as determined using the computer simulation model.

The probable construction cost to implement this ECO by building is shown in Table M30.1. This project cost is the construction cost plus 6% SIOH.

Building Number	umber Savings (BTUH)		Project Cost	Simple Payback	Savings to Invest Ratio	
Castle Buildings	147	\$787	\$1,447	2.28	5.11	
Pipe Tunnels	55	\$293	\$481	. 2.03	5.75	

Table M30.1



	CALCULATION SHEET	DATE	SHEET OF
PROJECT	USDB ENERGY SAVINGS OPPORTUNITY SURVEY	Mar-90 BASIS FOR CALCU	1 2 LATION
LOCATION			TED.
ARCHITECT/	CLARK RICHARDSON & BISKUP		CTOR BID
ECO MEASU	RE ECO-M30	COMPUTED BY RGB	CHECKED BY MAW

TEST DATA, BTUH LOSS PER LINEAL FOOT REF: Guidlines for Saving Energy in Existing Buildings Federal Energy Administration Office of Energy Conservation and Environment

Table was developed from fig. 44 of the Guidlines for Saving Energy in Existing Buildings

Ambient Temperature 68° F Domestic Hot Water Temperature 180°

Pipe Size	BTUH Loss Bare Pipe	BTUH Loss Insulated	BTUH Savings	Hours per Year	\$ Savings per L.F.
3/4"	85	19	66	4380	\$1.54
1"	105	23	82	4380	\$1.92
1-1/4"	126	26	100	4380	\$2.34
1-1/2"	150	31	119	4380	\$2.78
2"	171	37	134	4380	\$3.13
2-1/2"	250	45	205	4380	\$4.79

• 50





	CALCULA	ATION SHEE	T	DATE	E 1ar-90	SHEET 0
ROJECT	USDB	0.0.000 -		BASI	S FOR CALCUL	
DCATION	ENERGY	SAVINGS O	PORTUNI		K HAND	
						ER
RCHITECT/E		CHARDSON	I & RICKI ID			CTOR BID
CO MEASUR	E		a DISKUP	СОМ	PUTED BY	(SPECIFY) CHECKED
	ECO-M30				RGB	N
TEST DAT	A, BTUH LOS	SS PER LINI	EAL FOOT			
REF: Guidli	nes for Savir	na Enerav in	Existing Bui			
Federal Ene	ergy Adminis	tration Office	of Energy (n and Environment		
Tables deri	ved from Tab	loc MOG On				
Length of pi	ipe estimated	from field in	ISpection an			
- 4						
Castle Dull-	liago					
Castle Build Pipe	Feet of	\$ Savings	\$ Savings			
Size	Bare Pipe	per Ft.	Year			
3/4"	80	\$1.54	\$123			
1"		\$1.92	\$0			
1-1/4"	260	\$2.34	\$608			
1-1/2"	20	\$2.78	\$56			
2"		\$3.13	\$0			
			¥¥			
	1					
	Energy Sav	rings =	\$787.00			
	Energy Sav	rings =	\$787.00			
	Energy Sav	rings =	\$7 87. 0 0			
		rings =	\$787.00			
	S	•				
Pipe	s Feet of	\$ Savings	\$ Savings			
Size	S	\$ Savings per Ft.	\$ Savings Year			
Pipe Size 3/4"	s Feet of	\$ Savings per Ft. \$1.54	\$ Savings Year \$0			
Pipe Size 3/4" 1"	s Feet of Bare Pipe	\$ Savings per Ft. \$1.54 \$1.92	\$ Savings Year \$0 \$0			
Pipe Size 3/4" 1" 1-1/4"	s Feet of Bare Pipe 60	\$ Savings per Ft. \$1.54 \$1.92 \$2.34	\$ Savings Year \$0 \$0 \$140			
Pipe Size 3/4" 1" 1-1/4" 1-1/2"	s Feet of Bare Pipe	\$ Savings per Ft. \$1.54 \$1.92 \$2.34 \$2.78	\$ Savings Year \$0 \$0 \$140 \$153			
Pipe Size 3/4" 1" 1-1/4"	s Feet of Bare Pipe 60	\$ Savings per Ft. \$1.54 \$1.92 \$2.34	\$ Savings Year \$0 \$0 \$140			
Pipe Size 3/4" 1" 1-1/4" 1-1/2"	s Feet of Bare Pipe 60	\$ Savings per Ft. \$1.54 \$1.92 \$2.34 \$2.78	\$ Savings Year \$0 \$0 \$140 \$153			
Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2"	s Feet of Bare Pipe 60 55	\$ Savings per Ft. \$1.54 \$1.92 \$2.34 \$2.78 \$3.13	\$ Savings Year \$0 \$0 \$140 \$153 \$0			
Pipe Size 3/4" 1" 1-1/4" 1-1/2" 2"	s Feet of Bare Pipe 60	\$ Savings per Ft. \$1.54 \$1.92 \$2.34 \$2.78 \$3.13	\$ Savings Year \$0 \$0 \$140 \$153			

F A	PROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY & LO(TITL 990 E: 0(.e: 1496. Dis	FION INVES RT LEAVEN SCRETE PC	STMEN	T PR([H - 1 NAM	OGRAM (E USDB REC	GION N 30CB	OS. 7 PARED		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1	. INVESTMEN A. CONSTRU B. SIOH C. DESIGN (D. ENERGY E. SALVAGE F. TOTAL IN	JCTK COST CREI VAL	DIT CALC(1) UE COST		.9					\$\$ \$\$ \$\$ \$ \$ \$	1365. 82. 75. 1370. 0. 1370.
2.	ENERGY SAV	/ING	S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COS	F & DI:	SCOUNTE	D SAVI	NGS		
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR			NUAL \$ /INGS(3)		OUNT TOR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	0. 0. 0. 147. 0.		\$ \$ \$ \$ \$	0. 0. 600. 0.		8.69 12.42 12.21 11.67 10.36		0. 0. 0. 7002. 0.
	F. TOTAL			147.		\$	600.			\$	7002.
3.	NON ENERGY	Y SAV	VINGS(+) / C(OST(-)							
	A. ANNUAL F (1) DISCO	UNT	FACTOR (TA	BLE A)			9.11			\$	0.
	(2) DISCO	UNT	ED SAVING/(COST (3A)						\$	0.
	C. TOTAL NC						COST(-) (3	8A2+3B	d4)	\$	0.
	A IF 3D B IF 3D C IF 31	AX N 01 IS 01 IS 01B I	ENERGY QU ON ENERGY = OR > 3C G(< 3C CALC \$ = > 1 GO T \$ < 1 PROJEC	CALC (2F5) TO ITEM SIR = (2F5- O ITEM 4	5 X .33 4 +3D1)/*	3) 1F)=		\$	2311.		
4.	FIRST YEAR [DOLL	AR SAVINGS	3 2F3+3A+(3	B1D/(`	YEAR	S ECONON	AIC LIFI	Ξ))	\$	600.
5.	TOTAL NET D	ISCO	UNTED SAVI	NGS (2F5+	3C)					\$	7002.
6.	DISCOUNTED (IF < 1 PROJEC	SAV CT D	INGS RATIO OES NOT QL	JALIFY)		(SIR))=(5 / 1F) =		5.11		
7.	SIMPLE PAYB	ACK	PERIOD (ES ⁻	TIMATED)	SPB=	=1F/4			2.28		



.

P F	ENERG ISTALLATION & L ROJECT NO. & TI ISCAL YEAR 1990 NALYSIS DATE:	ITLE: 1496 0 DIS	TON INVEST	rtion n/	Rogram (E0 - USDB REC ME: ECOM3	GION NOS. 7		JDY: USDBAE LCCID 1.035 CENSUS: 2 RB
1.	E. SALVAGE V)ST REDIT CALC (14		9			0000000000000000000000000000000000000	454. 27. 25. 455. 0. 455.
2.	ENERGY SAVIN ANALYSIS DAT	NGS (+) / COST (E ANNUAL SAVI	(-) INGS, UNIT	COST &	DISCOUNTE	D SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		DISCOUNTED AVINGS(5)
	B. DIST C. RESID D. NAT G	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	0. 0. 0. 55. 0.	\$ \$ \$ \$ \$	0. 0. 0. 224. 0.	8.69 12.42 12.21 11.67 10.36		0. 0. 2614. 0.
	F. TOTAL		55.	\$	224.		\$	2614.
3.	NON ENERGY S	SAVINGS(+) / CC	DST(-)					
	A. ANNUAL REG	CURRING (+/-) NT FACTOR (TA	BLE A)		9.11		\$	0.
	(2) DISCOUM	NTED SAVING/C	OST (3A X	3A1)	0.11		\$	0.
	C. TOTAL NON	ENERGY DISCO	OUNTED SA	VINGS(+)/COST(-) (3	A2+3Bd4)	\$	0.
	A IF 3D1 B IF 3D1 C IF 3D1	ON ENERGY QU X NON ENERGY IS = OR > 3C GO IS < 3C CALC B IS = > 1 GO TO B IS < 1 PROJEC	CALC (2F5 D TO ITEM 4 SIR = (2F5+ D ITEM 4	X .33) 3D1)/1F):	-	\$ 863.		
4.	FIRST YEAR DO	OLLAR SAVINGS	2F3+3A+(3	B1D/(YEA	RS ECONON	AIC LIFE))	\$	224.
5.	TOTAL NET DISC	COUNTED SAVI	NGS (2F5+3	BC)			\$	2614.
6.	DISCOUNTED SA (IF < 1 PROJECT		ALIFY)	(S	IR)=(5 / 1F)=	5.75		
7.	SIMPLE PAYBAC	CK PERIOD (EST	FIMATED)	SPB=1F	/4	2.03		



CONSTRUCTION COST ESTIN	MATE		DATE PR	EPARED			SHEET OF
PROJECT USDB ENERGY STUDY				BASIS FOR E	STIMATE		<u>I</u>
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER CLARK RICHARDSON & BISH				x	CODE (B (PRELIMINA C (FINAL DES	1 COMPLETED) RY DESIGN) IGN)
DRAWING NO. Castle Buildings		ESTIM	ATOR	R.G.B.	OTHER	(SPECIFY)	
	QU	ANTITY	M	ATERIAL	1	ABOR	M.A.W. TOTAL
1/2" FIBERGLASS PIPE INSULATION W/ ALL SERVICE JACKET	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
<u>3/4" PIPE</u>	80	L. F.	\$0.87	\$69.60	\$1.44	\$115.20	\$184.1
1-1/4" PIPE	260	L. F.	\$1.01	\$262.60	\$1.57	\$408.20	\$670.8
1-1/2" PIPE	20	<u>L. F.</u>	\$1.10	\$22.00	<u>\$1.57</u>	\$31.40	\$53.4
	╉╍╍╌╂			\$354		\$555	\$90
CONTINGENCY 10%	┼──┤		\$0.10	\$35	10%	\$55	\$9
SUBTOTAL VORK COMP,TAX,SOC.SEC.,INS	+			\$389		\$610	\$99
DIRECT COST	+		\$0.04	<u>\$14</u> \$403	13.0%	\$79	\$9
VERHEAD AND PROFIT			\$0.25	\$403	25%	\$689 \$172	\$1,09
SUBTOTAL				\$504	20/6	\$861	\$27: \$1,36
CONSTRUCTION COST NG. FORM 150							\$1,365

1AVC-59



			DATE PREPARED				SHEET OF 2	
PROJECT USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				BASIS FOR ESTIMATE X CODE A (NO DESIGN COMPLETED) CODE B (PRELIMINARY DESIGN) CODE C (FINAL DESIGN)				
								CLARK RICHARDSON & BISP
DRAWING NO. Pipe Tunnels			NTOR R.G.B.			CHECKED BY M.A.W.		
		ANTITY		ATERIAL	Ĺ	ABOR	TOTAL	
1/2" FIBERGLASS PIPE INSULATION W/ ALL SERVICE JACKET	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
1-1/4" PIPE	60	L. F.	\$1.01	\$60.60	\$1.57	\$94.20	\$154.8	
<u>1-1/2" PIPE</u>	55	L. F.	\$1.10	\$60.50	\$1.57	\$86.35	\$146.8	
SUBTOTAL				\$121		\$181		
CONTINGENCY 10%			\$0.10	\$12	10%	\$18	\$30	
SUBTOTAL				\$133	10/0	\$199	\$33	
VORK COMP, TAX, SOC.SEC., INS			\$0.04	\$5	13.0%	\$26	\$3 [.]	
DIRECT COST				\$138		\$225	\$363	
VERHEAD AND PROFIT		-	\$0.25	\$35	25%	\$56	\$91	
SUBTOTAL				\$173		\$281	\$454	
CONSTRUCTION COST							\$454	

1AVC-59



-

ECO-M31

HEAT RECOVERY FOR LAUNDRY

HEAT RECOVERY FOR LAUNDRY

ENERGY CONSERVATION OPPORTUNITY: ECO-M31

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M31) analyzes energy savings possibilities from heat recovery from equipment in the laundry facility at the USDB. Because the laundry facility is beingrelocated, we are only making general recommendations based on the most up-to-date information available for laundry equipment in the USDB at this time.

SCOPE:

The ECO simulation (ECO-M31) investigates possibilities for heat recovery from laundry wash water, dryers, and irons (presses). Heat recovery applications in similar laundry facilities will be investigated and their feasibility at the USDB will be discussed.

Laundry wash water heat may be recovered in two ways; either by recycling dirty wash water and attempting to clean it by mechanical and chemical means or by using a system designed for recovering heat only (not water).

Disadvantages to recycling dirty wash water are that they require complicated hardware and expensive chemicals. High initial cost, high operating costs, and more maintenance problems rule this out as a possibility.

Heat reclamation systems, however, are simpler to install, operate, and maintain because they have fewer mechanical components and controls (see Fig. 1). Spent hot wash water is dumped first to a channel leading to a sump pit. Before it reaches the pit, it passes through a series of screens to remove lint and other solids. The dirty water is then pumped from the sump into the shell of a heat exchanger where it passes over a series of helical coil heat exchangers. Fresh (cold) water inside the coils passes in the opposite direction. Typically, dirty hot water enters the shell of the heat exchanger at 135° F and exits at 85° F while cold fresh water enters the heat exchanger at 60° F and exits at 110° F. This preheated fresh water then enters a water heater where it is brought up to 180° F and stored in a stratified storage tank for use upon demand. Some designs facilitate the washdown of heat exchanger coils without the need for disassembly of the unit. Typically, these units are installed in concrete troughs to permit washdown of the coils in place. These cleanings, which normally take less than 15 minutes, require no tools and are typically done weekly.



Heat recovery from dryer exhaust can be accomplished by means of air-to-air heat exchangers. Hot, lint-laden air exhausted from the dryers would enter a counterflow heat exchanger on one side while cooler outside air enters from the opposite side.

This supply would then be used as preheated make-up air for the dryers. Plates in the heat transfer matrix separate the two air streams and act as a heat transfer surface. The main problems inherent in systems such as this are related to lint and moisture in the air. However, these problems are addressed by careful selection of heat exchanger materials and adequate plate spacing.

Heat recovery from the nine dryers in the USDB laundry could best be done, but at a prohibitive cost, by nine heat recovery units (HRU's) which would only operate when their respective dryer was running. This would maximize the utilization of waste heat, taking it only from an active dryer and transferring it to make-up air for that same dryer. On the other hand, a central heat recovery unit (see Fig. 2) serving all nine dryers would be removing and supplying air at a constant rate, so that if some dryers are not operating, lower exhaust temperatures would reduce the amount of waste (and recoverable) heat.available. The ideal arrangement of dryers for a central HRU would be side-by side, against a wall with an insulated plenum space and room for exhaust ductwork inside. Make-up air preheated by the HRU would be dumped into the plenum for direct use by the dryers. This type of layout would be much better than dumping make-up air into the occupied space during the heating season, because it could be used year-round and it more efficiently utilizes the heat recovered. For this reason, we recommend that special consideration is given to layout of the dryers if this ECO is to be implemented.

Heat recovery from steam irons/presses is not a valid consideration. They do not waste enough heat in a form that is easily recovered. Their function is to apply heat, moisture, and pressure directly to pieces of laundry. Because this process transfers heat efficiently and without much waste, there is no opportunity for heat recovery here.

MODELING TECHNIQUES:

Energy savings associated with implementation of this ECO were calculated using performance data from manufacturers of helical coil heat exchangers and air-to air heat recovery units.

ECO IMPLEMENTATION:

The best opportunity for implementation of this ECO would be when the laundry facility reaches a permanent location. This way, heat recovery systems can be incorporated into the design more readily than trying to incorporate them into an existing facility.

This implementation would include installation of a wastewater heat recovery system, a new semi-instantaneous water heater, and the associated pumps, piping, and accessories required for proper operation of the system. If dryer heat recovery is to be implemented, installation of an 18,000 cfm air-to-air heat recovery unit, and associated controls, ductwork and accessories would be required.

SUMMARY:

The project cost is the construction cost, plus 6% SIOH. Wastewater heat recovery and dryer exhaust heat recovery were considered as separate projects.



The energy savings associated with the implementation of this ECO by project is also shown in Table M31-1 in MBTU's per year savings as determined by hand calculations.

The simple payback for both ECO projects is shown in Table M31-1.


The savings to investment ratio (SIR) for both ECO projects is shown in Table M31-1.

We recommend wash water heat recovery, but dryer exhaust heat recovery is not as feasible. High first cost and space constraints make it a less attractive alternative.

Project	Gas Energy Savings (MBTU/yr.)	Electric Energy Savings (MBTU/yr.)	Cost Saving s (\$/yr.)	Project Cost (\$)	Simple Payback (years)	Savings to Invest Ratio
Wash water H.R.	3,878	-6.43	15,742	43,829	2.78	4.18
Dryer Exhaust H.R	2,821	-73.5	10,597	111,688	10.54	1.13

Table M31-1





DRYER EXHAUST HEAT RECOVERY SCHEMATIC

NOT TO SCALE

------ Fig. 2 -PAGE M31-4

ECO-M31

	CALCULATION SHEET	Mar-90	SHEET OF
PROJECT		BASIS FOR CALCUL	ATION
LOCATION	ENERGY SAVINGS OPPORTUNITY SURVEY	X HAND	
	FORT LEAVENWORTH, KANSAS	COMPUTI	ER
ARCHITECT/I	ENGINEER		CTOR BID
	CLARK RICHARDSON & BISKUP		(SPECIFY)
ECO MEASUI	CO-M31 WASH WATER HEAT RECOVERY	BMS	CHECKED BY MAW
	GIVEN:		
			-
	HOT WATER USE TEMP., °F	160	
	AVERAGE COLD WATER INLET TEMPERATURE, °F	50	
	GALLONS WATER/LB. OF LAUNDRY	2.5	
	PERCENT OF WASTE WATER THAT IS HOT	70	
	HOURS OF OPERATION PER WEEK	4(
	ELECTRICITY COST, DOLLARS/MBTU GAS COST IN DOLLARS/MBTU	12.44	
	BOILER SEASONAL EFFICIENCY, %	4.08 74	
			-
	CALCULATED WASTE WATER TEMP., °F	127	
	WASTE WATER TEMP USED IN ANALYSIS, °F	124	
	BASED ON HEAT EXCHANGER MANUFACTURER'S		
	PERFORMANCE DATA FOR 30 GPM UNIT:		
		104 / 01	7
	SHELL SIDE TEMPERATURE, °F IN/OUT TUBE SIDE TEMPERATURE, °F IN/OUT	124 / 91	
	TODE SIDE TEMPERATURE, THIN/OUT	50 / 96	J
	STEAM HEAT RECOVERED, MBTU/YR:	2,870	
	GAS HEAT RECOVERED, MBTU/YR:	3,878	
	(2) 30 GPM UNITS ARE REQUIRED.		
	PUMP ENERGY CALCULATION FOR THIS ECO		
			1
	FRESH WATER PUMP CAPACITY, GPM:	60	
	FRESH WATER PUMP HEAD, FT. W: FRESH WATER PUMP EFFICIENCY, %:	38 65	
	WASTE WATER PUMP CAPACITY, GPM:	84	
	WASTE WATER PUMP HEAD, FT, W:	10	
	WASTE WATER PUMP EFFICIENCY, %:	65	
	FRESH WATER PUMP POWER CONSUMPTION, WATTS:	662	3
	FRESH WATER PUMP ENERGY USE, MBTU/YEAR:	4.70	
	WASTE WATER PUMP POWER CONSUMPTION, WATTS:	244	
	WASTE WATER PUMP ENERGY USE, MBTU/YEAR:	1.73	
	TOTAL PUMP ENERGY, MBTU/YR.:	6.43	ł
	NET ENERGY SAVINGS FOR WASH WATER H.R., MBTU/Y	(R.: 3,872	
	NET ENERGY SAVINGS, \$/YR:	15,742	

	CALCULATION SHEET			DATE	SHEET	0F 2			
PROJECT	USDB		· · · · · · · · · · · · · · · · · · ·	Mar-901BASIS FOR CALCULATIONXHANDCOMPUTERCOMPUTED BYCHECKED BCOMPUTED BYCHECKED BBMSMJST SIDE: TEMPERATURE (°F) =140TT TEMPERATURE (°F) =140W.G.) =0.0398W.G.) =1.01ST SIDE: TEMPERATURE (°F) =140ST SIDE: TEMPERATURE (°F) =140T TEMPERATURE (°F) =140ST SIDE: TEMPERATURE IS140MULB. W./LB. D.A.) =0.0306W.G.)					
	ENERGY SAVINGS OPP	ORTUNITY SU	RVEY	Mar-901BASIS FOR CALCULATIONXHANDCOMPUTERCONTRACTOR BIDOTHER (SPECIFY)COMPUTED BYCOMPUTED BYCHECKED BYBMSMASIDE:MPERATURE (°F) =140MPERATURE (°F) =114.1218,00018,000/LB. D.A.) =0.0398G.) =1.01SIDE:MPERATURE (°F) =140EMPERATURE (°F) =140EMPERATURE (°F) =140SIDE:MPERATURE (°F) =0.0398/LB. D.A.) =0.0398/ (LB. W./LB. D.A.) =0.0306G.) =0.97DNDENSED (LB./HR.)699MALYSISOUTDOOR AIR DRY-BULB					
OCATION									
RCHITECT/E	FORT LEAVENWORTH,	KANSAS							
CO MEASUF	CLARK RICHARDSON &	BISKUP		OTHER	R (SPECIFY)				
	ECO-M31 DRYER EXHA	UST HEAT REC	OVERY	1	CHECKED	BY MAW			
AIR-TO-AII	R HEAT RECOVERY UNIT	PERFORMANC	E DATA:						
SUMMER	(EFFECTIVENESS = 57.9								
SUPPLY S	IDE:	•	EXHAUST	SIDE:					
INLET TEN	PERATURE (°F) =	95	INLET TEM	IPERATURE (°F) =	140				
OUTLET T	EMPERATURE (°F) =	121.07	OUTLET T	EMPERATURE (°F) =	114.12				
CFM =		18,000	CFM =						
W (LB. W./	LB. D.A.) =	0.0168							
ΔΡ (IN. W.(i.) =	0.99	ΔΡ (IN. W.(G.) =	1.01				
	(EFFECTIVENESS = 65.3	6%)							
SUPPLY SI		_	EXHAUST						
		0							
CFM =	EMPERATURE (°F) =	91.5		EMPERATURE (°F) =					
	_B. D.A.) =	18000	CFM =	0 W 4 D D					
ΔP (IN. W.C		0.0001							
	2.) =	0.87							
			ΔP (IN. W.C						
				()	000				
ASSUMPTI	ONS MADE FOR YEAR-RO	UND HEAT RE			000				
1) AMOUN TEMPE 2)HEAT EX	T OF WATER CONDENSED RATURE IS A LINEAR REL	D FROM DRYEF	COVERY BIN AN R EXHAUST VS. (<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPE 2)HEAT EX	T OF WATER CONDENSEE RATURE IS A LINEAR REL/ CHANGER EFFECTIVEDNE \R RELATIONSHIP.	D FROM DRYEF	COVERY BIN AN R EXHAUST VS. (<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSEE RATURE IS A LINEAR REL/ CHANGER EFFECTIVEDNE \R RELATIONSHIP.	D FROM DRYEF	COVERY BIN AN R EXHAUST VS. (<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSEE RATURE IS A LINEAR REL/ CHANGER EFFECTIVEDNE NR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i)	D FROM DRYEF	COVERY BIN AN R EXHAUST VS. (<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSEE RATURE IS A LINEAR REL CHANGER EFFECTIVEDNE NR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE:	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO	COVERY BIN AN R EXHAUST VS. (DOR AIR DRY-BL	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSEE RATURE IS A LINEAR REL/ CHANGER EFFECTIVEDNE NR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO	COVERY BIN AN R EXHAUST VS. (DOR AIR DRY-BL	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSEE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE NR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO	COVERY BIN AN R EXHAUST VS. (DOR AIR DRY-BL	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSEE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE NR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795)	COVERY BIN AN R EXHAUST VS. (DOR AIR DRY-BU AIR STREAMS	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
1) AMOUN TEMPEI 2)HEAT EX A LINEA THEREFOR	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. 8E: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. 8E: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB	·			
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB	•			
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. RE: 08 X 18000 X (140 - Tc,i) WHERE: ΔQ = HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				
 AMOUNT TEMPEI 2)HEAT EXA A LINEA THEREFOR ΔQ = E X 1.4 THIS FORM 	T OF WATER CONDENSE RATURE IS A LINEAR RELA CHANGER EFFECTIVEDNE AR RELATIONSHIP. WHERE: $\Delta Q =$ HEAT TRANSFERRE E = EFFECTIVENESS = .6536 - (Tc,i/95) X (.65 Tc,i = OUTSIDE AIR DRY-	D FROM DRYEF ATIONSHIP. ESS VS. OUTDO ED BETWEEN A 5365795) BULB TEMPER ULATE HEAT F	COVERY BIN AN R EXHAUST VS. 4 DOR AIR DRY-BU AIR STREAMS ATURE	<u>ALYSIS</u> OUTDOOR AIR DRY-	BULB				

		N SHEE	• •			DATE Mar-90		SHEET	0F 2
PROJECT	USDB						R CALCUL		2
OCATION	ENERGY SAV	INGS O	PPORTUNI	TY SURVE	/				
OCATION						<u> </u>	HAND	_	
RCHITECT/E		WORN	H, KANSAS				COMPUTE		
	CLARK RICHA		& BISKLIP				CONTRAC	(SPECIFY)	
CO MEASUR	E					COMPUTE		CHECKED	BY
	ECO-M31 DRY	ER EXH	AUST HEA	T RECOVE	RY		BMS		MAW
÷				T RECOVEI USING IODIFIED B					
				BIN	HOURS/YE		STEAM	1	
	Т	EMP.	AVG. DB		10013/12	05:30 TO	MBTU'S		
		BIN	TEMP	01 TO 08	09 TO 16	13:30	RECOV.		
		0.11		01 10 00	031010	10.00			
	1(05/109	107	0	3	1	0.37		
		00/104	107	0	15	7	2.97		
		95/99	97	0	51	25	12.08		
		90/94	92	0	127	62	33.66		
		35/89	87	6	203	101	60.95		
		30/84	82	56	265	142	94.41		
		75/79	77	162	262	165	119.94		
	7	70/74	72	257	236	173	136.63		
	6	65/69	67	274	209	164	139.95		
	6	60/64	62	264	195	154	141.33		
	5	55/59	57	230	190	144	141.53		
	5	50/54	52	197	185	135	141.58		
	4	5/49	47	181	177	127	141.65		
		0/44	42	188	169	125	147.85		
		5/39	37	226	175	136	170.13		
		0/34	32	248	151	129	170.26		
		25/29	27	214	113	103	143.12		
		0/24	22	150	76	71	103.66		
		5/19	17	103	52	48	73,49		
		0/14	12	67	33	31	49.70		
		5/9	7	50	20	21	35.19		
		0/4	2	23	8	9	15.74		
		5/-1	- 3	14	3	5	9.12		
		1 <u>0/-6</u> 5/-11	- 8	4	0	1	1.90		
		3/*11	-13		0	0	0.00		
	то	TALS		2916	2918	2079	2087		
						2070[20071		
	GAS	S COST	, \$/MBTU:				74% 4.08		
		CTRICI	TY COST,	SAVINGS	, MBIU:		2820		
				S/MBTU:			12.44		
				Y CONSUM		TU:	13.9 73.5		
	тот	AL EST	IMATED A	NNUAL S	AVINGS, \$	=	10,591		

PI FI	ENE ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY & LO TITL 990	.E: 1496 DIS	TION INVES RT LEAVEN SCRETE PC		ROGRAM (E	GION NOS. 7 31W		JDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1.	INVESTMEN A. CONSTRU B. SIOH C. DESIGN C D. ENERGY E. SALVAGE F. TOTAL IN		- DIT CALC(1. UE COST		(.9	·		\$\$ \$\$ \$\$ \$ + \$\$	43829. 2630. 2411. 43983. 0. 43983.
2.	ENERGY SAV	/ING ATE /	S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	F COST & I	DISCOUNTE	D SAVINGS		
	FUEL		UNIT COST \$/MBTU(1)			NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		DISCOUNTED SAVINGS(5)
,	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	-6. 0. 0. 3878. 0.	\$ \$	-75. 0. 0. 15822. 0.	8.69 12.42 12.21 11.67 10.36		-652. 0. 0. 184643. 0.
	F. TOTAL			3872.	\$	15747.		\$	183991.
3.	NON ENERGY	Y SAV	/INGS(+) / C(OST(-)					
	A. ANNUAL F		RRING (+/-) FACTOR (TA			0.44		\$	0.
	(2) DISCO	UNT	ED SAVING/C	COST (3A)	(3A1) -	9.11		\$	0.
	C. TOTAL NO	N EN	IERGY DISC	OUNTED SA	AVINGS(+)	/COST(-) (3	3A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3[AX N 1 IS 1 IS 01B I	ENERGY QU ON ENERGY = OR > 3C GO < 3C CALC S = > 1 GO T S < 1 PROJEC	CALC (2F5 TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1F)=		\$ 60717.		
4.	FIRST YEAR	OLL	AR SAVINGS	3 2F3+3A+(3	BB1D/(YEA	RS ECONON	AIC LIFE))	\$	15747.
5.	TOTAL NET D	ISCO	UNTED SAV	INGS (2F5+	-3C)			\$	183991.
6.	DISCOUNTED (IF < 1 PROJE	SAV CT D	INGS RATIO OES NOT QU	JALIFY)	(SI	R)=(5 / 1F)=	4.18		
7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F/	4	2.79		

F	ENE NSTALLATION PROJECT NO. 8 ISCAL YEAR 1 NALYSIS DAT	ERG\ & LC & TIT 1990	LE: 1496 DI	TION INVES ORT LEAVEN SCRETE PC	STMENT NWORTH ORTION N	PROGRAM (EGION M31D	NOS. 7 REPARED		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1	E. SALVAGI	COS COS CRE E VA	T EDIT CALC (1		(.9				\$ \$ \$ \$ \$ \$ \$	111688. 6701. 6143. 112079. 0. 112079.
2.	. ENERGY SA ANALYSIS D	VING ATE	S (+) / COST ANNUAL SA	`(-) ∕INGS, UNI⁻	T COST 8		ED SA\	/INGS		
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YF		ANNUAL \$ SAVINGS(3)		SCOUNT CTOR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$\$ \$\$ \$\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	-74. 0. 0. 2821. 0.	\$ \$ \$ \$	-921. 0. 0. 11510. 0.		8.69 12.42 12.21 11.67 10.36		-8003. 0. 0. 134322. 0.
	F. TOTAL			2747.	\$	10589.		,	\$	126319.
3.	NON ENERG	IY SA	VINGS(+) / C	OST(-)						
	A. ANNUAL I		JRRING (+/-) FACTOR (TA			0.44			\$	0.
	(2) DISCO	DUNT	ED SAVING/	COST (3A >	< 3A1)	9.11			\$	0.
	C. TOTAL NO	ON EI	NERGY DISC	OUNTED S	AVINGS(-	+) /COST(-) (3A2+38	3d4)	\$	0.
	A IF 31 B IF 31 C IF 3	IAX N D1 IS D1 IS D1 B	I ENERGY QU ION ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T S < 1 PROJE(' CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1F))=	\$	41685.		
4.	FIRST YEAR	DOLL	AR SAVINGS	S 2F3+3A+(3	3B1D/(YE	ARS ECONO		=E))	\$	10589.
	TOTAL NET D								\$	126319.
6.	DISCOUNTED (IF < 1 PROJE) SAV	INGS RATIO	JALIFY)	. (8	SIR)=(5 / 1F)=	2	1.13		
7.	SIMPLE PAYE	BACK	PERIOD (ES	TIMATED)	SPB=1	=/4		10.58		



ECO-M31

•

CONSTRUCTION COST ESTIMA				REPARED	4/2/90)	SHEET OF
PROJECT				BASIS FOR E			1
USDB ENERGY STUDY LOCATION FORT LEAVENWORTH, KS				x	CODE	3 (PRELIMINA	N COMPLETED) ARY DESIGN)
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	0					C (FINAL DES	iiGN)
DRAWING NO. NONE		ESTIM	ATOR	l	UTHER	(SPECIFY) CHECKED B	
NONE		ANTITY	M	BMS IATERIAL		ABOR	MAW TOTAL
ECO-M31 WASH WATER HEAT	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	COST
RECOVERY SYSTEM							
HELICAL COIL HEAT EXCHANGER	2	EA	\$9,500	\$19,000	\$1,010	\$2,020	\$21,02
FRESH WATER PUMP (59 GPM, 50 FT. HD.)	1	EA	\$1,070	\$1,070	\$180	\$180	\$1,25
WASTE WATER PUMP (94 GPM, 10 FT. HD.)	1	EA	\$500	\$500	\$40	\$40	\$54
STRATIFIED WATER STORAGE TANK 2" SCHEDULE 40 STEEL PIPING	1	EA	\$6,500	\$6,500	\$355	\$355	\$6,85
ACCESSORIES	100	LF	\$3	\$289	\$6	\$555	\$84
							· · · · · · · · · · · · · · · · · · ·
SUBTOTAL				\$27,359		\$3,150	\$30,50
ONTINGENCY 10%			10%	\$2,736	10%	\$315	\$3,05
SUBTOTAL				\$30,095		\$3,465	\$33,560
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$1,053	13.0%	\$450	\$1,503
DIRECT COST				\$31,148		\$3,915	\$35,063
VERHEAD AND PROFIT			25%	\$7,787	25%	\$979	\$8,766
SUBTOTAL				\$38,935		\$4,894	\$43,829
CONSTRUCTION COST							\$43,829



.

PROJECT			<u> </u>	BASIS FOR E	4/2/90		2	
USDB ENERGY STUDY								
				x	CODE	A (NO DESIGI	N COMPLETED)	
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER					CODE	B (PRELIMINA	RY DESIGN)	
CLARK BICHARDSON & BU	SKUP					C (FINAL DES (SPECIFY)	IGN)	
DRAWING NO.		ESTIM	ATOR					
NONE				BMS			MAW	
ECO-M31		ANTITY		MATERIAL		ABOR	TOTAL	
	NO.	UNIT MEAS.	PER	TOTAL	PER	TOTAL	COST	
DRYER EXHAUST HEAT		INCAS.	UNIT		UNIT			
RECOVERY SYSTEM								
18,000 CFM HEAT RECOVERY UNIT							·····	
& CONTROLS	1	EA	\$71,220	\$71,220	\$4,280	\$4,280	\$75,50	
DUCTWORK & ACCESSORIES	805				• -			
	825		\$1	\$652	\$2	\$1,774	\$2,42	
				1		1		
			1	1				
		+						
					1			
		Í						
					+			
				Í				
			<u>+</u>					
SUBTOTAL				\$71,872		\$6,054	\$77,926	
ONTINGENCY 10%			10%	\$7,187	10%	\$605	\$7,792	
SUBTOTAL				#70 050			A	
				\$79,059		\$6,659	\$85,718	
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$2,767	13.0%	\$866	\$3,633	
					10.070			
DIRECT COST				\$81,826		\$7,525	\$89,351	
VERHEAD AND PROFIT	T							
	++		25%	\$20,456	25%	\$1,881	\$22,337	
SUBTOTAL				\$102 202	1	60.406	A444 000	
	++			\$102,282		\$9,406	\$111,688	
CONSTRUCTION COST	1		1	1			\$111,688	



.

ECO-M39

WATER HEATING HEAT PUMPS

6



WATER HEATING HEATPUMPS

ENERGY CONSERVATION OPPORTUNITY: ECO-M39

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-M39) analyzes the energy savings associated with installing water heating heatpumps to condition the interior spaces.

SCOPE:

The ECO simulation (ECO-M39) replaces any space conditioning equipement with water source heatpumps. The replacement of space conditioning equipment can be completed in any of the buildings being considered that meet interior space conditions. The application of this ECO was considered for all of the buildings that presently have cooling in the spaces:



Building 450 Building 463 Building 464 Building 465 Building 472

Building 473 Building 475A Building 475B Building 475H

MODELING TECHNIQUES:

The modeling technique used to calculated the energy savings for this ECO was calculated using hand calculations. The efficiencies of the existing systems can be determined from the computer simulation printouts. Table M39.1 gives the existing heating and cooling systems efficiencies versus the heatpump system efficiencies. The data for the heatpump efficiencies was determined from a heatpump installation study³ that was considered similar in capacity to the buildings in the USDB.

ECO-M39



Building Number	Existing Cooling Efficiency (KWh/Ton)	Existing Heating Efficiency (thrm/Btuh)	Heatpump Cooling Efficiency (KWh/Ton)	Heatpump Heating Efficiency (thrm/thrm)
450	1.30	0.85	1.1	0.85
463	1.35	0.83	1.1	0.85
464	1.35	0.83	1.1	0.85
465	1.45	0.78	1.1	0.85
472	1.30	0.77	1.1	0.85
473	1.35	0.83	1.1	0.85
475A	1.48	0.85	1.1	0.85
475B	1.48	0.85	1.1	0.85
475H	1.48	0.85	1.1	0.85

Table M39.1

With the known yearly heating and cooling load from the computer simulations, a yearly energy savings was determined in Table M39.2. Table M39.3 displays the total energy savings in MBTU and the cost savings in dollars.

Building Number	Existing Cooling Energy (KWh/yr)	Existing Heating Energy (thrm/yr)	Heatpump Cooling Energy (KWh/yr)	Heatpump Heating Energy (thrm/yr)
450	17,892	3,629	15,139	3,629
463	11,514	1,577	9,382	1,540
464	18,063	2,195	14,718	2,143
465	12,914	35,995	9,797	33,031
472	38,980	15,515	32,983	14,054
473	26,906	2,407	21,923	2,407
475A	22,868	12,773	16,996	12,773
475B	14,139	8,477	10,509	8,477
475H	10,589	8,137	7,870	8,137

Table M39.2

ECO IMPLEMENTATION:

To implement this ECO, a considerable amount of mechanical demolition and new retrofit is necessary. Some of the buildings have existing piping to areas for heatpumps which can be utilized for the condenser water. In this case the installation



of the heatpumps is average. In other buildings, the means of cooling in done by package window air conditioners. In these cases, the piping for the condenser water loop will be installed for each heatpump location. A heatpump would be installed in every location of the window air conditioner.

SUMMARY:

The energy savings associated with the implementation of this ECO by building is shown below in Table M39.3 in million BTU's per year savings as determined in the calculation section of this section.

The project cost is the construction cost as determined in the cost estimate plus 6% SIOH.

Building Number	Energy Savings (MBTU)	Cost Savings	Project Cost	Simple Payback	Savings to Invest Ratio
450	9	\$117	\$77,691	656.70	0.01
463	11	\$106	\$56,779	521.87	0.02
464	16	\$163	\$63,266	34.46	0.02
465	307	\$1,342	\$41,353	29.11	0.34
472	166	\$851	\$169,273	189.65	0.06
473	17	\$212	\$91,436	410.25	
475A	20	\$249	\$103,019	391.68	0.02
475B	12	\$154	\$64,902		0.02
475H	9	\$115		412.37	0.02
Table M39.3	ĭ	ΨΤΟ	49,791	420.35	0.02

Table M39.3

None of the buildings considered for this ECO show a payback that is feasible for implementing the ECO. One of the reasons for not showing a good payback, is that the condenser water that is used to loop through the heatpumps is not available and a fluid cooler or water tower has to be installed. The project cost is very high for this ECO because of the conditions of the work areas and that some piping for the buildings has to be installed. To make the payback even less favorable, the heatpumps have a higher maintenance cost than the existing equipment.



ECO-M39

PI FI Al	ISTALLATION & ROJECT NO. & SCAL YEAR 19 NALYSIS DATE	RGY (LOC TITLI 90 : 03	ATION: FOI E: 1496 DIS	FION INVES RT LEAVEN SCRETE PO	TMEN	IT F TH N N	ROGRAM (EC	ION NOS.	7	TUDY: USD LCCID 1 CENSU	.035
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	OST OST CREE VALU	DIT CALC (1) JE COST		.9					\$43 540 5735 5	293. 398. 031. 550. 0. 550.
2.	ENERGY SAV ANALYSIS DA	INGS TE A	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT	cosi	Т&	DISCOUNTED	SAVINGS			
	FUEL		INIT COST /MBTU(1)	SAVINGS MBTU/YR			ANNUAL \$ SAVINGS(3)	DISCOUN FACTOR(DISCOUNT SAVINGS(5	
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$	12.44 .00 .00 4.08 .00	9. 0. 0. 0.		\$ \$ \$ \$ \$	112. 0. 0. 0. 0.	8.6 12.4 12.2 11.6 10.3	12 21 57	g	973. 0. 0. 0. 0.
	F. TOTAL			9.	:	\$	112.		\$	9	73.
3.	NON ENERGY	SAV	INGS(+) / C(OST(-)							
	A. ANNUAL RI (1) DISCOU	JNT I	ACTOR (TA	BLE A)			9.11		\$		0.
			D SAVING/C						\$		0.
	C. TOTAL NO)/COST(-) (3A	\2+3Bd4)	\$		0.
	A IF 3D1 B IF 3D1 C IF 3D	X NC IS = IS < 1B IS	ENERGY QU ON ENERGY OR > 3C G(3C CALC S = > 1 GO T(< 1 PROJEC	CALC (2F5 D TO ITEM / SIR = (2F5+ D ITEM 4	X .33 4 ⊦3⊡1)/*	3) 1F)		321	I. -		
4.	FIRST YEAR D	OLLA	R SAVINGS	2F3+3A+(3	B1D/(\	YE	ARS ECONOM	IC LIFE))	\$	11	12.
5.	TOTAL NET DI	SCO	JNTED SAVI	NGS (2F5+	3C)				\$		73.
6.	DISCOUNTED : (IF < 1 PROJEC	SAVI T DC	NGS RATIO	, JALIFY)		(S	ilR)=(5 / 1F)=	0.0	1		
7.	SIMPLE PAYBA	VCK F	PERIOD (ES	TIMATED)	SPB=	=1F	/4	656.70)		



Р F A	ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY LC TIT 90 : (LE: 1496 DIS	TION INVES RT LEAVEN SCRETE PC	STMENT IWORTI	PROGRAM	REGION M39	NOS. 7 REPARED		TUDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1.	A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV	ICT OS CRE VAI	T EDIT CALC(1 LUE COST		.9				\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	53565. 3214. 2946. 53753. 0. 53753.
2.	ENERGY SAV ANALYSIS DA		S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	гсозт	& DISCOUN	ITED SA	VINGS		
	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		ANNUAL \$ SAVINGS(:		SCOUNT CTOR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	7. 0. 0. 4. 0.	99 69 69 69 69 69		7.).). 3.	8.69 12.42 12.21 11.67 10.36		756. 0. 0. 187. 0.
	F. TOTAL			11.	\$	103	3.		\$	943.
3.	NON ENERGY	SA	VINGS(+) / C0	OST(-)						
	A. ANNUAL R (1) DISCOU	JNJ	FACTOR (TA	BLE A)		9.11	1		\$	0.
			ED SAVING/(\$	0.
	C. TOTAL NO) (3A2+3	Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3D	I IS I IS I IS 1B	N ENERGY QU NON ENERGY = OR > 3C GO < 3C CALC IS = > 1 GO T S < 1 PROJEC	CALC (2F5 TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 ⊦3D1)/1	F)=	\$	311.		
4.	FIRST YEAR D	OLI	AR SAVINGS	2F3+3A+(3	B1D/(Y	EARS ECON	NOMIC L	IFE))	\$	103.
5.	TOTAL NET DI	SCO	OUNTED SAV	INGS (2F5+	3C)				\$	943.
6.	DISCOUNTED (IF < 1 PROJEC	SA\ CT [/INGS RATIO DOES NOT QL	JALIFY)		(SIR)=(5 / 1F	=)=	0.02		
7.	SIMPLE PAYBA	CK	PERIOD (ES	TIMATED)	SPB=	1F/4		521.87		



~

	P F	L ENERGY ISTALLATION & LO ROJECT NO. & TITI ISCAL YEAR 1990 NALYSIS DATE: 0	LE: 1496 DIS	ION INVES TLEAVEN CRETE POI	TMENT WORTH RTION I	PROGRAM (EGION NOS. 39	7	TUDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
	1.	INVESTMENT A. CONSTRUCTI B. SIOH C. DESIGN COS D. ENERGY CRE E. SALVAGE VAI F. TOTAL INVES	T EDIT CALC (14 LUE COST		9			\$ \$ \$ \$ \$ \$ \$	59685. 3581. 3283. 59894. 0. 59894.
	2.	ENERGY SAVING ANALYSIS DATE	ANNUAL SAV	(-) INGS, UNIT	COST	& DISCOUNT	ED SAVINGS		
		FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)	ANNUAL \$ SAVINGS(3)	DISCOUN		DISCOUNTED SAVINGS(5)
		A. ELECT \$ B. DIST \$ C. RESID \$ D. NAT G \$ E. COAL \$	2.00 .00 .00 343.24 .00	11. 0. 0. 5. 0.	\$ \$ \$ \$ \$	22. 0. 0. 1716. 0.	8.0 12.4 12.2 11.6 10.3	42 21 67	191. 0. 0. 20026. 0.
9		F. TOTAL		16.	\$	1738.		\$	20217.
	3.	NON ENERGY SA	VINGS(+) / CC	DST(-)					
		A. ANNUAL RECU (1) DISCOUNT	Γ FACTOR (ΤΑ	BLE A)		9.11		\$	0.
		(2) DISCOUNT	TED SAVING/C	OST (3A X				\$	0.
		C. TOTAL NON E					(3A2+3Bd4)	\$	0.
		B IF 3D1 IS C IF 3D1B	N ENERGY QL NON ENERGY = OR > 3C G(< 3C CALC \$ IS = > 1 GO T(IS < 1 PROJEC	CALC (2F5) TO ITEM 4 SIR = (2F5+) ITEM 4	X .33) I 3D1)/1I	-)=	\$ 667	2.	
	4.	FIRST YEAR DOLI	LAR SAVINGS	2F3+3A+(3	B1D/(YI	EARS ECONO	OMIC LIFE))	\$	1738.
	5.	TOTAL NET DISCO	OUNTED SAVI	NGS (2F5+3	BC)			\$	20217.
	6.	DISCOUNTED SAV (IF < 1 PROJECT [IALIFY)	1	(SIR)=(5 / 1F)	= 0.3	4	
	7.	SIMPLE PAYBACK	(PERIOD (ES	FIMATED)	SPB=	F/4	34.4	6	





INSTALLATION & PROJECT NO. & FISCAL YEAR 19 ANALYSIS DATE	RGY CONSERVA LOCATION: FO TITLE: 1496 90 DIS : 03-30-90	OST ANALYSIS FION INVESTMI RT LEAVENWO SCRETE PORTI ECONOMIC I	ENT PROG PRTH - US ON NAME:	RAM (EC DB REGI 465M39	IP) ON NOS. 7 PREPARED	L	Y: USDBAE CCID 1.035 CENSUS: 2 B
E. SALVAGE	ICTION COST OST CREDIT CALC (1)	-				\$ \$ \$ \$ \$ \$ \$ \$	39012. 2341. 2146. 39149. 0. 39149.
2. ENERGY SAV ANALYSIS DA	INGS (+) / COST TE ANNUAL SAV	(-) 'INGS, UNIT CC	ST & DISC		SAVINGS		
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		AL \$ IGS(3)	DISCOUNT FACTOR(4)		COUNTED VINGS(5)
A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	11. 0. 0. 296. 0.	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	137. 0. 0. 1208. 0.	8.69 12.42 12.21 11.67 10.36		1191. 0. 0. 14097. 0.
F. TOTAL		307.	\$	1345.		\$	15288.
3. NON ENERGY	' SAVINGS(+) / C	OST(-)					
A. ANNUAL R	ECURRING (+/-) UNT FACTOR (TA			9.11		\$	0.
(2) DISCO	UNTED SAVING/	COST (3A X 3A	\1)	9.11		\$	0.
C. TOTAL NO	N ENERGY DISC	OUNTED SAVIN	NGS(+) /CO	ST(-) (3A	2+3Bd4)	\$	0.
(1) 25% MA A IF 3D [.] B IF 3D C IF 3D	NON ENERGY QU AX NON ENERGY 1 IS = OR > 3C G 1 IS < 3C CALC 1B IS = > 1 GO T 1B IS < 1 PROJEC	CALC (2F5 X O TO ITEM 4 SIR = (2F5+3D O ITEM 4	.33) 1)/1F}=	\$	5045.		
4. FIRST YEAR D	OLLAR SAVINGS	3 2 F3+3A+(3 B1[)/(YEARS E	ECONOMI	C LIFE))	\$	1345.
5. TOTAL NET DI	SCOUNTED SAV	INGS (2F5+3C)				\$	15288.
6. DISCOUNTED (IF < 1 PROJEC	SAVINGS RATIO CT DOES NOT QU	JALIFY)	(SIR)=(5 / 1F)=	0.39		
7. SIMPLE PAYBA	ACK PERIOD (ES	TIMATED) SF	PB=1F/4		29.11		



ECO-M39

*,

P F	ENER ISTALLATION 8 ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY LOC TITL 90	E: 1496 DIS	FION INVES RT LEAVEN SCRETE PO	STMENT PF IWORTH - DRTION NA	OGRAM (FO	BION NOS.	7	CUDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	ICTK OST CREI VAL	DIT CALC (1. UE COST		.9			\$ \$ \$ \$ \$ \$	159692. 9582. 8783. 160251. 0. 160251.
2.	ENERGY SAV ANALYSIS DA	ING:	S (+) / COST NNUAL SAV	(-) 'INGS, UNIT	COST & E	SCOUNTE	D SAVINGS		
	FUEL		JNIT COST S/MBTU(1)	SAVINGS MBTU/YR		INUAL \$ VINGS(3)	DISCOUI FACTOR		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	20. 0. 0. 146. 0.	\$ \$ \$	249. 0. 0. 596. 0.	8. 12. 12. 11. 11.	21 67	2164. 0. 0. 6955. 0.
	F. TOTAL			166.	\$	845.		\$	9119.
3.	NON ENERGY	SAV	/INGS(+) / C0	OST(-)					
	A. ANNUAL R (1) DISCO	ECU UNT	RRING (+/-) FACTOR (TA			9.11		\$	0.
	(2) DISCO	UNTI	ED SAVING/	COST (3A X	(3A1)	3.11		\$	0.
	C. TOTAL NO	NEN	IERGY DISC	OUNTED SA	AVINGS(+)	/COST(-) (3	A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX N 1 IS : 1 IS : 01B I	ENERGY QU ON ENERGY = OR > 3C G < 3C CALC S = > 1 GO T S < 1 PROJEC	' CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .33) 4 +3D1)/1F)=		\$ 300	9.	
4.	FIRST YEAR D	OLL	AR SAVINGS	5 2F3+3A+(3	3B1D/(YEAI	RS ECONON	AIC LIFE))	\$	845.
5.	TOTAL NET DI	sco	UNTED SAV	INGS (2F5+	-3C)			\$	9119.
6.	DISCOUNTED (IF < 1 PROJEC	SAV CT D	INGS RATIO OES NOT QU	JALIFY)	(SII	R)=(5 / 1F)=	0.0	6	
7.	SIMPLE PAYB	АСК	PERIOD (ES	TIMATED)	SPB=1F/4	\$	189.6	5	



ENEF INSTALLATION & PROJECT NO. & FISCAL YEAR 19 ANALYSIS DATE	TITLE: 1496 90	ION INVESTM	IENT PRO ORTH - L	GRAM (EC JSDB REGI E: 473M39	ION NOS. 7	LC	Y: USDBAE CCID 1.035 CENSUS: 2
1. INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE	- ICTION COST	A+1B+1C)X.9		LARS	PREPARED	BY: CHI \$ \$ \$ -\$ \$	86261. 5176. 4744. 86563. 0. 86563.
2. ENERGY SAV ANALYSIS DA	(INGS (+) / COST TE ANNUAL SAV	(-) INGS, UNIT C	OST & DIS	SCOUNTED	SAVINGS	·	
FUEL	UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR(2)		IUAL \$ 'INGS(3)	DISCOUNT FACTOR(4)		COUNTED /INGS(5)
A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	17. 0. 0. 0. 0.	\$\$ \$\$ \$\$ \$	211. 0. 0. 0. 0.	8.69 12.42 12.21 11.67 10.36		1834. 0. 0. 0. 0.
F. TOTAL		17.	\$	211.		\$	1834.
3. NON ENERGY	SAVINGS(+) / CO	OST(-)					
(1) DISCO	ECURRING (+/-) UNT FACTOR (TA			9.11		\$	0.
(2) DISCO	UNTED SAVING/C	COST (3A X 3	•			\$	0.
	N ENERGY DISC			OST(-) (3A	\2+3Bd4)	\$	0.
(1) 25% MA A IF 3D B IF 3D C IF 3D	NON ENERGY QU AX NON ENERGY 1 IS = OR > 3C G(1 IS < 3C CALC 3 11B IS = > 1 GO T 1B IS < 1 PROJEC	CALC (2F5 X D TO ITEM 4 SIR = (2F5+3E O ITEM 4	⊂.33) D1)/1F)=	\$	605.		
4. FIRST YEAR D	OLLAR SAVINGS	2F3+3A+(3B1	D/(YEARS		IC LIFE))	\$	211.
5. TOTAL NET DI	SCOUNTED SAV	NGS (2F5+3C))			\$	1834.
	SAVINGS RATIO CT DOES NOT QU	JALIFY)	(SIR)	=(5 / 1F)=	0.02	:	
7. SIMPLE PAYBA	ACK PERIOD (ES	TIMATED) S	PB=1F/4		410.25		



.

	PR FIS	ENEF TALLATION 8 DJECT NO. & CAL YEAR 19 ALYSIS DATE	RGY LC TIT 90	CATION: FO LE: 1496 DIS	TION INVES RT LEAVEN SCRETE PO		IT P TH N NA	ROGRAM (EC	ION NOS. 7		UDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
-		INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY (E. SALVAGE F. TOTAL INV		T DIT CALC (1 LUE COST		.9				0000000000000000000000000000000000000	97188. 5831. 5345. 97528. 0. 97528.
2	2.	ENERGY SAV ANALYSIS DA		IS (+) / COST ANNUAL SA\	(-) /INGS, UNIT	cos	Т&	DISCOUNTED) SAVINGS		
	1	FUEL		UNIT COST \$/MBTU(1)	SAVINGS MBTU/YR		A S	NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		DISCOUNTED SAVINGS(5)
	 (A. ELECT 3. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	20. 0. 0. 0.		\$ \$ \$ \$ \$	249. 0. 0. 0. 0.	8.69 12.42 12.21 11.67 10.36		2164. 0. 0. 0. 0.
	F	F. TOTAL			20.		\$	249.		\$	2164.
3	. 1	NON ENERGY	' SA	VINGS(+) / C	OST(-)						
	ļ	A. ANNUAL R	ECI	JRRING (+/-) FACTOR (T/				0.11		\$	0.
		(2) DISCO	UNT	ED SAVING/	COST (3A X	(3A1))	9.11		\$	0.
	C	C. TOTAL NO	ΝE	NERGY DISC	OUNTED SA	AVING	iS(+))/COST(-) (3/	A2+3Bd4)	\$	0.
	0	A IF 3D B IF 3D C IF 3D	AX N 1 IS 1 IS 1 IS	I ENERGY Q ION ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T S < 1 PROJE	CALC (2F5 O TO ITEM SIR = (2F5- O ITEM 4	5 X .3: 4 +3D1)/	3) '1F)=		5 714.		
· 4.	F	IRST YEAR D	OLI		3 2F3+3A+(3	B1D/(`	YEA	RS ECONOM	IC LIFE))	\$	249.
5.	Т	OTAL NET DI	sco	OUNTED SAV	INGS (2F5+	3C)				\$	2164.
6.	D (I	ISCOUNTED F < 1 PROJEC	SA\ CT [/INGS RATIO OES NOT QI	JALIFY)		(Si	IR)=(5 / 1F)=	0.02		
7.	S	IMPLE PAYBA	ACK	PERIOD (ES	TIMATED)	SPB₌	=1F/	′ 4	391.68		



P F	ENEI STALLATION & ROJECT NO. & ISCAL YEAR 19 NALYSIS DATE	RGY & LO TITI 190	E: 1496. 	TION INVES RT LEAVEN SCRETE PC	STMENT P WORTH	ROGRAM (F	GION NOS. 7 39	L	DY: USDBAE CCID 1.035 CENSUS: 2
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY E. SALVAGE F. TOTAL INV	JCTI COST CRE VAL	T DIT CALC (1. .UE COST		. .9			\$ \$ \$ \$ \$ \$	61228. 3674. 3368. 61443. 0. 61443.
2.	ENERGY SAV ANALYSIS DA	/ING	S (+) / COST ANNUAL SAV	(-) 'INGS, UNIT	COST &	DISCOUNTE	D SAVINGS		
	FUEL		UNIT COST \$/MBTU(1)		5 А	NNUAL \$ AVINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	12. 0. 0. 0.	\$ \$ \$	149. 0. 0. 0. 0.	8.69 12.42 12.21 11.67 10.36		1295. 0. 0. 0. 0.
	F. TOTAL			12.	\$	149.		\$	1295.
3.	NON ENERGY	Y SA	VINGS(+) / C	OST(-)					
	A. ANNUAL R		JRRING (+/-) FACTOR (TA			0.11		\$	0.
	(2) DISCO	UNT	ED SAVING/	COST (3A >	(3A1)	9.11		\$	0.
	C. TOTAL NO	N EI	NERGY DISC	OUNTED S	AVINGS(+)/COST(-) (3	3A2+3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX N 1 IS 1 IS 01B	I ENERGY QU ION ENERGY = OR > 3C G < 3C CALC IS = > 1 GO T S < 1 PROJE(' CALC (2F5 O TO ITEM SIR = (2F5 O ITEM 4	5 X .33) 4 +3D1)/1F):		\$ 427.		Ľ
4.	FIRST YEAR D	OLL	AR SAVINGS	5 2F3+3A+(3	3B1D/(YEA	ARS ECONO	MIC LIFE))	\$	149.
	TOTAL NET D							\$	1295.
6.	DISCOUNTED (IF < 1 PROJEC	SAV CT D	VINGS RATIO	JALIFY)	(S	IR)=(5 / 1F)=	0.02		
7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F	/4	412.37		



•

P Fi	ISTALLATION & ROJECT NO. & ISCAL YEAR 19		TION INVES RT LEAVEN SCRETE POI	TMENT PRO WORTH -	OGRAM (ECUSDB REG	110N NOS. 7	Ĺ	DY: USDBAE CCID 1.035 CENSUS: 2
	B. SIOH C. DESIGN C D. ENERGY E. SALVAGE F. TOTAL INV	UCTION COST	IE)	9			\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	46915. 2815. 2580. 47079. 0. 47079.
	ANALYSIS DA	ATE ANNUAL SAV	NNGS, UNIT	COST & DI	SCOUNTED	SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)			NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)		SCOUNTED VINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	9. 0. 0. 0.	\$ \$ \$ \$ \$ \$ \$	112. 0. 0. 0. 0.	8.69 12.42 12.21 11.67 10.36		973. 0. 0. 0. 0.
	F. TOTAL		9.	\$	112.		\$	973.
3.	NON ENERGY	Y SAVINGS(+) / C	OST(-)					
	A. ANNUAL R	RECURRING (+/-) OUNT FACTOR (T/			0.44		\$	0.
	(2) DISCO	OUNTED SAVING	COST (3A X	3A1)	9.11		\$	0.
	C. TOTAL NO	ON ENERGY DISC	OUNTED SA	VINGS(+)/	COST(-) (3	A2+3Bd4)	\$	0.
	(1) 25% M. A IF 3D B IF 3D C IF 3I	NON ENERGY Q IAX NON ENERGY D1 IS = OR > 3C G D1 IS < 3C CALC D1B IS = > 1 GO T D1B IS < 1 PROJE	/ CALC (2F5 O TO ITEM 4 SIR = (2F5+ O ITEM 4	X .33) I 3D1)/1F)=		\$ 321. 		
4.	FIRST YEAR [DOLLAR SAVING	S 2F3+3A+(3	B1D/(YEAF	S ECONOM	IC LIFE))	\$	112.
5.	TOTAL NET D	SCOUNTED SAV	'INGS (2F5+:	BC)			\$	973.
6.		SAVINGS RATIO		(SIF	?)=(5 / 1F)=	0.02		
7.	SIMPLE PAYB	ACK PERIOD (ES	TIMATED)	SPB=1F/4		420.35		





.

CONSTRUCTION COST ESTIMATE			DATEP	REPARED	4/2/9	h	SHEET OF
PROJECT USDB ENERGY STUDY	<u></u>		L	BASIS FOR	ESTIMATE		11
LOCATION				+ x	CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS ARCHITECT/ENGINEER			<u></u>			(PRELIMINAF	RY DESIGN)
CLARK RICHARDSON & BISKI	JP	••• *				(FINAL DESIC	GN)
DRAWING NO. NONE		ESTIM	ATOR	.		CHECKED B	Y
ECO-M39		ANTITY	Γ <u></u>	MJM MATERIAL		ABOR	MAW
WATER HEATING HEATPUMPS	NO.	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	TOTAL COST
BUILDING 450, 32 TONS OF COOLING,						· .	
FLUID COOLER LOCATED ON NORTH SIDE							
OF BUILDING, PUMP IN EXISTING							
MECHANICAL ROOM, COST ON A SQUARE							
FOOT BASIS.	9200	SQFT	\$3	\$23,276	\$2	\$14,352	\$37
DEMOLISH EXISTING HVAC EQUIPMENT.			· · · · · · · · ·				
COST ON A SQUARE FOOT BASIS.	9200	SOFT			\$1	\$11,500	\$11,
and the second of the second secon	an _e to si	1999 - S.	t gada.			eger e	¥
	1.4		•				
						s	
				• • • • •			
	ng at ago da ser T		· · · · · ·	· · · · · · · · · · · · · · · · · · ·			
SUBTOTAL				\$23,276		\$25,852	\$49,1
CONTINGENCY 10%			10%	\$2,328	10%	\$2,585	\$4,9
SUBTOTAL				\$25,604		\$28,437	\$54,
VORK COMP, TAX, SOC.SEC., INS	·		3.50%	\$896	13.0%	\$3,697	\$4,5
		<u> </u>		\$26,500		\$32,134	\$58,0
			25%	\$6,625	25%	\$8,034	\$14,6
SUBTOTAL		2		\$33,125		\$40,168	\$73,2
CONSTRUCTION COST							\$73,2

.

1AVC-59



BAL (* 768 242 GAL

1

and the second sec

and the second sec

CONSTRUCTION COST ESTIMATE				REPARED	~	SHEET OF	
PROJECT USDB ENERGY STUDY				BASIS FOR	4/2/9 ESTIMATI		2 9
LOCATION FORT LEAVENWORTH, KS				x		(NO DESIGN	COMPLETED)
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL					CODE C	(PRELIMINAF	ty design) 3N)
DRAWING NO.		ESTIM	ATOR	L	OTHER	(SPECIFY)	Y
ECO-M39	QU	ANTITY	N	MJM IATERIAL	1	LABOR	MAW TOTAL
WATER HEATING HEATPUMPS	NO. UNITS	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	COST
BUILDING 463 , 22 TONS OF COOLING,							
FLUID COOLER LOCATED ON NORTH SIDE							
OF BUILDING, PUMP IN EXISTING	L						
HEAT EXCHANGER ROOM, COST ON A							
SQUARE FOOT BASIS.	7700	SQFT	\$3	\$19,481	\$2	\$12,012	\$31,493
DEMOLISH EXISTING HVAC EQUIPMENT,							
COST ON A SQUARE FOOT BASIS.	7700	SQFT			\$1	\$4,620	\$4,620
							·
							······
SUBTOTAL				\$19,481		\$16,632	\$36,113
CONTINGENCY 10%			10%	\$1,948	10%	\$1,663	\$3,611
SUBTOTAL				\$21,429		\$18,295	\$39,724
VORK COMP, TAX, SOC. SEC., INS			3.50%	\$750	13.0%	\$2,378	\$3,128
DIRECT COST				\$22,179		\$20,673	\$42,852
			25%	\$5,545	25%	\$5,168	\$10,713
				\$27,724		\$25,841	\$53,565
CONSTRUCTION COST							\$53,565

.





CONSTRUCTION COST ESTIMATE					DATE PREPARED 4/2/90				
PROJECT USDB ENERGY STUDY				BASIS FOR			3 9		
FORT LEAVENWORTH, KS				x	CODE B	(NO DESIGN (PRELIMINAF	COMPLETED) RY DESIGN)		
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKU	IP				_CODE C	(FINAL DESIC (SPECIFY)	GN)		
DRAWING NO. NONE	<u>.</u>	ESTIM	ATOR	L		CHECKED B			
ECO-M39	QU.	ANTITY	N	MJM IATERIAL		L ABOR	MAW TOTAL		
WATER HEATING HEATPUMPS	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST		
BUILDING 464, 26 TONS OF COOLING,									
FLUID COOLER LOCATED ON NORTH SIDE									
OF BUILDING, PUMP IN EXISTING									
FIRST FLOOR CLOSET, COST ON A									
SQUARE FOOT BASIS.	6700	SQFT	\$3	\$22,043	\$2	\$14,204	\$36,247		
DEMOLISH EXISTING HVAC EQUIPMENT,									
COST ON A SQUARE FOOT BASIS.	6700	SQFT			\$1	\$4,020	\$4,020		
				•					
SUBTOTAL				\$22,043		\$18,224	\$40,267		
CONTINGENCY 10%			10%	\$2,204	10%	\$1,822	\$4,026		
SUBTOTAL				\$24,247		\$20,046	\$44,293		
WORK COMP, TAX, SOC.SEC., INS			3.50%	\$849	13.0%	\$2,606	\$3,455		
DIRECT COST				\$25,096		\$22,652	\$47,748		
OVERHEAD AND PROFIT			25%	\$6,274	25%	\$5,663	\$11,937		
SUBTOTAL				\$31,370		\$28,315	\$59,685		
CONSTRUCTION COST							\$59,685		

بالاعتبار البيع بالحاصية بالعريبيين

البسا يحتجب والبيلي ويرجحج وتستهمتهم ستطامه ششائر الرزير ليس





.

بمستملح الأرافية ودواري والمرد المنتاج مارونية والمتروي ويملوه المراكب الرامطولوميور بالمتوسية والعمو

INSTRUCTION COST ESTIMATE		DATE PREPARED				SHEET OF		
PROJECT	СТ				SHEET OF 4 9			
USDB ENERGY STUDY				BASIS FOR	ESTIMATE			
LOCATION FORT LEAVENWORTH, KS				<u> </u>		(NO DESIGN	COMPLETED)	
ARCHITECT/ENGINEER		· · · · · ·			CODE B	(PRELIMINAF	IY DESIGN) GN)	
CLARK RICHARDSON & BISKU DRAWING NO.	IP	ESTIM	ATOR		OTHER	(SPECIFY)		
NONE ECO-M39				МЈМ			MAW	
WATER HEATING HEATPUMPS	NO.	ANTITY	PER	ATERIAL TOTAL	PER	ABOR TOTAL	TOTAL COST	
	UNITS	MEAS.	UNIT		UNIT			
BUILDING 465, 17 TONS OF COOLING,								
FLUID COOLER LOCATED ON WEST SIDE								
OF BUILDING, PUMP IN EXISTING					ļ			
MECHANICAL ROOM, COST ON A SQUARE								
FOOT BASIS.	4897	SQFT	\$3	\$12,389	\$2	\$7,639	\$20,029	
DEMOLISH EXISTING HVAC EQUIPMENT,								
COST ON A SQUARE FOOT BASIS.	4897	SQFT			\$1	\$6,121	\$6,121	
	-							
SUBTOTAL				\$12,389		\$13,761	\$26,150	
CONTINGENCY 10%			10%	\$1,239	10%	\$1,376	\$2,615	
SUBTOTAL				\$13,628		\$15,137	\$28,765	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$477	13.0%	\$1,968	\$2,445	
				\$14,105		\$17,105	\$31,210	
VERHEAD AND PROFIT			25%	\$3,526	25%	\$4,276	\$7,802	
SUBTOTAL				\$17,631		\$21,381	\$39,012	
CONSTRUCTION COST NG. FORM 150				<u> </u>			\$39,012	

1AVC-59





• ~

الييوسيوو سيوسونا أراط مسجيسة وتحور فنقو والتحاب بالتحوير الالترار الراران

~.

CONSTRUCTION COST ESTIMATE DATE PRE				REPARED		SHEET OF 5 9		
PROJECT					4/2/90 BASIS FOR ESTIMATE			
	OCATION					(NO DÉSIGN	COMPLETED)	
FORT LEAVENWORTH, KS				X	_CODE B	(PRELIMINAF (FINAL DESIC	RY DESIGN)	
CLARK RICHARDSON & BISKUP DRAWING NO. NONE					OTHER	(SPECIFY)		
•				МЈМ		CHECKED B	MAW	
WATER HEATING HEATPUMPS	NO.	ANTITY UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	LABOR TOTAL	TOTAL COST	
BUILDING 472, 69 TONS OF COOLING,						-		
FLUID COOLER LOCATED ON SOUTH SIDE								
OF BUILDING, PUMP IN EXISTING								
MECHANICAL ROOM, COST ON A SQUARE								
FOOT BASIS.	19300	SQFT	\$3	\$58,479	\$2	\$37,635	\$96,114	
DEMOLISH EXISTING HVAC EQUIPMENT,								
COST ON A SQUARE FOOT BASIS.	19300	SQFT			\$1	\$11,580	\$11,580	
SUBTOTAL				\$58,479		\$49,215	\$107,694	
CONTINGENCY 10%			10%	\$5,848	10%	\$4,922	\$10,770	
SUBTOTAL				\$64,327		\$54,137	\$118,464	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$2,251	13.0%	\$7,038	\$9,289	
DIRECT COST				\$66,578		\$61,175	\$127,753	
VERHEAD AND PROFIT			25%	\$16,645	25%	\$15,294	\$31,939	
SUBTOTAL				\$83,223		\$76,469	\$159,692	
CONSTRUCTION COST NG. FORM 150							\$159,692	





and and a state of the state of

لديد بالمحس

CONSTRUCTION COST ESTIMATE DATE PREP				REPARED	SHEET OF 6 9			
ROJECT BA					4/2/90 BASIS FOR ESTIMATE			
FORT LEAVENWORTH, KS	x	CODE B	(NO DESIGN (PRELIMINAF	COMPLETED)				
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKL	ιÞ				_CODE C	(FINAL DESIC	GN)	
DRAWING NO. ESTIMATO			ATOR	1	UTHER			
ECO-M39 WATER HEATING HEATPUMPS		ANTITY		MJM IATERIAL		LABOR	MAW TOTAL	
	NO. ÚNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 473, 39 TONS OF COOLING,								
FLUID COOLER LOCATED ON NORTH SIDE								
OF BUILDING, PUMP IN BLDG 463								
MECHANICAL ROOM, COST ON A SQUARE								
FOOT BASIS.	12400	SQFT	\$3	\$31,372	\$2	\$19,344	\$50,71	
DEMOLISH EXISTING HVAC EQUIPMENT,								
COST ON A SQUARE FOOT BASIS.	12400	SQFT			\$1	\$7,440	\$7,44	
							•	
							······	
SUBTOTAL				\$31,372		\$26,784	\$58,156	
CONTINGENCY 10%			10%	\$3,137	10%	\$2,678	\$5,815	
SUBTOTAL				\$34,509		\$29,462	\$63,971	
VORK COMP, TAX, SOC.SEC., INS			3.50%	\$1,208	13.0%	\$3,830	\$5,038	
DIRECT COST				\$35,717		\$33,292	\$69,009	
VERHEAD AND PROFIT			25%	\$8,929	25%	\$8,323	\$17,252	
SUBTOTAL				\$44,646		\$41,615	\$86,261	
CONSTRUCTION COST							\$86,261	

ма 1910 година. С

...

رايات مستقدية مرافيا با





.

CONSTRUCTION COST ESTIMATE	TON COST ESTIMATE DATE PR			REPARED		SHEET OF	
PROJECT				BASIS FOR	4/2/90 ESTIMATE		7 9
				x	CODE A	(NO DESIGN	COMPLETED)
FORT LEAVENWORTH, KS						(PRELIMINAF	RY DESIGN) GN)
CLARK RICHARDSON & BISKU DRAWING NO.	IP	ESTIM	ATOR		OTHER	(SPECIFY)	Y
NONE ECO-M39		ANTITY	1 N	MJM IATERIAL	1	1	MAW
WATER HEATING HEATPUMPS	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	_ABOR TOTAL	TOTAL COST
BUILDING 475A , 39 TONS OF COOLING,							
FLUID COOLER LOCATED ON NORTH SIDE			-				
OF CASTLE, PUMP IN ROTUNDA							
MECHANICAL ROOM, COST ON A SQUARE							
FOOT BASIS.	11746	SQFT	\$3	\$35,590	\$2	\$22,905	\$58,495
DEMOLISH EXISTING HVAC EQUIPMENT,							
COST ON A SQUARE FOOT BASIS.	11746	SQFT			\$1	\$7,048	\$7,048
							······································
SUBTOTAL				\$35,590		\$29,952	\$65,543
CONTINGENCY 10%			10%	\$3,559	10%	\$2,995	\$6,554
SUBTOTAL				\$39,149		\$32,947	\$72,097
WORK COMP, TAX, SOC.SEC., INS			3.50%	\$1,370	13.0%	\$4,283	\$5,653
DIRECT COST				\$40,519		\$37,230	\$77,750
OVERHEAD AND PROFIT			25%	\$10,130	25%	\$9,308	\$19,438
SUBTOTAL				\$50,649		\$46,538	\$97,188
CONSTRUCTION COST ENG. FORM 150							\$97,188



1	
	, di

······

CONSTRUCTION COST ESTIMATE DATE PRI				REPARED		SHEET OF		
PROJECT	Т					<u>0</u>	8 9	
USDB ENERGY STUDY				BASIS FOR	ESTIMATE	3		
LOCATION FORT LEAVENWORTH, KS ARCHITECT/ENGINEER				X	_CODE B	(PRELIMINAF	COMPLETED) RY DESIGN)	
CLARK RICHARDSON & BISKU	P			·	_CODE C	(FINAL DESIC (SPECIFY)	GN)	
DRAWING NO. NONE	<u></u>	ESTIM	ATOR		UINCH	CHECKED B	Y	
ECO-M39	QU	ANTITY	N	MJM MATERIAL	1	ABOR	MAW TOTAL	
WATER HEATING HEATPUMPS	NO. UNITS	UNIT MEAS.	PER	TOTAL	PER UNIT	TOTAL	COST	
BUILDING 475B, 28 TONS OF COOLING,								
FLUID COOLER LOCATED ON NORTH SIDE								
OF CASTLE, PUMP IN ROTUNDA								
MECHANICAL ROOM, COST ON A SQUARE								
FOOT BASIS.	7400	SQFT	\$3	\$22,422	\$2	\$14,430	\$36,852	
DEMOLISH EXISTING HVAC EQUIPMENT,								
COST ON A SQUARE FOOT BASIS.	7400	SQFT			\$1	\$4,440	\$4,440	
				·····				
SUBTOTAL				\$22,422		\$18,870	\$41,292	
ONTINGENCY 10%			10%	\$2,242	10%	\$1,887	\$4,129	
SUBTOTAL				\$24,664		\$20,757	\$45,421	
ORK COMP, TAX, SOC.SEC., INS			3.50%	\$863	13.0%	\$2,698	\$3,561	
DIRECT COST				\$25,527		\$23,455	\$48,982	
VERHEAD AND PROFIT			25%	\$6,382	25%	\$5,864	\$12,246	
SUBTOTAL				\$31,909		\$29,319	\$61,228	
CONSTRUCTION COST NG. FORM 150							\$61,228	

1AVC-59



.....

.

CONSTRUCTION COST ESTIMATE	TION COST ESTIMATE			REPARED	SHEET OF			
PROJECT USDB ENERGY STUDY				BASIS FOR	4/2/9		99	
LOCATION				x	_CODE A	(NO DESIGN	COMPLETED)	
FORT LEAVENWORTH, KS					CODE B	(PRELIMINAF (FINAL DESIC	RY DESIGN)	
CLARK RICHARDSON & BISKU DRAWING NO.	P	ESTIM	ATOR		OTHER	(SPECIFY)		
			MJM			MAW		
WATER HEATING HEATPUMPS	NO.	UNIT MEAS.	PER UNIT	ATERIAL TOTAL	PER UNIT	<u>ABOR</u> TOTAL	TOTAL COST	
BUILDING 475H, 20 TONS OF COOLING,								
FLUID COOLER LOCATED ON NORTH SIDE								
OF CASTLE, PUMP IN ROTUNDA								
MECHANICAL ROOM, COST ON A SQUARE								
FOOT BASIS.	6744	SQFT	\$3	\$17,062	\$2	\$10,521	\$27,583	
DEMOLISH EXISTING HVAC EQUIPMENT,								
COST ON A SQUARE FOOT BASIS.	6744	SQFT			\$1	\$4,046	\$4,046	
SUBTOTAL				\$17,062		\$14,567	\$31,629	
ONTINGENCY 10%			10%	\$1,706	10%	\$1,457	\$3,163	
SUBTOTAL				\$18,768		\$16,024	\$34,792	
ORK COMP, TAX, SOC. SEC., INS			3.50%	\$657	13.0%	\$2,083	\$2,740	
DIRECT COST				\$19,425		\$18,107	\$37,532	
VERHEAD AND PROFIT			25%	\$4,856	25%	\$4,527	\$9,383	
SUBTOTAL				\$24,281		\$22,634	\$46,915	
CONSTRUCTION COST NG. FORM 150 AVC-59							\$46,915	

· -

an and a second seco



ECO-E1

LIGHTING LEVELS

LIGHTING LEVELS

ENERGY CONSERVATION OPPORTUNITY: ECO-E1

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-E1) analyzes energy savings associated with lighting level reduction. Project implementation may change existing light fixture layout and new motion detector installation. Project implementation will not affect any high security area light fixtures because of associated high and material labor costs.

SCOPE:

This ECO simulation removes or relocates existing light fixtures and installs motion detectors. The application of this project was considered for the following buildings:

450 463 464 465 466	Building Building Building Building Building	473 474 475A 475B 475E
472	Building	475H
	463 464 465 466	463Building464Building465Building466Building

MODELING TECHNIQUES:

The modeling technique used to justify the existing light fixture removal or modification was the study of lighting energy usage measured in watts per square foot. Army Regulation No. 11-27, Section 3-8b; requires that during working hours, overhead lighting will be reduced to 50 foot-candles at work areas, and 10 or less foot-candles in nonworking areas as prescribed in DOD 4270.1-M. On the average, a lighting level of 50 foot-candles uses about 1.5 watts per square foot. Based on this value, our studies show that USDB lighting levels are in general at or below this level. Original lighting design made extensive use of daylighting and kept artificial lighting to a minimum Therefore, USDB lighting levels cannot be efficiently reduced by removing or modifying existing light fixtures.

Motion sensor installation can be justified in some instances, but lighting use patterns affect potential savings. Some examples of potential savings are shown on page E1-3. The modeling technique for this portion is based on low security fixtures in low security areas. Payback times for fixtures in higher security areas are significantly longer because of higher labor and material costs.



ECO-E1

PAGE E1-1

ECO IMPLEMENTATION:

As discussed in the modeling technique section, fixture and lamp removal is not recommended, so no implementation of that option will be discussed.

Motion sensor installation within a space includes the following: demolition of existing switch and associated circuitry; installation of a motion sensor and associated circuitry; and motion sensor calibration. Motion sensors should only be installed after study of lighting use patterns in that space.

SUMMARY:

We believe motion sensors can be installed at a good payback rate in conference-type rooms (may include chapels) where lighting loads are high and where the room may be unoccupied 30% of the time.

Motion sensor installation is not recommended in office spaces because lighting loads are generally low. We do not recommend motion sensor installation in spaces that are considered high security because of higher labor costs associated with those spaces.

Payback calculations for various rooms are shown on page E1-3. Only those rooms with SIR values greater than one are used in life cycle cost analysis.

Sample calculation for typical room installations are shown on page E1-4.

Life cycle cost analysis for this ECO is shown on page E1-5.



	TION SHEET			DATE	· · · · · · · · · · · · · · · · · · ·	SHEET	OF
PROJECT USDB				Mar-90 BASIS FOR			1
LOCATION	AVINGS OPPOI	TUNITY SU	RVEY	x	HAND		
FORT LEA	<u>VENWORTH, KS</u>	<u> </u>				7	
ARCHITECT/ENGINEER					CONTRACT	ror Bid	
	HARDSON & BI	<u>SKUP</u>			OTHER (SPECIFY)	
ECO MEASURE				COMPUTER) BY	CHECKED I	BY
ECO-E1					DJG		MAW
BUILDING # AND ROOM TYPE			ANNUAL				SIR
AND ROOM TYPE		ANNUAL NORMAL HOURS	ANNUAL HOURS SAVED	ANNUAL KWH SAVED	ANNUAL SAVINGS	PAYBACK IN YEARS	SIR
50 CONFERENCE ROOM		NORMAL	HOURS	KWH			SIR 1.9
AND ROOM TYPE 50 CONFERENCE ROOM 75A CONFERENCE ROOM	WATTS	NORMAL HOURS	HOURS SAVED	KWH SAVED	SAVINGS	IN YEARS	
AND ROOM TYPE 50 CONFERENCE ROOM 75A CONFERENCE ROOM 75A CHAPEL	WATTS 1280	NORMAL HOURS 2080	HOURS SAVED 624	KWH SAVED 799	SAVINGS \$33.96	IN YEARS 5.9	1.9
AND ROOM TYPE 50 CONFERENCE ROOM 75A CONFERENCE ROOM 75A CHAPEL 75E CONFERENCE ROOM	WATTS 1280 640	NORMAL HOURS 2080 2080	HOURS SAVED 624 624	KWH <u>SAVED</u> 799 399	\$33.96 \$16.96	IN YEARS 5.9 11.8	1.9 0.9
AND ROOM TYPE 50 CONFERENCE ROOM 75A CONFERENCE ROOM 75A CONFERENCE ROOM 75B CONFERENCE ROOM 75B CHAPEL	WATTS 1280 640 1620	NORMAL HOURS 2080 2080 2080	HOURS SAVED 624 624 624	KWH SAVED 799 399 1011	\$33.96 \$16.96 \$42.97	IN YEARS 5.9 11.8 4.7	1.9 0.9 2.4
	WATTS 1280 640 1620 480	NORMAL HOURS 2080 2080 2080 2080 2080	HOURS SAVED 624 624 624 624	KWH SAVED 799 399 1011 300	SAVINGS \$33.96 \$16.96 \$42.97 \$12.75	IN YEARS 5.9 11.8 4.7 15.7	1.9 0.9 2.4 0.7

ECO-E1

	CALCULATION SHEET		DATE Mar-90	SHEET	0F 1
PROJECT	USDB ENERGY SAVINGS OPPORTUNITY SURV		BASIS FOR CALC		
LOCATION	FORT LEAVENWORTH, KS			ITED	
ARCHITECT/E	NGINEER CLARK RICHARDSON & BISKUP			ACTOR BID	n
ECO MEASUR	E ECO-E1		COMPUTED BY		
AVERAGE PA WITH INFRAR	YBACK TIME FOR REPLACING EXISTING S ED MOTION SENSORS FOR VARIOUS SPA	WITCHES CES	000		
ALL COSTS A	RE BASED ON MEANS CONSTRUCTION/DE COST FOR FORT LEAVENWORTH USDB IS	MOLITION COS	ST DATA WH		
DEMO EXIS DEMO 8' EI INSTALL 20 INSTALL 40	COR INSTALLATION COST STING SWITCH BOX MT WITH WIRING D', 3/4" EMT D', #12 CONDUCTORS OTION SENSOR	\$2.66 \$5.76 \$53.60 \$13.60 \$125.00			
	ST PER INSTALLATION	\$200.62			
LIGHTING I ANNUAL LI ANNUAL C ANNUAL S	GHTING TIME OST @ \$0.0425 PER KWH AVINGS IF LIGHTS ARE OFF 30% OF TIME NSTALLATION	2E ROOM 720 WATTS 3750 HOURS \$114.75 \$34.43 \$200.62 5.8 YEARS			
LIGHTING L ANNUAL LI ANNUAL CO ANNUAL SA	GHTING TIME DST @ \$0.0425 PER KWH AVINGS IF LIGHTS ARE OFF 25% OF TIME INSTALLATION	CE ROOM 320 WATTS 3750 HOURS \$51.00 \$12.75 \$200.62 15.7 YEARS			
IN USE, ENI	AS ARE VERY DEPENDENT ON SEVERAL IT IT PRACTICES IN SWITCHING LIGHTS OFF. ERGY SAVINGS WILL BE MINIMAL. I OF TIME THAT LIGHTS WILL NOT BE IN US AL SAVINGS WILL FLUCTUATE ACCORDING	. IF PEOPLE NO	ORMALLY TURN LI	GHTS OFF W	HEN NC

PI FI	ENER STALLATION & ROJECT NO. & SCAL YEAR 199 NALYSIS DATE:	IGY CONS LOCATIO TITLE: 14 30	96 DISCF	N INVEST LEAVENV RETE POF	rment Norti Rtion	PRO	GRAM (EC	ION NO	S. 7 PARED		JDY: USDBAE LCCID 1.035 CENSUS: 2 CRB
1.	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV	CTION CO OST CREDIT C VALUE CO	ALC (1A+ OST		9			,		***	802. 48. 44. 805. 0. 805.
2.	ENERGY SAV ANALYSIS DA	INGS (+) / TE ANNU	COST (-) AL SAVIN	GS, UNIT	COST	& DIS	COUNTE	D SAVIN	IGS		
	FUEL	UNIT \$/MBT		SAVINGS /IBTU/YR(2)		UAL \$ INGS(3)		OUNT OR(4)		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ 4	.44 .00 .00 .08 .00	11. 0. 0. 0. 0.			137. 0. 0. 0. 0.		11.16 17.19 17.12 16.15 13.92		1529. 0. 0. 0. 0.
	F. TOTAL			11.	\$	5	137.			\$	1529.
3.	NON ENERGY	SAVING	S(+) / COS	T(-)							
	A. ANNUAL R (1) DISCOU						11.65			\$	0.
	(2) DISCOU	UNTED S	AVING/CO	ST (3A X	3A1)		11.05			\$	0.
	C. TOTAL NO	N ENERG	Y DISCOU	INTED SA	VINGS	S(+) /C	OST(-) (3	A2+3Bd	4)	\$	0.
	B IF 3D ⁻ C IF 3D	AX NON E 1 IS = OR 1 IS < 3C / 1B IS = >	RGY QUAI NERGY C, > 3C GO 1 CALC SIF 1 GO TO I PROJECT	ALC (2F5 FO ITEM 4 R = (2F5+ TEM 4	X .33 ¦ 3D1)/1) F)=	:	\$	505.		
4.	FIRST YEAR D	OLLAR S	AVINGS 21	F3+3A+(3l	B1D/(Y	'EARS			:))	\$	137.
5.	TOTAL NET DI	SCOUNTI	ED SAVINO	GS (2F5+3	BC)					\$	1529.
6.	DISCOUNTED (IF < 1 PROJEC			LIFY)		(SIR)₌	=(5 / 1F)=		1.90		
7.	SIMPLE PAYBA	ACK PERI	OD (ESTIN	ATED)	SPB=	1F/4			5.88		



ENERGY EFFICIENT LIGHTING SYSTEMS



ENERGY EFFICIENT LIGHTING SYSTEMS ENERGY CONSERVATION OPPORTUNITY: ECO-E2

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-E2) analyzes energy savings associated with converting existing lighting systems to energy efficient lighting systems. Project implementation may include component replacement in existing lighting systems to energy efficient units or a complete changeover to more efficient light sources.

SCOPE:

This ECO simulation replaces existing light fixture components with efficient units and replaces inefficient light source systems with efficient light source systems. The application of this project was considered for the following buildings:

. . .

Building	450	Building	475A
Building	463	Building	475B
Building	464	Building	475C
Building	465	Building	475D
Building	466	Building	475E
Building	472	Building	475F
Building	473	Building	475G
Building	474	Building	475H
Building	475	5	

MODELING TECHNIQUES:

– •• ••

The modeling technique used to justify light fixture component replacement was based on the removal of the existing light fixture component and replacement with a more efficient unit. Currently, USDB personnel are replacing 40w fluorescent lamps with 34w fluorescent lamps. Energy savings associated with the lamp change are not totally reallized until the existing ballasts are replaced with energy efficient units.

The modeling technique used to justify light source conversion was based on the removal of the existing incandescent lamp and replacement with a new fluorescent adapter and lamp.

Conversion to HID lamp sources was not investigated due to the extremely high first costs associated with the installation of HID light fixtures.





ECO IMPLEMENTATION:

<u>Option 1:</u> ECO implementation will include ballast and lamp replacement in existing light fixtures with high efficiency units as maintenance requires.

<u>Option 2:</u> Existing incandescent sources will be replaced with fluorescent lamp conversion kits and will be mounted in existing light fixtures.

SUMMARY:

Energy savings due to incandescent/fluorescent light source conversion by building are shown on Table E2.1.

Option 1 probable construction cost has been calculated on page E2-3. Based on these figures, we recommend that existing lighting components be replaced with energy efficient models only as existing components fail. This can be done during regular lighting maintenance by USDB maintenance personnel.

Option 2 probable construction cost has been calculated on page E2-4. Field work indicated that incandescent fixtures are used on a regular basis only in building 475A stairwell. We recommend replacement of these fixtures.

Life cycle costs associated with this ECO are shown on page E2-5.

Building Number 475A	MBTU/Yr. Savings	Energy Savings	Project Cost	Simple Payback	Savings to Invest Ratio
473A	8	\$100	\$131	1.24	9.00

Table E2.1



	CALCULATION SHEET	DATE Mar-90	SHEET OF
PROJECT	USDB	BASIS FOR CA	LCULATION
LOCATION	ENERGY SAVINGS OPPORTUNITY		- -
LUCATION	FORT LEAVENWORTH, KS		D IPUTER
ARCHITECT/	'ENGINEER	CON	TRACTOR BID
ECO MEASU	CLARK RICHARDSON & BISKUP		HER (SPECIFY)
	ECO-E2	COMPUTED BY DJG	
AVERAGE P	AYBACK TIME FOR RELAMPING ANI	D REBALLASTING FLUORESCENT LI	GHT FIXTURES
ALL COSTS A	ARE BASED ON MEANS CONSTRUCT	ION/DEMOLITION COST DATA	
ELECTRICITY	Y COST FOR FORT LEAVENWORTH U	JSDB IS \$0.0425 PER KWH	
ASSUME FIX	TURES ARE ON FOR 365 DAYS x 12 H	HOURS PER DAY = 4380 HOURS PER	YEAR
2 LAMP FLUC	DRESCENT LIGHT FIXTURE		
COST TO	O REBALLAST LIGHT FIXTURE O RELAMP LIGHT FIXTURE WITH 34V XOST PER FIXTURE	\$58.00 V LAMPS \$9.25 x 2 = \$18.50 \$76.50	
ELECTR 8W PER	ICITY SAVINGS LAMP x 2 LAMPS PER FIXTURE	= 16W PER FIXTURE PER F = 0.016 KWH PER FIXTUR	
\$0.0425	PER KWH x 0.016 KWH x 4380 HRS	= \$2.98 PER YEAR	
TOTAL C	<u>PAYBACK</u> COST PER FIXTURE ICITY SAVINGS PER YEAR PAYBACK IN YEARS	\$76.50 \$2.98 25.7	
LAMP FLUO	RESCENT LIGHT FIXTURE		
COST TO	D REBALLAST LIGHT FIXTURE D RELAMP LIGHT FIXTURE WITH 34W OST PER FIXTURE	\$58.00 x 2 = \$116.00 / LAMPS \$9.25 x 4 = \$37.00 \$153.00	
ELECTRI 8W PER	ICITY SAVINGS LAMP x 4 LAMPS PER FIXTURE	= 32W PER FIXTURE PER H	
\$0.0425	PER KWH x 0.032 KWH x 4380 HRS	= 0.032 KWH PER FIXTUR = \$5.97 PER YEAR	E
	<u>PAYBACK</u> OST PER FIXTURE CITY SAVINGS PER YEAR	\$153.00 \$5.97	

CALCULATION SHEET		DATE		SHEET	0F
PROJECT USDB	·	Mar-90 BASIS FOR CA			1
ENERGY SAVINGS OPPORTUNIT	Y SURVEY	BASIS FOR CA	LCOLAIN		
LOCATION		X	HAND		
FORT LEAVENWORTH, KS			COMPUT		
ARCHITECT/ENGINEER CLARK RICHARDSON & BISKUP			CONTRA		
ECO MEASURE		COMPUTED B		(SPECIFY) CHECKED	PV
ECO-E2		COMIN OTED D	DJG	UNEUKED	MAW
CALCULATIONS FOR RETROFITTING INCANDE BUILDING 475A STAIRWELL	<u>SCENT FIXT</u>	URES TO FLUO	RESCENT	FIXTURES	
ALL COSTS ARE BASED ON MEANS CONSTRUC	TION/DEMO	LITION COST D	ΑΤΑ		
ELECTRICITY COST FOR FORT LEAVENWORTH					
ASSUME FIXTURES ARE ON FOR 365 DAYS x 24	HOURS PEI	R DAY = 8760 H	OURS PER	R YEAR	
DESCRIPTION	NUMBER	INSTALLED	TOTAL	ENERGY	TOTAL
ADAPTER BALLAST	(EACH)	COST	COST	USE (W)	ENERGY USE
13W DOUBLE TWIN TUBE FLUORESCENT LAMP	6 6	\$11.00	\$66	3	18
LABOR	6	\$5.84 \$3.75	\$35 \$23	<u>13</u> 0	<u>78</u> 0
TOTAL			\$124	0	0.096KW
					<u> </u>
EXISTING ELECTRICITY USAGE = 6 LAMPS x 60V	V PER LAMP	= 360 W OR .36	6KW/H		•
NEW ELECTRICITY USAGE = 0.096 KW/H					
TOTAL ELECTRICTY SAVED = 0.36 KW/H - 0.096 I	KW/H = 0.264	i KW/H			
YEARLY SAVINGS = 0.264 KW/H x \$0.0425 /KWH	x 8760 HOLU				
	x 0/00 HOU	NG/ 1 EAN = \$90.	29 PER 10	AR	

P FI	ISTALLATION ROJECT NO. 8 SCAL YEAR 11	LIFE CYCLE C ERGY CONSERVA & LOCATION: FO & TITLE: 1496 990 DIS	TION INVEST RT LEAVEN SCRETE POF	IMENT PR WORTH - RTION NAM	OGRAM (EC USDB REC 1E: ECOE2	GION NOS. 7	LC	Y: USDBAE CID 1.035 CENSUS: 2
A	VAL 1515 DATE	E: 03-23-90	ECONOM	IC LIFE 25	YEARS	PREPARED	BY: CRE	3
1.	B. SIOH C. DESIGN D. ENERGY E. SALVAGE	RUCTION COST		9			\$ \$ \$ \$ \$ \$ \$	124. 7. 124. 0. 124.
2.	ENERGY SA ANALYSIS D	VINGS (+) / COST DATE ANNUAL SAV	(-) /INGS, UNIT	COST & D	ISCOUNTE	D SAVINGS		
	FUEL	UNIT COST \$/MBTU(1)			NUAL \$ VINGS(3)	DISCOUNT FACTOR(4)	-	COUNTED /INGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ 12.44 \$.00 \$.00 \$ 4.08 \$.00	8. 0. 0. 0.	\$ \$ \$ \$ \$	100. 0. 0. 0. 0.	11.16 17.19 17.12 16.15 13.92		1116. 0. 0. 0. 0.
	F. TOTAL		8.	\$	100.		\$	1116.
3.	NON ENERG	GY SAVINGS(+) / C	OST(-)					
	A. ANNUAL	RECURRING (+/-)					\$	0.
	(1) DISCO	OUNT FACTOR (Ť. OUNTED SAVING/	ABLE A) COST (3A -X	341)	11.65		* \$	0.
		ON ENERGY DISC		•			↓ \$	
	D. PROJECT (1) 25% M A IF 31 B IF 31 C IF 3	T NON ENERGY Q MAX NON ENERG D1 IS = OR > 3C G D1 IS < 3C CALC 3D1B IS = > 1 GO 3D1B IS < 1 PROJE	UALIFICATIO Y CALC (2F5 O TO ITEM 4 SIR = (2F5+ FO ITEM 4	DN TEST X .33) 4. -3D1)/1F)=		\$ 368. 	φ	0.
4.	FIRST YEAR	DOLLAR SAVING	S 2F3+3A+(3	B1D/(YEAF	RS ECONO	VIC LIFE))	\$	100.
5.	TOTAL NET I	DISCOUNTED SAV	/INGS (2F5+	3C)			\$	1116.
6.	DISCOUNTEI (IF < 1 PROJI	D SAVINGS RATIO) UALIFY)	(SII	R)=(5 / 1F)=	9.00		
7.	SIMPLE PAY	BACK PERIOD (E	STIMATED)	SPB=1F/4	1	1.24		



ENERGY EFFICIENT MOTORS





ENERGY EFFICIENT MOTORS

ENERGY CONSERVATION OPPORTUNITY: ECO-E3

PURPOSE:

This Energy Conservation Opportunity simulation (ECO-E3) analyzes energy savings in replacing inefficient motors with energy efficient motors. This project includes investigating any power factor charges the USDB is charged.

SCOPE:

This ECO simulation (ECO-E3) determines motor sizes that can be replaced to conserve electricity. This project also determines methods of power factor reduction if the USDB pays a high power factor penalty. The application of this project was considered for the following buildings:

463	Building	475
464	Building	475C
465		475D
472		475F
473	<u> </u>	475G
474	. .	
	464 465 472 473	464Building465Building472Building473Building

MODELING TECHNIQUES:

The Fort Leavenworth USDB power supplier (KPL Gas Service) was contacted. The supplier confirmed that Fort Leavenworth would be charged a power factor penalty, but added that the Fort maintains a power factor of near 100% (or 1) and has not been charged a power factor penalty in the past. Therefore, no changes are required in the USDB power factor.

The modeling technique used to justify motor replacement with high efficiency motors was based on the removal of existing low efficiency motors, replacing them with high efficiency motors, and analyzing energy saved per year based on estimated running time. A sample Life Cycle Cost analysis showing how the SIR's were calculated on each individual motoris included on page E3-21.

ECO IMPLEMENTATION:



ECO implementation will include removal of motors and replacement with high efficiency motors.



SUMMARY:

Because the Fort Leavenworth complex power factor is nearly 100% (or 1) at all times, no power factor correction is recommended.

Average efficiencies and energy savings for various motor sizes and their associated payback times are shown on page E3-3.

Efficiency and watt loss data for various motor sizes are shown on page E3-4.

Energy savings, SIR's, and payback times for various motors in USDB buildings are shown on pages E3-5 and E3-6.

Installation costs for various motor sizes are shown on pages E3-7 to E3-19.

Life cycle cost analysis for this ECO is shown on page E3-20. Only those motors with an SIR of greater than one are included in the analysis.

RECOMMENDATIONS

We recommend replacement of all motors listed on pages E3-5 and E3-6 where calculated SIR values are greater than one. All of the motors listed on those pages are nearing the end of efficient life. Therefore, we recommend that all new motors installed at the USDB during regular maintenance and replacement be high efficiency motors.





AVERAGE EFFICIENCIES AND ENERGY SAVINGS FOR VARIOUS MOTOR SIZES STANDARD VS HIGH EFFICIENCY PAYBACKS FOR REPLACING AN EXISTING MOTOR

LIGBOR						
		HIEFF	STANDARD	HIEFF	WATT	INSTALLED
POWER	MOTOR	MOTOR	MOTOR	MOTOR	LOSS	HI EFF MTR
	EFFICIENCY	EFFICIENCY	WATT LOSS	WATT LOSS	DIFFERENCE	COST
1	76.5	84.0	229	142	87	\$420
1.5	78.5	85.5	306	190	117	\$442
2	80.8	86.5	355	233	122	\$466
3	79.9	88.5	563	291	272	\$582
5	83.1	89.5	759	438	321	\$644
7.5	83.8	90.2	1082	608	474	\$820
10	85.0	90.2	1316	811	506	\$966
15	86.5	91.7	1746	1013	734	\$1,255
20	87.5	93.0	2131	1123	1008	\$1,527
25	88.0	93.0	2543	1404	1139	\$1,780
30	88.1	93.0	3023	1685	1338	\$2,030
40	89.4	93.6	3538	2040	1498	\$2,623
50	90.4	94.1	3961	2339	1622	\$3,232
	3 5 7.5 10 15 20 25 30 40	POWER MOTOR EFFICIENCY 1 76.5 1.5 78.5 2 80.8 3 79.9 5 83.1 7.5 83.8 10 85.0 15 86.5 20 87.5 25 88.0 30 88.1 40 89.4	POWER MOTOR EFFICIENCY MOTOR EFFICIENCY 1 76.5 84.0 1.5 78.5 85.5 2 80.8 86.5 3 79.9 88.5 5 83.1 89.5 7.5 83.8 90.2 10 85.0 90.2 15 86.5 91.7 20 87.5 93.0 25 88.0 93.0 30 88.1 93.0 40 89.4 93.6	POWER MOTOR EFFICIENCY MOTOR EFFICIENCY MOTOR EFFICIENCY MOTOR WATT LOSS 1 76.5 84.0 229 1.5 78.5 85.5 306 2 80.8 86.5 355 3 79.9 88.5 563 5 83.1 89.5 759 7.5 83.8 90.2 1082 10 85.0 90.2 1316 15 86.5 91.7 1746 20 87.5 93.0 2131 25 88.0 93.0 2543 30 88.1 93.0 3023 40 89.4 93.6 3538	POWER MOTOR MOTOR <th< td=""><td>POWER MOTOR MOTOR MOTOR MOTOR MOTOR MOTOR MOTOR LOSS 1 76.5 84.0 229 142 87 1.5 78.5 85.5 306 190 117 2 80.8 86.5 355 233 122 3 79.9 88.5 563 291 272 5 83.1 89.5 759 438 321 7.5 83.8 90.2 1082 608 474 10 85.0 90.2 1316 811 506 15 86.5 91.7 1746 1013 734 20 87.5 93.0 2131 1123 1008 25 88.0 93.0 2543 1404 1139 30 88.1 93.0 3023 1685 1338 40 89.4 93.6 3538 2040 1498 </td></th<>	POWER MOTOR MOTOR MOTOR MOTOR MOTOR MOTOR MOTOR LOSS 1 76.5 84.0 229 142 87 1.5 78.5 85.5 306 190 117 2 80.8 86.5 355 233 122 3 79.9 88.5 563 291 272 5 83.1 89.5 759 438 321 7.5 83.8 90.2 1082 608 474 10 85.0 90.2 1316 811 506 15 86.5 91.7 1746 1013 734 20 87.5 93.0 2131 1123 1008 25 88.0 93.0 2543 1404 1139 30 88.1 93.0 3023 1685 1338 40 89.4 93.6 3538 2040 1498

HORSE-		8760	HOURS		5000 HOURS			
POWER	ENERGY SAVINGS	COST SAVINGS	SIMPLE PAYBACK	SIR	ENERGY SAVINGS	COST SAVINGS	SIMPLE PAYBACK	SIR
1	763	\$32	13.0	0.9	435	\$19	22.7	0.5
1.5	1,022	\$43	10.2	1.1	584	\$25	17.8	0.6
2	1,066	\$45	10.3	1.1	608	\$26	18.0	0.6
3	2,384	\$101	5.7	1.9	1,361	\$58	10.1	1.1
5	2,812	\$119	5.4	2.0	1,605	\$68	9.4	1.2
7.5	4,150	\$176	4.6	2.4	2,369	\$101	8.1	1.4
10	4,432	\$188	5.1	2.2	2,530	\$108	9.0	1.2
15	6,426	\$273	4.6	2.4	3,668	\$156	8.1	1.4
20	8,834	\$375	4.1	2.7	5,042	\$214	7.1	1.5
25	9,981	\$424	4.2	2.6	5,697	\$242	7.4	1.5
30	11,725	\$498	4.1	2.7	6,692	\$284	7.1	1.5
40	13,120	\$558	4.7	2.3	7,489	\$318	8.2	1.3
50	14,212	\$604	5.4	2.1	8,112	\$345	9.4	1.2


HORSE-		4380	HOURS		2920 HOURS				
POWER	ENERGY SAVINGS	COST SAVINGS	SIMPLE PAYBACK	SIR	ENERGY SAVINGS	COST SAVINGS	SIMPLE PAYBACK	SIR	
1	381	\$16	25.9	0.4	254	\$11	38.9	0.3	
1.5		\$22	20.3	0.5	341	\$14	30.5	0.4	
2	533	\$23	20.6	0.5	355	\$15	30.9	0.4	
3	1,192	\$51	11.5	1.0	795	\$34	17.2	0.6	
5	1,406	\$60	10.8	1.0	937	\$40	16.2	0.7	
7.5	2,075		9.3	1.2	1,383	\$59	13.9	0.8	
10	the second se	\$94	10.3	1.1	1,477	\$63	15.4	0.7	
15	3,213	\$137	9.2	1.2	2,142	\$91	13.8	0.8	
20	4,417	\$188	8.1	1.4	2,945	\$125	12.2	0.9	
25	4,991	\$212	8.4	1.3	3,327	\$141	12.6	0.9	
30	5,862	\$249	8.1	1.4	3,908	\$166	12.2	0.9	
40	6,560	\$279	9.4	1.2	4,373	\$186	14.1	0.8	
50	7,106	\$302	10.7	1.0	4,737	\$201	16.1	0.7	




25 YEAR DISCOUNT FACTOR = 11.16

ELECTRICITY COST = 4.25¢/KWH





MOTOR HORSEPOWER



THESE GRAPHS ARE BASED ON INFORMATION PUBLISHED BY RELIANCE ELECTRIC CORPORATION.



PAGE E3-4

5

B.
3
المحتيب ا

	CALCULATI	UN SHEI	51		DATE Mar 00		SHEET	
PROJECT	USDB	·····			Mar-90	CALCULATIO	1 2	
_		VINGS C	PPORTUNI	TY SURVEY	BASIS FUR	CALCOLATION	Y	
OCATION					x	HAND		
DOLUTEOTIC	FORT LEAV	ENWORT	H, KS			COMPUTER		
RCHITECT/EN						CONTRACTO		
CO MEASURE	CLARK RICH	IARDSO	A & BISKUP		0011011770	OTHER (SP		
	ECO-E3				COMPUTED		CHECK	
	200 20				<u>L</u>	DJG		MAW
BUILDING # AN		HP	OPER.	SAVINGS	SAVINGS	INSTALLED	SIR	PAYBA
NOTOR DESCR	IPTION		HOURS/	PER YEAR	PER YEAR	COST		YEAR
UILDING 463		+	YEAR	MBTU'S	DOLLARS			
AN		1.5	4380	1.7	\$21.15	\$442	0.5	20.9
UILDING 463		5	4380	4.8	*F0 74	AO (1)		
ONDENSING L	INIT		4300	4.0	\$59.71	\$644	1.0	10.8
UILDING 464		1.5	4380	1.7	\$21,15	\$442	0.5	20.9
AN						Ψ'TTE	0.5	20.9
UILDING 464		1.5	4380	1.7	\$21.15	\$442	0.5	20.9
AN UILDING 465		<u> </u>						
OMPRESSOR		5	5000	5.5	\$68.42	\$644	1.2	9.4
UILDING 465		5	5000	5.5	\$69.40	0044		
OMPRESSOR			3000	5.5	\$68.42	\$644	1.2	9.4
UILDING 465	······································	1.5	4380	1.7	\$21.15	\$442	0.5	20.9
OLD WATER P	UMP					Ψ ⁻⁺⁻⁺ <i>L</i> _n	0.5	20.9
UILDING 465		7.5	4380	7.1	\$88.32	\$820	1.2	9.3
<u>OT WATER PU</u> UILDING 465	MP							
IR HANDLING I	INIT	2	4380	1.8	\$22.39	\$466	0.5	20.8
UILDING 465		1	4380	1.3	\$16.17	* 400		
R HANDLING	JNIT		4000	1.5	\$10.17	\$420	0.4	26.0
UILDING 465		1	4380	1.3	\$16.17	\$420	0.4	26.0
R HANDLING	JNIT					• • • • •		20.0
UILDING 472 OT WATER PU		3	4380	4.1	\$51.00	\$582	1.0	11.4
JILDING 472	MP	1.5	4380		001.15			
AN		1.5	4360	1.7	\$21.15	\$442	0.5	20.9
JILDING 473		3	4380	4.1	\$51.00	\$582	1.0	11.4
OT WATER PU	MP				Ψ07.00	WUUZ I	1.0	11.4
JILDING 473		5	4380	4.8	\$59.71	\$644	1.0	10.8
<u>DT WATER PUI</u> JILDING 474	NP	+						
DILDING 474 DILER FEED PL	IMP	40	8760	44.8	\$557.31	\$2,623	2.4	4.7
JILDING 474		10	8760	15.1	\$187.84	£066		
N.			0,00	10.1	φ107.04	\$966	2.2	5.1
JILDING 474		10	8760	15.1	\$187.84	\$966	2.2	5.1
N								0.1
JILDING 474 N		10	8760	15.1	\$187.84	\$966	2.2	5.1
JILDING 474		10	8760	15.1				
NDENSATE P	JMP		0/00	15.1	\$187.84	\$966	2.2	5.1
ILDING 474		10	8760	15.1	\$187.84	\$966	2.2	5.1
NDENSATE P	JMP				4.07.07	\$300	د.د	5.1
IILDING 474		3	8760	8.1	\$100.76	\$582	1.9	5.8
COMPRESSO	DR	┝───┤						
ILDING 474 R COMPRESSO		25	8760	34.1	\$424.20	\$1,780	2.7	4.2
	/m		1		1	1	1	

CALCULATION S	HEET		DATE		SHEET OF			
PROJECT USDB			Mar-90 2 2 BASIS FOR CALCULATION					
ENERGY SAVING	S OPPC	BASIS FUR (ALCOLATION					
LOCATION		<u> </u>	HAND					
FORT LEAVENW	<u>ORTH, K</u>	S			COMPUTER			
	SON & E		CONTRACTO					
ECO MEASURE			COMPUTED	OTHER (SP				
ECO-E3	ECO-E3						KED BY MAW	
BUILDING # AND	HP	OPER.	SAVINGS	SAVINGS	INCTALLED	017		
MOTOR DESCRIPTION		HOURS/ YEAR	PER YEAR MBTU'S	PER YEAR DOLLARS	INSTALLED COST	SIR	PAYBACH YEARS	
BUILDING 475 ROTUNDA CONDENSING UNIT	3	4380	4.1	\$51.00	\$582	1.0	11.4	
BUILDING 475 ROTUNDA CONDENSING UNIT	7.5	4380	7.1	\$88.32	\$820	1.2	9.3	
BUILDING 475C FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475C FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475D FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475D FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475F FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475F FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475G FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
BUILDING 475G FAN	5	4380	4.8	\$59.71	\$644	1.0	10.8	
TOTAL (SIR > 1)			248	\$3,085.00	\$20,929	1.6	6.8	





25-YEAR DISCOUNT FACTOR= 11.16

CONSTRUCTION COST ESTIMATE	EPARED 16-Mar-90)		SHEET 1 OF			
PROJECT	BASIS FOR E		<u> </u>				
ENERGY SAVING OPPORTUNITY SURVEY							
FORT LEAVENWORTH KANSAS	<u> </u>		A (NO DESIGN B (PRELIMINAI	COMPLETED)			
RCHITECT/ENGINEER						C (FINAL DESI	GN)
CLARK, RICHARSON, & BISKUP		ESTIM			OTHEF	(SPECIFY)	
1 HORSEPOWER MOTOR REPLACE				DJG		CHECKED BY	MAW
,		NTITY		LABOR		MATERIAL	TOTAL
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER	TOTAL	COST
			<u>ONIT</u>		UNIT		
	 						
OTOR REMOVAL	1	EA	\$44.00	\$44		\$0	
HP ENERGY EFFICIENT MOTOR	1	EA	\$40.00	\$40	\$140.00		
	·			\$40	\$148.00	\$148	\$1
OTOR CONNECTION	1	EA	\$23.00	\$23	\$3.15	\$3	
SUBTOTAL				\$107			
ONTINGENCY						\$151	\$2
			10%	\$11	10%	\$15	\$
				\$118		\$166	\$2
ORK COMP, SOC. SEC., INS., TAXES			13.50%	\$16	3 500		
			10.00%		3.50%	\$6	\$
DIRECT COST				\$134		\$172	\$3
VERHEAD & PROFIT	T						
					{	25.0%	\$
CONSTRUCTION COST							\$38
он							
						10.0%	\$3
TOTAL PROJECT COST							\$42
					T	T	
			f				·······
							· · · · · · · · · · · · · · · · · · ·
			l l				
					 +		
	T		T				
				ſ	T		
1		1		1		1	

議



CONSTRUCTION COST ESTIMATE	CONSTRUCTION COST ESTIMATE			DATE PREPARED				
PROJECT				3/16/90 BASIS FOR E		SHEET 1 OF 1		
ENERGY SAVING OPPORTUNITY SU	JRVEY			IDASIS FOR E	SIMALE			
LOCATION FORT LEAVENWORTH, KANSAS				 ×		A (NO DESIGN B (PRELIMINAF		
ARCHITECT/ENGINEER CLARK, RICHARSON, & BISKUP						C (FINAL DESIG	GN)	
DRAWING NO.		ESTIM	ATOR					
1.5 HORSEPOWER MOTOR REPLAC				DJG		CHECKED BY	MAW	
	NO.		PER	LABOR TOTAL	PER	MATERIAL TOTAL	TOTAL	
	UNITS	MEAS.	UNIT		UNIT		COST	
MOTOR REMOVAL	1	EA	\$44.00	\$44				
1.5 HP ENERGY EFFICIENT MOTOR			\$40.00	\$40	\$162.00	\$0	\$44	
MOTOR CONNECTION	1		\$23.00	\$23	\$3.15	\$162	\$202	
	<u>-</u>		<u></u>	φ23	- 3 3.15	\$3	\$26	
SUBTOTAL				\$107		\$165	\$272	
CONTINGENCY			10%	\$11	10%	\$17	<u>\$27</u>	
				\$118		\$182	\$299	
WORK COMP, SOC. SEC., INS., TAXES			13.50%	\$16	3.50%	\$6	\$22	
DIRECT COST				\$134		\$188	\$322	
OVERHEAD & PROFIT						25.0%	\$80	
CONSTRUCTION COST							\$402	
SIOH								
TOTAL PROJECT COST						10.0%	\$40	
							\$442	



CONSTRUCTION COST ESTIMATE	DATE PR	EPARED 3/16/90		SHEET 1 OF			
PROJECT	1,	BASIS FOR ESTIMATE					
ENERGY SAVING OPPORTUNITY SU LOCATION FORT LEAVENWORTH, KANSAS ARCHITECT/ENGINEER		CODE A (NO DESIGN COMPL CODE B (PRELIMINARY DESI CODE C (FINAL DESIGN)					
CLARK, RICHARSON, & BISKUP DRAWING NO.		IESTIM	ATOP		OTHER	(SPECIFY)	
2 HORSEPOWER MOTOR REPLACE				DJG			MAW
	NO.	NTITY UNIT MEAS.	PER UNIT	LABOR TOTAL	PER UNIT		TOTAL COST
MOTOR REMOVAL	1	EA	\$44.00	\$44		\$0	\$4
2 HP ENERGY EFFICIENT MOTOR	1	EA	\$40.00	\$40	\$177.00	\$177	\$21
MOTOR CONNECTION	1	EA	\$23.00	\$23	\$3.15	\$3	\$2
SUBTOTAL				\$107		\$180	\$26
CONTINGENCY			10%	\$11	10%	\$18	\$2
				\$118		\$198	\$31
WORK COMP, SOC. SEC., INS., TAXES			13.50%	\$16	3.50%	\$7	\$2
DIRECT COST				\$134		\$205	\$3
OVERHEAD & PROFIT						25.0%	\$8
CONSTRUCTION COST							\$42
SIOH						10.0%	\$4
TOTAL PROJECT COST							\$46
							· · · · · · · · · · · · · · · · · · ·



CONSTRUCTION COST ESTIMATE	EPARED 3/16/90		SHEET 1 OF				
PROJECT ENERGY SAVING OPPORTUNITY SU	BASIS FOR ESTIMATE						
LOCATION FORT LEAVENWORTH, KANSAS ARCHITECT/ENGINEER		X		A (NO DESIGN B (PRELIMINAF C (FINAL DESI	RY DESIGN)		
CLARK, RICHARSON, & BISKUP					OTHER	(SPECIFY)	311)
DRAWING NO. 3 HORSEPOWER MOTOR REPLACE	ATOR	DJG		CHECKED BY	MAW		
	QUA NO.	NTITY	050	LABOR		ATERIAL	TOTAL
		UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
MOTOR REMOVAL	1	EA	\$44.00	\$44		\$0	\$
	1	EA	\$40.00	\$40	\$245.00	\$245	\$2
NOTOR CONNECTION	1		\$28.00	\$28	\$3.70	\$245 \$4	\$2
SUBTOTAL				¢110			
CONTINGENCY			109/	\$112		\$249	\$3
			10%	\$11	10%	\$25	\$
VORK COMP, SOC. SEC., INS., TAXES			13.50%	<u>\$123</u> \$17	3.50%	\$274	\$3
DIRECT COST			10.00%	<u> </u>	3.50%	\$10	\$
211201 0001				\$14U		\$283	\$4
VERHEAD & PROFIT						25.0%	\$10
CONSTRUCTION COST							\$52
ЮН						10.0%	\$
TOTAL PROJECT COST							\$58
							· · · · · · · · · · · · · · · · · · ·
G. FORM 150 VC-59							

, cert

CONSTRUCTION COST ESTIMATE	DATE PF	SHEET 1 OF						
PROJECT ENERGY SAVING OPPORTUNITY SU		3/16/90 BASIS FOR ES	J					
LOCATION	RVET			X CODE A (NO DESIGN COMPLI				
FORT LEAVENWORTH, KANSAS ARCHITECT/ENGINEER						3 (PRELIMINAF	RY DESIGN	
CLARK, RICHARSON, & BISKUP						(FINAL DESIC	GN)	
DRAWING NO. 5 HORSEPOWER MOTOR REPLACE		ESTIM	ATOR			CHECKED BY		
S HORSEPOWER MOTOR REPLACE	QUA	NTITY		DJG LABOR	I N	ATERIAL	MAW TOTAL	
	NO.	UNIT	PER	TOTAL	PER	TOTAL	COST	
		MEAS.	UNIT		UNIT			
MOTOR REMOVAL	1	EA	\$44.00	\$44		\$0	\$4	
5 HP ENERGY EFFICIENT MOTOR	1	EA	\$40.00	\$40	\$285.00	\$285	\$32	
MOTOR CONNECTION	1	EA	\$28.00	\$28	\$3.70	\$4	\$3	
SUBTOTAL				\$112		\$289	\$40	
CONTINGENCY			10%	\$11	10%	\$29	\$4	
			<u></u>	\$123		\$318	\$44	
WORK COMP, SOC. SEC., INS., TAXES			13.50%	\$17	3.50%	\$11	\$2	
DIRECT COST			••••••	\$140		\$329	\$46	
OVERHEAD & PROFIT						25.0%	\$11	
CONSTRUCTION COST						20.078	\$58	
SIOH						10.0%	\$5	
TOTAL PROJECT COST							\$64	
							· · · · · · · · · · · · · · · · · · ·	
NG. FORM 150 NC-59								

and the second

CONSTRUCTION COST ESTIMATE	REPARED 3/16/90		SHEET 1 OF				
PROJECT ENERGY SAVING OPPORTUNITY SU	BASIS FOR ES	<u></u>					
LOCATION FORT LEAVENWORTH, KANSAS ARCHITECT/ENGINEER		X CODE A (NO DESIGN COMPLETED CODE B (PRELIMINARY DESIGN) CODE C (FINAL DESIGN)					
CLARK, RICHARSON, & BISKUP DRAWING NO.		ESTIM	ATOP		OTHER	(SPECIFY) CHECKED BY	,
7.5 HORSEPOWER MOTOR REPLAC				DJG	-		MAW
	NO.	NTITY UNIT MEAS.	PER UNIT	LABOR TOTAL	PER UNIT		TOTAL COST
MOTOR REMOVAL	1	EA	\$44.00	\$44		\$0	\$4
7.5 HP ENERGY EFFICIENT MOTOR	1	EA	\$43.00	\$43	\$388.00	\$388	\$43
MOTOR CONNECTION	1	EA	\$33.00	\$33	\$4.40	\$4	\$3
SUBTOTAL				\$120		\$392	¢E1
CONTINGENCY			10%	\$12	10%	\$392	<u>\$51</u> \$5
				\$132	10 /8	\$432	\$56
NORK COMP, SOC. SEC., INS., TAXES			13.50%	\$18	3.50%	\$15	\$36
DIRECT COST				\$150		\$447	\$59
OVERHEAD & PROFIT						0E 00/	
CONSTRUCTION COST						25.0%	<u>\$14</u> \$74
						10.0%	\$7
TOTAL PROJECT COST							\$82
							·
							· · · · · · · · · · · · · · · · · · ·

ENG. FORM 1AVC-59

CONSTRUCTION COST ESTIMATE	EPARED 3/16/90		SHEET 1 OF				
PROJECT	BASIS FOR ES	·····					
ENERGY SAVING OPPORTUNITY SURVEY LOCATION FORT LEAVENWORTH, KANSAS						A (NO DESIGN B (PRELIMINA)	
RCHITECT/ENGINEER CLARK, RICHARSON, & BISKUP			C (FINAL DESI	GN)			
DRAWING NO.		ESTIM	ATOR	l	OTHER	(SPECIFY)	
10 HORSEPOWER MOTOR REPLAC				DJG	·		MAW
	NO.		PER	LABOR TOTAL	PER	ATERIAL TOTAL	TOTAL COST
	UNITS.	MEAS.	UNIT		UNIT		
IOTOR REMOVAL	1	EA	\$44.00	\$44		\$0	\$
0 HP ENERGY EFFICIENT MOTOR	1	EA	\$45.00	\$45	\$468.00	\$468	\$5
IOTOR CONNECTION	1	EA	\$43.00	\$43	\$4.40	\$4	\$
SUBTOTAL				\$132		\$472	\$60
ONTINGENCY			10%	\$13	10%	\$47	\$
				\$145		\$520	\$6
ORK COMP, SOC. SEC., INS., TAXES			13.50%	\$20	3.50%	\$18	\$
DIRECT COST				\$165		\$538	
VERHEAD & PROFIT						25.0%	\$17
CONSTRUCTION COST]						\$87
он						10.0%	\$8
TOTAL PROJECT COST							\$96
							· · · · · · · · · · · · · · · · · · ·
			1			1	······································





CONSTRUCTION COST ESTIMATE	CONSTRUCTION COST ESTIMATE			DATE PREPARED					
PROJECT		·····	I	3/16/90 BASIS FOR ES					
ENERGY SAVING OPPORTUNITY SU LOCATION	IRVEY			X	CODE				
FORT LEAVENWORTH, KANSAS				CODE B (PRELIMINARY DESIGN					
CLARK, RICHARSON, & BISKUP				CODE C (FINAL DESIGN) OTHER (SPECIFY)					
DRAWING NO. 15 HORSEPOWER MOTOR REPLAC	~	ESTIM	ATOR	•		CHECKED BY			
13 HORSEFOWER MOTOR REPLAC		NTITY		DJG LABOR			MAW TOTAL		
	NO.	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST		
	UNITS	INICAS.			UNIT				
MOTOR REMOVAL	1	EA	\$44.00	\$44		\$0	\$44		
15 HP ENERGY EFFICIENT MOTOR	1	EA	\$57.00	\$57	\$625.00	\$625	\$682		
MOTOR CONNECTION	1	EA	\$55.00	\$55	\$5.65	\$6	\$61		
SUBTOTAL				\$156		\$631	\$787		
CONTINGENCY			10%	\$16	10%	\$63	\$79		
				\$172		\$694	\$865		
WORK COMP, SOC. SEC., INS., TAXES			13.50%	\$23	3.50%	\$24	\$47		
DIRECT COST				\$195		\$718	\$913		
OVERHEAD & PROFIT						25.0%	\$228		
CONSTRUCTION COST						20.070	\$1,141		
SIOH						10.0%	\$114		
TOTAL PROJECT COST							\$1,255		
				1					
NG. FORM 150 AVC-59	L.	L			I_				



CONSTRUCTION COST ESTIMATE	IEPARED 3/16/90			SHEET 1 OF			
PROJECT ENERGY SAVING OPPORTUNITY SU	BASIS FOR ES	STIMATE		A			
OCATION FORT LEAVENWORTH, KANSAS	<u>x</u>	CODE	A (NO DESIGN B (PRELIMINA)	RY DESIGN			
CLARK, RICHARSON, & BISKUP						C (FINAL DESI	GN)
DRAWING NO. 20 HORSEPOWER MOTOR REPLAC	e:	ESTIM	ATOR	<u> </u>	<u> </u>	CHECKED BY	
LO HONGER OWER MOTOR REPLAC		NTITY		DJG LABOR		MATERIAL	MAW TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
IOTOR REMOVAL		EA	\$55.00	¢55			
				\$55		\$0	9
0 HP ENERGY EFFICIENT MOTOR	1		\$70.00	\$70	\$754.00	\$754	\$8
OTOR CONNECTION	1	EA	\$67.00	\$67	\$10.60	\$11	
SUBTOTAL				\$192		\$765	\$9
ONTINGENCY			10%	\$19	10%	\$76	9
				\$211		\$841	\$1,0
ORK COMP, SOC. SEC., INS., TAXES			13.50%	\$29	3.50%	\$29	\$
DIRECT COST				\$240		\$870	\$1,1
VERHEAD & PROFIT							
CONSTRUCTION COST						25.0%	\$2
							\$1,3
он						10.0%	\$1
TOTAL PROJECT COST							\$1,5
							<u> </u>
				1			
							<u> </u>



	EPARED 3/16/90		, and a second	SHEET 1 OF			
HOJECT ENERGY SAVING OPPORTUNITY SU	BASIS FOR ESTIMATE						
OCATION FORT LEAVENWORTH, KANSAS RCHITECT/ENGINEER		×	COMPLETED) RY DESIGN)				
CLARK, RICHARSON, & BISKUP						C (FINAL DESIC (SPECIFY)	JIN)
RAWING NO. 25 HORSEPOWER MOTOR REPLAC	E	ESTIM	ATOR	DJG		CHECKED BY	MAW
	QUA	NTITY		LABOR		ATERIAL	TOTAL
	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
OTOR REMOVAL	1	EA	\$55.00	\$55		\$0	\$
5 HP ENERGY EFFICIENT MOTOR	1	EA	\$72.00	\$72	\$014		
	1	EA	\$67.00	\$12	\$914 \$10.60	<u>\$914</u> \$11	\$9
		<u> </u>	<u> </u>		\$10.60		\$
SUBTOTAL				\$194		\$925	\$1,1
ONTINGENCY			10%	\$19	10%	\$92	\$1
				\$213		\$1,017	\$1,2
ORK COMP, SOC. SEC., INS., TAXES			13.50%	\$29	3.50%	\$36	\$(
DIRECT COST				\$242		\$1,053	\$1,2
VERHEAD & PROFIT						25.0%	\$32
CONSTRUCTION COST							\$1,61
он							.
TOTAL PROJECT COST						10.0%	\$16 \$1,78



CONSTRUCTION COST ESTIMATE	EPARED 3/16/90			SHEET 1 OF			
PROJECT	BASIS FOR ESTIMATE						
ENERGY SAVING OPPORTUNITY SU LOCATION FORT LEAVENWORTH, KANSAS ARCHITECT/ENGINEER		X CODE A (NO DESIGN COMPLE CODE B (PRELIMINARY DESIC CODE C (FINAL DESIGN)					
CLARK, RICHARSON, & BISKUP DRAWING NO.		ESTIM	ATOP		OTHER	(SPECIFY)	·/
30 HORSEPOWER MOTOR REPLAC	E		RIOR	DJG		CHECKED BY	MAW
	QUA NO.		PER	LABOR TOTAL	PER N	IATERIAL TOTAL	TOTAL COST
		MEAS.				TOTAL	0051
MOTOR REMOVAL	1	EA	\$55.00	\$55		\$0	\$!
30 HP ENERGY EFFICIENT MOTOR	1	EA	\$76.00	\$76	\$1,069	\$1,069	\$1,14
MOTOR CONNECTION	1		\$67.00	\$67	\$10.60	\$11	\$7
SUBTOTAL				\$198		\$1,080	\$1,27
CONTINGENCY			10%	\$20	10%	\$108	\$12
				\$218		\$1,188	\$1,40
WORK COMP, SOC. SEC., INS., TAXES			13.50%	\$29	3.50%	\$42	\$
DIRECT COST				\$247		\$1,229	\$1,47
OVERHEAD & PROFIT						25.0%	\$36
CONSTRUCTION COST							\$1,8 4
SIOH						10.0%	\$18
TOTAL PROJECT COST							\$2,03
							•
		·					
NG. FORM 150 AVC-59		ł	l_		<u> </u>	L	



CONSTRUCTION COST ESTIMATE			DATE PR	EPARED 3/16/90			SHEET 1 OF
PROJECT	BASIS FOR ES	STIMATE					
ENERGY SAVING OPPORTUNITY SL LOCATION FORT LEAVENWORTH, KANSAS							
ARCHITECT/ENGINEER		*******				3 (PRELIMINAF	RY DESIGN)
CLARK, RICHARSON, & BISKUP DRAWING NO.		ESTIM	ATOD		OTHER	(SPECIFY)	
40 HORSEPOWER MOTOR REPLAC	E	ESTIM	ATOH	DJG		CHECKED BY	MAW
	NO.	NTITY	PER	LABOR TOTAL	N PER	ATERIAL	TOTAL
	UNITS		UNIT			TOTAL	COST
MOTOR REMOVAL	1	EA	\$60.00	\$60	-	\$0	\$
10 HP ENERGY EFFICIENT MOTOR	1	EA	\$91.00	\$91	\$1,390	\$1,390	م \$1,4
MOTOR CONNECTION	1	EA	\$82.00	\$82	\$30.00	\$30	په ۱,4 \$1
SUBTOTAL				\$233		\$1,420	\$1,6
CONTINGENCY			10%	\$23	10%	\$142	\$10
				\$256		\$1,562	\$1,8
VORK COMP, SOC. SEC., INS., TAXES			13.50%	\$35	3.50%	\$55	\$8
DIRECT COST				\$291		\$1,617	\$1,90
VERHEAD & PROFIT						25.0%	\$47
CONSTRUCTION COST						20.076	\$47
1011							
						10.0%	\$23
TOTAL PROJECT COST							\$2,62
							,
······································							
			<u> </u>				
							<u></u>
G. FORM 150 /C-59				<u> </u>			



	, si
-	

CONSTRUCTION COST ESTIMATE		REPARED					
PROJECT			L	3/16/90 BASIS FOR ES			1
ENERGY SAVING OPPORTUNITY SU OCATION							
FORT LEAVENWORTH, KANSAS	<u> </u>	CODE	A (NO DESIGN	COMPLETED)			
ARCHITECT/ENGINEER						B (PRELIMINAF C (FINAL DESIG	(Y DESIGN) SNI
CLARK, RICHARSON, & BISKUP		15050			OTHER	(SPECIFY)	
50 HORSEPOWER MOTOR REPLAC	F	ESTIM	ATOR	DJG		CHECKED BY	
		NTITY	1	LABOR	A		MAW TOTAL
	NO.	UNIT	PER	TOTAL	PER	TOTAL	COST
· · · · · · · · · · · · · · · · · · ·	UNITS	MEAS.			UNIT		
MOTOR REMOVAL							
	1		\$60.00	\$60		\$0	
	1		\$115.00	\$115	\$1,753	\$1,753	\$1,8
	1	EA	\$82.00	\$82	\$30.00	\$30	\$1
SUBTOTAL				\$257		\$1,783	\$2,0
CONTINGENCY			10%	\$26	10%	\$178	\$2
				\$283		\$1,961	\$2,2
VORK COMP, SOC. SEC., INS., TAXES			13.50%	\$38	3.50%	\$69	\$1
DIRECT COST				\$321		\$2,030	\$2,3
VERHEAD & PROFIT							
CONSTRUCTION COST						25.0%	\$5
							\$2,9
ОН						10.0%	\$29
TOTAL PROJECT COST						10,0 /8	\$3,2
		1			1		



	Sar	np	e	for	10	0 k	۱P			
P Fl		LIF RGY (LOC TITLI 90	E CYCLE CO CONSERVAT ATION: FOF E: 1496 DIS	OST ANALY TON INVES RT LEAVEN	sis sumi Tment p Worth	MARY ROGRAM · USDB R ·ME: ECO	I (ECIP) EGION	NNOS. 7 PREPARED	l	DY: USDBAE LCCID 1.035 CENSUS: 2
	INVESTMENT A. CONSTRU B. SIOH C. DESIGN C D. ENERGY C E. SALVAGE F. TOTAL INV ENERGY SAV	JCTIC CREE VALU /ESTI	DIT CALC (1/ JE COST MENT (1D-1 S (+) / COST	E) (-)					\$ \$ \$ \$ \$	20929. 1256. 1151. 21002. 0. 21002.
	ANALYSIS DA	ATE A	NNUAL SAV	ÍNGS, UNIT						
	FUEL		JNIT COST //MBTU(1)	SAVINGS MBTU/YR		NNUAL \$ AVINGS(3		SCOUNT ACTOR(4)		SCOUNTED AVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	248. 0. 0. 0. 0.	\$ \$ \$ \$ \$	3085. 0. 0. 0. 0.		11.16 17.19 17.12 16.15 13.92		34429. 0. 0. 0. 0.
	F. TOTAL			248.	\$	3085.			\$	34429.
3.	NON ENERGY	(SAV	'INGS(+) / C(OST(-)						
	A. ANNUAL R (1) DISCO	ECUI UNT	RRING (+/-) FACTOR (TA			11.65			\$	0.
	(2) DISCO	UNTE	ED SAVING/C	COST (3A X					\$	0.
	C. TOTAL NO) /COST(-)	(3A2+	-3Bd4)	\$	0.
	A IF 3D B IF 3D C IF 3D	AX N0 1 IS = 1 IS < 01B IS	ENERGY QL ON ENERGY ON = OR > 3C GG C = OR > 3C CALC = 3C C = S = S = S = S = S = S = S = S = S =	CALC (2F5 D TO ITEM / SIR = (2F5- O ITEM 4	X .33) 4 -3D1)/1F)=		\$	11362.		
4.	FIRST YEAR D	OLL	AR SAVINGS	2F3+3A+(3	B1D/(YEA	RS ECON	оміс	LIFE))	\$	3085.
	TOTAL NET D								\$	34429.
6.	DISCOUNTED (IF < 1 PROJEC	SAVI CT DO	NGS RATIO DES NOT QL	JALIFY)	(S	IR)=(5 / 1F)=	1.64		
7.	SIMPLE PAYB	ACK	PERIOD (ES	TIMATED)	SPB=1F	/4		6.81		



PI	ISTALLATION & I ROJECT NO. & T	GY CO LOCA ITLE:	ONSERVAT ATION: FOI : 1496		iment pf Worth -	OGRAM (ECUSDB REC	GION NOS.		JDY: USDBAE LCCID 1.035 CENSUS: 2
	SCAL YEAR 199 NALYSIS DATE:			CRETE POR ECONOM		ME: ECOE3 YEARS		ED BY: C	RB
1.	INVESTMENT A. CONSTRUC B. SIOH C. DESIGN CC D. ENERGY C E. SALVAGE V F. TOTAL INVI	DST REDI /ALU	T CALC (1. E COST		9			\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	878. 53. 48. 881. 0. 881.
2.	ENERGY SAVI ANALYSIS DAT	NGS TE AN	(+) / COST INUAL SAV	(-) 'INGS, UNIT	COST & [DISCOUNTE	D SAVINGS		
	FUEL		NIT COST MBTU(1)	SAVINGS MBTU/YR(NNUAL \$ AVINGS(3)	DISCOUN FACTOR(4		DISCOUNTED SAVINGS(5)
	A. ELECT B. DIST C. RESID D. NAT G E. COAL	\$ \$ \$ \$ \$	12.44 .00 .00 4.08 .00	15. 0. 0. 0.	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	187. 0. 0. 0. 0.	11.1 17.1 17.1 16.1 13.9	9 2 5	2087. 0. 0. 0. 0.
	F. TOTAL			15.	\$	187.		\$	2087.
3.	NON ENERGY	SAVI	NGS(+) / C	OST(-)					
	A. ANNUAL RE (1) DISCOU					11.65		\$	0.
	(2) DISCOL	JNTE	D SAVING/	COST (3A X	(3A1)			\$	0.
	C. TOTAL NON	N ENE	ERGY DISC	OUNTED SA	VINGS(+)	/COST(-) (3	3A2+3Bd4)	\$	0.
	B IF 3D1 C IF 3D	X NO IS = IS < 1B IS	N ENERGY OR > 3C G 3C CALC = > 1 GO T	′ CALC (2F5 O TO ITEM 4 SIR = (2F5+	X .33) 4 ⊦3D1)/1F)=		\$ 689). -	
4.	FIRST YEAR D	OLLA	R SAVINGS	6 2F3+3A+(3	B1D/(YEA	RS ECONO	MIC LIFE))	\$	187.
5.	TOTAL NET DIS	SCOL	INTED SAV	INGS (2F5+	3C)			\$	2087.
6.	DISCOUNTED S (IF < 1 PROJEC				(SI	R)=(5 / 1F)=	2.37	7	
7.	SIMPLE PAYBA	CK P	ERIOD (ES	TIMATED)	SPB=1F/	'4	4.71	l	





REFERENCES

- 1. <u>COOLING AND HEATING LOAD CALCULATION MANUAL</u>, American Society of Heating, Refrigeration, and Air-Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA 30329.
- 2. <u>ASHRAE HANDBOOK. 1981 FUNDEMENTALS</u>, American Society of Heating, Refrigeration, and Air-Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA 30329.
- 3. <u>ENERGY ENGINEERING</u>, Journal of the Association of Energy Engineers, The Fairmont Press, Inc., 700 Indian Trail, Lilburn, GA 30247.
- 4. <u>ASHRAE HANDBOOK, 1977 FUNDEMENTALS</u>, American Society of Heating, Refrigeration, and Air-Conditioning Engineers, Inc., 345 East 47th Street, New York, NY 10017.



SCOPE OF WORK

· · ·

GENERAL SCOPE OF WORK

ENERGY SURVEY FOR THE

UNITED STATES DISCIPLINARY BARRACKS (USDB)

AT

.

FORT LEAVENWORTH, KANSAS

ENERGY ENGINEERING ANALYSIS PROGRAM (EEAP)

)

1

SCOPE OF WORK

ENERGY SURVEY FOR THE UNITED STATES DISCIPLINARY BARRACKS (USDB) AT FORT LEAVENWORTH, KANSAS

ENERGY ENGINEERING ANALYSIS PROGRAM

TABLE OF CONTENTS

- 1. BRIEF DESCRIPTION OF WORK
- 2. GENERAL
- 3. PROJECT MANAGEMENT
- 4. SERVICES AND MATERIALS
- 5. PROJECT DOCUMENTATION
 - 5.1 ECIP Project
 - 5.2 MCA Project
 - 5.3 Non-ECIP Projects
 - 5.4 Nonfeasible ECOs
- 6. DETAILED SCOPE OF WORK
- 7. WORK TO BE ACCOMPLISHED
 - 7.1 Audit and Analysis
 - 7.2 Identify ECOs
 - 7.3 Prepare Programming Documentation for ECIP Projects
 - 7.4 Prepare Implementation Documentation
 - 7.5 List and Prioritize All Projects
 - 7.6 Submittals, Presentations, and Reviews

ANNEX

- A ENERGY CONSERVATION OPPORTUNITIES
- B DETAILED SCOPE OF WORK
- C REQUIRED DD FORM 1391 DATA

D - EXECUTIVE SUMMARY GUIDELINE



1. BRIEF DESCRIPTION OF WORK: The Architect-Engineer (AE) shall:

1.1 Perform a complete energy audit and analysis of the USDB.

1.2 Identify all Energy Conservation Opportunities (ECOs) including low cost/no cost ECOs and perform complete evaluations of each.

1.3 Prepare programming documentation [DD Form 1391, Life Cycle Cost Analysis Summary Sheet with backup calculations and Project Development Brochure (PDB)] for any Energy Conservation Investment Program (ECIP) and MCA projects.

1.4 Prepare implementation documentation for all justifiable energy conservation opportunities.

1.5 List and prioritize all recommended energy conservation opportunities.

1.6 Prepare a comprehensive report which will document the work accomplished, the results and the recommendations.

2. GENERAL

2.1 An energy study, including a detailed energy survey, shall be accomplished for the USDB. The study shall integrate the results of and any available data from prior or ongoing energy conservation studies, projects, designs, or plans with work done under this contract. This Scope of Work is not intended to prescribe the details in which the studies are to be conducted or limit the AE in the exercise of his professional engineering expertise, good judgment or investigative ingenuity. However, the information and analysis outlined herein are considered to be minimum essentials for adequate performance of this study. The study shall include a comprehensive energy report documenting study methods and results.

2.2 An Energy Engineering Analysis Program (EEAP) study has been accomplished for the installation at which the USDB is located. The portions of the study applicable to the USDB, if any, shall be incorporated into this study. This report shall list the recommended USDB related ECOs from the previous study. This list shall identify the previous study, summarize the USDB related ECOs and the anticipated energy savings, and identify the fiscal year for which the project was or is programmed. The backup calculations and project documentation from the previous study shall be reproduced and included as a appendix to the report. Any USDB related ECOs shall be reevaluated under this contract. Any USDB related ECOs recommended from the previous studies but not implemented nor programmed for implementation shall be updated in accordance with the latest ECIP guidance.



3

2.3 The AE shall ensure that all methods of energy conservation pertaining to USDB, which will reduce the <u>energy consumption</u> of the installation in compliance with the Army Facilities Energy Plan, have been considered and documented. All methods of energy conservation which are reasonable and practical shall be considered, including improvements of operational methods and procedures as well as physical facilities. All new and updated energy conservation opportunities which produce energy or dollar savings shall be documented in this report. Any energy conservation opportunities considered infeasible shall be documented in the report with reasons for eliminating. A list of general energy conservation opportunities (ECOS) is included as Annex A to this scope. This list shall be considered and the evaluation of each ECO documented in the report. This list is not intended to be restrictive but only to assure that at least these opportunities are addressed in the report. Some of the energy conservation opportunities in Annex A may not be applicable. A statement to that effect in the report is all that is required.

2.4 The study shall consider the use of all energy sources. The energy sources include electric, natural gas, liquefied petroleum gas, bulk oil, other oil products, steam when procured, gasoline, coal, solar, etc.

2.5 The "Energy Conservation Investment Program (ECIP) Guidance," described in a letter from DAEN-MPO-U, 10 August 1982 and revised by letters from DAEN-ZCF-U, 4 March 1985 and 11 June 1986, establishes criteria for ECIP projects and shall be used for performing the economic analyses of all ECOs and projects. Construction cost escalation for DD Form 1391 submission shall be calculated using the guidelines contained in <u>AR 415-17</u> and the latest <u>Tri-Service MCP index</u>. The Tri-Service MCP Index, when updated, is contained in the <u>latest applicable</u> edition of the Engineer Improvement Recommendation System (EIRS) bulletin.

2.6 Energy conservation opportunities determined to be technically and economically feasible shall be developed into projects acceptable to installation personnel. This may involve combining similar ECOs into larger packages which will qualify for ECIP or MCA funding, and determining, in coordination with installation personnel, the appropriate packaging and implementation approach for all feasible ECOs.

2.7 All recommended ECOs, including maintenance, operation and low cost, no cost opportunities shall be ranked in order of highest to lowest Savings Investment Ratio (SIR). Projects, after they are determined, shall be categorized by type and ranked within each category in order of highest to lowest SIR.

2.8 Projects which qualify for ECIP funding shall be identified, separately listed, prioritized by Saving Investment Ratio (SIR).

2.9 All energy conservation opportunities shall be listed and prioritized by SIR.



3. PROJECT MANAGEMENT

3.1 <u>Project Managers.</u> The AE shall designate a project manager to serve as a point of contact and liaison for work required under this contract. Upon award of this contract, the individual shall be immediately designated in writing. The AE's designated project manager shall be approved by the Contracting Officer prior to commencement of work. This designated individual shall be responsible for coordination of work required under this contract. The Contracting Officer will designate a project manager to serve as the Government's point of contact and liaison for all work required under this contract. This individual will be the Government's representative.

3.2 <u>Installation Assistance.</u> The Commanding Officer of the Fort Leavenworth DEH will designate an individual who will serve as the point of contact for obtaining information and assisting in establishing contacts with the proper individuals and organizations as necessary in the accomplishment of the work required under this contract.

3.3 <u>Public Disclosures.</u> The AE shall make no public announcements or disclosures relative to information contained or developed in this contract, except as authorized by the Contracting Officer.

3.4 <u>Meetings.</u> Meetings will be scheduled whenever requested by the AE or the Contracting Officer for the resolution of questions or problems encountered in the performance of work. The AE and/or the designated representative(s) shall be required to attend and participate in all meetings pertinent to the work required under this contract as directed by the Contracting Officer.

3.5 <u>Site Visits, Inspections, and Investigations.</u> The AE shall visit and inspect/investigate the site of the project as necessary and required during the preparation and accomplishment of the work.

3.6 Records.

3.6.1 The AE shall provide a record of all significant conferences, meetings, discussions, verbal directions, telephone conversations, etc., with Government representative(s) relative to this contract in which the AE and/or designated representative(s) thereof participated. These records shall be dated and shall identify the contract number, and modification number if applicable, participating personnel, subject discussed and conclusions reached. The AE shall forward to the Contracting Officer within ten calendar days, a r+eproducible copy of the record or receipt.

3.6.2 The AE shall provide a record of requests for and/or receipt of Government/furnished material, data, documents, information, etc., which if not furnished in a timely manner, would significantly impair the normal progression of the work under this contract. The records shall be dated and shall identify the contract number and modification number, if applicable. The AE shall forward to the Contracting Officer within ten calendar days, a reproducible copy of the record of receipt.





3.7 <u>Interviews.</u> The AE and the Government's representative shall conduct entry and exit interviews with the Director of Engineering and Housing and USDB representative before starting work at the installation and after completion of the field work. The Government's representative shall schedule the interviews at least one week in advance.

3.7.1 <u>Entry.</u> The entry interview shall thoroughly brief and describe the intended procedures for the survey and shall be conducted prior to commencing work at the facility. As a minimum, the interview shall cover the following points:

a. Schedules

b. Names of energy analysts who will be conducting the site survey.

c. Proposed working hours.

d. Support requirements from the Director of Engineering and Housing and USDB representatives.

3.7.2 Exit. The exit interview shall include a thorough briefing describing the items surveyed and probable areas of energy conservation. The interview shall also solicit input and advice from the Director of Engineering and Housing and USDB representatives.

4. <u>SERVICES AND MATERIALS.</u> All services, materials (except those specifically enumerated to be furnished by the Government), plant, labor, superintendency and travel necessary to perform the work and render the data required under this contract are included in the lump sum price of the contract.

5. <u>PROJECT DOCUMENTATION</u>. All energy conservation opportunities (ECO') shall be included in one of the following categories and presented in the report as such.

5.1 ECIP Projects. To qualify as an ECIP project, and ECO, or several ECOs which have been combined, must have a construction cost estimate greater than \$200,000, a Saving Investment Ratio (SIR) greater than one and a simple payback period of less than ten years. The overall project, and each discrete part of the project, shall have a SIR greater than one. For all projects meeting the above criteria, complete programming documentation will be required. Programming documentation shall consist of a DD Form 1391, Life Cycle Cost Analysis Summary Sheet(s) (with necessary backup data to verify the numbers presented), and a project development brochure (PDB). A Life Cycle Cost Analysis Summary Sheet shall be developed for each ECO and for the overall project when more than one ECO is combined. For projects and ECOs developed from previous studies, the backup data shall consist of copies of the original calculation and analysis, with new pages updating and revising the original calculation and analysis. In addition, the backup data shall include as much of the following as is available: The increment of work the project or ECO was developed under in the previous study, title(s) of the project(s), the energy to cost (E/C) ratio, the benefit to cost (B/C) ratio, the current working estimate (CWE), and the payback period. This information shall be included as part of the backup data. The purpose of this information is to provide a means to prevent duplication of projects in any future reports.





5.2 <u>MCA Projects.</u> To qualify as a MCA project, and ECO, or several ECOs which have been combined, must have a construction cost estimate greater than \$200,000 and a Saving Investment Ratio (SIR) greater than one. The overall project, and each discrete part of the project, shall have a SIR greater than one. For all projects meeting the above criteria, complete programming documentation will be required. Programming documentation shall consist of a DD Form 1391, Life Cycle Cost Analysis Summary Sheet(s) (with necessary backup data to verify the numbers presented), and a project development brochure (PDB). A Life Cycle Cost Analysis Summary Sheet shall be developed for each ECO and for the overall project when more than one ECO is combined.

5.3 <u>Non-ECIP Projects.</u> Projects which normally do not meet ECIP criteria, but which have an overall SIR greater than one shall be documented. The Life Cycle Cost Analysis Summary Sheet shall be completed through and including line 6 for all projects or ECOs. Each project shall be analyzed to determine if it is feasible even if it does not meet ECIP criteria. These ECOs or projects may not meet the nonenergy qualification test. For projects or ECOs which meet this criteria, the Life Cycle Cost Analysis Summery Sheet, completely filled out, with all the necessary backup data to verify the numbers presented, a complete description of the project and the simple payback period shall be included in the report. Additionally, these projects shall have the necessary documentation prepared, in accordance with the requirements of the Government's representative, for one of the following categories:

a. Quick Return on Investment Program (QRIP). This program is for projects which have a total cost not over \$100,000 and a simple payback period of two years or less.

b. OSD Productivity Investment Funding (OSD PIF). This program is for projects which have a total cost greater than \$100,000 and a simple payback period of four years or less.

c. Productivity Enhancing Capital Investment Program (PECIP). This program is for projects which have a total cost of more than;\$3,000 and a simple payback period of four years or less.

The programs are all described in detail in AR 5-4, Change No. 1.

d. Regular Military Construction Army (MCA) Program. This program is for projects which have a total cost greater than \$200,,000 and a simple payback period of ten to twenty-five years. Projects or ECOs which qualify for this program shall be economically analyzed in accordance with the requirements for Special Directed Studies in Engineering Technical Letter (ETL) 1110-3-332.

e. Low Cost/No Cost Projects. These are projects which the Director of Engineering and Housing can perform with his funds.

5.4 <u>Nonfeasible ECOs.</u> All ECOs which the AE has considered but which are not feasible, shall be documented in the report with reasons and justifications showing why they were rejected.



7

6. <u>DETAILED SCOPE OF WORK.</u> The general Scope of Work is intended to apply to contract efforts for the USDB included under this contract except as modified by the detailed Scope of Work. The detailed Scope of Work is contained in Annex B.

7. WORK TO BE ACCOMPLISHED

7.1 Audit and Analysis

7.1.1 Audit. The audit consists of gathering data and inspecting the USDB in the field. These activities shall be closely coordinated with the Government's representative, the Director of Engineering and Housing and USDB representatives. The AE shall become familiar with the USDB and undertake field trips to obtain required data. The AE shall document his field surveys on forms developed for the survey, or standard forms, and submit the completed forms as part of the report. Data sources shall be identified and assumptions clearly stated and justified. Data collected during the audit shall be in sufficient detail to identify all the major energy using equipment and processes. The AE shall measure and record the voltage and amperage of all motors one horsepower and larger. The information gathered shall be compared to the name plate data to determine whether the motor is being properly utilized. Data should be gathered when the motor is loaded. Air handling system supply, return and exhaust air quantities, temperatures, relative humidities, lighting levels, and similar data shall be based on measurements made during the audit and not on "as-built" drawings. All test and/or measurement equipment shall be properly calibrated prior to its use. Operating sequences for equipment, control schedules, facility operating hours, methods of operation, and past performance records should also be obtained during the (CEN SUPPLIFE audit .-

7.1.2 <u>Analysis.</u> The energy analysis is a comprehensive study of the USDB's energy usage. It includes a detailed investigation of the facilities operation, its environment and its equipment. The energy analysis shall provide the following types of information: (a) a baseline of energy usage of the existing USDB, (b) peak heating and cooling loads, (c) energy usage by systems (<u>lighting</u>, heating, cooling, <u>domestic hot water</u>, etc.), (d) a basis for evaluating ECOs, and (e) a <u>baseline of energy usage of the USDB after</u> incorporation of all recommended ECOs. The AE shall develop graphic presentations, i.e., graphs and charts, which depict a complete energy consumption picture for the USDB as they are now and after implementation of the recommended energy conservation opportunities.

7.1.3 Computer Modeling. The analysis shall use computer modeling. Computer modeling shall be used to incorporate field survey data, weather data, occupancy schedules, building construction data, energy distribution systems and equipment data into a model of the total facility. The computer program shall be used to develop load profiles, calculate energy savings, and evaluate energy conservation opportunities. The computer program shall be capable of analyzing the energy requirements of buildings, performance of heating, cooling, and ventilating equipment, (energy distribution systems, and energy conversion equipment.) The computer results shall be verified by comparing them to any available utility bills or records. The computer program shall analyze the facility on <u>an hour-by-hour basis rather</u> than the bin data method of bin data to simulate an hour-by-hour analysis.



Unless the Building Loads Analysis and Systems Thermodynamic (BLAST) program is used, the AE shall submit a sample computer run with an explanation of all input and output data and a summary of program methodology and energy evaluation capabilities for approval by the Contracting Officer prior to use of the program for analysis. The computer program used must be comparable to the BLAST program.

7.2 Identify ECOs. All methods of energy conservation which are reasonable and practical shall be considered, including improvements of operational methods and procedures and maintenance practices as well as the physical facilities. A list of energy conservation opportunities is included as Annex A to this scope. This list is not intended to e restrictive but only to assure that at least these opportunities are considered in the report. Each of the items shall be considered and discussed in the report. Those items on the list which are not practical, have been previously accomplished, are inappropriate or can be eliminated from detailed analysis based on preliminary analysis shall be listed in the report along with the reason for elimination from further analysis. All potential ECOs which are not eliminated by preliminary considerations shall be thoroughly documented and evaluated as to technical and economic feasibility. The AE shall provide all data needed to support the recommended ECO. All assumptions shall be clearly stated. Calculations shall be prepared showing how all numbers in the ECO were figured. Calculations shall be an orderly step-by-step progression from the first assumption to the final number. A Life Cycle Cost Analysis Summary Sheet shall be prepared for each ECO and included as part of the supporting data for ECOs which would replace the existing heating, ventilating, and air conditioning (HVAC) system or significantly change it (such as converting a multizone system to a variable air volume (HVAV system) the AE is required to run a computer simulation to analyze the system and to determine the energy savings. This requirement to use computer modeling applies only to heated and air conditioned or air conditioned only buildings which exceed 8,000 square feet or heated only buildings in excess of 20,000 square feet. The computer program shall analyze the building on an hour-by- hour basis rather than the bin data method or bin data to simulate an hour-by-hour analysis. Unless the Building Loads Analysis and System Termodynamic (BLAST) program is used, the AE shall submit a sample computer run with an explanation of all input and output data and a summary of program methodology and energy evaluation capabilities for approval of the Contracting Officer prior to use of the program for analysis. The computer program used must be comparable to the BLAST program.

7.3 <u>Prepare Programming Documentation for ECIP Projects.</u> For ECOs which meet ECIP criteria or ECOs which can be combined to meet ECIP criteria, complete programming documentation shall be prepared. Complete programming documentation consists of DD Form 1391, PDB and supporting data. These forms shall be separate from the report. They shall be bound similarly to the final report in a manner which will facilitate repeated disassembly and reassembly. A sample programming document shall be submitted for review and approval with the interim submittal. This sample shall be submitted and approved prior to the preparation of any other programming documentation. To the degree possible, the project selected for the sample submission shall be typical of the majority of subsequent projects to be submitted. The sample shall consist of complete programming documentation with primary emphasis on format and manner of presentation rather than precise accuracy of cost estimates and energy saving data.







7.3.1 Military Construction Project Data (DD Form 1391). These documents shall be prepared in accordance with AR 415-15 and the supplemental requirements in Annex C. A complete DD Form 1391 shall be prepared for each project. The form shall include a statement that the project results from an EEAP study. Documents shall be complete as required for submission to higher DA headquarters. These programming documents will require review and signatures by the proper installation personnel. All documents shall be completed except for the required signatures.

7.3.2 Project Development Brochure (PDB). Preparation of the PDB requires the AE to delineate the functional requirements of the project as related to the specific site. The AE shall prepare PDBs in accordance with AR 415-20 and TM 5-800-3. Most projects will not require all the forms and checklists included in the Technical Manual (TM). Only that information needed for the project shall be included. The PDB-I format described in the TM shall be used for whatever information is needed.

7.3.3 Supporting Data. The AE shall provide all data and calculations needed to support the recommended project. Descriptions of the products, manufacturers catalog cuts, pertinent drawings and sketches shall also be included. A Life Cycle Cost Analysis Summary Sheet shall be prepared for each ECIP project and each discrete part of the project and included as part of the supporting data.

7.4 <u>Prepare Implementation Documentation</u>. For feasible projects or ECOs which normally do not meet ECIP criteria, implementation documentation shall be prepared. Each feasible project or ECO shall be individually packaged and fully documented and included as a separate section in the volume containing the programming documentation. Each project or ECC shall have a complete description of the changes required, economic justifications, sketches, and other backup data included as a section in the report. The documentation required will be as determined by the Governments's representative. Documentation required will be in the categories listed in paragraph 5.3. For the QRIP, OSD PIF and PECIP projects, documentation shall be prepared in accordance with the requirements of AR 5-4, Change No. 1. For MCA projects the documentation required by ETL 1110-3-332 shall be included in lieu of the ECIP Life Cycle Cost Analysis. For low cost/no cost projects which the Director of Engineering and Housing personnel can perform, the following information shall be provided.

- a. Brief description of the project.
- b. Brief description of the reasons for the modification.
- c. Specific instructions for performing the modification.
- d. Estimated dollar and energy saving per year.

e. Estimated man-hours and labor and materials costs. Costs shall be calculated for the current calendar year and so marked. Man-hours shall be listed by trade. For projects that would repair and existing system so that it will function properly, also include the estimated man-hours by trade and labor and material costs necessary to maintain the system in that condition. Some of the simple practical modifications may be developed on a per unit basis.



10

An example of this type of modification would be the repair or replacement of steam traps on an as needed basis. As a rule, however, the AE should develop complete projects, if at all possible, rather than per unit modifications. Separate sheets for each project showing the above information shall be prepared and included in the report.

7.5 List and Prioritize All Projects.

7.5.1 The AE shall list and prioritize all energy conservation opportunities by saving investment ratios.

7.5.2 The AE shall list and prioritize all projects by types of projects and savings investments ratios.

7.6 Submittals, Presentations and Reviews. The work accomplished shall be fully documented by a comprehensive report. The report shall have a table of contents and be indexed. Tabs and dividers shall clearly and distinctly divide sections, subsections, and appendices. All pages shall be numbered. The AE shall give a formal presentation of all but the final submittal to; installation, command, and other government personnel. During the presentation, the personnel in attendance shall be given ample opportunity to ask questions and discuss any changes deemed necessary to the study. A review conference will be conducted the same day, following the presentation. Each comment presented at the review conference will be discussed and resolved or action items assigned. The AE shall provide all comments and written notification of the action taken on each comment to all reviewing agencies within three weeks after the review meeting. It is anticipated that each presentation and review conference will require approximately one working day. The presentation and review conferences will be at the installation on the date(s) agreeable to the Director of Engineering and Housing, the AE and the Government's representative. The Contracting Officer may require a resubmittal of any document(s), if such document(s) are not approved because they are determined by the Contracting Officer to be inadequate for the intended purpose.

7.6.1 Interim Submittal. An interim report shall be submitted for review after completion of the field survey and an analysis has been performed on all of the ECOs. The report shall indicate the work which has been accomplished to date, illustrate the methods and justifications of the approaches taken and contain a plan of the work remaining to complete the study. Calculations showing energy and dollar savings and SIRs of all ECOs shall be included. The simple payback period of all ECOs shall be calculated and shown in the report. The AE shall submit the Scope of Work and any modifications to the Scope of Work as an appendix to the report. A narrative summary describing the work and results to date shall be a part of this submittal. During the review period, the Government's representative shall coordinate with the Director of Engineering and Housing and provide the AE with direction for packaging or combining ECOs for programming purposes. A sample programming document (DD Form 1391, PDB, and supporting data) for one ECIP project shall be submitted with this report. The survey forms only may be submitted in final form with this submittal. They should be clearly marked at the time of submission that they should be retained. They shall be bound in a standard three-ring binder which will allow repeated disassembly and reassembly of the material contained within.





7.6.2 Prefinal Submittal. The AE shall prepare and submit the prefinal report when all work under this contract is complete. The AE shall submit the Scope of Work for the installation studied, and any modifications to the Scope of Work, as an appendix to the submittal. The report shall contain a narrative summary of conclusions and recommendations, together with all raw and supporting data, methods used, and sources of information. The report shall integrate all aspects of the study. The report shall include an order of priority by SIR in which the recommended ECOs should be accomplished. Completed programming and implementation documents for all recommended new projects shall be included. The programming and implementation documents shall be ready for review and signature by the installation commander. The prefinal report, Executive Summary, and all appendices will be bound in standard. three-ring binders which will allow repeated which will allow repeated disassembly and reassembly. The prefinal submittal shall be arranged to include (a) a separately bound Executive Summary, to give a brief overview of what was accomplished and the results of this study using graphs, tables and charts as much as possible (see Annex D for minimum requirements), (b) the narrative report containing a copy of the Executive Summary at the beginning of the volume and describing in detail what was accomplished and the results of this study, (c) appendices to include the detailed calculations and all backup material and (d) the programming and implementation documentation. A list of all projects and ECOs developed during this study shall be included in the Executive Summary and shall include the following data from the Life Cycle Cost Analysis Sheet: the cost construction plus SIOH), the annual energy savings type and amount), the annual dollar savings, the SIR and the analysis date. For all programmed projects also include the year in which it is programmed and the programmed year cost. The simple payback period shall also be shown for these projects and ECOs.

7.6.3 Final Submittal. Any revisions or corrections resulting from comments made during the review of the prefinal report or during the presentation shall be incorporated into the final report. These revisions or corrections may be in the form of replacement pages, which may be inserted in the prefinal report, or complete new volumes. Pen and ink changes or errata sheets will not be acceptable. If replacement pages are to be issued, it shall be clearly stated with the prefinal submittal that the submitted documents will be changed only to comply with the comments made during the prefinal conference and that the volumes issued at the time of the prefinal submittal should be retained. Failure to do so will require resubmission of the complete volumes. If new volumes are submitted, they shall be in standard three-ring binders and shall contain all the information presented in the prefinal report with any necessary changes made. Detailed instructions of what to do with the replacement pages should be securely attached to the replacement pages.

ANNEX A ENERGY CONSERVATION OPPORTUNITIES

Heating, ventilating, and air conditioning

- 1. Shut off air handing units whenever possible.
- 2. Reduce outside air intake when air must be heated or cooled before use.
- 3. Repair and maintain steam lines and steam traps.
- Use outside air for free cooling whenever possible. (Dry bulb economizers)
- 5. Recover heating or cooling with energy recovery units.
- 6. Insulate ducts and piping.
- 7. Install night setback controls.
- Install computerize energy monitoring and control system (EMCS). (Cycle fans and pumps, shead loads during peak use, etc.)
- 9. Maintain equipment (clean coils, maintain filters, repair and/or maintain equipment and controls).
- 10. Convert separate AC units to central plant.
- 11. Replace Current ventilation with new ventilation or replace current ventilation with new windows and HVAC.

Boiler plant

- 1. Reduce steam distribution pressure.
- 2. Increase boiler efficiency.
- 3. Repair, replace, or install condensate return system.
- 4. Insulate boiler and boiler piping.
- 5. Install economizer.
- 6. Install air preheater.
- 7. Check boilerfeed water chemistry program.
- 8. Clean boiler tubes.
- 9. Blowdown controls.
- 10. Boiler and chiller control modifications.
- 11. Water treatment to prevent tube fouling.
- 12. Blowdown heat recovery.
- 13. Oxygen trim controls.
- 14. Convert complete DB heating system from high pressure steam to hot water.
- 15. Convert high pressure steam to co-generation.

Lighting

- 1. Reduce lighting levels.
- 2. Convert to energy efficient systems.

Building envelope

- 1. Reduce infiltration by caulking and weather-stripping.
- 2. Install insulated glass or double glazed windows.
- 3. Install roof insulation.
- 4. Install loading dock seals.
- 5. Install vestibules on entrances.
- 6. Reduce window heat gain by solar shading, screening, curtains, or blinds.
- 7. Install wall insulation.
- 8. Prevent air stratification.

Electrical equipment

- 1. Install capacitors and synchronous motor to increase power factor.
- 2. Convert to energy efficient motors.

Plumbing

- 1. Reduce domestic hot water temperature.
- 2. Install flow restrictions. (Shower & sinks).
- 3. Install faucets which automatically shut off water flow.
- 4. Decentralize hot water heating.
- 5. Add pipe insulation.

Laundry

- 1. Install heat reclamation system for laundry wash water.
- 2. Install heat reclamation system on dryers.
- 3. Install heat reclamation system on irons.

Kitchen

- 1. Shut off range hood exhaust whenever possible.
- 2. Install high-efficiency steam control valves.
- 3. Shut off equipment and appliances whenever possible.
- 4. Install makeup air supply for exhaust.
- 5. Install heat reclamation system for exhaust heat.
 - 6. Turn off lights in coolers.
 - 7. Water heating heat pump.

....

ANNEX B

ENERGY SURVEY FOR THE UNITED STATES DISCIPLINARY BARRACKS (USDB) ENERGY ENGINEERING ANALYSIS PROGRAM (EEAP) FORT LEAVENWORTH, KANSAS

DETAILED SCOPE OF WORK

1. <u>Brief Description of Work.</u> This project involves a coordinated energy study, including a detailed energy survey for the United States Disciplinary Barracks (USDB) at Fort Leavenworth, Kansas. This study shall integrate the results of all prior to ongoing energy conservation. projects, designs or plans with work done under this contract.

2. <u>Authorization.</u> This project is authorized by CEHND-ED-PM letter dated 29 Nov 88, subject: Energy Engineering Analysis Program (EEAP) FY89 Budget.

3. <u>Services to be performed by the Contractor</u>. The A-E shall perform and shall assume responsibility for the accuracy of the work and completeness of the following services in connection with the above project in accordance with the General Scope of Work as amended by criteria and instruction listed herein. Quality of work accomplished under this contract will be a determining factor in consideration of the A/E for future work.

a. POC at Fort Leavenworth will be Mr. Richard Wilms at 913-684-5639.

b. POC at Kansas City District will be Mr. Robert McCormick at 816-426-2782.

c. POC at USDB will be Capt. Doane at 913-684-2560.

d. ECIP projects shall be estimated to and programmed for implementation as FY 95 projects.

e. Five 1391/PDB will be prepared. Should more or less be required, suitable adjustment to the contract price will be made.

f. The AE shall develop a long range plan to identify all projects needed to make the USDB complex an energy saving institution. Projects shall be grouped in accordance with existing funding guidance.





5. Distribution. Fifteen (15) sets of each submittal shall be furnished to reviewers in accordance with the following distribution schedule:

5 copies

1 copy

1 copy

Commander U.S. Army Engineer District, Kansas City 5 copies ATTN: CEMRKED-MF/McCormick 700 Federal Building Kansas City, MO 64106-2896 2 copies Commander

Missouri River Division ATTN: CEMRDED-MA/Whelchel PO Box 103, Downtown Station Omaha, Nebraska 68101-0103

Commander CAC & Ft. Leavenworth ATTN: ATZL-GEH Building 85 Ft. Leavenworth, KS 66027-5020

Commander USACE-CEEC-EE/Mr. D. Beranek 20 Massachusetts Avenue, NW Washington, DC 20314

Commander HQ, TRADOC ATTN: ATEN-FE Fort Monroe, VA 23351

Transmission of documents will be by express mail or other expedient means. Only two (2) copies of the survey forms will be provided, one to CEMRK-ED-MF and one to Fort Leavenworth.

6. Data, Information and Services to be Furnished by the Government. The Government will furnish the following data, information, and services:

a. A/E Instructions.

b. Energy Conservation Investment Program (ECIP) Guidance, dated 10 Aug 82 , and revisions dated 4 Mar 85 and 11 June 86.

c. ETLs 1110-3-254, Use of Electric Power Comfort Space Heating, 1110-3-282, Energy Conservation, 1110-3-294, Interior Design Temperatures, 1110-3-318, Procedures for Programming Energy Monitoring and Control Systems (EMCS) Funded through the MCA Program, 1110-3-332, Economic Studies, 1110-3-354, Direct Digital Control of HVAC Systems and 1110-3-364, Storm Windows.

d. TM 5-785, Engineering Weather Data, TM 5-800-2, General Criteria Preparation of Cost Estimates, TM 5-800-3, Project Development Brochure and TM 5-815-2, Energy Monitoring and Control Systems (EMCS).





e. AR 415-15, Military Construction Army (MCA) Program Development, AR 415-17, Cost Estimating for Military Programming, AR 415-20, Construction Project Development and Design Approval, AR 415-28, Department of the Army Facility Classes and Construction Categories, AR 415-35, Construction, Minor Construction, AR 420-10, General Provisions, Organization, Functions and Personnel, and AR 5-4, Change No. 1, Department of the Army Productivity Improvement Program.

f. An example of a currently completed programming document for an ECIP project.

7. <u>Completion Schedule.</u> The A/E shall complete the work and services for each increment as follows:

a. Interim submittal - within one hundred and eighty (180) calendar days of Notice to Proceed.

b. Prefinal Submittal - within sixty (60) calendar days of the interim submittal presentation and review conference.

c. Final submittal - within sixty (60) calendar days after prefinal submittal presentation and review conference.

The A/E shall allow a period of approximately forty five (45) days for review by Government forces for each submission. Presentation of each submission will occur upon completion of the review period for that submission.

8. Method of Payment.

a. <u>Title I Services - Design</u>. Payment for design work and services will be made in accordance with the following procedures:

Partial Payment. The Architect-Engineer shall prepare and submit to the U.S. Army Engineer District, Kansas City, partial payment estimates using ENG Form 93, which shall serve as the request for payment. All partial payments shall be based on work completed as of the 15th day of the report month and shall be submitted to the office of the Contracting Officer by the 18th day of the month. The pay estimate shall be submitted with ENG Form 93, in accordance with the "Instructions for Completion of ENG Form 93 - Payment Estimate, "dated 5 January 1983. The U.S. Army Engineer District, Kansas City, will prepare supporting payment documents after obtaining necessary approvals and forward all documents to the U.S. Army Engineer District, Omaha, for issuance of the payment check. All questions, regarding payments shall be directed to the U.S. Army Engineer District, Kansas City.

b. <u>Additional Conferences.</u> Payment for furnishing the services of technically qualified representatives to attend conferences other than the review conferences specified above, when so requested in writing by the Contracting Officer, will be made at rate per hour for the discipline involved plus travel expenses computed in accordance with Government Joint Travel Regulations. Payment for attending additional conferences shall be made after submittal of a separate ENG Form 93, which shall not be assigned a partial payment estimate number.





9. <u>Video Record.</u> The government reserves the right to make a video record of the presentation.



۰. •

, -

18

ł

ANNEX C

REQUIRED DD FORM 1391 DATA

To facilitate ECIP project approval, the following supplemental data shall be provided:

a. In title block, clearly identify projects as "ECIP."

b. Complete description of each item of work to be accomplished including quantity, square footage, etc.

c. A comprehensive listing of buildings, zones, or areas including building numbers, square foot floor areas, designated temporary or permanent, and usage.

d. List references, assumptions and provide calculations to support dollar and energy savings, and indicate any added costs.

(1) If a specific building, zone, or area is used for sample calculations, identify building, zone or area, category, orientation, square footage floor area, window and wall area for each exposure.

(2) Identify weather data source.

(3) Identify infiltration assumptions before and after improvements.

(4) Include source of expertise and demonstrate savings claimed. Identify any special or critical environmental conditions such as pressure relationships, exhaust or outside air quantities, temperatures, humidity, etc.

e. Claims for boiler efficiency improvements much identify data to support present properly adjusted boiler operation and future expected efficiency. If full replacement of boilers is indicated, explain rejection of alternatives such as replace burners, nonfunctioning controls, etc. Assessment of the complete existing installation is required to make accurate determinations of required retrofit actions.

f. Lighting retrofit projects must identify number and type of fixtures, and wattage of each fixture being deleted and installed. New lighting shall be only of the level to meet current criteria. Lamp changes in existing fixtures is not considered an ECIP type project.

g. An ECIP Life Cycle Cost Analysis Summary Sheet as shown in the ECIP Guidance shall be provided for the complete project and for each discrete part included in the project. The SIR is applicable to all segments of the project. Supporting documentation consisting of basic engineering and economic calculations showing how savings were determined shall be included.

h. The DD Form 1391 face sheet shall include, for the complete project, the annual dollar and MBTU savings, SIR, simple amortization period and a statement attesting that all buildings and retrofit actions will be in active use throughout the amortization period.





i. The calendar year in which the cost was calculated shall be clearly shown on the DD Form 1391.

j. For each temporary building included in the project. Separate documentation is required showing (1) a minimum 10-year continuing need, based on the installation's annual real property utilization survey, for active building retention after retrofit, (2) the specific retrofit action applicable, and (3) an economic analysis supporting the specific retrofit.

k. Nonappropriated funded facilities will not be included in an ECIP project without an accompanying statement certifying that utility costs are not reimbursable.

1. Any requirements required by ECIP guidance dated 10 August 1982 and any revisions thereto. Note that unescalated costs/savings are to be used in the economic analysis.

m. The five digit category code number for all ECIP projects developed under this scope of work is 80000.

ANNEX D

EXECUTIVE SUMMARY GUIDELINE

- 1. Introduction.
- 2. Building Data (types, similar facilities, sizes, etc.).
- 3. Present Energy Consumption.
 - o Total Annual Energy Used.
 - o Source Energy Consumption.

Electricity - KWH, Dollars, BTU Fuel Oil - GALS, Dollars, BTU Natural Gas - THERMS, Dollars, BTU Propane - GALS, Dollars, BTU Other - QTY, Dollars, BTU

o Energy Consumption by Systems.

4. Historical Energy Consumption.

5. Energy Conservation Analysis.

o ECOs Investigated.

- o ECOs Recommended.
- o ECOs Rejected. (Provide economics or reasons)
- o ECIP Projects Developed. (Provide list)*
- o Non-ECIP Projects Developed. (Provide list)*
- o Operational or Policy Change Recommendations.

* Include the following data from the Life Cycle Cost Analysis Summary Sheet: the cost (construction plus SIOH), the annual energy savings (type and amount), the annual dollar savings, the SIR and the analysis date. For all programmed projects also include the year in which it is programmed and the programmed year cost. Show the simple payback period for all ECOs.

6. Energy and Cost Savings.

- o Total Potential Energy and Cost Savings.
- o Percentage of Energy Conserved.

o Energy Use and Cost Before and After the Energy Conservation Opportunities are Implemented.





1

- 7. Energy Plan.
 - o Project Breakouts with Total Cost and SIR.
 - o Schedule of Energy Conservation Project Implementation.



MEETING MINUTES

CLARK, RICHARDSON AND BISKUP

Consulting Engineers, Inc.----



2701 ROCKCREEK PARKWAY • SUITE 111 • NORTH KANSAS CITY, MO 64117 TELEPHONE (816) 472-7200 FAX: (816) 472-1385

October 23, 1989

Department of the Army Kansas City District, Corps of Engineers 700 Federal Building 601 East 12th St. Kansas City, Missouri 64106

Attn: MRKED-MF/Robert McCormick

Re: Energy Engineering Analysis for the United States Disciplinary Barracks. Notes from the initial meeting.

Bob,



The enclosed notes are from our first meeting with Ft. Leavenworth personnel where we discussed the procedures required for us to gain and maintain access inside the USDB for the field work required for this project.

I would also like to request the government furnished information outlined on page 16 of Annex B of the scope of work. We would appreciate this information as soon as possible.

If you have any questions please call myself or Gary Transmeier at 472-7200.

Sincerely,

Mark A. Wendland, P.E. Clark Richardson & Biskup

cc.. Rich Willms - Ft Leavenworth DEH Tom Lance - Architects Consortium

Meeting Notes

PROJECT: Energy Survey for the United States Disciplinary Barracks

DATE: October 16, 1989

SUBJECT: Entry Interview

ATTENDING: Mark Wendland - CRB Tom Lance -Architects Consortium Rich Willms - Ft. Leavenworth DEH

Gary Transmeier - CRB Dave Scott - Architects Consortium Captain Doane - USDB

Requirements for access to USDB

- 1. CRB will send names and SS numbers of persons requiring access to the USDB to Rich W. by 10/18/89. Security check is expected to take 10 working days from the receipt of the information.
- 2. Cameras are allowed in the USDB, however no pictures of inmates are allowed. Rich will explore the possibility of Ft. Leavenworth developing the pictures and clearing them for the A/E's use.
- 3. Tools are allowed, ie: wrenches, screwdrivers, measuring equipment etc., however they should be kept to the minimum number required for that days work and be in a locked case when they are not in use. Additionally, a property pass will be carried identifying which tools are carried into the USDB so they can be checked out when leaving the facility. The tools will also be engraved or marked with the CRB logo to help identify tools. We understand that if a tool is lost or stolen, we should immediately notify Captain Doane. Ladders can be used inside the facility, however the A/E will need to schedule their use with Captain Doane at least 1 day in advance.
- 4. Parking and entrance to the facility will be by the west personnel gate. Cars should be registered with the Provo office.
- 5. Hours of access should be from 8:00 AM to 11:30 AM and from 12:30 PM to 4:30 PM to avoid delays and interference with transfer schedules of inmates working outside the facility. Access at all hours is allowed however the west gate closes at 5:00 PM and the south or main entrance will be used. We do not anticipate needing access other than the hours scheduled.
- 6. The only holiday that may interfere with the field work, is November 10, 1989, veterans day. We will work around that holiday





- 7. If an alarm is sounded while A/E personnel are inside the facility, the personnel are to proceed directly to the west gate and will be escorted out of the facility. If exiting at the west gate is not possible, go to Captain Doane's office in building 467. His number is 684-2560.
- 8. A/E field personnel should stay in pairs and travel with a guard thru maximum security areas. All field personnel will carry a small card identifying the person, describing the project and identifying Captain Doane as our USDB contact to help facilitate the interface between field personnel and USDB personnel.

General Project Information

- 9. Outside contractor labor rates should be used for all cost estimates.
- 10. In the medical sections of building 465 equipment shutdowns should be scheduled.
- 11. A schedule of the areas we intend to survey and the days we will be there will be given to Captain Doane to help identify possible coordination problems with other work in the facility.
- 12. The kitchen areas are known to have inadequate ventilation. Building 463, (Visitor Center) is also known to be inadequate.

DATE: 1-29-90

ATTENDING: Dave Anaya - DEH Fred Murawski - USDB Mike Mahoney - CRB Mark Wendland - CRB

SUBJECT: USDB - ECO Development

A list of Applicable Buildings for Each ECO was passed out. (See attached list.) ECO's are divided into Architectural, Mechanical and Electrical classifications. The buildings that applied to each ECO are listed under that ECO. Each ECO was discussed along with the buildings listed under it, and modifications to the lists were made based on the discussion. ECO's were modified and buildings were deleted and added based on the information from Dave. Anaya. and Fred Murawski.

- 1. Castle will be considered in terms of ventilation only. No mechanical cooling.
- 2. Better funding opportunities exist for new work packages with construction costs of less than \$200,000. Repair work can go to \$2,000,000.
- 3. The existing Castle is currently being modified. 2 tier (old laundry) will become a craft shop. 3 tier (mess) will be remodeled. All other tier functions will remain.
- 4. Buildings 465, 474 and Castle have all had new roofs, in the last five years. 6" of insulation was added at that time.
- 5. The only dock door to consider is on building 470, which is not part of the study. We will still provide an ECO on the door.
- 6. Window tinting for solar shading ECO is not a security problem.
- 7. On applicable ECO's separate out the cost of adding prison inmate construction.
- 8. In some cases avoided costs can be used to improve paybacks. Only if the cost would already have to be incurred by the USDB at some point within the payback period.
- 9. Use ACA prison standards for minimum ventilation requirements.
- 10. Buildings 463 and 473 have no warm up capability. Existing systems are to small.
- 11. Synergistic effects will be modeled for the Final Submittal once the initial savings have been determined for the Interim Submittal.
- 12. Previous maintenance experience indicates that installing flow restricters and automatic shut off valves are not acceptable.



Consulting Engineers, Inc., P.C.---

UNIVERSAL PLAZA 6900 NORTH EXECUTIVE DRIVE • SUITE 201 • KANSAS CITY, MISSOURI 64120 TELEPHONE (816) 483-0600 FAX: (816) 483-0111

DATE:

February 14, 1990

Fort Leavenworth

CRB #1496

LOCATION:

ATTENDEES: Richard Willms Fort Leavenworth DEH Captain Doane USDB Tom Lance ACI David Scott ACI

SUBJECT:

USDB Energy Study

ITEMS:

- 1. ACI gave Captain Doane a sample of the metal clad gypboard that would be used for an interior skin if insulation were added to the castle cell barracks. Captain Doane stated that the metal clad gypboard would only be necessary for the castle cell wings 475C, D, F, G and 475E in the gym and mess hall. The metal clad gypboard is only necessary from the floor to 10'. Above 10' a standard gypboard is sufficient. All other buildings in the USDB that are being considered for wall insulation can have standard gypboard.
- 2. ACI discussed the replacement of single pane windows with a double glazed window with a better coefficient of heat transfer. Captain Doane stated that some of the buildings in the USDB are considered historical and cannot have any exterior changes made to them. Captain Doane will get a list of the historical buildings to CRB. Richard Willms will get a copy of the window specification presently being used by the Fort Leavenworth DEH to CRB.
- 3. ACI discussed the use of exterior shading on the windows of the buildings to cut down on the solar load. A low "e" film cover would be acceptable. Only those windows with surfaces facing the sun with a large solar gain need to have the window film installed. The windows facing north do not need the film.
- 4. ACI showed feasible ideas for vestibules on buildings 463 (south gate) and the castle. Richard Willms stated he would like to see improvements to the existing vestibules in the castle. He also stated he would like to see a revolving door on the south of building 463 and a new vestibule on the north door. Captain Doane stated he would get the bullet resistant glass type requirements for the south door on building 463 to CRB.



2/16/90

Meeting Minutes

Page 1

- 5. CRB briefly stated that the base load modeling was completed and that CRB had started writing the ECO reports. Not all of the ECO reports require the use of the computer model for the buildings.

The items listed above represent our interpretation of the meeting events. Please contact Michael Mahoney if there are any additions or revisions to the above items.

Michael J. Mahoney

Michaelf Mohoney

