

ESTCP Cost and Performance Report

(EW-200821)



Dew Point Evaporative Comfort Cooling

July 2013



ENVIRONMENTAL SECURITY
TECHNOLOGY CERTIFICATION PROGRAM

U.S. Department of Defense

Report Documentation Page

Form Approved
OMB No. 0704-0188

Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.

1. REPORT DATE JUL 2013		2. REPORT TYPE		3. DATES COVERED 00-00-2013 to 00-00-2013	
4. TITLE AND SUBTITLE Dew Point Evaporative Comfort Cooling				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Environmental Security Technology Certification Program (ESTCP), 4800 Mark Center Drive, Suite 17D08, Alexandria, VA, 22350-3605				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT Same as Report (SAR)	18. NUMBER OF PAGES 47	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			

COST & PERFORMANCE REPORT

Project: EW-200821

TABLE OF CONTENTS

	Page
EXECUTIVE SUMMARY	ES-1
1.0 INTRODUCTION	1
1.1 BACKGROUND	1
1.2 OBJECTIVES OF THE DEMONSTRATION.....	1
1.3 REGULATORY DRIVERS	2
2.0 TECHNOLOGY DESCRIPTION	3
2.1 EVAPORATIVE COOLING.....	3
2.2 TECHNOLOGY OVERVIEW	4
2.2.1 How It Works.....	5
2.3 ADVANTAGES AND LIMITATIONS OF THE TECHNOLOGY.....	7
3.0 PERFORMANCE OBJECTIVES	9
4.0 FACILITY/SITE DESCRIPTION.....	11
4.1 FACILITY/SITE LOCATION AND OPERATIONS.....	12
4.2 FACILITY/SITE CONDITIONS	12
5.0 TEST DESIGN	13
5.1 CONCEPTUAL TEST DESIGN.....	13
5.2 BASELINE CHARACTERIZATION.....	13
5.3 DESIGN AND LAYOUT OF TECHNOLOGY COMPONENTS	13
5.4 OPERATIONAL TESTING.....	13
5.5 SAMPLING PROTOCOL	14
6.0 PERFORMANCE ASSESSMENT	15
6.1 QUALITATIVE PERFORMANCE OBJECTIVES.....	17
7.0 COST MODEL	19
7.1 COST ANALYSIS AND COMPARISON.....	22
7.1.1 Results.....	23
8.0 IMPLEMENTATION ISSUES	25
8.1 LESSONS LEARNED.....	25
8.2 DECISION MAKING FACTORS	27
8.2.1 Climate.....	27
8.2.2 HVAC Equipment Replacement.....	27
8.2.3 Facilities with No Cooling and New Construction.....	27
8.2.4 Facility Types.....	29

TABLE OF CONTENTS (continued)

	Page
9.0 REFERENCES	31
APPENDIX A POINTS OF CONTACT.....	A-1

LIST OF FIGURES

	Page
Figure 1.	Multistaged indirect evaporative cooler installation priorities. ES-3
Figure 2.	DEC media..... 4
Figure 3.	Internal HMX process airstream and EA stream airflow..... 6
Figure 4.	Side view of Coolerado airflow process. 6
Figure 5.	ASHRAE climate zone map. 8
Figure 6.	Coolerado DAS..... 14
Figure 7.	Coolerado seasonal efficiency comparison..... 19
Figure 8.	Training facility annual operating cost comparison..... 21
Figure 9.	Coolerado drain water piping..... 25
Figure 10.	Coolerado units and manhole over water storage tank. 26
Figure 11.	Military bases by ASHRAE climate zone. 28

LIST OF TABLES

	Page
Table 1.	Quantitative performance objectives. ES-1
Table 2.	Qualitative performance objectives. ES-2
Table 3.	Quantitative performance objectives. 9
Table 4.	Qualitative performance objectives. 9
Table 5.	Building types at Fort Carson. 11
Table 6.	TMY3 and measured climate data. 11
Table 7.	Quantitative performance objectives. 15
Table 8.	Qualitative performance objectives. 15
Table 9.	2010 and 2011 quantitative performance results. 16
Table 10.	Coolerado installed costs. 20
Table 11.	Fort Carson Coolerado economics. 21
Table 12.	Fort Carson Coolerado economics. 22
Table 13.	Utility rates for selected locations. 23
Table 14.	Energy savings and cost analysis results. 23

ACRONYMS AND ABBREVIATIONS

AC	air conditioning
AHU	air handling unit
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
BLCC	Building Life Cycle Costing
Btu	British thermal units
cfm	cubic feet per minute
CoC	cycle of concentration
CRAC	computer room air-conditioner
DAS	data acquisition system
DEC	direct evaporative cooler
DoD	U.S. Department of Defense
DOE	U.S. Department of Energy
DX	direct expansion
E.O.	Executive Order
EA	exhaust air
EAT	exhaust air temperature
ECM	electronically commutated motor
EER	energy efficiency ratio
EISA	Energy Independence and Security Act
ESTCP	Environmental Security Technology Certification Program
EUI	energy use intensity
FEMP	Federal Energy Management Program
ft ²	square feet
FY	fiscal year
HMX	heat mass exchanger
HVAC	heating, ventilating, and air-conditioning
IEC	indirect evaporative cooling
IEER	integrated energy efficiency ratio
kBtu	kilo British thermal unit
kW	kilowatt
kWh	kilowatt-hour
M-Cycle	Maisotsenko Cycle
MCDB	mean coincident dry bulb
mi ²	square miles
MMBtu	million British thermal units

ACRONYMS AND ABBREVIATIONS (continued)

NPV	net present value
NREL	National Renewable Energy Laboratory
O&M	operations and maintenance
OA	outdoor air
OAT	outside air temperature
PSZ	packaged single zone
RA	return air
RAT	return air temperature
RH	relative humidity
RTU	rooftop unit
SA	supply air
SAT	supply air temperature
SP	static pressure
SPP	simple payback period
TDS	total dissolved solids
TMY	typical meteorological year
ton-h	ton hours
TTF	Thermal Test Facility
U.S.	United States
WBE	wet bulb effectiveness

ACKNOWLEDGEMENTS

The authors would like to thank the Environmental Security Technology Certification Program (ESTCP) project team members for their creativity, persistence, and willingness to support this project. Scott Clark, the Energy Program Coordinator for Fort Carson, was instrumental in setting up the demonstration and has provided countless hours assisting with the installation of the data acquisition system (DAS) and multiyear performance testing. Fort Carson engineers worked with the project partners to design and integrate the Coolerado units into five facilities and designed an innovative rain water catchment system for four units at the Theater. Mountain Energy Partnership provided invaluable assistance with the design and installation of the DAS, as well as data analysis support. On-site heating, ventilation, and air-conditioning technicians diligently recorded operation and maintenance activities and provided valuable insights into operation and maintenance costs of the units. Several members of the Coolerado team, including Tim Heaton, Steve Slayzak, Leland Gillian, and Daniel Zube, also went out of their way to accommodate the requests of the Fort Carson and National Renewable Energy Laboratory (NREL) staff members. Various members of NREL's Commercial Buildings Research team, including James Page, Andrew Parker, Michael Deru, and Brent Griffith, provided laboratory and field testing assistance and modeling support. Finally, the project would not have been possible without financial support from the ESTCP program, whose members also provided valuable insights into the types of data analysis procedures and results that would be most beneficial to U.S. Department of Defense (DoD) facilities and engineers.

*Technical material contained in this report has been approved for public release.
Mention of trade names or commercial products in this report is for informational purposes only;
no endorsement or recommendation is implied.*

This page left blank intentionally.

EXECUTIVE SUMMARY

Air-conditioning (AC) is the single largest contributor to peak demand on United States (U.S.) electricity grids and is the primary cause of grid failures and blackouts (Purdum, 2000. Power generators and refrigeration-based AC units are least efficient at high ambient temperatures, when cooling demand is highest. AC accounts for approximately 15% of all source energy used for electricity production in the U.S. alone (nearly 4 quadrillion British thermal units [Btu]), which results in the release of about 343 million tons of carbon dioxide into the atmosphere every year (U.S. Department of Energy [DOE], 2011). Evaporative ACs can mitigate the environmental impacts and help meet Energy Independence and Security Act (EISA) 2007 and U.S. Department of Defense (DoD) energy policy goals by eliminating energy waste and reducing electricity demand.

Researchers have developed a new multi-staged indirect evaporative cooling (IEC) technology known as the Coolerado Cooler. This technology uses a thermodynamic cycle referred to as the Maisotsenko Cycle (or M-Cycle). The product works by cooling both the primary (or product) air and the secondary (or working) air in a 20-stage process. Each stage contributes to cooling by combining multiple direct stages with a single indirect stage. The cumulative result is a lower supply air temperature than is possible with conventional evaporative cooling technologies, as the unit can achieve wet bulb effectiveness (WBE) of 90%–120%.

The project objective was to demonstrate the capabilities of the high-performance multi-staged IEC technology and its ability to enhance energy efficiency and interior comfort in dry climates, while substantially reducing electric-peak demand. The project was designed to test 24 cooling units in five commercial building types at Fort Carson Army Base in Colorado Springs, Colorado, to provide an analysis of energy use, water use, energy performance, and interior thermal comfort. In addition to these buildings, a stand-alone unit was installed at the wastewater treatment plant to test the technology’s ability to operate using gray water. Table 1 and Table 2 summarize the performance objectives, success criteria, and results.

Table 1. Quantitative performance objectives.

Performance Objective	Success Criteria	Results
Improve comfort provided by evaporative cooling <i>(Performance)</i>	<1% outside ASHRAE summer comfort zone Supply air <70°F	<i>Comfort Zone = Pass</i> <i>Supply air <70°F = Pass for 80% of units monitored</i>
Provide high-efficiency cooling <i>(Energy Efficiency)</i>	Peak power <1 kilowatt (kW)/ton Average power <0.6 kW/ton	<i>Peak Power = Pass</i> <i>Average Power = Pass</i>
Sustain high cooling performance <i>(Service Life)</i>	<5% degradation of WBE over 3 years Negligible increase in supply air pressure drop	<i>WBE = Pass</i> <i>Negligible Increase pressure drop = Pass</i>
Minimize water consumption <i>(Water Conservation)</i>	Demonstrate conservation approach consuming <2.5 gal/ton-h	<i>Water use = Fail</i>

ASHRAE = American Society of Heating, Refrigerating and Air-Conditioning Engineers
kW = kilowatt
gal/ton-h = gallon per ton hour

Table 2. Qualitative performance objectives.

Performance Objective	Success Criteria	Results
Maintainability (<i>Ease of use</i>)	A single facility technician able to effectively operate and maintain equipment with minimal training	<i>Pass</i>
Maintainability (<i>Cost</i>)	>90% of units fall within nominal IEC maintenance schedule by project end	<i>Pass</i>
Maintainability (<i>Failure</i>)	No signs of biological growth, including gray-water unit No ruptured water lines	<i>Fail</i>

In general, the units met all performance objectives other than the supply air temperature limit for select units, the water draw requirement, and maintainability (failure). The increased water draw was due to high water consumption settings in the Coolerado controls, which were modified near the end of the 2011 cooling season. These modifications reduced water consumption to levels that were slightly higher than the original performance metric and were around 3 gal/ton-h. The test unit that was operated on gray-water showed significant algae growth that rendered the unit inoperable within a span of 3 weeks.

The Coolerado units demonstrated the ability to operate with an average seasonal efficiency as low as 0.157 kW/ton (energy efficiency ratio [EER] = 76.4) when calculated as a function of the total cooling provided by the unit and as low as 0.262 kW/ton (EER = 45.8) when calculated as a function of building cooling, which is considerably better than the specified performance metric.

The total installed costs, seasonal energy efficiency, energy use, and projected water consumption of the Coolerado units were used to compare the economics and performance to a code-minimum packaged rooftop unit (RTU) with an integrated energy efficiency ratio (IEER) of 12. Given the measured performance of the Coolerado units during the 2011 cooling season, the annual energy savings were estimated at 63.3% compared to a code-minimum RTU. The estimated simple payback was 7.62–41.8 years, depending on the facility that the unit was installed in when the maintenance costs were assumed to be equivalent to a packaged RTU.

The economics are extremely sensitive to operations and maintenance (O&M) costs; any increase or decrease in O&M costs has a significant impact on the economics of the installation.

The performance of the Coolerado technology was also evaluated in a retrofit scenario using the energy simulation software tools eQuest and EnergyPlus in three building types across six applicable climate zones (Phoenix, AZ; Las Vegas, NV; Los Angeles, CA; Albuquerque, NM; Colorado Springs, CO; and Helena, MT). Building types included a small classroom (400 square feet [ft²]), a data center (19,994 ft²), and a quick-serve restaurant (2500 ft²). The performance of the Coolerado units was compared to common cooling technologies with respect to energy use, water consumption, and O&M costs. The economics were calculated using the federal life cycle costing procedures outlined in the Federal Energy Management Program (FEMP) Building Life Cycle Costing (BLCC).

The Coolerado technology can reduce energy use by 57%–92% relative to standard air-cooled, refrigeration-based AC units, depending on facility type, location, baseline heating, ventilating, and air-conditioning (HVAC) equipment, and technology application. The Coolerado technology

has the best economics when applied to data centers, which had a positive net present value (NPV) in all climate zones. The quick service restaurant had favorable economics in Phoenix and unfavorable economics in Colorado Springs and the simple payback period (SPP) was better in both climate zones than the single-zone classroom. The single-zone classroom unit showed favorable economics in Phoenix and Las Vegas, and unfavorable economics with payback periods of 52–345 years in Los Angeles, Albuquerque, Colorado Springs, and Helena.

The economic analysis indicates that the Coolerado technology has the best economics as a retrofit technology when it is competing against smaller air-cooled AC systems with EERs of 8–12. DoD should target facility types with high internal loads and/or high ventilation rates that require year-round cooling. The data center application is the most cost effective application in all five applicable climate regions and this application should take precedence over all other applications. For common DoD spaces such as offices, warehouses, and other facilities with internal loads below 2 Watts/ft², the system is not life cycle cost effective if the building has an existing cooling system; unless it is installed in locations that require year around cooling such as Phoenix or Las Vegas as an outside air pre-conditioner. The multistage indirect evaporative cooler system should be considered in new construction and for facilities without existing AC systems in all five climate zones. Figure 1 lists the top three suggested installation priorities for DoD.




Figure 1. Multistaged indirect evaporative cooler installation priorities.

This page left blank intentionally.

1.0 INTRODUCTION

Evaporative cooling is an environmentally beneficial technology that is losing ground in parts of the country where it provides the greatest pollution reduction benefits and electricity grid congestion relief. The overall value proposition of evaporative coolers has failed to prevent over-reliance on electric-peaking mechanical air conditioning (AC), largely because of perceptions of inferior comfort. Innovative, high-performance, multi-staged indirect evaporative cooling (IEC) units have been developed that surpass evaporative cooling paradigms for comfort-cooling applications and have demonstrated the ability to significantly reduce AC energy use.

1.1 BACKGROUND

AC is the single largest contributor to peak demand on U.S. electricity grids and is a cause of grid failures and blackouts. Power generators and refrigeration-based AC units are least efficient at high ambient temperatures, when cooling demand is highest. This leads to increased pollution, excessive investment in standby generation capacity, and poor utilization of peaking assets. Evaporative ACs can help meet the Energy Independence and Security Act (EISA) and U.S. Department of Defense (DoD) energy policy goals by eliminating energy waste and reducing electricity demand.

A common misconception is that evaporative coolers do not supply cold enough air to meet accepted comfort standards. New dew point evaporative cooler configurations can provide colder supply air (SA) temperatures (SAT) and more comfortable indoor conditions than traditional evaporative cooling systems. This technology can lower AC energy consumption by 50%–90% relative to standard air-cooled, refrigeration-based AC units, and reduce the total peak demand of a base in arid western states. In California, for example, AC energy use comprises 30% of the summer peak electricity demand (Brown, 2002).

In addition to the energy benefits the technology will also reduce inventories of ozone depleting refrigerants and enhance health, comfort, and productivity by providing ventilation rates in compliance with or exceeding American Society of Heating and Air Conditioning Engineers (ASHRAE) Standard 62.1-2010 Ventilation for Acceptable Indoor Air Quality (ASHRAE, 2010), Leadership in Engineering and Environmental Design 2009 v2.2 requirements U.S. Green Building Council, 2009).

1.2 OBJECTIVES OF THE DEMONSTRATION

The primary objective was to demonstrate the capabilities of a new high-performance, multi-staged IEC technology to enhance energy efficiency and interior comfort in dry climates, while substantially reducing electric peak demand. The project was designed to test 24 cooling units in five commercial building types to provide a side-by-side comparison of energy use, water use, energy performance, and interior thermal comfort. The objectives are provided below:

- Validate the performance of the units relative to predefined qualitative and quantitative performance metrics:
 - Improve comfort provided by evaporative cooling,

- Provide high efficiency cooling,
 - Sustain high cooling performance,
 - Minimize water consumption, and
 - Increase maintainability – ease of use, cost, and failure mode.
- Outline the advantages and disadvantages of the technology.
 - Create a detailed application guide for DoD energy managers and engineers.
 - Present a market analysis that compares the economic feasibility of IECs to standard direct expansion (DX) cooling units in different climate zones.
 - Create a new performance model of the IEC that can be used by design engineers and energy analysts to model the units in various building types and locations.

The performance of each unit was evaluated under different operational characteristics and the water consumption characteristics of the units were validated throughout the 2-year demonstration.

1.3 REGULATORY DRIVERS

The DoD ESTCP awarded this new technology demonstration project as a means to identify programmatic changes that could be applied to the design and construction of energy-efficient, evaporative-based AC equipment on new and existing facilities. A new high-performance, multi-staged IEC unit could be implemented throughout the western half of the U.S. to help the agency meet and exceed the requirements set forth in Executive Order (E.O.) 13423, Energy Policy Act of 2005, and the EISA 2007.

E.O. 13423 and E.O. 13514 list requirements for water conservation at federal facilities. E.O. 13514 expands on the requirements set by E.O. 13423, mandating federal agencies to reduce potable water consumption intensity 2% annually through Fiscal Year (FY) 2020. This would result in a 26% reduction by the end of FY 2020, relative to a FY 2007 baseline. E.O. 13514 also mandates a reduction in industrial, landscaping, and agricultural water consumption by 2% annually, or 20% by the end of FY 2020, relative to a FY 2010 baseline.

The key features of EISA 2007 that pertain to this technology are outlined in section 431 and requires a reduction in energy use intensity (EUI) kilo British thermal units(kBtu/square feet[ft²]/yr) of federal buildings of 3%/year, from a 2003 baseline, resulting in a 30% EUI reduction by 2015. The EISA 2007 legislation has superseded all previous EUI reduction mandates.

The new multi-staged IEC unit will substantially reduce energy use and peak demand, which will help meet EISA 2007 requirements, but it also has the potential to increase potable water consumption, which will be detrimental to the E.O. 13514 requirements. Although the technology can increase on-site water use, it was shown to reduce regional water consumption. A detailed description of regional power plant water consumption characteristics is provided in Section 7.0. Each DoD installation is encouraged to try to identify alternative sources of water for the units and recapture excess water for reuse in irrigation systems, if this is permitted by local jurisdictions.

2.0 TECHNOLOGY DESCRIPTION

2.1 EVAPORATIVE COOLING

Direct evaporative coolers (DEC) cool air by directly evaporating water into an airstream. As the water changes phases from a liquid to a vapor through heat of vaporization principles, heat is drawn from the air and the air temperature is reduced. In low-humidity areas, evaporating water into the air provides a natural and energy-efficient means of cooling. DECs, also called swamp coolers, rely on this principle, cooling outdoor air (OA) by passing it over water-saturated pads, causing the water to evaporate into it. Unlike central AC systems that recirculate the same air, residential DECs provide a steady stream of fresh air into the house and require an exhaust air (EA) path through the house.

Conventional evaporative cooling has high potential for significant energy savings in dry climates. Evaporative systems have competitive first costs and significantly reduce operating energy use and peak loads. The primary concern with traditional evaporative cooling units is their ability to maintain comfortable interior conditions. DECs are typically rated with a SA cubic feet per minute (cfm), rather than a cooling capacity. The temperature of the SA that an evaporative cooling unit can provide is typically rated as a wet bulb effectiveness (WBE) with the following equation:

$$\varepsilon = \frac{T_{DB} - T_{supply}}{T_{DB} - T_{WB}}$$

Where:

- T_{DB} = dry bulb temperature of entering air
- T_{supply} = supply air temperature
- T_{WB} = wet bulb temperature of entering air

The efficiency of a DEC is a function of the following:

- *Evaporative pad effectiveness.* The typical residential swamp cooler will use an aspen pad that has a WBE of 65%–78%. The pads are typically made from aspen trees, plastic, or paper. A more efficient option for the evaporative pad is a rigid media cooler, which has more surface area per cubic volume and the medium is rigid, which prevents it from sagging over time and can achieve a WBE as high as 90% (Palmer, 2002). The WBE is also a function of pad thickness, the air velocity through the pad, and the effectiveness of the water distribution through the pad (Figure 2).




Figure 2. DEC media.

(Source: Jesse Dean, National Renewable Energy Laboratory [NREL])

- *Supply fan and motor efficiency.* The efficiencies of the fan, motor, and belt/drive have a significant impact on unit efficiency. Typical DEC systems use a centrifugal fan, belt drive, and single-phase induction motor. The motors are typically one or two speed. Single-phase asynchronous induction motors are not subject to the same efficiency standards as three-phase motors and can have poor efficiencies, with electrical motor efficiencies as low as 50%. The most efficient designs use high-efficiency centrifugal fans, direct drive supply, and electronically commutated motors (ECM). ECMs have significantly higher electrical efficiencies and allow for fully variable-speed operation.

The standard DEC also includes a circulation pump that will draw a small amount of power when it is circulating fluid through the direct evaporative pad.

There are number of commercially available residential and commercial evaporative cooling systems. An overview of commercially available evaporative cooling technologies and their design characteristics is provided in Appendix D of the Final Report.

2.2 TECHNOLOGY OVERVIEW

An internally manifolded IEC designed by Coolerado of Arvada, Colorado, has made dew point temperature—rather than wet bulb—the new low temperature limit for evaporative cooling. Wet bulb is the temperature at which air will cool when water is evaporated in unsaturated air. The U.S. Department of Energy (DOE) laboratory testing has proven this cooler’s ability to supply air at or below ambient wet bulb temperature (100%–120% WBE), surpassing state-of-the-art IECs (about 70% effective) and even swamp coolers (about 90% effective) without adding humidity to the SA. Accomplished by elegant use of multistage IEC, this approach is 2–4 times as energy efficient as conventional AC and significantly enhances occupant comfort and the climate range for non-compressive, non-refrigerant-based ACs. DEC uses about 1.37 gallon per sensible (ton-h) of cooling to the SA (Note: DEC systems are adiabatic coolers, meaning that they do not

significantly change the enthalpy of the cooled airstream). However, DEC's only work with 100% OA. If more OA is supplied than stipulated by ventilation requirements (ASHRAE 62.1-2010 and 62.2-2010), the instantaneous sensible cooling for airflow above minimum ventilation must be de-rated by the factor:

$$\text{Derating ratio} = \frac{\text{return air temperature (RAT)} - \text{SAT}}{\text{outside air temperature (OAT)} - \text{SAT}}$$

The water evaporation rate (in gallons/ton-h) must then be divided by this de-rating ratio.

The Coolerado cooler heat mass exchanger (HMX) has an evaporative water consumption rate of 2.5 gallons/ton-h. These coolers may have the same issue if supplying more OA than ventilation requirements, and thus require the same method of de-rating. However, these ACs can run down to 45% OA ratio if return air (RA) is used, which will limit the amount of de-rated cooling. Thus, water consumption can be compared case-by-case only, using an annual simulation of building loads. At certain times during the season, a Coolerado Cooler can have a de-rating ratio that makes up for the difference in evaporation rate. During these, usually high ambient wet bulb periods, the water evaporation by a Coolerado Cooler may be less than a DEC. In summary, in a climate like Colorado Springs a DEC will use roughly the same amount of water as the Coolerado Cooler, and the Coolerado Cooler will use less energy than a standard residential DEC with a standard, constant speed fan motor.

Scalable for residential or commercial application, the evaporative cores are made of plastic to separate the dry SA flows from the wet, EA flows, and can be mass produced by an automated assembly line. The wet exhaust flows serve as progressively colder heat sinks to produce the colder supply temperatures unique to this all-indirect technology. Fresh air is provided to the building at temperatures and relative humidities (RH) that achieve indoor comfort in climates with design wet bulb temperatures below 70°F, which includes most of the western U.S. Ambient dry bulb temperature is irrelevant, as the wet bulb temperature is the dominant factor in determining the SAT provided by the IEC.

2.2.1 How It Works

The Coolerado Cooler has a unique design that maximizes the effectiveness of the direct and indirect stages of its cooling process. The schematic in Figure 3 illustrates fluid movement through the patented HMX. The HMX is made of plastic in a geometric design that cools both the product and working airstreams in an isolated heat exchange process.




Figure 3. Internal HMX process airstream and EA stream airflow.
(Source: NREL)

Figure 4 provides a side view of the Coolerado Cooler and an illustration of the main components.




Figure 4. Side view of Coolerado airflow process.
(Source: Coolerado)

Fan energy is the only form of electrical energy input into the system. The fan is driven by an ECM that is >90% efficient and is variable down to a near 0% flow rate. The inlet air passes through a filter before it enters the unit. The top portion of the inlet air is supplied to the space as the primary/product air stream. The air that flows through the bottom part of the HMX is the secondary/working air. The system of cascading incremental airflows creates a thermodynamic cycle called the Maisotsenko Cycle (M-Cycle) (see Figure 3). The cycle works by cooling both the primary/product air and the secondary/working air in a 20-stage process. The cumulative result is a lower primary/product air temperature than is possible with conventional evaporative cooling technologies. The key difference between this and other direct/indirect processes is that the secondary/working air that is accumulating moisture is exhausted at each stage, enabling the primary/product air to be delivered at a lower dry bulb temperature.

The advantage of the M-Cycle is that the working air is purged repeatedly so the initial conditions are essentially reset, as lower dry bulb and wet bulb temperatures are established with each purge cycle. This allows the eventual SAT to be below what the original initial conditions would indicate possible—below the thermodynamic wet bulb temperature. This key staged-cooling process is essentially what sets the Coolerado Cooler apart from other IEC and DEC systems and enables greater cooling performance. During this process, no moisture is added to the primary/product air.

2.3 ADVANTAGES AND LIMITATIONS OF THE TECHNOLOGY

The primary advantage of dew point IEC is its ability to supply colder SATs than traditional evaporative cooling units, which extends the range of applicable climate zones and increases thermal comfort. The increased performance over traditional evaporative cooling units comes at a fraction of the energy use and energy cost of mechanical air-conditioning. An IEC may have diverse applications; it can be applied as a single-zone dedicated outside air system, as an OA pre-conditioner or mixed air (OA and RA) conditioner that feeds into an RTU or air handling unit (AHU). Additional benefits include improved ventilation rates versus traditional AC, reduced strain on and investment in power distribution grids, and reduction in harmful refrigerant gases. The energy savings improve energy security and reduce pollution. The Coolerado can provide up to 30% colder SATs than traditional DEC without adding moisture to the SA stream. The Coolerado can also reduce AC energy use by 57%–92% depending on facility type, location, baseline HVAC equipment efficiency, and application.

The target climates for the Coolerado are ASHRAE climate zones 2B, 3B, 4B, 5B, and 6B. The system should be installed as an OA pre-conditioner in climate zones 2B and 3B and can be applied as a zone cooler for climate zones 4B, 5B, and 6B. An ASHRAE climate zone map is provided in Figure 5.




Figure 5. ASHRAE climate zone map.
(Source: Joelynn Schroeder, NREL)

Although the technology can be installed in ASHRAE climate zones 1A–7A, the increased OA humidity levels reduce the cooling capacity of the unit and the overall energy savings to the point that the technology cannot provide a favorable return on investment. Other limitations include increased on-site water consumption, inability to dehumidify, and sensitivity to inlet air conditions. The increased water consumption is of particular note, since the target climate areas are also those that typically must reduce potable water consumption due to the dry climate. When this technology was attempted to use non-potable gray water, the media experienced biological fouling. This could potentially be overcome with enhanced filtering, but the additional costs would most likely cause an unfavorable economic payback.

Coolerado has developed a dew point IEC with mechanical AC to extend energy savings benefits to all climates. The 5-ton H80 unit recently exceeded Western Cooling Efficiency Challenge goals; a description of the technology is provided in Appendix D of the Final Report (Kozubal, 2010).

3.0 PERFORMANCE OBJECTIVES

Table 3 and Table 4 summarize the quantitative and qualitative performance objectives outlined for the evaluation of the Coolerado Cooler. The quantitative objectives include interior thermal comfort, energy efficiency, service life, and water use metrics; qualitative performance objectives include ease of use, cost, and failure, which address the maintainability of the system. Each performance objective is described in detail below. The results presented in Section 6 highlight how the Coolerado units in this demonstration project met or did not meet these performance objectives.

Table 3. Quantitative performance objectives.

Performance Objective	Metric	Data Requirements	Success Criteria
Improve comfort provided by evaporative cooling (<i>Performance</i>)	<ul style="list-style-type: none"> Hours outside psychrometric comfort zone SAT 	<ul style="list-style-type: none"> Interior space temperature Indoor humidity SAT 	<ul style="list-style-type: none"> <1% outside ASHRAE summer comfort zone SA <70°F OK to apply where design wet bulb $\leq 70^\circ\text{F}$
Provide high efficiency cooling (<i>Energy Efficiency</i>)	<ul style="list-style-type: none"> kW/ton of building cooling 	<ul style="list-style-type: none"> SAT Building EA temperature (EAT) Coolerado power consumption SA flow rate 	<ul style="list-style-type: none"> Peak power <1 kW/ton Average power <0.6 kW/ton
Sustain high cooling performance (<i>Service Life</i>)	<ul style="list-style-type: none"> WBE SA pressure drop 	<ul style="list-style-type: none"> SAT Outdoor air temperature Core pressure drop Outdoor air humidity 	<ul style="list-style-type: none"> <5% degradation of WBE over 3 years Negligible increase in SA pressure drop
Minimize water consumption (<i>Water Conservation</i>)	<ul style="list-style-type: none"> Gal/ton·h of building cooling Site water quality TDS 	<ul style="list-style-type: none"> Water inlet flow Water outlet flow Water conductivity 	<ul style="list-style-type: none"> Demonstrate conservation approach consuming <2.5 gal/ton-h

TDS = total dissolved solids

Table 4. Qualitative performance objectives.

Performance Objective	Metric	Data Requirements	Success Criteria
Maintainability (<i>Ease of Use</i>)	Ability of an HVAC technician to operate and maintain the technology	Standard form feedback from the HVAC technician on time required to maintain	A single facility technician able to effectively operate and maintain equipment with minimal training
Maintainability (<i>Cost</i>)	Service Frequency	Standard form feedback from the HVAC technician on time required to maintain	>90% of units fall within nominal IEC maintenance schedule by project end
Maintainability (<i>Failure</i>)	Biological Fouling Freezing	Visual inspection	<ul style="list-style-type: none"> No signs of biological growth, including gray-water unit No ruptured water lines

This page left blank intentionally.

4.0 FACILITY/SITE DESCRIPTION

Fort Carson Army Base is located in Colorado Springs, Colorado. The base sits atop a high plane at 5835 feet against the foothills of the Rocky Mountains. The base covers more than 8.7 square miles (mi²) and includes more than 11 million ft² of building area. Facilities include offices, headquarter buildings, commissaries (on-base grocery stores), a hospital; barracks, and retail spaces. Other spaces that do not fall into these categories include—but are not limited to—a training facility, auditorium, and event center. Table 5 summarizes the percentage of total facility square footage based on building type.

Table 5. Building types at Fort Carson.

Building Type	Percent of Total
Other	41
Barracks	29
Headquarters	17
Offices	5.7
Hospital	4.6
Retail space	1.8
Commissaries	0.9

The OATs are typically 80°–90°F during the cooling season and are rarely above 100°F. The OA wet bulb temperatures are low during the cooling season (50°–60°F), making Colorado Springs ideal for evaporative cooling technologies. One disadvantage is that the cooling season is relatively short, typically June–August, with fewer than 500 cooling degree days (base 65°F). Table 6 summarizes the Typical Meteorological Year (TMY) 3 weather data for Colorado Springs and the maximum measured OA conditions at Fort Carson during July 2010.

Table 6. TMY3 and measured climate data.

Climate Data	TMY3 Data for Colorado Springs
Cooling design day (0.4%) dry bulb	90.3°F
Cooling design day (0.4%) mean coincident wet bulb	58.8°F
Evaporative design day (0.4%) wet bulb	63.3°F
Evaporative design day (0.4%) MCDB	78.3°F
Measured maximum dry bulb (July 2010)	97.8°F
Measured maximum mean coincident wet bulb (July 2010)	62.9°F
Maximum wet bulb (July 2010)	70.8°F
Number (percent) of hours above 0.4% design conditions	113 hours (1.3%)

MCDB = mean coincident dry bulb

The measured wet bulb temperature is significantly higher than the ASHRAE 0.4% design condition (70.8°F versus 63.3°F) and there were 113 hours above the 0.4% design condition. A similar trend was also monitored for the 2011 cooling season. The increased outdoor wet bulb temperatures made it more difficult for the Coolerado Cooler to meet the SAT and thermal comfort performance metrics.

4.1 FACILITY/SITE LOCATION AND OPERATIONS

Twenty-four Coolerado C60 units were installed across five facilities at Fort Carson, including a training center (classrooms), auditorium, events center, a digester facility, and a jet aeration facility. One additional Coolerado unit was installed as a standalone unit at the wastewater treatment facility to test its performance with wastewater. These facilities were selected based on their different end uses, occupant densities, cooling loads, schedules, and physical constraints. All the systems were set up as zone coolers with 100% OA. Most were installed as ground or stand mounted; a few were roof mounted.

4.2 FACILITY/SITE CONDITIONS

Many of the facilities selected for the demonstration used old HVAC systems that did not provide adequate cooling; therefore, installing the Coolerado units had the potential to save energy and improve occupant comfort. Additionally, all the selected facilities are of older vintages and had significant air leakage, so it was not necessary to install pressure relief dampers in conjunction with the Coolerado units, which saved installation costs.

5.0 TEST DESIGN

5.1 CONCEPTUAL TEST DESIGN

The conceptual test design consisted of a combination of controlled laboratory testing and field testing. NREL tested two units in the Thermal Test Facility (TTF) before the installation and installed instrumentation and data acquisition equipment on 20 of the 24 Coolerado C60 units. The two units tested at the laboratory were used to pre-calibrate the field monitoring systems to improve the accuracy of field data. These two units were installed at the training center.

5.2 BASELINE CHARACTERIZATION

Because mechanical AC is a well-understood technology, baseline measurements were not required for individual sites to project energy savings relative to conventional equipment at various efficiency levels. Once cooling loads were established for each demonstration site, comparisons of Coolerado energy use versus energy needs of mechanical AC were straightforward. The efficiencies of competing cooling technologies, including DX RTUs and chillers, were analyzed using manufacturer's data and performance algorithms used in building energy modeling tools such as eQUEST and EnergyPlus.

5.3 DESIGN AND LAYOUT OF TECHNOLOGY COMPONENTS

Figure 5 shows the experimental layout for the training facility and represents all the demonstration buildings except the wastewater demonstration, which discharged to the outdoors because of the experimental nature of gray water use in the Coolerado unit. The figure describes a 100% OA displacement cooling application, where no cooling air is recirculated and cooling and dehumidification loads are carried from the building by exfiltrating EA. All units employ MERV 15 filters, have minimal duct static pressure (SP) losses, and conserve water by modulating makeup water in response to a wet bulb depression sensor that predicts evaporation rates at current ambient conditions. For through-the-wall units, SA is ducted in at low elevations to ensure the occupied zone is maintained at the coolest temperature possible, while air that has already picked up internal loads is still cool enough to buffer the space by carrying away solar loads in unoccupied volumes, such as ceiling plenums. For rooftop installations, where ceiling discharge is required, special diffusers force air downward and encourage cooling air throw to the floor to achieve the same displacement effect. Barometric exhaust dampers close when the Coolerado units are not pressurizing the space to ensure maximum displacement cooling without compromising envelope integrity during non-cooling hours.

Each unit modulated its SA flow with an ECM in response to a thermostat control signal. The wastewater unit was an exception; it operated continuously at full flow to accelerate any negative impacts of operating on gray water and discharged its process air to the outdoors to avoid concerns about potential biological growth.

5.4 OPERATIONAL TESTING

Testing was conducted in startup and monitoring phases. During startup, Coolerado and NREL engineers installed sensors and confirmed that HVAC and data systems operated properly.

Startup commenced as the equipment installation proceeded in July 2009 and concluded in September 2009. Systems performance was monitored during the 2010 and 2011 cooling seasons (July, August, and September). NREL removed the monitoring equipment after the demonstration ended in September 2011. The on-site operations and maintenance (O&M) contractor took responsibility for operating the units from the beginning of the demonstration, and the units will be used for space conditioning into the foreseeable future.

5.5 SAMPLING PROTOCOL

A data acquisition system (DAS) was installed on 20 of the 24 Coolerado units installed at Fort Carson. The DAS was designed to capture information on the energy and water performance of the Coolerado unit, as well as space temperature and exhaust air temperature (EAT). Multiple DASs were installed at Fort Carson, and the data from all the sensors were stored and partially processed on Campbell Scientific Data Loggers. The data loggers were equipped with cellular modems that allowed for remote monitoring and analysis of metered data. All sensors were sampled every 10 seconds and any mathematical manipulations of those primary measurements were made on the same 10-second interval. Data are stored as averages or totals in four separate data tables identical in field description but varying in storage interval: 1-minute, 15-minute, 60-minute, and 24-hours (midnight-to-midnight). Figure 6 shows the DAS points for the typical Coolerado unit. A list of sensors and associated accuracy specifications is contained in Appendix B of the Final Report.




Figure 6. Coolerado DAS.
(Source: Joshua Bauer, NREL)

6.0 PERFORMANCE ASSESSMENT

Performance data were collected during the 2010 and 2011 cooling seasons, which included July, August, and September. The results presented in this section highlight the performance objective results of the best- and worst-performing units from those seasons (see Table 7).

Table 7. Quantitative performance objectives.

Performance Objective	Metric	Data Requirements	Success Criteria	Results
Improve comfort provided by evaporative cooling (<i>Performance</i>)	<ul style="list-style-type: none"> Hours outside psychrometric comfort zone SAT 	<ul style="list-style-type: none"> Interior space temperature Indoor humidity SAT 	<ul style="list-style-type: none"> <1% outside ASHRAE summer comfort zone SA <70°F OK to apply where design wet bulb ≤<70°F 	<i>Comfort Zone = Pass</i> <i>SA <70°F = Pass for 80% of unit monitored</i> <i>Wet Bulb = Pass</i>
Provide high-efficiency cooling (<i>Energy Efficiency</i>)	<ul style="list-style-type: none"> kW/ton of building cooling 	<ul style="list-style-type: none"> SAT Building EAT Coolerado power consumption SA flow rate 	<ul style="list-style-type: none"> Peak power <1 kW/ton Average power <0.6 kW/ton 	<i>Peak Power = Pass</i> <i>Average Power = Pass</i>
Sustain high cooling performance (<i>Service Life</i>)	<ul style="list-style-type: none"> WBE SA pressure drop 	<ul style="list-style-type: none"> SAT Outdoor air temperature Core pressure drop Outdoor air humidity 	<ul style="list-style-type: none"> <5% degradation of WBE over 3 years Negligible increase in SA pressure drop 	<i>WBE = Pass</i> <i>Negligible Increase pressure drop = Pass</i>
Minimize water consumption (<i>Water Conservation</i>)	<ul style="list-style-type: none"> Gallons/ton-hr of building cooling Site water quality (TDS) 	<ul style="list-style-type: none"> Water inlet flow Water outlet flow Water conductivity 	<ul style="list-style-type: none"> Demonstrate conservation approach consuming <2.5 gal/ton-h 	<i>Water use = Fail</i>

Table 8. Qualitative performance objectives.

Performance Objective	Metric	Data Requirements	Success Criteria	Results
Maintainability (<i>Ease of use</i>)	Ability of an HVAC technician to operate and maintain the technology	Standard form feedback from the HVAC technician on time required to maintain	A single facility technician able to effectively operate and maintain equipment with minimal training	<i>Pass</i>
Maintainability (<i>Cost</i>)	Service Frequency	Standard form feedback from the HVAC technician on time required to maintain	>90% of units fall within nominal IEC maintenance schedule by project end	<i>Pass</i>
Maintainability (<i>Failure</i>)	Biological Fouling Freezing	Visual inspection	<ul style="list-style-type: none"> No signs of biological growth, including gray water unit No ruptured water lines 	<i>Fail</i>

All units were able to maintain room air conditions (temperature and relative humidity) within the ASHRAE thermal comfort zone >99% of the time for both the 2010 and 2011 cooling

season. A total of 9 units in 2010 and 13 units in 2011 were able to supply air at less than 70°F for more than 95% of operating hours.

The majority of the units had daily electrical efficiencies less than 0.6 kW/ton for more than 96% of the days in operation over the 2 year period. The electrical efficiency was significantly better for the classroom facility than the other facilities because the classroom units were properly sized to meet 100% of the cooling load within the space and had the ability to operate at partial fan speeds for the majority of the year. These units operated between 0.2 and 0.3 kW/ton in 2010 and around 0.2 kW/ton during 2011. An average kW/ton of 0.2 is equivalent to an energy efficiency ratio (EER) of 60, and would result in energy savings of 80% relative to a minimally code compliant packaged rooftop unit with an EER of 12.

Excessive water use was a result of improper cycles of concentration (CoC) settings on the Coolerado control board. For the 2010 cooling season and the majority of the 2011 cooling season, the CoC was set to 1.5-1.6 by the manufactures, which was explained to be standard practice at the time. With this water use setting, the units would send two parts water down the drain for every one part of water that was evaporated. This resulted in water consumption between 6 and 10 gallons/ton-hr. The settings were modified to a CoC of 5 at the end of the 2011 cooling season after determining that this was the recommended setting for the Coolerado. As a result, the units were able achieve a water use amounts of about 3 gallon/ton-hr, which is only slightly higher than the requirement in the performance metric.

Table 9 summarizes the percent of operating hours or days each monitored unit met the performance objectives.

Table 9. 2010 and 2011 quantitative performance results.

Building	Unit	Percent of Hours within ASHRAE Comfort Zone		Percent of Hours Average Supply Air Temp < 70°F		Percent of Days Average Efficiency < 0.6 kW/ton		Percent of Days Average Water Use < 2.5 Gal/ton-hr	
		2010	2011	2010	2011	2010	2011	2010	2011
Training facility	1	100	100	59.2	96.5	100	100	0.0	0.0
	2	100	100	76.6	99.5	100	98.7	2.3	0.0
	3	100	100	99.4	100	100	100	0.0	0.0
	4	100	100	96.3	97.5	100	100	0.0	0.0
Event center	1	100	100	100	100	100	100	5.6	8.6
	3	100	100	99.7	99.8	100	100	0.0	21.4
	5	100	100	95.1	99.7	96.7	98.8	0.0	8.2
	7	100	100	98.2	99.8	98.9	96.5	1.1	4.7
Theater	9	100	100	99.3	97.0	96.0	85.5	18.5	0.0
	10	100	100	94.9	100	96.0	93.3	91.5	No data
	11	100	100	62.7	99.9	90.9	96.7	3.3	0.0
	12	100	100	99.3	98.0	100.0	96.9	1.1	0.0
Digester	1	100	100	57.9	77.4	2.3	93.5	0.0	0.0
Jet-aeration	West	100	100	68.8	77.0	0.0	97.8	0.0	0.0
	East	100	100	No data	84.3	95.3	97.8	2.4	11.0
Wastewater unit	1	100	100	41.7	70.2	100	75.8	100	No data

6.1 QUALITATIVE PERFORMANCE OBJECTIVES

Qualitative performance objectives included ease of use, cost, and failure. The demonstration met the ease-of-use metric by requiring only a single facility technician to effectively operate and maintain the equipment with minimal training. The standard maintenance time per unit ranged from 7.25 hours/year/unit to 1.7 hours/unit/year depending on the installation and on the extent of the maintenance required. Given the average maintenance time of 3.8 to 5.5 hours per unit per year, more than 90% of units fell within nominal IEC maintenance schedule and therefore met the cost objective. Units operating on potable water showed no signs of failure in regards to biological growth or ruptured water lines. Units at the Training Facility, however, did experience ruptured water lines but were a result of unforeseen issues with installation rather than Coolerado technology malfunctions. The unit operating at the water treatment facility operating on gray-water experienced algae growth in the media, leading to a failure for this performance objective.

This page left blank intentionally.

7.0 COST MODEL

Twenty-four Coolerado C60 units were installed across five facilities at Fort Carson including a training center (classrooms), auditorium, events center, a digester facility, and a jet aeration facility. All the systems were set up as zone coolers with 100% OA. Most were ground or stand mounted; a few were roof mounted. The event center, digester facility, and jet aeration facility did not have AC before the demonstration. The training center was using small spot coolers that could not meet the cooling load and the theater had an antiquated HVAC system that had insufficient cooling capacity.

Because the facilities had insufficient AC capacity before the Coolerado units were installed, the economics of the Coolerado installation were compared to the economics of installing an appropriately sized packaged rooftop unit (RTU) and the associated ductwork and controls. The total installed costs, seasonal energy efficiency, energy use, and projected water consumption of the Coolerado units were used to compare the economics and performance to a code-minimum packaged RTU with an integrated energy efficiency ratio (IEER) of 12.

The seasonal efficiency of each Coolerado unit was calculated as a function of the total building cooling provided over the 2011 cooling season and total electrical energy use. The cooling capacity was calculated as a function of space temperature (building cooling) and OAT (total cooling). Figure 7 shows the annual average operational cooling efficiency for each unit.




Figure 7. Coolerado seasonal efficiency comparison.

The total energy use for each unit was multiplied by the ratio of the seasonal building efficiency of the Coolerado unit and the IEER of the proposed packaged unit (in kW/ton). The seasonal efficiency was calculated as a function of building cooling for all facilities except the jet aeration and digester units, where the total cooling efficiency was increased by 20% to properly model the seasonal building cooling efficiency.

The annual energy use for the 2011 cooling season was taken directly from measured energy use data and the water consumption was calculated based on the total cooling provided over the 2011 cooling season, assuming a water consumption rate of 3 gallons/ton-h. Because the water settings were modified during the 2010 and 2011 cooling seasons, the water consumption rate during the first part of the summer was higher than at the end of the 2011 cooling season. The water consumption rate for the later part of the summer when the CoC setting was set to five was approximately 3 gal/ton-h and is indicative of future operation. The electricity rate at Fort Carson is \$0.07/kilowatt hour (kWh) and the water rate is \$3.80/1000 gallons.

The O&M costs of the Coolerado unit were based on maintenance logs from the Fort Carson demonstration. The maintenance time per unit was 7.25–2.65 hours/unit/year, depending on the installation and required maintenance. For this analysis, the annual O&M time is assumed to be 2.65 hours. Using a standard maintenance labor rate from RS Means (\$54.375/hour), the labor cost was assumed to be \$144/unit and the material cost was assumed to be \$15/unit for a total O&M cost of \$160/unit/year and the total cost premium per Coolerado unit was assumed to be \$34/yr (RS Means Engineering Department, 2013).

Given the measured performance of the Coolerado units, the annual energy savings are estimated at 63.3% compared to a code-minimum RTU. The energy savings would be greater if compared to an older packaged RTU with an EER of 8–9.

Table 10 shows the installed costs for the five facilities and the wastewater unit.

Table 10. Coolerado installed costs.

Location	Number of Units	Total Cost (\$)	Cost per Unit (\$)
Training center	4	\$67,416	\$16,854
Event center	8	\$131,770	\$16,471
Theater	8	\$126,099	\$15,762
Jet aeration	2	\$25,625	\$12,813
Wastewater facility	1	\$13,141	\$13,141
Wastewater unit (\$)	1	\$8170	\$8170

The installed costs for the packaged RTUs was assumed to be \$4000–\$5200 per cooling ton and includes installed costs for the RTU and associated ductwork. The range was based on the amount of internal ductwork needed. The RTU capacity was calculated assuming each Coolerado unit was rated at 3 tons of cooling, and one to two RTUs were assumed to be installed at each facility.

Table 11 shows the annual cost savings, incremental installed costs, and SPP.

Table 11. Fort Carson Coolerado economics.

Facility Name	Annual Cost Savings (\$)	Incremental Installed Cost (\$)	Simple Payback (years)	NPV (\$)
Training facility	-\$16	\$5016	-312.6	-\$5416
Theater	-\$38	\$1299	-33.8	-\$2249
Event center	\$65	\$6970	107.9	-\$5344
Jet aeration	\$111	\$1625	14.60	\$1151

The Jet Aeration facility had the best payback period, primarily because the units ran 24/7 throughout the cooling season because of the high internal loads. The increased runtime increased annual kW-h energy savings. The event center also had positive annual cost savings. The other facilities would have shown positive cost savings if the savings had been compared to an older RTU with an EER of 8–9.

Although the units significantly reduced energy use, the increased O&M and water consumption costs raised annual operating costs for facilities with reduced cooling loads and runtimes. Figure 8 shows the annual operating costs for the four units at the training facility compared to the annual energy costs of the RTU. The O&M costs represent a higher percentage of the total annual costs than the energy costs.




Figure 8. Training facility annual operating cost comparison.

The economics are very sensitive to O&M costs; any increase or decrease in O&M costs has a significant impact on the economics of the installation (see Table 12). Given the O&M costs are subjective and the O&M costs for packaged RTUs can exceed the costs assumed here, the economics of the installation are provided without incremental increase in O&M.

Table 12. Fort Carson Coolerado economics.

Facility Name	Annual Cost Savings (\$)	Incremental Installed Cost (\$)	Simple Payback (yrs)	Net Present Value (\$)
Training facility	\$120	\$5016	41.8	-\$2015
Theater	\$98	\$1299	13.3	\$1152
Event center	\$201	\$6970	34.7	-\$1943
Jet aeration	\$213	\$1625	7.62	\$3703

The estimated SPP was 7.62–41.8 year, depending on the facility where the unit was installed.

7.1 COST ANALYSIS AND COMPARISON

The building types that were evaluated included a small classroom (400 ft²), a data center (19,994 ft²), and a quick-serve restaurant (2500 ft²). Coolerado performance was compared to common cooling technologies with respect to energy and water savings and a number of cost parameters. Energy savings, SPP, and net present value (NVP) results are presented.

The baseline HVAC systems included a packaged single zone (PSZ) unit with DX coils (EER = 9) for the small classroom, a constant volume AHU with an air-cooled screw chiller (EER = 8.76) for the data center, and two constant volume RTUs for the quick-serve restaurant (one serving the kitchen, one serving the dining area). For the small classroom, a C60 Coolerado was modeled as a standalone zone cooler if the unit was able to meet 98% of the cooling load; otherwise, the M30 was modeled as an outside air pre-conditioner for the packaged unit. Thirty M30 Coolerados were modeled as zone coolers in the data center model. One C60 Coolerado was modeled as a pre-cooler retrofit on the RTU serving the kitchen in the quick-serve restaurant.

The utility rates applied to each model are listed in Table 13; water rates based on data from Fort Carson. Note that O&M and capital costs used in the models were adjusted for each location based on the following *RS Means* city cost adjustment factors: Phoenix, 93.7%; Las Vegas, 104.2%; Los Angeles, 105.3%; Albuquerque 87.4%; Colorado Springs, 90.0%; and Helena, 88.2%.

Table 13. Utility rates for selected locations.

Location	Electricity Rate (\$/kWh)	Natural Gas Rate (\$/MMBtu)	Water Rate* (\$/1000 gal)
Phoenix, AZ	0.116	7.81	3.75
Las Vegas, NV	0.139	8.13	3.75
Los Angeles, CA	0.101	7.29	3.75
Albuquerque, NM	0.075	6.52	3.75
Colorado Springs, CO	0.075	6.53	3.75
Helena, MT	0.076	7.48	3.75

MMBtu = million British thermal units

7.1.1 Results

The results for the energy simulations are provided in Table 14; energy savings, SPP, and NPV of the Coolerados are compared to the baseline technologies. (The quick-serve restaurant was modeled in two locations only.) Note that, the capital, consumables, and O&M costs used in the baseline models were taken from the *RS Means Facilities Maintenance and Repair 2001 Data Book*. Results show annual Coolerado energy savings ranging from 57% to 92% across all locations and building types. The economics were calculated using the federal life cycle costing procedures outlined in the Federal Energy Management Program (FEMP) Building Life Cycle Costing (BLCC). The real discount rate for 2012 is 2%, with an inflation rate of 3.6% and a nominal discount rate of 5.6%. The real electricity escalation rate was set to -0.54%, which the nominal rate slightly less than the inflation rate, and the project lifetime is specified as 40 years.

Table 14. Energy savings and cost analysis results.

Location	Metric	Small Classroom	Data Center	Quick-Serve Restaurant
Phoenix, AZ	Percent Energy Use Reduction	65%	77%	70%
	SPP (years)	11	14.3	9.9
	NPV	\$6552	\$1,241,631	\$1999
Las Vegas, NV	Percent Energy Use Reduction	68%	76%	
	SPP (years)	12.7	13.1	
	NPV	\$5599	\$1,666,419	
Los Angeles, CA	Percent Energy Use Reduction	63%	81%	
	SPP (years)	52.1	16.5	
	NPV	-\$3016	\$969,384	
Albuquerque, NM	Percent Energy Use Reduction	66%	86%	
	SPP (years)	173.5	17.7	
	NPV	-\$12,345	\$638,040	
Colorado Springs, CO	Percent Energy Use Reduction	64%	88%	57%
	SPP (years)	275.2	13	61.8
	NPV	-\$8827	\$1,091,370	-\$6835
Helena, MT	Percent Energy Use Reduction	65%	92%	
	SPP (years)	345.4	14.4	
	NPV	-\$9002	\$1,060,271	

Coolerado applications have the best economics in data center facility due to their year-round cooling requirements. SPP periods and NPVs vary across location due to variable capital costs, on-site water and electricity costs, O&M costs, and, in the case of the small classroom, application methodology. The quick service restaurant had favorable economics in Phoenix and unfavorable economics in Colorado Springs, and the SPP was better in both climate zones than the single zone classroom. The single zone classroom unit showed favorable economics in Phoenix and Las Vegas.

The economic analysis indicates that the Coolerado technology has the best economics as a retrofit technology when it is competing against smaller air cooled AC systems with EERs ranging from 8 to 12. DoD should target facility types with high internal loads and/or high ventilation rates that require year around cooling.

8.0 IMPLEMENTATION ISSUES

8.1 LESSONS LEARNED

Demonstration projects are an effective way to uncover hidden issues that can arise during operation. The following is a list of lessons learned during the demonstration at Fort Carson, which provide design considerations for future installations.

- *Water runoff.* Wastewater from the units installed at the theater was collected through polyvinyl chloride piping and flowed across a cement sidewalk to the adjoining grass. The water eventually created a safety hazard. Wastewater that will not be used for irrigation needs to be routed to a sewer drain or diverted to avoid puddles and prevent safety hazards. Another solution that should be explored is underground water storage tanks. Two 800-gallon storage tanks were installed to collect wastewater for four Coolerado units at the theater before the 2011 cooling season. The tanks were tied into the local irrigation system and sump pumps supplied the water to the irrigation system (see Figure 9 and Figure 10).



Figure 9. Coolerado drain water piping.

(Source: Jesse Dean, NREL)



Figure 10. Coolerado units and manhole over water storage tank.
(Source: Jesse Dean, NREL)

- *CoCs.* The CoC setting (ratio of parts water evaporated to parts wastewater) has a significant impact on water consumption. For the 2010 and most of the 2011 cooling seasons, the CoC was set at 1.5–1.6 by Coolerado. This was standard practice at the time. Water consumption was 6–10 gal/ton-h. However, the recommended set point for the Coolerado is 5 CoC, with four parts evaporated for every one part drained. A CoC of 5 should be considered the upper limit for CoC in order to ensure cooling performance per design intent. At the end of the 2011 cooling season the settings were modified with the CoC setting of 5. As a result, the units were able achieve a water use rate of about 2.8 gal/ton-h, which is slightly higher than the requirement in the performance metric.
- *Sizing.* The Coolerado must be sized properly to achieve the highest possible efficiency. To meet indoor comfort conditions with undersized units, the temperature set points must be at a low setting, which could lead to higher energy consumption and lower efficiencies than if the units were slightly bigger. Properly sized units will spend more time operating at partial fan speeds and at higher WBEs.
- *Sealing and winterization.* All units should be sealed with caulk when installed and winterized during the off season to minimize infiltration in climate zones that experience freezing. Observations showed air gaps around the ductwork on the through-the-wall units. Also, diligent winterization of units will prevent drafts, reduce heating energy consumption, and maintain indoor comfort.

- *Gray-water use.* Based on the on-site testing from the wastewater treatment plant, the Coolerado should not utilize gray-water without significant filtering taking place.
- *O&M Costs versus. Energy Costs.* This demonstration showed that although energy use was reduced for all buildings, those uses that had reduced cooling loads and runtimes showed an increase in O&M and water costs. In addition, the O&M costs of the Coolerado make up a higher percentage of the total annual costs compared to a typical RTU.

8.2 DECISION MAKING FACTORS

The following factors should be considered when evaluating the applicability of Coolerado Coolers in a particular area.

8.2.1 Climate

The target climate zones for the Coolerado technology are ASHRAE climate zones 2B, 3B, 4B, 5B, and 6B. The system should be installed as an OA pre-conditioner in climate zones 2B and 3B and can be applied as a zone cooler for climate zones 4B, 5B, and 6B.


Figure 11 shows a list of applicable military bases.

8.2.2 HVAC Equipment Replacement

When the HVAC equipment is at the end of its useful life and needs to be replaced, the economics of the Coolerado improve over the retrofit costs presented in the market analysis. For example, if the computer room air-conditioner (CRAC) units in a data center need to be replaced it would be more cost effective to use that funding to supplement the installation of Coolerado units.

8.2.3 Facilities with No Cooling and New Construction

The economics of the units will also improve when there is no AC system and when applied to new construction. In this case the installed costs were associated with the incremental costs above those of traditional AC equipment and the associated ductwork.



DYESS AFB	Ablene, TX	Air Force
GOODFELLOW AFB	San Angelo, TX	Air Force
LAUGHLIN AFB	Del Rio, TX	Air Force
HOLLAMAN AFB	HOLLAMAN AFB, NM	Air Force
WHITE SANDS MISSILE RANGE	WHITE SANDS, NM	Army
FORT BLISS	FORT BLISS, TX	Army
CANNON AFB	CANNON AFB, NM	Air Force
KIRTLAND AFB	KIRTLAND, NM	Air Force
EDWARDS AFB	California city, CA	Air Force
CHINA LAKE NAVAL AIR WEAPONS STATION	Ridgecrest, CA	Navy
DAVIS-MONTHAN AFB	Tucson, AZ	Air Force
FORT HUACHUCA	Huachuca City, AZ	Army
YUMA PROVING GROUND	Yuma, AZ	Army
YUMA MCAS	Yuma, AZ	Marine Corps
EL CENTRO NAVAL AIR FACILITY	EL CENTRO, CA	Navy
FORT IRWIN	Barstow, CA	Army
LEMOORE NAS	LEMOORE, CA	Navy
BARSTOW MC LOGISTICS BASE	BARSTOW, CA	Marine Corps
TWENTYNINE PALMS MC AIR-GROUND COMBAT CENTER	TWENTYNINE PALMS, CA	Marine Corps
NELLIS AFB	NELLIS AFB, NV	Air Force
Creech Air Force Base	Indian Springs, NV	Air Force
LOS ANGELES AFB	LOS ANGELES, CA	Air Force
FORT MacARTHUR	Los Angeles, CA	Army
LUKE AFB	Luke AFB, AZ	Air Force
CORONADO NAVAL AMPHIBIOUS BASE	CORONADO, CA	Navy

NORTH ISLAND NAS	San Diego, CA	Navy
FLEET ANTISUBMARINE WARFARE TRAINING CENTER	San Diego, CA	Navy
SAN DIEGO NAVAL MEDICAL CENTER	SAN DIEGO, CA	Navy
SAN DIEGO NS	SAN DIEGO, CA	Navy
SAN DIEGO NAVAL SUBMARINE BASE	SAN DIEGO, CA	Navy
AIR STATION MIRAMAR	San Diego, CA	Marine Corps
CAMP PENDLETON	Oceanside, CA	Marine Corps
SAN DIEGO MC RECRUIT DEPOT	SAN DIEGO, CA	Marine Corps
BEALE AFB	Yuba City, CA	Air Force
McCLELLAN AFB	North Highlands, CA	Air Force
TRAVIS AFB	Fairfield, CA	Air Force
BUCKLEY ANGB	Aurora, CO	Air Force
CHEYENNE MOUNTAIN AIR STATION	Colorado Springs, CO	Air Force
PETERSON AFB	Colorado Springs, CO	Air Force
SCHRIEVER AFB	Colorado Springs, CO	Air Force
U.S. AIR FORCE ACADEMY	Colorado Springs, CO	Air Force
FORT CARSON	Colorado Springs, CO	Army
MOUNTAIN HOME AFB	MOUNTAIN HOME, ID	Air Force
MALMSTROM AFB	Great Falls, MT	Air Force
HILL AFB	HILL, UT	Air Force
DUGWAY PROVING GROUNDS	DUGWAY PROVING GROUNDS, UT	Army
FAIRCHILD AFB	FAIRCHILD, WA	Air Force
WHIDBEY ISLAND NAS	WHIDBEY ISLAND, WA	Navy
E.E. WARREN AFB	E.E. WARREN, WY	Air Force
FALLON NAS	FALLON, NV	Navy

ASHRAE Climate Zone	City
1A	Miami, FL
2A	Houston, TX
2B	Phoenix, AZ
3A	Atlanta, GA
3B-CA	Los Angeles, CA
3B-other	Las Vegas, NV
3C	San Francisco, CA
4A	Baltimore, MD
4B	Albuquerque, NM
4C	Seattle, WA
5A	Chicago, IL
5B	Boulder, CO
6A	Minneapolis, MN
6B	Helena, MT
7	Duluth, MN
8	Fairbanks, AK

Figure 11. Military bases by ASHRAE climate zone.
(Source: Joelynn Schroeder, NREL)

8.2.4 Facility Types

This technology has the best economics when applied to facilities with high internal cooling loads that require year-round cooling and when competing against air-cooled direct refrigeration-based AC systems. The top facility types are discussed here:

- *Data centers.* Data centers have the highest internal loads of any facility type. These facilities typically have no economizer cooling and can accept higher SATs.
- *Quick service.* Quick-service restaurants have very high internal loads and ventilation rates, and are typically conditioned with packaged RTUs. This facility type is also ideal for Coolerado units.
- *Supermarket, dining/restaurant, small medical, laboratory, computer room classroom.* All these building types have strict environmental regulations, high internal loads, or high ventilation rates and are good candidates for the Coolerado unit as an OA pre-conditioner in climate zones 2B and 3B.
- *Office, warehouse, barracks, other.* All the building types with lower internal loads and ventilation rates are potential candidates for the unit, but the reduced hours of operation will increase the SPP period.

This page left blank intentionally.

9.0 REFERENCES

American Society of Heating, Refrigerating, and Air Conditioning Engineers (ASHRAE). "ASHRAE Standard 62.1-2010." <http://www.techstreet.com/ashrae/standards/ashrae/62-1-2010?product-id=1720986> (2010).

Brown, Richard E., J.G.K., "Electricity Use I California: Past Trends and Present Usage Patterns." *Energy Policy* (2002): 31(9). p. 15

Department of Energy (DOE). "2011 Buildings Energy Data Book." <https://buildingsdatabook.eren.doe.gov>.

DOE. "Building Life Cycle Cost Programs." <http://www1.eere.energy.gov/femp/information/download-blcc.html>.

Kozubal, Eric and Steven Slayzak. "Coolerado 5 Ton RTU Performance: Western Cooling Challenge Results," National Renewable Energy Laboratory (November 2010).

Palmer, J.D. "Evaporative Cooling Design Guidelines Manual," New Mexico Energy, Minerals, and Natural Resources Department, Energy Conservation and Management Division. http://www.emnrd.state.nm.us/ecmd/multimedia/documents/Evap_Cooling_Design_Manual.pdf, December 2002.

Purdum, Todd, "Heat Wave Nearly Causes Rolling Blackouts in California," *New York Times*, August 2, 2000, <http://www.nytimes.com/2000/08/02/US/heat-wave-nearly-causes-rolling-blackouts-in-california.html>.

RSMeans Engineering Department. *RS Means Facilities Maintenance and Repair Cost Data Book*. 20th ed. RS Means, 2013

This page left blank intentionally.

APPENDIX A
POINTS OF CONTACT

Point of Contact	Organization	Phone Fax E-Mail	Role in Project
Jesse Dean	National Renewable Energy Laboratory	Phone: (303) 384-7539 E-Mail: Jesse.dean@nrel.gov	Co-Principal Investigator
Eric Kozubal	National Renewable Energy Laboratory	Phone: (303) 384-6155 E-Mail: Eric.Kozubal@nrel.gov	Co-Principal Investigator
Lesley Herman	National Renewable Energy Laboratory	Phone: (303) 275-4318 E-Mail: Lesley.Herman@nrel.gov	Investigator
Scott Clark	Fort Carson Department of Public Works	Phone: (719) 526-1739 E-Mail: scott.b.clark@us.army.mil	Site Sponsor, Fort Carson Project Manager
Tim Heaton	Coolerado	Phone: (720) 974-9612 E-Mail: timheaton@coolerado.com	Industry Partner, Coolerado Vice President
Mark Eastment	Eastment Consulting	Phone: (303) 956-3927 E-Mail: meastment@gmail.com	Data Acquisition System
Ed Hancock	Mountain Energy Partnership	Phone: (303) 517-8238 E-Mail: CEHancock3@aol.com	Data Acquisition System
Greg Barker	Mountain Energy Partnership	Phone: (303) 775-7646 E-Mail: GBARKER123@aol.com	Data Acquisition System
James Galvin	ESTCP Office	Phone: (571) 372-6397 E-Mail: james.j.galvin.civ@mail.mil	Energy and Water Program Manager



ESTCP Office

4800 Mark Center Drive
Suite 17D08
Alexandria, VA 22350-3605

(571) 372-6565 (Phone)

E-mail: estcp@estcp.org
www.serdp-estcp.org